

OFFICIAL USE ONLY – Predecisional Information



# STATE-OF-THE-ART REACTOR CONSEQUENCE ANALYSES

Office of Nuclear Regulatory Research  
Advisory Committee on Reactor Safeguards Briefing  
November 16, 2007

OFFICIAL USE ONLY-  
Predecisional Information

# Agenda

- Overview
- Process Review
- Preliminary Results of the Peach Bottom Atomic Power Station and Surry Power Station Assessments
  - Preliminary Findings
  - Sensitivity Analyses
  - Emergency Preparedness
  - Comparison with the 1982 Sandia Siting Study
- Commission Paper on Reporting Latent Cancer Fatalities
- Path Forward

## SOARCA Objectives

- Perform a state-of-the-art, realistic evaluation of severe accident progression, radiological releases and offsite consequences for dominant accident sequences
- Provide a more accurate assessment of potential offsite consequences to replace previous consequence analyses

OFFICIAL USE ONLY – Predecisional Information

# Severe Accident Improvements


- 25 years of national and international research
- Regulatory improvements reduced the likelihood of severe accidents
- Improved modeling capability
- Improvements in plant design
- Other plant improvements

OFFICIAL USE ONLY –  
Predecisional Information

OFFICIAL USE ONLY – Predecisional Information

# SOARCA OVERVIEW

## SOARCA PROCESS



OFFICIAL USE ONLY-  
Predecisional Information

# SOARCA Approach

- Full power operation
- Plant-specific sequences with a  $CDF \geq 10^{-6}$  ( $CDF \geq 10^{-7}$  for bypass events)
- External events included
- Consideration of all mitigative measures, including B.5.b
- Sensitivity analyses to assess the effectiveness of different safety measures
- State-of-the-art accident progression modeling based on 25 years of research to provide a best-estimate for accident progression, containment performance, time of release and fission product behavior
- More realistic offsite dispersion modeling
- Site-specific evaluation of public evacuation based on updated Emergency Plans
- Dose threshold for reporting latent cancer fatalities (5 rem in one year, 10 rem lifetime)

# SOARCA Insights

- Sequences dominated by external events, primarily large seismic events (PWR also includes bypass events)
- Previously used sequences have a significantly lower probability of occurrence or are not consider to be feasible
  - Alpha mode failure
  - High pressure melt through
  - ATWS
- B.5.b measures are effective at preventing core damage and containment failure

# SOARCA Preliminary Findings

- All events identified by the screening criteria (including bypass events) would be mitigated by B.5.b measures or, in some cases, by other plant systems
- Analyses were performed which confirmed effectiveness of mitigative measures
- Performed sensitivity analyses assuming no mitigative measures to further demonstrate the effectiveness of these mitigative measures and to provide results to compare with 1982 SNL Siting Study
- The analyses performed with and without mitigative measures resulted in significantly less severe consequences than the 1982 study



# Sequence Screening Process

## (Internal Events)

- Initial Screening - use enhanced SPAR models to screen out low CDFs initiating events with an overall CDF  $\leq 1.0E-7$  and sequences with a CDF  $< 1.0E-8$ . This step eliminates  $< 10\%$  of the overall CDF (typically about 5%)
- Sequence Evaluation – identify and evaluate the dominant cutsets for the remaining sequences ( $\sim 90\%$  of initiator CDF). Determine system and equipment availability / unavailability and accident sequence timing
- Scenario Grouping - group sequences together that have similar times to core damage and equipment unavailability
- Sequences selected refined by external events and mitigative measures assessments

# Sequence Screening Process

## (External Events)

- Identify dominant externally initiated event sequences (e.g., fire, seismic, flooding, wind) based upon available probabilistic risk assessment documentation from NUREG-1150, IPEEE submittals, as well as any additional / available supporting documentation
- Seismic margin assessments were excluded from this effort because they do not provide the required risk information
- Identified potential mapping between dominant external events and internally initiated events identified by the SPAR analysis
- Where mapping between external and internal events are not possible or appropriate, a unique externally initiated event or sensitivity study was recommended
- The resulting limited set of scenarios obtained for each SOARCA plant was used for subsequent accident progression and consequence analysis

## Containment Systems States

Identify the availability of engineered systems that can impact post-core damage containment accident progression, containment failure and radionuclide release

- Identify the anticipated availability of containment and containment support systems not considered in the Level 1 core damage analysis:
  - determine availability of front line system using cutset information
  - constructed a system dependency table showing the support systems required for performance of the target front line system
  - determine availability of front line system using engineering judgment
- Availability of systems such as low pressure injection that can impact containment accident progression (e.g. cooling debris in reactor cavity or cooling reactor vessel after core damage but prior to vessel failure) that were not evaluated in the Level 1 core damage analysis will be determined using engineering judgment

## Mitigative Measures Analysis

- The mitigative measures analyses are qualitative, sequence-specific systems and operational analyses based on licensee identified mitigative measures from EOPs, SAMGs, and other severe accident guidelines that are applicable to, and determined to be available during a sequence groupings whose availability, capability and timing will be utilized as an input into the MELCOR analyses

# Mitigative Measures Analysis Process

- For those dominating sequences / sequence groupings within the scope of SOARCA, applicable mitigative measures that are potentially available (not eliminated by initial conditions) are identify
- The staff performs systems and operations analyses based on the initial conditions and anticipated subsequent failures using applicable performance shaping factors to:
  - verify the availability of the primary system,
  - determine the availability of support systems and equipment
  - determine conservative time estimates for implementation
- The staff determines the anticipated availability, capability and the timing of implementation
- MELCOR will determine the effectiveness of those mitigative measures that are expected to be available at a given time

# Emergency Preparedness

- Techniques used to model EP was previously presented to ACRS
- Effort was successful in developing cohort data
  - Population
  - Evacuation timing
  - Travel speed
  - Roadway network
- Data was used in MACCS2 to develop consequence estimates
- Staff is considering assessing earthquake impact on EP through sensitivity analyses


## MACCS2 Assumptions

- Cancer detectability threshold for latent cancer fatalities
- No contaminated food or water consumed
- Latest federal guidelines used for dose conversion factors
- KI ingestion by half the 0 – 10 mile population, suboptimum timing
- Median values from US/CEC study of uncertainty for non-site specific parameter
- Site-specific population and meteorology
- Costs cost-of-living adjusted from NUREG-1150
- Projected dose during emergency period, 5 rem relocate in 1 day; 2 rem, 2 days
- Return criteria: 0.5 rem in 1 yr for Peach Bottom, 4 rem in 5 yr for Surry
- In general, 1-hr plume segments are used


# Structural Analyses Objective

Evaluating behavior of containment structures under severe accident conditions, and predicting the following performance criteria at the selected sites:

- Functional Failure Pressure - Leakage
- Structural Failure Pressure - Rupture
- Develop Leakage Rate and/or Leakage Area as a Function of Internal Pressure



**Peach Bottom "Mark I –  
Steel Containment"**



**Surry "Reinforced Concrete  
Containment"**




## Peach Bottom Mark I – Steel Cont.

### Approach:

- Review/reevaluate major failure criteria based on 25 years of research and testing performed by SNL and other organizations

### Result:


- The dominant cause for containment leakage is head flange bolt strain under gradually increasing internal pressure



OFFICIAL USE ONLY - Predecisional Information

# Peach Bottom Results

**Pressure vs. Area of Leakage at  
Peach Bottom (Mark I) Containment**



| P <sub>T</sub><br>(psig) | Area of<br>Leakage<br>(in <sup>2</sup> ) | Bolt<br>Elasticity |
|--------------------------|--|--------------------|
| 10                       | 0.00                                     | Elastic            |
| 15                       | 0.00                                     | Elastic            |
| 20                       | 0.00                                     | Elastic            |
| 25                       | 0.00                                     | Elastic            |
| 30                       | 0.00                                     | Elastic            |
| 40                       | 0.00                                     | Elastic, gasket    |
| 50                       | 0.00                                     | Elastic, gasket    |
| 60                       | 0.00                                     | Elastic, gasket    |
| 70                       | 0.00                                     | Elastic, gasket    |
| 80                       | 0.00                                     | Elastic, gasket    |
| 81                       | 0.46                                     | Elastic            |
| 82                       | 1.20                                     | Elastic            |
| 83                       | 1.94                                     | Elastic            |
| 84                       | 2.68                                     | Elastic            |
| 85                       | 3.41                                     | Elastic            |
| 90                       | 7.10                                     | Elastic            |
| 100                      | 14.48                                    | Elastic            |
| 120                      | 29.24                                    | Elastic            |

5%  
Relaxation  
of pre-load

P<sub>d</sub> = 56 psig

OFFICIAL USE ONLY -  
Predecisional Information

## Surry - Reinforced Concrete - Cont.

### Approach:

- Research of 25 years of analyses and testing on reinforced concrete containments support the hypothesis of “leak-before-break” failure mode. Therefore, it is expected that the range of pressure needed for catastrophic burst can never be reached -- leakage should prevent catastrophic burst.
- General behavior of concrete containment under gradually increasing internal pressure:
  - **First**, cracking of containment concrete.
  - **Second**, yielding of liner then tearing, and path(s) for leakage is/are created.
  - **Third**, yielding of hoop-reinforcement, and enlarging.
  - **Finally**, reinforced concrete containment structures are predicted to have significant leakage once the global strain levels are reached on the order of 1% to 2%.


OFFICIAL USE ONLY - Predecisional Information

# Evaluation of Reinforced Concrete Containment Structures

|   | Diablo Canyon | Salem    | Seabrook | Surry    |
|---|---------------|----------|----------|----------|
| Containment Radius Inside $R_c$ (ft)                        | 70.00         | 70.00    | 70.00    | 63.00    |
| Containment Volume $V_c$ (ft <sup>3</sup> )                 | 2.63E+06      | 2.62E+06 | 2.70E+06 | 1.80E+06 |
| Density $\rho$ - N <sub>2</sub> or air (#/ft <sup>3</sup> ) | 0.0752        | 0.0752   | 0.0752   | 0.0752   |
| Atmospheric Pressure $P_a$ (psia)                           | 14.70         | 14.70    | 14.70    | 14.70    |
| Liner Plate Thickness $t_L$ (inch)                          | 0.375         | 0.375    | 0.375    | 0.375    |
| % of Liner Plate $\rho_L = t_L / t_c$                       | 0.0089        | 0.0069   | 0.0069   | 0.0069   |
| Containment Shell Wall Thick $t_c$ (inch)                   | 42.00         | 54.00    | 54.00    | 54.00    |
| Hoop Rebar Area $A_r$ (in <sup>2</sup> /ft)                 | 14.12         | 15.644   | 20.364   | 18.777   |
| % of Hoop Rebar $\rho_H = A_r / t_c$                        | 0.028         | 0.024    | 0.031    | 0.029    |
| % of Total Steel $\rho_T = \rho_L + \rho_H$                 | 0.037         | 0.031    | 0.038    | 0.036    |
| Modulus of Elas. of Liner & Rebar (psi)                     | 3.00E+07      | 3.00E+07 | 3.00E+07 | 2.80E+07 |
| Containment Design Pressure $P_d$ (psig)                    | 47.00         | 47.00    | 65.00    | 60.00    |
| Liner Plate Yield Strength $S_{y-L}$ (psi)                  | 5.00E+04      | 5.00E+04 | 5.00E+04 | 3.20E+04 |
| Rebar Yield Strength $S_{y-r}$ (psi)                        | 7.00E+04      | 7.00E+04 | 7.00E+04 | 5.00E+04 |
| Rebar Strength @ 2% Strain $S_{2\%}$ (psi)                  | 7.50E+04      | 7.50E+04 | 7.50E+04 | 5.40E+04 |

OFFICIAL USE ONLY -  
Predecisional Information

# Surry - Reinforced Concrete - Cont.




| SURRY                     |         |                   |
|---------------------------|---------|-------------------|
| Pressure                  | $P/P_d$ | LR<br>(%Mass/Day) |
| $P = P_d = 60\text{psig}$ | 1.00    | 0.14%             |
| Liner @ $S_{y-L}$         | 1.37    | 10%               |
| Rebar @ $S_{y-r}$         | 1.99    | 13%               |
| 2% Strain                 | 2.13    | 62%               |
| 145 psig                  | 2.42    | 352%              |


OFFICIAL USE ONLY - Predecisional Information

# Surry Results

Surry Containment Performance:  
Leakage Area as a Function of Pressure Ratio Due to Average Air  
Sonic Velocity of 1,258<sup>ft/sec</sup>, and for Temperature Levels up to 300°F  
at Pressure Resisting Members




Surry Containment Performance:  
Leak Rate as a Function of Pressure Ratio  
at Temperature Levels up to 300°F



OFFICIAL USE ONLY -  
Predecisional Information

# SURRY - Reinforced Concrete - Cont



## SURRY Cont. Ref. Dwg.:

11448-FV-S1A  
11448-FV-1F  
11448-FM-1A  
11448-FM-1F  
11448-FV-IJ  
11448-FC-15G

# Peach Bottom Accident Sequences

- PRA models indicate core damage probability dominated by seismic event, which is functionally a long-term SBO ( $1 \times 10^{-6}$  to  $5 \times 10^{-6}$  /yr)
  - Fire and flood events would be similar in terms of core damage progression
- Internal events have frequencies  $< 10^{-6}$ /yr
  - Initially identified 1 sequence, Loss of Vital AC Bus E-12, as  $> 10^{-6}$ /yr; subsequently determined to be  $< 10^{-6}$ /yr
    - Notwithstanding, MELCOR analysis showed event to be mitigated without crediting B.5.b equipment
- Bypass events are of very low frequency:  $\sim 10^{-10}$ /yr



# Peach Bottom LTSBO

## Approach to MELCOR Analysis

- Perform MELCOR analysis crediting B.5.b equipment and procedures
  - Evaluate sufficiency of B.5.b measures to prevent environmental release
  - B.5.b measures were demonstrated to prevent core damage for LTSBO
- Perform MELCOR analysis without crediting B.5.b equipment and procedures
  - Understand value of mitigation strategies

## Peach Bottom LTSBO

- Loss of offsite and onsite AC power
- RCIC starts automatically
- Operator, by procedure, depressurizes at 1 hr
- Batteries exhausted at 4 hours
  
- Mitigated
  - Portable power supply ensures long-term DC to hold SRV open and provide level indication (allows management of RCIC)
- Unmitigated
  - After 4 hrs:
    - Open SRV recloses
    - RCIC terminates
    - No subsequent actions taken


## Peach Bottom LTSBO

- B.5.b mitigation
  - Portable power supply for SRV operation and reactor vessel level indication
    - Prevent excessive cycles on SRV
    - Provide level indication to manage injection
  - Manual control of RCIC without DC power
  - Portable diesel-driven pump (250 psi, 500 gpm) for makeup
  - Portable air supply to operate containment vent valves

~~OFFICIAL USE ONLY - Predecisional Information~~

# Peach Bottom LTSBO Pressure Response


## Successful Mitigation with Portable Equipment



~~OFFICIAL USE ONLY -  
Predecisional Information~~


# Peach Bottom LTSBO Level Response

## Successful Mitigation with Portable Equipment



# Peach Bottom LTSBO Pressure Response

## Successful Mitigation with Portable Equipment



# Peach Bottom LTSBO

## Successful Mitigation with Portable Equipment

- B.5.b equipment is sufficient to prevent core damage
  - No source term
  - No offsite health consequences


# Peach Bottom Mitigative Measures Sensitivity Analysis

- Long-term SBO – without B.5.b mitigation
  - Loss of offsite and onsite AC power
  - RCIC starts automatically
  - Operator, by procedure, depressurizes at 1 hr
  - Batteries exhausted at 4 hrs
- Accident progression
  - RCIC lost at 5 hrs
  - Core uncover in 9 hrs
  - Core damage in 10 hrs
  - RPV and containment failure in 20 hrs, start of radioactive release (liner melt-through)
  - Time from start of evacuation to radioactive release: ~17 hrs




# Peach Bottom LTSBO Pressure Response

## No Mitigation with Portable Equipment




# Peach Bottom LTSBO Level Response


## No Mitigation with Portable Equipment



## Peach Bottom LTSBO Containment Pressure Response No Mitigation with Portable Equipment




## Peach Bottom LTSBO Iodine Release and Transport No Mitigation with Portable Equipment



OFFICIAL USE ONLY – Predecisional Information

## Peach Bottom LTSBO Cesium Release and Transport No Mitigation with Portable Equipment



OFFICIAL USE ONLY -  
Predecisional Information

# Peach Bottom LTSBO

## No Mitigation with Portable Equipment

- Offsite radioactive release is small
  - 2 – 4 % release of volatiles, except noble gases
  - Release is much less severe than 1982 Siting Study (SST1)
- Accident progression timing and emergency evacuation significantly reduce potential consequences

# Peach Bottom LTSBO

## No Mitigation with Portable Equipment

- Comparison of consequences to 1982 Siting Study's SST1 release<sup>1</sup>

|                       | Early Fatalities (mean) | Latent Cancer Fatalities <sup>2</sup> (mean) |
|-----------------------|-------------------------|--|
| LTSBO (without B.5.b) | 0                       | 25   |
| 1982 Siting Study     | 92                      | 2700   |

1 Comparison not based on same assumptions, e.g., different EP model used

2 SOARCA used dose threshold (5 rem/year, 10 rem lifetime), 1982 Siting Study used LNT

## Peach Bottom Loss of Vital AC Bus E-12


- Initially identified as having  $CDF > 10^{-6}$ , subsequently determined to be  $< 10^{-6}$
- MELCOR analysis showed event to be mitigated without crediting B.5.b equipment




## Peach Bottom Loss of Vital AC Bus E-12

- Initiator: Loss of Div IV dc power resulting in
  - SCRAM, MSIV closure, containment isolation
  - RCIC automatically starts, 1 CRDHS pump active
- Operator actions (base case):
  - Load shed to maximize duration of DC power
  - Maximize flow from single CRDHS pump (B.5.b-related)
  - Depressurize RCS at 1.5 hours
  - Secure CRDHS from 4 – 7 hrs to prevent RPV overfill
- Sufficient to prevent core damage

# Peach Bottom Loss of Vital AC Bus E-12 Pressure Response



# Peach Bottom Loss of Vital AC Bus E-12 Level Response



## Peach Bottom Loss of Vital AC Bus E-12 Sensitivities

| Sensitivity  | RCIC duration | Maximize CRDHS flow <sup>1</sup> (B.5.b) | CRDHS off to prevent RPV overfill | Depressurize <sup>2</sup> (open SRV) | Repressurize (SRV closes) | Results              |
|--------------|---------------|--|-----------------------------------|--------------------------------------|---------------------------|----------------------|
| Baseline     | 4 hrs         | 1 hr                                     | 4.3 - 7 hrs                       | 1.5 hrs                              | 4 hrs                     | No CD                |
| CRD Flow     | "             | Not done                                 | "                                 | "                                    | "                         | No CD                |
| CRD Flow     | "             | Not done                                 | Not done                          | "                                    | "                         | No CD                |
| Battery life | 2 - 6 hrs     | Not done                                 | Not done                          | "                                    | 2 - 6 hrs                 | ≥3 hr life averts CD |
| Depressurize | 2 - 6 hrs     | Not done                                 | Not done                          | Not done                             | N/A                       | CD, no VF            |

<sup>1</sup> Increases CRHDS flow from 110 to 140 gpm

<sup>2</sup> Increases CRDHS flow from 110 to 180 gpm

Injection required to replace water lost by boiling at 4 hours ~150 gpm

# Peach Bottom Loss of Vital AC Bus E-12

## Insights

- Sufficient injection without B.5.b equipment to prevent core damage
  - SPAR does not credit CRDHS for coolant makeup
- RPV depressurization and maximizing CRDHS flow are important operator actions to optimize recovery
- SLC (50 gpm) also available for high pressure injection
- Battery duration is important

# Surry Accident Sequences

- Dominant PRA events
  - Long-term SBO ( $1 \times 10^{-5}$  to  $2 \times 10^{-5}$ /yr)
  - Short-term SBO ( $1 \times 10^{-6}$  to  $2 \times 10^{-6}$ /yr)
  - ISLOCA ( $7 \times 10^{-7}$ /yr)
  - SGTR ( $5 \times 10^{-7}$ /yr)
- SBO events are due to seismic, flooding and fire initiators, and are modeled as seismic event
  - Internal fire and internal flood events are less challenging, more mitigation available
- ISLOCA and SGTR are due to random equipment failures followed by operator errors

## Surry LTSBO

- Initial loss of AC power
- TD-AFW starts automatically to fill SGs
  - At 15 min, operator throttles flow to maintain normal level
- Open SG PORVs for 100 F/hr RCS cooldown
- Batteries exhaust at 8 hrs
- Mitigated
  - Portable equipment used to manage TD-AFW and make up for RCP seal leakage
- Unmitigated
  - After 5 hrs:
    - ECST empty
    - No subsequent actions taken

# Surry LTSBO

- B.5.b mitigation
  - Portable air bottles to operate SG PORVs
    - Depressurize and cooldown RCS
  - Portable power supply to restore SG and RCS level indication
  - Manual operation of TD-AFW without dc power
  - Portable diesel-driven high-pressure pump for injecting into the RCS
    - Makeup for RCP seal leakage
  - Portable diesel-driven low-pressure pump for refilling Emergency CST




OFFICIAL USE ONLY - Predecisional Information

# Surry LTSBO Pressure Response

## Successful Mitigation with Portable Equipment

Primary and Secondary Pressures  
LTSBO - Mitigation with Portable Equipment




OFFICIAL USE ONLY -  
Predecisional Information

OFFICIAL USE ONLY - Predecisional Information

# Surry LTSBO Level Response


## Successful Mitigation with Portable Equipment



OFFICIAL USE ONLY -  
Predecisional Information

# Surry LTSBO Seal Leakage vs Injection Response

## Successful Mitigation with Portable Equipment



## Surry LTSBO

- B.5.b mitigation is sufficient to prevent core damage
  - No source term
  - No offsite health consequences

# Surry Mitigative Measures Sensitivity Analysis


- Long-term SBO – without B.5.b mitigation
  - Loss of offsite and onsite AC power
  - TD-AFW starts automatically to fill SGs
    - At 15 min, operator throttles flow to maintain normal level
  - Open SG PORVs for 100 F/hr RCS cooldown
  - TD-AFW lost at 5 hours (Emergency CST empty)
  - Batteries exhaust at 8 hours
- Accident progression
  - Core damage at 16 hrs
  - Containment failure at 45 hrs (increased containment leakage)
  - Public evacuation begins at 2.5 hrs

~~OFFICIAL USE ONLY - Predecisional Information~~

# Surry LTSBO Pressure Response

## No mitigation with Portable Equipment

Primary and Secondary Pressures  
LTSBO - No Mitigation With Portable Equipment




~~OFFICIAL USE ONLY - Predecisional Information~~

OFFICIAL USE ONLY – Predecisional Information

# Surry LTSBO Level Response

## No mitigation with Portable Equipment




OFFICIAL USE ONLY -  
Predecisional Information

OFFICIAL USE ONLY – Predecisional Information

# Surry LTSBO Containment Pressure Response

## No mitigation with Portable Equipment




OFFICIAL USE ONLY-  
Predecisional Information



# Surry LTSBO Iodine Release and Transport


## No mitigation with Portable Equipment



OFFICIAL USE ONLY - Predecisional Information

# Surry LTSBO Cesium Release and Transport

## No mitigation with Portable Equipment



OFFICIAL USE ONLY -  
Predecisional Information

## Surry STSBO

- Loss of offsite and onsite AC and DC power
  - Mechanical failure of TD-AFW
  - No instrumentation or injection
- 
- |  |  |
|--|--|
| <ul style="list-style-type: none"><li>• Mitigated<ul style="list-style-type: none"><li>– At 8 hrs, portable pump connected to spray system</li></ul></li></ul> | <ul style="list-style-type: none"><li>• Unmitigated<ul style="list-style-type: none"><li>– No action taken</li></ul></li></ul> |
|--|--|

## Surry STSBO

- B.5.b mitigation
  - SG and RCS injection with portable pump may not be practical due to accident progression timing and earthquake severity
    - Core damage at 3 hrs
    - Reactor vessel lower head failure at 7 hrs
  - Portable pump (2000 gpm) assumed to be connected to containment spray system at 8 hrs

# Surry STSBO


- Emergency containment sprays
  - Portable pump assumed to run until containment filled to 1 m above the bottom of the vessel (1 million gallons)
  - Ex-vessel debris subsequently boils water in cavity
    - Late containment overpressure at 3 days
    - No airborne aerosol (only noble gas release to environment)
  - Better spray operation possible
    - Intermittent
    - More water

OFFICIAL USE ONLY - Predecisional Information

# Surry STSBO Pressure Response

## Mitigation with Portable Equipment

Primary and Secondary Pressures  
STSBO




OFFICIAL USE ONLY -  
Predecisional Information

OFFICIAL USE ONLY - Predecisional Information

# Surry STSBO Pressure Response

## Mitigation with Portable Equipment




OFFICIAL USE ONLY -  
Predecisional Information

OFFICIAL USE ONLY - Predecisional Information

# Surry STSBO Containment Pressure Response

## Mitigation with Portable Equipment




OFFICIAL USE ONLY -  
Predecisional Information



OFFICIAL USE ONLY - Predecisional Information

# Surry STSBO Iodine Release and Transport

## Mitigation with Portable Equipment




OFFICIAL USE ONLY -  
Predecisional Information

OFFICIAL USE ONLY - Predecisional Information

# Surry STSBO Cesium Release and Transport

## Mitigation with Portable Equipment



OFFICIAL USE ONLY -  
Predecisional Information

## Surry STSBO

- B.5.b mitigation is sufficient to prevent offsite release (except noble gases)
  - No early fatalities
  - No latent cancer fatalities


# Surry Mitigative Measures Sensitivity Analysis

- Short-term SBO – without B.5.b mitigation
  - Loss of offsite and onsite AC and DC power
  - Mechanical failure of TD-AFW
  - No indication or injection
- Accident progression
  - Core damage at 3 hrs
  - Containment failure at 25 hrs
  - Public evacuation begins at 2.5 hrs

OFFICIAL USE ONLY - Predecisional Information

# Surry STSBO Containment Pressure Response

## No Mitigation with Portable Equipment




OFFICIAL USE ONLY -  
Predecisional Information

OFFICIAL USE ONLY - Predecisional Information

# Surry STSBO Iodine Release and Transport

## No Mitigation with Portable Equipment




OFFICIAL USE ONLY -  
Predecisional Information

OFFICIAL USE ONLY - Predecisional Information

# Surry STSBO Cesium Release and Transport

## Mitigation with Portable Equipment



OFFICIAL USE ONLY -  
Predecisional Information

# Surry LTSBO and STSBO

## No Mitigation with Portable Equipment

- SBO sequences without B.5.b measures have relatively small releases, 1% or less of volatile radionuclides
- Comparison of consequences<sup>1</sup>

|                       | Early Fatalities (mean) | Latent Cancer Fatalities <sup>2</sup> (mean) |
|-----------------------|-------------------------|--|
| LTSBO (without B.5.b) | 0                       | 0  |
| STSBO (without B.5.b) | 0                       | 0  |
| 1982 Siting Study     | 45                      | 1300   |

**1** Comparison not based on same assumptions, e.g., different EP model used

**2** SOARCA used dose threshold (5 rem/year, 10 rem lifetime), 1982 Siting Study used LNT



## Surry SGTR

- Break of single tube
- Plant response
  - HPI, AFW initiate
  - Turbine stop valves close
  - Steam dump valves throttle and close
  - Faulted SG floods at 40 min
- Operator response
  - AFW delivery to faulted SG secured by operator on high level at 10 min

## Surry SGTR

- SPAR: Operator errors result in core damage
  - Fail to depressurize and cool down the RCS
  - Fail to refill RWST or cross-connect to unaffected unit's RWST
  - Fail to isolate faulted SG
- SOARCA mitigation measure review
  - Concluded that, within a couple of hours, the operators with assistance from TSC and EOF would correct errors

# Surry SGTR

## Mitigation Starts at 2.5 Hrs

- Assumed operator begins mitigation at 2.5 hrs
  - Operator recognizes SGTR occurred
    - SG floods at 40 min even though AFW is secured to that SG
  - Operator actions
    - Isolate faulted SG (close MSIV)
    - Secure HHSI
    - Initiate controlled cool-down (100 deg F/hr) utilizing intact SGs and steam dump valves
    - Enter RHR at 4 hrs
- MELCOR analysis showed no core damage

# Surry SGTR


## No Mitigation

- Accident progression
  - RWST empty at 11 hrs
  - ECST empty at 1.5 days
  - Core damage at 2 days

OFFICIAL USE ONLY - Predecisional Information

# Surry SGTR Pressure Response No Mitigation


Surry SGTR without Operator Action - System Pressures



OFFICIAL USE ONLY -  
Predecisional Information

# Surry SGTR Vessel Level Response No Mitigation

Surry SGTR without Operator Action - Reactor Vessel Level




OFFICIAL USE ONLY – Predecisional Information

# Surry SGTR RWST Inventory Response

## No Mitigation

Surry SGTR without Operator Action - RWST & ECST Inventories



OFFICIAL USE ONLY  
Predecisional Information

# Surry SGTR

## No Mitigation

- Sensitivity: SG PORV on faulted SG sticks open due to overfill and water passing through valve
  - Accident progression
    - RWST empty at 9 hours
    - Core damage at 1 day



## Surry SGTR – Insights

- MELCOR analysis indicates that operators and others (TSC, EOF) have time to correct errors
  - Event can be mitigated with installed (non-B.5.b) equipment
  - Other mitigation options exist
    - Refill RWST or cross-connect to unaffected unit's RWST
    - Use B.5.b pumps to feed RCS and steam generators
- Unmitigated cases have 1 to 2 day delay until core damage
  - Suggests unmitigated case is unrealistic

## Surry ISLOCA

- Failure of LPI check valves' disks resulting in LPI pipe break in Safeguards Bldg
- Plant response
  - HPI, LPI, AFW initiate
  - 2/3 of HPI goes into cold legs, 1/3 goes out break
  - LPI pumps stop due to Safeguards Bldg flooding
    - Subsequently, RWST gravity drains through break
- Operator response
  - Per procedures, secure 1 HPI pump at 15 min
  - Shift HPI to hot legs at 45 min
  - Open SG PORVs for 100 F/hr RCS cooldown

## Surry ISLOCA

- SPAR: Operator error results in core damage
  - Fail to refill RWST or cross-connect to unaffected unit's RWST
- SOARCA mitigation measure review
  - Concluded that, within a couple of hours, the operators with assistance from TSC and EOF would recognize the need to cross-connect to unaffected unit's RWST


# Surry ISLOCA

## Mitigation with Unaffected Unit's RWST

- Operator begins mitigation at 1.75 hours
  - Operator recognizes ISLOCA occurred
    - Flooding in Safeguards Building and Auxiliary Building
    - Initiation of safety injection
  - Cross-connect to unaffected unit's RWST at 1.75 hrs
  - Start RHR cooling at 6 hrs
- MELCOR analysis showed no core damage

~~OFFICIAL USE ONLY – Predecisional Information~~

# Surry ISLOCA Geometry Schematic




~~OFFICIAL USE ONLY – Predecisional Information~~

OFFICIAL USE ONLY - Predecisional Information

# Surry ISLOCA Pressure Response

## Mitigation with Unaffected Unit's RWST

Primary and Secondary Pressures  
ISLOCA




OFFICIAL USE ONLY -  
Predecisional Information

OFFICIAL USE ONLY – Predecisional Information

# Surry ISLOCA Level Response

## Mitigation with Unaffected Unit's RWST




OFFICIAL USE ONLY  
Predecisional Information

OFFICIAL USE ONLY - Predecisional Information

# Surry ISLOCA ECCS Flow Response

## Mitigation with Unaffected Unit's RWST




OFFICIAL USE ONLY -  
Predecisional Information



OFFICIAL USE ONLY – Predecisional Information

# Surry ISLOCA Level Response

## Mitigation with Unaffected Unit's RWST




OFFICIAL USE ONLY –  
Predecisional Information

OFFICIAL USE ONLY - Predecisional Information

# Surry ISLOCA RWST Level Response

## Mitigation with Unaffected Unit's RWST



OFFICIAL USE ONLY -  
Predecisional Information

# Surry ISLOCA


## No Mitigation with Unaffected Unit's RWST

- Accident progression
  - RWST empty at 3 hrs
    - Assumes double-ended break of LHI pipe, resulting in gravity draining the RWST through the break in 3 hours
  - Release starts at 10 hrs
    - Release is scrubbed by water over break

OFFICIAL USE ONLY - Predecisional Information

# Surry ISLOCA Pressure Response

## No Mitigation with Unaffected Unit's RWST




OFFICIAL USE ONLY -  
Predecisional Information

OFFICIAL USE ONLY - Predecisional Information

# Surry ISLOCA Level Response

## No Mitigation with Unaffected Unit's RWST




OFFICIAL USE ONLY -  
Predecisional Information

OFFICIAL USE ONLY - Predecisional Information

# Surry ISLOCA RWST Level Response

## No Mitigation with Unaffected Unit's RWST




OFFICIAL USE ONLY -  
Predecisional Information

OFFICIAL USE ONLY - Predecisional Information

# Surry ISLOCA Iodine Release and Transport


## No Mitigation with Unaffected Unit's RWST



OFFICIAL USE ONLY -  
Predecisional Information

# Surry ISLOCA Cesium Release and Transport

## No Mitigation with Unaffected Unit's RWST





# Surry ISLOCA

- Insights
  - MELCOR analysis indicates that operators and others (TSC, EOF) have time to correct errors
    - Event can be mitigated with installed (non-B.5.b) equipment
    - Other mitigation options exist
      - Use B.5.b pumps to feed RCS and steam generators
  - Unmitigated case has scrubbed release
    - Suggests small offsite health consequences
    - Offsite consequence analysis ongoing

## Summary

- Peach Bottom LTSBO
  - Turbine-driven system (RCIC) and B.5.b prevent core damage
  - Without B.5.b
    - No early fatalities
    - 25 latent cancer fatalities
- Surry LTSBO
  - Turbine-driven system (AFW) and B.5.b prevent core damage
  - Without B.5.b
    - No early fatalities
    - No latent cancer fatalities
- Surry STSBO
  - B.5.b emergency containment spray prevents environmental release (except noble gases)
  - Without B.5.b
    - No early fatalities
    - No latent cancer fatalities

## Summary

- Peach Bottom and Surry SBO scenarios
  - B.5.b provides an additional layer of injection capability
  - Sufficient time to implement B.5.b equipment
  - Accident progression timing (long time to core damage and containment failure) and mitigative measures significantly reduce the potential for core damage and/or containment failure

## Summary

- Surry SGTR
  - Installed systems (HPI, AFW, RWST) sufficient to prevent core damage
  - Assuming no mitigation results in 1 – 2 day delay until core damage
    - Unrealistic to assume operators delay this long
- Surry ISLOCA
  - Installed systems (HPI, unaffected unit's RWST) sufficient to prevent core damage
    - MELCOR analysis shows 3 hours until RWST depleted
      - More time available if LHI pipe break is smaller than double-ended
  - Assuming no mitigation with unaffected unit's RWST
    - Release scrubbed by water over break
- Surry bypass scenarios
  - Accident progression timing (long time to core damage) and mitigative measures significantly reduce the potential for core damage and/or containment failure
  - Additional injection capability provided by B.5.b equipment not necessary

# Reporting Latent Cancer Fatalities

- Commission Paper – Notation Vote
- Options
  - Range of thresholds (0 – 5 rem)
  - Linear no threshold (LNT)
  - Estimate point value from Health Physics Society
    - 5 rem in one year, 10 rem in a life time
- Staff Analysis
  - Estimate point value from Health Physics Society
    - 5 rem in one year, 10 rem in a life time
- In staff review

## Status of Pilot Plants

- Peach Bottom, Surry and Sequoyah volunteered
- Recommend completing Peach Bottom and Surry, publishing the results, then solicit additional volunteers
  - Dialogue with stakeholders and potential volunteers
  - Solicit additional volunteers

# SOARCA SCHEDULE

- SOARCA Initial Results September 2007
- Additional SOARCA Analyses December 2008
  - 1 additional plant
  - Finalize initial results
  - Source term uncertainty analysis
  - Additional sensitivity analyses
  - Peer review
- SOARCA Analyses (up to 5 additional plants) TBD