


OFFICIAL USE ONLY



**U.S.NRC**

UNITED STATES NUCLEAR REGULATORY COMMISSION

*Protecting People and the Environment*

# **State-of-the-Art Reactor Consequence Analyses (SOARCA)**

ACRS Regulatory Policy and Practices

Sub-Committee Closed Meeting

July 10, 2007

OFFICIAL USE ONLY

2/13

OFFICIAL USE ONLY

# SOARCA

## ACRS Subcommittee Closed Meeting

### Agenda

- Sequence Selection - Initial Findings
- Preliminary Accident Progression Insights
- Structural Analyses
- Emergency Preparedness
- Latent Cancer Fatality Dose Response Model

OFFICIAL USE ONLY

~~OFFICIAL USE ONLY~~

# **SOARCA**

## **Preliminary Accident Sequence Selection**

Richard Sherry

~~OFFICIAL USE ONLY~~

OFFICIAL USE ONLY

# Peach Bottom Internal Event Sequence Groups

Sequence Group	CDF (per year)	Dominant Outlets
1	Mid $10^{-7}$	Reactor transients and failures of HPCI/RCIC (pump/hardware failures, DC power failures) and RCS depressurization (power switch failure, DC power failure, or operator error).
2	Low $10^{-7}$	Reactor transients with 2 or more stuck-open SRVs and the failure of LPI (operator error, hardware failures).
3	High $10^{-8}$	Loss of vital AC Bus 'E12' with failure of SPC/SDC (operator error, hardware failures), operators fail to recover PCS, containment failure (due to initiator failing CVS), and late injection (containment failure). <b>HPCI/RCIC and RCS depressurization are successful.</b>
4	Mid $10^{-8}$	Reactor transients with failure of RPS (ATWS).
5	Mid $10^{-8}$	Inadvertent open relief valve with failure of PCS (due to initiator), CRD (pump failure, operator error) and failure of LPI/Alternate Injection (operator error). <b>HPCI/RCIC are successful.</b>
6	Low $10^{-8}$	SLOCA with failure of PCS (due to initiator) and operator failure to start/control late injection. <b>HPCI/RCIC and SPC are successful.</b>
7	Low $10^{-8}$	Loss of offsite power and failures of HPCI/RCIC (pump/hardware failures, operator error) and LPI/alternate injection (operator error). <b>RCS depressurization is successful.</b>
8	Low $10^{-8}$	Station blackout (FTR, TM, FTS, CCF) with failure of operators to restore power to a vital bus prior to battery depletion (2 hours).
9	Low $10^{-8}$	Loss of offsite power and failures of SPC (operator error) and LPI/alternate injection (operator error). <b>HPCI/RCIC and RCS depressurization are successful.</b>
10	Low $10^{-8}$	Loss of offsite power and failures of SPC (operator error) and RCS depressurization (operator error). <b>HPCI/RCIC are successful.</b>
Total CDF =	Low $10^{-7}$	The dominant sequence groups account for 98% of the total CDF.

OFFICIAL USE ONLY

# Peach Bottom Dominant External Sequence Group Summary Containment Systems Status

## EE-1 – EE (Seismic) Initiated Long Term SBO

**Representative Frequency:** 1E-6 to 5E-6/RY

**Sequence Summary:** LOOP and SBO occurs due to a seismic or internal fire event; HPCI available initially until loss of room cooling and/or battery depletion renders it inoperable; containment cooling functions are inoperable; containment is isolated; recovery of offsite power is not expected during the mission time.

SYSTEM STATUS SUMMARY		
System/Function	Status	Notes
PCS	Not Available	Loss of AC Power
ADS	Available	
SRVs	Not Failed	
HPCI	Available	
RCIC	Not Available	Seismic Initiator
CRD	Not Available	Loss of AC Power
SPC	Not Available	Loss of AC Power
Containment Spray.	Not Available	Loss of AC Power
LPCI	Not Available	Loss of AC Power
LPCS	Not Available	Loss of AC Power
Containment Vent	Not Available	
SDC	Not Available	Loss of AC Power

~~OFFICIAL USE ONLY~~

~~OFFICIAL USE ONLY~~

# Surry Internal Event Sequence Groups

Sequence Group	CDF (per year)	Dominant Event Description
1	High $10^{-7}$	Loss of offsite power with EDG/SWS unavailabilities cause a loss of RCP seal cooling, subsequent failure of RCP seals (due to Stage 1 and/or Stage 2 binding/popping or o-ring extrusion), and the failure of HPI. Operators fail to restore offsite power within 2 hours. The dominant sequence in this group indicates a RCP seal leak rate of 182 gpm that will initiate within 13 minutes of the loss of seal cooling.
2	Mid $10^{-7}$	SGTR with operators failing to isolate the faulted SG or cooldown and depressurize the reactor and failing to initiate long term heat removal (SGTR Procedure ECA 3.1/3.2). SPAR Model assumes that operators fail to refill the RWST given the previous operator failures.
3	Mid $10^{-7}$	ISLOCA (non-recoverable) from the LPI pipe.
4	Mid $10^{-7}$	Station blackout (FTR dominant) with failure of operators to recover power to a vital bus prior to battery depletion (4 hours).
5	Low $10^{-7}$	Reactor transient with failure of RPS (ATWS). Most of this sequence group's CDF is due to an ATWS with failure to limit RCS pressure <3200 psi.
6	Low $10^{-7}$	ISLOCA from the RHR letdown line (non-recoverable or operators fail to recover). This ISLOCA sequence does not bypass containment.
7	Low $10^{-7}$	Station blackout (FTR dominant) cause a loss of RCP seal cooling, subsequent failure of RCP seals (Stage 2 binding/popping). Operators fail to restore power to a vital bus within 4 hours.
8	Mid $10^{-7}$	Reactor transients with AFW unavailabilities lead to failure of all feedwater and feed and bleed.
9	Mid $10^{-7}$	MLOCA with failure of HPR.
10	Mid $10^{-7}$	SLOCA with RHR/CSR unavailable.
11	Mid $10^{-7}$	SLOCA with failure of HPI and secondary side cooling.
12	Mid $10^{-7}$	Station blackout (FTR dominant) with operator failure to cooldown RCS to <1720 psi within two hours causes a loss of RCP seal cooling, subsequent failure of RCP seals (Stages 1 and 2 o-ring extrusion). Operators fail to restore power to a vital bus within 2 hours.
13	Mid $10^{-7}$	SGTR with RHR failures (operator and hardware) and operator failure to refill CST.
Total CDF	Low $10^{-7}$	The dominant sequence groups account for 95% of the total CDF.

~~OFFICIAL USE ONLY~~

OFFICIAL USE ONLY

# Surry Dominant Internal Sequence Group Summary Containment Systems Status

## IE-1 – Steam Generator Tube Rupture (SGTR)

**Representative Frequency:** 5E-7/R Y

**Sequence Summary:** SGTR with operators failing to isolate the faulted SG or cooldown and depressurize the reactor and failing to initiate long term heat removal. Operators fail to refill the RWST given the previous operator failures.

SYSTEM STATUS SUMMARY		
System/Function	Status	Notes
HPI	Available Until RWST Depleted	
LPI	Available Until RWST Depleted	
HPR	Not Available	No Water in Containment Sump
LPR	Not Available	No Water in Containment Sump
PORVs	Available	
AFW	Available	
Containment Spray Inject.	Available Until RWST Depleted	
Containment Spray Recirc.	Not Available	No Water in Containment Sump
Cont. Spray HX	Not Available	No Water in Containment Sump
Fan Coolers	Not Available	
Accumulators	Available	

OFFICIAL USE ONLY

~~OFFICIAL USE ONLY~~

# Surry Dominant Internal Sequence Group Summary Containment Systems Status

## IE-2 – Interfacing Systems LOCA (Low Pressure Injection System)

**Representative Frequency:** 7E-7/RV

**Sequence Summary:** Failure of two check valves in series in the discharge path of the LPI system. Rupture of LPI low pressure piping. Inability to isolate rupture location. Failure of injection upon RWST depletion.

SYSTEM STATUS SUMMARY		
System/Function	Status	Notes
HPI	Available Until RWST Depleted	
LPI	Failed by rupture of LPI piping	
HPR	Not Available	No Water in Containment Sump
LPR	Not Available	No Water in Containment Sump
PORVs	Available	
AFW	Available	
Containment Spray Inject.	Available Until RWST Depleted	
Containment Spray Recirc.	Not Available	No Water in Containment Sump
Cont. Spray HX	Not Available	No Water in Containment Sump
Fan Coolers	Not Available	
Accumulators	Available	

~~OFFICIAL USE ONLY~~



~~OFFICIAL USE ONLY~~

# Surry Dominant External Sequence Group Summary Containment Systems Status

## EE-1 – EE (Seismic/Flooding) Initiated Long Term SBO

**Representative Frequency:** 1E-5 to 2E-5/RY

**Sequence Summary:** LOOP and SBO occurs due to an internal flooding or seismic event; TDAFW pump available initially. RCP seal LOCA may occur; containment cooling functions are inoperable; late core damage occurs; containment is isolated; recovery of offsite power is not expected during the mission time.

SYSTEM STATUS SUMMARY			
System/Function	Status	Notes	
HPI	Not Available		
LPI	Not Available		
HPR	Not Available		
LPR	Not Available		
PORVs	Available		
AFW	TDAFW Available Early	Until loss of DC power	
Containment Spray Inject.	Not Available		
Containment Spray Recirc.	Not Available		
Cont. Spray HX	Not Available		
Fan Coolers	Not Available		
Accumulators	Available		

~~OFFICIAL USE ONLY~~

OFFICIAL USE ONLY

# Surry Dominant External Sequence Group

## Summary Containment Systems Status

### EE-2 – EE (Seismic/Flooding) Initiated Short Term SBO

**Representative Frequency:** 1E-6 to 2E-6/RY

**Sequence Summary:** LOOP and SBO occurs due to an internal flooding, seismic or internal fire event; ATWS or failure of AFW system causes early core damage; containment cooling functions are inoperable; containment is isolated; recovery of offsite power is not expected during the mission time.

SYSTEM STATUS SUMMARY			
System/Function	Status	Notes	
HPI	Not Available		
LPI	Not Available		
HPR	Not Available		
LPR	Not Available		
PORVs	Available		
AFW	Not Available		
Containment Spray Inject.	Not Available		
Containment Spray Recirc.	Not Available		
Cont. Spray HX	Not Available		
Fan Coolers	Not Available		
Accumulators	Available		

OFFICIAL USE ONLY

# Sequence Selection Summary Peach Bottom and Surry

- Total IE CDFs in low to mid  $10^{-6}$  range for both Surry and Peach Bottom
- External event initiated sequences have estimated CDFs that are greater than internally initiated sequences

OFFICIAL USE ONLY

# **SOARCA**

## **Preliminary Accident Progression Insights**

Jason Schaperow

OFFICIAL USE ONLY

# Peach Bottom – Sequences

- Internal events
  - None ( $<10^{-6}$ ); ISLOCA  $\sim 10^{-10}$
- External events
  - Long-term station blackout

OFFICIAL USE ONLY

# Long-term Station Blackout

## (Peach Bottom)

- AC power fails
- High pressure injection available via HPCI (turbine-driven system) until battery depletion
- Event chronology affected by battery life
  - Battery needed to hold SRV open and to control injection
  - Battery life depends on age of batteries and effectiveness of load shedding (2 to 8 hrs w/o load shed)
- Options for mitigation
  - Manual operation of HPCI after battery depletion
  - Use portable generator to hold SRV open after battery depletion
  - Inject with portable pump (500 gpm at 250 psi)
- Mitigation to prevent core damage appears feasible

OFFICIAL USE ONLY


# Preliminary MELCOR Examination of Accident Progression and PRA Success Criteria

(Peach Bottom)

- Loss of vital AC bus E-12 (initially identified as risk-important, later judged to be below the  $10^{-6}$ /ry CDF threshold)
  - Loss of AC power to DC inverters
  - Available: Turbine-driven systems, CRDHS, SRV, LPI
  - EOPs direct operators to maintain level with RCIC and begin controlled depressurization
  - Event chronology affected by battery life
- MELCOR analysis of CRD effectiveness
  - Detailed T/H analyses of specific cutsets reveal margins to core damage and substantial margins on vessel failure
  - Not a significant “release” sequence as suggested by simplified PRA criterion
- Additional available mitigation
  - Increased CRD flow (140 gpm) , SLC injection (50 gpm)
  - Manual control of RCIC
  - EDMG portable generator and pump

OFFICIAL USE ONLY

# MELCOR Analysis of CRD Effectiveness



OFFICIAL USE ONLY



OFFICIAL USE ONLY

# Preliminary Insight

## (Peach Bottom)

- Scenarios initially identified involve loss of AC power to key plant equipment
- Scenarios evolve slowly
  - Availability of DC power extends time to onset of core damage
  - Battery lifetime is an important assumption
- Mitigation may prevent core damage
  - PRA success criteria appear conservative with respect to effectiveness of CRDHS
    - Best-estimate calculations will likely demonstrate outcome does not lead to core damage
  - Manual intervention with installed and portable equipment could prevent or limit extent of core damage

OFFICIAL USE ONLY

# Surry – Sequences

- Internal events
  - Low head injection ISLOCA
  - Spontaneous SGTR
- External events
  - Long-term station blackout
  - Short-term station blackout

# Low head injection ISLOCA (Surry)

- Low-head-injection inboard isolation check valves (2) disc failure
  - Check valves in 6" pipe with a venturi.
- Exposure of low pressure piping in Safeguards Building to RCS pressure assumed to result in leak outside containment
- Mitigation
  - High head injection is available, 3 pumps at 150 gpm/pump
  - Leak location may be underwater (scrubbing)
- Mitigation using installed equipment appears sufficient to prevent core damage, PRA appears to not credit operator actions in the long term
- Portable generator and pumps available, if needed

OFFICIAL USE ONLY

# Spontaneous SGTR

## (Surry)

- Operators fail to diagnose tube rupture and follow procedure resulting in pumping the RWST inventory into the RCS and out through the ruptured tube
- Timing associated with this scenario is long
  - 14 hrs to deplete RWST, assuming 450 gpm injection
  - Have cross-tie to other unit's RWST
- Mitigation
  - Additional crews of operators, TSC, EOF, and NRC Ops Center
  - All plant systems are available
  - Once RCS pressure drops sufficiently (AFW, RHR)
- Mitigation appears to be sufficient to prevent core damage, PRA appears to not credit operator actions in the long term
- Portable generator and pumps available, if needed

OFFICIAL USE ONLY

# Long-term Station Blackout

## (Surry)

- AC power fails
- TD-AFW removes decay heat until RCS water level drops due to RCP seal leakage (preventing adequate convection of heat from core to SGs)
- TD-AFW
  - Battery used to indicate SG level and control TD-AFW
  - Licensee PRA has a conservative estimate of 8 hours for battery life – requested licensee provide realistic estimate
  - Once battery depleted, manually control TD-AFW and restore level indication with portable generator
- RCP seal leakage
  - Leakage estimated at 21 gpm/pump
  - Increased leakage possible when seals subjected to high temperatures – research planned to estimate seal failure timing
  - Make up for leakage with portable pump and restore level indication with portable generator
- Mitigation to prevent core damage appears feasible

# Short-term Station Blackout (Surry)

- AC and DC power fails
- Flooding/fire
  - TD-AFW automatically starts and runs at design speed
    - Operators take manual control to prevent SG overfill
  - Make up for RCP leakage with portable pump
- Seismic
  - Direct mechanical failure of TD-AFW
    - Limiting scenario in terms of timing
  - Evaluating availability of portable pumps and portable generator

~~OFFICIAL USE ONLY~~

# Preliminary Insight (Surry)

- Scenarios identified have long times until core damage and release to the environment
  - Fastest scenario identified is seismic-induced loss of AC and DC power with direct mechanical failure of TD-AFW
- Mitigation may prevent core damage for some scenarios
  - PRA success criteria for preventing core damage appear conservative with respect to crediting installed equipment and operator actions
  - Time to deploy portable equipment appears sufficient to prevent core damage when installed equipment not available

~~OFFICIAL USE ONLY~~

OFFICIAL USE ONLY

# **SOARCA**

## **Structural Analyses**

Ata Istar

OFFICIAL USE ONLY



# OBJECTIVE

Perform Structural Evaluation of Containments to  
Determine the following:

- Functional Failure Pressure - Leakage
- Structural Failure Pressure - Rupture
- Develop Leakage Rate and/or Area as a Function of Internal Pressure

# Peach Bottom (Mark I – Steel)

## Background:

- Considerable Variation in Predicting Failure Pressure Levels and Locations in Numerous Studies were Performed Previously
- Failure Pressure Varies between 195 to 86 psig at various Temperature Levels
- Failure Locations:
  - Drywell Shell Melt-Through
  - Wet Well Rapture
  - Equipment Hatch Leakage
  - Bellow Failure
  - Penetrations Failure
  - Seismic Stabilizer Punch-Through of Drywell Shell
  - Drywell Head Flange Leakage

~~OFFICIAL USE ONLY~~

# Peach Bottom (Mark I – Steel)

## Approach:

- Review/Reevaluate Major Failure Criteria Based on the 25 Years of Research and Testing Carried out at SNL and other Reports


## Result:

- Based on the Plant Specific Information The Most Dominant Containment Cause for Leakage is Determined to be at Drywell Head Flange

~~OFFICIAL USE ONLY~~

OFFICIAL USE ONLY

# Dry-Well Top Flange Assembly




OFFICIAL USE ONLY



OFFICIAL USE ONLY

# Result

**Pressure vs. Area of Leakage at  
Peach Bottom (Mark I) Containment**



Pressure (psig)	Area of Leakage (in <sup>2</sup> )	Material Elasticity
10	0.00	Elastic
15	0.00	Elastic
20	0.00	Elastic
25	0.00	Elastic
30	0.00	Elastic
40	0.00	Elastic, gasket
50	0.00	Elastic, gasket
60	0.00	Elastic, gasket
70	0.00	Elastic, gasket
80	0.00	Elastic, gasket
81	0.46	Elastic
82	1.20	Elastic
83	1.94	Elastic
84	2.68	Elastic
85	3.41	Elastic
90	7.10	Elastic
100	14.46	Elastic
120	29.24	Elastic

5%  
Relaxation  
of Pre-load

$P_d = 56 \text{ psig}$

OFFICIAL USE ONLY

# Surry

## (PWR – Reinforced Concrete)

### Approach:

- Research of 25 years of Analyses and Testing on Reinforced Concrete Containment Support the Hypothesis of “Leak-Before-Break” Failure Mode for Reinforced Concrete Containment Structures

Therefore, it is Expected that the Range of Pressure Needed for Catastrophic Rupture/Burst can never be Reached, since Leakage should Prevent Catastrophic Rupture/Burst

# Surry

## (PWR – Reinforced Concrete)

### Approach cont.:

- General Behavior of Concrete Containment under Gradual Increasing Internal Pressure:
  - first, Cracking of Containment Concrete
  - second, Yielding of Liner then Tearing, and Path(s) for Leakage is/are Created
  - third, Yielding of Hoop-Reinforcement, and Enlarging
  - finally, Reinforced Concrete Containments Structures are Predicted to have Significant Leakage (Rupture Like) once the Global Strain Levels are Reached on the order of 1% to 2%



# 1:6 Scale Reinforced Concrete Model Evaluation per NUREG/CR-5121

## Approach cont.:

- Following Simplified Approach was Used to Determine Behavior of the Existing Reinforced Concrete PWR Containments in the USA. Results of Simplified Approach are quite Consistent with Detailed Analytical Analyses Performed:

$$P_{fail} = (A_{hoop} * S_{rebar@2\%} + A_{liner} * S_{liner@2\%}) / R$$

$$P_{yield} = (A_{hoop} * S_{rebar} + A_{liner} * S_{liner}) / R$$

Where:


$P_{fail}$  = Containment failure pressure,  
 $P_{yield}$  = Containment pressure at which hoop rebars and liner plate yield,  
 $A_{hoop}$  = Area of the hoop rebars,  
 $A_{liner}$  = Area of the liner plate,  
 $Y_{rebar}$  = Yield stress of the rebar,  
 $Y_{liner}$  = Yield stress of the liner plate,  
 $S_{rebar@2\%}$  = Stress in the rebar at 2% strain,  
 $S_{liner@2\%}$  = Stress in the liner at 2% strain,  
 $R$  = Radius of the containment.

# Comparison of 1:6 Scale Reinforced Concrete Model Evaluation per NUREG/CR-5121

Source	Pressure at Rebar+Liner (psig)	Pressure at 2% Strain (psig)
Round Robin Analysis (Max)	138	185
Round Robin Analysis (Min)	120	128
Round Robin Analysis (Ave)	126	156
Test Data	120	145

OFFICIAL USE ONLY

# 1:6 Scale Reinforced Concrete Model Evaluation per NUREG/CR-5121



OFFICIAL USE ONLY

~~OFFICIAL USE ONLY~~

# 1:6 Scale Reinforced Concrete Model Evaluation per NUREG/CR-5121

Relating Internal Pressure Levels of 1:6 Scale  
Model of Concrete Containment Structure to  
Leak Rates Measured during Testing.


$$V = 10,890 \text{ ft}^3$$

P (psig)	P/P <sub>d</sub>	Leak Rate (% Mass / Day)	Leak Rate (SCFM)	Leak Rate (% Vol. / Day)
37	0.80	0.0%	0.0	0.00%
46	1.00	0.14%	0.04	0.55%
135	2.93	10%	6	87%
140	3.04	13%	10	130%
142	3.09	62%	49	653%
144	3.13	243%	199	2,446%
145	3.15	352%	285	3,765%

~~OFFICIAL USE ONLY~~

OFFICIAL USE ONLY

# 1:6 Scale Reinforced Concrete Model Evaluation per NUREG/CR-5121




OFFICIAL USE ONLY

# Evaluation of Selected Reinforced Concrete Containment Structures

		Diablo Canyon	Salem	Seabrook	Surry
Containment Radius Inside $R_c$ (ft)		70.00	70.00	70.00	63.00
Containment Volume $V_c$ (ft <sup>3</sup> )		2.63E+06	2.62E+06	2.70E+06	1.80E+06
Density $\rho$ – N <sub>2</sub> or air (#/ft <sup>3</sup> )		0.0752	0.0752	0.0752	0.0752
Atmospheric Pressure $P_a$ (psia)		14.70	14.70	14.70	14.70
Liner Plate Thickness $t_L$ (inch)		0.375	0.375	0.375	0.375
% of Liner Plate $\rho_L = t_L / t_c$		0.0089	0.0069	0.0069	0.0069
Containment Shell Wall Thick $t_c$ (inch)		42.00	54.00	54.00	54.00
Hoop Rebar Area $A_r$ (in <sup>2</sup> /ft)		14.12	15.644	20.364	18.777
% of Hoop Rebar $\rho_H = A_r / t_c$		0.028	0.024	0.031	0.029
% of Total Steel $\rho_T = \rho_L + \rho_H$		0.037	0.031	0.038	0.036
Modulus of Elas. of Liner & Rebar $E$ (psi)	3.00E+07	3.00E+07	3.00E+07	3.00E+07	2.80E+07
Containment Design Pressure $P_d$ (psig)		47.00	47.00	65.00	60.00
Liner Plate Yield Strength $S_{yL}$ (psi)	5.00E+04	5.00E+04	5.00E+04	5.00E+04	3.20E+04
Rebar Yield Strength $S_{yR}$ (psi)	7.00E+04	7.00E+04	7.00E+04	7.00E+04	5.00E+04
Rebar Strength @ 2% Strain $S_u$ (psi)	7.50E+04	7.50E+04	7.50E+04	7.50E+04	5.40E+04

# Surry (PWR – Reinforced Concrete)



SURRY		
Pressure	P/P <sub>d</sub>	LR <sub>%Mass/Day</sub>
P = P <sub>d</sub> = 60 psig	1.00	0.14%
Liner @ S <sub>y-L</sub>	1.37	10%
Rebar @ S <sub>y-r</sub>	1.99	13%
2% Strain	2.13	62%
145 psig	2.42	352%

# FOLLOW-UP CONSIDERATIONS

Other Potential Effects that are not well defined are to be Incorporated for “Containment Performance / Capacity” Evaluations by Adhering to sound Engineering Judgments:

- Predicting Structural Capacity Band ( $\pm$ )
- Predicting Effects of Temperature Extremes ( $>400^{\circ}\text{F}$ )
- Predicting Effects of Degradation (e.g.; corrosion)
- Predicting Effects of Aging (e.g.; radiation effect)
- Effects of Original Construction Defects (if any)




OFFICIAL USE ONLY

# FOLLOW-UP CONSIDERATIONS

(SNL Performance Model Presentation, June 2004)

Effects of Temperature, Degradation:



OFFICIAL USE ONLY

OFFICIAL USE ONLY

# **SOARCA**

## **Emergency Preparedness**

Joseph Jones

OFFICIAL USE ONLY

~~OFFICIAL USE ONLY~~

# Peach Bottom

- Preliminary model developed
- Based on Long Term Station Black Out scenario
- General Emergency is declared about 2 hours after loss of all A/C power
  - Evacuation starts at General Emergency

~~OFFICIAL USE ONLY~~

# Peach Bottom

- Modeling evacuation within emergency planning zone (EPZ) based on evacuation time estimate report
  - Delay times and speed of evacuating cohorts
- SNL using the OREMs code to model evacuation in the 10-20 mile area
  - Estimate delay times for ad hoc evacuation
  - Estimate travel speed based on OREMs analysis

# Peach Bottom


- Identified 6 cohorts
  - Identified characteristics for WinMACCS
- Early precautionary actions at Site Area Emergency are not taken in PA (atypical)
  - Maryland follows PA lead.

OFFICIAL USE ONLY

# Event Sequence

## Cohort movement with respect to EALs

### Long Term Station Blackout



OFFICIAL USE ONLY


OFFICIAL USE ONLY

# Peach Bottom Populations and ETEs

Region	Population	Non-Evacuating	Evacuated	Number of Vehicles
0-10	71,362	357	71,005	40,574
10-20	392,257	1,961	390,296	223,026
Total	463,619	2,288	461,301	263,600

- Evacuation Times

- EPZ: 0-10 miles,
  - 6.5 hours(from licensee ETE)
- 0-20 miles
  - 19:19 hours (draft)



## Typical distribution for evacuation time

- Total evacuation time 19 hours, 19 minutes
- Start time 11 pm (22:00)
- End time 5:19 pm (17:19)
- Avg. Speed – not used

OFFICIAL USE ONLY

OFFICIAL USE ONLY

# Cohort Descriptions and Parameters

Cohort	Region	Delay to Shelter (hr)	Delay to Evacuation (hr)	Population	Load Factor	Number of Vehicles
<b>Schools</b>	0-10	1.0	0.0	12,215	40	305 buses
	10-20	2.5	10.0	66,694	175	38,111
<b>Shadow</b>	0-10	0.0	0.5	7,136	175	4,078
	10-20	0.0	1.0	39,226	175	22,415
<b>Special Needs</b>	0-10	0.0	1.0	400	175	229
	10-20	0.0	1.0	2,196	175	1,255
<b>Public</b>	0-10	0.5	2.0	46,631	175	26,646
	10-20	2.5	10.0	258,645	175	147,797
<b>Tail</b>	0-10	4.0	0.0	4,623	175	2,642
	10-20	0.0	14.0	23,535	175	13,449
<b>Non-Evacuating</b>	0-10	--	--	357	--	204
	10-20	--	--	1,961	--	--


OFFICIAL USE ONLY



OFFICIAL USE ONLY

# Peach Bottom 0-20 Miles

- Evacuation Time Estimate (ETE) for 0 – 10 miles is provided by the licensee.
- ETE for 10 – 20 is developed




OFFICIAL USE ONLY

OFFICIAL USE ONLY

# Peach Bottom Roadway Network

To develop  
the OREMS  
model, nodes  
are created  
at selected  
intersections




OFFICIAL USE ONLY

Map detail

~~OFFICIAL USE ONLY~~

# Peach Bottom Nodal Network

Example of node layout




OREMS detail

~~OFFICIAL USE ONLY~~

OFFICIAL USE ONLY

# Peach Bottom Nodal Network


- Nodal network is representative of the roadway network within the 10-20 mile zone




OFFICIAL USE ONLY

OFFICIAL USE ONLY

# Modeling Output



- Data is used to populate WinMACCS vehicular movement



Output

OFFICIAL USE ONLY

OFFICIAL USE ONLY


# Peach Bottom

- WinMACCS has options for angular resolution, rather than 16 sectors can use 32, 48 or 64
  - Reduces overestimate of population dose on sector center line

OFFICIAL USE ONLY

OFFICIAL USE ONLY

# Peach Bottom WinMACCS



- WinMACCS vehicle direction and speed input for:
  - 32 grid elements
  - 15 rings
- Simulates realistic vehicular movement

OFFICIAL USE ONLY

OFFICIAL USE ONLY

# EP Modeling

- Expect to fine tune model as experience running WinMACCS is gained
- Will learn from effort and move on to model Surry

OFFICIAL USE ONLY



OFFICIAL USE ONLY

# **SOARCA**

## **Latent Cancer Fatality Dose Response Model**

Jocelyn Mitchell

OFFICIAL USE ONLY

# Latent Cancer Fatality Dose Response Model

- Initially proposed to use a range of dose thresholds from 0 to 5 rem.
  - Will not facilitate a common understanding
  - Leaves the interpretation of the results to the reader
- Options considered:
  - Range of dose thresholds
  - Probabilistic distribution of dose thresholds
  - Point value
- Recommend to Commission using 5 rem in a year/10 rem in a lifetime
  - Health Physics Society recommendation
  - Detectable Limit