

# Occupational Radiation Exposure at Commercial Nuclear Power Reactors 1982

Annual Report

---

---

**U.S. Nuclear Regulatory  
Commission**  
**Office of Resource Management**

B. G. Brooks



## NOTICE

### Availability of Reference Materials Cited in NRC Publications

Most documents cited in NRC publications will be available from one of the following sources:

1. The NRC Public Document Room, 1717 H Street, N.W.  
Washington, DC 20555
2. The NRC/GPO Sales Program, U.S. Nuclear Regulatory Commission,  
Washington, DC 20555
3. The National Technical Information Service, Springfield, VA 22161

Although the listing that follows represents the majority of documents cited in NRC publications, it is not intended to be exhaustive.

Referenced documents available for inspection and copying for a fee from the NRC Public Document Room include NRC correspondence and internal NRC memoranda; NRC Office of Inspection and Enforcement bulletins, circulars, information notices, inspection and investigation notices; Licensee Event Reports; vendor reports and correspondence; Commission papers; and applicant and licensee documents and correspondence.

The following documents in the NUREG series are available for purchase from the NRC/GPO Sales Program: formal NRC staff and contractor reports, NRC-sponsored conference proceedings, and NRC booklets and brochures. Also available are Regulatory Guides, NRC regulations in the *Code of Federal Regulations*, and *Nuclear Regulatory Commission Issuances*.

Documents available from the National Technical Information Service include NUREG series reports and technical reports prepared by other federal agencies and reports prepared by the Atomic Energy Commission, forerunner agency to the Nuclear Regulatory Commission.

Documents available from public and special technical libraries include all open literature items, such as books, journal and periodical articles, and transactions. *Federal Register* notices, federal and state legislation, and congressional reports can usually be obtained from these libraries.

Documents such as theses, dissertations, foreign reports and translations, and non-NRC conference proceedings are available for purchase from the organization sponsoring the publication cited.

Single copies of NRC draft reports are available free upon written request to the Division of Technical Information and Document Control, U.S. Nuclear Regulatory Commission, Washington, DC 20555.

Copies of industry codes and standards used in a substantive manner in the NRC regulatory process are maintained at the NRC Library, 7920 Norfolk Avenue, Bethesda, Maryland, and are available there for reference use by the public. Codes and standards are usually copyrighted and may be purchased from the originating organization or, if they are American National Standards, from the American National Standards Institute, 1430 Broadway, New York, NY 10018.

GOPO Printed copy price: \$5.00

---

---

# Occupational Radiation Exposure at Commercial Nuclear Power Reactors 1982

## Annual Report

---

---

Manuscript Completed: September 1983  
Date Published: December 1983

B. G. Brooks

**Management Information Branch  
Office of Resource Management  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555**



PREVIOUS REPORTS IN SERIES

1. T. D. Murphy, "A Compilation of Occupational Radiation Exposure from Light Water Cooled Nuclear Power Plants, 1969-1973," USAEC Report WASH-1311, May 1974.
2. T. D. Murphy, C. S. Hinson, "Occupational Radiation Exposure at Light Water Cooled Power Reactors, 1969-1974," USNRC Report NUREG-75/032, June 1975.
3. T. D. Murphy, et al, "Occupational Radiation Exposure at Light Water Cooled Power Reactors, 1969-1975," USNRC Report NUREG-0109, August 1976.
4. L. A. Johnson, "Occupational Radiation Exposure at Light Water Cooled Power Reactors, 1969-1976," USNRC Report NUREG-0323, March 1978.
5. L. A. Johnson, "Occupational Radiation Exposure at Light Water Cooled Power Reactors, 1977," USNRC Report NUREG-0482, May 1979.
6. B. G. Brooks, "Occupational Radiation Exposure at Commercial Nuclear Power Reactors, 1978," USNRC Report NUREG-0594, November 1979.
7. B. G. Brooks, "Occupational Radiation Exposure at Commercial Nuclear Power Reactors, 1979," USNRC Report NUREG-0713, Vol. 1, March 1981.
8. B. G. Brooks, "Occupational Radiation Exposure at Commercial Nuclear Power Reactors, 1980," USNRC Report NUREG-0713, Vol. 2, December 1981.
9. B. G. Brooks, "Occupational Radiation Exposure at Commercial Nuclear Power Reactors, 1981," USNRC Report NUREG-0713, Vol. 3, November 1982.

## ABSTRACT

This report presents an updated compilation of occupational radiation exposures at commercial nuclear power reactors for the years 1969 through 1982. This report is one of a series of reports which are published annually and is available at all NRC Public Document Rooms, or may be purchased from either of the organizations identified on the inside of the front cover of this report. The bulk of the information contained in this document was derived from reports submitted to the United States Nuclear Regulatory Commission in accordance with requirements of individual plant technical specifications and in accordance with §20.407 of Title 10, Chapter 1, Code of Federal Regulations (10 CFR §20.407).

This year's report contains data received from the 74 light water cooled reactors (LWRs) and one high temperature gas cooled reactor (HTGR) that had been declared to be in commercial operation for at least one full year as of December 31, 1982. This represents an increase of four reactors over the number contained in last year's report. The total number of personnel monitored at LWRs in 1982 was 129,275, a slight increase from that found in 1981 (124,504). The number of workers that received measurable doses during 1982 was 84,322 which is about 2,000 more than that found in 1981. The total collective dose at LWRs for 1982 is estimated to be 52,190 man-rems, which is about 2,000 man-rems less than that reported in 1981. The result was that the average measurable dose per worker decreased to 0.62 rems, and the average collective dose per reactor decreased by about 70 man-rems to a value of 705 man-rems. The collective dose per megawatt-year of generated electricity by each reactor also decreased slightly to an average value of 1.6 man-rems per megawatt-year. A brief prospective on the health implications of these annual occupational doses is also provided. The staff estimates that a worker receiving an annual radiation dose of 0.62 rems over an entire working career may have his/her risk of dying from cancer increased by less than two percent of the normal risk of dying from cancer.

The report also presents a summary and some analyses of the exposure data contained in the "termination reports" that have been submitted by nuclear power licensees to the Commission pursuant to 10 CFR 20.408. As of December 31, 1982, personal identification and exposure information had been collected and computerized for some 250,000 of these terminating reactor personnel. Analysis of these data indicate that in 1981 there were about 2,200 quarterly transient\* workers who incurred an average dose of 0.42 rems and some 5,300 yearly transient\* workers who incurred an average dose of 0.97 rems. The collective dose (about 5,100 man-rems) incurred by the yearly transients constituted nine percent of the total collective dose calculated for 1981. The termination data reported in 1982 has not yet been completely computerized, and, therefore, such analyses for transient workers in 1982 were not available for presentation in this report.

\* Transient workers are those workers who begin and end their employment or work assignment at two or more different licensed facilities within one calendar quarter (quarterly transients) or one calendar year (yearly transients).



## CONTENTS

	<u>Page</u>
ABSTRACT. . . . .	iii
1. INTRODUCTION . . . . .	1
2. SUMMARY OF OCCUPATIONAL MONITORING DATA AND POWER GENERATION . . . . .	2
2.1 Definitions of Terms and Sources of Data. . . . .	2
2.1.1 Number of Reactors . . . . .	2
2.1.2 Collective Dose. . . . .	2
2.1.3 Breakdown of Collective Dose . . . . .	2
2.1.4 Workers with Measurable Whole Body Doses . . . . .	6
2.1.5 Megawatt-years of Electricity. . . . .	6
2.1.6 Collective Dose per Megawatt-year. . . . .	6
2.1.7 Average Rated Capacity . . . . .	6
2.2 Average Annual Occupational Doses . . . . .	7
2.3 Plant Rankings by Collective Dose per Reactor . . . . .	7
3. ANNUAL DOSE DISTRIBUTIONS. . . . .	19
3.1 Annual Whole Body Dose Distributions. . . . .	19
3.2 Dose Distributions by Work and Job Function . . . . .	22
3.3 Health Implications of Average Annual Doses . . . . .	26
3.4 High Temperature Gas Cooled Reactor . . . . .	27
4. TERMINATION DATA SUBMITTED PURSUANT TO 10 CFR §20.408. . . . .	28
4.1 Termination Reports, 1969-1981. . . . .	28
4.2 Limitations of the Termination Data . . . . .	28
4.3 Transient Workers per Calendar Quarter. . . . .	29
4.4 Transient Workers per Calendar Year . . . . .	30
4.5 Temporary Workers per Calendar Year . . . . .	33
4.6 Age and Dose Distribution of Terminated Workers . . . . .	35
4.7 Career Doses . . . . .	35
5. PERSONNEL OVEREXPOSURES. . . . .	41
REFERENCES. . . . .	43
APPENDIX A - Personnel, Dose, and Power Generation Summary, 1969-1982. . . . .	45
APPENDIX B - Annual Whole Body Doses at Licensed Nuclear Power Facilities, 1982 . . . . .	67
APPENDIX C - Number of Personnel and Man-Rems by Work and Job Function, 1982 . . . . .	73

## CONTENTS

	<u>Page</u>
TABLES AND FIGURES	
TABLE 1 Summary of Annual Information Reported by Commercial Boiling Water Reactors, 1969-1982 . . . . .	3
TABLE 2 Summary of Annual Information Reported by Commercial Pressurized Water Reactors, 1969-1982 . . . . .	4
TABLE 3 Summary of Annual Information Reported by Commercial Light Water Cooled Reactors, 1969-1982 . . . . .	5
TABLE 4 Boiling Water Reactors Listed in Ascending Order of Man-Rems per Reactor, 1978-1982 . . . . .	12
TABLE 5 Pressurized Water Reactors Listed in Ascending Order of Man-Rems per Reactor, 1978-1982. . . . .	13
TABLE 6 Five-Year Totals and Averages for Light Water Reactors, 1978-1982 . . . . .	15
TABLE 7 Summary Distribution of Annual Whole Body Doses at Commercial Light Water Cooled Reactors, 1969-1982 . . . . .	20
TABLE 8 Collective Annual Doses by Work Function and Personnel Type, 1982 . . . . .	23
TABLE 9 Percentages of Annual Collective Dose at LWRs by Work Function, 1975-1982 . . . . .	24
TABLE 10 Annual Collective Doses by Occupation and Personnel Type, 1982 . . . . .	25
TABLE 11 Annual Doses at Fort St. Vrain, 1974-1982 . . . . .	27
TABLE 12 Termination Reports Submitted for Reactor Personnel, 1969-1982 . . . . .	29
TABLE 13 Transient Workers per Calendar Quarter at Nuclear Power Facilities, 1972-1981 . . . . .	31
TABLE 14 Transient Workers Per Calendar Year at Nuclear Power Facilities, 1977-1981 . . . . .	32
TABLE 15a Actual and Compiled Dose Distributions of Transient Workers per Calendar Year at LWRs . . . . .	34
TABLE 15b Effects of Transient Workers on Annual Statistical Compilations . . . . .	34

## CONTENTS

	<u>Page</u>
TABLES AND FIGURES	
TABLE 16 Temporary Workers Per Calendar Year . . . . .	35
TABLE 17 Age & Dose Distribution of Terminating Reactor Personnel . . . . .	36
TABLE 18 Career Doses for Terminating Reactor Personnel, 1977-1982 . . . . .	38
TABLE 19 Summary of Career Doses for Terminating Reactor Personnel, 1977-1982 . . . . .	39
TABLE 20 Personnel Overexposures at Power Reactors, 1971-1982 . . . . .	42
FIGURES	
FIGURE 1 Average Annual Collective Doses and Number of Workers at Commercial Light Water Cooled Reactors, 1969-1982 . . . . .	8
FIGURE 2 Total Annual Values at LWRs, 1969-1982 . . . . .	9
FIGURE 3 Average Annual Values at LWRs, 1969-1982 . . . . .	10
FIGURE 4 Average, Median, and Extreme Values of the Collective Dose per Reactor, 1973-1982 . . . . .	11
FIGURE 5 Collective Dose per Year at BWRs, 1978-1982 . . . . .	16
FIGURE 6 Collective Dose per Year at PWRs, 1978-1982 . . . . .	17
FIGURE 7 Collective Dose per Year at PWRs, (continued) . . . . .	18
FIGURE 8 Cumulative Percent of Annual Individual Doses, 1982 . . . . .	21
FIGURE 9 Age and Dose Distributions of Personnel Terminating in 1981 . . . . .	37



OCCUPATIONAL RADIATION EXPOSURE AT  
COMMERCIAL NUCLEAR POWER REACTORS  
1982

1. INTRODUCTION

In 1974, the NRC staff began changing the technical specifications of operating nuclear power reactors to require the submittal of an annual report which indicated the number of individuals exposed and their cumulative annual doses, broken down by type of personnel, work function, and occupation. (The format for reporting is contained in Regulatory Guide 1.16, "Reporting of Operating Information - Appendix A Technical Specifications," and is similar to that shown in Appendix C of this report.) To obtain data for previous years, each reactor licensee was requested to provide similar information for each year since 1969 in which they had a unit in commercial operation. In every instance, an estimate of the total collective dose (man-rems) incurred by all individuals monitored during the year was provided; however, the number of workers who received measurable doses could not always be determined. The information given in Appendix A, therefore, is not complete for all plants for the years 1969 through 1972.

On February 4, 1974, 10 CFR §20.407 was amended to require licensed nuclear power utilities, among other licensees, to submit an annual statistical report indicating the distribution of the whole body doses of all individuals monitored at each facility. These reports (see Appendix B) allow an estimate to be made of the total collective dose, and of the number of workers receiving measurable doses. These values were used throughout this report (except for Tables 8, 9, 10 and Appendix C) for the years 1973 through 1981.

The plant operating data, such as plant capacity and megawatt-years of electricity generated, was obtained or derived from data included in various issues of the "Operating Units Status Report," (Ref. 1), and from the report "U. S. Central Station Nuclear Power Plants, 1976" (Ref. 2).

This report, and each of its predecessors, summarizes information reported during previous years. However, more plant specific data, such as the annual reports submitted by each plant pursuant to 10 CFR §20.407 and their technical specifications, may be found in those documents listed on the front cover of this report. Additional operating data and statistics for each of the years after 1972 through 1979 may be found in a series of reports, "Nuclear Power Plant Operating Experience" (Refs. 3-9). These documents are available at all NRC public document rooms, or they may be purchased from the National Technical Information Service, as shown in the Reference section.

## 2. SUMMARY OF OCCUPATIONAL MONITORING DATA AND POWER GENERATION

### 2.1 Definitions of Terms and Sources of Data

#### 2.1.1 Number of Reactors

Tables 1 through 3 provide summaries of the plant data given in Appendix A for boiling water reactors (BWRs), pressurized water reactors (PWRs), and all light water cooled reactors (LWRs), respectively. The number of reactors included each year (those without parentheses) are those reactors that had been in commercial operation for at least one full year as of December 31 of each of the indicated years. The figure shown in parentheses (for the years 1969-1972) is the number of reactors that provided both the number of individuals that received measurable doses (referred to as "workers") while visiting or working at the facility and the summation of the annual whole body doses (called man-rems) of all of these workers. The annual collective doses shown in parentheses and the other information marked with an asterisk are also based on the data submitted by the number of reactors shown in parentheses.

#### 2.1.2 Collective Dose

The collective dose (in man-rems) shown for 1969 through 1972 were obtained by special requests made to the licensee or from monthly and semi-annual operating reports that had been previously submitted pursuant to plant technical specifications. When possible, the number of workers receiving measurable doses was obtained in the same manner. Beginning with 1973, the collective dose and the number of workers receiving measurable doses were obtained from the annual reports submitted pursuant to 10 CFR §20.407. For the years 1973 through 1980, the annual collective dose was calculated for each facility by summing the products obtained by multiplying the number of individuals reported in each of the dose ranges (shown in Table 7 and Appendix B) by the midpoint of the corresponding range. Past experience has shown that the actual mean dose of individuals reported in each dose range is less than the midpoint of the range, and the collective doses shown in this report for these may be about 10% too high. In 1981, a few facilities began reporting the actual collective dose (as determined from official personnel dosimetry results) on their 20.407 annual reports, and the NRC staff used these doses instead of the above-described calculations. The staff would prefer to use the actual collective dose and hopes that more facilities make it available.

#### 2.1.3 Breakdown of Collective Dose

In Appendix A, the collective dose that was calculated from the §20.407-type annual reports is broken down by work function (operations and maintenance) and by personnel type (contractor, and station and utility combined) for each plant site. The proportion of the collective dose shown for each type is the same as that reported in the plant's annual report required by its technical specifications (see Appendix C). This was done in the following way:

- (1) The collective dose incurred by workers in the work function "Reactor Operations and Surveillance" on each plant's annual report submitted

TABLE 1

**SUMMARY OF ANNUAL INFORMATION REPORTED BY  
COMMERCIAL BOILING WATER REACTORS**

Year	Number Of Reactors Included	1969 - 1982		1969 - 1982		Average Man-REMs Generated Per Reactor	Average MW-Yrs Generated Per Reactor	Average Rated Capacity Net (MWe)
		Annual Collective Doses (Man-rems)	No. of Workers With Measurable Doses	Gross MW-Yrs Electricity Generated	Average Dose Per Worker (REms)			
1969	3 (2)	586 (300)	290*	192	1.03*	195	145*	3.1
1970	6 (4)	764 (510)	1,321*	912	0.39*	127	330*	0.8
1971	7 (5)	1,784 (1,069)	1,873*	1,308	0.57*	255	375*	1.4
1972	10 (7)	2,858 (2,130)	2,253*	3,058	0.94*	286	323*	0.9
1973	12	4,564	5,340	3,394	0.85	380	445	1.3
1974	14	7,095	8,769	4,059	0.81	507	626	1.7
1975	18	12,611	14,607	5,786	0.86	701	812	2.2
1976	23	12,626	17,859	8,586	0.71	549	776	1.5
1977	23	19,042	21,388	9,098	0.89	828	930	2.1
1978	25	15,096	20,278	11,774	0.74	604	811	1.3
1979	25	18,322	25,245	11,671	0.73	733	1,010	1.6
1980	26	29,530	34,094	10,868	0.87	1,136	1,311	2.7
1981	26	25,471	34,832	10,899	0.73	980	1,340	2.3
1982	26	24,437	32,235	10,655	0.76	940	1,240	2.3
							410	674

\* During the years 1969 through 1972, all plants reported collective doses but a few did not submit the number of personnel that received measurable doses. The number of reactors that did report doses and number of workers is given in parentheses in the second column. The collective doses shown in parentheses in the third column, as well as the asterisked numbers in the remaining columns, are all based on the data submitted by the number of reactors shown in parentheses. This correction, and others, changed some of the values from those appearing in earlier NUREG documents.

**TABLE 2**  
**SUMMARY OF ANNUAL INFORMATION REPORTED BY**  
**COMMERCIAL PRESSURIZED WATER REACTORS**

Year	Number Of Reactors Included	Annual Collective Doses (Man-rems)	No. of Workers With Measurable Doses	Gross MW-Yrs Electricity Generated	1969 - 1982		Average No. Personnel With Measurable Doses Per Reactor	Average Generated Per Reactor	Average MW-Yrs Generated Per Reactor	Average Rated Capacity Net (MWe)
					Average Dose Per Worker (Rems)	Average Collective Dose Per Reactor (Man-rems)				
1969	4 (3)	661 (363)	454*	1,097	0.80*	165	151*	0.6	274	349
1970	4 (3)	2,738 (1,099)	1,340*	979	0.82*	684	447*	2.8	245	349
1971	6 (4)	1,844 (912)	905*	1,912	1.01*	307	226*	1.0	319	399
1972	8 (5)	3,708 (2,083)	1,885*	2,544	1.11*	464	377*	1.5	318	446
1973	12	9,399	9,440	3,770	1.00	783	787	2.5	314	533
1974	20	6,627	9,697	6,824	0.68	331	485	1.0	341	619
1975	26	8,268	10,884	11,983	0.76	318	419	0.7	461	643
1976	30	13,807	17,588	13,325	0.79	460	586	1.0	444	675
1977	34	13,469	20,878	17,346	0.65	396	614	0.8	510	699
1978	39	16,713	25,720	19,840	0.65	429	659	0.8	509	723
1979	42	21,659	38,877	18,249	0.56	516	924	1.2	434	729
1980	42	24,266	46,237	18,287	0.52	578	1,101	1.3	435	721
1981	44	28,671	47,351	20,552	0.61	652	1,076	1.4	467	745
1982	48	27,753	52,147	22,141	0.53	578	1,086	1.3	578	773

\* During the years 1969 through 1972, all plants reported collective doses but a few did not submit the number of personnel that received measurable doses. The number of reactors that did report doses and number of workers is given in parentheses in the second column. The collective doses shown in parentheses in the third column, as well as the asterisked numbers in the remaining columns, are all based on the data submitted by the number of reactors shown in parentheses. This correction, and others, changed some of the values from those appearing in earlier NUREG documents.

**TABLE 3**  
**SUMMARY OF ANNUAL INFORMATION REPORTED**  
**BY COMMERCIAL LIGHT WATER COOLED REACTORS**

1969 - 1982

		1969 - 1982								
Year	Number Of Reactors Included	Annual Collective Doses (Man-rem)	No. of Workers With Measurable Doses	Gross MW-Yrs Electricity Generated	Average Dose Per Worker (Rems)	Average Collective Dose Per Reactor (Man-rem)	Average No. Personnel With Measurable Doses Per Reactor	Average Man-rem Per MW-Yr	Average MW-Yrs Generated Per Reactor	Average Rated Capacity Net (MW-e)
1969	7 (5)	1,247 (663)	744*	1,289	0.89*	178	149*	1.0	184	247
1970	10 (7)	3,502 (1,609)	2,661*	1,892	0.60*	350	380*	1.9	189	300
1971	13 (9)	3,628 (1,981)	2,778*	3,220	0.71*	280	309*	1.1	248	367
1972	18 (12)	6,566 (4,213)	4,143*	5,602	1.02*	365	345*	1.2	311	408
1973	24	13,963	14,780	7,164	0.94	582	616	1.9	299	496
1974	34	13,722	18,466	10,883	0.74	404	543	1.3	320	575
1975	44	20,879	25,491	17,759	0.82	475	579	1.2	404	630
1976	53	26,433	35,447	21,911	0.75	499	669	1.2	413	663
1977	57	32,511	42,266	26,444	0.77	570	742	1.2	464	677
1978	64	31,809	45,998	31,614	0.69	497	719	1.0	494	702
1979	67	39,981	64,122	29,920	0.62	597	956	1.3	447	705
1980	68	53,796	80,331	29,155	0.67	791	1,181	1.8	429	699
1981	70	54,142	82,183	31,451	0.66	773	1,174	1.7	449	719
1982	74	52,190	84,382	32,795	0.62	705	1,139	1.6	443	738

\* During the years 1969 through 1972, all plants reported collective doses but a few did not submit the number of personnel that received measurable doses. The number of reactors that did report doses and number of workers is given in parentheses in the second column. The collective doses shown in parentheses in the third column, as well as the asterisked numbers in the remaining columns, are all based on the data submitted by the number of reactors shown in parentheses. This correction, and others, changed some of the values from those appearing in earlier NUREG documents.

pursuant to their technical specifications (the first number in the last columns in Appendix C) was determined. (2) The ratio of this dose to the total collective dose (the last number in the last columns in Appendix C) was calculated and multiplied by the total collective dose that had been estimated using the \$20.407-type annual report. This product is the number of man-rems shown in the column headed "Operations" in Appendix A. (3) The number of man-rems shown in the column headed "Maintenance and Others" in Appendix A was determined by first summing the collective doses incurred by workers in the five remaining functions, given in Appendix C, and then calculating the fraction that this dose is of the total collective dose. This fraction was multiplied by the total collective dose estimated from the \$20.407-type annual reports to yield the number of man-rems shown in this column of Appendix A. (4) A similar procedure was followed in determining the number of man-rems in the type of personnel columns "Contractor" and "Station & Utility" in Appendix A.

#### 2.1.4 Workers With Measurable Whole Body Doses

The number of workers with measurable doses, rather than the total number of individuals monitored, is shown in Tables 1 through 3 and Appendix A. These values were used to calculate the average annual dose per worker and the average number of personnel per reactor. This was done to delete those individuals, many of whom probably did not routinely work in radiation areas (and were monitored for convenience or for identification purposes), who may have received exposures too small to be detected by personnel monitoring devices.

#### 2.1.5 Megawatt-years of Electricity

The number of gross megawatt-years (MW-Yr) of electric energy generated each year by each facility is shown in Appendix A. This number was obtained by dividing the gross megawatt-hours of electricity annually produced by each facility by 8,760, the number of hours in the year. The gross megawatt-years of generated electricity that are presented in Tables 1 through 3 are the sums of that produced by all of the reactors included each year. This sum is divided by the number of those reactors included each year to yield the average amount of electric energy generated (MW-Yr) per reactor, which is also shown in Tables 1 through 3.

#### 2.1.6 Collective Dose per Megawatt-year

The number of megawatt-years generated was also used to determine average values of the annual collective dose per megawatt-year generated. This was calculated by dividing the total collective dose by the total gross megawatt-years generated to yield a quotient, having the units "man-rems per MW-Yr," that is used as a measure of the dose incurred by workers at power reactors in relation to the gross electric energy produced. This value was also calculated for each reactor site and is presented in Tables 4 through 6 and Appendix A.

#### 2.1.7 Average Rated Capacity

The average rated capacity, shown in Tables 1 through 3, was found by dividing the sum of the net maximum dependable capacities (Net MWe) of

the reactors by the number of reactors included each year. The net maximum dependable capacity is defined to be the gross electrical output as measured at the output terminals of the turbine generator during the most restrictive seasonal conditions, less the normal station service loads. This is the "capacity" shown for each plant in Appendix A.

## 2.2 Average Annual Occupational Doses

Some of the data presented in Tables 1 and 2 is graphically displayed in Figure 1, where it can be seen that the average collective dose and average number of workers per BWR has been higher than that for PWRs for the last eight years and that the values of both parameters have, in general, continued to rise at both types of facilities. In 1982, however, the values of both parameters decreased at both PWRs and BWRs for the first time in several years. From Table 1, it can be seen that the average collective dose, dose per worker, and collective dose per megawatt-year at BWRs decreased slightly or remained about the same as those found for 1981. At PWRs (Table 2), the values of these three parameters decreased to 578 man-rems per reactor, 0.53 rems per worker, and 1.3 man-rems per megawatt-year, while the average number of workers per reactor (1,086) remained nearly the same as the 1981 value.

Figures 2 and 3 are plots of much of the information that is given in Table 3 for all light water reactors. One can see that of all of the parameters plotted, only the number of reactors, total number of workers and total megawatt years showed increases over last year's values.

To further assist in the identification of any trends that might exist, Figure 4 displays the average and the median\* values of the collective dose per reactor for BWRs and for PWRs for the years 1973 through 1982. The ranges of the values reported each year are shown by the vertical lines with a small bar at each end marking the two extreme values. The rectangles indicate the range of values of the collective dose exhibited by those plants ranked in the twenty-fifth through the seventy-fifth percentiles. Since the median values are not as greatly affected by the extreme values of the collective doses, one can see that they do not fluctuate as much from year to year as do the average values. The median collective dose for PWRs appears to have increased to about 500 man-rems, while for BWRs, it appears to have levelled off at about 940 man-rems. Nearly every year the median collective dose is less than the average, which indicates that the collective dose for most plants is less than the average collective dose per reactor (the value that is widely quoted).

## 2.3 Plant Rankings By Collective Dose Per Reactor

The number of reactors from which data have been collected is still rather small, and the information reported by a few reactors where unusual conditions or problems may have occurred could have a large impact on some of the statistics presented in this report. In an effort to identify those plants, Tables 4 and 5 list the BWRs and PWRs in ascending order of

---

\*The value at which 50% of the reactors reported greater collective doses and the other 50% reported smaller collective doses.

FIGURE 1  
COMMERCIAL LIGHT WATER COOLED REACTORS  
1969 - 1982




FIGURE 2  
TOTAL ANNUAL VALUES  
AT LIGHT WATER COOLED REACTORS  
1969 - 1982






FIGURE 3  
AVERAGE ANNUAL VALUES  
AT LIGHT WATER COOLED REACTORS  
1969-1982



**FIGURE 4**  
**AVERAGE, MEDIAN AND EXTREME VALUES OF**  
**THE COLLECTIVE DOSE PER REACTOR**  
 1973 - 1982



**TABLE 4**  
**BOILING WATER REACTORS**  
**LISTED IN ASCENDING ORDER OF MAN-REMS PER REACTOR**  
**1978 - 1982**

1982										1981										1980											
Site Name		1 Man- Rems per Site		Dose per Worker		Man- Rems per MW-Yr.		Site Name		1 Man- Rems per Site		Dose per Worker		Man- Rems per MW-Yr.		Site Name		1 Man- Rems per Site		Dose per Worker		Man- Rems per MW-Yr.		Site Name		1 Man- Rems per Site		Dose per Worker		Man- Rems per MW-Yr.	
Cooper Station	158	0.53	0.27	Humboldt Bay	31	0.23	0.00	Humboldt Bay	22	0.15	0.00	0.00	0.00	0.00	Humboldt Bay	19	0.27	0.00	0.08												
La Crosse	164	0.90	7.60	Monticello	157	0.42	0.30	La Crosse	218	1.76	8.26	La Crosse	123	0.66	4.2	0.68	La Crosse	205	1.39	11.9	0.81										
Big Rock Point	175	0.61	3.60	La Crosse	186	1.22	7.75	Hatch 1,2	449	0.23	0.45	Big Rock Point	160	0.33	2.8	0.47	Vermont Yankee	205	0.43	0.4	0.24										
Hatch 1	248	0.19	0.48	Cooper	221	0.52	0.37	Big Rock Point	354	0.59	7.24	Cooper Station	579	0.62	1.3	0.45	Duane Arnold	227	0.44	0.8	0.48										
Nine Mile Point	314	0.56	0.56	Duane Arnold	275	0.36	0.78	Monticello	531	0.48	1.29	Hatch 1,2	1,337	0.46	1.5	0.35	Big Rock Point	328	0.63	7.5	0.58										
Humboldt Bay	335	1.05	-	Big Rock Point	455	0.73	35.00	Nine Mile Point	551	0.50	1.11	Vermont Yankee	731	0.58	1.7	0.45	Cooper Station	542	0.73	0.9	0.52										
Vermont Yankee	339	0.36	0.87	Oyster Creek	467	0.55	0.86	Browns Ferry 1,2,3	1,825	0.67	0.84	Duane Arnold	790	0.61	2.8	0.50	Hatch 1,2	1,460	0.43	1.9	0.33										
Monticello	375	0.55	0.82	Browns Ferry 1,2,3	1,667	0.62	0.70	Duane Arnold	671	0.61	1.98	Browns Ferry 1,2,3	2,380	0.70	1.1	0.49	Browns Ferry 1,2,3	2,220	0.68	1.1	0.51										
Brunswick 1&2	1004	0.69	0.86	Hatch	582	0.27	1.45	Dresden 1,2,3	2,105	0.77	1.96	Oyster Creek	917	0.54	2.9	0.40	Oyster Creek	865	0.68	3.6	0.51										
Dresden 1,2&3	1529	0.79	1.23	Dresden 1,2,3	1,800	0.75	1.78	Cooper Station	859	1.09	1.92	Dresden 1,2,3	2,820	1.16	2.7	0.76	Millstone Point 1	929	0.68	1.9	0.48										
Browns Ferry 1,2,&3	1792	0.75	0.90	Peach Bottom 2,3	1,388	0.61	0.80	Peach Bottom 2,3	2,302	0.83	1.68	Monticello	1,004	0.69	2.6	0.52	Dresden 1,2,3	2,923	1.14	2.7	0.73										
Peach Bottom 2&3	1317	0.59	0.80	Hatch	1,317	1.59	1.44	Peach Bottom 2,3	2,080	0.80	1.80	Peach Bottom 2,3	2,505	0.88	2.2	0.56	Peach Bottom 2,3	1,977	0.72	1.2	0.48										
Quad Cities 1&2	1618	1.34	1.44	Fitzpatrick	859	1.01	2.46	Vermont Yankee	1,338	0.93	3.74	Brunswick 1,2	2,638	0.68	2.9	0.66	Monticello	993	0.76	3.4	0.57										
Fitzpatrick	909	1.00	1.83	Pilgrim	1,015	0.41	1.77	Oyster Creek	1,733	0.88	7.44	Fitzpatrick	1,425	0.57	2.5	0.44	Fitzpatrick	1,190	0.51	2.0	0.37										
Quane Arnold	974	0.86	6.53	Quad Cities 1,2,	2,158	1.28	2.01	Brunswick 1,2	3,870	1.02	5.63	Millstone 1	2,040	0.99	4.00	1,496	Nine Mile Point	1,264	0.93	9.5	0.66										
Millstone 1	1239	0.89	2.23	Vermont Yankee	1,170	0.36	2.85	Fitzpatrick	2,603	0.90	3.21	Millstone Point 1	2,158	0.71	5.32	3,146	Pilgrim	1,539	0.54	3.9	0.42										
Oyster Creek	1229	0.91	2.96	Brunswick 1,2	1,497	1.13	4.23	Quad Cities 1,2	4,838	1.57	5.58	Nine Mile Point	1,592	0.78	4.1	0.59	Quad Cities 1,2	3,757	1.62	3.7	0.79										
Pilgrim	1327	0.80	2.55	Nine Mile Point	1,733	1.01	3.55	Pilgrim	3,626	1.02	10.06	Pilgrim	1,836	0.66	4.5	0.44	Brunswick 1,2	3,792	0.76	6.5	0.70										
Averages per Reactor	604	0.74	1.55	Averages per Reactor	733	0.73	1.57	Averages per Reactor	1,135	0.87	2.72	Averages per Reactor	980	0.73	2.3	0.57	Averages per Reactor	940	0.76	2.3	0.59										

<sup>1</sup>For sites with more than one operating reactor, the number of man-rem per reactor is obtained by dividing the number of man-rem for the site by the number of reactors.

2CR is the ratio of the annual collective dose delivered at individual doses exceeding 1.5 rems to the total collective dose.

<sup>1</sup>For sites with more than one operating reactor, the number of man-tems per reactor is obtained by dividing the number of man-tems for the site by the number of reactors.

**2CR** is the ratio of the annual collective dose delivered at individual doses exceeding 1.5 rems to the total collective dose.

**TABLE 5**  
**PRESSURIZED WATER REACTORS**  
 LISTED IN ASCENDING ORDER OF MAN-REMS PER REACTOR  
 1978 - 1982

Site Name	Site	1978				1979				1980				1981				1982			
		1 Man- Rems per Worker	Dose per Worker (Rems)	Man- Rems per MW-Yr.	Site Name	1 Man- Rems per Site	Dose per Worker (Rems)	Man- Rems per MW-Yr.	Site Name	1 Man- Rems per Site	Dose per Worker (Rems)	Man- Rems per MW-Yr.	Site Name	1 Man- Rems per Site	Dose per Worker (Rems)	Man- Rems per MW-Yr.	Site Name	1 Man- Rems per Site	Dose per Worker (Rems)	Man- Rems per MW-Yr.	Site Name
Davis Besse		48	0.11	0.15	Davis Besse	30	0.10	0.08	Davis Besse	154	0.12	0.60	Davis Besse	58	0.10	0.1	Keweenaw	101	0.29	0.2	0.11
Farley 1		103	0.20	0.15	Prairie Island 1,2	180	0.30	0.21	Keweenaw	165	0.41	0.38	Keweenaw	141	0.37	0.3	Prairie Island 1,2	229	0.36	0.2	0.16
Prairie Island 1&2		221	0.40	0.24	Fort Calhoun	126	0.28	0.29	Prairie Island 1,2	353	0.36	0.44	Prairie Island 1,2	329	0.39	0.4	Haddam Neck	126	0.23	0.2	0.27
Haddam Neck		117	0.54	0.21	Ranch Seco	126	0.44	0.18	Three Mile Island 1,2	394	0.17	-	Three Mile Island 1,2	376	0.18	0.06	Davis Besse	164	0.12	0.4	0.06
Salem 1		122	0.21	0.22	Keweenaw	127	0.37	0.31	Yankee Rose	213	0.42	5.98	Beaver Valley	229	0.19	0.4	McGuire	169	0.11	0.3	0.03
Keweenaw		154	0.46	0.33	Yankee Rose	127	0.29	0.85	North Anna 1	218	0.10	0.32	Salem 1	254	0.15	0.3	Crystal River	177	0.23	0.3	0.13
Point Beach 1&2		320	0.95	0.33	Beaver Valley	132	0.19	0.60	Cook 1,2	493	0.37	0.32	Piney Beach 1,2	596	0.77	0.8	Fort Calhoun	217	0.36	0.5	0.42
Arkansas 1		189	0.26	0.30	San Onofre	139	0.27	0.50	Piney Beach 1,2	598	0.07	0.82	Yankee Rose	302	0.59	2.8	Farley 1,2	484	0.33	0.4	0.18
Brave Valley		190	0.29	0.63	Maine Yankee	154	0.39	0.29	Indian Point 3	308	0.32	0.84	Calvert Cliffs 1,2	607	0.39	0.4	St. Lucie	272	0.26	0.3	0.18
Calvert Cliffs 1 & 2		500	0.36	0.42	Trojan	257	0.35	0.41	Calvert Cliffs 1,2	677	0.45	0.52	Cook 1,2	655	0.49	0.4	Point Beach 1,2	609	0.79	0.8	0.50
Yankee Rose		282	0.50	1.94	Point Beach 1,2	644	1.06	0.80	Arkansas 1	342	0.28	0.76	North Anna 1,2	680	0.28	0.5	Palisades	330	0.21	0.8	0.20
Trojan		312	0.45	1.55	Deane 1,2,3	1,001	0.48	0.59	Oconee 1,2,3	1,055	0.50	0.62	Indian Point 3	364	0.54	1.0	Rancho Seco	337	0.44	0.8	0.36
Crystal River		321	0.50	1.03	Cook 1,2	718	0.50	0.52	Rancho Seco	412	0.46	0.78	Oconee 1,2,3	402	0.52	1.3	Cook 1,2	699	0.46	0.5	0.27
Rancho Seco		323	0.64	0.53	Arkansas	369	0.28	0.93	Trojan	421	0.36	0.58	Crystal River 3	408	0.36	0.8	Arkansas 1,2	803	0.50	0.9	0.43
Cook 1		336	0.43	0.45	Calvert Cliffs 1,2	805	0.56	0.69	Palisades	424	0.32	1.47	Maine Yankee	424	0.49	0.7	Trojan	419	0.42	0.7	0.35
St. Lucie		337	0.42	0.56	St. Lucie	438	0.48	0.74	Farley	435	0.33	0.78	Fort Calhoun	458	0.56	1.8	Yankee Rose	474	0.58	4.4	0.54
San Onofre		401	0.52	1.24	North Anna	449	0.22	0.89	Salem 1	449	0.26	0.66	Farley	511	0.38	1.6	Three Mile Island 1,2	1,004	0.47	reactor seventy	0.44
Fort Calhoun		410	0.68	1.20	Millstone Point 2	472	0.62	0.91	Zion 1,2	520	0.68	0.65	Millstone Point 2	531	0.60	0.7	Calvert Cliffs 1,2	1,057	0.59	0.8	0.40
Maine Yankee		420	0.68	0.65	Crystal River	495	0.43	1.09	Maine Yankee*	524	0.63	0.88	Arkansas 1,2	1,102	0.50	1.0	Sequoayah	570	0.29	1.0	0.18
Ginnia		450	0.68	1.17	Indian Point 3	636	0.79	1.12	Millstone Point 2	625	0.59	1.55	Zion 1,2	1,720	0.88	1.3	Surrey 1,2	1,490	0.79	1.1	0.73
Oconee 1,2&3		1,393	0.85	0.73	Zion 1,2	1,274	0.87	1.03	Palisades	636	0.71	1.10	Palisades	902	0.42	2.2	Indian Point 1,2	1,635	0.76	3.1	0.52
Three Mile Island 1		504	0.26	0.73	Three Mile Island 1,2	1,170	0.29	4.40	St. Lucie	668	0.75	2.76	St. Lucie	929	0.63	1.6	San Onofre	832	0.27	13.5	0.35
Zion 1 & 2		1,017	0.92	0.63	Ginnia	592	0.67	1.67	Brower Valley	553	0.30	13.89	Robinson 2	733	0.50	1.7	Maine Yankee	618	0.48	1.1	0.32
Turkey Point 3&4		1,032	0.77	1.03	Indian Point 3	636	0.79	1.12	Crystal River	625	0.59	1.55	Turkey Point 3,4	7251	0.77	3.4	Zion 1,2	599	0.34	1.8	0.26
Indian Point 1,2 & 3		2,006	1.95	1.71	Zion 1,2	1,274	0.87	1.03	Haddam Neck	1,353	0.73	3.17	Indian Point 1,2	2,731	1.05	7.4	Turkey Point 3,4	570	0.29	1.0	0.18
Palisades		764	0.50	1.45	Indian Point 1,2	1,279	0.95	2.23	Ft. Calhoun	668	0.75	2.76	St. Lucie	929	0.63	1.6	Ginnia	1,915	0.67	2.5	0.67
Surrey 1&2		1,837	0.83	1.52	Farley	643	0.52	3.05	Ginnia	708	0.66	1.91	Haddam Neck	1,036	0.67	2.1	North Anna 1,2	2,103	1.34	1.8	0.76
Robinson 2		963	1.02	2.01	Indian Point 3,4	1,680	0.84	2.07	Turkey Point 3,4	1,651	0.92	1.67	Indian Point 1,2	2,731	1.05	7.4	Turkey Point 3,4	1,655	0.77	2.3	0.48
Millstone 2		1,621	1.14	3.02	Palisades	854	0.53	2.06	Haddam Neck	1,852	0.92	4.78	Surry 1,2	4,244	1.13	4.7	Ginnia	1,140	1.02	3.9	0.65
Average per Reactor		428	0.65	0.84	Haddam Neck	1,161	0.95	2.35	Robinson 2	3,836	0.72	6.75	San Onofre	3,223	1.11	33.6	Indian Point 3	1,226	0.83	7.1	0.59
Reactor		510	0.55	1.17	Averages per Reactor	2,387	0.71	10.45	San Onofre 1	2,387	0.78	28.53	Averages per Reactor	652	0.61	1.4	Millstone Point 2	1,413	0.68	2.4	0.48
																	Robinson 2	1,426	0.71	5.1	0.65
																	Averages per Reactor	578	0.53	1.3	0.49

\* Indian Point 1 was defueled in 1974.

† For sites with more than one operating reactor, the number of man-rem's per reactor is obtained by dividing the number of man-rem's for the site by the number of reactors.

‡ CR is the ratio of the annual collective dose delivered at individual doses exceeding 1.5 rem to the total collective dose.

man-rems per reactor for each of the years 1977 through 1982. Two other parameters, dose per worker and collective dose per megawatt-year, are also given for each plant and could have been used in listing the plants as well. Also shown is a parameter "CR" which is defined to be the ratio of the annual collective dose delivered at individual doses exceeding 1.5 rems to the total annual collective dose. This indicates the proportion of the total collective dose at the plant that was received by individuals who incurred annual doses of 1.5 rems or greater. CR is one of the parameters that the United Nations Scientific Committee on the Effects of Atomic Radiation (UNSCEAR) recommended be used in the analysis and comparison of exposure data. The latest UNSCEAR report (Ref. 10) states that the normal values of CR lie between 0.05 and 0.50, and one can see that CR for most of the plants fell within this range in 1982.

Table 6 lists the plants that had been in commercial operation for at least five years as of December 31, 1982. At both BWRs and PWRs, the number of workers per reactor-year increased by less than 10%, while the values of the average collective dose per reactor-year and collective dose per megawatt-year remained about the same as those found for the five years ending in 1981. Also, the average dose per worker decreased slightly at both BWRs and PWRs during this period. Figures 5, 6 and 7 are plots of some of the data that were used in Table 6. The dark bars indicate the collective dose per site for each of the last five years (unless the reactor was in commercial operation for a shorter time), and the circles indicate the five-year average of the collective dose per megawatt-year for each site. They are in order by age of the facility, and one can quickly see that the newer PWRs (Figure 6) have values of these two parameters that are smaller than those of the newer BWRs (Figure 5). This is also true when comparing the plots of the newer PWRs with that of the older PWRs (Figure 7), but not when comparing the newer and older BWRs (Figure 5).

In general, one can see from the listings in Tables 4 through 6 and Figures 5 through 7 that the plants having the lower values of the three parameters shown for each year are usually the newer plants. Some of the older, smaller plants also appear near the top of the listings since they report small collective doses; however, the ratio of their man-rems to the number of megawatt-years generated will be higher because of their limited power generation capacity. Usually, when a plant reports a large annual collective dose, and a large man-rems to megawatt-year ratio as well, it indicates that extensive maintenance or modifications were undertaken during the year. For example, the PWR facilities reporting high values for these two parameters during the last few years generally have been involved in extensive tube-sleeving jobs related to the repair of steam generators. At both types of plants, in-service inspections and other plant modifications (such as pipe hangers, snubbers, and safe-end replacements) were also major contributors. It should be noted that the differences in nuclear plant designs and the ages of plants (Ref. 11) even between plants of a given type affect the nature of these parameters as well, and one should be careful when attempting to draw conclusions from this data.

TABLE 6  
FIVE-YEAR TOTALS AND AVERAGES  
Light Water Reactors Listed in Ascending Order of Man-remns per Reactor  
1978 - 1982

Boiling Water Reactors				Pressurized Water Reactors					
2Site Name	1Total Man-remns per Site	Workers with Measurable Doses	Average Dose per Worker (remns)	Total Mega-Watt Years	Average Man-remns per Mw-Yr	2Site Name	1Total Man-remns per Site	Workers with Measurable Doses	Average Dose per Worker (remns)
Humboldt Bay	416	743	0.56	0.0	-	Davis Besse	454	3936	0.12
La Crosse	896	794	1.13	118.8	7.5	Prairie Island 1,2	1312	3604	0.36
Big Rock	1172	2507	0.47	210.9	5.6	Keweenaw	688	1815	0.38
Cooper	2389	3186	0.74	2694.7	0.9	Point Beach 1,2	2765	3047	0.91
Duane Arnold	2339	4787	0.61	1396.5	2.1	Yankee Rowe	1398	2837	0.49
Manticello	3060	4918	0.62	2073.6	1.5	Cook 1,2	2901	6436	0.45
Browns Ferry 1,2,3	9884	14433	0.68	10725.5	0.9	Rancho Seco	1600	3223	0.50
Dresden 1,2,3	11159	12050	0.93	5450.6	2.0	Beaver Valley	1703	6159	0.28
Vermont Yankee	31783	5342	0.71	2089.4	1.8	Calvert Cliffs	3646	7675	0.48
Peach Bottom 2,3	9490	12885	0.74	7495.6	1.3	Fort Calhoun	1879	3364	0.56
Nine Mile Pt.	5258	6442	0.82	1934.3	2.7	Trojan	2025	4894	0.41
Oyster Creek	5261	7178	0.73	1763.2	2.9	Crystal River	2026	4746	0.43
Fitzpatrick	6123	8622	0.74	2502.0	2.6	Maine Yankee	2079	3929	0.53
Brunswick 1,2	13306	16348	0.82	4175.8	3.3	Oconee 1,2,3	6452	10750	0.60
Quad Cities 1,2	14517	10544	1.38	5242.0	2.8	St. Lucie	2508	5296	0.47
Millstone Point 1	7615	10060	0.76	2261.9	3.4	Palisades	3274	7460	0.57
Pilgrim	9343	13331	0.70	2252.6	4.1	Zion 1,2	7034	7268	0.97
Grand Totals and Averages per Reactor-Year	107,481	134,770	0.80	52,387.4	2.1	Gimna	3545	4650	0.76
	896	1123		437.0		Haddam Neck	3753	5415	0.70
						Turkey Point 3,4	8733	11029	0.79
						Millstone Point 2	4673	6042	0.77
						Robinson 2	6162	7879	0.78
						San Onofre	6982	10305	0.68
						Surry 1,2	14931	18207	0.82
						Grand Totals and Averages per Reactor-Year	92,623	149,966	0.62
							561	909	479.0

1. For sites with more than one operating reactor, the number of man-remns per reactor is obtained by dividing the number of man-remns for the site by the number of reactors.

2. Multiple unit sites where not all reactors had completed five full years of commercial operation as of 12-31-82 are not included.

Figure 5  
COLLECTIVE DOSE PER YEAR at BWRS 1978 - 1982




Figure 6  
COLLECTIVE DOSE PER YEAR at PWRs 1978 - 1982





Figure 7

COLLECTIVE DOSE PER YEAR at PWRs (continued) 1978 - 1982



### 3. ANNUAL DOSE DISTRIBUTIONS

#### 3.1 Annual Whole Body Dose Distributions

Table 7 summarizes the distribution of the annual whole body doses received by workers at commercial LWRs during each of the years 1969 through 1982. This distribution is the sum of the annual dose distributions reported by each licensed nuclear facility each year. The distribution reported by each facility for 1982 is shown in Appendix B. From Table 7, one can see that prior to 1973 the reports had a different format such that for doses less than two rems there were only two dose ranges, 0.0 to 1.25 rems and 1.25 to 2.0 rems. This did not allow an estimate of the collective dose, as previously described, to be made for these years. For the years after 1972, the table indicates that the annual collective dose increased nearly every year, as did the number of monitored individuals. However, the values of CR show that the portion of the collective dose due to individual doses greater than 1.5 rems has decreased from a high of 0.72 in 1973 and has leveled off at about 0.55 for the last few years.

Since personnel monitoring data has frequently been found to have lognormal distributions (Ref 12), trends in the data may be observed from log-probability plots of the data. If the data are lognormally distributed, the data points will form a straight line when plotted on log-probability paper on which cumulative probabilities are laid off on the vertical axis at distances proportional to the corresponding number of standard deviations above or below the median, and the dose is plotted on the horizontal axis which has a logarithmic scale. Figure 8 displays such plots of the dose distributions of workers at BWRs and PWRs in 1982. The position of the plot for the PWRs above that of the BWRs indicates that a larger portion of workers at PWRs received lower doses which resulted in a lower median dose (point at which the 50 percentile line crosses the plots) and a smaller value of CR.

Further examination of the plots reveals that they form fairly straight lines only to about 1.5 rems where they start to curve upward. This curve is typical of distributions when there are several workers in the higher dose ranges, (Ref. 10) and indicates that not the entire distribution is a lognormal one. A new theoretical analysis of occupational dose distributions (Ref. 13) has found that these data are far better fitted by a hybrid lognormal distribution. At low doses, this distribution is lognormal, but at higher doses, where radiation control programs require that each worker's total dose be closely monitored so that the frequency of doses approaching the dose limits is reduced, the distribution is normal. This method of analyzing occupational doses may prove to have several valuable applications (Ref. 14) for individuals involved in radiation protection programs.

The compilation of the distribution data submitted by each facility into one report, however, introduces an additional source of error. Since individuals are not identified in the annual distribution reports, an individual who was monitored by five different reactor facilities would have been counted once on each facility's report. Therefore, when the data were summed to determine the total number of individuals monitored

**TABLE 7\***  
**SUMMARY DISTRIBUTION OF ANNUAL WHOLE BODY DOSES**  
**AT COMMERCIAL LIGHT WATER COOLED REACTORS**  
**1969 - 1982**


Year	No Measurable Exposure	Number of Individuals with Whole Body Exposures in the Indicated Ranges (Rems)										Total Number Monitored	** Annual Collective Doses (Man-rem)	*** CR					
		<0.10	0.25	0.50	0.75	1.0	2.0	3.0	4.0	5.0	6.0	7.0	8.0	9.0	10.0	11.0			
0.0-1.25																			
1969	2,479		128		134	65	25	5	2							2,838			
1970	6,839		146		166	163	88	98	8	1						7,509			
1971	8,586		410		315	137	105	17	11							9,581			
1972	14,095		688		532	189	111	46	21	9	6	6				15,713			
1973	19,043	5,494	1,698	1,214	740	652	2,468	1,584	422	251	125	71	38	16	7	33,823	13,963	0.72	
1974	20,472	6,735	2,887	2,056	1,182	906	2,503	1,378	471	226	86	30	6			38,938	13,722	0.63	
1975	18,854	8,841	3,674	2,750	1,685	1,339	3,948	1,872	691	423	169	60	24	12	1	44,343	20,879	0.65	
1976	25,704	12,821	5,130	4,135	2,520	2,030	4,880	2,354	789	487	188	70	26	11	5	1	61,151	26,433	0.62
1977	24,868	13,970	6,534	5,050	3,258	2,486	6,162	2,837	1,130	569	141	66	36	21	6		67,134	32,511	0.61
1978	30,143	16,639	6,943	5,504	3,399	2,498	6,405	2,989	1,080	418	67	26	8			(>12) 2	76,121	31,804	0.50
1979	41,191	24,512	9,881	8,090	5,147	3,426	7,898	3,306	1,255	477	86	28	13	2		(11-12) 1	105,313	39,981	0.54
1980	47,377	29,638	11,750	9,820	6,082	4,518	11,474	4,515	1,537	686	192	98	18	3			127,708	53,796	0.56
1981	42,323	29,332	12,217	10,326	6,625	4,903	11,766	4,546	1,793	486	93	81	11	2	1	(>12) 1	124,506	54,142	0.55
1982	44,893	31,480	12,693	10,814	6,739	4,795	10,855	4,666	1,814	432	56	13	4	0	1		129,275	52,190	0.54

\* Summary of reports submitted in accordance with 10 CFR 20.407 by plants that had been in commercial operation for at least one full year as of December 31 of each of the indicated years.

\*\* The collective dose and CR were not reported by the facilities but were calculated by the NRC staff using methods described in this document.

\*\*\* CR is the ratio of the annual collective dose delivered at individual doses exceeding 1.5 rems to the total annual collective dose.

**Figure 8**  
**CUMULATIVE PERCENT OF ANNUAL INDIVIDUAL DOSES**  
**1982**



NOTE: Each point on the curves represent the cumulative percentage of workers with measurable dose who received doses less than the indicated annual dose. The median measurable dose is the dose at which the curve crosses the fiftieth percentile.

\*CR is the ratio of the annual collective dose delivered at individual doses exceeding 1.5 rems to the total collective dose.

by all facilities, this person would have been counted as five individuals rather than as one. This affects the distribution of doses as well as the number of individuals and their average dose, because the individual could have been counted five times in the lower dose ranges rather than one time in a higher range in which his actual accumulated dose (the sum of his doses incurred at each facility) would have placed him. Further discussion of this is provided in Section 4.4.

### 3.2 Dose Distribution by Work and Job Function

Tables 8, 9 and 10 summarize the annual data submitted in accordance with plant technical specifications in a format similar to that shown in Appendix C. The licensees are requested to record the collective doses received by station employees, utility employees, and contract workers among various prescribed work functions and occupations. The report submitted by each station for 1982 is contained in Appendix C. One may note that in some cases, the licensee data had to be modified slightly in order to fit into the prescribed categories.

Table 8 provides a detailed summary of the distribution of collective dose by work function and personnel types for BWRs, PWRs and all LWRs. It shows that contract workers performing special maintenance at LWRs incur the largest portion of the collective dose. Table 9 presents a more general summary of this data for the last eight years, and one can see that workers involved in routine and special maintenance activities continue to incur most of the total cumulative dose. At BWRs (Table 8) workers involved in these activities received 77.7% of the cumulative dose for BWRs, and at PWRs these workers received 72.1% of the cumulative dose, about the same as last year's value. The portions of the collective dose received by workers during inservice inspection and refueling at BWRs are 4.3% and 2.7%, respectively; at PWRs such workers received 8.3% and 5.9%, respectively, of the collective dose. Overall, contractor personnel received 61.9% of the collective dose (five percent less than last year), and the station and utility employees received the remaining 38.1% at LWRs.

Table 10 presents the distribution of the collective dose at all LWRs among five occupations. As expected, maintenance personnel incurred the majority (74.2%) of the collective dose with contractor-maintenance personnel receiving about twice as much as the station and utility maintenance employees, combined. Supervisory personnel received only 2.7% of the dose, while workers in the remaining three occupations - operations, health physics, and engineering - received 7.1%, 8.9%, and 7.1%, respectively, of the collective dose. The collective doses shown in Tables 8 and 10 do not equal those shown in other tables in the report because they are the sum of the doses taken from the type of annual reports shown in Appendix C rather than the collective dose that was obtained or calculated from the \$20.407-type annual reports.

**TABLE 8\***  
**ANNUAL COLLECTIVE DOSES**  
**BY WORK FUNCTION AND PERSONNEL TYPE**

WORK FUNCTION	STATION EMPLOYEES MAN-REMS	% OF TOTAL	UTILITY EMPLOYEES MAN-REMS	% OF TOTAL	CONTRACT WORKERS & OTHERS		TOTAL PER FUNCTION MAN-REMS	% OF TOTAL
					% OF TOTAL	% OF TOTAL		
<b>BOILING WATER REACTORS</b>								
REACTOR OPERATIONS &	1462	6.4 %	144	0.6 %	475	2.1 %	2082	9.1 %
SURVEILLANCE	2001	8.7 %	1414	6.2 %	4310	18.8 %	7725	33.7 %
ROUTINE MAINTENANCE	130	0.6 %	146	0.6 %	709	3.1 %	985	4.3 %
INSERVICE INSPECTION	1093	4.8 %	897	3.9 %	8106	35.4 %	10096	44.0 %
SPECIAL MAINTENANCE	649	2.8 %	11	0.1 %	765	3.3 %	1427	6.2 %
WASTE PROCESSING	292	1.3 %	29	0.1 %	288	1.3 %	611	2.7 %
TOTALS	5629	24.6 %	2643	11.5 %	14656	63.9 %	22929	100.0 %
<b>PRESSURIZED WATER REACTORS</b>								
REACTOR OPERATIONS &	1592	5.9 %	182	0.7 %	829	3.1 %	2604	9.6 %
SURVEILLANCE	2600	9.6 %	457	1.7 %	3200	11.8 %	6258	23.1 %
ROUTINE MAINTENANCE	438	1.6 %	327	1.2 %	1494	5.5 %	2260	8.3 %
INSERVICE INSPECTION	2228	8.2 %	1602	5.9 %	9477	34.9 %	13308	49.1 %
SPECIAL MAINTENANCE	431	1.6 %	42	0.2 %	615	2.3 %	1089	4.0 %
WASTE PROCESSING	726	2.7 %	178	0.7 %	699	2.6 %	1604	5.9 %
REFUELING								
TOTALS	8018	29.6 %	2790	10.3 %	16316	60.2 %	27125	100.0 %
<b>ALL LIGHT WATER REACTORS</b>								
REACTOR OPERATIONS &	3054	6.1 %	326	0.7 %	1305	2.6 %	4687	9.4 %
SURVEILLANCE	4602	9.2 %	1871	3.7 %	7510	15.0 %	13984	27.9 %
ROUTINE MAINTENANCE	568	1.1 %	473	0.9 %	2204	4.4 %	3246	6.5 %
INSERVICE INSPECTION	3322	6.6 %	2499	5.0 %	17583	35.1 %	23405	46.8 %
SPECIAL MAINTENANCE	1081	2.2 %	54	0.1 %	1380	2.8 %	2517	5.0 %
WASTE PROCESSING	1018	2.0 %	208	0.4 %	987	2.0 %	2214	4.4 %
REFUELING								
TOTALS	13648	27.3 %	5434	10.9 %	30972	61.9 %	50055	100.0 %

\* Table does not include results from Point Beach 1, 2 (586 man-rems) because of formatting problems.

TABLE 9  
PERCENTAGES OF ANNUAL COLLECTIVE DOSE  
AT LWRS BY WORK FUNCTION

Work Function	1975	1976	1977	Percent of Dose			
				1978	1979	1980	1981
Reactor Operations and Surveillance	10.8%	10.2%	10.5%	13.3%	12.2%	9.5%	8.9%
Routine Maintenance	52.6%	31.0%	28.1%	31.5%	29.2%	35.5%	36.1%
Inservice Inspection	3.0%	6.0%	6.4%	7.7%	9.0%	5.5%	5.3%
Special Maintenance	19.0%	40.0%	42.5%	35.9%	39.4%	40.6%	40.5%
Waste Processing	6.9%	5.0%	5.8%	5.0%	3.6%	3.0%	4.2%
Refueling	7.7%	7.9%	6.7%	6.6%	6.6%	6.1%	5.0%

**TABLE 10\***  
**ANNUAL COLLECTIVE DOSES**  
**BY OCCUPATION AND PERSONNEL TYPE**

1982

OCCUPATION	STATION	EMPLOYEES	MAN-REMS	UTILITY		CONTRACT WORKERS	% OF TOTAL	TOTAL MAN-REMS	PER FUNCTION % OF TOTAL
				MAN-REMS	% OF TOTAL	EMPLOYEES	MAN-REMS		
<b>BOILING WATER REACTORS</b>									
MAINTENANCE	2802	12.3 %	2365	10.3 %	12805	55.8 %	17972	78.4 %	
OPERATIONS	1452	6.3 %	32	0.1 %	211	0.9 %	1696	7.3 %	
HEALTH PHYSICS	670	2.9 %	10	0.0 %	711	3.1 %	1391	6.0 %	
SUPERVISORY	347	1.5 %	17	0.1 %	81	0.4 %	445	2.0 %	
ENGINEERING	358	1.6 %	219	1.0 %	848	3.7 %	1425	6.2 %	
<b>TOTALS</b>	<b>5629</b>	<b>24.6 %</b>	<b>2643</b>	<b>11.5 %</b>	<b>14656</b>	<b>63.9 %</b>	<b>22929</b>	<b>100.0 %</b>	
<b>PRESSURIZED WATER REACTORS</b>									
MAINTENANCE	4318	15.9 %	2307	8.5 %	12530	46.2 %	19155	70.6 %	
OPERATIONS	1576	5.8 %	100	0.4 %	1192	0.7 %	1868	6.9 %	
HEALTH PHYSICS	989	3.6 %	98	0.4 %	1964	7.2 %	3051	11.2 %	
SUPERVISORY	476	1.8 %	92	0.3 %	323	1.2 %	892	3.3 %	
ENGINEERING	660	2.4 %	193	0.7 %	1307	4.8 %	2160	8.0 %	
<b>TOTALS</b>	<b>8019</b>	<b>29.5 %</b>	<b>2791</b>	<b>10.3 %</b>	<b>16317</b>	<b>60.2 %</b>	<b>27126</b>	<b>100.0 %</b>	
<b>ALL LIGHT WATER REACTORS</b>									
MAINTENANCE	7120	14.2 %	4672	9.4 %	25335	50.6 %	37127	74.2 %	
OPERATIONS	3028	6.0 %	132	0.3 %	403	0.8 %	3564	7.1 %	
HEALTH PHYSICS	1659	3.3 %	108	0.2 %	2675	5.4 %	4441	8.9 %	
SUPERVISORY	823	1.7 %	110	0.2 %	404	0.8 %	1337	2.7 %	
ENGINEERING	1018	2.0 %	412	0.8 %	2155	4.3 %	3586	7.1 %	
<b>TOTALS</b>	<b>13648</b>	<b>27.2 %</b>	<b>5434</b>	<b>10.9 %</b>	<b>30972</b>	<b>61.9 %</b>	<b>50055</b>	<b>100.0 %</b>	

### 3.3 Health Implications of Average Annual Doses

If any biological effects are caused by exposure to radiation in the work place, the effects are likely to occur only after many years. The most important radiation-induced health effects are excess cancers, which can be manifested only years after exposure, and generic damage, which can be expressed only in subsequent generations. A vast amount of scientific information is available from which estimates of these risks can be made. Much of this information, however, has been obtained from epidemiologic studies of human populations at levels of exposure considerably higher than those normally experienced in the work place. Complementary to this, information obtained from many animal and cell biology studies have greatly enhanced our knowledge and understanding of the biological effects of ionizing radiation. Although using this information to estimate risks in the work place introduces uncertainties, these uncertainties can be dealt with in such a manner that the risk is not likely to be underestimated. Thus, the discussion below is likely to overstate the health implications rather than understate them.

Cancer induction as a result of radiation exposure has been examined by many organizations having scientific and medical expertise in the subject. One of these, the National Academy of Sciences (NAS), published a comprehensive review of the biological effects of ionizing radiation in 1980 (Ref. 15). Based on this report, a large working population receiving one million man-rems might suffer an estimated 100 to 200 additional cancer deaths over the remaining years of their lives. This risk estimate can be applied to the 52,190 man-rems (Table 3) and the 84,382 workers who received measurable exposures. The result is that for the total work force exposed at commercial LWRs in 1982, the expected number of additional cancer deaths that might result from radiation dose received that year would be less than ten. These deaths would occur many years following the exposure and would be in addition to the approximately 12,000 cancer deaths that occur normally in a population of 80,000 workers without exposure to this amount of radiation. Perhaps more meaningful to the individual workers are the health implications to the workers receiving the average dose of 0.62 rems or the maximum dose of 10 rems or so during 1982. The estimated increased cancer death risk is less than one chance in 10,000 for the average dose and about one chance in 1,000 for the ten-rem dose. Should a worker receive 0.62 rems per year continuously during his entire working career (working until age 65) his risk of dying from cancer could increase by about 2% of the normal risk of dying of cancer. These risks can be compared to the American Cancer Society's estimates of one chance in four of developing cancer and one chance in seven of dying of cancer.

The potential genetic effects from a workers population receiving about 50,000 man-rems is very small compared to genetic damages that occur spontaneously in this population. Based again on the 1980 NAS report, from zero to four serious genetic diseases could be induced in first generation children of the 80,000 exposed\* workers and from three to 60

---

\*Assuming that, on the average, each exposed person will have one child in the future, i.e., 80,000 children born to this worker population.

in all future generations. This number can be compared to the approximately 100,000 serious genetic defects that occur normally in one million live births, i.e., an average of about one serious defect in every ten live births. Thus, the total genetic damage in the first generation children of 80,000 workers would be an increase of less than four cases (less than 0.05%) to the expected 8,000 cases that occur normally.

### 3.4 High Temperature Gas Cooled Reactor (HTGR)

The only HTGR operating in the United States is the Fort St. Vrain plant near Denver, Colorado. It is owned by the Public Service Company of Colorado who was licensed to operate the plant on December 21, 1973. The 330 MWe (net) rated plant achieved initial criticality on January 31, 1974, and began generating electricity in December 1976. However, the plant did not declare commercial operability until July 1, 1979 and for most of 1982 it was still restricted to a 70% power level, except for testing.

As shown in Table 11, annual whole body doses incurred by workers at the plant have, in general, been minimal. In 1982, everyone monitored received a whole body dose that was less than 0.10 rems, and no one has ever exceeded an annual dose of 0.25 rems. The average dose per worker remains at about 0.05 rems or less. For the nine years ending on December 31, 1982, the total collective dose for workers at the site was about 22.0 man-rems, and a total of 373 megawatt-years of electricity had been generated. This yields a nine-year average of about 0.1 man-rems per megawatt-year. The average value of this parameter for LWRs is seventeen times as much (Table 3).

TABLE 11  
ANNUAL WHOLE BODY DOSES AT FORT ST. VRAIN  
1974 - 1982

No. of Individuals with Annual Doses in Ranges (Rems)				Total No. of Individuals Monitored	Annual Collective Dose (Man-Reems)	Gross MW-Yrs Generated	Average Measurable Dose Per Worker (Reems)
Year	No Measurable Dose	Measurable <0.10	0.10-0.25				
1974	1597	63	1	1,661	3.3	0.0	0.05
1975	1263	0	0	1,263	0.0	0.0	0.00
1976	1362	25	0	1,387	1.3	2.8	0.05
1977	946	55	1	1,002	2.9	29.8	0.05
1978	896	34	0	930	1.7	75.7	0.05
1979	1149	170	2	1,271	6.4	52.1	0.01
1980	902	57	1	960	3.0	83.2	0.05
1981	1096	31	0	1,127	1.0	93.6	0.03
1982	978	22	0	1,000	0.4	72.6	0.02

#### 4. TERMINATION DATA SUBMITTED PURSUANT TO 10 CFR §20.408

##### 4.1 Termination Reports, 1969-1981

In 1969 the NRC (then the Atomic Energy Commission) began requiring operating nuclear power facilities and three other types of licensees\* to submit personnel identification and exposure information upon the termination of each monitored person's employment or work assignment in the licensee's facility. The appropriate information on each report is manually coded and entered into the Commission's computerized Radiation Exposure Information and Reporting System (REIRS) at Oak Ridge, Tennessee. The data are retrievable by several criteria - social security number, name, facility, etc. - which allows statistical analyses of the data, as well as the tracing of individual dose histories. During the years that this information has been collected, some 880,000 termination records have been received for approximately 250,000 individuals who have been reported as having terminated their employment at nuclear power plants. The figures given for the number of reports and the number of individuals are different because numerous individuals have been terminated more than once over the years and because some individuals may have had external doses reported for more than one part of the body, as well as estimates of internal depositions of radioactive material, each of which is counted as one record. Table 12 provides a breakdown of this information for individuals terminating during each of the fourteen years and shows that the number of such records continues to increase each year; however, the number of terminating individuals appears to have leveled off at about 66,000.

##### 4.2 Limitations of the Termination Data

When examining or using the statistics shown in the report that are based on the termination data, one should keep in mind that these data have various limitations, such as the following: (1) Some licensees submit a termination report for each monitored non-utility employee at the end of each monitoring period rather than waiting until the individual actually leaves the facility. (2) The period(s) of exposure that are reported for terminating individuals may indicate the monitoring period during which he may have been exposed to radiation rather than the actual dates of exposure. (3) Some licensees report cumulative periods of exposure and doses rather than the actual periods and dose incurred during each period. (4) Licensees having more than one licensed facility sometimes file a termination report when the individual leaves the second facility that includes the dose which he incurred at the first facility that had already been reported. Although attempts have been made to correct for some of these problems, they are still an additional source of error in any statistics developed from the termination data.

---

\*Industrial radiographers; fuel processors, fabricators, and reprocessors; and manufacturers and distributors of specified quantities of byproduct material.

TABLE 12  
TERMINATION REPORTS SUBMITTED  
FOR REACTOR PERSONNEL  
1969 - 1981

Year	Number of Termination Records	Number of Terminating Individuals
1969	790	730
1970	2,130	1,910
1971	2,350	2,200
1972	4,500	3,890
1973	11,530	9,070
1974	16,950	11,600
1975	38,380	22,630
1976	63,590	35,290
1977	81,704	36,864
1978	85,308	37,359
1979*	118,218*	48,305*
1980*	162,515*	65,092*
1981*	174,546**	65,747*
1982**	83,247**	31,587*

\*Data for these years were updated based on more recent compilations.

\*\*Not all of the termination data for individuals terminating during 1982 have been entered into the REIR System.

#### 4.3 Transient Workers per Calendar Quarter

One use that is being made of the information contained in the termination reports is the examination of the doses being received by short-term workers. Since nearly half of the termination reports indicated periods of exposure that were less than 90 days, it is possible that several thousand individuals could have been employed by two or more licensees during the same calendar quarter. Thus, a "transient" worker is defined here as an individual who began and terminated employment at two or more different licensed facilities within one calendar quarter. This allows one to examine the doses of those workers most likely to approach the quarterly limits without their employer's knowledge since they move so rapidly among facilities.

Table 13 displays some of the information gathered from these termination reports that were submitted by the licensed nuclear power facilities. The number of these workers has increased more than twentyfold during the five years 1972 through 1976, but now appears to be increasing at a much smaller rate. The top part of Table 13 shows that the average individual dose (which is close to being a quarterly dose for most of these workers) showed a decreasing trend in the earlier years and has leveled off at about 0.42 rems. The lower half of the table breaks down the information shown in the first part and presents the doses of the workers employed by two, three and four or more different reactor licensees. One can see that the majority of these workers were reported by two different licensees during a quarter, while the smaller number of those terminated by three or more licensees generally received higher average doses. Examinations of these records have revealed that some individuals have worked for as many as six different NRC licensees during one calendar quarter. However, only a few instances have been found in which a worker exceeded his quarterly limit of three rems as a result of his working at two different licensed facilities within one calendar quarter. Two of them occurred in 1980 when the doses that the workers had received while employed by the first utility were revised upward later in the year. This resulted in their receiving a quarterly dose that slightly exceeded three rems. That is not to say that no other workers' doses have exceeded the quarterly limit because the records of those who were employed by a second licensee for a period spanning the end of a calendar quarter could not be examined in this manner, and the records of those employed by other than four categories of NRC licensees are not submitted to the NRC.

#### 4.4 Transient Workers per Calendar Year

Since the number of transient workers per calendar quarter comprise only a small percentage of the total number of individuals terminating each year, it was decided to change the criteria such that the records of more workers would be examined. This was done by selecting the records of all individuals who began and terminated two or more periods of employment with at least two different reactor facilities within one calendar year and by summing each worker's whole body doses. An examination of this data would allow one to determine the number and average dose for these "annual transients." Table 14 presents the number and doses of these transients that was found among the individuals terminating during each of the five years 1977 through 1981. This has not been done for the 1982 data because not all of it has yet been computerized. One can see that the number of these workers has nearly doubled since 1977. The average dose, however, has declined somewhat since then and remains at about one rem. The lower portion of the table shows the number and doses of workers that were terminated by two, three and four or more different reactor licensees during each year. One can see that the average dose of workers employed by two licensees increased to 0.91 rems in 1980, while in 1981 it fell back to a value (0.78 rems) more in line with that found for previous years. The average dose of workers employed by four or more licensees has continued to decline, and in 1981 it was calculated to be 1.56 rems.

In order to determine the impact that the inclusion of these individuals in each of two or more licensee's annual reports had on the annual summary (Table 7) for all nuclear power facilities (one of the problems mentioned

TABLE 13

TRANSIENT WORKERS PER CALENDAR QUARTER  
AT NUCLEAR POWER FACILITIES

1972 - 1981

Year	No. of Commercial Reactors	No. of Workers Terminated by Two or More Licenses		Collective Dose (Man-rems)	Average Dose (Rems)
		No. of Workers Terminated by Three Licenses	Average Dose (Rems)		
1972	18	57	1.00	57	1.00
1973	24	146	0.84	123	0.84
1974	34	285	0.56	157	0.56
1975	44	684	0.72	493	0.72
1976	53	1,257	0.71	889	0.71
1977	57	1,435	0.59	851	0.59
1978	64	1,500	0.45	680	0.45
1979	67	1,754	0.46	802	0.46
1980*	69	2,218	0.47	1,033	0.47
1981	73	2,249	0.42	938	0.42
Year	No. of Workers Terminated by Two Licenses	Collective Dose (Man-rems)	Average Dose (Rems)	No. of Workers Terminated by Three Licensees	Average Dose (Rems)
1972	54	52	0.96	2	1.50
1973	133	108	0.81	11	1.18
1974	255	132	0.52	28	24
1975	609	427	0.70	70	62
1976	1,095	720	0.66	145	146
1977	1,271	718	0.56	147	115
1978	1,303	590	0.45	165	75
1979	1,527	647	0.43	178	130
1980*	1,896	856	0.45	259	140
1981	1,897	767	0.40	297	148

\* Revised according to latest compilations.

TABLE 14  
 TRANSIENT WORKERS PER CALENDAR YEAR  
 AT NUCLEAR POWER FACILITIES

1977 - 1981

Year	No. of Commercial Reactors	No. of Workers Terminated by		Collective Dose (Man-rems)	Average Dose (Rems)	Average Dose (Rems)
		Two or More Licensees	Two or More Licensees			
1977	57	3,161	3,161	3,776	1.19	1.19
1978	64	3,202	3,202	3,231	1.01	1.01
1979	67	3,938	3,938	3,891	0.99	0.99
1980	69	5,463	5,463	6,028	1.10	1.10
1981	73	5,264	5,264	5,109	0.97	0.97

Year	No. of Workers Terminated by Two Licensees	No. of Workers Terminated by		Collective Dose (Man-rems)	Average Dose (Rems)	Average Dose (Rems)
		Three Licensees	Four or More Licensees			
1977	2,166	1,987	0.92	572	1.47	1.47
1978	2,119	1,490	0.70	621	1.28	1.28
1979	2,761	2,097	0.76	688	1.17	1.17
1980	3,772	3,444	0.91	959	1.30	1.30
1981	3,633	2,845	0.78	902	1.25	1.25

Year	No. of Workers Terminated by Two Licensees	No. of Workers Terminated by		Collective Dose (Man-rems)	Average Dose (Rems)	Average Dose (Rems)
		Three Licensees	Four or More Licensees			
1977	2,166	1,987	0.92	842	1.47	1.47
1978	2,119	1,490	0.70	792	1.28	1.28
1979	2,761	2,097	0.76	805	1.17	1.17
1980	3,772	3,444	0.91	1,245	1.30	1.30
1981	3,633	2,845	0.78	902	1.25	1.25

in Section 3.1) Tables 15a and 15b are presented. Table 15a shows the actual distribution of these transient workers' doses as determined from the above-described termination reports and compares it with the distribution of the whole body doses as they would have appeared in a compilation of the annual statistical reports submitted by each of the nuclear power facilities. During each of the years shown, there was an increasing number of transient workers who were counted more than once. Some individuals were reported by as many as nine different facilities. In 1977 the 2,873 transients that received a measurable dose were counted as 6,341 workers. By 1980 the number had grown to 4,930 transients who were probably counted as 10,749 workers since they were employed at several facilities. The latter incurred a collective dose of 6,028 man-rems, an average dose of 1.10 rems, and an average measurable dose of 1.22 rems. In 1981 these figures decreased somewhat, and there were 4,737 annual transients who received measurable doses that totaled to be 5,109 man-rems. This yielded an average measurable dose of 1.08 rems.

Table 15b illustrates the impact that the multiple reporting of these transient workers had on the staff's compilations of the annual statistical reports for the years 1977 through 1981. Since each nuclear power facility reports the distribution of the doses received by workers while monitored by the particular facility during the year, one would expect that a summation of these reports would result in individuals being counted several times in dose ranges lower than the range in which their total accumulated dose (the sum of the personnel monitoring results incurred at each facility during the year) would actually place them. Thus, while the total collective dose would remain about the same, the number of workers, their dose distribution, and their average dose would be affected by this multiple reporting. This was found to be true because too few workers were reported in the higher dose ranges. For example, in 1977 the compiled annual reports indicated that 270 individuals received doses greater than five rems, while the adjusted distribution indicated that there were at least 351 such workers. This resulted in an average measurable dose of 0.80 rems rather than the 0.74 rems obtained from the compiled reports. Although the number of these transient workers increased from 3,161 in 1977 to 5,264 in 1981, the number of them with doses exceeding five rems has remained at about 50 except for 1980 when the number increased to 92. In general, however, since the number of transient workers receiving measurable doses is only about five percent of the total number receiving measurable doses during the year, their impact on most of the statistics derived from compilations of the annual summary reports is not very great.

#### 4.5 Temporary Workers Per Calendar Year

In order to complete the examination of the doses received by the short-term workers employed at nuclear power facilities, Table 16 summarizes the data compiled on "temporary workers". Temporary workers were defined to be those individuals who began and ended their employment at only one nuclear power facility during the calendar year. One can see from Table 16 that the number of these individuals has grown during the last few years, but appears to have levelled off to about 28,000 workers with measurable doses in 1980 and 1981. Comparison of these figures with those in Table 15b reveals that these workers comprised 36% of the total number of

TABLE 15a  
ACTUAL AND COMPILED DOSE DISTRIBUTIONS OF  
TRANSIENT WORKERS PER CALENDAR YEAR AT POWER REACTORS

Type of Distribution and Year	Number of Individuals with Whole Body Doses in the Ranges (Rems)										Total Individuals	Total Man-Rems	Avg. Dose (Rems)	Avg. Meas. Dose (Rems)
	Less than Measurable	Measurable <0.10	0.10-0.25	0.25-0.50	0.50-0.75	0.75-1.00	1.00-2.00	2.00-3.00	3.00-4.00	4.00-5.00				
Actual Distribution of Transients - 1977	288	782	300	236	184	151	500	381	213	100	50	23	11	2
Compiled Distribution of Transients - 1977	1,594	2,357	804	768	552	417	1,013	362	55	8	5			
Actual Distribution of Transients - 1978	308	885	317	282	177	131	463	307	168	107	42	13	1	1
Compiled Distribution of Transients - 1978	2,079	2,423	918	788	488	382	873	262	51	11	0	2		
Actual Distribution of Transients - 1979	373	883	398	358	281	240	678	410	195	71	32	14	4	1
Compiled Distribution of Transients - 1979	2,130	2,676	1,259	1,048	673	460	1,040	313	46	3	1			
Actual Distribution of Transients - 1980	533	1,175	565	482	388	277	829	595	353	174	47	25	15	4
Compiled Distribution of Transients - 1980	3,207	3,910	1,639	1,398	900	661	1,632	503	74	29	4	4	4	
Actual Distribution of Transients - 1981	527	1,238	482	409	373	303	935	589	260	102	30	15	0	1
Compiled Distribution of Transients - 1981	3,487	3,660	1,450	1,392	943	707	1,481	325	68	8	0	1		

TABLE 15b  
EFFECTS OF TRANSIENT WORKERS ON ANNUAL STATISTICAL COMPILENTIONS

a Compiled Statistical Distribution - 1977	27,671	15,523	6,750	5,179	3,300	2,500	6,174	2,838	1,130	569	141	66	36	21	6	71,304	32,731	0.46	0.74	
b Compiled Statistical Distribution - 1977	26,305	13,948	6,246	4,647	2,932	2,234	5,661	2,857	1,288	661	186	89	47	23	6	67,130	32,643	0.49	0.80	
a Compiled Statistical Distribution - 1978	31,039	16,673	6,943	5,504	3,399	2,498	6,405	2,989	1,080	418	67	26	8		2	77,051	31,806	0.41	0.69	
b Compiled Statistical Distribution - 1978	29,268	15,135	6,342	4,998	3,088	2,247	5,995	3,034	1,197	514	109	37	9		1	2	71,976	31,668	0.45	0.74
a Compiled Statistical Distribution - 1979	42,340	24,632	9,883	8,090	5,147	3,426	7,898	3,306	1,255	477	86	28	13	2	1	106,584	39,987	0.38	0.62	
b Compiled Statistical Distribution - 1979	40,583	22,831	9,022	7,400	4,755	3,206	7,536	3,403	1,404	545	117	42	17	3	1	100,873	39,525	0.39	0.66	
a Compiled Statistical Distribution - 1980	47,377	29,695	11,751	9,820	6,082	4,518	11,474	4,615	1,537	686	192	98	18	3		128,668	53,799	0.42	0.67	
b Compiled Statistical Distribution - 1980	44,703	26,960	10,677	8,904	5,570	4,134	10,671	4,607	1,816	831	235	119	29	7	1	120,166	53,626	0.45	0.72	
a Compiled Statistical Distribution - 1981	42,323	29,332	12,217	10,326	6,625	4,903	11,766	4,546	1,763	486	93	81	11	2	1	124,506	54,142	0.43	0.66	
b Compiled Statistical Distribution - 1981	39,363	26,910	11,249	9,343	6,055	4,499	11,221	4,810	1,955	580	123	95	11	3		116,219	54,249	0.47	0.71	

<sup>a</sup>Based on data submitted by all reactors, although all of them may not have been in commercial operation for a full year.

<sup>b</sup>Collective dose found by summing the actual doses reported for those workers on their termination reports.

<sup>c</sup>Distribution found by subtracting the actual from the compiled distribution shown in Table 15a and then subtracting this difference from the compiled statistical distribution shown in Table 15b.

workers (76,856) receiving a measurable dose in 1981, while their collective dose was only 30% of the total collective dose. Their average measurable dose of 0.59 rems was also considerably less than the overall average of 0.71 rems.

TABLE 16  
TEMPORARY WORKERS PER CALENDAR YEAR  
(Individuals terminated by only one employer)

YEAR	No. of Reactors	Total No. Monitored	No. with Meas'ble Dose	Collective Dose	Avg. Dose (Rems)	Avg. Meas'ble Dose (Rems)
1977	57	29,090	19,094	11,373	0.39	0.60
1978	64	28,864	17,110	9,821	0.34	0.57
1979	67	38,347	21,491	9,488	0.25	0.44
1980	69	48,383	28,305	16,168	0.33	0.57
1981	73	47,348	27,984	16,393	0.35	0.59

#### 4.6 Age and Dose Distribution of Terminated Workers

Since some of the termination reports provide the birth date of the individual, one could examine these records and determine the age and dose distributions of workers that terminated during the year. Table 17 indicates the results of such examinations for the years 1975, 1978, 1980 and 1981 for power reactor personnel. One can see that the age and dose distributions for personnel terminating during these four years has remained about the same with more than 50% of the individuals being less than 35 years of age at termination each year. From 1975 to 1981 there was an increase of 8% in the collective dose incurred by these younger workers (less than 35 years old) the largest increase being in the collective dose received by 25 to 29 year-olds which went from 20% to 24%. Most of the other age groups incurred collective doses more comparable to their fraction of the total number of personnel. Figure 9 graphically displays the age and dose distributions of those workers terminating during 1981 for whom a birth date was reported.

#### 4.7 Career Doses

The termination data also permit estimation of the whole body doses accumulated by the workers monitored by nuclear power facilities when they terminate their employment. This was done by summing each individual's periods of exposure and corresponding whole body doses to give the worker's cumulative years of exposure and occupational dose that he received during his "career." The termination data for some 207,000 individuals terminating from nuclear power facilities between 1977 and 1982 were examined in this manner. The cumulative periods of employment and whole body doses were then broken down into ten ranges for the length of employment and fifteen ranges for the cumulative doses. Table 18 contains these detailed dose distributions, and Table 19 summarizes the

TABLE 17

## AGE AND DOSE DISTRIBUTION OF TERMINATING REACTOR PERSONNEL

Age Range (Years)	Term'd Personnel Number	1975		1978		1980		1981	
		Collective Dose Man-rem's (%)	Term'd Personnel Number (%)						
18-24	1,982 (14%)	829 (17%)	3,372 (14%)	1,792 (14%)	5,685 (14%)	3,354 (14%)	6,359 (15%)	3,843 (17%)	
25-29	2,488 (19%)	991 (20%)	4,641 (19%)	3,022 (23%)	7,590 (19%)	5,041 (22%)	8,444 (20%)	5,434 (24%)	
30-34	2,232 (17%)	825 (16%)	4,569 (19%)	2,775 (21%)	7,773 (20%)	4,964 (21%)	8,253 (19%)	4,595 (20%)	
35-39	1,679 (12%)	619 (12%)	3,295 (13%)	1,784 (13%)	5,515 (14%)	3,244 (14%)	6,235 (14%)	3,223 (14%)	
40-44	1,428 (11%)	535 (10%)	2,458 (10%)	1,304 (10%)	4,021 (10%)	2,327 (10%)	4,380 (10%)	2,124 (10%)	
45-49	1,297 (10%)	418 (8%)	1,910 (8%)	894 (7%)	3,130 (8%)	1,664 (7%)	3,231 (8%)	1,397 (6%)	
50-55	1,077 (8%)	342 (7%)	1,721 (7%)	782 (6%)	2,613 (7%)	1,268 (5%)	2,580 (6%)	908 (4%)	
56-59	700 (5%)	241 (5%)	1,344 (6%)	499 (4%)	2,024 (5%)	990 (4%)	1,996 (5%)	584 (3%)	
> 60	493 (4%)	233 (5%)	923 (4%)	324 (2%)	1,403 (3%)	612 (3%)	1,377 (3%)	354 (2%)	
<b>Totals</b>	<b>13,376 (100%)</b>	<b>5,033 (100%)</b>	<b>24,234 (100%)</b>	<b>13,176 (100%)</b>	<b>39,754 (100%)</b>	<b>23,464 (100%)</b>	<b>42,855 (100%)</b>	<b>22,466 (100%)</b>	

FIGURE 9  
AGE AND DOSE DISTRIBUTIONS OF PERSONNEL TERMINATING IN 1981




TABLE 18  
CAREER DOSE DISTRIBUTIONS FOR TERMINATING PERSONNEL  
1977 - 1982

Total Length of Employment	No Measurable Exposure <0.10	Number of Individuals with Whole Body Doses in the Following Ranges (Rems)										Total Number Monitored	Total Man Rems				
		0.10-0.25	0.25-0.50	0.50-0.75	0.75-1.0	1.0-2.0	2.0-3.0	3.0-4.0	4.0-5.0	5.0-10.0	10.0-15.0	15.0-20.0	20.0-25.0				
<90 days	58,774	31,304	7,370	5,453	3,442	2,428	7,473	3,030	1,078	346	178	2	0	1	0	120,879	32,953
90 D. - 1 Yr.	9,140	13,324	6,453	4,880	3,173	2,467	6,375	3,811	2,043	1,209	1,406	90	9	2	0	54,382	48,735
1 - 2 Yrs.	2,184	3,173	1,733	1,449	960	709	1,962	1,275	977	671	1,490	238	46	15	3	16,885	28,750
2 - 3 Yrs.	857	1,301	692	584	324	274	696	538	337	276	791	219	51	12	10	6,962	15,197
3 - 4 Yrs.	335	534	346	294	175	148	355	224	177	156	395	138	47	15	3	3,342	8,524
4 - 5 Yrs.	149	274	203	192	116	73	181	110	81	63	222	102	37	8	3	1,814	5,140
5 - 10 Yrs.	167	326	201	219	167	110	309	223	188	124	350	148	94	47	31	2,704	10,466
10 - 15 Yrs.	16	28	27	23	12	12	32	16	23	6	56	24	20	13	27	335	2,459
15 - 20 Yrs.	2	3	3	1	3	1	3	5	3	5	5	4	8	3	13	62	834
>20 Yrs.	21	7	6	1	7	0	8	2	4	0	5	0	1	1	1	63	185
Totals	71,645	50,274	17,034	13,096	8,379	6,222	17,394	9,234	4,911	2,856	4,898	965	312	117	91	207,428	153,143

TABLE 19  
SUMMARY OF CAREER DOSES FOR TERMINATING REACTOR PERSONNEL  
1977 - 1982

Total Length of Employment	Number of Monitored Individuals	No. of Workers with Meas'ble Doses	Total Collective Dose (Man-rems)	Avg. Meas'ble Dose for Period (Rems)	Highest Dose (Rems)	Years over Which Highest Dose Accumulated
<90 days	120,879	62,105	32,853	0.53	22*	*OE-3/81
900 - 1 Yr.	54,382	45,242	48,735	1.08	21	'77 - '78
1 - 2 Yrs.	16,885	14,701	28,750	1.96 - .747	29	'77 - '82
2 - 3 Yrs.	6,962	6,105	15,197	2.49 <sup>1,708</sup> <sub>.747</sub>	33	'77 - '81
3 - 4 Yrs.	3,342	3,007	8,524	2.83 <sup>1,549</sup> <sub>.747</sub>	28	'76 - '81
4 - 5 Yrs.	1,814	1,665	5,140	3.09 <sup>1,497</sup> <sub>.747</sub>	28	'77 - '82
5 - 10 Yrs.	2,704	2,537	10,466	4.13 <sup>2,647</sup> <sub>.747</sub>	53	'74 - '81
10 - 15 Yrs.	335	319	2,459	7.71 <sup>2,373</sup> <sub>.747</sub>	60	'62 - '76
15 - 20 Yrs.	62	60	834	13.90 <sup>2,347</sup> <sub>.747</sub>	54	'62 - '77
> 20 Yrs.	63	42	185	4.40	51	'59 - '81
Totals	207,428	135,783	153,143			

\*Personnel overexposure.

data and presents the average measurable doses, the highest cumulative doses, and the years during which the highest doses were accumulated. One can quickly see that more than half of the terminated individuals (120,879) has been exposed for less than 90 days and that nearly half of this number (58,774) did not receive a measurable dose. A good fraction of these were probably visitors, such as reporters, company representatives, consultants, etc. that were monitored for identification and convenience. It is primarily for the reason that the average measurable dose is shown rather than the average dose per monitored individual.

Table 19 shows that the average measurable dose ranges from 0.53 rems for periods less than 90 days to a high of 13.90 rems for the 15 to 20 year period. In general, the data shows that the average annual dose (estimated by dividing the average dose for the period by the average number of years in the period) tends to decline with increasing length of employment. However, since there is such a small number of workers have longer periods of employment, these average doses may change appreciably as more data is collected and analyzed. It should also be pointed out that these statistics do not give a clear indication of the actual time period over which doses were accumulated. For example, a worker could be employed by a nuclear power facility for one month each year for ten years, and he would be placed in the employment range of 90 days to one year. Therefore care should be taken when making conclusions based on these data.

## 5. PERSONNEL OVEREXPOSURES

Table 19 presents the number and types of personnel overexposures that have been reported by power reactors pursuant to 10 CFR §20.403 and §20.405 since 1971. In 1982 there were only two individuals reported as being overexposed. One overexposure occurred at the Indian Point 2 plant on June 1, 1982, when a contractor diver received a whole body dose of 8.67 rems (to bring his dose for the quarter to 9.4 rems). While attempting to relocate a fuel assembly, the diver's survey equipment malfunctioned, and he entered the high radiation field produced by the assembly without immediately realizing it. The other overexposure occurred at the Zion 1 plant on March 25, 1982, when a shift engineer received a whole body dose of five rems. The engineer was participating in a planned entry into the cavity beneath the reactor vessel in an attempt to locate water leaks which were causing problems with the head removal operations.

TABLE 20  
PERSONNEL OVEREXPOSURES AT POWER REACTORS  
1971 - 1982

Year	Number of Workers Overexposed to External Radiation	Sum of Whole Body Doses (Man-rems)	Maximum Whole Body Dose (Rems)	Number of Workers Exposed to Excessive Concentrations of Radioactive Material	Maximum Exposure 2000 MPC-hrs
1971	2	4.5	3.1	21	6.1 rems (thyroid)
1972	16	49.7	5.1	2	2000 MPC-hrs
1973	19	61.2	4.0	0	--
1974	43	155.9	6.1	12	433 MPC-hrs
1975	14	44.2	3.8	7	13.5 rems (lung)
1976	20	74.3	10.1	1	248 MPC-hrs
1977	27	52.9	3.6	0	--
1978	9	71.1	27.3	0	--
1979	21	43.4	10.1	0	--
1980	73	266.2	4.9	0	--
1981	7	35.4	21	0	--
1982	2	14.4	9.4	0	--

## REFERENCES

1. U. S. Nuclear Regulatory Commission, "Licensed Operating Reactors Status Summary Report," USNRC Report NUREG-0020, 1975-1982.\*
2. U. S. Energy Research and Development Administration, "Operating History, U. S. Central Station Nuclear Power Plants, 1976," USERDA Report ERDA-77-125.
3. U. S. Atomic Energy Commission, "Nuclear Power Plant Operating Experience During 1973," USAEC Report OOE-ES-004, December 1974.\*
4. U. S. Nuclear Regulatory Commission, "Nuclear Power Plant Operating Experience 1974-1975," USNRC Report NUREG-0227, April 1977.\*
5. U. S. Nuclear Regulatory Commission, "Nuclear Power Plant Operating Experience 1976," USNRC Report NUREG-0366, December 1977.\*
6. M. R. Beebe, "Nuclear Power Plant Operating Experience 1977," USNRC Report NUREG-0483, February 1979.\*
7. "Nuclear Power Plant Operating Experience 1978," USNRC Report NUREG-0618, December 1979.\*
8. "Nuclear Power Plant Operating Experience 1979," USNRC Report NUREG/CR-1496, May 1981.\*
9. "Nuclear Power Plant Operating Experience 1980," USNRC Report NUREG/CR-2378, ORNL/NSIC-191, October, 1982.\*
10. United Nations, "Report of the Scientific Committee on the Effects of Atomic Radiation," Annex H, General Assembly of Official Records, 1982, United Nations, New York.
11. "Trends in Nuclear Power Plant Man-Rem Per Megawatt-Year," L. A. Cross, A. P. Cross, presented to American Nuclear Society-European Nuclear Society International Conference, Washington, D.C., November 17-20, 1980.
12. Brodsky, A., R. Specht, B. Brooks, et. al., "Log-Normal Distributions of Occupational Exposure in Medicine and Industry." Presented at the 9th Midyear Topical Symposium of the Health Physics Society, 1976.
13. Kumazawa, S. and T. Numakunai, "A New Theoretical Analysis of Occupational Dose Distributions Indicating the Effect of Dose Limits," Health Physics, Vol. 41, No. 3, 1981.

\*Report is available for purchase from the National Technical Information Service, Springfield, Virginia 22161, and/or the NRC/GPO Sales Program, Division of Technical Information and Document Control, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555.

14. Kumazawa, S. and T. Numakunai, "A Method for Implementation of ALARA for Occupational Exposure Using the Hybrid Lognormal Model." Presented at the 27th Annual Meeting of the Health Physics Society, July 1, 1982.
15. National Academy of Sciences, "The Effects on Populations of Exposure to Low Levels of Ionizing Radiation: 1980," Committee on the Biological Effects of Ionizing Radiations, July 1980. Available from the National Academy Press, 2101 Constitution Avenue, N.W., Washington, D.C. 20418.

## **APPENDIX A\***

**Personnel, Dose and Power Generation Summary**

**1969 - 1982**

---

**\*A discussion of the methods used to collect and calculate the information contained in this appendix is given in Section 2.1.**

**Appendix A**  
**Personnel, Dose and Power Generation Summary**

Reporting Organization	Year	Mega-watt-Year (Mw-Yr)	Unit Availability Factor	Total Personnel With Measurable Doses	Total Man-rem	Man-rem per Work Function		Man-rem per Personnel Type	Average Dose per Worker (Rems)	Man-rem per MW-Yr
						Operat-	Maint.			
<b>ARKANSAS 1, 2</b> Docket 50-313; DPR-51, NPF-6 1st commercial operation 12/74,- Type - PWR Capacity - 836, 858 MWe	1975	588.0	76.5	147	21	262	100	189	0.14	0.0
	1976	464.6	56.6	476	289	228	111	145	0.61	0.6
	1977	610.3	76.8	601	256	28	80	0.43	0.4	0.4
	1978	627.2	77.5	722	189	32	157	109	0.26	0.3
	1979	397.0	55.3	1321	369	54	315	252	0.28	0.9
	1980	452.8	63.7	1233	342	81	261	213	0.28	0.8
	1981	1104.7	68.3	2225	1102	130	972	843	0.50	1.0
	1982	905.4	58.6	1608	803	97	706	505	0.50	0.9
<b>BEAVER VALLEY 1</b> Docket 50-334; DPR-66 1st commercial operation 10/76 Type - PWR Capacity - 810 MWe	1977	355.6	57.0	331	87	8	79	58	29	0.26
	1978	304.2	40.8	646	190	11	179	152	38	0.29
	1979	221.0	40.0	704	132	22	110	67	65	0.19
	1980	39.8	6.8	1817	553	76	477	477	76	0.30
	1981	573.4	73.6	1237	229	38	191	142	87	13.9
	1982	326.7	41.6	1755	599	126	473	481	118	0.19
<b>BIG ROCK POINT</b> Docket 50-155, DPR-6 1st commercial operation 3/63 Type - BWR Capacity - 64 MWe	1969	48.1		165	136				0.82	2.8
	1970	43.5		290	194				0.67	4.5
	1971	44.4		260	184				0.71	4.1
	1972	43.5		195	181				0.93	4.2
	1973	50.9		241	285				1.18	5.6
	1974	40.7	70.3	281	276	54	222	42	234	6.8
	1975	35.1	59.8	300	180	58	122	20	160	5.1
	1976	29.5	50.1	488	289	82	207	105	184	9.8
	1977	43.6	73.4	465	334	94	240	60	274	7.7
	1978	48.5	77.9	285	175	93	82	9	166	3.6
	1979	13.0	23.5	623	455	89	366	102	353	35.0

**Appendix A (Continued)**  
**Personnel, Dose and Power Generation Summary**

Reporting Organization	Year	Mega-watt-Year (MWh-Yr)	Unit Availability Factor	Total Personnel With Measurable Doses	Total Man-rems	Man-rems per Work Function		Man-rems per Personnel Type	Average Dose per Worker (Rems)	Man-rems per Station & Utility
						Operations	Maint. & Others			
BIG ROCK POINT (Continued)	1980	48.9	79.0	599	16	338	91	263	0.59	7.2
	1981	56.9	90.6	479	58	102	38	122	0.33	2.8
	1982	43.6	70.8	521	129	199	68	260	0.63	7.5
BROWNS FERRY 1, 2, 3 Docket 50-259, 50-260, 50-296; DPR-33, -52, -68 1st commercial operation 8/74, 3/75, 3/77 Type - BWR Capacity - 1065 MWe	1975	161.7	17.8	2380	325	803	249	614	0.14	2.0
	1976	337.6	26.9	2207	234	863	259	1533	0.11	0.7
	1977	1327.5	73.0	1858	4	1792	1378	0.46	0.6	
	1978	1992.1	73.5	2376	1667	0	289	0.75	0.9	
	1979	2393.0	79.1	2689	1825	4	1821	49	0.62	0.7
	1980	2182.1	73.6	2712	3379	100	2280	404	0.67	0.8
	1981	2132.9	69.5	3379	2277	2220	2039	1976	0.70	1.1
	1982	2025.4	67.6				317	1903	0.68	1.1
BRUNSWICK 2, 1 Docket 50-324, 50-325; DPR-62, -71 1st commercial operation 11/75, 3/77 Type - BWR Capacity - 790, 790 MWe	1976	297.2	56.0	1265	326	15	311	222	0.26	1.1
	1977	291.1	55.7	1512	1119	48	1071	782	0.74	3.8
	1978	1173.1	83.7	1458	1004	99	905	309	0.69	0.8
	1979	810.0	60.1	2891	2602	97	2905	528	0.90	3.2
	1980	687.2	52.2	3788	3870	111	3759	772	1.02	5.6
	1981	925.2	56.9	3854	2638	159	2479	1890	0.68	2.9
	1982	540.3	50.3	4957	3792	162	3630	2841	0.76	6.5
CALVERT CLIFFS 1, 2 Docket 50-317, 50-318; DPR-53, -69	1976	753.4	95.2	507	74	28	46	66	0.15	0.1
	1977	583.0	72.1	2265	547	36	511	224	0.24	0.9
	1978	1188.5	75.8	1391	500	13	487	143	0.36	0.4

**Appendix A (Continued)**  
**Personnel, Dose and Power Generation Summary**

Reporting Organization	Year	Mega-watt-Year (MW-Yr)	Unit Availability Factor	Total Personnel With Measurable Doses	Total Man-rem	Man-rem per Work Function Maint. & Others	Man-rem per Work Function Maint. & Others	Man-rem per Personnel Type Contrac-tor	Average Dose per Worker (Rems)	Man-rem per Station & Utility	Man-rem per Personnel Type
CALVERT CLIFFS 1, 2 (Continued) 1st commercial operation 5/75, 4/77 Type - PWR Capacity 825 MWe	1979 1980 1981 1982	1161.0 1309.9 1379.7 1238.3	74.0 84.1 83.1 73.7	1428 1496 1555 1805	805 677 607 1057	33 15 29 84	772 662 578 973	423 402 378 402	382 275 229 655	0.56 0.45 0.39 0.59	0.7 0.5 0.4 0.8
C00K 1, 2 Docket 50-315; DPR-58, -74 1st commercial operation 8/75, 7/78 Type - PWR Capacity - 1044 MWe, 1082 MWe	1976 1977 1978 1979 1980 1981 1982	807.4 573.0 744.8 1373.0 1552.4 1557.3 1461.6	83.1 76.1 73.6 65.3 74.1 73.4 69.8	395 802 778 1445 1345 1341 1527	116 299 336 718 493 655 699	13 21 49 45 46 48 67	103 278 287 673 447 607 632	71 138 139 454 323 442 472	45 161 197 264 170 213 227	0.29 0.37 0.43 0.50 0.37 0.49 0.46	0.1 0.5 0.4 0.5 0.3 0.4 0.5
COPPER STATION Docket 50-298; DPR-46 1st commercial operation 7/74 Type - BWR Capacity - 764 MWe	1975 1976 1977 1978 1979 1980 1981 1982	456.4 433.3 538.2 576.0 591.0 448.3 457.1 622.3	83.6 75.5 86.2 91.0 87.6 71.2 71.2 84.6	579 763 315 297 426 785 935 743	117 350 197 158 221 859 579 542	30 39 50 40 50 70 63 66	87 311 147 118 171 789 516 476	19 210 66 58 89 644 382 361	98 140 131 100 132 215 197 181	0.20 0.46 0.63 0.53 0.52 1.09 0.62 0.73	0.2 0.8 0.4 0.5 0.3 1.9 1.3 0.9

**Appendix A (Continued)**  
**Personnel, Dose and Power Generation Summary**

Reporting Organization	Year	Mega-watt-Year (MW-Yr)	Unit Availability Factor	Total Personnel With Measurable Doses	Total Man-rems	Man-rems per Work Function	Man-rems per Maint. & Others	Man-rems per Contractor	Man-rems per Station & Utility	Average Dose per Worker (Rems)	Man-rems per Personnel Type
CRYSTAL RIVER 3 Docket 50-302; DPR-72 1st commercial operation 3/77 Type - PWR Capacity - 806 MWe	1978	311.5	41.4	643	321	8	313	244	77	0.50	1.0
	1979	453.0	58.9	1150	495	29	466	346	149	0.43	1.1
	1980	402.1	53.2	1053	625	24	601	382	243	0.59	1.6
	1981	490.4	62.2	1120	408	18	340	236	172	0.36	0.8
	1982	589.8	76.0	780	177	9	168	116	61	0.23	0.3
DAVIS-BESSE 1 Docket 50-346; NPF-3 1st commercial operation 11/77 Type - PWR Capacity - 874 MWe	1978	326.4	48.7	421	48	13	35	14	34	0.11	0.1
	1979	381.0	67.0	304	30	8	22	5	25	0.10	0.1
	1980	256.4	36.2	1283	154	4	150	121	33	0.12	0.6
	1981	531.4	67.4	578	58	1	57	32	26	0.10	0.1
	1982	390.8	51.5	1350	164	12	152	139	25	0.12	0.4
DRESDEN 1, * 2, 3 Docket 50-010, 50-237, 50-249; DPR-2, -19, -25 1st commercial operation 7/60, 7/70, 11/71 Type - BWR Capacity - 197, 772, 773 MWe	1969	99.7			286						
	1970	163.1			143						
	1971	394.5			715						
	1972	1243.7			728						
	1973	1112.2			1341						
FORT CALUMET 1 Docket 50-011, 50-240, 50-241; DPR-2, -19, -25 1st commercial operation 7/60, 7/70, 11/71 Type - BWR Capacity - 197, 772, 773 MWe	1974	842.5	54.9	1594	1662	143	796	344	595	0.70	2.9
	1975	708.1	54.6	2310	3423	271	3152	57	1605	1.04	0.9
	1976	1127.2	80.8	1746	1680	228	1452	749	931	1.48	1.8
	1977	1132.9	77.0	1862	1693	316	1377	693	1000	0.91	0.6
	1978	1242.2	79.5	1946	1529	204	1325	619	910	0.79	2.0
FORT CALUMET 2 Docket 50-012, 50-242, 50-243; DPR-2, -19, -25 1st commercial operation 7/60, 7/70, 11/71 Type - BWR Capacity - 197, 772, 773 MWe	1979	1013.0	74.7	2407	1800	191	1609	641	1159	0.75	4.8
	1980	1074.4	55.0	2717	2105	236	1869	1093	1012	0.77	1.5
	1981	1035.7	51.5	2408	2802	120	2682	1850	952	1.16	1.2
	1982	1085.3	77.9	2572	2923	136	2787	1731	1192	1.14	1.8

\*Dresden 1 is shutdown, but it is still included in the count of commercial reactors shown elsewhere in the report.

**Appendix A (Continued)**  
**Personnel, Dose and Power Generation Summary**

Reporting Organization	Year	Mega-watt-Year (MW-Yr)	Unit Availability Factor	Total Personnel With Measurable Doses	Total Man-rems	Man-rems per Work Function & Others	Man-rems per Personnel Type	Man-rems per Contractor	Average Dose per Worker (Rems)	Man-rems per MW-Yr
DUANE ARNOLD Docket 50-331; DPR-49 1st commercial operation 2/75 Type - BWR Capacity - 515 MWe	1976	305.2	78.0	350	105	14	91	62	43	0.30
	1977	353.6	78.9	538	299	36	263	220	79	0.56
	1978	149.2	33.2	1112	974	59	915	932	42	0.88
	1979	352.0	78.0	757	275	35	240	219	56	0.36
	1980	339.1	73.3	1108	671	32	639	570	101	0.61
	1981	277.7	69.8	1286	790	56	734	598	192	0.61
	1982	278.5	74.7	524	229	18	211	175	54	0.44
FARLEY 1, 2 <sup>a</sup> Docket 50-348, 50-364; NPF-2, -8 1st commercial operation 12/77, 7/81 Type - PWR Capacity - 804, 814 MWe	1978	713.8	86.5	527	108	39	69	34	74	0.20
	1979	211.0	28.6	1227	643	108	535	460	183	0.52
	1980	557.3	69.3	1330	435	106	329	185	250	0.33
	1981	310.2	41.4	1331	511	96	415	270	241	0.38
	1982	1271.5	79.2	1453	484	155	329	196	288	0.33
FITZPATRICK Docket 50-333; DPR-59 1st commercial operation 7/75 Type - BWR Capacity - 810 MWe	1976	489.0	71.6	600	202	14	1066	937	143	0.34
	1977	460.5	68.4	1380	1080	909	743	597	312	0.78
	1978	497.0	72.1	904	850	859	690	538	321	1.00
	1979	349.0	50.8	850	2056	2040	118	1922	1808	1.01
	1980	509.5	70.3	2490	1425	187	1238	1072	353	2.5
	1981	562.9	74.7	2322	1190	136	1054	862	328	0.99
	1982	583.6	75.0							4.0
										2.5
										2.0
										0.51

<sup>a</sup>Farley 2 was counted for the first time in 1982.

**Appendix A (Continued)**  
**Personnel, Dose and Power Generation Summary**

Reporting Organization	Year	Mega-watt-Year (MW-Yr)	Unit Availability Factor	Total Personnel With Measurable Doses	Total Man-rem	Man-rem per Work Function Maint. & Others	Man-rem per Personnel Type	Average Dose per Worker (Rems)	Man-rem per MW-Yr
							Contractor	Station & Utility	
<b>FORT CALHOUN</b> Docket 50-285; DPR-40 1st commercial operation 9/73 Type - PWR Capacity - 478 MWe									
1974	294.0	83.5	327	71	294	285	47	0.22	0.2
1975	252.3	67.4	469	313	28	38	202	0.63	1.2
1976	265.9	69.5	516	297	33	264	275	0.61	1.2
1977	351.8	79.4	535	410	59	351	72	225	0.56
1978	342.3	75.1	596	126	19	107	151	259	0.69
1979	440.0	95.7	451	668	38	426	47	0.28	1.2
1980	242.3	60.4	891	668	61	397	242	0.75	2.8
1981	260.9	72.3	822	458	44	254	204	0.56	1.8
1982	418.0	89.7	604	217	173	99	118	0.36	0.5
<b>GINNA</b> Docket 50-244; DPR-18 1st commercial operation 7/70 Type - PWR Capacity - 470 MWe									
1971	327.8	340	430	69	361	108	322	1.26	1.3
1972	293.6	677	1032	71	961	278	754	1.52	3.5
1973	409.5	319	224	55	169	84	140	0.70	0.5
1974	253.7	62.4	884	1225				1.39	4.8
1975	365.2	76.7	685	538				0.78	1.5
1976	248.8	58.2	758	636	29	607	210	0.84	2.5
1977	365.6	85.5	530	401	15	386	120	0.76	1.1
1978	386.5	80.6	657	450	20	430	98	352	0.68
1979	355.0	72.8	878	592	68	524	207	385	0.67
1980	370.5	76.0	1073	708	64	644	302	406	0.66
1981	399.0	82.1	925	655	49	606	251	404	0.66
1982	289.0	58.8	1117	1140	80	1060	546	594	1.9
									1.9
									3.9

**Appendix A (Continued)**  
**Personnel, Dose and Power Generation Summary**

Reporting Organization	Year	Mega-watt-Year (Mw-Yr)	Unit Availability Factor	Total Personnel With Measurable Doses	Total Man-rem	Man-rem per Work Function & Others	Man-rem per Personel Type		Average Dose per Worker (Rems)	Man-rem per MW-Yr
							Contractor	Station & Utility		
HADDAM NECK (CONN. YANKEE) Docket 50-213; DPR-61 1st commercial operation 1/68 Type - PWR Capacity - 555 MWe	1969	438.5		138	106		27	79	0.77	0.2
	1970	424.7		734	689		463	226	0.94	1.6
	1971	502.2		289	342		166	176	1.18	0.7
	1972	515.6		355	325		181	144	0.91	0.6
	1973	293.1	91.2	951	697		544	153	0.73	2.4
	1974	521.4		550	201		683	196	0.70	0.9
	1975	494.3	89.9	795	703	20	444	253	0.36	0.4
	1976	482.9	82.5	644	449	5	582	440	0.88	1.4
	1977	480.7	83.9	894	641	59	117	25	0.72	1.3
	1978	563.4	98.6	216	216		92	18	0.54	0.2
	1979	493.0	87.5	1226	1161	73	1088	783	0.95	2.4
	1980	426.8	75.0	1860	1353	175	1178	1076	0.73	3.2
	1981	487.5	84.3	1554	1036	174	862	809	0.67	2.1
	1982	543.9	93.4	559	126	46	80	22	0.23	0.2
HATCH 1, 2 Docket 50-321, 50-366; DPR-57; NPF-05 1st commercial operation 12/75, 9/79 Type - BWR Capacity - 757, 771 MWe	1976	496.3	83.8	630	134	79	55	4	130	0.21
	1977	446.8	66.3	1303	465	96	369	220	245	0.36
	1978	513.0	72.8	1304	248	88	160	52	196	0.19
	1979	401.0	54.6	2131	582	85	497	382	200	0.27
	1980	1008.7	70.9	1930	449	143	306	163	286	0.23
	1981	870.9	64.3	2899	1337	20	1137	792	545	0.46
	1982	768.0	56.6	3418	1460	218	1242	1064	396	0.43
HUMBOLDT BAY <sup>a</sup> Docket 50-133; DPR-7	1969	44.6		125	164	69	95	12	152	3.7
	1970	49.3		115	209	130	79	37	172	1.82

<sup>a</sup>Humboldt Bay is shutdown indefinitely. It is still included in the count of commercial reactors.

**Appendix A (Continued)**  
**Dose and Power Generation Summary**

Reporting Organization	Year	Personnel	Unit Availability Factor	Total Personnel With Measurable Doses	Total Man-remns	Man-remns per Work Function Maint. & Others	Man-remns per Work Operations	Man-remns per Station & Utility	Man-remns per Personnel Contractor	Average Dose per Worker (Rems)	Man-remns per MW-Yr
<b>HUMBOLDT BAY (Continued)</b>											
1st commercial operation 8/63	1971	39.6	140	292	114	178	65	227	2.09	7.4	
Type - BWR	1972	43.1	127	253	81	172	57	196	1.99	5.9	
Capacity - 63 MWe	1973	50.1	210	266	60	206			1.27	5.3	
	1974	43.4	296	318	103	215			1.07	7.3	
	1975	45.3	265	339	131	208			1.28	7.5	
	1976	23.5	523	683	37	646	112	227	1.31	29.1	
	1977	0	1063	1904	24	1880	50	633	1.79	-	
	1978	0	0	320	13	322	973	931	1.05	-	
	1979	0	0	135	31	11	145	190	0.23	-	
	1980	0	0	142	22	10	2	29	0.15	-	
	1981	0	0	75	9	12	3	19	0.12	-	
	1982	0	0	71	19	5	14	0	0.27	-	
<b>INDIAN POINT 1,* 2, 3**</b>											
Docket 50-3, 50-247, 50-286;	1969	206.2			298					1.4	
DPR-5, -26, -64	1970	43.3			1639					37.8	
1st commercial operation 10/62,	1971	154.0			768					5.0	
8/73, 8/76	1972	142.3			967					6.8	
Type - PWR	1973	0			5262					-	
	1974	556.1	2998	709	4553				2415	1.75	
	1975	584.4	1019	910						0.89	
	1976	273.9	891	705						1.6	
	1977	1278.3	34.8	1950	539	47	658	0.79		1.2	
	1978	1172.3	75.3	1391	154	1796	1778	1.23		7.1	
			67.8	1909	1070	189	383	687	0.77	0.8	
					2006	260	1746	759	1.05	1.05	

\* Indian Point 1 was defueled in 1975. It had a capacity of 265 MWe. It is still included in the count of commercial reactors.

\*\* Indian Point 3 was purchased by a different utility and now reports separately.

Appendix A (Continued)  
Personnel, Dose and Power Generation Summary

Reporting Organization	Year	Mega-watt-Year (MW-Yr)	Unit Availability Factor	Total Personnel With Measurable Doses	Total Man-rem's	Man-rem's per Work Function	Man-rem's per Personnel Type		Average Dose per Worker (Rems)	Man-rem's per MW-Yr
							Maint.	Operat. & Others	Contractor	
INDIAN POINT 1,* <sup>2</sup> Docket 50-3, 50-247, DPR-5, -26 1st commercial operation 10/62, 8/73 Type - PWR Capacity - 0,864 MWe	1979 1980 1981 1982	574.0 510.8 367.5 532.4	71.4 64.8 46.0 65.4	1349 1577 2595 2144	1279 971 2731 1635	209 181 237 343	1070 790 2494 1292	612 398 1595 883	667 573 1137 752	0.95 0.62 1.05 0.76
INDIAN POINT 3** Docket 50-286; DPR-64 1st commercial operation 8/76 Type - PWR Capacity - 891 MWe	1979 1980 1981 1982	568.0 367.3 365.8 171.5	66.5 53.2 59.8 22.5	808 977 677 1477	636 308 364 1226	63 47 46 42	573 261 318 1184	482 210 255 1094	154 98 109 132	0.79 0.32 0.54 0.83
KENWAUNEE Docket 50-305; DPR-43 1st commercial operation 6/74 Type - PWR Capacity - 511 MWe	1975 1976 1977 1978 1979 1980 1981 1982	401.9 405.9 425.0 466.6 412.0 433.8 451.8 458.4	88.2 78.9 79.9 89.5 79.0 82.1 86.7 87.6	104 381 312 335 343 401 383 353	28 270 139 154 127 165 141 101	1 16 8 11 6 7 7 5	27 254 131 143 121 158 134 103	12 193 76 89 79 103 94 96	16 77 63 65 48 62 47 50	0.27 0.71 0.44 0.46 0.37 0.41 0.37 0.29

\*INDIAN POINT 1 was defueled in 1975. It had a capacity of 265 MWe. It is still included in the count of commercial reactors.

\*\*INDIAN POINT 3 was purchased by a different utility and now reports separately.

**Appendix A (Continued)**  
**Personnel, Dose and Power Generation Summary**

Reporting Organization	Year	Mega-watt-year (MW-Yr)	Unit Availability Factor	Total Personnel With Measurable Doses	Total Man-rem	Man-rem per Work Function Maint. & Others	Man-rem per Personnel Type	Man-rem per Station & Utility	Average Dose per Worker (Rems)	Man-rem per Rems per MW-Yr
							Contractor	40	71	
LACROSSE Docket 50-409; DPR-45 1st commercial operation 11/69 Type - BWR Capacity - 48 MWe	1970	15.3		218	111				0.72	7.2
	1971	33.1		151	158				1.14	4.8
	1972	29.2		157	172				1.41	5.9
	1973	24.4		115	221				1.21	9.1
	1974	37.9	81.0	139	89				1.42	3.7
	1975	32.0	69.6	234					1.42	7.3
	1976	21.2	47.6	118	40	71	6	105	0.94	5.2
	1977	11.3	33.7	141	224	60	8	216	1.59	19.8
	1978	21.6	62.0	182	164	69	6	158	0.90	7.6
	1979	24.0	71.8	153	186	65	121	21	165	1.22
	1980	26.4	68.5	124	218	63	155	11	207	1.76
	1981	29.6	76.0	187	123	62	61	3	120	0.66
	1982	17.2	44.6	148	205	65	140	16	189	1.39
										11.9
MAINE YANKEE Docket 50-309; DPR-36 1st commercial operation 12/72 Type - PWR Capacity - 810 MWe	1973	408.7		782	117				58	0.15
	1974	432.6	68.7	619	420	64	356	188	232	0.68
	1975	542.9	79.9	440	319	15	304	181	138	0.72
	1976	712.2	95.0	244	85	27	58	26	59	0.35
	1977	617.6	82.2	508	245	46	199	112	133	0.1
	1978	642.7	84.1	638	420	54	366	262	158	0.48
	1979	537.0	68.4	393	154	70	84	26	128	0.6
	1980	527.0	72.2	735	462	117	345	277	185	0.3
	1981	624.2	78.2	868	424	11	413	308	116	0.9
	1982	542.5	69.1	1295	619	33	586	462	157	0.7
										1.1

## **Personnel], Appendix A (Continued) Dose and Power Generation Summary**

\*MC GUIRE was counted for the first time in 1982.

**Appendix A (Continued)**  
**Personnel, Dose and Power Generation Summary**

Reporting Organization	Year	Mega-watt-Year (Mw-Yr)	Unit Availability Factor	Total Personnel With Measurable Doses	Total Man-rem	Man-rem per Work Function Maint. & Others	Man-rem per Work Function Maint.	Man-rem per Personnel Type Contractor	Man-rem per Station & Utility	Average Dose per Worker (Rems)	Man-rem per worker per Mw-Yr
<b>MONTICELLO</b> Docket 50-263; DPR-22 1st commercial operation 6/71 Type - BWR Capacity - 525 MWe	1972	424.4	389.5	99	61	40	21	1	60	0.62	0.1
	1973	349.3	74.9	401	176	48	128	67	109	0.44	0.4
	1974	344.8	72.2	842	349	91	258	0.41	1.0		
	1975	476.4	91.5	1353	1353	59	204	51	212	1.00	3.9
	1976	425.6	79.9	860	1000	135	865	661	339	0.81	0.5
	1977	459.4	87.2	679	375	62	313	165	210	1.16	2.3
	1978	522.0	97.6	372	157	62	95	51	106	0.42	0.8
	1979	411.8	78.2	1114	531	82	449	248	283	0.48	1.3
	1980	389.3	72.6	1446	104	101	903	756	248	0.69	2.6
	1981	291.1	63.3	1307	993	130	863	760	233	0.76	3.4
<b>NINE MILE POINT 1</b> Docket 50-220; DPR-63 1st commercial operation 12/69 Type - BWR Capacity - 610 MWe	1970	227.0		821	44	12	32	17	27	0.05	0.2
	1971	346.5		1006	195	43	152	63	132	0.19	0.6
	1972	381.8		735	285	59	226	28	257	0.39	0.7
	1973	411.0		550	567	139	428	118	449	1.03	1.4
	1974	385.9	70.5	740	824	42	782	279	545	1.11	2.1
	1975	359.0	72.1	649	681	68	613	203	478	1.05	1.9
	1976	484.6	88.2	392	428	52	376	229	199	1.09	0.9
	1977	347.4	59.2	1093	1383	41	1342	883	500	1.26	4.0
	1978	527.7	95.1	561	314	59	255	26	288	0.56	0.6
	1979	354.0	66.1	1326	1497	106	1391	940	557	1.13	4.2
	1980	533.9	92.3	1174	591	75	516	251	340	0.50	1.1
	1981	385.2	66.0	2029	1592	144	1448	1064	528	0.78	4.1
	1982	133.5	21.4	1352	1264	63	1201	944	320	0.93	9.5

**Appendix A (Continued)**  
**Personnel, Dose and Power Generation Summary**

Reporting Organization	Year	Mega-watt-Year (MW-Yr)	Unit Availability Factor	Total Personnel With Measurable Doses	Total Man-rem	Man-rem per Work Function		Man-rem per Personnel Type	Average Dose per Worker (Rems)	Man-rem per MW-Yr
						Maint. & Others	Operat. & Others			
NORTH ANNA 1, 2, Docket 50-338; NPF-04, - 09 1st commercial operation 6/78, 12/80 Type - PWR Capacity - 865, 890 MWe	1979 1980 1981 1982	507.0 681.8 1241.9 777.7	61.7 86.5 71.5 45.8	2025 2086 2416 2872	449 218 680 1915	78 128 188 78	371 90 492 1837	190 85 343 1207	259 133 337 708	0.22 0.10 0.28 0.67
OCONEE 1, 2, 3 Docket 50-269, 50-270, 50-287; DPR-38, -47, -55 1st commercial operation 7/73 9/74, 12/74 Type - PWR Capacity - 860, 860, 860 MWe	1974 1975 1976 1977 1978 1979 1980 1981 1982	650.6 1838.3 1561.4 1566.4 1909.0 1708.0 1703.7 1661.5 1293.1	60.1 75.5 63.0 65.9 75.8 67.7 70.1 66.8 52.5	844 829 1215 1595 1636 2100 2124 2445 2445	517 497 1026 1328 1393 1001 1055 1211 1792	18 72 65 244 179 123 117 113 97	499 425 961 1084 1214 878 938 1098 1695	144 90 219 294 340 181 162 275 364	373 407 807 1034 1053 820 893 936 1428	0.61 0.60 0.84 0.83 0.85 0.48 0.50 0.50 0.73
OYSTER CREEK Docket 50-219; DPR-16 1st commercial operation 12/69 Type - BWR Capacity - 620 MWe	1970 1971 1972 1973 1974 1975 1976 1977 1978 1979 1980	413.6 448.9 515.0 424.6 434.5 373.6 456.5 385.7 431.8 541.0 232.9	95 249 339 782 935 1210 1582 1673 1411 842 1966	63 240 582 1236 984 1140 1078 1614 1279 467 1733	21 50 150 195 166 169 70 76 134 95 97	42 190 432 1041 818 971 1008 1538 1145 372 1636	11 92 167 683 162 271 587 1048 696 135 1182	52 148 415 553 822 869 491 566 583 332 551	0.66 0.96 1.72 1.58 1.05 0.94 0.68 0.96 0.91 0.55 0.88	

**Appendix A (Continued)**  
**Personnel, Dose and Power Generation Summary**

Reporting Organization	Year	Mega-watt-Year (MW-Yr)	Unit Availability Factor	Total Personnel With Measurable Doses	Man-rem per Work Function		Man-rem per Personnel Type	Average Dose per Worker (Rems)	Man-rem per MW-Yr
					Total Man-rem	Man-rem per Maint. & Others			
OYSTER CREEK (Continued)	1981	314.8	59.8	1689	917	48	869	479	0.54
	1982	242.7	62.5	1270	865	33	832	491	0.68
PALISADES	1972	216.8	5.5	975	78	16	1117	661	472
Docket 50-255; DPR-20	1973	286.8	774	1133	627	23	673	109	587
1st commercial operation 12/71	1974	10.7	495	306	100	13	87	23	77
Type - PWR	1975	302.0	64.5	742	696	52	712	173	591
Capacity - 635 MWe	1976	346.9	55.2	332	764	99	755	360	494
	1977	616.6	91.4	1599	854	424	191	312	112
	1978	320.2	49.7	1307	1307	167	735	737	165
	1979	415.0	59.9	2151	902	167	257	203	127
	1980	288.3	42.9	1554	330	73			
	1981	418.2	57.2						
	1982	404.3	54.7						
PEACH BOTTOM 2, <sup>3</sup>	1975	1234.3	80.9	971	228	180	660	434	406
Docket 50-277; DPR-44, -56	1976	1379.2	73.0	2136	840	223	1813	1374	662
1st commercial operation 7/74,	1977	1052.4	58.7	2827	2036	162	1155	709	608
12/74	1978	1636.3	84.0	2244	1317	245	1143	717	671
Type - BWR	1979	1740.0	84.5	2276	1388	2302	1991	1596	1880
Capacity - 1051, 1035 MWe	1980	1374.2	66.3	2774	2857	2506	2233	311	706
	1981	1161.8	58.0	1583.3	2734	1977	1664	313	626
	1982							1347	630

Appendix A (Continued)  
Personnel, Dose and Power Generation Summary

Reporting Organization	Year	Mega-watt-Year (MW-Yr)	Unit Availability Factor	Total Personnel With Measurable Doses	Total Man-rems	Man-rems per Work Function & Others	Man-rems per Work Operations	Man-rems per Maint. & Others	Man-rems per Personnel Type & Utility		Average Dose per Worker (Rems)	Man-rems per MW-Yr
									Contractor	Station & Utility		
PILGRIM 1 Docket 50-293; DPR-35 1st commercial operation 12/72 Type - BWR Capacity - 670 MWe	1973	484.0	39.2	230	126	49	77				0.55	0.3
	1974	234.1	71.3	454	415	798	142	656	412	386	0.91	1.8
	1975	308.1	60.7	473	1317	2648	66	2582	2270	378	1.69	2.6
	1976	287.8	61.4	1875	3142	146	2996	2176	966	2.01	9.2	
	1977	316.6	83.1	1667	1327	157	1170	895	432	1.68	9.9	
	1978	519.5	89.4	2458	1015	131	884	516	499	0.80	2.5	
	1979	574.0	56.2	3549	3626	207	3419	3076	550	0.41	1.8	
	1980	360.3	65.9	2803	1836	70	1766	1418	418	1.02	10.1	
	1981	408.9	63.9	2854	1539	314	1225	1094	445	0.66	4.5	
	1982	389.9								0.54	3.9	
POINT BEACH 1, 2 Docket 50-266, 50-301; DPR-24, -27 1st commercial operation 12/70, -10/72 Type - PWR Capacity - 495 MWe	1971	393.4			164						0.4	
	1972	378.3			580							
	1973	693.7			501	588	72	516			1.17	0.8
	1974	760.2	81.3		400	295	70	225	81	214	0.74	0.4
	1975	801.2	82.9		339	459				263	1.35	0.6
	1976	857.3	86.7		313	370	58	312	107	217	1.18	0.4
	1977	873.9	87.3		417	429	63	366	212	209	1.03	0.5
	1978	914.4	90.9		336	320	71	249	111	195	0.95	0.3
	1979	808.0	80.8		610	644	65	579	449	178	1.06	0.8
	1980	727.2	82.5		561	598	60	538	420	178	1.07	0.8
	1981	760.4	83.6		773	596	83	513	364	232	0.77	0.8
	1982	757.2	84.3		767	609	72	537	375	234	0.79	

**Appendix A (Continued)**  
**Personnel, Dose and Power Generation Summary**

Reporting Organization	Year	Mega-Watt-Year (MW-Yr)	Unit Availability Factor	Total Personnel With Measurable Doses	Total Man-rem	Man-rem per Work Function Maint. & Others	Man-rem per Work Operations	Man-rem per Personnel Contractor	Man-rem per Personnel Type	Average Dose per Worker (Rems)	Man-rem per Station & Utility	Average Dose per MW-Yr
						Maint.	Contrac-	Type	Utility			
PRAIRIE ISLAND 1, 2 Docket 50-282, 50-306; DPR-42, -60 1st commercial operation 12/73, 12/74 Type - PWR Capacity - 503, 500 MWe	1974	181.9	43.9	150	18	123	68	379	235	0.12	0.26	0.1
	1975	836.0	83.3	477	447	300	73	227	60	0.55	212	0.6
	1976	725.2	76.6	818	447	221	43	178	48	0.42	240	0.3
	1977	922.9	87.2	718	300	180	29	151	49	0.40	173	0.2
	1978	941.1	92.2	546	221	353	40	313	141	0.30	131	0.2
	1979	865.0	86.0	594	180	329	153	176	128	0.36	212	0.4
	1980	800.7	79.9	983	353	329	153	199	68	0.39	201	0.4
	1981	844.9	80.5	836	40	229				0.36	161	
	1982	944.9	90.4	645								
QUAD CITIES 1, 2 Docket 50-254, 50-265; DPR-29, -30 1st commercial operation 2/73, 3/73 Type - BWR Capacity - 769, 769 MWe	1974	958.1	72.3	678	482	1618	114	1504	36	0.71	446	0.5
	1975	833.6	68.4	1083	1225	1651	269	1382	692	1.49	926	1.9
	1976	951.2	73.1	1083	907	1031	108	923	648	1.35	1003	1.7
	1977	970.1	84.0	1207	1618	156	1462	373	373	1.14	658	1.1
	1978	1124.5	88.6	1688	2158	215	1943	722	722	1.34	896	1.4
	1979	1075.0	84.6	3089	4838	291	4547	1250	908	1.28	908	2.0
	1980	866.9	64.4	2246	3146	100	3046	3657	1181	1.57	1181	5.6
	1981	1156.9	81.1	2314	3757	177	3580	2623	523	1.40	2623	2.7
	1982	1018.7	76.0					2653	2653	1.62	1104	3.7
RANCHO SECO Docket 50-312; DPR-54 1st commercial operation 4/75 Type - PWR Capacity - 873 MWe	1976	268.1	30.4	297	58	6	52	17	41	0.19	0.76	0.2
	1977	706.4	77.1	515	390	61	329	248	142	0.64	147	0.5
	1978	607.7	80.5	508	323	76	247	176	62	0.44	62	0.5
	1979	687.0	91.1	287	126	27	99	64	131	0.46	281	0.8
	1980	530.9	60.4	890	412	110	302	319	266	0.52	137	1.3
	1981	321.2	40.2	772	402	83	49	337	217	0.44	120	0.8
	1982	409.5	53.3	766								

Appendix A (Continued)  
Personnel, Dose and Power Generation Summary

Reporting Organization	Year	Mega-watt-Year (MW-Yr)	Unit Availability Factor	Total Personnel With Measurable Doses	Man-rems per Work Function			Man-rems per Personnel Type	Man-rems per Station & Utility	Average Dose per Worker (Rads)	Man-rems per MW-Yr
					Total Man-rems	Operat. & Others	Maint. & Others				
ROBINSON 2 Docket 50-261; DPR-23 1st commercial operation 3/71 Type - PWR Capacity - 665 MWe	1972	580.0	245	215	42	173	137	78	0.88	0.4	
	1973	455.1	83.3	831	695	487			0.84	1.5	
	1974	578.1	72.7	853	672				0.79	1.2	
	1975	501.8	84.7	849	1142				1.34	2.3	
	1976	585.5	84.7	597	715	30	685	457	1.20	1.2	
	1977	511.5	85.2	634	455	52	403	223	0.72	0.9	
	1978	480.5	72.0	943	963	63	900	529	1.02	2.0	
	1979	482.0	70.8	1454	1188	60	1128	794	0.82	2.5	
	1980	387.3	62.2	2009	1852	79	1773	1379	0.92	4.8	
	1981	426.6	73.0	1462	733	45	688	513	0.50	1.7	
SALEM 1, 2* Docket 50-272,-311; DPR-70,-75 1st commercial operation 6/77, 10/81 Type - PWR Capacity - 1079, 1106, MWe	1978	546.4	55.6	574	122	28	94	32	90	0.21	0.2
	1979	250.0	25.5	1488	584	100	484	359	225	0.39	2.3
	1980	680.6	69.2	1704	449	55	394	281	168	0.26	0.7
	1981	743.0	78.1	1652	254	4	250	152	102	0.15	0.3
	1982	1440.4	72.6	3228	1203	66	1137	846	357	0.37	6.8
SAN ONOFRE 1 Docket 50-206; DPR-13 1st commercial operation 1/68 Type - PWR Capacity - 436 MWe	1969	314.1		123	42	10	32	5	37	0.34	0.1
	1970	365.9		251	155	13	142	59	96	0.62	0.4
	1971	362.1		121	50	12	38	3	47	0.41	0.1
	1972	338.5		326	256	29	227	117	139	0.78	0.8
	1973	273.7		570	353	40	313	168	185	0.62	1.3
	1974	377.8		219	71					0.32	0.2
	1975	389.0		424	292					0.69	0.7

\*SALEM 2 and SEQUOYAH 1 were counted for the first time in 1982.

Appendix A (Continued)  
Personnel, Dose and Power Generation Summary

Reporting Organization	Year	Mega-watt-Year (MW-Yr)	Unit Availability Factor	Total Personnel With Measurable Doses	Total Man-rems	Operational Work Functions	Man-rems per Work Function	Man-rems per Personnel Type		Average Dose per Worker (Rems)	Man-rems per MW-Yr
								Contractor	Station & Utility		
SAN ONOFRE 1 (Continued)	1976	297.9	70.2	1330	880	147	733	629	251	0.66	2.9
	1977	281.2	63.7	985	847	77	770	451	396	0.86	3.0
	1978	323.2	80.2	764	401	25	376	234	167	0.52	1.2
	1979	401.0	90.2	521	139	23	116	65	74	0.27	0.3
	1980	97.3	22.3	3063	2387	219	2168	2018	369	0.78	24.5
	1981	95.9	26.7	2902	3223	100	3123	3104	119	1.11	33.6
	1982	61.6	15.7	3055	832	81	751	729	102	0.27	13.5
SEQUOYAH 1*	1982	583.5	52.8	1965	570	67	503	57	513	0.29	1.0
83 Docket 50-327; DPR-77 1st commercial operation 7/81 Type - PWR Capacity - 1128 MWe											
ST. LUCIE 1	1977	649.1	84.7	445	152	26	126	92	60	0.34	0.2
	1978	606.4	76.5	797	337	15	322	140	197	0.42	0.6
	1979	592.0	74.0	907	438	25	413	209	229	0.48	0.7
	1980	627.9	77.5	1074	532	82	450	195	337	0.50	0.8
	1982	816.8	94.0	1045	272	17	255	105	167	0.26	0.3

\*SALEM 2 and SEQUOYAH 1 were counted for the first time in 1982.

**Appendix A (Continued)**  
**Personnel, Dose and Power Generation Summary**

Reporting Organization	Year	Mega-watt-Year (MW-Yr)	Unit Availability Factor	Total Personnel With Measurable Doses	Total Man-rem	Man-rem per Work Functions	Man-rem per Maint. & Others	Personnel Type		Average Dose per Worker (Rems)	Man-rem per MW-Yr
								Contractor	Station & Utility		
SURRY 1, 2 Docket 50-280, 50-281; DPR-32, -37 1st commercial operation 12/72, 5/73	1973 1974 1975 1976 1977 1978 1979 1980 1981 1982	420.6 717.4 1079.0 930.7 1139.0 1210.6 34.3.0 568.2 907.6 1323.3	49.8 70.8 60.4 72.2 77.2 42.3 40.3 59.3 88.5	936 1715 1948 2753 1860 2203 5065 5317 3753 1878	152 884 1649 3165 2307 1837 3584 3836 4244 1490	72 27 44 348 726 173 353 353 428 399	812 1622 2721 1959 1111 3411 3483 3816 1091	1065 1873 1292 1380 1029 2975 3117 719 506	584 1292 927 808 609 609 719 1204 984	0.16 0.51 0.85 1.15 1.24 0.83 0.71 0.72 0.79	0.4 1.2 1.5 3.4 2.0 1.5 10.4 6.6 4.7
*THREE MILE ISLAND 1, 2 Docket 50-289; DPR-50, -73 1st commercial operation-9/74, 12/78	1975 1976 1977 1978 1979 1980 1981 1982	675.9 530.0 664.5 690.5 266.0 0.0 0.0 0.0	82.2 65.4 80.9 85.1 21.9 0.0 0.0 0.0	131 819 1122 1929 4024 2328 2103 2123	73 286 359 504 1392 394 376 1004	23 15 23 197 197 29 50 62	263 344 481 1195 1365 234 326 942	18 69 128 481 907 234 190 433	55 217 231 235 485 160 186 571	0.56 0.35 0.32 0.26 0.26 0.35 0.17 0.47	0.1 0.5 0.5 0.5 0.7 - - -
TROJAN Docket 50-344; NPF-1 1st commercial operation 5/76	1977 1978 1979 1980 1981 1982	792.0 205.5 631.0 727.5 775.6 579.5	92.6 20.6 58.1 72.5 74.1 60.8	591 711 736 1159 1311 977	174 319 257 421 609 419	30 81 74 77 113 76	144 238 183 344 496 343	105 124 113 116 363 168	69 195 144 305 246 251	0.29 0.45 0.35 0.36 0.46 0.42	0.2 1.5 0.4 0.6 0.8 0.7

\*Three Mile Island 1 and 2 are shutdown. They are still included in the count of commercial reactors.

Appendix A (Continued)  
Personnel, Dose and Power Generation Summary

Reporting Organization	Year	Mega-watt-Year (MW-Yr)	Unit Availability Factor	Total Personnel With Measurable Doses	Total Man-rem's	Man-rem's per Work Function	Average Dose per Worker (Rems)	Man-rem's per Personnel Type		Man-rem's per MW-Yr
								Contractor	Station & Utility	
TURKEY POINT 3, 4 Docket 50-250; DPR-31; DPR-32, -41 1st commercial operation 12/72, 9/73	1973	401.9	953.6	444	78	366	202	252	0.18	0.2
Type - PWR Capacity - 646 MWe	1974	1003.7	74.9	794	454	88	606	559	0.57	0.5
	1975			1176	876	270	1095	868	0.74	0.9
	1976	974.2	71.2	1647	1184	89	942	522	0.72	1.2
	1977	979.5	72.1	1319	1036	94	942	514	0.78	1.1
	1978	1000.2	78.8	1336	1032	90	942	486	0.77	1.0
	1979	811.0	62.4	2002	1680	299	1381	997	683	0.84
	1980	990.6	73.6	1803	1651	232	1419	1218	433	2.1
	1981	654.0	46.8	2932	2251	274	1977	1854	397	1.7
	1982	915.7	65.2	2956	2119	197	1922	1656	463	3.4
									0.72	2.3
VERMONT YANKEE Docket 50-271; DPR-28 1st commercial operation 11/72	1973	222.1	216	244	85	216	24	192	103	0.35
Type - BWR Capacity - 504 MWe	1974	303.5	87.8	357	153	70	83	63	113	0.60
	1975	429.0	77.1	282	411	36	375	246	90	0.54
	1976	389.6	85.1	641	258	83	175	90	165	0.50
	1977	423.5	75.9	934	339	78	261	158	168	1.0
	1978	387.5	82.1	1220	1170	546	624	642	181	0.40
	1979	414.0	71.5	1443	1338	141	1197	926	528	0.36
	1980	357.8	84.6	1264	731	121	610	408	412	0.9
	1981	429.1	96.0	781	205	60	145	80	323	2.8
	1982	501.0							125	0.58
									0.43	1.7
										0.4
YANKEE ROWE Docket 50-29; DPR-3 1st commercial operation 7/61	1969	138.3		193	215	83	132	78	133	1.11
Type - PWR Capacity - 175 MWe	1970	146.1		355	255	90	165	158	97	0.72
	1971	173.5		155	90	46	44	19	71	1.7
	1972	78.7		282	255	63	192	146	109	0.58
	1973	127.1		133	99		47	52	52	0.5
										3.2
										0.8

**Appendix A (Continued)**  
**Dose and Power Generation Summary**

Reporting Organization	Year	Mega-watt-year (MW-Yr)	Unit Availability Factor	Total Personnel With Measurable Doses	Total Man-rems	Man-rems per Work Function		Man-rems per Personnel Type	Average Dose per Worker (Rems)	Man-rems per MW-Yr
						Oper-ations	Maint. & Others			
<b>YANKEE Rowe (Continued)</b>										
	1974	111.3	243	205	64	99	106	.84	1.8	
	1975	145.1	249	116	42	66	50	0.47	0.8	
	1976	152.2	152	59	28	328	4	0.39	0.4	
	1977	124.6	725	356	26	256	174	182	0.49	2.9
	1978	145.0	81.0	565	127	16	95	187	0.50	1.9
	1979	149.0	81.6	441	213	6	111	52	0.29	0.9
	1980	35.6	22.0	502	302	8	207	90	0.42	6.0
	1981	109.0	74.4	515	468	6	294	136	0.59	2.8
	1982	108.6	73.4	474			215	259	0.54	4.4
<b>ZION 1, 2</b>										
	1974	425.3	71.1	306	56	17	110	43	0.18	0.1
	1975	1181.5	74.9	436	127	64	49	78	0.29	0.1
	1976	1134.9	61.9	774	571	1003	507	314	0.74	0.5
	1977	1358.6	75.0	784	43	1017	960	442	1.28	0.7
	1978	1613.5	80.2	1104	150	1274	867	418	0.92	0.6
	1979	1238.0	67.6	1472	168	1106	747	527	0.87	1.0
	1980	1411.2	74.1	1363	920	97	823	560	0.67	0.7
	1981	1366.9	72.3	1754	1720	50	1670	1155	0.98	1.3
	1982	1186.4	64.3	1575	2103	42	2061	1688	415	1.34

**APPENDIX B**

**Annual Whole Body Doses at Licensed Nuclear Power Facilities  
1982**

**APPENDIX B**  
**ANNUAL WHOLE BODY DOSES AT LICENSED NUCLEAR POWER FACILITIES**  
**1982**

PLANT NAME and TYPE	Number of Individuals with Whole Body Doses in the Following Ranges (Rems)										Total Number Monitored	Number with Measurable Exposure	Total Man-Rems	
	No Measurable Exposure <0.10	Measurable 0.10-0.25	0.25-0.50	0.50-0.75	0.75-1.0	1.0-2.0	2.0-3.0	3.0-4.0	4.0-5.0	5.0-6.0	6.0-7.0	7.0-8.0	8.0-9.0	9.0-10.0
Arkansas 1, 2 PWRs	682	637	268	225	130	93	178	62	12	3				2,290
Beaver Valley PWR	825	738	317	288	155	91	141	25						2,580
Big Rock Point BWR	129	246	58	36	30	26	82	27	12	4				650
Browns Ferry 1, 2, 3 BWRs	3,075	789	565	541	332	258	498	214	80					6,352
Brunswick 1, 2 BWRs	1,372	2,181	480	396	273	206	639	472	310					3,277
Calvert Cliffs 1, 2 PWRs	929	508	350	290	146	153	283	52	22	1				6,329
Cook 1, 2 PWRs	722	503	282	250	191	110	164	25	2					2,734
Cooper Station BWR	1,631	262	63	74	72	65	144	48	15					1,805
Crystal River 3 PWR	1,415	409	173	101	60	10	25	2						1,057
Davis-Besse PWR	1,298	932	269	83	36	15	15							2,249
Dresden 1, 2, 3 BWRs	672	587	294	259	223	147	444	399	174	43	2			1,527
Duane Arnold BWR	767	274	74	48	33	24	44	18	9					699
Farley 1, 2* PWRs	124	632	285	205	133	94	100	4						2,195
Fitzpatrick BWR	688	789	372	318	252	204	307	50	29	1				2,648
Fort Calhoun PWR	228	335	83	74	39	13	40	10	8	2				3,010
Gimna PWR	436	248	130	131	125	76	219	109	45	34				832
														604
														217
														1,553
														1,117
														1,140

\* Plants counted for the first time in 1982.

\*\* These plants provided their actual collective dose in their 20-407 reports. The collective dose shown for the other plants is calculated by NRC staff.

**APPENDIX B**  
**ANNUAL WHOLE BODY DOSES AT LICENSED NUCLEAR POWER FACILITIES**  
**1982**

PLANT NAME and TYPE	No. Measurable Exposure	Measurable Exposure <0.10	Number of Individuals with Whole Body Doses in the Following Ranges (Rems)									Total Number Monitored	Number with Measurable Exposure	Total Man-Rems					
			0.10-0.25	0.25-0.50	0.50-0.75	0.75-1.0	1.0-2.0	2.0-3.0	3.0-4.0	4.0-5.0	5.0-6.0	6.0-7.0	7.0-8.0	8.0-9.0	9.0-10.0	>12.0			
Haddam Neck	PWR	530	323	111	65	17	10	26	7								1,089	559	126**
Hatch 1, 2	BWRs	1,287	1,197	719	628	347	149	274	85	17	2						4,705	3,418	1,460
Humboldt Bay	BWR	86	31	16	13	5	4	2									157	71	19
Indian Point 1, 2	PWRs	694	575	309	272	233	155	408	133	46	12	0	0	0	0	1	2,838	2,144	1,635
Indian Point 3	PWR	676	348	246	188	124	93	277	185	14	2						2,153	1,477	1,226
Keweenaw	PWR	300	161	65	61	29	25	11	1								653	353	101
LaCrosse	BWR	35	42	12	8	9	6	28	18	13	12						183	148	205
Maine Yankee	PWR	285	533	178	159	101	113	189	21	1							1,580	1,295	619
McGuire 1*	PWR	2,004	1,067	275	156	42	12	8									3,564	1,560	169**
Millstone 1	BWR	375	379	178	185	154	126	236	103	9							1,745	1,370	929**
Millstone 2	PWR	571	574	269	290	232	188	358	157	14	1						2,654	2,083	1,413**
Monticello	BWR	1,203	349	212	222	102	72	210	87	43	10						2,510	1,307	993
Nine Mile Point	BWR	721	354	190	153	121	86	228	132	65	21	2					2,073	1,352	1,264
North Anna 1, 2	PWRs	489	1,453	310	225	150	103	317	158	84	44	25	3				3,361	2,872	1,915
Oconee 1, 2, 3	PWRs	1,024	729	353	278	206	151	453	216	55	4						3,469	2,445	1,792**
Oyster Creek	BWR	480	417	163	160	138	94	195	71	28	3	1					1,750	1,270	865

\* Plants counted for the first time in 1982.

\*\* These plants provided their actual collective dose in their 20,407 reports. The collective dose shown for the other plants is calculated by NRC staff.

**APPENDIX B**  
**ANNUAL WHOLE BODY DOSES AT LICENSED NUCLEAR POWER FACILITIES**  
1982

NAME and TYPE	Number of Individuals with Whole Body Doses in the Following Ranges (Rems)										Total Number Monitored	Number with Measurable Exposure	Total Man-Rems
	No Measurable Exposure	Measurable <0.10	0.10-0.25	0.25-0.50	0.50-0.75	0.75-1.0	1.0-2.0	2.0-3.0	3.0-4.0	4.0-5.0			
Palisades PWR	154	1,006	227	149	74	34	54	8	2				1,708
Peach Bottom 2, 3 BWRs	1,566	731	277	492	304	241	475	168	35	9	2		4,300
Pilgrim 1 BWR	0	881	473	644	244	153	323	83	46	7			2,854
Point Beach 1, 2 PWRs	224	169	106	120	74	60	175	48	12	3			991
Prairie Island 1, 2 PWRs	410	216	153	131	61	36	47	1				1,055	645
Quad Cities 1, 2 BWRs	817	274	190	151	152	152	596	383	298	118			3,131
Rancho Seco PWR	300	285	139	151	64	33	70	17	6	1			766
Robinson 2 PWR	1,144	929	193	161	114	80	287	158	82	7			3,155
Salem 1, 2* PWRs	1,195	1,388	647	490	189	170	296	42	6				1,426
San Onofre PWR	5,357	1,902	338	287	167	103	191	60	7				4,423
Sequoayah 1* PWR	2,219	869	395	318	160	94	121	8					8,412
St. Lucie PWR	569	568	191	126	64	38	55	3					3,228
Surry 1, 2 PWR	400	751	394	125	87	86	167	116	72	43	23	10	4
Three Mile Isl. 1, 2 PWRs	607	1,033	288	197	124	122	269	77	11	2			2,730
Trojan PWR	103	335	258	139	79	47	89	25	4	1			6,080
Turkey Point 3, 4 PWRs	1,286	711	459	477	323	215	550	165	55	1			4,242
													2,956
													2,119

\* Plants counted for the first time in 1982.

\*\* These plants provided their actual collective dose in their 20-407 reports. The collective dose shown for the other plants is calculated by NRC staff.

**APPENDIX B  
ANNUAL WHOLE BODY DOSES AT LICENSED NUCLEAR POWER FACILITIES  
1982**

PLANT NAME and TYPE		Number of Individuals with Whole Body Doses in the Following Ranges (Rems)												Number with Measurable Exposure				Total Number Monitored		Number with Measurable Exposure		Total Number Monitored	
No. Measurable Exposure	Meas. Expos. < 0.10	0.10-0.25	0.25-0.50	0.50-0.75	0.75-1.0	1.0-2.0	2.0-3.0	3.0-4.0	4.0-5.0	5.0-6.0	6.0-7.0	7.0-8.0	8.0-9.0	9.0-10.0	> 10.0	Total Number Monitored	Total Number Monitored	Total Number Monitored	Total Number Monitored				
Vermont Yankee	BWR	757	161	95	75	48	33	69									1,238	481	205				
Yankee-Roxe	PWR	1,275	383	60	79	59	45	121	57	9	1						2,089	814	474**				
Zion 1, 2	PWR	757	285	141	120	112	81	357	376	62	40	1					2,332	1,575	2,103				
BWR Totals		15,661	9,944	4,431	4,403	2,839	2,046	4,794	2,358	1,183	230	7					47,896	32,235	24,437				
PWR Totals		29,232	21,536	8,262	6,411	3,900	2,749	6,061	2,328	631	202	49	13	4	0	1	81,378	52,146	27,753				
Fort St. Vrain	HTGR	978	22															1,000	22	0**			

These plants provided their actual collective dose in their 20,407 reports. The collective dose shown for the other plants is calculated by NRC staff.



**APPENDIX C**  
**Number of Personnel and Man-rems by Work and Job Function**  
**1982**

Note: A 't' preceding a plant name indicates that the licensee's input was recategorized by NRC staff.

**APPENDIX C**

NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION  
(PWR) 1982

WORK & JOB FUNCTION	STATION EMPLOYEES		TOTAL CONTRACT & OTHERS		STATION EMPLOYEES		TOTAL CONTRACT & OTHERS		TOTAL MAN-REMS	
	MAINTENANCE PERSONNEL	OPERATING PERSONNEL	HEALTH PHYSICS PERSONNEL	SUPERVISORY PERSONNEL	ENGINEERING PERSONNEL	MAINTENANCE PERSONNEL	OPERATING PERSONNEL	HEALTH PHYSICS PERSONNEL	SUPERVISORY PERSONNEL	ENGINEERING PERSONNEL
ROUTINE MAINTENANCE										
MAINTENANCE PERSONNEL	106	2	114	0	0	46	390	0	507	49,148
OPERATING PERSONNEL	1	0	0	0	0	0	237	0	0	0,0
HEALTH PHYSICS PERSONNEL	27	0	0	12	0	8	170	0	0	3,140
SUPERVISORY PERSONNEL	1	0	0	1	0	0	120	0	0	0,158
ENGINEERING PERSONNEL	0	2	0	1	0	0	0	0	0	0,321
TOTAL	126	3	69	198	58,025	0	370	0	507	22,217
										80,672
IN-SERVICE INSPECTION										
MAINTENANCE PERSONNEL	10	1	38	0	0	3,453	0	277	10,336	
OPERATING PERSONNEL	1	0	0	0	0	0	338	0	0	
HEALTH PHYSICS PERSONNEL	4	0	3	0	0	2,526	0	0	0	0,472
SUPERVISORY PERSONNEL	1	0	0	0	0	1,057	0	0	0	0,194
ENGINEERING PERSONNEL	1	3	7	0	0	0,216	0	458	0	2,528
TOTAL	135	2	135	272	54,917	0	735	13,336	21,661	112,191
SPECIAL MAINTENANCE										
MAINTENANCE PERSONNEL	89	4	340	0	0	61,219	1	147	229,049	
OPERATING PERSONNEL	11	0	41	0	0	3,373	0	0	0	
HEALTH PHYSICS PERSONNEL	34	0	2	0	0	20,288	0	0	0	16,485
SUPERVISORY PERSONNEL	4	0	2	0	0	1,096	0	0	0	
ENGINEERING PERSONNEL	4	1	21	0	0	1,065	0	105	0	8,958
TOTAL	142	5	404	551	87,041	0	1,252	255,686	343,979	
WASTE PROCESSING										
MAINTENANCE PERSONNEL	23	0	39	0	0	5,167	0	0	0	29,208
OPERATING PERSONNEL	4	0	0	0	0	0,784	0	0	0	0,0
HEALTH PHYSICS PERSONNEL	12	0	4	0	0	7,457	0	0	0	1,304
SUPERVISORY PERSONNEL	1	0	0	0	0	0,148	0	0	0	0,0
ENGINEERING PERSONNEL	0	0	2	0	0	0,0	0	0	0	1,110
TOTAL	40	0	45	85	13,556	0	0	31,622	45,178	
REFUELING										
MAINTENANCE PERSONNEL	54	1	96	0	0	17,948	0	172	29,888	
OPERATING PERSONNEL	22	0	0	14	1	4,491	0	0	0	
HEALTH PHYSICS PERSONNEL	7	0	1	0	0	1,485	0	0	0	3,238
SUPERVISORY PERSONNEL	2	0	23	0	0	0,529	0	0	0	0,367
ENGINEERING PERSONNEL	3	0	134	223	24,909	0	0	8,201	25,297	
TOTAL	88	1	0	0	0	0	0	0	0	66,775
TOTAL BY JOB FUNCTION										
MAINTENANCE PERSONNEL	314	9	642	0	0	146,235	2	205	350,670	499,110
OPERATING PERSONNEL	98	0	0	127	12	37,388	0	0	0	37,388
HEALTH PHYSICS PERSONNEL	117	0	0	4	15	57,453	0	0	43,696	101,149
SUPERVISORY PERSONNEL	11	0	4	0	0	3,225	0	0	1,719	4,944
ENGINEERING PERSONNEL	8	6	62	76	1,737	0	831	25,297	27,865	
GRAND TOTAL	548	15	835	1398	246,038	3,036	421,382	670,456		

**APPENDIX C**  
**PLANT: BEAVER VALLEY (PWR)**  
**NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION**

WORK & JOB FUNCTION	1982			TOTAL
	STATION EMPLOYEES	UTILITY CONTRACT	TOTAL	
EMPLOYEES & OTHERS	PERSONS	STATION EMPLOYEES	UTILITY EMPLOYEES	EMPLOYEES & OTHERS
<b>REACTOR OPERATIONS &amp; SURV.</b>				
MAINTENANCE PERSONNEL	7	0	36	1.375
OPERATING PERSONNEL	39	0	10.850	0.0
HEALTH PHYSICS PERSONNEL	31	1	8.600	0.150
SUPERVISORY PERSONNEL	12	0	3.530	0.0
ENGINEERING PERSONNEL	5	2	1.555	0.215
<b>TOTAL</b>	<b>94</b>	<b>3</b>	<b>278</b>	<b>25.910</b>
ROUTINE MAINTENANCE				
MAINTENANCE PERSONNEL	75	3	271	54.410
OPERATING PERSONNEL	2	0	0	0.305
HEALTH PHYSICS PERSONNEL	2	0	0	0.355
SUPERVISORY PERSONNEL	11	0	1	4.455
ENGINEERING PERSONNEL	6	0	26	0.815
<b>TOTAL</b>	<b>96</b>	<b>3</b>	<b>403</b>	<b>60.340</b>
IN-SERVICE INSPECTION				
MAINTENANCE PERSONNEL	0	0	8	0.0
OPERATING PERSONNEL	1	0	0	0.145
HEALTH PHYSICS PERSONNEL	0	0	1	0.0
SUPERVISORY PERSONNEL	1	0	0	0.165
ENGINEERING PERSONNEL	4	0	7	1.260
<b>TOTAL</b>	<b>6</b>	<b>0</b>	<b>16</b>	<b>1.570</b>
SPECIAL MAINTENANCE				
MAINTENANCE PERSONNEL	21	0	312	7.680
OPERATING PERSONNEL	0	0	0	0.0
HEALTH PHYSICS PERSONNEL	2	0	12	0.485
SUPERVISORY PERSONNEL	2	0	5	0.230
ENGINEERING PERSONNEL	2	0	16	1.030
<b>TOTAL</b>	<b>27</b>	<b>0</b>	<b>345</b>	<b>9.425</b>
WASTE PROCESSING				
MAINTENANCE PERSONNEL	5	0	7	1.045
OPERATING PERSONNEL	2	0	0	1.330
HEALTH PHYSICS PERSONNEL	0	0	2	0.0
SUPERVISORY PERSONNEL	3	0	0	1.580
ENGINEERING PERSONNEL	0	0	0	0.0
<b>TOTAL</b>	<b>10</b>	<b>0</b>	<b>9</b>	<b>3.955</b>
REFUELING				
MAINTENANCE PERSONNEL	14	0	20	5.060
OPERATING PERSONNEL	0	0	0	0.0
HEALTH PHYSICS PERSONNEL	0	0	2	0.0
SUPERVISORY PERSONNEL	3	0	0	0.545
ENGINEERING PERSONNEL	3	0	3	2.685
<b>TOTAL</b>	<b>20</b>	<b>0</b>	<b>25</b>	<b>8.290</b>
<b>TOTAL BY JOB FUNCTION</b>				
MAINTENANCE PERSONNEL	122	3	654	779
OPERATING PERSONNEL	44	0	0	44
HEALTH PHYSICS PERSONNEL	35	1	134	170
SUPERVISORY PERSONNEL	32	0	15	47
ENGINEERING PERSONNEL	20	2	77	99
<b>GRAND TOTAL</b>	<b>253</b>	<b>6</b>	<b>880</b>	<b>1139</b>

\*\* Majority of collective dose due to TMI-type modifications.

**PLANT: BIG ROCK POINT \***

(BWR) (1982)

**APPENDIX C**

WORK & JOB FUNCTION	NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION					TOTAL MAN-REMS	
	NUMBER OF PERSONNEL (>100 M-REM)		TOTAL		STATION EMPLOYEES		
	STATION EMPLOYEES	UTILITY CONTRACT	PERSONS	EMPLOYEES			
REACTOR OPERATIONS & SURV.							
MAINTENANCE PERSONNEL	27	73	79	10.035	3.953	3.069	
OPERATING PERSONNEL	49	8	17	40.288	0.538	1.743	
HEALTH PHYSICS PERSONNEL	15	28	7	24.804	3.579	4.554	
SUPERVISORY PERSONNEL	30	59	14	11.767	2.730	1.055	
ENGINEERING PERSONNEL	24	45	49	5.714	1.304	3.416	
<b>TOTAL</b>	<b>145</b>	<b>213</b>	<b>166</b>	<b>92.608</b>	<b>12.104</b>	<b>13.837</b>	
ROUTINE MAINTENANCE							
MAINTENANCE PERSONNEL	31	58	49	47.949	12.453	5.164	
OPERATING PERSONNEL	25	0	1	1.886	0.0	0.137	
HEALTH PHYSICS PERSONNEL	10	0	4	0.674	0.0	0.100	
SUPERVISORY PERSONNEL	7	8	4	1.080	0.279	0.274	
ENGINEERING PERSONNEL	5	9	5	0.353	1.144	0.986	
<b>TOTAL</b>	<b>78</b>	<b>75</b>	<b>63</b>	<b>51.942</b>	<b>13.876</b>	<b>6.661</b>	
IN-SERVICE INSPECTION							
MAINTENANCE PERSONNEL	7	48	25	1.227	30.913	23.081	
OPERATING PERSONNEL	10	1	3	1.919	0.029	0.166	
HEALTH PHYSICS PERSONNEL	10	5	7	1.616	1.058	3.038	
SUPERVISORY PERSONNEL	4	10	1	0.910	2.919	0.643	
ENGINEERING PERSONNEL	6	2	5	0.861	1.254	0.995	
<b>TOTAL</b>	<b>37</b>	<b>66</b>	<b>41</b>	<b>6.533</b>	<b>36.173</b>	<b>7.323</b>	
SPECIAL MAINTENANCE							
MAINTENANCE PERSONNEL	17	23	8	7.289	5.170	3.912	
OPERATING PERSONNEL	13	2	0	0.414	0.204	0.0	
HEALTH PHYSICS PERSONNEL	9	2	0	1.502	0.099	0.0	
SUPERVISORY PERSONNEL	6	0	0	0.925	0.0	0.0	
ENGINEERING PERSONNEL	0	0	2	0.0	0.0	0.563	
<b>TOTAL</b>	<b>45</b>	<b>27</b>	<b>10</b>	<b>8.2</b>	<b>10.130</b>	<b>5.473</b>	
WASTE PROCESSING							
MAINTENANCE PERSONNEL	13	3	4	1.984	0.281	3.994	
OPERATING PERSONNEL	24	0	0	1.503	0.0	0.0	
HEALTH PHYSICS PERSONNEL	12	9	1	0.872	0.135	0.211	
SUPERVISORY PERSONNEL	1	0	1	0.011	0.0	0.043	
ENGINEERING PERSONNEL	1	0	2	0.010	0.0	0.341	
<b>TOTAL</b>	<b>51</b>	<b>12</b>	<b>8</b>	<b>4.380</b>	<b>0.416</b>	<b>4.602</b>	
REFUELING							
MAINTENANCE PERSONNEL	6	0	0	1.038	0.0	0.0	
OPERATING PERSONNEL	32	0	1	3.788	0.0	0.058	
HEALTH PHYSICS PERSONNEL	8	0	1	0.105	0.0	0.015	
SUPERVISORY PERSONNEL	5	0	2	0.484	0.0	0.341	
ENGINEERING PERSONNEL	6	2	10	0.204	0.006	4.540	
<b>TOTAL</b>	<b>57</b>	<b>2</b>	<b>14</b>	<b>5.619</b>	<b>0.006</b>	<b>4.954</b>	
TOTAL BY JOB FUNCTION							
MAINTENANCE PERSONNEL	101	205	165	471	52.770	39.220	
OPERATING PERSONNEL	153	11	22	186	49.798	2.104	
HEALTH PHYSICS PERSONNEL	64	44	20	128	29.362	52.673	
SUPERVISORY PERSONNEL	53	77	22	152	15.177	4.871	
ENGINEERING PERSONNEL	42	58	73	173	7.142	3.708	
<b>GRAND TOTAL</b>	<b>413</b>	<b>395</b>	<b>302</b>	<b>1110</b>	<b>171.212</b>	<b>61.852</b>	

\* Workers may be counted in more than one category.

\*\* Includes valve and pump repair, steam line repairs, chemical tank piping replacement, recirculating pump temperature sensor and sump repair.

**APPENDIX C**  
**NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION**

WORK & JOB FUNCTION	NUMBER OF PERSONNEL AND MAN-REM (BWR) 1982			TOTAL		
	STATION EMPLOYEES	UTILITY CONTRACT	TOTAL	STATION EMPLOYEES	UTILITY CONTRACT	TOTAL
REACTOR OPERATIONS & SURV.	EMPLOYEES & OTHERS	PERSONS	EMPLOYEES	EMPLOYEES & OTHERS	MAN-REMS	
MAINTENANCE PERSONNEL	48	112	23	16	600	29.600
OPERATING PERSONNEL	90	0	0	22.000	0.0	16.500
HEALTH PHYSICS PERSONNEL	25	0	58	7.700	0.0	0.0
SUPERVISORY PERSONNEL	0	0	0	0.0	0.0	26.900
ENGINEERING PERSONNEL	0	43	0	0.0	0.0	0.0
<b>TOTAL</b>	<b>163</b>	<b>155</b>	<b>81</b>	<b>399</b>	<b>46.300</b>	<b>51.200</b>
ROUTINE MAINTENANCE				184.800	696.100	125.600
MAINTENANCE PERSONNEL	324	936	195	75.200	0.0	0.0
OPERATING PERSONNEL	161	0	0	13.000	0.0	41.400
HEALTH PHYSICS PERSONNEL	30	0	68	0.0	0.0	0.0
SUPERVISORY PERSONNEL	0	0	0	0.0	0.0	0.0
ENGINEERING PERSONNEL	0	93	0	0.0	45.000	0.0
<b>TOTAL</b>	<b>515</b>	<b>1029</b>	<b>263</b>	<b>18.07</b>	<b>273.000</b>	<b>741.100</b>
IN-SERVICE INSPECTION				0.0	0.700	0.500
MAINTENANCE PERSONNEL	0	0	0	0.0	0.0	0.0
OPERATING PERSONNEL	0	0	0	0.0	0.0	0.0
HEALTH PHYSICS PERSONNEL	0	0	0	0.0	0.0	0.0
SUPERVISORY PERSONNEL	0	0	0	0.0	0.0	0.0
ENGINEERING PERSONNEL	0	0	0	0.0	0.0	0.0
<b>TOTAL</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0.0</b>	<b>0.700</b>	<b>0.500</b>
SPECIAL MAINTENANCE				8.800	317.000	31.000
MAINTENANCE PERSONNEL	32	623	95	1.300	0.0	0.0
OPERATING PERSONNEL	8	0	0	0.400	0.0	0.0
HEALTH PHYSICS PERSONNEL	3	0	11	0.0	0.0	3.200
SUPERVISORY PERSONNEL	0	0	0	0.0	0.0	0.0
ENGINEERING PERSONNEL	0	36	0	0.0	13.100	0.0
<b>TOTAL</b>	<b>43</b>	<b>659</b>	<b>106</b>	<b>8.08</b>	<b>10.500</b>	<b>330.100</b>
WASTE PROCESSING				9.300	1.000	0.0
MAINTENANCE PERSONNEL	26	3	0	7.400	0.0	0.0
OPERATING PERSONNEL	15	0	0	1.700	0.0	0.900
HEALTH PHYSICS PERSONNEL	5	0	2	0.0	0.0	0.0
SUPERVISORY PERSONNEL	0	0	0	0.0	0.0	0.0
ENGINEERING PERSONNEL	0	0	0	0.300	0.0	0.0
<b>TOTAL</b>	<b>46</b>	<b>3</b>	<b>2</b>	<b>51</b>	<b>18.700</b>	<b>34.200</b>
REFUELING				0.0	3.600	1.000
MAINTENANCE PERSONNEL	0	20	4	6.300	0.0	0.0
OPERATING PERSONNEL	19	0	0	0.0	0.0	0.0
HEALTH PHYSICS PERSONNEL	0	0	0	0.0	0.0	0.0
SUPERVISORY PERSONNEL	0	0	0	0.0	0.0	0.0
ENGINEERING PERSONNEL	0	0	0	0.0	0.0	0.0
<b>TOTAL</b>	<b>19</b>	<b>20</b>	<b>4</b>	<b>43</b>	<b>6.300</b>	<b>3.600</b>
TOTAL BY JOB FUNCTION				3.600	1.000	10.900
MAINTENANCE PERSONNEL	430	1694	317	2441	1048.000	174.600
OPERATING PERSONNEL	293	0	0	293	112.200	0.0
HEALTH PHYSICS PERSONNEL	63	0	139	202	22.800	72.400
SUPERVISORY PERSONNEL	0	0	0	0	0.0	0.0
ENGINEERING PERSONNEL	0	172	0	172	0.300	79.700
<b>GRAND TOTAL</b>	<b>786</b>	<b>1866</b>	<b>456</b>	<b>3108</b>	<b>354.800</b>	<b>1127.700</b>
						<b>247.000</b>
						<b>1729.500</b>

PLANT: BRUNSWICK 1, 2      (BWR)      NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION

WORK & JOB FUNCTION & SURV.	STATION			TOTAL			STATION			TOTAL		
	EMPLOYEES	UTILITY CONTRACT	PERSONS	EMPLOYEES	UTILIT	CONTRACT	EMPLOYEES	UTILIT	CONTRACT	EMPLOYEES	UTILIT	CONTRACT
MAINTENANCE PERSONNEL	16	0	2	26	0.01	0	0	0.040	4.225	0	0	0
OPERATING PERSONNEL	59	2	35	78	3.65	1.717	0	0.0	6.788	0	0	0
HEALTH PHYSICS PERSONNEL	16	1	11	18	9.05	0.717	0	0.0	11.943	0	0	0
SUPERVISORY PERSONNEL	1	0	0	0	0.137	0.0	0	0.0	0.0	0	0	0
ENGINEERING PERSONNEL	7	10	2	4	4.431	4.515	0	0.0	0.0	0	0	0
<b>TOTAL</b>	<b>99</b>	<b>13</b>	<b>50</b>	<b>162</b>	<b>127.919</b>	<b>6.989</b>	<b>23.748</b>	<b>2.340</b>	<b>158.656</b>			
ROUTINE MAINTENANCE												
MAIN ENCE PERSONNEL	68	13	193	109	45.8	9.211	310	3.00				
OPERATING PERSONNEL	6	0	0	0	0.0	0.0	0	0.0	0.0	0	0	0
HEALTH PHYSICS PERSONNEL	8	0	6	9.460	0.422	5.975	0	0.0	0.0	0	0	0
SUPERVISORY PERSONNEL	0	0	0	0.0	0.0	0.0	0	0.0	0.0	0	0	0
ENGINEERING PERSONNEL	8	1	24	5.728	0.401	17.755	0	0.0	0.0	0	0	0
<b>TOTAL</b>	<b>90</b>	<b>14</b>	<b>223</b>	<b>133.350</b>	<b>10.034</b>	<b>334.030</b>	<b>477.414</b>					
IN-SERVICE INSPECTION												
MAINTENANCE PERSONNEL	0	0	16	0.0	0.0	0.0	0	0.0	22.629	0	0	0
OPERATING PERSONNEL	0	0	0	0.0	0.0	0.0	0	0.0	0.0	0	0	0
HEALTH PHYSICS PERSONNEL	3	0	5	3.101	0.082	5.741	0	0.0	0.0	0	0	0
SUPERVISORY PERSONNEL	0	0	0	0.0	0.0	0.0	0	0.0	0.0	0	0	0
ENGINEERING PERSONNEL	3	2	22	4.175	2.271	19.685	0	0.0	0.0	0	0	0
<b>TOTAL</b>	<b>9</b>	<b>2</b>	<b>43</b>	<b>7.276</b>	<b>2.353</b>	<b>48.055</b>	<b>57.684</b>					
SPECIAL MAINTENANCE												
MAINTENANCE PERSONNEL	164	86	961	256	772	59.603	1454.597					
OPERATING PERSONNEL	6	4	0	8.704	2.917	0.0	0.0	0.0	0.0	0	0	0
HEALTH PHYSICS PERSONNEL	43	1	63	43.697	1.516	69.159	0	0.0	0.0	0	0	0
SUPERVISORY PERSONNEL	0	0	0	0.0	0.0	0.0	0	0.0	0.0	0	0	0
ENGINEERING PERSONNEL	33	31	149	23.263	14.930	112.027	0	0.0	0.0	0	0	0
<b>TOTAL</b>	<b>246</b>	<b>122</b>	<b>1164</b>	<b>1532</b>	<b>332.416</b>	<b>78.966</b>	<b>1635.783</b>	<b>2047.165</b>				
WASTE PROCESSING												
MAINTENANCE PERSONNEL	49	6	290	76.690	3.700	460.705	0	0.0	0.0	0	0	0
OPERATING PERSONNEL	48	0	0	65.583	0.0	0.0	0	0.0	0.0	0	0	0
HEALTH PHYSICS PERSONNEL	11	0	11	12.557	0.500	11.706	0	0.0	0.0	0	0	0
SUPERVISORY PERSONNEL	0	0	0	0.0	0.0	0.0	0	0.0	0.0	0	0	0
ENGINEERING PERSONNEL	11	3	45	16.7845	1.413	36.337	0	0.0	0.0	0	0	0
<b>TOTAL</b>	<b>119</b>	<b>9</b>	<b>346</b>	<b>474</b>	<b>162.675</b>	<b>5.613</b>	<b>508.748</b>	<b>677.036</b>				
REFUELING												
MAINTENANCE PERSONNEL	21	10	140	31.529	7.244	218.690	0	0.0	0.0	0	0	0
OPERATING PERSONNEL	9	0	0	13.258	0.0	0.0	0	0.0	0.0	0	0	0
HEALTH PHYSICS PERSONNEL	6	0	10	6.198	0.210	11.469	0	0.0	0.0	0	0	0
SUPERVISORY PERSONNEL	0	0	0	0.0	0.0	0.0	0	0.0	0.0	0	0	0
ENGINEERING PERSONNEL	6	0	0	4.175	0.363	0.0	0	0.0	0.0	0	0	0
<b>TOTAL</b>	<b>42</b>	<b>10</b>	<b>150</b>	<b>202</b>	<b>55.160</b>	<b>7.817</b>	<b>230.159</b>	<b>293.136</b>				
TOTAL BY JOB FUNCTION												
MAINTENANCE PERSONNEL	318	115	1602	500.530	79.798	2471.146	3051.474					
OPERATING PERSONNEL	128	6	35	174.614	4.634	6.788	18.036					
HEALTH PHYSICS PERSONNEL	87	2	106	195	93.918	3.447	115.993	213.358				
SUPERVISORY PERSONNEL	1	0	0	1	0.137	0.0	0.0	0.0		0.0	0.0	0.0
ENGINEERING PERSONNEL	71	47	233	351	49.597	23.893	186.596	260.086				
<b>GRAND TOTAL</b>	<b>605</b>	<b>170</b>	<b>1976</b>	<b>2751</b>	<b>818.796</b>	<b>111.772</b>	<b>2780.523</b>	<b>3711.091</b>				

**PLANT: CALVERT CLIFFS 1,2\*** (PWR) **NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION**

WORK & JOB FUNCTION	STATION			STATION			TOTAL			TOTAL MAN-REMS	
	EMPLOYEES	UTILITY EMPLOYEES	OTHERS	PERSONS	EMPLOYEES	OTHERS	PERSONS	EMPLOYEES	OTHERS	EMPLOYEES	MAN-REMS
<b>REACTOR OPERATIONS &amp; SURV.</b>											
MAINTENANCE PERSONNEL	0	4	0	0	28	0	0	1.277	0.0	1.277	0.0
OPERATING PERSONNEL	80	0	28	35	35	334	0	0	0	0	5.558
HEALTH PHYSICS PERSONNEL	19	17	43	6.951	4.719	0.0	4.719	0.0	0.0	20.919	0.0
SUPERVISORY PERSONNEL	3	0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ENGINEERING PERSONNEL	0	0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
<b>TOTAL</b>	<b>102</b>	<b>21</b>	<b>71</b>	<b>194</b>	<b>42</b>	<b>285</b>	<b>5.996</b>	<b>26.477</b>	<b>26.477</b>	<b>74.758</b>	
<b>ROUTINE MAINTENANCE</b>											
MAINTENANCE PERSONNEL	104	33	62	27.401	6.435	14.472	14.472	14.472	14.472	14.472	14.472
OPERATING PERSONNEL	21	33	14	5.308	0.356	3.052	3.052	3.052	3.052	3.052	3.052
HEALTH PHYSICS PERSONNEL	18	2	19	5.534	0.321	5.937	5.937	5.937	5.937	5.937	5.937
SUPERVISORY PERSONNEL	3	0	5	0.442	0.0	0.706	0.706	0.706	0.706	0.706	0.706
ENGINEERING PERSONNEL	8	1	10	1.317	0.198	1.778	1.778	1.778	1.778	1.778	1.778
<b>TOTAL</b>	<b>154</b>	<b>39</b>	<b>110</b>	<b>303</b>	<b>40.002</b>	<b>7.310</b>	<b>25.945</b>	<b>7.310</b>	<b>25.945</b>	<b>73.257</b>	
<b>IN-SERVICE INSPECTION</b>											
MAINTENANCE PERSONNEL	8	95	69	8.403	75.497	72.425	72.425	72.425	72.425	72.425	72.425
OPERATING PERSONNEL	4	8	13	1.314	2.880	5.551	5.551	5.551	5.551	5.551	5.551
HEALTH PHYSICS PERSONNEL	0	0	24	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SUPERVISORY PERSONNEL	0	0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ENGINEERING PERSONNEL	1	1	15	0.866	1.111	4.318	4.318	4.318	4.318	4.318	4.318
<b>TOTAL</b>	<b>13</b>	<b>104</b>	<b>121</b>	<b>238</b>	<b>10.583</b>	<b>79.488</b>	<b>87.847</b>	<b>79.488</b>	<b>87.847</b>	<b>177.918</b>	
<b>SPECIAL MAINTENANCE</b>											
MAINTENANCE PERSONNEL	180	155	286	108.348	83.571	121.404	121.404	121.404	121.404	121.404	121.404
OPERATING PERSONNEL	35	35	30	14.197	16.013	9.171	9.171	9.171	9.171	9.171	9.171
HEALTH PHYSICS PERSONNEL	30	59	72	15.436	20.601	30.548	30.548	30.548	30.548	30.548	30.548
SUPERVISORY PERSONNEL	6	0	8	1.897	0.0	2.366	2.366	2.366	2.366	2.366	2.366
ENGINEERING PERSONNEL	13	1	53	4.432	0.837	18.662	18.662	18.662	18.662	18.662	18.662
<b>TOTAL</b>	<b>264</b>	<b>250</b>	<b>449</b>	<b>963</b>	<b>144.310</b>	<b>121.022</b>	<b>181.951</b>	<b>121.022</b>	<b>181.951</b>	<b>447.283</b>	
<b>WASTE PROCESSING</b>											
MAINTENANCE PERSONNEL	5	7	23	2.713	1.819	5.865	5.865	5.865	5.865	5.865	5.865
OPERATING PERSONNEL	24	0	1	10.584	0.0	0.204	0.204	0.204	0.204	0.204	0.204
HEALTH PHYSICS PERSONNEL	17	57	40	13.491	15.076	20.279	20.279	20.279	20.279	20.279	20.279
SUPERVISORY PERSONNEL	2	0	1	1.102	0.0	0.124	0.124	0.124	0.124	0.124	0.124
ENGINEERING PERSONNEL	0	0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
<b>TOTAL</b>	<b>48</b>	<b>64</b>	<b>65</b>	<b>177</b>	<b>27.890</b>	<b>16.895</b>	<b>26.472</b>	<b>27.890</b>	<b>16.895</b>	<b>71.257</b>	
<b>REFUELING</b>											
MAINTENANCE PERSONNEL	69	58	4	45.208	27.588	0.731	0.731	0.731	0.731	0.731	0.731
OPERATING PERSONNEL	20	14	3	4.945	5.963	1.155	1.155	1.155	1.155	1.155	1.155
HEALTH PHYSICS PERSONNEL	1	7	12	0.105	1.351	4.919	4.919	4.919	4.919	4.919	4.919
SUPERVISORY PERSONNEL	9	0	1	2.014	0.0	0.199	0.199	0.199	0.199	0.199	0.199
ENGINEERING PERSONNEL	1	0	10	0.133	0.0	1.982	1.982	1.982	1.982	1.982	1.982
<b>TOTAL</b>	<b>100</b>	<b>79</b>	<b>30</b>	<b>209</b>	<b>52.405</b>	<b>34.902</b>	<b>8.986</b>	<b>34.902</b>	<b>8.986</b>	<b>96.293</b>	
<b>TOTAL BY JOB FUNCTION</b>											
MAINTENANCE PERSONNEL	366(204)	352(252)	4	1162(839)	192.073	214.897	214.897	214.897	214.897	214.897	214.897
OPERATING PERSONNEL	184(150)	60(138)	3	333(261)	71.682	25.212	25.212	25.212	25.212	25.212	25.212
HEALTH PHYSICS PERSONNEL	85(46)	142(100)	210(133)	437(249)	41.517	42.068	42.068	42.068	42.068	42.068	42.068
SUPERVISORY PERSONNEL	23(19)	0	15(11)	38(30)	5.455	3.395	3.395	3.395	3.395	3.395	3.395
ENGINEERING PERSONNEL	23(24)	3(3)	88(80)	114(107)	6.748	2.146	2.146	2.146	2.146	2.146	2.146
<b>GRAND TOTAL</b>	<b>681(443)</b>	<b>557(393)</b>	<b>846(680)</b>	<b>2084(1516)</b>	<b>3117.475</b>	<b>265.613</b>	<b>357.678</b>	<b>265.613</b>	<b>357.678</b>	<b>960.766</b>	<b>960.766</b>

\*Workers may be counted in more than one category. Numbers in parentheses are total numbers of individuals.

WORK & JOB FUNCTION	NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION 1982					TOTAL MAN-REMS	
	STATION EMPLOYEES	NUMBER OF PERSONNEL (>100 M-REM)	UTILITY CONTRACT	TOTAL PERSONS	STATION EMPLOYEES	UTILITY CONTRACT & OTHERS	
<u>REACTOR OPERATIONS &amp; SURV.</u>							
MAINTENANCE PERSONNEL	2	0	1	0	0.904	0.0	0.205
OPERATING PERSONNEL	71	0	0	72	32.329	0.0	0.0
HEALTH PHYSICS PERSONNEL	19	0	0	1	5.537	0.0	21.745
SUPERVISORY PERSONNEL	4	0	0	0	0.722	0.0	0.122
ENGINEERING PERSONNEL	2	0	0	0	0.245	0.0	0.0
<b>TOTAL</b>	<b>98</b>	<b>0</b>	<b>74</b>	<b>172</b>	<b>39.737</b>	<b>0.0</b>	<b>61.809</b>
<u>ROUTINE MAINTENANCE</u>							
MAINTENANCE PERSONNEL	101	7	221	104	408	2.061	80.367
OPERATING PERSONNEL	23	0	5	10	145	0.0	1.304
HEALTH PHYSICS PERSONNEL	5	0	26	1	082	0.0	7.892
SUPERVISORY PERSONNEL	7	1	3	2	5.98	0.205	1.231
ENGINEERING PERSONNEL	6	2	2	0	1.139	0.244	0.560
<b>TOTAL</b>	<b>142</b>	<b>10</b>	<b>257</b>	<b>409</b>	<b>119.372</b>	<b>2.510</b>	<b>91.354</b>
<u>IN-SERVICE INSPECTION</u>							
MAINTENANCE PERSONNEL	30	3	180	9.446	1.758	90.323	
OPERATING PERSONNEL	3	0	3	0.412	0.0	0.637	
HEALTH PHYSICS PERSONNEL	7	0	24	1.027	0.0	2.032	
SUPERVISORY PERSONNEL	4	0	2	0.786	0.0	3.176	
ENGINEERING PERSONNEL	9	0	0	1.585	0.0	0.340	
<b>TOTAL</b>	<b>53</b>	<b>3</b>	<b>209</b>	<b>13.256</b>	<b>1.758</b>	<b>97.000</b>	<b>213.236</b>
<u>SPECIAL MAINTENANCE</u>							
MAINTENANCE PERSONNEL	25	5	288	7.111	2.974	140.066	
OPERATING PERSONNEL	0	0	10	0.0	0.0	0.0	
HEALTH PHYSICS PERSONNEL	0	0	14	0.0	0.0	0.0	
SUPERVISORY PERSONNEL	0	1	6	0.0	0.331	3.273	
ENGINEERING PERSONNEL	3	6	5	0.516	1.081	1.192	
<b>TOTAL</b>	<b>28</b>	<b>12</b>	<b>323</b>	<b>13.256</b>	<b>4.386</b>	<b>149.739</b>	<b>161.752</b>
<u>WASTE PROCESSING</u>							
MAINTENANCE PERSONNEL	26	5	68	5.664	0.699	35.769	
OPERATING PERSONNEL	1	0	5	0.219	0.0	0.0	
HEALTH PHYSICS PERSONNEL	4	0	8	0.888	0.0	2.380	
SUPERVISORY PERSONNEL	2	0	0	2.538	0.0	2.295	
ENGINEERING PERSONNEL	0	0	0	0.0	0.0	0.0	
<b>TOTAL</b>	<b>33</b>	<b>5</b>	<b>78</b>	<b>116</b>	<b>9.309</b>	<b>0.699</b>	<b>40.444</b>
<u>REFUELING</u>							
MAINTENANCE PERSONNEL	8	3	55	2.985	2.579	32.884	
OPERATING PERSONNEL	6	0	0	1.796	0.0	0.0	
HEALTH PHYSICS PERSONNEL	0	0	6	0.0	0.0	1.057	
SUPERVISORY PERSONNEL	3	0	0	0.749	0.0	0.0	
ENGINEERING PERSONNEL	8	0	0	1.827	0.0	0.0	
<b>TOTAL</b>	<b>25</b>	<b>3</b>	<b>61</b>	<b>8.9</b>	<b>7.357</b>	<b>2.579</b>	<b>33.941</b>
<u>TOTAL BY JOB FUNCTION</u>							
MAINTENANCE PERSONNEL	192(108)	23(12)	\$ 13,596	1028(716)	130,518	10,071	379,614
OPERATING PERSONNEL	104(96)	0	20(17)	124(113)	44,901	0.0	6,353
HEALTH PHYSICS PERSONNEL	35(20)	0	150(82)	185(102)	8,534	0.0	41,865
SUPERVISORY PERSONNEL	20(16)	2(1)	12(8)	34(25)	7,393	0.0	50,399
ENGINEERING PERSONNEL	28(20)	8(6)	7(5)	43(31)	5,312	1.325	12,895
<b>GRAND TOTAL</b>	<b>379(260)</b>	<b>33(19)</b>	<b>1092(708)</b>	<b>14,141(987)</b>	<b>196,658</b>	<b>11,932</b>	<b>434,550</b>

\*Workers may be counted in more than one category. Numbers in parentheses are total numbers of individuals.

APPENDIX C  
PLANT: COOPER (BWR) NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION

WORK & JOB FUNCTION	NUMBER OF PERSONNEL (1982)			TOTAL			TOTAL	
	STATION EMPLOYEES	UTILITY CONTRACT	EMPLOYEES & OTHERS	PERSONS	STATION EMPLOYEES	UTILITY EMPLOYEES	& OTHERS	MAN-REMS
<u>REACTOR OPERATIONS &amp; SURV.</u>								
MAINTENANCE PERSONNEL	4	0	1	1	0.947	0.0	0.0	0.005
OPERATING PERSONNEL	46	0	0	0	29.941	0.0	0.0	0.0
HEALTH PHYSICS PERSONNEL	14	0	0	0	9.594	0.0	0.0	0.0
SUPERVISORY PERSONNEL	10	2	1	1	4.933	0.022	0.0	0.206
ENGINEERING PERSONNEL	17	10	3	14	14.133	1.093	0.350	0.350
TOTAL	91	12	5	108	59.548	1.115	0.561	61.224
<u>ROUTINE MAINTENANCE</u>								
MAINTENANCE PERSONNEL	50	1	94	94	74.374	0.111	76.411	
OPERATING PERSONNEL	4	0	0	0	1.240	0.0	0.0	0.0
HEALTH PHYSICS PERSONNEL	12	0	0	0	6.066	0.0	0.0	0.0
SUPERVISORY PERSONNEL	5	2	1	1	1.530	0.904	0.286	0.286
ENGINEERING PERSONNEL	10	11	3	14	4.583	1.985	0.176	0.176
TOTAL	81	14	98	193	87.793	3.000	76.873	167.666
<u>IN-SERVICE INSPECTION</u>								
MAINTENANCE PERSONNEL	0	0	14	14	0.0	0.0	0.0	5.706
OPERATING PERSONNEL	0	0	0	0	0.0	0.0	0.0	0.0
HEALTH PHYSICS PERSONNEL	0	0	0	0	0.0	0.0	0.0	0.0
SUPERVISORY PERSONNEL	1	0	1	1	0.144	0.0	0.0	0.711
ENGINEERING PERSONNEL	0	0	0	0	0.0	0.0	0.0	0.0
TOTAL	1	0	15	16	0.144	0.0	0.0	6.417
<u>SPECIAL MAINTENANCE</u>								
MAINTENANCE PERSONNEL	4	0	210	210	0.909	0.0	0.0	243.360
OPERATING PERSONNEL	1	0	0	0	0.444	0.0	0.0	0.0
HEALTH PHYSICS PERSONNEL	4	0	0	0	1.429	0.0	0.0	0.0
SUPERVISORY PERSONNEL	0	4	7	7	0.0	1.111	2.600	2.600
ENGINEERING PERSONNEL	1	15	11	15	0.676	4.957	6.758	6.758
TOTAL	10	19	228	257	3.458	6.068	252.718	262.244
<u>WASTE PROCESSING</u>								
MAINTENANCE PERSONNEL	3	0	0	0	0.087	0.0	0.0	0.0
OPERATING PERSONNEL	20	0	0	0	4.067	0.0	0.0	0.0
HEALTH PHYSICS PERSONNEL	13	0	0	0	2.030	0.0	0.0	0.0
SUPERVISORY PERSONNEL	0	0	0	0	0.0	0.0	0.0	0.0
ENGINEERING PERSONNEL	0	0	0	0	0.0	0.0	0.0	0.0
TOTAL	36	0	0	36	6.184	0.0	0.0	6.184
<u>REFUELING</u>								
MAINTENANCE PERSONNEL	0	0	0	0	0.0	0.0	0.0	0.0
OPERATING PERSONNEL	18	0	0	0	1.085	0.0	0.0	0.0
HEALTH PHYSICS PERSONNEL	5	0	0	0	0.129	0.0	0.0	0.0
SUPERVISORY PERSONNEL	2	0	0	0	0.095	0.0	0.0	0.0
ENGINEERING PERSONNEL	2	0	0	0	0.554	0.0	0.0	0.0
TOTAL	27	0	0	27	1.863	0.0	0.0	1.863
<u>TOTAL BY JOB FUNCTION</u>								
MAINTENANCE PERSONNEL	61	1	319	381	76.317	0.111	325.482	401.910
OPERATING PERSONNEL	89	0	0	89	36.777	0.0	0.0	36.777
HEALTH PHYSICS PERSONNEL	48	0	10	48	19.248	0.0	0.0	19.248
SUPERVISORY PERSONNEL	18	8	18	36	6.702	2.037	3.803	12.562
ENGINEERING PERSONNEL	30	36	17	83	19.946	8.035	7.284	35.265
GRAND TOTAL	246	45	346	637	158.990	10.183	336.569	505.742

PLANT: CRYSTAL RIVER (CPWR) NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION

WORK & JOB FUNCTION	1982				1982			
	STATION EMPLOYEES	NUMBER OF PERSONNEL	NUMBER OF PERSONNEL (>100 M-REM)	TOTAL CONTRACT	STATION EMPLOYEES	NUMBER OF PERSONNEL	NUMBER OF PERSONNEL (>100 M-REM)	TOTAL CONTRACT
<b>REACTOR OPERATIONS &amp; SURV.</b>								
MAINTENANCE PERSONNEL	0	0	0	0	0	0	0	0
OPERATING PERSONNEL	3	0	0	0	1	1.700	0.100	0.0
HEALTH PHYSICS PERSONNEL	1	0	0	0	4	4.840	0.0	0.020
SUPERVISORY PERSONNEL	0	0	0	0	0	0.380	0.030	0.070
ENGINEERING PERSONNEL	0	0	0	0	0	0.050	0.0	0.0
<b>TOTAL</b>	<b>4</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>4</b>	<b>6.970</b>	<b>0.130</b>	<b>0.090</b>
<b>ROUTINE MAINTENANCE</b>								<b>7.190</b>
MAINTENANCE PERSONNEL	38	77	129	15.900	6	6.960	69.260	
OPERATING PERSONNEL	8	0	0	6.290	0	0.340	1.710	
HEALTH PHYSICS PERSONNEL	9	0	27	3.330	0	0.130	8.280	
SUPERVISORY PERSONNEL	8	0	17	5.410	0	0.110	7.060	
ENGINEERING PERSONNEL	1	0	9	0.680	0	0.290	2.920	
<b>TOTAL</b>	<b>64</b>	<b>77</b>	<b>182</b>	<b>323</b>	<b>31.610</b>	<b>7.830</b>	<b>89.230</b>	<b>128.670</b>
<b>IN-SERVICE INSPECTION</b>								
MAINTENANCE PERSONNEL	0	0	0	0	0	0.090	0.0	0.080
OPERATING PERSONNEL	0	0	0	0	0	0.0	0.0	0.0
HEALTH PHYSICS PERSONNEL	0	0	0	0	0	0.0	0.0	0.0
SUPERVISORY PERSONNEL	0	0	0	0	0	0.0	0.0	0.0
ENGINEERING PERSONNEL	0	0	0	0	0	0.670	0.0	0.0
<b>TOTAL</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0.760</b>	<b>0.0</b>	<b>0.080</b>
<b>SPECIAL MAINTENANCE</b>								
MAINTENANCE PERSONNEL	0	0	0	0	0	0.0	0.0	0.0
OPERATING PERSONNEL	0	0	0	0	0	0.0	0.0	0.0
HEALTH PHYSICS PERSONNEL	0	0	0	0	0	0.0	0.0	0.0
SUPERVISORY PERSONNEL	0	0	0	0	0	0.0	0.0	0.0
ENGINEERING PERSONNEL	0	0	0	0	0	0.0	0.0	0.0
<b>TOTAL</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>
<b>WASTE PROCESSING</b>								
MAINTENANCE PERSONNEL	2	0	0	0	0	0.510	0.550	1.780
OPERATING PERSONNEL	0	0	8	0	0	0.340	0.0	1.590
HEALTH PHYSICS PERSONNEL	0	0	0	0	0	0.500	0.010	0.110
SUPERVISORY PERSONNEL	0	0	0	0	0	0.130	0.0	0.240
ENGINEERING PERSONNEL	0	0	0	0	0	0.0	0.0	0.010
<b>TOTAL</b>	<b>2</b>	<b>0</b>	<b>8</b>	<b>10</b>	<b>1.480</b>	<b>0.560</b>	<b>3.730</b>	<b>5.770</b>
<b>REFUELING</b>								
MAINTENANCE PERSONNEL	0	0	0	0	0	0.0	0.0	0.0
OPERATING PERSONNEL	0	0	0	0	0	0.0	0.0	0.0
HEALTH PHYSICS PERSONNEL	0	0	0	0	0	0.0	0.0	0.0
SUPERVISORY PERSONNEL	0	0	0	0	0	0.0	0.0	0.0
ENGINEERING PERSONNEL	0	0	0	0	0	0.0	0.0	0.0
<b>TOTAL</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>
<b>TOTAL BY JOB FUNCTION</b>								
MAINTENANCE PERSONNEL	40	77	129	246	16.500	7.510	71.120	95.130
OPERATING PERSONNEL	11	0	8	19	8.330	0.440	3.360	12.070
HEALTH PHYSICS PERSONNEL	10	0	27	37	8.670	0.140	8.410	17.220
SUPERVISORY PERSONNEL	8	0	17	25	5.920	0.140	7.370	13.430
ENGINEERING PERSONNEL	1	0	9	10	1.400	0.290	2.930	4.620
<b>GRAND TOTAL</b>	<b>70</b>	<b>77</b>	<b>190</b>	<b>337</b>	<b>40.820</b>	<b>8.520</b>	<b>93.130</b>	<b>142.470</b>

**PLANT: DAVIS BESSIE\***      (PWR)      **APPENDIX C**  
**NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION**  
**1982**

WORK & JOB FUNCTION	EMPLOYEES	STATION		TOTAL	STATION	EMPLOYEES	UTILITY	MAN-REM	TOTAL
		EMPLOYEES	CONTRACT		PERSONS	& OTHERS	EMPLOYEES	EMPLOYEES	CONTRACT
<b>REACTOR OPERATIONS &amp; SURV.</b>									
MAINTENANCE PERSONNEL	58	11	408		1,395		0.140	10.760	
OPERATING PERSONNEL	74	2	15		2,935		0.010	0.295	
HEALTH PHYSICS PERSONNEL	16	0	40		1,275		0.0	1.470	
SUPERVISORY PERSONNEL	17	0	4		0.430		0.0	0.105	
ENGINEERING PERSONNEL	2	0	6		0.005		0.0	0.185	
<b>TOTAL</b>	<b>167</b>	<b>13</b>	<b>473</b>	<b>6,53</b>	<b>6,040</b>	<b>0.150</b>	<b>12.815</b>	<b>19.005</b>	
<b>ROUTINE MAINTENANCE</b>									
MAINTENANCE PERSONNEL	108	43	1055		14,330		3.520	136.715	
OPERATING PERSONNEL	95	6	20		5,580		0.435	0.955	
HEALTH PHYSICS PERSONNEL	20	0	83		4,115		0.0	24.500	
SUPERVISORY PERSONNEL	30	0	11		1,810		0.0	0.435	
ENGINEERING PERSONNEL	3	0	33		0.195		0.0	3.245	
<b>TOTAL</b>	<b>256</b>	<b>49</b>	<b>1202</b>	<b>1507</b>	<b>26,030</b>	<b>3.955</b>	<b>165.850</b>	<b>195.835</b>	
<b>IN-SERVICE INSPECTION</b>									
MAINTENANCE PERSONNEL	0	0	4		0.0		0.0	0.060	
OPERATING PERSONNEL	6	0	1		0.065		0.0	0.005	
HEALTH PHYSICS PERSONNEL	0	0	1		0.0		0.0	0.020	
SUPERVISORY PERSONNEL	0	0	0		0.0		0.0	0.0	
ENGINEERING PERSONNEL	0	0	1		0.0		0.0	0.010	
<b>TOTAL</b>	<b>6</b>	<b>0</b>	<b>7</b>	<b>13</b>	<b>0.065</b>	<b>0.0</b>	<b>0.0</b>	<b>0.095</b>	<b>0.160</b>
<b>SPECIAL MAINTENANCE</b>									
MAINTENANCE PERSONNEL	39	5	293		1,515		0.410	33.545	
OPERATING PERSONNEL	10	1	1		0.885		0.020	0.080	
HEALTH PHYSICS PERSONNEL	3	0	35		0.075		0.0	5.370	
SUPERVISORY PERSONNEL	8	0	3		0.350		0.0	0.040	
ENGINEERING PERSONNEL	0	0	16		0.0		0.0	1.395	
<b>TOTAL</b>	<b>60</b>	<b>6</b>	<b>348</b>	<b>414</b>	<b>2,825</b>	<b>0.430</b>	<b>40.430</b>	<b>43.685</b>	
<b>WASTE PROCESSING</b>									
MAINTENANCE PERSONNEL	0	0	3		0.0		0.0	0.180	
OPERATING PERSONNEL	2	0	4		0.015		0.0	1.295	
HEALTH PHYSICS PERSONNEL	3	0	3		0.025		0.0	0.030	
SUPERVISORY PERSONNEL	1	0	2		0.165		0.0	0.455	
ENGINEERING PERSONNEL	0	0	0		0.0		0.0	0.0	
<b>TOTAL</b>	<b>6</b>	<b>0</b>	<b>12</b>	<b>18</b>	<b>0.205</b>	<b>0.0</b>	<b>1.960</b>	<b>2.165</b>	
<b>REFUELING</b>									
MAINTENANCE PERSONNEL	0	0	15		0.0		0.0	2.325	
OPERATING PERSONNEL	0	0	1		0.0		0.0	0.010	
HEALTH PHYSICS PERSONNEL	0	0	0		0.0		0.0	0.0	
SUPERVISORY PERSONNEL	0	0	1		0.0		0.0	0.015	
ENGINEERING PERSONNEL	0	0	2		0.0		0.0	0.125	
<b>TOTAL</b>	<b>0</b>	<b>0</b>	<b>19</b>	<b>19</b>	<b>0.0</b>	<b>0.0</b>	<b>2.475</b>	<b>2.475</b>	
<b>TOTAL BY JOB FUNCTION</b>									
MAINTENANCE PERSONNEL	205	59	1778		2042		4.070	183.585	204.895
OPERATING PERSONNEL	187	9	42		238		0.465	12.640	12.585
HEALTH PHYSICS PERSONNEL	42	0	162		204		5.490	31.390	36.880
SUPERVISORY PERSONNEL	56	0	21		77		2.755	0.0	3.805
ENGINEERING PERSONNEL	5	0	58		63		0.200	4.960	5.160
<b>GRAND TOTAL</b>	<b>495</b>	<b>68</b>	<b>2061</b>	<b>2624</b>	<b>35.165</b>	<b>4.535</b>	<b>223.625</b>	<b>263.325</b>	

\* Workers may be counted in more than one category.

## APPENDIX C NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION

APPENDIX C  
AND MAN-REM BY WORK AND JOB FUNCTION

WORK & JOB FUNCTION		NUMBER OF PERSONNEL (> 100 M-REM)			1982			TOTAL MAN-REMS	
REACTOR OPERATIONS & SURV.		STATION EMPLOYEES		UTILITY CONTRACT	TOTAL		STATION EMPLOYEES		TOTAL
MAINTENANCE PERSONNEL		26	4	0	PERSONS		EMPLOYEES		MAN-REMS
MAINTENANCE PERSONNEL		170	193	772	255.900	185.700	1520.000		
OPERATING PERSONNEL		32	68	0	33.100	15.300	0.00		
HEALTH PHYSICS PERSONNEL		27	0	0	62.400	0.0	0.00		
SUPERVISORY PERSONNEL		2	0	0	80.900	0.0	0.00		
ENGINEERING PERSONNEL		9	0	0	11.500	0.0	0.00		
TOTAL		2	0	0	1.200	0.0	0.00		
TOTAL		110	5	0	115	130.300	2.100	0.0	132.400
 ROUTINE MAINTENANCE									
MAINTENANCE PERSONNEL		20	60	69	30.400	89.200	135.100		
OPERATING PERSONNEL		6	0	0	6.600	0.0	0.00		
HEALTH PHYSICS PERSONNEL		3	0	0	6.000	0.0	0.00		
SUPERVISORY PERSONNEL		8	0	0	6.200	0.0	0.00		
ENGINEERING PERSONNEL		43	0	0	2.700	0.0	0.00		
TOTAL		354	261	772	454.500	201.000	1520.000		2175.500
 IN-SERVICE INSPECTION									
MAINTENANCE PERSONNEL		0	0	0	0.0	0.0	0.00		
OPERATING PERSONNEL		0	0	0	0.0	0.0	0.00		
HEALTH PHYSICS PERSONNEL		0	0	0	0.0	0.0	0.00		
SUPERVISORY PERSONNEL		0	0	0	0.0	0.0	0.00		
ENGINEERING PERSONNEL		0	0	0	0.0	0.0	0.00		
TOTAL		0	0	0	0.0	0.0	0.00		0.0
 SPECIAL MAINTENANCE									
MAINTENANCE PERSONNEL		0	0	0	0.0	0.0	0.00		
OPERATING PERSONNEL		0	0	0	0.0	0.0	0.00		
HEALTH PHYSICS PERSONNEL		0	0	0	0.0	0.0	0.00		
SUPERVISORY PERSONNEL		0	0	0	0.0	0.0	0.00		
ENGINEERING PERSONNEL		0	0	0	0.0	0.0	0.00		
TOTAL		0	0	0	0.0	0.0	0.00		0.0
 WASTE PROCESSING									
MAINTENANCE PERSONNEL		29	6	17	43.300	3.100	33.800		
OPERATING PERSONNEL		36	2	0	38.100	0.500	0.00		
HEALTH PHYSICS PERSONNEL		9	0	0	21.800	0.0	0.00		
SUPERVISORY PERSONNEL		28	0	0	27.800	0.0	0.00		
ENGINEERING PERSONNEL		4	0	0	1.800	0.0	0.00		
TOTAL		106	8	17	132.800	3.600	33.800		170.200
 REFUELING									
MAINTENANCE PERSONNEL		43	0	0	65.100	0.0	0.00		
OPERATING PERSONNEL		13	2	0	13.200	0.300	0.00		
HEALTH PHYSICS PERSONNEL		2	0	0	5.000	0.0	0.00		
SUPERVISORY PERSONNEL		9	0	0	12.200	0.0	0.00		
ENGINEERING PERSONNEL		4	0	0	2.100	0.0	0.00		
TOTAL		71	2	0	97.600	0.300	0.00		97.900
 TOTAL BY JOB FUNCTION									
MAINTENANCE PERSONNEL		288	263	858	1409	433.800	279.800	1688.900	2402.500
OPERATING PERSONNEL		158	73	0	231	165.600	16.400	0.0	182.000
HEALTH PHYSICS PERSONNEL		43	0	0	43	99.100	0.0	0.0	99.100
SUPERVISORY PERSONNEL		136	0	0	136	138.600	0.0	0.0	138.600
ENGINEERING PERSONNEL		58	0	0	58	30.000	0.0	0.0	30.000
GRAND TOTAL		683	336	858	1877	867.100	296.200	1688.900	2852.500

**APPENDIX C**  
**PLANT: DUANE ARNOLD\***      (BWR)      **NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION**  
**1982**

WORK & JOB FUNCTION	STATION			TOTAL			STATION			TOTAL		
	EMPLOYEES	UTILITY	CONTRACT	EMPLOYEES	& OTHERS	PERSONS	EMPLOYEES	EMPLOYEES	& OTHERS	EMPLOYEES	EMPLOYEES	MAN-REMS
<b>REACTOR OPERATIONS &amp; SURV.</b>												
MAINTENANCE PERSONNEL	10	1	3	0	0	588	0	0	0	0	0	0.190
OPERATING PERSONNEL	38	1	2	19	301	0	0	0	0	0	0	0.251
HEALTH PHYSICS PERSONNEL	10	0	9	0	0	9	0	0	0	0	0	0.498
SUPERVISORY PERSONNEL	8	3	4	0	0	0	0.230	0	0	0	0	0.098
ENGINEERING PERSONNEL	1	3	9	0	0	0	0.020	0	0	0	0	0.985
<b>TOTAL</b>	<b>65</b>	<b>8</b>	<b>27</b>	<b>100</b>	<b>20</b>	<b>389</b>	<b>0</b>	<b>100</b>	<b>0</b>	<b>2</b>	<b>0.022</b>	<b>23.011</b>
<b>ROUTINE MAINTENANCE</b>												
MAINTENANCE PERSONNEL	33	7	207	14	699	0	0	290	0	0	115.195	
OPERATING PERSONNEL	10	0	4	0	0	0	0	0	0	0	0	0.453
HEALTH PHYSICS PERSONNEL	10	0	16	0	0	9	0.989	0	0	0	0	1.359
SUPERVISORY PERSONNEL	4	1	21	0	0	4	0.518	0	0	0	0	8.234
ENGINEERING PERSONNEL	2	3	50	0	0	50	0.215	0	0	0	0	3.898
<b>TOTAL</b>	<b>59</b>	<b>11</b>	<b>298</b>	<b>368</b>	<b>17.098</b>	<b>0</b>	<b>0.057</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>146.634</b>
<b>IN-SERVICE INSPECTION</b>												
MAINTENANCE PERSONNEL	10	0	68	0	0	0	0.356	0	0	0	0	21.971
OPERATING PERSONNEL	4	0	4	0	0	4	0.195	0	0	0	0	0.075
HEALTH PHYSICS PERSONNEL	10	0	34	0	0	34	0.013	0	0	0	0	19.742
SUPERVISORY PERSONNEL	13	0	43	0	0	43	0.619	0	0	0	0	2.086
ENGINEERING PERSONNEL	8	2	18	100	0	100	2.647	0	0	0	0	22.987
<b>TOTAL</b>	<b>45</b>	<b>20</b>	<b>249</b>	<b>314</b>	<b>12.830</b>	<b>0</b>	<b>2.323</b>	<b>66.861</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>82.014</b>
<b>SPECIAL MAINTENANCE</b>												
MAINTENANCE PERSONNEL	24	2	98	4	345	0	0	847	0	0	17.336	
OPERATING PERSONNEL	2	0	0	0	0	0	0.010	0	0	0	0	0.0
HEALTH PHYSICS PERSONNEL	6	0	12	0	0	12	0.428	0	0	0	0	1.002
SUPERVISORY PERSONNEL	3	1	6	0	0	6	0.095	0	0	0	0	0.267
ENGINEERING PERSONNEL	2	2	16	0	0	16	0.950	0	0	0	0	0.993
<b>TOTAL</b>	<b>37</b>	<b>5</b>	<b>132</b>	<b>174</b>	<b>4.928</b>	<b>0</b>	<b>0.920</b>	<b>19.598</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>25.446</b>
<b>WASTE PROCESSING</b>												
MAINTENANCE PERSONNEL	1	0	16	0	0	16	0.010	0	0	0	0	0.594
OPERATING PERSONNEL	7	0	8	0	0	8	0.280	0	0	0	0	0.500
HEALTH PHYSICS PERSONNEL	1	0	1	0	0	1	0.010	0	0	0	0	0.010
SUPERVISORY PERSONNEL	1	1	9	0	0	9	0.321	0	0	0	0	1.138
ENGINEERING PERSONNEL	0	0	10	0	0	10	0.0	0	0	0	0	0.165
<b>TOTAL</b>	<b>10</b>	<b>1</b>	<b>44</b>	<b>55</b>	<b>10.621</b>	<b>0</b>	<b>0.004</b>	<b>10.407</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>21.032</b>
<b>REFUELING</b>												
MAINTENANCE PERSONNEL	0	0	0	0	0	0	0.0	0	0	0	0	0.0
OPERATING PERSONNEL	0	0	0	0	0	0	0.0	0	0	0	0	0.0
HEALTH PHYSICS PERSONNEL	0	0	0	0	0	0	0.0	0	0	0	0	0.0
SUPERVISORY PERSONNEL	0	0	0	0	0	0	0.0	0	0	0	0	0.0
ENGINEERING PERSONNEL	0	0	0	0	0	0	0.0	0	0	0	0	0.0
<b>TOTAL</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0.0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0.0</b>
<b>TOTAL BY JOB FUNCTION</b>												
MAINTENANCE PERSONNEL	78	10	392	480	19.998	1	1.187	155.286	1	1.187	176.471	
OPERATING PERSONNEL	61	1	18	80	30.463	0	0.002	9.279	0	0	9.279	
HEALTH PHYSICS PERSONNEL	35	0	72	107	11.190	1	0.0	22.611	1	0.0	39.744	
SUPERVISORY PERSONNEL	29	8	83	120	1.783	0	0.156	11.823	0	0.156	33.801	
ENGINEERING PERSONNEL	13	26	185	224	2.932	2	2.399	2.399	2	2.399	13.762	
<b>GRAND TOTAL</b>	<b>216</b>	<b>45</b>	<b>750</b>	<b>1011</b>	<b>66.366</b>	<b>3</b>	<b>3.744</b>	<b>228.027</b>	<b>3</b>	<b>3.744</b>	<b>298.137</b>	

\*Workers may be counted in more than one category.

**PLANT: FARLEY 1,2\***      (PWR)      **APPENDIX C**

1982

WORK & JOB FUNCTION	NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION						TOTAL MAN-REMS		
	STATION			TOTAL		EMPLOYEES	UTILITY	STATION	TOTAL MAN-REMS
	EMPLOYEES	UTILITY	CONTRACT	PERSONS	& OTHERS	EMPLOYEES		EMPLOYEES	
<b>REACTOR OPERATIONS &amp; SURV.</b>									
MAINTENANCE PERSONNEL	88	1	7			4.050	0.030	0.304	
OPERATING PERSONNEL	137	1	0			39.316	0.020	0.0	
HEALTH PHYSICS PERSONNEL	80	2	49			36.129	0.320	23.794	
SUPERVISORY PERSONNEL	166	9	25			20.473	0.561	1.257	
ENGINEERING PERSONNEL	43	19	187			4.009	0.689	11.599	
<b>TOTAL</b>	<b>514</b>	<b>32</b>	<b>268</b>	<b>814</b>	<b>103.977</b>	<b>1.620</b>	<b>36.954</b>	<b>142.551</b>	
<b>ROUTINE MAINTENANCE</b>									
MAINTENANCE PERSONNEL	148	1	11			34.925	0.293	1.210	
OPERATING PERSONNEL	94	1	0			30.411	0.100	0.0	
HEALTH PHYSICS PERSONNEL	34	1	12			7.410	0.020	0.657	
SUPERVISORY PERSONNEL	63	4	5			6.098	0.209	0.927	
ENGINEERING PERSONNEL	11	12	277			0.348	0.589	24.169	
<b>TOTAL</b>	<b>350</b>	<b>19</b>	<b>305</b>	<b>674</b>	<b>79.192</b>	<b>1.211</b>	<b>26.963</b>	<b>107.366</b>	
<b>IN-SERVICE INSPECTION</b>									
MAINTENANCE PERSONNEL	4	0	5			0.103	0.0	0.411	
OPERATING PERSONNEL	3	0	6			0.097	0.0	0.0	
HEALTH PHYSICS PERSONNEL	1	0	1			0.011	0.0	0.012	
SUPERVISORY PERSONNEL	2	3	0			0.067	0.060	0.0	
ENGINEERING PERSONNEL	4	3	71			0.354	0.087	10.082	
<b>TOTAL</b>	<b>14</b>	<b>6</b>	<b>77</b>	<b>97</b>	<b>0.632</b>	<b>0.147</b>	<b>10.505</b>	<b>11.284</b>	
<b>SPECIAL MAINTENANCE</b>									
MAINTENANCE PERSONNEL	141	1	11			58.768	0.277	2.487	
OPERATING PERSONNEL	49	0	0			5.931	0.0	0.0	
HEALTH PHYSICS PERSONNEL	26	1	11			3.657	0.020	1.019	
SUPERVISORY PERSONNEL	49	1	4			4.496	0.020	0.579	
ENGINEERING PERSONNEL	13	11	404			0.519	0.355	97.956	
<b>TOTAL</b>	<b>278</b>	<b>14</b>	<b>430</b>	<b>722</b>	<b>73.371</b>	<b>0.672</b>	<b>102.041</b>	<b>176.084</b>	
<b>WASTE PROCESSING</b>									
MAINTENANCE PERSONNEL	0	0	0			0.0	0.0	0.0	
OPERATING PERSONNEL	16	0	0			1.168	0.0	0.0	
HEALTH PHYSICS PERSONNEL	8	0	3			1.306	0.0	1.082	
SUPERVISORY PERSONNEL	6	0	1			0.312	0.0	0.040	
ENGINEERING PERSONNEL	0	0	0			0.0	0.0	0.0	
<b>TOTAL</b>	<b>30</b>	<b>0</b>	<b>4</b>	<b>34</b>	<b>2.786</b>	<b>0.0</b>	<b>1.122</b>	<b>3.903</b>	
<b>REFUELING</b>									
MAINTENANCE PERSONNEL	21	0	3			0.819	0.0	0.058	
OPERATING PERSONNEL	6	0	0			0.401	0.0	0.0	
HEALTH PHYSICS PERSONNEL	1	0	3			0.041	0.0	0.103	
SUPERVISORY PERSONNEL	16	0	2			0.332	0.0	0.057	
ENGINEERING PERSONNEL	6	2	20			0.271	0.030	2.430	
<b>TOTAL</b>	<b>50</b>	<b>2</b>	<b>28</b>	<b>80</b>	<b>1.864</b>	<b>0.030</b>	<b>2.648</b>	<b>4.542</b>	
<b>TOTAL BY JOB FUNCTION</b>									
MAINTENANCE PERSONNEL	402	3	37			98.665	0.600	4.470	
OPERATING PERSONNEL	305	2	0			307	77.324	0.120	
HEALTH PHYSICS PERSONNEL	150	4	79			48.554	0.360	26.667	
SUPERVISORY PERSONNEL	302	17	37			356	31.778	0.850	
ENGINEERING PERSONNEL	77	47	959			5.501	1.750	146.236	
<b>GRAND TOTAL</b>	<b>1236</b>	<b>73</b>	<b>1112</b>	<b>2421</b>	<b>261.822</b>	<b>3.680</b>	<b>180.233</b>	<b>445.735</b>	

\* Workers may be counted in more than one category.

**APPENDIX C**  
**NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION**  
**1982**

WORK & JOB FUNCTION	STATION EMPLOYEES	UTILITY EMPLOYEES	CONTRACT & OTHERS	TOTAL PERSONS	STATION EMPLOYEES	UTILITY EMPLOYEES	CONTRACT & OTHERS	TOTAL MAN-REMS	MAN-REMS
<b>REFACTOR OPERATIONS &amp; SURV.</b>									
MAINTENANCE PERSONNEL	74	0	62	136	11.016	0.0	0.0	14.650	
OPERATING PERSONNEL	178	0	1	179	54.890	0.0	0.0	1.680	
HEALTH PHYSICS PERSONNEL	31	0	56	87	20.260	0.0	0.0	28.510	
SUPERVISORY PERSONNEL	0	0	0	0	0.0	0.0	0.0	0.0	
ENGINEERING PERSONNEL	3	0	20	23	3.860	0.0	0.0	1.480	
<b>TOTAL</b>	<b>286</b>	<b>0</b>	<b>139</b>	<b>425</b>	<b>90.026</b>	<b>0.0</b>	<b>0.0</b>	<b>46.120</b>	<b>136.146</b>
<b>ROUTINE MAINTENANCE</b>									
MAINTENANCE PERSONNEL	124	0	575	700	129.500	0.0	0.0	207.630	
OPERATING PERSONNEL	65	0	4	69	7.510	0.0	0.0	0.190	
HEALTH PHYSICS PERSONNEL	11	0	0	11	1.340	0.0	0.0	0.0	
SUPERVISORY PERSONNEL	0	0	0	0	0.0	0.0	0.0	0.0	
ENGINEERING PERSONNEL	30	0	90	120	5.030	0.0	0.0	11.000	
<b>TOTAL</b>	<b>230</b>	<b>0</b>	<b>669</b>	<b>898</b>	<b>143.380</b>	<b>0.0</b>	<b>0.0</b>	<b>218.820</b>	<b>362.200</b>
<b>IN-SERVICE INSPECTION</b>									
MAINTENANCE PERSONNEL	48	0	124	172	2.660	0.0	0.0	7.230	
OPERATING PERSONNEL	86	0	7	93	6.920	0.0	0.0	5.130	
HEALTH PHYSICS PERSONNEL	14	0	4	18	0.360	0.0	0.0	0.060	
SUPERVISORY PERSONNEL	0	0	0	0	0.0	0.0	0.0	0.0	
ENGINEERING PERSONNEL	39	0	55	94	4.130	0.0	0.0	4.530	
<b>TOTAL</b>	<b>187</b>	<b>0</b>	<b>190</b>	<b>377</b>	<b>14.070</b>	<b>0.0</b>	<b>0.0</b>	<b>16.950</b>	<b>31.020</b>
<b>SPECIAL MAINTENANCE</b>									
MAINTENANCE PERSONNEL	65	0	927	1000	4.800	0.0	0.0	477.780	
OPERATING PERSONNEL	32	0	2	34	4.370	0.0	0.0	0.370	
HEALTH PHYSICS PERSONNEL	5	0	4	9	0.130	0.0	0.0	2.630	
SUPERVISORY PERSONNEL	0	0	0	0	0.0	0.0	0.0	0.0	
ENGINEERING PERSONNEL	28	0	108	136	3.520	0.0	0.0	45.970	
<b>TOTAL</b>	<b>130</b>	<b>0</b>	<b>1041</b>	<b>1171</b>	<b>12.820</b>	<b>0.0</b>	<b>0.0</b>	<b>526.750</b>	<b>539.570</b>
<b>WASTE PROCESSING</b>									
MAINTENANCE PERSONNEL	123	0	127	150	27.950	0.0	0.0	17.030	
OPERATING PERSONNEL	52	0	5	57	38.250	0.0	0.0	7.740	
HEALTH PHYSICS PERSONNEL	11	0	9	20	0.360	0.0	0.0	0.380	
SUPERVISORY PERSONNEL	0	0	0	0	0.0	0.0	0.0	0.0	
ENGINEERING PERSONNEL	11	0	55	66	0.290	0.0	0.0	28.340	
<b>TOTAL</b>	<b>197</b>	<b>0</b>	<b>196</b>	<b>393</b>	<b>66.850</b>	<b>0.0</b>	<b>0.0</b>	<b>53.690</b>	<b>120.340</b>
<b>REFUELING</b>									
MAINTENANCE PERSONNEL	0	0	0	0	0.0	0.0	0.0	0.0	
OPERATING PERSONNEL	0	0	0	0	0.0	0.0	0.0	0.0	
HEALTH PHYSICS PERSONNEL	0	0	0	0	0.0	0.0	0.0	0.0	
SUPERVISORY PERSONNEL	0	0	0	0	0.0	0.0	0.0	0.0	
ENGINEERING PERSONNEL	0	0	0	0	0.0	0.0	0.0	0.0	
<b>TOTAL</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>
<b>TOTAL BY JOB FUNCTION</b>									
MAINTENANCE PERSONNEL	434	0	1815	2249	175.926	0.0	0.0	724.320	900.246
OPERATING PERSONNEL	413	0	19	432	111.940	0.0	0.0	14.910	126.850
HEALTH PHYSICS PERSONNEL	72	0	73	145	22.450	0.0	0.0	31.580	54.030
SUPERVISORY PERSONNEL	0	0	0	0	0.0	0.0	0.0	0.0	0.0
ENGINEERING PERSONNEL	111	0	328	353	16.830	0.0	0.0	91.320	108.150
<b>GRAND TOTAL</b>	<b>1030</b>	<b>0</b>	<b>2235</b>	<b>3265</b>	<b>327.146</b>	<b>0.0</b>	<b>0.0</b>	<b>862.130</b>	<b>1189.276</b>

\* Workers may be counted in more than one category.

## APPENDIX C NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION

APPENDIX C

## APPENDIX C NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION

PLANT: FT. CALHOUN		(PWR)		NUMBER OF PERSONNEL (>100 M-REM)		1982	
WORK & JOB FUNCTION	REACTOR OPERATIONS & SURV.	STATION EMPLOYEES	UTILITY EMPLOYEES	PERSONS	TOTAL	MAN-REMS	TOTAL
		& OTHERS		PERSONS	STATION EMPLOYEES	UTILITY EMPLOYEES	MAN-REMS
Maintenance Personnel	1	0	3	3	1.311	0.305	0.784
Operating Personnel	12	0	0	0	4.345	0.0	0.0
Health Physics Personnel	21	0	19	8	6.55	0.237	8.316
Supervisory Personnel	1	0	0	0	0.424	0.009	0.0
Engineering Personnel	7	1	1	1	1.861	1.931	0.282
<b>TOTAL</b>	<b>42</b>	<b>3</b>	<b>23</b>	<b>68</b>	<b>16.596</b>	<b>2.482</b>	<b>9.382</b>
ROUTINE MAINTENANCE							
Maintenance Personnel	31	17	33	8	5.588	6.505	15.592
Operating Personnel	0	0	0	0	0.124	0.0	0.0
Health Physics Personnel	0	0	0	0	0.045	0.019	0.055
Supervisory Personnel	0	0	0	0	0.043	0.0	0.0
Engineering Personnel	1	0	0	0	0.475	0.292	0.15
<b>TOTAL</b>	<b>32</b>	<b>17</b>	<b>33</b>	<b>82</b>	<b>9.275</b>	<b>6.816</b>	<b>15.662</b>
IN-SERVICE INSPECTION							
Maintenance Personnel	0	0	3	0	0.0	0.0	0.527
Operating Personnel	0	0	0	0	0.0	0.0	0.0
Health Physics Personnel	0	0	0	0	0.0	0.0	0.0
Supervisory Personnel	0	0	0	0	0.0	0.0	0.0
Engineering Personnel	1	0	0	0	0.204	0.254	0.025
<b>TOTAL</b>	<b>1</b>	<b>0</b>	<b>3</b>	<b>4</b>	<b>0.204</b>	<b>0.254</b>	<b>0.552</b>
SPECIAL MAINTENANCE							
Maintenance Personnel	25	25	62	10	10.080	8.636	32.790
Operating Personnel	0	0	0	0	0.347	0.0	0.0
Health Physics Personnel	4	0	9	1	1.467	0.008	2.483
Supervisory Personnel	0	0	0	0	0.257	0.0	0.0
Engineering Personnel	5	5	2	2	2.232	1.872	0.475
<b>TOTAL</b>	<b>34</b>	<b>30</b>	<b>73</b>	<b>137</b>	<b>14.383</b>	<b>10.516</b>	<b>35.748</b>
WASTE PROCESSING							
Maintenance Personnel	11	3	2	6	4.590	1.116	0.548
Operating Personnel	1	0	0	0	0.559	0.0	0.0
Health Physics Personnel	3	0	0	4	4.509	0.0	0.008
Supervisory Personnel	0	0	0	0	0.017	0.0	0.0
Engineering Personnel	0	0	0	0	0.010	0.0	0.0
<b>TOTAL</b>	<b>15</b>	<b>3</b>	<b>2</b>	<b>20</b>	<b>9.685</b>	<b>1.116</b>	<b>0.556</b>
REFUELING							
Maintenance Personnel	5	10	5	1	1.394	2.686	1.766
Operating Personnel	0	0	0	0	0.213	0.0	0.0
Health Physics Personnel	0	0	0	0	0.045	0.0	0.020
Supervisory Personnel	0	0	0	0	0.039	0.0	0.0
Engineering Personnel	1	0	0	0	0.352	0.128	0.020
<b>TOTAL</b>	<b>6</b>	<b>10</b>	<b>5</b>	<b>21</b>	<b>2.043</b>	<b>2.814</b>	<b>1.806</b>
<b>TOTAL BY JOB FUNCTION</b>							
Maintenance Personnel	73	55	108	236	25.963	19.248	52.007
Operating Personnel	13	0	0	1	5.588	0.0	5.588
Health Physics Personnel	28	0	28	56	14.721	0.264	25.867
Supervisory Personnel	1	0	0	1	0.780	0.009	0.789
Engineering Personnel	15	8	3	26	5.134	4.477	10.472
<b>GRAND TOTAL</b>	<b>130</b>	<b>139</b>	<b>139</b>	<b>332</b>	<b>52.186</b>	<b>23.998</b>	<b>132.890</b>

**PLANT: GINNA\***

**APPENDIX C  
(PWR) NUMBER OF PERSONNEL AND MAN-REM 1982**

WORK & JOB FUNCTION	NUMBER OF PERSONNEL (>100 M-REM)			TOTAL			TOTAL MAN-REMS		
	STATION EMPLOYEES	UTILITY EMPLOYEES	CONTRACT & OTHERS	PERSONS	STATION EMPLOYEES	UTILITY EMPLOYEES	CONTRACT & OTHERS	MAN-REMS	
<b>REACTOR OPERATIONS &amp; SURV.</b>									
MAINTENANCE PERSONNEL	21	40	245	287	14	584	14	689	
OPERATING PERSONNEL	0	31	2	33	0	16	623	0.796	0.022
HEALTH PHYSICS PERSONNEL	30	14	3	47	5.385	3.831	3	0.285	0.010
SUPERVISORY PERSONNEL	28	14	11	53	2.102	3.253	3	0.819	0.279
ENGINEERING PERSONNEL	50	2	8	60	3.075	0.250	0	0.230	0.003
<b>TOTAL</b>	<b>325</b>	<b>101</b>	<b>269</b>	<b>695</b>	<b>39.339</b>	<b>28.861</b>	<b>9.219</b>	<b>77.419</b>	
<b>ROUTINE MAINTENANCE</b>									
MAINTENANCE PERSONNEL	256	41	241	57	663	14.791	74.411		
OPERATING PERSONNEL	0	27	2	0	0	0.672	0	0.022	
HEALTH PHYSICS PERSONNEL	30	14	2	46	6.506	2.766	2	0.285	
SUPERVISORY PERSONNEL	29	13	9	53	3.856	1.136	1	0.819	0.010
ENGINEERING PERSONNEL	47	1	6	56	2.998	0.212	0	0.230	0.003
<b>TOTAL</b>	<b>362</b>	<b>96</b>	<b>260</b>	<b>718</b>	<b>71.023</b>	<b>19.577</b>	<b>75.403</b>	<b>166.003</b>	
<b>IN-SERVICE INSPECTION</b>									
MAINTENANCE PERSONNEL	18	18	21	50	0.422	0.206	0	0.226	
OPERATING PERSONNEL	0	0	0	0	0	0	0	0	
HEALTH PHYSICS PERSONNEL	9	8	1	18	0.280	0.135	0	0.001	
SUPERVISORY PERSONNEL	11	10	6	27	0.913	0.421	0	0.438	
ENGINEERING PERSONNEL	1	1	1	3	0.055	0	0	0.178	
<b>TOTAL</b>	<b>39</b>	<b>37</b>	<b>29</b>	<b>105</b>	<b>1.670</b>	<b>0.762</b>	<b>0</b>	<b>0.842</b>	<b>3.274</b>
<b>SPECIAL MAINTENANCE</b>									
MAINTENANCE PERSONNEL	292	41	260	224	849	26.147	419.138		
OPERATING PERSONNEL	0	30	2	0	0	3.017	0	0.405	
HEALTH PHYSICS PERSONNEL	30	13	3	33	16.613	21.020	0	0.322	
SUPERVISORY PERSONNEL	39	14	12	64	27.354	8.919	9	0.635	
ENGINEERING PERSONNEL	70	2	7	84	49.737	0.235	0	0.100	
<b>TOTAL</b>	<b>431</b>	<b>100</b>	<b>284</b>	<b>815</b>	<b>318.553</b>	<b>59.338</b>	<b>437.600</b>	<b>815.491</b>	
<b>WASTE PROCESSING</b>									
MAINTENANCE PERSONNEL	16	25	44	100	1.974	2.189	1	2.233	
OPERATING PERSONNEL	0	18	1	1	0	1.317	0	0.015	
HEALTH PHYSICS PERSONNEL	20	12	1	33	1.700	0.857	0	0.001	
SUPERVISORY PERSONNEL	5	2	0	7	0.368	0.160	0	0.000	
ENGINEERING PERSONNEL	8	0	0	8	1.525	0	0	0.000	
<b>TOTAL</b>	<b>49</b>	<b>57</b>	<b>46</b>	<b>152</b>	<b>5.567</b>	<b>4.523</b>	<b>1.249</b>	<b>11.339</b>	
<b>REFUELING</b>									
MAINTENANCE PERSONNEL	14	28	29	66	4.095	2.105	6.944		
OPERATING PERSONNEL	0	3	0	3	0	3.290	0	0.000	
HEALTH PHYSICS PERSONNEL	13	8	0	21	1.818	0.478	0	0.000	
SUPERVISORY PERSONNEL	1	3	0	4	0.340	0.546	0	0.000	
ENGINEERING PERSONNEL	17	0	0	17	15.205	0	0	0.000	
<b>TOTAL</b>	<b>45</b>	<b>42</b>	<b>29</b>	<b>116</b>	<b>21.458</b>	<b>6.419</b>	<b>6.944</b>	<b>34.821</b>	
<b>TOTAL BY JOB FUNCTION</b>									
MAINTENANCE PERSONNEL	813 (324)	193 (41)	840 (266)	1846 (631)	317.780	50.022	509.041	876.843	
OPERATING PERSONNEL	0	109 (31)	7 (2)	116 (33)	0	24.919	1.238	26.157	
HEALTH PHYSICS PERSONNEL	132 (30)	69 (14)	10 (3)	211 (47)	32.302	29.087	0.618	62.007	
SUPERVISORY PERSONNEL	113 (39)	56 (14)	38 (12)	207 (65)	34.933	14.755	11.171	60.859	
ENGINEERING PERSONNEL	193 (88)	6 (2)	22 (8)	221 (98)	72.595	0.697	9.189	82.481	
<b>GRAND TOTAL</b>	<b>1251 (481)</b>	<b>433 (102)</b>	<b>917 (251)</b>	<b>2601 (874)</b>	<b>457.610</b>	<b>119.480</b>	<b>531.257</b>	<b>1108.347</b>	

\*Workers may be counted in more than one category. Numbers in parentheses are total numbers of individuals.

**APPENDIX C**

**NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION**

PLANT: HADDAM NECK	(PWR)	NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION 1982						TOTAL MAN-REMS	
		STATION EMPLOYEES	NUMBER OF PERSONNEL (>1000 M-REM)	UTILITY EMPLOYEES	CONTRACT & OTHERS	TOTAL PERSONS	STATION EMPLOYEES	UTILITY EMPLOYEES	
<b>WORK &amp; JOB FUNCTION</b>									
REACTOR OPERATIONS & SURV.									
MAINTENANCE PERSONNEL	0	0	0	0	0	0	0.450	0.020	0.030
OPERATING PERSONNEL	44	0	30	7	22	370	0.180	0.000	8.270
HEALTH PHYSICS PERSONNEL	23	0	0	7	9.180	0.070	0.000	2.410	1.950
SUPERVISORY PERSONNEL	0	0	0	0	0.0	0.020	0.000	0.000	0.000
ENGINEERING PERSONNEL	2	0	0	0	0.880	0.420	0.000	0.200	0.280
<b>TOTAL</b>	<b>69</b>	<b>0</b>	<b>37</b>	<b>106</b>	<b>32.880</b>	<b>0.710</b>	<b>10.910</b>	<b>44.500</b>	
<b>ROUTINE MAINTENANCE</b>									
MAINTENANCE PERSONNEL	49	0	7	22	22.590	0.040	0.000	2.680	
OPERATING PERSONNEL	3	1	0	2.100	0.200	0.000	0.140		
HEALTH PHYSICS PERSONNEL	26	1	6	15.270	0.210	0.000	1.950		
SUPERVISORY PERSONNEL	0	0	0	0.0	0.000	0.000	0.000		
ENGINEERING PERSONNEL	1	0	0	0.460	0.280	0.000	0.080		
<b>TOTAL</b>	<b>79</b>	<b>2</b>	<b>13</b>	<b>94</b>	<b>40.420</b>	<b>0.730</b>	<b>4.850</b>	<b>46.000</b>	
<b>IN-SERVICE INSPECTION</b>									
MAINTENANCE PERSONNEL	0	0	0	0	0.120	0.000	0.000	0.020	
OPERATING PERSONNEL	0	0	0	0.520	0.000	0.000	0.010		
HEALTH PHYSICS PERSONNEL	0	0	0	0.220	0.000	0.000	0.060		
SUPERVISORY PERSONNEL	0	0	0	0.0	0.000	0.000	0.000		
ENGINEERING PERSONNEL	2	0	0	1.150	0.050	0.000	0.030		
<b>TOTAL</b>	<b>2</b>	<b>0</b>	<b>0</b>	<b>2.010</b>	<b>0.050</b>	<b>0.000</b>	<b>0.120</b>	<b>2.180</b>	
<b>SPECIAL MAINTENANCE</b>									
MAINTENANCE PERSONNEL	1	18	14	0.210	4.150	4.210			
OPERATING PERSONNEL	0	2	0	0.100	0.670	0.050			
HEALTH PHYSICS PERSONNEL	1	0	4	0.980	0.0	0.820			
SUPERVISORY PERSONNEL	0	1	1	0.0	0.150	0.160			
ENGINEERING PERSONNEL	0	1	0	0.120	0.550	0.0			
<b>TOTAL</b>	<b>2</b>	<b>22</b>	<b>19</b>	<b>4.3</b>	<b>1.410</b>	<b>5.520</b>	<b>5.240</b>	<b>12.170</b>	
<b>WASTE PROCESSING</b>									
MAINTENANCE PERSONNEL	2	0	0	0	0.310	0.0	0.0	0.030	
OPERATING PERSONNEL	0	0	0	0	0.200	0.0	0.0	0.030	
HEALTH PHYSICS PERSONNEL	18	0	1	15.900	0.0	0.0	0.150		
SUPERVISORY PERSONNEL	0	0	0	0.0	0.0	0.0	0.0		
ENGINEERING PERSONNEL	0	0	0	0.0	0.0	0.0	0.0		
<b>TOTAL</b>	<b>20</b>	<b>0</b>	<b>1</b>	<b>21</b>	<b>16.410</b>	<b>0.0</b>	<b>0.180</b>	<b>16.590</b>	
<b>REFUELING</b>									
MAINTENANCE PERSONNEL	0	0	0	0	0.010	0.0	0.0	0.010	
OPERATING PERSONNEL	0	0	0	0	0.260	0.0	0.0	0.010	
HEALTH PHYSICS PERSONNEL	0	0	0	0.110	0.0	0.0	0.0		
SUPERVISORY PERSONNEL	0	0	0	0.0	0.0	0.0	0.0		
ENGINEERING PERSONNEL	0	0	0	0.060	0.0	0.0	0.0		
<b>TOTAL</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0.440</b>	<b>0.0</b>	<b>0.0</b>	<b>0.020</b>	<b>0.460</b>	
<b>TOTAL BY JOB FUNCTION</b>									
MAINTENANCE PERSONNEL	52	18	21	91	23.690	4.210	6.940	34.840	
OPERATING PERSONNEL	47	3	30	80	25.550	1.050	8.510	35.110	
HEALTH PHYSICS PERSONNEL	68	1	18	87	41.660	0.280	5.400	47.340	
SUPERVISORY PERSONNEL	0	1	1	2	0.0	0.170	0.160	0.330	
ENGINEERING PERSONNEL	5	1	0	6	2.670	1.300	0.310	4.280	
<b>GRAND TOTAL</b>	<b>172</b>	<b>24</b>	<b>70</b>	<b>266</b>	<b>93.570</b>	<b>7.010</b>	<b>21.320</b>	<b>121.900</b>	

**PLANT: HATCH 1,2**      **APPENDIX C**      **NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION**

WORK & JOB FUNCTION	NUMBER OF PERSONNEL (>100 M-REM)			TOTAL			TOTAL MAN-REMS		
	STATION		UTILITY	TOTAL		STATION	UTILITY		TOTAL
	EMPLOYEES	CONTRACT	EMPLOYEES & OTHERS	PERSONS		EMPLOYEES	EMPLOYEES	& OTHERS	MAN-REMS
<b>REACTOR OPERATIONS &amp; SURV.</b>									
MAINTENANCE PERSONNEL	24	1	14		6.000	0.0	6.000	0.0	5.000
OPERATING PERSONNEL	120	8	4		48.000	4.000	26.000	0.0	2.000
HEALTH PHYSICS PERSONNEL	39	0	154		3.000	0.0	0.0	0.0	89.000
SUPERVISORY PERSONNEL	44	4	1		3.000	0.0	1.000	0.0	0.0
ENGINEERING PERSONNEL	8	3	1		1.000	1.000	0.0	0.0	0.0
<b>TOTAL</b>	<b>235</b>	<b>16</b>	<b>174</b>	<b>425</b>	<b>89.000</b>	<b>6.000</b>	<b>6.000</b>	<b>0.0</b>	<b>191.000</b>
<b>ROUTINE MAINTENANCE</b>									
MAINTENANCE PERSONNEL	173	14	381		74.000	3.000	3.000	0.0	143.000
OPERATING PERSONNEL	68	5	2		16.000	2.000	0.0	0.0	0.0
HEALTH PHYSICS PERSONNEL	13	0	46		3.000	0.0	0.0	0.0	17.000
SUPERVISORY PERSONNEL	16	1	9		3.000	0.0	0.0	0.0	5.000
ENGINEERING PERSONNEL	12	3	11		2.000	0.0	0.0	0.0	4.000
<b>TOTAL</b>	<b>282</b>	<b>23</b>	<b>449</b>	<b>754</b>	<b>98.000</b>	<b>5.000</b>	<b>5.000</b>	<b>0.0</b>	<b>272.000</b>
<b>IN-SERVICE INSPECTION</b>									
MAINTENANCE PERSONNEL	2	0	11		0.0	0.0	0.0	0.0	6.000
OPERATING PERSONNEL	1	0	0		0.0	0.0	0.0	0.0	0.0
HEALTH PHYSICS PERSONNEL	0	0	2		0.0	0.0	0.0	0.0	0.0
SUPERVISORY PERSONNEL	0	0	0		0.0	0.0	0.0	0.0	0.0
ENGINEERING PERSONNEL	0	1	4		0.0	0.0	0.0	0.0	1.000
<b>TOTAL</b>	<b>3</b>	<b>1</b>	<b>17</b>	<b>21</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>7.000</b>
<b>SPECIAL MAINTENANCE</b>									
MAINTENANCE PERSONNEL	187	13	1274		106.000	5.000	5.000	0.0	570.000
OPERATING PERSONNEL	24	0	9		4.000	0.0	0.0	0.0	4.000
HEALTH PHYSICS PERSONNEL	10	0	54		3.000	0.0	0.0	0.0	19.000
SUPERVISORY PERSONNEL	13	1	22		5.000	0.0	0.0	0.0	12.000
ENGINEERING PERSONNEL	27	10	55		7.000	3.000	3.000	0.0	20.000
<b>TOTAL</b>	<b>261</b>	<b>24</b>	<b>1414</b>	<b>1699</b>	<b>125.000</b>	<b>8.000</b>	<b>8.000</b>	<b>0.0</b>	<b>758.000</b>
<b>WASTE PROCESSING</b>									
MAINTENANCE PERSONNEL	6	2	35		1.000	0.0	0.0	0.0	9.000
OPERATING PERSONNEL	7	0	1		1.000	0.0	0.0	0.0	1.000
HEALTH PHYSICS PERSONNEL	0	0	13		0.0	0.0	0.0	0.0	7.000
SUPERVISORY PERSONNEL	2	0	1		1.000	0.0	0.0	0.0	0.0
ENGINEERING PERSONNEL	2	0	1		0.0	0.0	0.0	0.0	0.0
<b>TOTAL</b>	<b>17</b>	<b>2</b>	<b>51</b>	<b>70</b>	<b>3.000</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>17.000</b>
<b>REFUELING</b>									
MAINTENANCE PERSONNEL	50	3	52		11.000	1.000	1.000	0.0	15.000
OPERATING PERSONNEL	6	0	0		1.000	0.0	0.0	0.0	0.0
HEALTH PHYSICS PERSONNEL	2	0	13		0.0	0.0	0.0	0.0	3.000
SUPERVISORY PERSONNEL	1	0	0		0.0	0.0	0.0	0.0	0.0
ENGINEERING PERSONNEL	3	0	7		1.000	0.0	0.0	0.0	2.000
<b>TOTAL</b>	<b>62</b>	<b>3</b>	<b>72</b>	<b>137</b>	<b>13.000</b>	<b>1.000</b>	<b>1.000</b>	<b>0.0</b>	<b>20.000</b>
<b>TOTAL BY JOB FUNCTION</b>									
MAINTENANCE PERSONNEL	442	33	1767		2242	198.000	9.000	9.000	955.000
OPERATING PERSONNEL	226	13	16		255	70.000	6.000	7.000	83.000
HEALTH PHYSICS PERSONNEL	64	0	282		346	32.000	0.0	0.0	167.000
SUPERVISORY PERSONNEL	76	6	33		115	17.000	1.000	1.000	35.000
ENGINEERING PERSONNEL	52	17	79		148	11.000	4.000	4.000	42.000
<b>GRAND TOTAL</b>	<b>860</b>	<b>69</b>	<b>2177</b>	<b>3106</b>	<b>328.000</b>	<b>20.000</b>	<b>934.000</b>	<b>20.000</b>	<b>1282.000</b>

**APPENDIX C**  
**NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION**

PLANT: HUMBOLDT BAY	(BWR)	NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION						TOTAL		
		STATION	NUMBER OF PERSONNEL (>100 M-REM)	UTILITY CONTRACT	TOTAL	PERSONS	STATION	EMPLOYEES	UTILITY CONTRACT	
WORK & JOB FUNCTION	EMPLOYEES	EMPLOYEES	& OTHERS	EMPLOYEES	EMPLOYEES	EMPLOYEES	EMPLOYEES	EMPLOYEES	EMPLOYEES	TOTAL
REACTOR OPERATIONS & SURV.										
MAINTENANCE PERSONNEL	0	0	0	0	0	0.0	0.0	0.0	0.0	0.0
OPERATING PERSONNEL	12	0	0	0	0	2.500	0.0	0.0	0.0	0.0
HEALTH PHYSICS PERSONNEL	1	0	0	0	0	1.100	0.0	0.0	0.0	0.0
SUPERVISORY PERSONNEL	0	0	0	0	0	0.0	0.0	0.0	0.0	0.0
ENGINEERING PERSONNEL	0	0	0	0	0	0.500	0.0	0.0	0.0	0.0
<b>TOTAL</b>	<b>14</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>4.100</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>4.100</b>
ROUTINE MAINTENANCE										
MAINTENANCE PERSONNEL	16	0	0	0	0	6.000	0.0	0.0	0.0	0.0
OPERATING PERSONNEL	0	0	0	0	0	0.0	0.0	0.0	0.0	0.0
HEALTH PHYSICS PERSONNEL	1	0	0	0	0	0.800	0.0	0.0	0.0	0.0
SUPERVISORY PERSONNEL	0	0	0	0	0	0.0	0.0	0.0	0.0	0.0
ENGINEERING PERSONNEL	0	0	0	0	0	0.400	0.0	0.0	0.0	0.0
<b>TOTAL</b>	<b>17</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>7.200</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>7.200</b>
IN-SERVICE INSPECTION										
MAINTENANCE PERSONNEL	0	0	0	0	0	0.0	0.0	0.0	0.0	0.0
OPERATING PERSONNEL	0	0	0	0	0	0.0	0.0	0.0	0.0	0.0
HEALTH PHYSICS PERSONNEL	0	0	0	0	0	0.0	0.0	0.0	0.0	0.0
SUPERVISORY PERSONNEL	0	0	0	0	0	0.0	0.0	0.0	0.0	0.0
ENGINEERING PERSONNEL	0	0	0	0	0	0.0	0.0	0.0	0.0	0.0
<b>TOTAL</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>
SPECIAL MAINTENANCE										
MAINTENANCE PERSONNEL	0	0	0	0	0	0.0	0.0	0.0	0.0	0.0
OPERATING PERSONNEL	0	0	0	0	0	0.0	0.0	0.0	0.0	0.0
HEALTH PHYSICS PERSONNEL	0	0	0	0	0	0.0	0.0	0.0	0.0	0.0
SUPERVISORY PERSONNEL	0	0	0	0	0	0.0	0.0	0.0	0.0	0.0
ENGINEERING PERSONNEL	0	0	0	0	0	0.0	0.0	0.0	0.0	0.0
<b>TOTAL</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>
WASTE PROCESSING										
MAINTENANCE PERSONNEL	3	0	0	0	0	1.700	0.0	0.0	0.0	0.0
OPERATING PERSONNEL	4	0	0	0	0	1.300	0.0	0.0	0.0	0.0
HEALTH PHYSICS PERSONNEL	0	0	0	0	0	0.300	0.0	0.0	0.0	0.0
SUPERVISORY PERSONNEL	0	0	0	0	0	0.0	0.0	0.0	0.0	0.0
ENGINEERING PERSONNEL	1	0	0	0	0	0.500	0.0	0.0	0.0	0.0
<b>TOTAL</b>	<b>8</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>3.800</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>3.800</b>
REFUELING										
MAINTENANCE PERSONNEL	0	0	0	0	0	0.0	0.0	0.0	0.0	0.0
OPERATING PERSONNEL	0	0	0	0	0	0.0	0.0	0.0	0.0	0.0
HEALTH PHYSICS PERSONNEL	0	0	0	0	0	0.0	0.0	0.0	0.0	0.0
SUPERVISORY PERSONNEL	0	0	0	0	0	0.0	0.0	0.0	0.0	0.0
ENGINEERING PERSONNEL	0	0	0	0	0	0.0	0.0	0.0	0.0	0.0
<b>TOTAL</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>
TOTAL BY JOB FUNCTION										
MAINTENANCE PERSONNEL	19	0	0	0	0	19	7.700	0.0	0.0	7.700
OPERATING PERSONNEL	16	0	0	0	0	16	3.800	0.0	0.0	3.800
HEALTH PHYSICS PERSONNEL	3	0	0	0	0	3	2.200	0.0	0.0	2.200
SUPERVISORY PERSONNEL	0	0	0	0	0	0	0.0	0.0	0.0	0.0
ENGINEERING PERSONNEL	2	0	0	0	0	2	1.400	0.0	0.0	1.400
<b>GRAND TOTAL</b>	<b>40</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>40</b>	<b>15.100</b>	<b>0.0</b>	<b>0.0</b>	<b>15.100</b>

**APPENDIX C**  
**PLANT: INDIAN POINT 1,2\***      **(PWR)**      **NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION**  
**1982**

WORK & JOB FUNCTION	STATION EMPLOYEES	NUMBER OF PERSONNEL (>100 M-REM)		TOTAL PERSONS	STATION EMPLOYEES	NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION		TOTAL
		UTILITY CONTRACT	& OTHERS			STATION EMPLOYEES	UTILITY CONTRACT	
<b>REFACTOR OPERATIONS &amp; SURV.</b>								
M AINTENANCE PERSONNEL	71	162	283		17	336	37.388	28.289
O PERATING PERSONNEL	87	1	0		68	081	0.005	0.0
H EALTH PHYSICS PERSONNEL	15	0	88		9	132	0.0	120.618
S UPERVISORY PERSONNEL	67	26	92		31	171	4.609	14.030
E NGINEERING PERSONNEL	49	25	12		25	759	9.388	2.628
T OTAL	289	214	475	978	151.479	51.390	165.565	368.434
<b>ROUTINE MAINTENANCE</b>								
M AINTENANCE PERSONNEL	66	187	415		58	437	17.480	52.994
O PERATING PERSONNEL	87	1	0		85	499	0.010	0.0
H EALTH PHYSICS PERSONNEL	13	0	67		3	758	0.0	31.876
S UPERVISORY PERSONNEL	65	39	147		30	126	1.8.434	26.708
E NGINEERING PERSONNEL	44	29	17		5	326	4.811	4.131
T OTAL	275	256	646	1177	183.146	40.735	115.709	339.590
<b>IN-SERVICE INSPECTION</b>								
M AINTENANCE PERSONNEL	0	0	31		0	0	0.0	17.041
O PERATING PERSONNEL	0	0	0		0	0	0.0	0.0
H EALTH PHYSICS PERSONNEL	0	0	1		0	0	0.0	0.025
S UPERVISORY PERSONNEL	0	0	0		0	0	0.0	0.0
E NGINEERING PERSONNEL	9	0	13		2	911	0.0	8.480
T OTAL	9	0	45	54	2.911	0.0	0.0	25.546
<b>SPECIAL MAINTENANCE</b>								
M AINTENANCE PERSONNEL	57	265	605		6	886	260.954	391.805
O PERATING PERSONNEL	32	1	0		2	812	0.830	0.0
H EALTH PHYSICS PERSONNEL	1	0	14		0	015	0.0	1.588
S UPERVISORY PERSONNEL	29	45	142		2	320	29.371	27.246
E NGINEERING PERSONNEL	33	35	31		2	534	11.404	12.370
T OTAL	152	346	792	1290	14.567	302.559	433.009	750.135
<b>WASTE PROCESSING</b>								
M AINTENANCE PERSONNEL	22	35	201		11	126	3.333	188.124
O PERATING PERSONNEL	33	0	0		1	889	0.0	0.0
H EALTH PHYSICS PERSONNEL	4	0	17		0	505	0.0	4.934
S UPERVISORY PERSONNEL	11	6	8		4	517	0.285	4.278
E NGINEERING PERSONNEL	6	0	5		0	130	0.0	1.796
T OTAL	76	41	231	348	18.167	3.618	199.132	220.917
<b>REFUELING</b>								
M AINTENANCE PERSONNEL	10	71	42		0	985	20.416	7.612
O PERATING PERSONNEL	55	0	0		10	094	0.0	0.0
H EALTH PHYSICS PERSONNEL	0	0	0		0	0	0.0	0.0
S UPERVISORY PERSONNEL	10	13	3		2	699	3.361	0.130
E NGINEERING PERSONNEL	0	3	1		0	0	1.105	0.015
T OTAL	75	87	46	208	13.778	24.882	7.757	46.417
<b>TOTAL BY JOB FUNCTION</b>								
M AINTENANCE PERSONNEL	226	(77)	720(269)	1,577(704)	2523(1050)	94.770	339.571	685.865
O PERATING PERSONNEL	294	(88)	3(1)	0	297(89)	168.375	0.845	1120.206
H EALTH PHYSICS PERSONNEL	33	(16)	0	187(91)	220(107)	13.410	0.0	169.220
S UPERVISORY PERSONNEL	182	(69)	129(46)	392(160)	703(275)	70.833	0.0	159.041
E NGINEERING PERSONNEL	141	(49)	92(39)	79(36)	312(124)	36.660	56.060	172.451
GRAND TOTAL	876(299)	944(355)	2235(991)	4055(1645)	384.048	423.184	946.718	1753.950

\* Workers may be counted in more than one category. Numbers in parentheses are total numbers of individuals.

**APPENDIX C**

**PLANT: INDIAN POINT 3 (PWR)** **NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION**

WORK & JOB FUNCTION	STATION EMPLOYEES	NUMBER OF PERSONNEL (>100 M-REM)		TOTAL PERSONS	STATION EMPLOYEES	NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION		TOTAL MAN-REMS
		UTILITY	CONTRACT			EMPLOYEES & OTHERS	MAN-REMS	
<b>REACTOR OPERATIONS &amp; SURV.</b>								
MAINTENANCE PERSONNEL	4	0	3	3	2	2,060	0.0	1,790
OPERATING PERSONNEL	32	0	1	32	14,320	0.0	0.160	
HEALTH PHYSICS PERSONNEL	16	0	32	7,860	0.060	12,610		
SUPERVISORY PERSONNEL	7	0	0	3	0.020	0.030	0.160	
ENGINEERING PERSONNEL	9	1	11	2,680	0.430	3,470		
<b>TOTAL</b>	<b>68</b>	<b>1</b>	<b>47</b>	<b>29,940</b>	<b>0.520</b>	<b>18,190</b>	<b>48,650</b>	
<b>ROUTINE MAINTENANCE</b>								
MAINTENANCE PERSONNEL	12	0	38	5,250	0.0	16,940		
OPERATING PERSONNEL	18	0	0	3,400	0.0	0.250		
HEALTH PHYSICS PERSONNEL	14	0	73	18,230	0.10	53,350		
SUPERVISORY PERSONNEL	1	0	1	0.570	0.0	0.360		
ENGINEERING PERSONNEL	0	0	0	0.310	0.180	0.270		
<b>TOTAL</b>	<b>37</b>	<b>0</b>	<b>112</b>	<b>149</b>	<b>27,760</b>	<b>0.190</b>	<b>71,170</b>	<b>99,120</b>
<b>IN-SERVICE INSPECTION</b>								
MAINTENANCE PERSONNEL	0	0	38	0.100	0.0	20,230		
OPERATING PERSONNEL	0	0	4	0.280	0.0	1,450		
HEALTH PHYSICS PERSONNEL	0	0	2	0.060	0.0	0.880		
SUPERVISORY PERSONNEL	2	0	1	0.830	0.0	0.350		
ENGINEERING PERSONNEL	4	2	5	0.980	1.380	2,350		
<b>TOTAL</b>	<b>6</b>	<b>2</b>	<b>50</b>	<b>2,250</b>	<b>1,380</b>	<b>25,260</b>	<b>28,890</b>	
<b>SPECIAL MAINTENANCE</b>								
MAINTENANCE PERSONNEL	71	0	844	54,570	0.0	1085,190		
OPERATING PERSONNEL	26	0	11	12,690	0.0	9,650		
HEALTH PHYSICS PERSONNEL	19	0	46	4,370	0.0	31,150		
SUPERVISORY PERSONNEL	5	0	6	2,850	0.030	4,350		
ENGINEERING PERSONNEL	17	1	5	11,400	1,290	3,280		
<b>TOTAL</b>	<b>138</b>	<b>1</b>	<b>912</b>	<b>1051</b>	<b>85,880</b>	<b>1,320</b>	<b>1133,620</b>	<b>1220,820</b>
<b>WASTE PROCESSING</b>								
MAINTENANCE PERSONNEL	0	0	2	0.200	0.0	4,220		
OPERATING PERSONNEL	0	0	0	0.0	0.050	0.050		
HEALTH PHYSICS PERSONNEL	0	0	0	0.170	0.0	0.0		
SUPERVISORY PERSONNEL	0	0	0	0.020	0.0	0.0		
ENGINEERING PERSONNEL	0	0	0	0.030	0.0	0.010		
<b>TOTAL</b>	<b>0</b>	<b>0</b>	<b>2</b>	<b>0.420</b>	<b>0.0</b>	<b>4,280</b>	<b>4,700</b>	<b>28,260</b>
<b>REFUELING</b>								
MAINTENANCE PERSONNEL	0	0	33	0.670	0.010	20,070		
OPERATING PERSONNEL	5	0	0	4,050	0.0	0.0		
HEALTH PHYSICS PERSONNEL	0	0	1	0.0	0.0	0.130		
SUPERVISORY PERSONNEL	0	0	4	0.050	0.0	2,950		
ENGINEERING PERSONNEL	1	0	0	0.320	0.010	0.0		
<b>TOTAL</b>	<b>6</b>	<b>0</b>	<b>38</b>	<b>44</b>	<b>5,090</b>	<b>0.020</b>	<b>23,150</b>	<b>28,260</b>
<b>TOTAL BY JOB FUNCTION</b>								
MAINTENANCE PERSONNEL	87	0	958	1045	62,850	0.010	1148,440	1211,300
OPERATING PERSONNEL	73	0	16	89	34,740	0.0	11,560	46,300
HEALTH PHYSICS PERSONNEL	49	0	154	203	30,690	0.070	98,120	128,880
SUPERVISORY PERSONNEL	15	0	12	27	7,340	0.060	8,170	15,570
ENGINEERING PERSONNEL	31	4	21	56	15,720	3,290	9,380	28,390
<b>GRAND TOTAL</b>	<b>255</b>	<b>4</b>	<b>1161</b>	<b>1420</b>	<b>151,340</b>	<b>3,430</b>	<b>1275,670</b>	<b>1430,440</b>

**APPENDIX C**

WORK & JOB FUNCTION	(PWR)	NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION							
		1982				1982			
		STATION EMPLOYEES	UTILITY CONTRACT	TOTAL	STATION EMPLOYEES	UTILITY CONTRACT	TOTAL	MAN-REMS	TOTAL
<u>REACTOR OPERATIONS &amp; SURV.</u>									
MAINTENANCE PERSONNEL	5	1	0	0	0	0	0	0.0	0.0
OPERATING PERSONNEL	16	0	0	0	0	2.838	0.0	0.0	0.0
HEALTH PHYSICS PERSONNEL	0	0	0	0	0.0	0.0	0.0	0.0	0.0
SUPERVISORY PERSONNEL	6	0	0	0	0	0.729	0.0	0.0	0.0
ENGINEERING PERSONNEL	4	1	2	3	0.402	0.142	0.164	0.164	0.164
<b>TOTAL</b>	<b>31</b>	<b>2</b>	<b>3</b>	<b>36</b>	<b>4.424</b>	<b>0.142</b>	<b>0.164</b>	<b>4.730</b>	
<u>ROUTINE MAINTENANCE</u>									
MAINTENANCE PERSONNEL	34	16	41	52	5.469	4.637	9.016		
OPERATING PERSONNEL	11	0	11	11	1.188	0.0	2.286		
HEALTH PHYSICS PERSONNEL	16	1	8	11	11.326	0.669	2.475		
SUPERVISORY PERSONNEL	3	0	9	9	0.201	0.0	1.504		
ENGINEERING PERSONNEL	3	0	2	2	0.034	0.0	0.237		
<b>TOTAL</b>	<b>67</b>	<b>17</b>	<b>71</b>	<b>155</b>	<b>18.218</b>	<b>5.306</b>	<b>15.518</b>	<b>39.042</b>	
<u>IN-SERVICE INSPECTION</u>									
MAINTENANCE PERSONNEL	5	1	9	9	0.260	0.0	0.0	0.0	0.982
OPERATING PERSONNEL	0	0	1	1	0.0	0.0	0.0	0.0	0.117
HEALTH PHYSICS PERSONNEL	0	0	0	0	0.0	0.0	0.0	0.0	0.0
SUPERVISORY PERSONNEL	1	0	0	0	0.028	0.0	0.0	0.0	0.0
ENGINEERING PERSONNEL	0	0	0	0	0.0	0.0	0.0	0.0	0.0
<b>TOTAL</b>	<b>6</b>	<b>1</b>	<b>10</b>	<b>17</b>	<b>0.288</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>1.387</b>
<u>SPECIAL MAINTENANCE</u>									
MAINTENANCE PERSONNEL	32	11	52	52	4.458	1.636	19.785		
OPERATING PERSONNEL	14	0	0	0	0.724	0.0	0.0		
HEALTH PHYSICS PERSONNEL	4	1	0	0	0.233	0.072	0.0		
SUPERVISORY PERSONNEL	1	0	0	0	0.008	0.0	0.0		
ENGINEERING PERSONNEL	3	1	6	6	0.013	0.0	1.869		
<b>TOTAL</b>	<b>54</b>	<b>13</b>	<b>58</b>	<b>125</b>	<b>5.436</b>	<b>1.708</b>	<b>21.654</b>	<b>28.793</b>	
<u>WASTE PROCESSING</u>									
MAINTENANCE PERSONNEL	15	8	2	2	0.619	0.108	0.542		
OPERATING PERSONNEL	7	0	0	0	2.534	0.0	0.0		
HEALTH PHYSICS PERSONNEL	6	0	0	0	1.123	0.0	0.0		
SUPERVISORY PERSONNEL	2	0	0	0	0.282	0.0	0.0		
ENGINEERING PERSONNEL	3	0	0	0	0.0	0.0	0.0		
<b>TOTAL</b>	<b>33</b>	<b>8</b>	<b>2</b>	<b>43</b>	<b>4.558</b>	<b>0.108</b>	<b>0.542</b>	<b>5.208</b>	
<u>REFUELING</u>									
MAINTENANCE PERSONNEL	16	8	10	10	1.833	1.918	1.010		
OPERATING PERSONNEL	5	0	12	12	0.004	0.0	5.292		
HEALTH PHYSICS PERSONNEL	0	0	0	0	0.0	0.0	0.0		
SUPERVISORY PERSONNEL	2	0	0	0	0.019	0.0	0.0		
ENGINEERING PERSONNEL	3	0	0	0	0.126	0.0	0.0		
<b>TOTAL</b>	<b>26</b>	<b>8</b>	<b>22</b>	<b>56</b>	<b>1.982</b>	<b>1.918</b>	<b>6.302</b>	<b>10.202</b>	
<u>TOTAL BY JOB FUNCTION</u>									
MAINTENANCE PERSONNEL	107	45	114	266	13.094	8.299	31.335	52.728	
OPERATING PERSONNEL	53	0	24	77	7.288	0.0	7.695	14.983	
HEALTH PHYSICS PERSONNEL	26	2	9	37	12.682	0.741	2.475	15.898	
SUPERVISORY PERSONNEL	15	0	9	24	1.267	0.0	1.504	2.771	
ENGINEERING PERSONNEL	16	2	10	28	0.575	0.162	2.270	2.987	
<b>GRAND TOTAL</b>	<b>217</b>	<b>49</b>	<b>166</b>	<b>432</b>	<b>34.906</b>	<b>9.182</b>	<b>45.279</b>	<b>89.367</b>	

\* Workers may be counted in more than one category.

## PLANT: LACROSSE\*

APPENDIX C  
(BWR) NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION

WORK & JOB FUNCTION	NUMBER OF PERSONNEL EMPLOYEES	1982			TOTAL	STATION EMPLOYEES	TOTAL MAN-REMS	TOTAL
		STATION EMPLOYEES	UTILITY EMPLOYEES	CONTRACT & OTHERS			UTILITY EMPLOYEES	CONTRACT & OTHERS
<u>REACTOR OPERATIONS &amp; SURV.</u>								
MAINTENANCE PERSONNEL	0	0	0	0		0.0	0.0	0.238
OPERATING PERSONNEL	22	0	0	0		38.696	0.0	0.0
HEALTH PHYSICS PERSONNEL	9	0	0	0		11.221	0.0	0.0
SUPERVISORY PERSONNEL	19	0	0	1		10.987	0.100	0.534
ENGINEERING PERSONNEL	3	0	0	0		1.904	0.0	0.0
TOTAL	53	0	0	1	54	62.808	0.100	0.772
								63.680
<u>ROUTINE MAINTENANCE</u>								
MAINTENANCE PERSONNEL	21	0	2			33.314	0.0	0.397
OPERATING PERSONNEL	20	0	0			10.218	0.0	0.0
HEALTH PHYSICS PERSONNEL	6	0	0			2.953	0.0	0.0
SUPERVISORY PERSONNEL	14	0	0			4.737	0.0	0.005
ENGINEERING PERSONNEL	3	0	0			0.964	0.0	0.0
TOTAL	64	0	2			52.186	0.0	0.402
								52.588
<u>IN-SERVICE INSPECTION</u>								
MAINTENANCE PERSONNEL	1	0	17			0.559	0.0	12.629
OPERATING PERSONNEL	0	0	0			0.196	0.0	0.0
HEALTH PHYSICS PERSONNEL	2	0	0			0.417	0.0	0.0
SUPERVISORY PERSONNEL	5	0	0			4.200	0.0	0.005
ENGINEERING PERSONNEL	2	0	0			0.458	0.0	0.0
TOTAL	10	0	17			5.830	0.0	12.634
								18.464
<u>SPECIAL MAINTENANCE</u>								
MAINTENANCE PERSONNEL	17	0	6			14.628	0.0	2.093
OPERATING PERSONNEL	12	0	0			3.548	0.0	0.0
HEALTH PHYSICS PERSONNEL	6	0	0			2.346	0.0	0.0
SUPERVISORY PERSONNEL	9	0	0			4.527	0.0	0.078
ENGINEERING PERSONNEL	3	0	0			2.256	0.0	0.0
TOTAL	47	0	6			27.305	0.0	2.171
								29.476
<u>WASTE PROCESSING</u>								
MAINTENANCE PERSONNEL	7	0	0			2.466	0.0	0.0
OPERATING PERSONNEL	3	0	0			2.015	0.0	0.0
HEALTH PHYSICS PERSONNEL	6	0	0			5.020	0.0	0.0
SUPERVISORY PERSONNEL	7	0	0			4.626	0.0	0.0
ENGINEERING PERSONNEL	1	0	0			1.297	0.0	0.0
TOTAL	24	0	0			15.494	0.0	0.0
								15.494
<u>REFUELING</u>								
MAINTENANCE PERSONNEL	12	0	0			7.417	0.0	0.0
OPERATING PERSONNEL	17	0	0			6.929	0.0	0.0
HEALTH PHYSICS PERSONNEL	6	0	0			2.243	0.0	0.0
SUPERVISORY PERSONNEL	13	0	1			4.663	0.0	0.143
ENGINEERING PERSONNEL	2	0	0			0.509	0.0	0.0
TOTAL	50	0	1			21.761	0.0	0.143
								21.904
<u>TOTAL BY JOB FUNCTION</u>								
MAINTENANCE PERSONNEL	58	0	25			58.384	0.0	15.357
OPERATING PERSONNEL	74	0	0			61.602	0.0	61.602
HEALTH PHYSICS PERSONNEL	35	0	0			24.270	0.0	24.270
SUPERVISORY PERSONNEL	67	0	2			33.740	0.100	34.605
ENGINEERING PERSONNEL	14	0	0			7.388	0.0	7.388
GRAND TOTAL	248 (74)	0	27 (18)			185.384	0.100	16.122
								201.606

\* Workers may be counted in more than one category. Numbers in parentheses are total numbers of individuals.

**APPENDIX C**  
**PLANT: MAINE YANKEE (PWR)** **NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION**

WORK & JOB FUNCTION	EMPLOYEES	NUMBER OF PERSONNEL (>100 M-REM)			TOTAL MAN-REMS		
		STATION EMPLOYEES	UTILITY CONTRACT	TOTAL PERSONS	STATION EMPLOYEES	UTILITY CONTRACT & OTHERS	TOTAL MAN-REMS
<b>REACTOR OPERATIONS &amp; SURV.</b>							
MAINTENANCE PERSONNEL	5	0	1	1	0.965	0.0	0.965
OPERATING PERSONNEL	33	0	0	12.055	0.0	0.0	12.055
HEALTH PHYSICS PERSONNEL	8	0	0	3.375	0.0	0.0	3.375
SUPERVISORY PERSONNEL	9	0	11	3.405	0.0	0.020	3.425
ENGINEERING PERSONNEL	12	0	3	4.655	0.0	0.0	4.655
<b>TOTAL</b>	<b>67</b>	<b>0</b>	<b>20</b>	<b>87</b>	<b>24.455</b>	<b>0.020</b>	<b>8.508</b>
<b>ROUTINE MAINTENANCE</b>							
MAINTENANCE PERSONNEL	24	0	57	21.360	0.0	0.0	21.360
OPERATING PERSONNEL	1	0	0	0.770	0.0	0.0	0.770
HEALTH PHYSICS PERSONNEL	1	0	0	0.675	0.0	0.0	0.675
SUPERVISORY PERSONNEL	22	0	45	11.980	0.0	0.0	11.980
ENGINEERING PERSONNEL	2	0	4	0.825	0.0	0.0	0.825
<b>TOTAL</b>	<b>50</b>	<b>0</b>	<b>106</b>	<b>156</b>	<b>35.610</b>	<b>0.0</b>	<b>65.573</b>
<b>IN-SERVICE INSPECTION</b>							
MAINTENANCE PERSONNEL	18	0	111	8.820	0.0	0.0	8.820
OPERATING PERSONNEL	1	0	1	0.465	0.0	0.0	0.465
HEALTH PHYSICS PERSONNEL	0	0	0	0.0	0.0	0.0	0.0
SUPERVISORY PERSONNEL	6	0	10	2.140	0.0	0.0	2.140
ENGINEERING PERSONNEL	13	0	70	3.660	0.0	0.0	3.660
<b>TOTAL</b>	<b>38</b>	<b>0</b>	<b>192</b>	<b>230</b>	<b>15.085</b>	<b>0.035</b>	<b>114.113</b>
<b>SPECIAL MAINTENANCE</b>							
MAINTENANCE PERSONNEL	1	0	56	0.310	0.0	0.0	0.310
OPERATING PERSONNEL	0	0	0	0.030	0.0	0.0	0.030
HEALTH PHYSICS PERSONNEL	0	0	0	0.0	0.0	0.0	0.0
SUPERVISORY PERSONNEL	1	0	3	0.430	0.0	0.0	0.430
ENGINEERING PERSONNEL	2	0	4	0.480	0.0	0.0	0.480
<b>TOTAL</b>	<b>4</b>	<b>0</b>	<b>63</b>	<b>67</b>	<b>1.250</b>	<b>0.005</b>	<b>38.475</b>
<b>WASTE PROCESSING</b>							
MAINTENANCE PERSONNEL	1	0	6	0.350	0.0	0.0	0.350
OPERATING PERSONNEL	13	0	0	3.180	0.0	0.0	3.180
HEALTH PHYSICS PERSONNEL	0	0	0	0.110	0.0	0.0	0.110
SUPERVISORY PERSONNEL	8	0	1	3.205	0.0	0.0	3.205
ENGINEERING PERSONNEL	0	0	0	0.020	0.0	0.0	0.020
<b>TOTAL</b>	<b>22</b>	<b>0</b>	<b>7</b>	<b>29</b>	<b>6.865</b>	<b>0.0</b>	<b>1.800</b>
<b>REFUELING</b>							
MAINTENANCE PERSONNEL	24	0	306	18.505	0.0	0.0	18.505
OPERATING PERSONNEL	53	0	0	25.671	0.0	0.0	25.671
HEALTH PHYSICS PERSONNEL	12	0	55	3.450	0.0	0.0	3.450
SUPERVISORY PERSONNEL	28	0	23	20.458	0.0	0.0	20.458
ENGINEERING PERSONNEL	16	0	32	5.195	0.005	0.005	5.195
<b>TOTAL</b>	<b>133</b>	<b>0</b>	<b>416</b>	<b>549</b>	<b>73.279</b>	<b>0.005</b>	<b>230.514</b>
<b>TOTAL BY JOB FUNCTION</b>							
MAINTENANCE PERSONNEL	73	0	537	610	50.310	0.0	286.674
OPERATING PERSONNEL	101	0	1	102	42.171	0.0	42.171
HEALTH PHYSICS PERSONNEL	21	0	60	81	7.610	0.0	8.890
SUPERVISORY PERSONNEL	74	0	93	167	41.618	0.060	42.987
ENGINEERING PERSONNEL	45	0	113	158	14.835	0.005	15.310
<b>GRAND TOTAL</b>	<b>314</b>	<b>0</b>	<b>804</b>	<b>1118</b>	<b>156.544</b>	<b>0.065</b>	<b>458.983</b>
							<b>303.798</b>

**APPENDIX C**  
**NUMBER OF PERSONNEL AND MAN-REMS BY WORK AND JOB FUNCTION**  
**1982**

PLANT: MC GUIRE*	(PWR)	NUMBER OF PERSONNEL AND MAN-REMS						TOTAL
		STATION EMPLOYEES		STATION UTILTY CONTRACT		STATION EMPLOYEES		
WORK & JOB FUNCTION	EMPLOYEES	EMPLOYEES	& OTHERS	PERSONS	EMPLOYEES	EMPLOYEES	CONTRACT	TOTAL
<b>REACTOR OPERATIONS &amp; SURV.</b>								
MAINTENANCE PERSONNEL	100	203	47		5.270	7.395	3.345	
OPERATING PERSONNEL	51	1	0		10.124	0.370	0.0	
HEALTH PHYSICS PERSONNEL	57	14	55		9.275	1.080	7.532	
SUPERVISORY PERSONNEL	2	0	0		0.170	0.0	0.0	
ENGINEERING PERSONNEL	29	41	16		2.735	3.165	0.730	
<b>TOTAL</b>	<b>239</b>	<b>259</b>	<b>118</b>	<b>616</b>	<b>27.574</b>	<b>12.010</b>	<b>11.607</b>	<b>51.191</b>
<b>ROUTINE MAINTENANCE</b>								
MAINTENANCE PERSONNEL	112	209	41		16.280	40.065	5.380	
OPERATING PERSONNEL	18	1	0		0.390	0.0	0.0	
HEALTH PHYSICS PERSONNEL	44	9	44		4.575	0.385	8.125	
SUPERVISORY PERSONNEL	1	0	0		0.010	0.0	0.0	
ENGINEERING PERSONNEL	23	39	10		2.745	5.095	0.825	
<b>TOTAL</b>	<b>198</b>	<b>258</b>	<b>95</b>	<b>551</b>	<b>24.000</b>	<b>45.610</b>	<b>14.330</b>	<b>83.940</b>
<b>IN-SERVICE INSPECTION</b>								
MAINTENANCE PERSONNEL	27	74	6		6.085	32.405	0.230	
OPERATING PERSONNEL	0	0	0		0.0	0.0	0.0	
HEALTH PHYSICS PERSONNEL	25	1	28		3.805	0.010	7.340	
SUPERVISORY PERSONNEL	0	0	0		0.0	0.0	0.0	
ENGINEERING PERSONNEL	6	16	11		1.095	5.795	13.955	
<b>TOTAL</b>	<b>58</b>	<b>91</b>	<b>45</b>	<b>194</b>	<b>10.985</b>	<b>38.210</b>	<b>21.525</b>	<b>70.720</b>
<b>SPECIAL MAINTENANCE</b>								
MAINTENANCE PERSONNEL	66	189	14		13.340	83.590	0.425	
OPERATING PERSONNEL	6	1	0		0.125	0.120	0.0	
HEALTH PHYSICS PERSONNEL	28	6	31		1.720	0.255	3.335	
SUPERVISORY PERSONNEL	1	0	0		0.105	0.0	0.0	
ENGINEERING PERSONNEL	17	33	8		5.200	10.310	2.005	
<b>TOTAL</b>	<b>118</b>	<b>229</b>	<b>53</b>	<b>400</b>	<b>20.490</b>	<b>94.275</b>	<b>5.765</b>	<b>120.530</b>
<b>WASTE PROCESSING</b>								
MAINTENANCE PERSONNEL	42	29	29		1.055	0.820	2.000	
OPERATING PERSONNEL	20	0	0		0.355	0.0	0.0	
HEALTH PHYSICS PERSONNEL	32	2	26		2.350	0.015	1.045	
SUPERVISORY PERSONNEL	1	0	0		0.020	0.0	0.0	
ENGINEERING PERSONNEL	7	7	0		0.160	0.075	0.0	
<b>TOTAL</b>	<b>102</b>	<b>38</b>	<b>55</b>	<b>195</b>	<b>3.940</b>	<b>0.910</b>	<b>3.045</b>	<b>7.895</b>
<b>REFUELING</b>								
MAINTENANCE PERSONNEL	2	8	0		0.080	0.730	0.0	
OPERATING PERSONNEL	0	0	0		0.0	0.0	0.0	
HEALTH PHYSICS PERSONNEL	0	0	7		0.0	0.0	0.845	
SUPERVISORY PERSONNEL	0	0	0		0.0	0.0	0.0	
ENGINEERING PERSONNEL	0	0	1		0.0	0.0	0.0	
<b>TOTAL</b>	<b>2</b>	<b>8</b>	<b>8</b>	<b>18</b>	<b>0.080</b>	<b>0.730</b>	<b>0.855</b>	<b>1.665</b>
<b>TOTAL BY JOB FUNCTION</b>								
MAINTENANCE PERSONNEL	349(137)	712(248)	137 (49)		1198(424)	42.110	165.005	11.380
OPERATING PERSONNEL	95 (51)	3 (1)	0		98 (52)	10.994	0.555	0.0
HEALTH PHYSICS PERSONNEL	186 (58)	32 (14)	191 (55)		409 (127)	21.725	1.745	28.222
SUPERVISORY PERSONNEL	5 (2)	0	0		5 (2)	0.305	0.0	0.305
ENGINEERING PERSONNEL	82 (46)	136 (46)	46 (20)		264 (112)	11.935	24.440	17.525
<b>GRAND TOTAL</b>	<b>717(294)</b>	<b>883 (309)</b>	<b>374(124)</b>	<b>1974(717)</b>	<b>87.069</b>	<b>191.745</b>	<b>57.127</b>	<b>*335.941</b>

\*Workers may be counted in more than one category. Numbers in parentheses are total numbers of individuals.  
\*\*30 man-rems due to NRC mandated work.

**APPENDIX C**

**PLANT: MILLSTONE I \* (BWR)**

**NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION  
1982**

WORK & JOB FUNCTION	NUMBER OF PERSONNEL (>100 M-REM)			TOTAL	STATION EMPLOYEES	UTILITIY CONTRACT	TOTAL MAN-REMS	TOTAL
	STATION EMPLOYEES	UTILITY EMPLOYEES	& OTHERS		EMPLOYEES	EMPLOYEES	EMPLOYEES	MAN-REMS
<b>REACTOR OPERATIONS &amp; SURV.</b>								
MAINTENANCE PERSONNEL	19	0	1		7.830	0.0	0.860	
OPERATING PERSONNEL	56	0	0		47.260	0.0	0.290	
HEALTH PHYSICS PERSONNEL	24	2	18		9.720	0.760	5.170	
SUPERVISORY PERSONNEL	0	0	0		0.040	0.0	0.0	
ENGINEERING PERSONNEL	6	0	3		5.180	0.100	1.260	
<b>TOTAL</b>	<b>105</b>	<b>2</b>	<b>22</b>		<b>70.030</b>	<b>0.860</b>	<b>7.580</b>	<b>78.470</b>
<b>ROUTINE MAINTENANCE</b>								
MAINTENANCE PERSONNEL	5	0	0		1.320	0.050	0.030	
OPERATING PERSONNEL	0	0	0		0.020	0.0	0.0	
HEALTH PHYSICS PERSONNEL	0	0	0		0.100	0.0	0.210	
SUPERVISORY PERSONNEL	0	0	1		0.0	0.0	0.200	
ENGINEERING PERSONNEL	0	1	0		0.0	0.0	0.0	
<b>TOTAL</b>	<b>5</b>	<b>1</b>	<b>1</b>		<b>1.440</b>	<b>0.230</b>	<b>0.440</b>	<b>2.110</b>
<b>IN-SERVICE INSPECTION</b>								
MAINTENANCE PERSONNEL	1	0	100		1.150	0.070	57.050	
OPERATING PERSONNEL	1	0	9		0.450	0.0	1.720	
HEALTH PHYSICS PERSONNEL	2	0	10		0.360	0.0	3.350	
SUPERVISORY PERSONNEL	0	0	0		0.030	0.0	0.130	
ENGINEERING PERSONNEL	6	4	21		2.270	2.720	14.770	
<b>TOTAL</b>	<b>10</b>	<b>4</b>	<b>140</b>		<b>4.260</b>	<b>2.790</b>	<b>77.020</b>	<b>84.070</b>
<b>SPECIAL MAINTENANCE</b>								
MAINTENANCE PERSONNEL	67	113	680		81.660	46.110	367.470	
OPERATING PERSONNEL	42	0	23		12.930	0.0	13.020	
HEALTH PHYSICS PERSONNEL	16	2	101		12.790	0.660	48.990	
SUPERVISORY PERSONNEL	3	1	15		0.700	0.130	10.260	
ENGINEERING PERSONNEL	25	35	60		15.240	18.800	36.650	
<b>TOTAL</b>	<b>153</b>	<b>151</b>	<b>879</b>		<b>123.320</b>	<b>65.700</b>	<b>476.390</b>	<b>665.410</b>
<b>WASTE PROCESSING</b>								
MAINTENANCE PERSONNEL	9	0	23		2.560	0.0	13.210	
OPERATING PERSONNEL	12	0	0		4.990	0.0	0.0	
HEALTH PHYSICS PERSONNEL	8	0	10		9.020	0.0	4.300	
SUPERVISORY PERSONNEL	0	0	0		0.0	0.0	0.0	
ENGINEERING PERSONNEL	2	1	2		0.480	0.110	0.760	
<b>TOTAL</b>	<b>31</b>	<b>1</b>	<b>35</b>		<b>17.050</b>	<b>0.110</b>	<b>18.270</b>	<b>35.430</b>
<b>REFUELING</b>								
MAINTENANCE PERSONNEL	40	21	3		23.500	7.270	0.830	
OPERATING PERSONNEL	36	0	0		17.420	0.0	0.050	
HEALTH PHYSICS PERSONNEL	4	0	16		1.630	0.0	6.960	
SUPERVISORY PERSONNEL	0	0	1		0.210	0.0	0.430	
ENGINEERING PERSONNEL	16	4	7		7.000	1.860	2.910	
<b>TOTAL</b>	<b>96</b>	<b>25</b>	<b>27</b>		<b>49.760</b>	<b>9.130</b>	<b>11.180</b>	<b>70.070</b>
<b>TOTAL BY JOB FUNCTION</b>								
MAINTENANCE PERSONNEL	141	134	807		118.020	53.500	439.450	610.970
OPERATING PERSONNEL	147	0	32		179	83.070	15.080	98.150
HEALTH PHYSICS PERSONNEL	54	4	155		213	33.620	1.420	104.020
SUPERVISORY PERSONNEL	3	1	17		21	0.980	0.130	12.130
ENGINEERING PERSONNEL	55	45	93		193	30.170	23.770	110.290
<b>GRAND TOTAL</b>	<b>400</b>	<b>184</b>	<b>1104</b>		<b>1688</b>	<b>265.860</b>	<b>78.820</b>	<b>935.560</b>

\* Workers may be counted in more than one category.

**PLANT: MILLSTONE 2 (PWR)** **APPENDIX C** **NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION**

WORK & JOB FUNCTION	1982			TOTAL			TOTAL MAN-REMS	
	STATION EMPLOYEES	UTILITY EMPLOYEES	& OTHERS	PERSONS	STATION EMPLOYEES	UTILITY EMPLOYEES	& OTHERS	MAN-REMS
<b>REFACTOR OPERATIONS &amp; SURV.</b>								
MAINTENANCE PERSONNEL	3	0	0	0	1	1.850	0.0	0.020
OPERATING PERSONNEL	32	0	0	1	16	1.720	0.0	0.410
HEALTH PHYSICS PERSONNEL	14	0	0	0	6	0.350	0.0	0.300
SUPERVISORY PERSONNEL	0	0	0	0	0	0.0	0.0	0.060
ENGINEERING PERSONNEL	5	1	0	0	1	1.170	0.220	0.080
<b>TOTAL</b>	<b>54</b>	<b>1</b>	<b>0</b>	<b>1</b>	<b>56</b>	<b>26.090</b>	<b>0.220</b>	<b>0.870</b>
<b>ROUTINE MAINTENANCE</b>								
MAINTENANCE PERSONNEL	3	1	0	0	1	1.330	0.370	0.070
OPERATING PERSONNEL	0	0	0	0	0	0.060	0.0	0.020
HEALTH PHYSICS PERSONNEL	0	0	0	0	0	0.050	0.0	0.0
SUPERVISORY PERSONNEL	0	0	0	0	0	0.0	0.0	0.0
ENGINEERING PERSONNEL	0	0	0	0	0	0.060	0.150	0.0
<b>TOTAL</b>	<b>3</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>4</b>	<b>1.500</b>	<b>0.520</b>	<b>0.090</b>
<b>IN-SERVICE INSPECTION</b>								
MAINTENANCE PERSONNEL	11	0	71	71	4	4.250	0.0	61.160
OPERATING PERSONNEL	2	0	15	15	0	0.860	0.0	19.580
HEALTH PHYSICS PERSONNEL	0	0	13	13	0	0.040	0.0	4.790
SUPERVISORY PERSONNEL	0	0	1	1	0	0.080	0.0	0.240
ENGINEERING PERSONNEL	1	2	29	29	0	0.430	0.370	35.520
<b>TOTAL</b>	<b>14</b>	<b>2</b>	<b>129</b>	<b>145</b>	<b>5</b>	<b>5.660</b>	<b>0.370</b>	<b>121.290</b>
<b>** SPECIAL MAINTENANCE</b>								
MAINTENANCE PERSONNEL	65	38	818	818	67	6.940	18.340	882.860
OPERATING PERSONNEL	40	0	38	38	20	0.840	0.010	19.430
HEALTH PHYSICS PERSONNEL	22	3	88	88	9	4.10	1.400	60.490
SUPERVISORY PERSONNEL	1	0	10	10	0	0.950	0.0	7.940
ENGINEERING PERSONNEL	19	26	119	119	9	2.50	9.590	102.100
<b>TOTAL</b>	<b>147</b>	<b>67</b>	<b>1073</b>	<b>1287</b>	<b>108</b>	<b>3.90</b>	<b>29.340</b>	<b>1072.820</b>
<b>WASTE PROCESSING</b>								
MAINTENANCE PERSONNEL	4	0	7	7	1	1.720	0.0	2.090
OPERATING PERSONNEL	8	0	0	0	2	1.140	0.0	0.0
HEALTH PHYSICS PERSONNEL	4	0	1	1	1	1.710	0.0	0.760
SUPERVISORY PERSONNEL	0	0	0	0	0	0.0	0.0	0.0
ENGINEERING PERSONNEL	1	0	0	0	0	0.180	0.090	0.0
<b>TOTAL</b>	<b>17</b>	<b>0</b>	<b>8</b>	<b>25</b>	<b>5</b>	<b>5.750</b>	<b>0.690</b>	<b>2.850</b>
<b>REFUELING</b>								
MAINTENANCE PERSONNEL	25	0	27	27	11	1.740	0.180	14.570
OPERATING PERSONNEL	12	0	6	6	3	0.640	0.0	2.130
HEALTH PHYSICS PERSONNEL	1	1	9	9	0	0.350	0.340	2.760
SUPERVISORY PERSONNEL	0	0	1	1	0	0.010	0.0	0.260
ENGINEERING PERSONNEL	2	1	22	22	0	0.700	0.700	9.200
<b>TOTAL</b>	<b>40</b>	<b>2</b>	<b>65</b>	<b>107</b>	<b>15</b>	<b>8.840</b>	<b>1.220</b>	<b>28.920</b>
<b>TOTAL BY JOB FUNCTION</b>								
MAINTENANCE PERSONNEL	111	39	923	1073	88	8.30	18.890	960.770
OPERATING PERSONNEL	94	0	60	154	43	6.60	0.010	41.570
HEALTH PHYSICS PERSONNEL	41	4	111	156	17	9.10	1.740	85.240
SUPERVISORY PERSONNEL	1	0	12	13	1	0.040	0.0	69.100
ENGINEERING PERSONNEL	28	30	170	228	11	7.90	1.120	8.500
<b>GRAND TOTAL</b>	<b>275</b>	<b>73</b>	<b>1276</b>	<b>1624</b>	<b>31</b>	<b>163.230</b>	<b>31.760</b>	<b>1226.840</b>
<b>** Includes sparger repairs, flow restrictor replacement, steam generator modifications, decontamination, etc.</b>								

**APPENDIX C**  
**NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION**

PLANT: <sup>*</sup> MONTICELLO	(BWR)	1982						TOTAL MAN-REMS MAN-REMS
		NUMBER OF PERSONNEL >100 M-REM)		TOTAL CONTRACT PERSONS		STATION EMPLOYEES		
WORK & JOB FUNCTION	SURV.	STATION EMPLOYEES	UTILITY EMPLOYEES	CONTRACT & OTHERS	STATION EMPLOYEES	UTILITY EMPLOYEES	STATION EMPLOYEES	CONTRACT & OTHERS
<b>REACTOR OPERATIONS &amp; SURV.</b>								
MAINTENANCE PERSONNEL	47	54	226		12.199	1.992	34.806	
OPERATING PERSONNEL	52	0	2		37.598	0.0	0.530	
HEALTH PHYSICS PERSONNEL	19	0	30		7.677	0.0	7.892	
SUPERVISORY PERSONNEL	0	0	0		0.0	0.0	0.0	
ENGINEERING PERSONNEL	30	27	50		7.738	3.651	9.340	
<b>TOTAL</b>	<b>148</b>	<b>81</b>	<b>308</b>	<b>537</b>	<b>65.212</b>	<b>5.643</b>	<b>52.568</b>	<b>123.423</b>
<b>ROUTINE MAINTENANCE</b>								
MAINTENANCE PERSONNEL	58	97	334		25.664	9.842	34.224	
OPERATING PERSONNEL	36	0	0		2.531	0.0	0.0	
HEALTH PHYSICS PERSONNEL	5	0	10		0.470	0.0	1.195	
SUPERVISORY PERSONNEL	0	0	0		0.0	0.0	0.0	
ENGINEERING PERSONNEL	21	11	29		0.956	0.364	2.255	
<b>TOTAL</b>	<b>120</b>	<b>108</b>	<b>373</b>	<b>601</b>	<b>29.621</b>	<b>10.206</b>	<b>37.674</b>	<b>77.501</b>
<b>IN-SERVICE INSPECTION</b>								
MAINTENANCE PERSONNEL	3	11	32		0.037	1.160	22.623	
OPERATING PERSONNEL	0	0	0		0.0	0.0	0.0	
HEALTH PHYSICS PERSONNEL	0	0	0		0.0	0.0	0.0	
SUPERVISORY PERSONNEL	0	0	0		0.0	0.0	0.0	
ENGINEERING PERSONNEL	1	14	31		0.279	8.068	33.381	
<b>TOTAL</b>	<b>4</b>	<b>25</b>	<b>63</b>	<b>92</b>	<b>0.316</b>	<b>9.228</b>	<b>56.004</b>	<b>65.548</b>
<b>SPECIAL MAINTENANCE</b>								
MAINTENANCE PERSONNEL	45	82	590		16.768	19.423	501.542	
OPERATING PERSONNEL	49	0	0		16.271	0.0	0.0	
HEALTH PHYSICS PERSONNEL	14	0	29		3.328	0.0	25.477	
SUPERVISORY PERSONNEL	0	0	0		0.0	0.0	0.0	
ENGINEERING PERSONNEL	25	32	80		6.845	22.471	38.314	
<b>TOTAL</b>	<b>133</b>	<b>114</b>	<b>699</b>	<b>946</b>	<b>43.212</b>	<b>41.894</b>	<b>565.333</b>	<b>650.439</b>
<b>WASTE PROCESSING</b>								
MAINTENANCE PERSONNEL	13	7	11		0.671	0.133	0.227	
OPERATING PERSONNEL	25	0	1		1.468	0.0	0.366	
HEALTH PHYSICS PERSONNEL	2	0	4		0.242	0.0	0.315	
SUPERVISORY PERSONNEL	0	0	0		0.0	0.0	0.0	
ENGINEERING PERSONNEL	2	0	3		0.059	0.0	2.914	
<b>TOTAL</b>	<b>42</b>	<b>7</b>	<b>19</b>	<b>68</b>	<b>2.440</b>	<b>0.133</b>	<b>3.822</b>	<b>6.395</b>
<b>REFUELING</b>								
MAINTENANCE PERSONNEL	22	50	20		2.630	4.009	1.181	
OPERATING PERSONNEL	48	0	0		4.268	0.0	0.0	
HEALTH PHYSICS PERSONNEL	1	0	4		0.016	0.0	0.726	
SUPERVISORY PERSONNEL	0	0	0		0.0	0.0	0.0	
ENGINEERING PERSONNEL	7	2	15		1.326	0.135	2.940	
<b>TOTAL</b>	<b>78</b>	<b>52</b>	<b>39</b>	<b>169</b>	<b>8.240</b>	<b>4.144</b>	<b>4.847</b>	<b>17.231</b>
<b>TOTAL BY JOB FUNCTION</b>								
MAINTENANCE PERSONNEL	188	301	1213		57.969	36.559	594.603	
OPERATING PERSONNEL	210	0	3		62.136	0.0	0.896	
HEALTH PHYSICS PERSONNEL	41	0	77		11.733	0.0	35.605	
SUPERVISORY PERSONNEL	0	0	0		0.0	0.0	0.0	
ENGINEERING PERSONNEL	86	86	208		17.203	34.689	89.144	
<b>GRAND TOTAL</b>	<b>525</b>	<b>387</b>	<b>1501</b>	<b>2413</b>	<b>149.041</b>	<b>71.248</b>	<b>720.248</b>	<b>940.537</b>

\* Workers may be counted in more than one category.

\*\* Includes torus modifications, recirc. pipe repair, jet pump beam modifications, scram discharge pipe modifications.

**APPENDIX C**  
**PLANT: NINE MILE POINT\***      (BWR)      NUMBER OF PERSONNEL AND MAN-REMS  
 1982

WORK & JOB FUNCTION	STATION EMPLOYEES	NUMBER OF PERSONNEL (>100 M-REM)		NUMBER OF PERSONNEL (<100 M-REM)		TOTAL		MAN-REMS	
		UTILITY EMPLOYEES	CONTRACT & OTHERS	PERSONS	EMPLOYEES	STATION	UTILITY EMPLOYEES	CONTRACT & OTHERS	TOTAL
<b>REACTOR OPERATIONS &amp; SURV.</b>									
MAINTENANCE PERSONNEL	135	19	87	121		18.471	1.665	2.686	
OPERATING PERSONNEL	154	21	32	13	12.401	0.280	6.437		
HEALTH PHYSICS PERSONNEL	72	2	39	13	15.968	0.084	9.916		
SUPERVISORY PERSONNEL	48	0	2	2	4.575	0.004	0.184		
ENGINEERING PERSONNEL	12	12	37	10	0.528	0.155	0.770		
<b>TOTAL</b>	<b>421</b>	<b>56</b>	<b>289</b>	<b>766</b>	<b>51.943</b>	<b>2.188</b>	<b>19.993</b>	<b>74.124</b>	
<b>ROUTINE MAINTENANCE</b>									
MAINTENANCE PERSONNEL	87	8	33	32	8.971	0.108	1.396		
OPERATING PERSONNEL	42	2	13	13	1.830	0.039	2.726		
HEALTH PHYSICS PERSONNEL	21	1	2	2	2.085	0.005	0.602		
SUPERVISORY PERSONNEL	14	0	0	0	0.389	0.0	0.160		
ENGINEERING PERSONNEL	6	0	10	10	0.555	0.0	0.586		
<b>TOTAL</b>	<b>170</b>	<b>11</b>	<b>90</b>	<b>271</b>	<b>13.830</b>	<b>0.152</b>	<b>5.470</b>	<b>19.452</b>	
<b>IN-SERVICE INSPECTION</b>									
MAINTENANCE PERSONNEL	29	3	40	40	0.829	0.077	4.537		
OPERATING PERSONNEL	10	4	39	39	0.304	0.050	7.639		
HEALTH PHYSICS PERSONNEL	11	0	6	6	0.612	0.0	0.201		
SUPERVISORY PERSONNEL	12	0	5	5	0.507	0.0	0.645		
ENGINEERING PERSONNEL	5	5	21	21	0.651	0.045	2.357		
<b>TOTAL</b>	<b>67</b>	<b>12</b>	<b>111</b>	<b>190</b>	<b>2.903</b>	<b>0.172</b>	<b>15.379</b>	<b>18.454</b>	
<b>SPECIAL MAINTENANCE</b>									
MAINTENANCE PERSONNEL	622	98	713	539	112.354	18.732	789.948		
OPERATING PERSONNEL	436	18	92	92	52.661	0.293	111.627		
HEALTH PHYSICS PERSONNEL	164	3	31	31	35.932	0.37	28.367		
SUPERVISORY PERSONNEL	108	0	25	156	1.9157	0.0	18.666		
ENGINEERING PERSONNEL	62	25	1331	2867	11.030	2.323	88.398		
<b>TOTAL</b>	<b>1392</b>	<b>144</b>	<b>177</b>	<b>397</b>	<b>231.134</b>	<b>21.385</b>	<b>1037.006</b>	<b>1289.525</b>	
<b>WASTE PROCESSING</b>									
MAINTENANCE PERSONNEL	90	5	83	83	10.481	0.371	12.963		
OPERATING PERSONNEL	65	4	40	40	26.018	0.039	11.372		
HEALTH PHYSICS PERSONNEL	30	1	29	29	4.183	0.002	3.494		
SUPERVISORY PERSONNEL	13	1	4	4	0.775	0.001	1.434		
ENGINEERING PERSONNEL	5	6	21	21	0.064	0.126	1.304		
<b>TOTAL</b>	<b>203</b>	<b>17</b>	<b>177</b>	<b>397</b>	<b>41.521</b>	<b>0.539</b>	<b>30.567</b>	<b>72.627</b>	
<b>REFUELING</b>									
MAINTENANCE PERSONNEL	67	2	1	22	2.547	0.300	0.040		
OPERATING PERSONNEL	74	5	5	5	5.671	0.036	1.011		
HEALTH PHYSICS PERSONNEL	21	0	5	5	1.015	0.0	0.180		
SUPERVISORY PERSONNEL	16	0	1	1	1.394	0.0	0.010		
ENGINEERING PERSONNEL	8	2	1	1	0.180	0.007	0.035		
<b>TOTAL</b>	<b>186</b>	<b>9</b>	<b>30</b>	<b>225</b>	<b>10.807</b>	<b>0.343</b>	<b>1.276</b>	<b>12.426</b>	
<b>TOTAL BY JOB FUNCTION</b>									
MAINTENANCE PERSONNEL	1030	135	957	2122	153.653	21.253	811.570	986.476	
OPERATING PERSONNEL	781	54	593	1428	98.885	0.737	140.812	240.434	
HEALTH PHYSICS PERSONNEL	319	7	184	510	59.795	0.128	42.760	102.683	
SUPERVISORY PERSONNEL	211	3	48	262	26.797	0.005	21.099	47.901	
ENGINEERING PERSONNEL	98	50	246	394	13.008	2.656	9.345	10.9114	
<b>GRAND TOTAL</b>	<b>2439</b>	<b>249</b>	<b>2028</b>	<b>4716</b>	<b>352.138</b>	<b>24.779</b>	<b>1109.691</b>	<b>1486.608</b>	

\* Workers may be counted in more than one category.  
\*\* About 1100 man-rems were due to safe end replacement.

PLANT: NORTH ANNA 1,2 \* (PWR)

APPENDIX C  
NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION

WORK & JOB FUNCTION	NUMBER OF PERSONNEL (1982)			TOTAL MAN-REMS		
	STATION EMPLOYEES	UTILITY EMPLOYEES	>100 M-REM CONTRACT	TOTAL PERSONS	STATION EMPLOYEES	UTILITY EMPLOYEES & OTHERS
<u>REACTOR OPERATIONS &amp; SURV.</u>						
MAINTENANCE PERSONNEL	157	51	141	1	11.401	1.044
OPERATING PERSONNEL	108	0	14	1	11.284	0.0
HEALTH PHYSICS PERSONNEL	53	1	131	1	26.538	0.013
SUPERVISORY PERSONNEL	22	1	1	1	1.833	0.010
ENGINEERING PERSONNEL	23	11	32	1	0.605	0.123
<b>TOTAL</b>	<b>363</b>	<b>64</b>	<b>309</b>	<b>736</b>	<b>51,661</b>	<b>1,190</b>
<u>ROUTINE MAINTENANCE</u>						
MAINTENANCE PERSONNEL	188	77	602	2	226.743	123.283
OPERATING PERSONNEL	176	0	25	1	56.611	0.0
HEALTH PHYSICS PERSONNEL	51	0	127	1	21.642	0.0
SUPERVISORY PERSONNEL	44	3	3	2	1.554	0.059
ENGINEERING PERSONNEL	40	18	115	1	7.249	2.906
<b>TOTAL</b>	<b>499</b>	<b>98</b>	<b>872</b>	<b>1469</b>	<b>323.842</b>	<b>128.262</b>
<u>IN-SERVICE INSPECTION</u>						
MAINTENANCE PERSONNEL	160	34	170	1	27.061	4.522
OPERATING PERSONNEL	189	0	9	1	42.358	0.0
HEALTH PHYSICS PERSONNEL	23	0	71	1	2.416	0.0
SUPERVISORY PERSONNEL	41	3	2	1	1.648	0.251
ENGINEERING PERSONNEL	38	14	29	1	1.648	0.059
<b>TOTAL</b>	<b>431</b>	<b>51</b>	<b>281</b>	<b>763</b>	<b>75.037</b>	<b>4.832</b>
<u>SPECIAL MAINTENANCE</u>						
MAINTENANCE PERSONNEL	131	52	787	2	29.227	15.557
OPERATING PERSONNEL	104	3	3	1	19.225	6.55
HEALTH PHYSICS PERSONNEL	30	0	114	1	12.607	0.0
SUPERVISORY PERSONNEL	29	5	8	1	8.691	4.012
ENGINEERING PERSONNEL	52	23	193	1	14.768	5.987
<b>TOTAL</b>	<b>346</b>	<b>83</b>	<b>1138</b>	<b>1567</b>	<b>84.518</b>	<b>26.211</b>
<u>WASTE PROCESSING</u>						
MAINTENANCE PERSONNEL	53	14	101	1	1.874	0.516
OPERATING PERSONNEL	42	1	12	1	3.833	0.005
HEALTH PHYSICS PERSONNEL	29	0	103	1	7.798	0.0
SUPERVISORY PERSONNEL	1	0	0	1	1.134	0.0
ENGINEERING PERSONNEL	7	0	4	1	0.049	0.0
<b>TOTAL</b>	<b>132</b>	<b>15</b>	<b>220</b>	<b>367</b>	<b>14.688</b>	<b>0.521</b>
<u>REFUELING</u>						
MAINTENANCE PERSONNEL	96	52	79	1	6.657	8.927
OPERATING PERSONNEL	102	0	5	1	15.554	0.0
HEALTH PHYSICS PERSONNEL	15	0	71	1	0.513	0.371
SUPERVISORY PERSONNEL	15	4	3	1	3.013	0.516
ENGINEERING PERSONNEL	17	8	27	1	0.472	0.080
<b>TOTAL</b>	<b>245</b>	<b>64</b>	<b>185</b>	<b>494</b>	<b>26.209</b>	<b>10.945</b>
<u>TOTAL BY JOB FUNCTION</u>						
MAINTENANCE PERSONNEL	765	280	1880	2	302.963	153.849
OPERATING PERSONNEL	721	4	91	1	148.865	0.660
HEALTH PHYSICS PERSONNEL	201	1	617	1	71.514	0.013
SUPERVISORY PERSONNEL	152	16	167	1	27.822	7.353
ENGINEERING PERSONNEL	177	74	400	1	24.791	10.086
<b>GRAND TOTAL</b>	<b>2016</b>	<b>375</b>	<b>3005</b>	<b>5396</b>	<b>575.955</b>	<b>171.961</b>
						<b>49.582</b>

\* Workers may be counted in more than one category.

**APPENDIX C**

**PLANT: OCONEE 1,2,3 \* (PWR)**      **NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION**

WORK & JOB FUNCTION	STATION EMPLOYEES			TOTAL PERSONS			STATION EMPLOYEES			TOTAL MAN-REMS		
	STATION UTILITIES	EMPLOYEES	>100 M-REM	CONTRACT	OTHERS	PERSONS	EMPLOYEES	EMPLOYEES	UTILTY CONTRACT	EMPLOYEES	& OTHERS	MAN-REMS
<b>REACTOR OPERATIONS &amp; SURV.</b>												
MAINTENANCE PERSONNEL	79	238	40			4.990	12.110	12.110		1.595		
OPERATING PERSONNEL	103	11	0	42.460		5.150	0.0	0.0		0.0		
HEALTH PHYSICS PERSONNEL	64	0	97	17.020		0.020	9.656	9.656		0.0		
SUPERVISORY PERSONNEL	3	2	0	0.050		0.115	0.115	0.115		0.0		
ENGINEERING PERSONNEL	87	47	33	11.190		4.110	3.565	3.565		3.565		
<b>TOTAL</b>	<b>336</b>	<b>298</b>	<b>170</b>	<b>804</b>	<b>75.710</b>	<b>21.485</b>	<b>14.816</b>	<b>14.816</b>	<b>1112.011</b>			
<b>ROUTINE MAINTENANCE</b>												
MAINTENANCE PERSONNEL	345	526	147			136.745	76.605	76.605		75.995		
OPERATING PERSONNEL	103	16	0	13.895		2.020	0.0	0.0		0.0		
HEALTH PHYSICS PERSONNEL	83	1	113	13.830		0.0	42.475	42.475		42.475		
SUPERVISORY PERSONNEL	9	0	0	1.365		0.010	0.0	0.0		0.0		
ENGINEERING PERSONNEL	86	48	47	12.570		9.250	5.035	5.035		5.035		
<b>TOTAL</b>	<b>626</b>	<b>591</b>	<b>307</b>	<b>1524</b>	<b>178.405</b>	<b>87.885</b>	<b>123.505</b>	<b>123.505</b>	<b>389.795</b>			
<b>IN-SERVICE INSPECTION</b>												
MAINTENANCE PERSONNEL	113	259	55			24.110	116.005	116.005		18.755		
OPERATING PERSONNEL	11	3	0	0.730		0.105	0.0	0.0		0.0		
HEALTH PHYSICS PERSONNEL	47	0	93	3.905		0.0	20.605	20.605		20.605		
SUPERVISORY PERSONNEL	2	0	0	0.375		0.0	0.0	0.0		0.0		
ENGINEERING PERSONNEL	75	47	88	27.390		12.390	70.265	70.265		70.265		
<b>TOTAL</b>	<b>248</b>	<b>309</b>	<b>236</b>	<b>793</b>	<b>56.510</b>	<b>128.500</b>	<b>109.625</b>	<b>109.625</b>	<b>294.635</b>			
<b>SPECIAL MAINTENANCE</b>												
MAINTENANCE PERSONNEL	540	704	134			276.685	611.577	611.577		40.415		
OPERATING PERSONNEL	90	12	0	13.207		2.020	0.0	0.0		0.0		
HEALTH PHYSICS PERSONNEL	73	0	98	12.740		0.0	59.080	59.080		59.080		
SUPERVISORY PERSONNEL	7	1	0	3.475		0.010	0.0	0.0		0.0		
ENGINEERING PERSONNEL	129	68	94	48.560		24.180	40.660	40.660		40.660		
<b>TOTAL</b>	<b>839</b>	<b>785</b>	<b>326</b>	<b>1950</b>	<b>354.667</b>	<b>637.787</b>	<b>140.155</b>	<b>140.155</b>	<b>1132.609</b>			
<b>WASTE PROCESSING</b>												
MAINTENANCE PERSONNEL	35	56	61			7.585	3.440	3.440		12.090		
OPERATING PERSONNEL	13	1	0	1.840		0.090	0.0	0.0		0.0		
HEALTH PHYSICS PERSONNEL	33	0	54	12.165		0.0	6.400	6.400		6.400		
SUPERVISORY PERSONNEL	0	0	0	0.0		0.0	0.0	0.0		0.0		
ENGINEERING PERSONNEL	21	9	1	5.505		0.455	0.090	0.090		0.090		
<b>TOTAL</b>	<b>102</b>	<b>66</b>	<b>116</b>	<b>284</b>	<b>27.095</b>	<b>3.985</b>	<b>18.580</b>	<b>18.580</b>	<b>49.660</b>			
<b>REFUELING</b>												
MAINTENANCE PERSONNEL	115	93	36			41.555	10.085	10.085		2.725		
OPERATING PERSONNEL	83	6	0	14.245		0.415	0.0	0.0		0.0		
HEALTH PHYSICS PERSONNEL	11	0	72	1.150		0.0	8.440	8.440		8.440		
SUPERVISORY PERSONNEL	2	2	0	1.170		0.080	0.0	0.0		0.0		
ENGINEERING PERSONNEL	31	4	29	5.825		0.615	2.670	2.670		2.670		
<b>TOTAL</b>	<b>242</b>	<b>105</b>	<b>137</b>	<b>484</b>	<b>63.945</b>	<b>11.195</b>	<b>13.835</b>	<b>13.835</b>	<b>88.975</b>			
<b>TOTAL BY JOB FUNCTION</b>												
MAINTENANCE PERSONNEL	1227	(689)	1876(739)	473(200)		3576(1638)	491.670	491.670		151.575		
OPERATING PERSONNEL	403	(120)	49(18)	0		452(138)	86.377	86.377		9.800		
HEALTH PHYSICS PERSONNEL	311	(121)	0	527(120)		838(241)	60.810	60.810		146.556		
SUPERVISORY PERSONNEL	23	(9)	6	(2)		6(11)	6.435	6.435		0.215		
ENGINEERING PERSONNEL	429	(188)	223(79)	292(119)		944(386)	111.040	111.040		51.000		
<b>GRAND TOTAL</b>	<b>2393(1137)</b>	<b>2154(838)</b>	<b>1292(439)</b>	<b>5839(2614)</b>	<b>756.332</b>	<b>890.837</b>	<b>420.516</b>	<b>420.516</b>	<b>2067.685</b>			

\* Workers may be counted in more than one category. Numbers in parentheses are total numbers of individuals.

\*\* 406 man-rems were due to NRC mandated work.

**APPENDIX C**  
**PLANT: OYSTER CREEK \***      **(CBWR)**      **NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION**

WORK & JOB FUNCTION	STATION EMPLOYEES	NUMBER OF PERSONNEL ( $>100$ M-REM)		TOTAL PERSONS	STATION EMPLOYEES	NUMBER OF PERSONNEL ( $>100$ M-REM)		TOTAL PERSONS	STATION EMPLOYEES	NUMBER OF PERSONNEL ( $>100$ M-REM)		TOTAL PERSONS
		STATION UTILITy EMPLOYEES	CONTRACT & OTHERS			STATION UTILITy EMPLOYEES	CONTRACT & OTHERS			STATION UTILITy EMPLOYEES	CONTRACT & OTHERS	
<b>REACTOR OPERATIONS &amp; SURV.</b>												
MAINTENANCE PERSONNEL	67	12	42			5.990	0.192			11.746	0.0	
OPERATING PERSONNEL	37	1	0			2.341	0.0			1.574	0.0	
HEALTH PHYSICS PERSONNEL	11	0	24			1.059	0.0			2.096	0.0	
SUPERVISORY PERSONNEL	10	0	0			0.735	0.0			0.315	0.0	
ENGINEERING PERSONNEL	18	0	1			2.803	0.0			4.801	0.0	
<b>TOTAL</b>	<b>143</b>	<b>13</b>	<b>67</b>	<b>223</b>	<b>12.928</b>	<b>0.192</b>	<b>14.157</b>	<b>27.277</b>				
<b>ROUTINE MAINTENANCE</b>												
MAINTENANCE PERSONNEL	218	38	297			121.027	9.794			72.097	0.0	
OPERATING PERSONNEL	159	1	26			61.883	0.015			1.453	0.0	
HEALTH PHYSICS PERSONNEL	58	0	68			24.968	0.0			4.654	0.0	
SUPERVISORY PERSONNEL	51	0	1			6.426	0.0			0.255	0.0	
ENGINEERING PERSONNEL	68	1	38			6.609	0.013			0.0	0.0	
<b>TOTAL</b>	<b>554</b>	<b>40</b>	<b>430</b>	<b>1024</b>	<b>220.913</b>	<b>9.822</b>	<b>117.332</b>	<b>348.067</b>				
<b>IN-SERVICE INSPECTION</b>												
MAINTENANCE PERSONNEL	30	4	2			1.640	1.642			0.015	0.0	
OPERATING PERSONNEL	7	0	1			1.282	0.0			0.016	0.0	
HEALTH PHYSICS PERSONNEL	4	0	9			0.500	0.0			0.255	0.0	
SUPERVISORY PERSONNEL	3	0	0			0.217	0.0			0.0	0.0	
ENGINEERING PERSONNEL	8	0	2			0.592	0.0			0.260	0.0	
<b>TOTAL</b>	<b>52</b>	<b>4</b>	<b>14</b>	<b>70</b>	<b>4.231</b>	<b>1.642</b>	<b>0.546</b>	<b>6.419</b>				
<b>SPECIAL MAINTENANCE</b>												
MAINTENANCE PERSONNEL	150	33	317			23.259	18.537			246.577	0.0	
OPERATING PERSONNEL	49	1	4			3.517	1.122			1.453	0.0	
HEALTH PHYSICS PERSONNEL	28	0	36			2.895	0.0			4.654	0.0	
SUPERVISORY PERSONNEL	15	0	1			0.944	0.0			0.005	0.0	
ENGINEERING PERSONNEL	17	0	7			2.020	0.0			3.863	0.0	
<b>TOTAL</b>	<b>259</b>	<b>34</b>	<b>365</b>	<b>658</b>	<b>32.635</b>	<b>19.659</b>	<b>256.552</b>	<b>308.846</b>				
<b>WASTE PROCESSING</b>												
MAINTENANCE PERSONNEL	89	0	33			2.696	0.0			11.794	0.0	
OPERATING PERSONNEL	17	0	2			1.324	0.0			0.018	0.0	
HEALTH PHYSICS PERSONNEL	15	0	8			1.030	0.0			2.388	0.0	
SUPERVISORY PERSONNEL	3	0	0			0.166	0.0			0.0	0.0	
ENGINEERING PERSONNEL	1	0	1			0.006	0.0			0.196	0.0	
<b>TOTAL</b>	<b>125</b>	<b>0</b>	<b>44</b>	<b>169</b>	<b>5.222</b>	<b>0.0</b>	<b>14.396</b>	<b>19.618</b>				
<b>REFUELING</b>												
MAINTENANCE PERSONNEL	1	0	4			0.0	0.0			0.070	0.0	
OPERATING PERSONNEL	0	0	0			0.0	0.0			0.0	0.0	
HEALTH PHYSICS PERSONNEL	0	0	0			0.0	0.0			0.0	0.0	
SUPERVISORY PERSONNEL	0	0	0			0.0	0.0			0.0	0.0	
ENGINEERING PERSONNEL	0	0	0			0.0	0.0			0.0	0.0	
<b>TOTAL</b>	<b>1</b>	<b>0</b>	<b>4</b>	<b>5</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.070</b>				
<b>TOTAL BY JOB FUNCTION</b>												
MAINTENANCE PERSONNEL	555	(226)	695(415)			154.612	30.165			527.076	0.0	
OPERATING PERSONNEL	269	(161)	3(1)			70.347	1.137			74.545	0.0	
HEALTH PHYSICS PERSONNEL	116	(58)	145(69)			26.1(27)	30.452			78.596	0.0	
SUPERVISORY PERSONNEL	82	(52)	0			84(53)	8.488			8.602	0.0	
ENGINEERING PERSONNEL	112	(74)	1(1)			162(115)	12.030			21.478	0.0	
<b>GRAND TOTAL</b>	<b>1134(571)</b>	<b>9(14)</b>	<b>924(553)</b>	<b>2149(116)</b>	<b>275.929</b>	<b>31.315</b>	<b>403.053</b>	<b>710.297</b>				

\* Workers may be counted in more than one category. Numbers in parentheses are total numbers of individuals.

**APPENDIX C**

PLANT: PALISADES	(PWR)	NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION										TOTAL MAN-REMS	
		STATION EMPLOYEES		NUMBER OF PERSONNEL (>100 M-REM)		TOTAL CONTRACT PERSONS		STATION EMPLOYEES		UTILITY EMPLOYEES			
		MAINTENANCE PERSONNEL	OPERATING PERSONNEL	HEALTH PHYSICS PERSONNEL	SUPERVISORY PERSONNEL	ENGINEERING PERSONNEL	TOTAL	MAINTENANCE PERSONNEL	OPERATING PERSONNEL	HEALTH PHYSICS PERSONNEL	SUPERVISORY PERSONNEL	ENGINEERING PERSONNEL	
REACTOR OPERATIONS & SURV.		1	0	0	0	0	0	0.299	0.0	0.048	0.0	0.0	0.0
MAINTENANCE PERSONNEL	25	0	0	0	0	0	0	7.132	7.132	0.0	0.0	0.013	0.013
OPERATING PERSONNEL					45			20.262	20.262	0.560	0.60	20.310	20.310
HEALTH PHYSICS PERSONNEL	51	2	0	0	0	0	0	1.770	1.770	0.660	0.651	0.060	0.060
SUPERVISORY PERSONNEL	0	0	0	0	0	0	0	0.986	0.986	0.415	0.550	0.134	0.134
ENGINEERING PERSONNEL	5	2	0	0	2			0.467	0.467	0.039	0.162	0.046	0.046
<b>TOTAL</b>	<b>87</b>	<b>4</b>	<b>47</b>	<b>138</b>	<b>30.449</b>			<b>30.449</b>	<b>30.449</b>	<b>1.083</b>	<b>20.924</b>	<b>52.456</b>	<b>52.456</b>
ROUTINE MAINTENANCE								26.442	26.442	0.824	0.824	3.512	3.512
MAINTENANCE PERSONNEL	80	3	17					0.0	0.0	0.007	0.007	0.0	0.0
OPERATING PERSONNEL	0	0	0					0.053	0.053	0.004	0.004	0.060	0.060
HEALTH PHYSICS PERSONNEL	0	0	0					1.063	1.063	0.007	0.007	0.162	0.162
SUPERVISORY PERSONNEL	4	0	0					0.467	0.467	0.039	0.039	0.243	0.243
ENGINEERING PERSONNEL	2	0	1					0.106	0.106	0.0	0.0	0.902	0.902
<b>TOTAL</b>	<b>86</b>	<b>3</b>	<b>18</b>	<b>107</b>	<b>28.025</b>			<b>28.025</b>	<b>28.025</b>	<b>0.881</b>	<b>0.881</b>	<b>32.774</b>	<b>32.774</b>
IN-SERVICE INSPECTION								0.0	0.0	0.0	0.0	0.521	0.521
MAINTENANCE PERSONNEL	0	0	0					0.0	0.0	0.0	0.0	0.0	0.0
OPERATING PERSONNEL	0	0	0					0.014	0.014	0.0	0.0	0.0	0.0
HEALTH PHYSICS PERSONNEL	0	0	0					0.039	0.039	0.0	0.0	0.332	0.332
SUPERVISORY PERSONNEL	0	0	0					0.053	0.053	0.0	0.0	0.243	0.243
ENGINEERING PERSONNEL	0	0	1					0.106	0.106	0.0	0.0	0.796	0.796
<b>TOTAL</b>	<b>0</b>	<b>0</b>	<b>3</b>	<b>3</b>	<b>0.106</b>			<b>0.106</b>	<b>0.106</b>	<b>0.0</b>	<b>0.0</b>	<b>0.796</b>	<b>0.796</b>
SPECIAL MAINTENANCE								16.845	16.845	12.618	12.618	112.836	112.836
MAINTENANCE PERSONNEL	69	34	358					0.0	0.0	0.0	0.0	0.113	0.113
OPERATING PERSONNEL	0	0	1					0.0	0.0	0.0	0.0	0.0	0.0
HEALTH PHYSICS PERSONNEL	0	0	0					0.123	0.123	0.162	0.162	1.248	1.248
SUPERVISORY PERSONNEL	0	1	7					20	20	1.341	1.341	5.151	5.151
ENGINEERING PERSONNEL	3	0	20					386	386	18.309	18.309	119.348	119.348
<b>TOTAL</b>	<b>72</b>	<b>35</b>	<b>386</b>	<b>493</b>	<b>12.843</b>			<b>12.843</b>	<b>12.843</b>	<b>119.348</b>	<b>119.348</b>	<b>150.500</b>	<b>150.500</b>
WASTE PROCESSING								0.099	0.099	0.099	0.099	0.0	0.0
MAINTENANCE PERSONNEL	1	1	0					0	0	0.0	0.0	0.0	0.0
OPERATING PERSONNEL	0	0	2					0	0	0.099	0.099	1.543	1.543
HEALTH PHYSICS PERSONNEL	1	0	0					0	0	0.0	0.0	0.025	0.025
SUPERVISORY PERSONNEL	0	0	0					0	0	0.0	0.0	0.0	0.0
ENGINEERING PERSONNEL	0	0	0					0	0	0.042	0.042	0.332	0.332
<b>TOTAL</b>	<b>2</b>	<b>1</b>	<b>2</b>	<b>5</b>	<b>0.209</b>			<b>0.209</b>	<b>0.209</b>	<b>0.141</b>	<b>0.141</b>	<b>1.600</b>	<b>1.600</b>
REFUELING								0.0	0.0	0.0	0.0	0.0	0.0
MAINTENANCE PERSONNEL	0	0	0					0	0	0.046	0.046	0.0	0.0
OPERATING PERSONNEL	0	0	0					0	0	0.0	0.0	0.0	0.0
HEALTH PHYSICS PERSONNEL	0	0	0					0	0	0.0	0.0	0.0	0.0
SUPERVISORY PERSONNEL	0	0	0					0	0	0.0	0.0	0.0	0.0
ENGINEERING PERSONNEL	0	0	0					0	0	0.046	0.046	0.0	0.046
<b>TOTAL</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>			<b>0</b>	<b>0</b>	<b>0.0</b>	<b>0.0</b>	<b>0</b>	<b>0</b>
TOTAL BY JOB FUNCTION								566	566	43.685	43.685	116.869	116.869
MAINTENANCE PERSONNEL	151	38	377					28	28	7.178	7.178	1.669	1.669
OPERATING PERSONNEL	25	0	3					45	45	20.428	20.428	3.387	3.387
HEALTH PHYSICS PERSONNEL	52	2	17					17	17	2.995	2.995	0.229	0.229
SUPERVISORY PERSONNEL	9	1	2					24	24	2.858	2.858	0.559	0.559
ENGINEERING PERSONNEL	10	2	456					746	746	77.144	77.144	14.948	14.948
<b>GRAND TOTAL</b>	<b>247</b>	<b>43</b>	<b>456</b>					<b>746</b>	<b>746</b>	<b>146.536</b>	<b>146.536</b>	<b>238.628</b>	<b>238.628</b>

**APPENDIX C**  
**PLANT: PEACH BOTTOM 2,3 (BWR)**  
**NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION**

WORK & JOB FUNCTIONS & SURV.	NUMBER OF PERSONNEL (BWR)		NUMBER OF PERSONNEL (>100 M-REM)		TOTAL		TOTAL MAN-REMS		TOTAL MAN-REMS	
	STATION EMPLOYEES	UTILITY EMPLOYEES	CONTRACT & OTHERS	PERSONS	STATION EMPLOYEES	UTILITY EMPLOYEES	EMPLOYEES	CONTRACT & OTHERS	EMPLOYEES	MAN-REMS
<b>REACTOR OPERATIONS &amp; SURV.</b>										
MAINTENANCE PERSONNEL	3	62	53		0.533	31.747		20.562		
OPERATING PERSONNEL		4	30		63.945	1.248		5.059		
HEALTH PHYSICS PERSONNEL	68	1	49		52.618	0.258		52.277		
SUPERVISORY PERSONNEL	62	0	19		3.971	0.0		6.580		
ENGINEERING PERSONNEL	0	1	0		0.0	0.481		0.0		
<b>TOTAL</b>	<b>187</b>	<b>74</b>	<b>145</b>	<b>12</b>	<b>45.436</b>	<b>1.924</b>	<b>12.344</b>	<b>12.344</b>	<b>90.425</b>	<b>288.134</b>
<b>ROUTINE MAINTENANCE</b>										
MAINTENANCE PERSONNEL	7	524	970		4.822	349.903		990.657		
OPERATING PERSONNEL	5	21	10		1.044	1.255		6.087		
HEALTH PHYSICS PERSONNEL	13	0	19		0.0	0.0		0.0		
SUPERVISORY PERSONNEL	0	1	0		0.0	0.0		0.0		
ENGINEERING PERSONNEL	13	14	12		4.156	5.559		4.037		
<b>TOTAL</b>	<b>38</b>	<b>540</b>	<b>1011</b>	<b>1589</b>	<b>13.993</b>	<b>357.198</b>	<b>1007.361</b>	<b>1378.552</b>	<b>52.212</b>	<b>52.212</b>
<b>IN-SERVICE INSPECTION</b>										
MAINTENANCE PERSONNEL	0		3	36	0.0	0.0		1.090		48.360
OPERATING PERSONNEL	0		0	0	0.0	0.0		0.0		0.0
HEALTH PHYSICS PERSONNEL	0		0	0	0.0	0.0		0.0		0.0
SUPERVISORY PERSONNEL	0		0	2	0.0	0.0		0.0		1.380
ENGINEERING PERSONNEL	0		2	2	0.0	0.0		0.0		1.012
<b>TOTAL</b>	<b>0</b>	<b>0</b>	<b>5</b>	<b>40</b>	<b>4.5</b>	<b>0.0</b>	<b>1.460</b>	<b>50.752</b>	<b>52.212</b>	<b>52.212</b>
<b>SPECIAL MAINTENANCE</b>										
MAINTENANCE PERSONNEL	0		2	72	0.0	0.0		0.445		79.138
OPERATING PERSONNEL	0		0	0	0.0	0.0		0.0		0.0
HEALTH PHYSICS PERSONNEL	0		0	0	0.0	0.0		0.0		0.0
SUPERVISORY PERSONNEL	0		0	1	0.0	0.0		0.0		0.102
ENGINEERING PERSONNEL	0		0	2	0.0	0.0		0.0		0.652
<b>TOTAL</b>	<b>0</b>	<b>0</b>	<b>2</b>	<b>75</b>	<b>77</b>	<b>0.0</b>	<b>0.445</b>	<b>79.892</b>	<b>80.337</b>	<b>80.337</b>
<b>WASTE PROCESSING</b>										
MAINTENANCE PERSONNEL	0		1	13	0.0	0.0		0.325		9.046
OPERATING PERSONNEL	9	0	1	1	3.638	0.0		0.0		0.260
HEALTH PHYSICS PERSONNEL	4	0	0	0	1.309	0.0		0.0		0.0
SUPERVISORY PERSONNEL	0	0	0	0	0.0	0.0		0.0		0.0
ENGINEERING PERSONNEL	0	0	1	0	0.0	0.0		0.0		0.110
<b>TOTAL</b>	<b>13</b>	<b>1</b>	<b>15</b>	<b>29</b>	<b>4.947</b>	<b>0.325</b>	<b>9.416</b>	<b>9.416</b>	<b>9.416</b>	<b>14.688</b>
<b>REFUELING</b>										
MAINTENANCE PERSONNEL	0		18		0.0	0.0		2.452		3.319
OPERATING PERSONNEL	2	8	0		0.471	0.0		0.0		0.0
HEALTH PHYSICS PERSONNEL	1	0	0		0.240	0.0		0.0		0.0
SUPERVISORY PERSONNEL	0	1	0		0.0	0.540		0.0		0.0
ENGINEERING PERSONNEL	0	0	0		0.0	0.0		0.0		0.0
<b>TOTAL</b>	<b>3</b>	<b>9</b>	<b>18</b>	<b>30</b>	<b>0.711</b>	<b>2.992</b>	<b>3.319</b>	<b>3.319</b>	<b>3.319</b>	<b>7.022</b>
<b>TOTAL BY JOB FUNCTION</b>										
MAINTENANCE PERSONNEL	10 (10)	600 (665)	1162 (1076)		5.355	385.962		1151.082		1542.399
OPERATING PERSONNEL	2 (74)	5 (6)	4 (3)		130 (123)	69.098		2.503		85.007
HEALTH PHYSICS PERSONNEL	84 (63)	1 (1)	68 (58)		149 (122)	58.138		0.258		58.857
SUPERVISORY PERSONNEL	0	1	0		4 (3)	6 (6)		1.021		117.253
ENGINEERING PERSONNEL	67 (54)	2 (3)	23 (20)		119 (94)	49.592		7.853		1.665
<b>GRAND TOTAL</b>	<b>241 (201)</b>	<b>631 (655)</b>	<b>1304 (1200)</b>	<b>2176 (1966)</b>	<b>182.183</b>	<b>397.597</b>	<b>1241.165</b>	<b>1820.945</b>	<b>1820.945</b>	<b>1820.945</b>

\*Workers may be counted in more than one category. Numbers in parentheses are total numbers of individuals.

## APPENDIX C NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION

APPENDIX C

## NUMBER OF PERSONNEL AND MAN-RE-

PLANT: PILGRIM		(BWTR)		1982		TOTAL		MAN-REMS	
WORK & JOB FUNCTION	REACTOR OPERATIONS & SURV...	NUMBER OF PERSONNEL		>100 M-REM)		TOTAL	STATION EMPLOYEES	UTILITY CONTRACT	TOTAL
		STATION EMPLOYEES	UTILITY CONTRACT	EMPLOYEES	& OTHERS				
MAINTENANCE PERSONNEL	76	1	324	0	0	46.090	1.445	38.045	
OPERATING PERSONNEL	40	0	0	0	0	15.040	0.0	0.0	
HEALTH PHYSICS PERSONNEL	35	0	77	0	0	17.430	0.0	12.345	
SUPERVISORY PERSONNEL	103	1	18	9	1	62.080	0.645	2.880	
ENGINEERING PERSONNEL	21	7	41	3	1	10.055	18.525	7.580	
TOTAL	277	103	460	838	150	695	20.615	60.850	232.160

卷之三

108

SUPERVISORY PERSONNEL	20	16	18	2.362	3.712	3.622
ENGINEERING PERSONNEL	10	1	26	0.610	0.330	2.540
TOTAL	135	28	1119	1282	18.630	6.935
WASTE PROCESSING						
MAINTENANCE PERSONNEL	67	2	109	9.855	0.165	27.235
OPERATING PERSONNEL	15	0	0	28.710	0.0	0.0
HEALTH PHYSICS PERSONNEL	26	0	60	5.560	0.0	27.695
SUPERVISORY PERSONNEL	8	2	6	3.240	0.330	4.220
ENGINEERING PERSONNEL	2	2	0	0.055	0.0	0.0
TOTAL	111	125	200	62.620	0.250	59.150
						106.820

卷之三

REFUELING		TOTAL BY JOB FUNCTION		REFUELING	
		Maintenance Personnel	Operating Personnel	Health Physics Personnel	Supervisory Personnel
Maintenance Personnel	24	0	75	2,520	0.0
Operating Personnel	10	0	0	0,140	0.0
Health Physics Personnel	6	0	15	0,590	0.0
Supervisory Personnel	4	0	1	0,035	0.0
Engineering Personnel	2	0	2	0,090	0.0
<b>TOTAL</b>	<b>46</b>	<b>0</b>	<b>93</b>	<b>3,375</b>	<b>0.0</b>
					<b>7,355</b>
					<b>10.730</b>

REFUELING		TOTAL BY JOB FUNCTION		REFUELING	
		Maintenance Personnel	Operating Personnel	Health Physics Personnel	Supervisory Personnel
Maintenance Personnel	24	0	75	2,520	0.0
Operating Personnel	10	0	0	0,140	0.0
Health Physics Personnel	6	0	15	0,590	0.0
Supervisory Personnel	4	0	1	0,035	0.0
Engineering Personnel	2	0	2	0,090	0.0
<b>TOTAL</b>	<b>46</b>	<b>0</b>	<b>93</b>	<b>3,375</b>	<b>0.0</b>
					<b>7,355</b>
					<b>10.730</b>

REFUELING		TOTAL BY JOB FUNCTION		REFUELING	
		Maintenance Personnel	Operating Personnel	Health Physics Personnel	Supervisory Personnel
Maintenance Personnel	24	0	75	2,520	0.0
Operating Personnel	10	0	0	0,140	0.0
Health Physics Personnel	6	0	15	0,590	0.0
Supervisory Personnel	4	0	1	0,035	0.0
Engineering Personnel	2	0	2	0,090	0.0
<b>TOTAL</b>	<b>46</b>	<b>0</b>	<b>93</b>	<b>3,375</b>	<b>0.0</b>
					<b>7,355</b>
					<b>10.730</b>

**Numbers in parentheses are total numbers of individuals**

## APPENDIX C

## NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION

Plant: Point Beach 1, 2 (PWR) 1982

WORK & JOB FUNCTION	NUMBER OF PERSONNEL (>100 mrem)			TOTAL MAN-REMS				
	STATION EMPLOYEES	UTILITY EMPLOYEES	CONTRACT & OTHERS	TOTAL PERSONS	STATION EMPLOYEES	UTILITY EMPLOYEES	CONTRACT & OTHERS	TOTAL MAN-REM
Reactor Operations & Surv.					0.0			
Maintenance Personnel					34.637			
Operating Personnel					33.519			
Health Physics Personnel					0.630			
Supervisory Personnel					0.020			
Engineering Personnel					68.806			
<b>TOTAL</b>					<b>0.220</b>			<b>69.026</b>
Routine Maintenance					29.201			
Maintenance Personnel					0.0			
Operating Personnel					0.0			
Health Physics Personnel					0.0			
Supervisory Personnel					0.0			
Engineering Personnel					0.0			
<b>TOTAL</b>					<b>29.201</b>			<b>0.0</b>
In-Service Inspection					4.216			
Maintenance Personnel					13.885			
Operating Personnel					0.0			
Health Physics Personnel					8.465			
Supervisory Personnel					0.110			
Engineering Personnel					26.676			
<b>TOTAL</b>					<b>93.737</b>			<b>210.413</b>
Special Maintenance					46.428			
Maintenance Personnel					0.0			
Operating Personnel					0.0			
Health Physics Personnel					1.645			
Supervisory Personnel					0.0			
Engineering Personnel					48.073			
<b>TOTAL</b>					<b>48.073</b>			<b>258.523</b>
Waste Processing					0.170			
Maintenance Personnel					5.282			
Operating Personnel					5.116			
Health Physics Personnel					0.0			
Supervisory Personnel					0.0			
Engineering Personnel					10.568			
<b>TOTAL</b>					<b>10.568</b>			<b>306.596</b>
Refueling					35.005			
Maintenance Personnel					4.536			
Operating Personnel					1.065			
Health Physics Personnel					0.020			
Supervisory Personnel					0.590			
Engineering Personnel					41.216			
<b>TOTAL</b>					<b>41.216</b>			<b>41.276</b>
Total By Job Function	99				115.020			
Maintenance Personnel	65				58.340			
Operating Personnel	27				39.700			
Health Physics Personnel	18				10.760			
Supervisory Personnel	1				0.720			
Engineering Personnel	120				388	598	224.540	583.525
<b>GRAND TOTAL</b>					<b>388</b>	<b>598</b>	<b>224.540</b>	<b>583.525</b>

**PLANT: <sup>†</sup>PRAIRIE ISLAND 1,2 (PWR)**      **NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION**

WORK & JOB FUNCTION	STATION EMPLOYEES			TOTAL			STATION EMPLOYEES			TOTAL		
	UTILITY CONTRACT	OTHERS	PERSONS	EMPLOYEES	EMPLOYEES	PERSONS	EMPLOYEES	EMPLOYEES	PERSONS	EMPLOYEES	EMPLOYEES	PERSONS
<b>REACTOR OPERATIONS &amp; SURV.</b>												
Maintenance Personnel	16	5	0		4.907		1.439		0.103			
Operating Personnel	46	0	0		12.401		0.010		0.018			
Health Physics Personnel	14	0	1		6.743		0.0		0.700			
Supervisory Personnel	2	0	0		0.869		0.008		0.145			
Engineering Personnel	1	0	0		0.557		0.028		0.176			
<b>TOTAL</b>	<b>79</b>	<b>5</b>	<b>1</b>	<b>85</b>	<b>25.477</b>		<b>1.485</b>		<b>1.142</b>		<b>28.104</b>	
<b>ROUTINE MAINTENANCE</b>												
Maintenance Personnel	30	21	6		9.158		10.488		2.032			
Operating Personnel	2	0	0		0.734		0.0		0.0			
Health Physics Personnel	3	0	0		1.142		0.0		0.104			
Supervisory Personnel	1	0	0		0.127		0.109		0.036			
Engineering Personnel	4	0	1		1.325		0.005		0.679			
<b>TOTAL</b>	<b>40</b>	<b>21</b>	<b>7</b>	<b>68</b>	<b>12.486</b>		<b>10.602</b>		<b>2.851</b>		<b>25.939</b>	
<b>IN-SERVICE INSPECTION</b>												
Maintenance Personnel	11	8	55		3.532		2.577		25.798			
Operating Personnel	0	0	0		0.001		0.0		0.0			
Health Physics Personnel	3	0	14		1.151		0.0		3.449			
Supervisory Personnel	0	1	0		0.0		0.562		0.0			
Engineering Personnel	4	1	8		0.930		0.186		2.613			
<b>TOTAL</b>	<b>18</b>	<b>10</b>	<b>77</b>	<b>105</b>	<b>5.614</b>		<b>3.325</b>		<b>31.860</b>		<b>40.799</b>	
<b>SPECIAL MAINTENANCE</b>												
Maintenance Personnel	33	56	40		12.382		26.727		14.697			
Operating Personnel	2	0	0		0.682		0.029		0.061			
Health Physics Personnel	10	0	16		3.141		0.0		3.417			
Supervisory Personnel	0	0	2		0.110		0.083		0.776			
Engineering Personnel	5	1	9		1.479		0.137		3.553			
<b>TOTAL</b>	<b>50</b>	<b>57</b>	<b>67</b>	<b>174</b>	<b>17.794</b>		<b>26.976</b>		<b>22.504</b>		<b>67.274</b>	
<b>WASTE PROCESSING</b>												
Maintenance Personnel	28	0	12		9.750		0.0		3.382			
Operating Personnel	8	0	0		2.421		0.0		0.0			
Health Physics Personnel	9	0	1		4.360		0.0		0.294			
Supervisory Personnel	1	0	0		0.215		0.0		0.0			
Engineering Personnel	0	0	0		0.048		0.0		0.0			
<b>TOTAL</b>	<b>46</b>	<b>0</b>	<b>13</b>	<b>59</b>	<b>16.794</b>		<b>0.0</b>		<b>3.676</b>		<b>20.470</b>	
<b>REFUELING</b>												
Maintenance Personnel	32	45	1		13.238		12.039		0.192			
Operating Personnel	7	0	0		2.514		0.0		0.005			
Health Physics Personnel	0	0	1		0.174		0.0		0.267			
Supervisory Personnel	0	0	0		0.028		0.012		0.015			
Engineering Personnel	3	0	0		0.827		0.082		0.069			
<b>TOTAL</b>	<b>42</b>	<b>45</b>	<b>2</b>	<b>89</b>	<b>16.781</b>		<b>12.133</b>		<b>0.548</b>		<b>29.462</b>	
<b>TOTAL BY JOB FUNCTION</b>												
Maintenance Personnel	150	135	114		52.967		53.270		46.204		152.441	
Operating Personnel	65	0	65		18.753		0.039		0.084		18.876	
Health Physics Personnel	14	0	33		16.711		0.0		8.231		24.942	
Supervisory Personnel	2	1	2		1.349		0.974		0.972		3.095	
Engineering Personnel	17	2	18		5.166		0.438		7.090		12.694	
<b>GRAND TOTAL</b>	<b>275</b>	<b>138</b>	<b>167</b>	<b>580</b>	<b>94.946</b>		<b>54.521</b>		<b>62.581</b>		<b>212.048</b>	

\*\* Defined as 'non-routine' maintenance. All corrective maintenance is placed in this category.

**APPENDIX C**  
**PLANT: QUAD CITIES 1,2 (BWR)**      **NUMBER OF PERSONNEL AND MAN-REMS BY WORK AND JOB FUNCTION**  
**1982**

WORK & JOB FUNCTION	STATION EMPLOYEES			TOTAL			STATION EMPLOYEES			TOTAL		
	OPERATING PERSONNEL	UTILITY EMPLOYEES	CONTRACT & OTHERS	PERSONS	EMPLOYEES	EMPLOYEES	UTILITY EMPLOYEES	CONTRACT & OTHERS	EMPLOYEES	MAN-REMS	MAN-REMS	
<b>REACTOR OPERATIONS &amp; SURV.</b>												
MAINTENANCE PERSONNEL	15	0	0	0			38.586	0.0				
OPERATING PERSONNEL	88	0	0	0			109.863	0.0				
HEALTH PHYSICS PERSONNEL	8	0	0	0			7.669	0.0				
SUPERVISORY PERSONNEL	1	0	0	0			0.985	0.0				
ENGINEERING PERSONNEL	9	0	0	0			12.327	0.0				
<b>TOTAL</b>	<b>121</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>121</b>	<b>169.430</b>	<b>0.0</b>	<b>0.0</b>	<b>169.430</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>
<b>ROUTINE MAINTENANCE</b>												
MAINTENANCE PERSONNEL	93	19	109				246.496	27.008				
OPERATING PERSONNEL	4	0	0				5.782	0.0				
HEALTH PHYSICS PERSONNEL	18	0	0				17.431	0.0				
SUPERVISORY PERSONNEL	0	0	0				0.0	0.0				
ENGINEERING PERSONNEL	11	65	62				15.684	10.070				
<b>TOTAL</b>	<b>126</b>	<b>84</b>	<b>171</b>	<b>381</b>	<b>285.393</b>	<b>37.078</b>	<b>261.896</b>	<b>38.397</b>	<b>584.367</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>
<b>IN-SERVICE INSPECTION</b>												
MAINTENANCE PERSONNEL	1	0	85				3.859	0.0				
OPERATING PERSONNEL	0	0	0				0.0	0.0				
HEALTH PHYSICS PERSONNEL	12	0	0				11.853	0.0				
SUPERVISORY PERSONNEL	0	0	0				0.0	0.0				
ENGINEERING PERSONNEL	2	0	61				2.924	0.0				
<b>TOTAL</b>	<b>15</b>	<b>0</b>	<b>126</b>	<b>141</b>	<b>18.636</b>	<b>0.0</b>	<b>0.0</b>	<b>25.460</b>	<b>178.832</b>	<b>197.468</b>	<b>0.0</b>	<b>0.0</b>
<b>SPECIAL MAINTENANCE</b>												
MAINTENANCE PERSONNEL	16	221	1029				41.553	310.596				
OPERATING PERSONNEL	0	0	0				0.0	0.0				
HEALTH PHYSICS PERSONNEL	22	0	0				20.917	0.0				
SUPERVISORY PERSONNEL	20	0	0				16.945	0.0				
ENGINEERING PERSONNEL	27	0	237				36.633	0.0				
<b>TOTAL</b>	<b>85</b>	<b>221</b>	<b>1266</b>	<b>1572</b>	<b>116.048</b>	<b>310.596</b>	<b>0.0</b>	<b>144.667</b>	<b>2099.946</b>	<b>2526.590</b>	<b>0.0</b>	<b>0.0</b>
<b>WASTE PROCESSING</b>												
MAINTENANCE PERSONNEL	15	0	1				38.586	0.0				
OPERATING PERSONNEL	43	0	0				53.528	0.0				
HEALTH PHYSICS PERSONNEL	11	0	0				10.458	0.0				
SUPERVISORY PERSONNEL	1	0	0				1.150	0.0				
ENGINEERING PERSONNEL	0	0	0				0.0	0.0				
<b>TOTAL</b>	<b>70</b>	<b>0</b>	<b>1</b>	<b>71</b>	<b>103.722</b>	<b>0.0</b>	<b>0.0</b>	<b>104.826</b>	<b>178.832</b>	<b>197.468</b>	<b>0.0</b>	<b>0.0</b>
<b>REFUELING</b>												
MAINTENANCE PERSONNEL	6	0	1				16.779	0.0				
OPERATING PERSONNEL	0	0	0				0.0	0.0				
HEALTH PHYSICS PERSONNEL	2	0	0				1.394	0.0				
SUPERVISORY PERSONNEL	0	0	0				0.0	0.0				
ENGINEERING PERSONNEL	0	0	4				0.0	0.0				
<b>TOTAL</b>	<b>8</b>	<b>0</b>	<b>5</b>	<b>13</b>	<b>18.173</b>	<b>0.0</b>	<b>0.0</b>	<b>1.348</b>	<b>4.566</b>	<b>22.739</b>	<b>0.0</b>	<b>0.0</b>
<b>TOTAL BY JOB FUNCTION</b>												
MAINTENANCE PERSONNEL	146	240	1225				385.859	337.604				
OPERATING PERSONNEL	135	0	0				169.173	0.0				
HEALTH PHYSICS PERSONNEL	73	0	0				69.722	0.0				
SUPERVISORY PERSONNEL	22	0	0				22	0.0				
ENGINEERING PERSONNEL	49	65	344				67.568	10.070				
<b>GRAND TOTAL</b>	<b>425</b>	<b>305</b>	<b>1569</b>	<b>2299</b>	<b>711.402</b>	<b>347.674</b>	<b>0.0</b>	<b>209.872</b>	<b>287.510</b>	<b>3605.420</b>	<b>0.0</b>	<b>0.0</b>

**APPENDIX C**

PLANT: RANCHO SECO *	(PWR)	NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION 1982									
		STATION		NUMBER OF PERSONNEL (>100 M-REM)		TOTAL		STATION		TOTAL	
		EMPLOYEES	UTILITY	EMPLOYEES	CONTRACT	PERSONS	& OTHERS	EMPLOYEES	UTILITY	EMPLOYEES	MAN-REMS
WORK & JOB FUNCTION											
REACTOR OPERATIONS & SURV.											
MAINTENANCE PERSONNEL	77	0	4	1		4	160	0	0	0	0.760
OPERATING PERSONNEL	47	1	0	0		22	280	0	0.080	0	0.0
HEALTH PHYSICS PERSONNEL	24	3	31			6.450		0.070		4.700	
SUPERVISORY PERSONNEL	31	0	18			1.550		0.0		1.620	
ENGINEERING PERSONNEL	39	11	49			2.970		0.270		2.600	
TOTAL	218	15	139	372		37.410		0.420		9.680	47.510
ROUTINE MAINTENANCE											
MAINTENANCE PERSONNEL	82	0	16			19.620		0		61.310	
OPERATING PERSONNEL	11	0	0			0.480		0		0	
HEALTH PHYSICS PERSONNEL	23	1	28			3.280		0.010		12.880	
SUPERVISORY PERSONNEL	9	0	10			0.540		0		6.150	
ENGINEERING PERSONNEL	26	3	44			3.590		0.040		11.920	
TOTAL	151	4	246	401		27.510		0.050		92.260	119.820
IN-SERVICE INSPECTION											
MAINTENANCE PERSONNEL	0	0	0			0		0		0	0.0
OPERATING PERSONNEL	0	0	0			0		0		0	0.0
HEALTH PHYSICS PERSONNEL	0	0	0			0		0		0	0.0
SUPERVISORY PERSONNEL	0	0	0			0		0		0	0.0
ENGINEERING PERSONNEL	0	0	0			0		0		0	0.0
TOTAL	0	0	0	0		0		0		0	0.0
SPECIAL MAINTENANCE											
MAINTENANCE PERSONNEL	79	0	26	9		18.950		0		72.040	
OPERATING PERSONNEL	12	0	0			0.260		0		0	
HEALTH PHYSICS PERSONNEL	19	1	24			3.320		0.140		5.580	
SUPERVISORY PERSONNEL	11	0	22			1.860		0		2.290	
ENGINEERING PERSONNEL	19	14	79			9.430		0.910		8.060	
TOTAL	140	15	394	549		33.820		1.050		87.970	122.840
WASTE PROCESSING											
MAINTENANCE PERSONNEL	48	0	57			10.480		0		18.930	
OPERATING PERSONNEL	13	0	0			0.590		0		0	
HEALTH PHYSICS PERSONNEL	25	0	15			4.180		0		2.630	
SUPERVISORY PERSONNEL	4	0	1			0.180		0		0.020	
ENGINEERING PERSONNEL	2	0	1			0.020		0		0.020	
TOTAL	92	0	74	166		15.450		0		21.600	37.050
REFUELING											
MAINTENANCE PERSONNEL	6	0	3			0.080		0		0	
OPERATING PERSONNEL	19	0	0			0.350		0		0	
HEALTH PHYSICS PERSONNEL	3	0	0			0.010		0		0	
SUPERVISORY PERSONNEL	1	1	0			0.020		0		0	
ENGINEERING PERSONNEL	4	0	0			0.080		0		0	
TOTAL	33	1	3	37		0.540		0		0	0.540
TOTAL BY JOB FUNCTION											
MAINTENANCE PERSONNEL	292	0	534			53.290		0		153.040	206.330
OPERATING PERSONNEL	102	1	0			23.960		0.080		0	24.040
HEALTH PHYSICS PERSONNEL	94	5	98			17.240		0.220		25.790	43.250
SUPERVISORY PERSONNEL	56	1	51			4.150		0		10.080	14.230
ENGINEERING PERSONNEL	90	28	173			16.090		1.220		22.600	39.910
GRAND TOTAL	634	35	856	1525		114.730		1.520		211.510	327.760

\* Workers may be counted in more than one category.

**APPENDIX C**

**PLANT: ROBINSON 2**      **(PWR)**      **NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION**

WORK & JOB FUNCTION	STATION EMPLOYEES			TOTAL			STATION EMPLOYEES			TOTAL		
	NUMBER OF PERSONNEL	STATION UTILITy EMPLOYEES	CONTRACT & OTHERS	PERSONS	EMPLOYEES	EMPLOYEES	EMPLOYEES	EMPLOYEES	EMPLOYEES	CONTRACT & OTHERS	MAN-REMS	
<b>REACTOR OPERATIONS &amp; SURV.</b>												
MAINTENANCE PERSONNEL	7	4	12	15	12.258	4.454	12.258	4.454	12.258	4.454	18.797	
OPERATING PERSONNEL	18	12	39	55	23.933	16.365	23.933	16.365	23.933	16.365	6.544	
HEALTH PHYSICS PERSONNEL	13	0	0	7	10.738	2.627	10.738	2.627	10.738	2.627	6.624	
SUPERVISORY PERSONNEL	1	1	0	0	0.124	1.521	0.124	1.521	0.124	1.521	0.0	
ENGINEERING PERSONNEL	8	2	5	1	9.507	1.641	9.507	1.641	9.507	1.641	4.513	
<b>TOTAL</b>	<b>48</b>	<b>22</b>	<b>61</b>	<b>133</b>	<b>56.560</b>	<b>26.608</b>	<b>56.560</b>	<b>26.608</b>	<b>56.560</b>	<b>26.608</b>	<b>36.478</b>	
<b>ROUTINE MAINTENANCE</b>												
MAINTENANCE PERSONNEL	21	3	15	45	44.706	6.091	44.706	6.091	44.706	6.091	14.545	
OPERATING PERSONNEL	0	0	0	0	1.067	0.0	1.067	0.0	1.067	0.0	0.0	
HEALTH PHYSICS PERSONNEL	6	0	7	4	4.201	1.043	4.201	1.043	4.201	1.043	9.580	
SUPERVISORY PERSONNEL	0	0	0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
ENGINEERING PERSONNEL	0	0	1	1	0.890	0.074	0.890	0.074	0.890	0.074	1.497	
<b>TOTAL</b>	<b>29</b>	<b>4</b>	<b>24</b>	<b>58</b>	<b>50.864</b>	<b>7.208</b>	<b>50.864</b>	<b>7.208</b>	<b>50.864</b>	<b>7.208</b>	<b>25.622</b>	
<b>TOTAL</b>	<b>83</b>	<b>16</b>	<b>133</b>	<b>211</b>	<b>119.646</b>	<b>119.646</b>	<b>119.646</b>	<b>119.646</b>	<b>119.646</b>	<b>119.646</b>	<b>119.646</b>	
<b>IN-SERVICE INSPECTION</b>												
MAINTENANCE PERSONNEL	5	0	2	2	10.800	0.275	10.800	0.275	10.800	0.275	4.727	
OPERATING PERSONNEL	4	0	0	0	5.323	0.0	5.323	0.0	5.323	0.0	0.0	
HEALTH PHYSICS PERSONNEL	1	0	5	5	2.238	0.560	2.238	0.560	2.238	0.560	7.363	
SUPERVISORY PERSONNEL	0	0	0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
ENGINEERING PERSONNEL	6	2	50	50	7.253	1.692	7.253	1.692	7.253	1.692	45.177	
<b>TOTAL</b>	<b>17</b>	<b>3</b>	<b>58</b>	<b>79</b>	<b>25.614</b>	<b>5.527</b>	<b>25.614</b>	<b>5.527</b>	<b>25.614</b>	<b>5.527</b>	<b>57.267</b>	
<b>TOTAL</b>	<b>87</b>	<b>13</b>	<b>60</b>	<b>147</b>	<b>83.694</b>	<b>83.694</b>	<b>83.694</b>	<b>83.694</b>	<b>83.694</b>	<b>83.694</b>	<b>83.694</b>	
<b>SPECIAL MAINTENANCE</b>												
MAINTENANCE PERSONNEL	32	41	312	312	62.557	54.544	62.557	54.544	62.557	54.544	430.485	
OPERATING PERSONNEL	2	0	0	0	3.134	0.152	3.134	0.152	3.134	0.152	0.0	
HEALTH PHYSICS PERSONNEL	19	2	68	68	19.277	4.602	19.277	4.602	19.277	4.602	91.991	
SUPERVISORY PERSONNEL	0	0	0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
ENGINEERING PERSONNEL	32	15	99	99	37.510	9.692	37.510	9.692	37.510	9.692	85.371	
<b>TOTAL</b>	<b>87</b>	<b>60</b>	<b>481</b>	<b>628</b>	<b>122.478</b>	<b>69.109</b>	<b>122.478</b>	<b>69.109</b>	<b>122.478</b>	<b>69.109</b>	<b>607.847</b>	
<b>TOTAL</b>	<b>87</b>	<b>13</b>	<b>60</b>	<b>147</b>	<b>69.109</b>	<b>69.109</b>	<b>69.109</b>	<b>69.109</b>	<b>69.109</b>	<b>69.109</b>	<b>799.434</b>	
<b>WASTE PROCESSING</b>												
MAINTENANCE PERSONNEL	5	0	27	27	11.070	0.216	11.070	0.216	11.070	0.216	38.002	
OPERATING PERSONNEL	9	0	0	0	11.439	0.048	11.439	0.048	11.439	0.048	0.0	
HEALTH PHYSICS PERSONNEL	4	0	6	6	3.128	0.845	3.128	0.845	3.128	0.845	8.007	
SUPERVISORY PERSONNEL	0	0	0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
ENGINEERING PERSONNEL	0	0	0	0	0.350	0.003	0.350	0.003	0.350	0.003	0.0	
<b>TOTAL</b>	<b>19</b>	<b>0</b>	<b>33</b>	<b>53</b>	<b>25.987</b>	<b>1.112</b>	<b>25.987</b>	<b>1.112</b>	<b>25.987</b>	<b>1.112</b>	<b>46.009</b>	
<b>TOTAL</b>	<b>19</b>	<b>0</b>	<b>33</b>	<b>53</b>	<b>25.987</b>	<b>1.112</b>	<b>25.987</b>	<b>1.112</b>	<b>25.987</b>	<b>1.112</b>	<b>73.108</b>	
<b>REFUELING</b>												
MAINTENANCE PERSONNEL	13	11	54	54	25.901	14.615	25.901	14.615	25.901	14.615	79.149	
OPERATING PERSONNEL	6	0	0	0	8.078	0.0	8.078	0.0	8.078	0.0	0.0	
HEALTH PHYSICS PERSONNEL	2	0	10	10	2.569	0.562	2.569	0.562	2.569	0.562	13.055	
SUPERVISORY PERSONNEL	0	0	0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
ENGINEERING PERSONNEL	5	1	16	16	6.595	1.214	6.595	1.214	6.595	1.214	15.050	
<b>TOTAL</b>	<b>28</b>	<b>13</b>	<b>31</b>	<b>122</b>	<b>43.143</b>	<b>16.391</b>	<b>43.143</b>	<b>16.391</b>	<b>43.143</b>	<b>16.391</b>	<b>107.254</b>	
<b>TOTAL</b>	<b>28</b>	<b>13</b>	<b>31</b>	<b>122</b>	<b>43.143</b>	<b>16.391</b>	<b>43.143</b>	<b>16.391</b>	<b>43.143</b>	<b>16.391</b>	<b>107.254</b>	
<b>TOTAL BY JOB FUNCTION</b>												
MAINTENANCE PERSONNEL	86	61	425	573	167.292	80.195	167.292	80.195	167.292	80.195	585.705	
OPERATING PERSONNEL	40	12	39	92	52.974	16.565	52.974	16.565	52.974	16.565	6.544	
HEALTH PHYSICS PERSONNEL	47	6	103	157	42.151	10.239	42.151	10.239	42.151	10.239	136.620	
SUPERVISORY PERSONNEL	1	1	0	2	0.124	1.640	0.124	1.640	0.124	1.640	0.0	
ENGINEERING PERSONNEL	53	22	173	250	62.105	16.316	62.105	16.316	62.105	16.316	151.608	
<b>GRAND TOTAL</b>	<b>229</b>	<b>104</b>	<b>742</b>	<b>1076</b>	<b>324.646</b>	<b>122.955</b>	<b>324.646</b>	<b>122.955</b>	<b>324.646</b>	<b>122.955</b>	<b>880.477</b>	
<b>GRAND TOTAL</b>	<b>229</b>	<b>104</b>	<b>742</b>	<b>1076</b>	<b>324.646</b>	<b>122.955</b>	<b>324.646</b>	<b>122.955</b>	<b>324.646</b>	<b>122.955</b>	<b>880.477</b>	

**APPENDIX C**

PLANT: <sup>a</sup>SALEM 1,2 (PWR) NUMBER OF PERSONNEL AND MAN-REM 1982

WORK & JOB FUNCTION	STATION EMPLOYEES	NUMBER OF PERSONNEL (>100 M-REM)		TOTAL	STATION EMPLOYEES	NUMBER OF PERSONNEL (>100 M-REM)		TOTAL	MAN-REM
		UTILITY EMPLOYEES	CONTRACT & OTHERS			UTILITY EMPLOYEES	CONTRACT & OTHERS		
<b>REACTOR OPERATIONS &amp; SURV.</b>									
MAINTENANCE PERSONNEL	4	0	5		3.117	0.085	2.210		
OPERATING PERSONNEL	10	0	0		9.610	0.0	0.340		
HEALTH PHYSICS PERSONNEL	39	0	91		9.841	0.077	29.913		
SUPERVISORY PERSONNEL	1	0	2		0.200	0.0	0.495		
ENGINEERING PERSONNEL	3	0	1		0.999	0.465	0.535		
<b>TOTAL</b>	<b>57</b>	<b>0</b>	<b>99</b>	<b>156</b>	<b>23.767</b>	<b>0.627</b>	<b>33.493</b>	<b>57.887</b>	
<b>ROUTINE MAINTENANCE</b>									
MAINTENANCE PERSONNEL	51	1	98		21.088	0.260	31.988		
OPERATING PERSONNEL	26	0	0		7.547	0.0	0.0		
HEALTH PHYSICS PERSONNEL	1	0	8		3.493	0.0	2.808		
SUPERVISORY PERSONNEL	1	0	3		0.495	0.060	1.030		
ENGINEERING PERSONNEL	0	0	0		0.115	0.080	0.055		
<b>TOTAL</b>	<b>79</b>	<b>1</b>	<b>109</b>	<b>189</b>	<b>32.738</b>	<b>0.400</b>	<b>35.881</b>	<b>69.019</b>	
<b>IN-SERVICE INSPECTION</b>									
MAINTENANCE PERSONNEL	1	0	284		2.137	0.035	119.383		
OPERATING PERSONNEL	1	0	0		0.538	0.0	0.0		
HEALTH PHYSICS PERSONNEL	4	0	45		0.782	0.0	17.215		
SUPERVISORY PERSONNEL	0	0	5		0.030	0.030	2.262		
ENGINEERING PERSONNEL	2	2	0		0.445	1.094	0.040		
<b>TOTAL</b>	<b>8</b>	<b>2</b>	<b>334</b>	<b>344</b>	<b>3.932</b>	<b>1.159</b>	<b>138.900</b>	<b>143.991</b>	
<b>SPECIAL MAINTENANCE</b>									
MAINTENANCE PERSONNEL	133	10	868		57.713	5.508	345.010		
OPERATING PERSONNEL	30	0	0		12.496	0.0	0.182		
HEALTH PHYSICS PERSONNEL	7	0	84		2.899	0.057	26.253		
SUPERVISORY PERSONNEL	0	0	42		0.070	0.080	15.837		
ENGINEERING PERSONNEL	11	6	4		3.916	0.0	1.505		
<b>TOTAL</b>	<b>181</b>	<b>14</b>	<b>998</b>	<b>1193</b>	<b>77.094</b>	<b>5.645</b>	<b>388.787</b>	<b>471.526</b>	
<b>WASTE PROCESSING</b>									
MAINTENANCE PERSONNEL	6	0	0		1.650	0.0	0.470		
OPERATING PERSONNEL	0	0	0		0.260	0.0	0.060		
HEALTH PHYSICS PERSONNEL	2	0	235		1.425	0.265	69.636		
SUPERVISORY PERSONNEL	0	0	0		0.0	0.0	0.0		
ENGINEERING PERSONNEL	1	0	0		0.130	0.160	0.0		
<b>TOTAL</b>	<b>9</b>	<b>0</b>	<b>235</b>	<b>244</b>	<b>3.465</b>	<b>0.425</b>	<b>70.166</b>	<b>74.056</b>	
<b>REFUELING</b>									
MAINTENANCE PERSONNEL	299	14	87		121.237	5.540	35.018		
OPERATING PERSONNEL	87	0	0		28.830	0.090	0.020		
HEALTH PHYSICS PERSONNEL	13	0	77		4.285	0.0	41.351		
SUPERVISORY PERSONNEL	0	1	1		0.085	1.010	0.855		
ENGINEERING PERSONNEL	4	3	2		2.150	1.446	0.305		
<b>TOTAL</b>	<b>403</b>	<b>18</b>	<b>167</b>	<b>588</b>	<b>156.587</b>	<b>8.086</b>	<b>77.549</b>	<b>242.222</b>	
<b>TOTAL BY JOB FUNCTION</b>									
MAINTENANCE PERSONNEL	694	25	1342		206.942	11.428	534.079		752.449
OPERATING PERSONNEL	154	0	0		59.281	0.090	0.602		59.973
HEALTH PHYSICS PERSONNEL	66	0	540		606	0.399	187.176		210.300
SUPERVISORY PERSONNEL	2	1	53		56	0.880	1.180	20.479	22.539
ENGINEERING PERSONNEL	21	9	7		37	7.755	3.245	2.440	13.440
<b>GRAND TOTAL</b>	<b>737</b>	<b>35</b>	<b>1942</b>	<b>2714</b>	<b>297.583</b>	<b>16.342</b>	<b>744.776</b>	<b>1058.701</b>	

**PLANT: SAN ONOFRE \* (PWR)** **NUMBER OF PERSONNEL AND MAN-REMS** **1982**

WORK & JOB FUNCTION	STATION EMPLOYEES	NUMBER OF PERSONNEL (>100 M-REM)	TOTAL	STATION EMPLOYEES	NUMBER OF PERSONNEL (>100 M-REM)	TOTAL
REACTOR OPERATIONS & SURV.	UTILITY EMPLOYEES	CONTRACT & OTHERS	PERSONS	EMPLOYEES	CONTRACT & OTHERS	PERSONS
Maintenance Personnel	1	0	42	0	0.004	0.0
Operating Personnel	17	0	0	11,245	0.0	2,035
Health Physics Personnel	29	0	96	16,593	0.0	0.0
Supervisory Personnel	1	0	14	0.087	0.0	43,018
Engineering Personnel	11	0	152	2,040	0.0	0.0
<b>TOTAL</b>	<b>59</b>	<b>0</b>	<b>211</b>	<b>29,969</b>	<b>0.0</b>	<b>1,227</b>

ROUTINE MAINTENANCE	MAINTENANCE PERSONNEL	OPERATING PERSONNEL	HEALTH PHYSICS PERSONNEL	SUPERVISORY PERSONNEL	ENGINEERING PERSONNEL	<b>TOTAL</b>
Maintenance Personnel	43	2	639	0	0	24,656
Operating Personnel	5	0	0	0	0	0,328
Health Physics Personnel	23	0	142	13	1	6,793
Supervisory Personnel	2	1	0	0	0	0.183
Engineering Personnel	49	9	173	0	2	28,406
<b>TOTAL</b>	<b>122</b>	<b>12</b>	<b>967</b>	<b>1101</b>	<b>2</b>	<b>60,366</b>

IN-SERVICE INSPECTION	MAINTENANCE PERSONNEL	OPERATING PERSONNEL	HEALTH PHYSICS PERSONNEL	SUPERVISORY PERSONNEL	ENGINEERING PERSONNEL	<b>TOTAL</b>
Maintenance Personnel	3	0	0	13	0	0.256
Operating Personnel	0	0	0	0	0	0.0
Health Physics Personnel	5	0	5	0	0	0.0
Supervisory Personnel	0	0	0	0	0	0.0
Engineering Personnel	4	2	7	0	0	1.074
<b>TOTAL</b>	<b>12</b>	<b>2</b>	<b>25</b>	<b>39</b>	<b>0</b>	<b>0.34</b>

\*\* SPECIAL MAINTENANCE

MAINTENANCE PERSONNEL	OPERATING PERSONNEL	HEALTH PHYSICS PERSONNEL	SUPERVISORY PERSONNEL	ENGINEERING PERSONNEL	<b>TOTAL</b>
Maintenance Personnel	2	0	18	0	0.030
Operating Personnel	0	0	0	0	0.0
Health Physics Personnel	0	0	3	0	0.0
Supervisory Personnel	0	0	0	0	0.024
Engineering Personnel	5	0	3	1	0.021
<b>TOTAL</b>	<b>7</b>	<b>0</b>	<b>24</b>	<b>31</b>	<b>1.051</b>

WASTE PROCESSING	MAINTENANCE PERSONNEL	OPERATING PERSONNEL	HEALTH PHYSICS PERSONNEL	SUPERVISORY PERSONNEL	ENGINEERING PERSONNEL	<b>TOTAL</b>
Maintenance Personnel	0	0	6	0	0	0.0
Operating Personnel	3	0	0	11	0	0.34
Health Physics Personnel	1	0	0	0	0	0.005
Supervisory Personnel	0	0	0	0	0	0.0
Engineering Personnel	1	0	3	0	0	0.048
<b>TOTAL</b>	<b>5</b>	<b>0</b>	<b>20</b>	<b>25</b>	<b>0</b>	<b>0.087</b>

REFUELING

MAINTENANCE PERSONNEL	OPERATING PERSONNEL	HEALTH PHYSICS PERSONNEL	SUPERVISORY PERSONNEL	ENGINEERING PERSONNEL	<b>TOTAL</b>
Maintenance Personnel	0	0	0	0	0.0
Operating Personnel	0	0	0	0	0.0
Health Physics Personnel	0	0	0	0	0.0
Supervisory Personnel	0	0	0	0	0.0
Engineering Personnel	0	0	0	0	0.0
<b>TOTAL</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0.0</b>

TOTAL BY JOB FUNCTION

MAINTENANCE PERSONNEL	OPERATING PERSONNEL	HEALTH PHYSICS PERSONNEL	SUPERVISORY PERSONNEL	ENGINEERING PERSONNEL	<b>TOTAL</b>
Maintenance Personnel	49 (43)	2	718 (642)	769 (687)	24,946
Operating Personnel	25 (18)	0	0	25 (18)	0.0
Health Physics Personnel	58 (34)	0	257 (161)	315 (195)	24,229
Supervisory Personnel	3 (2)	1	13 (13)	17 (16)	0.270
Engineering Personnel	70 (48)	11 (9)	200 (180)	281 (237)	31,713
<b>GRAND TOTAL</b>	<b>205 (145)</b>	<b>14 (12)</b>	<b>1188 (996)</b>	<b>1407 (1153)</b>	<b>2,982</b>

\* Workers may be counted in more than one category. Numbers in parentheses are total numbers of individuals.

\*\* Includes calibration of safety related instruments and controls, installation of insulation on residual heat removal pump, and modifications to charging pump.

**APPENDIX C**

**PLANT: <sup>†</sup>SEQUOYAH 1 (PWR)**

WORK & JOB FUNCTION	STATION EMPLOYEES	NUMBER OF PERSONNEL			NUMBER OF PERSONNEL (>100 M-REM)			TOTAL MAN-REMS		
		STATION UTILITIY EMPLOYEES	CONTRACT % OTHERS	TOTAL PERSONS	STATION EMPLOYEES	UTILITY EMPLOYEES	CONTRACT & OTHERS	TOTAL MAN-REMS		
<b>REACTOR OPERATIONS &amp; SURV.</b>										
MAINTENANCE PERSONNEL	29	26	0	27	0	10,800	7,900	0,0	0,0	
OPERATING PERSONNEL	23	1	27	0	5,100	0,500	7,400			
HEALTH PHYSICS PERSONNEL	3	1	0	0	1,800	0,100	0,0			
SUPERVISORY PERSONNEL	0	0	0	0	0,0	0,0	0,0			
ENGINEERING PERSONNEL	0	0	0	0	0,0	0,0	0,0			
<b>TOTAL</b>	<b>55</b>	<b>28</b>	<b>27</b>	<b>110</b>	<b>17,700</b>	<b>8,500</b>	<b>7,400</b>	<b>33,600</b>		
<b>ROUTINE MAINTENANCE</b>										
MAINTENANCE PERSONNEL	375	40	0	4	89,400	7,200	0,0	0,0		
OPERATING PERSONNEL	89	24	4	27	14,700	6,000	0,800	0,0		
HEALTH PHYSICS PERSONNEL	1	0	0	0	0,100	0,0	0,0	0,0		
SUPERVISORY PERSONNEL	0	0	0	0	0,0	0,0	0,0	0,0		
ENGINEERING PERSONNEL	0	0	0	0	0,0	0,0	0,0	0,0		
<b>TOTAL</b>	<b>465</b>	<b>64</b>	<b>4</b>	<b>533</b>	<b>104,200</b>	<b>13,200</b>	<b>0,800</b>	<b>118,200</b>		
<b>IN-SERVICE INSPECTION</b>										
MAINTENANCE PERSONNEL	54	76	0	0	15,100	21,600	0,0	0,0		
OPERATING PERSONNEL	13	8	37	0	2,100	2,600	19,100			
HEALTH PHYSICS PERSONNEL	0	1	0	0	0,0	0,0	0,0			
SUPERVISORY PERSONNEL	0	0	0	0	0,0	0,0	0,0			
ENGINEERING PERSONNEL	0	0	0	0	0,0	0,0	0,0			
<b>TOTAL</b>	<b>67</b>	<b>85</b>	<b>37</b>	<b>189</b>	<b>17,200</b>	<b>24,400</b>	<b>19,100</b>	<b>60,700</b>		
<b>SPECIAL MAINTENANCE</b>										
MAINTENANCE PERSONNEL	19	1	0	0	3,400	0,100	0,0	0,0		
OPERATING PERSONNEL	0	0	0	0	0,0	0,0	0,0			
HEALTH PHYSICS PERSONNEL	0	0	0	0	0,0	0,0	0,0			
SUPERVISORY PERSONNEL	0	0	0	0	0,0	0,0	0,0			
ENGINEERING PERSONNEL	0	0	0	0	0,0	0,0	0,0			
<b>TOTAL</b>	<b>19</b>	<b>1</b>	<b>0</b>	<b>20</b>	<b>3,400</b>	<b>0,100</b>	<b>0,0</b>	<b>3,500</b>		
<b>WASTE PROCESSING</b>										
MAINTENANCE PERSONNEL	6	0	0	0	1,300	0,0	0,0	0,0		
OPERATING PERSONNEL	22	0	0	0	3,500	0,0	0,0	0,0		
HEALTH PHYSICS PERSONNEL	2	2	0	0	0,400	0,0	0,0	0,0		
SUPERVISORY PERSONNEL	0	0	0	0	0,0	0,0	0,0	0,0		
ENGINEERING PERSONNEL	0	0	0	0	0,0	0,0	0,0	0,0		
<b>TOTAL</b>	<b>30</b>	<b>0</b>	<b>0</b>	<b>30</b>	<b>5,200</b>	<b>0,0</b>	<b>0,0</b>	<b>5,200</b>		
<b>REFUELING</b>										
MAINTENANCE PERSONNEL	107	22	0	0	43,900	4,600	0,0	0,0		
OPERATING PERSONNEL	44	9	6	6	10,200	2,000	1,000	1,000		
HEALTH PHYSICS PERSONNEL	2	2	0	0	0,500	0,700	0,0	0,0		
SUPERVISORY PERSONNEL	0	0	0	0	0,0	0,0	0,0	0,0		
ENGINEERING PERSONNEL	0	0	0	0	0,0	0,0	0,0	0,0		
<b>TOTAL</b>	<b>153</b>	<b>33</b>	<b>6</b>	<b>192</b>	<b>54,600</b>	<b>7,300</b>	<b>1,000</b>	<b>62,900</b>		
<b>TOTAL BY JOB FUNCTION</b>										
MAINTENANCE PERSONNEL	590	165	0	755	163,900	41,400	0,0	0,0	205,300	
OPERATING PERSONNEL	191	42	74	307	35,600	11,100	28,300	75,000		
HEALTH PHYSICS PERSONNEL	8	4	0	12	2,800	1,000	0,0	3,800		
SUPERVISORY PERSONNEL	0	0	0	0	0,0	0,0	0,0	0,0		
ENGINEERING PERSONNEL	0	0	0	0	0,0	0,0	0,0	0,0		
<b>GRAND TOTAL</b>	<b>789</b>	<b>211</b>	<b>74</b>	<b>1074</b>	<b>202,300</b>	<b>53,500</b>	<b>28,300</b>	<b>284,100</b>		

**APPENDIX C**  
**PLANT: ST. LUCIE (PWR)**  
**NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION**  
**1982**

WORK & JOB FUNCTION	(PWR)	NUMBER OF PERSONNEL (>100 M-REM)				TOTAL	MAN-REMS	
		STATION EMPLOYEES	UTILITY EMPLOYEES	CONTRACT & OTHERS	PERSONS			
<b>REACTOR OPERATIONS &amp; SURV.</b>								
MAINTENANCE PERSONNEL	0	0	0	0	0	0.0	0.0	0.0
OPERATING PERSONNEL	36	0	0	0	0	8.590	0.0	0.0
HEALTH PHYSICS PERSONNEL	28	0	0	0	0	5.160	0.0	0.0
SUPERVISORY PERSONNEL	0	0	0	0	0	0.0	0.0	0.0
ENGINEERING PERSONNEL	0	0	0	0	0	0.0	0.0	0.0
<b>TOTAL</b>	<b>64</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>64</b>	<b>13.750</b>	<b>0.0</b>	<b>13.750</b>
<b>ROUTINE MAINTENANCE</b>								
MAINTENANCE PERSONNEL	118	0	0	0	0	28.980	0.0	0.0
OPERATING PERSONNEL	24	0	0	0	0	6.910	0.0	0.0
HEALTH PHYSICS PERSONNEL	25	0	0	0	0	5.650	0.0	0.0
SUPERVISORY PERSONNEL	2	0	0	0	0	0.740	0.0	0.0
ENGINEERING PERSONNEL	0	0	0	0	0	0.0	0.0	0.0
<b>TOTAL</b>	<b>169</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>169</b>	<b>42.280</b>	<b>0.0</b>	<b>42.280</b>
<b>IN-SERVICE INSPECTION</b>								
MAINTENANCE PERSONNEL	24	2	67	0	67	4.610	0.420	41.540
OPERATING PERSONNEL	13	0	0	0	0	1.020	0.0	0.0
HEALTH PHYSICS PERSONNEL	8	0	8	0	8	1.200	0.0	1.410
SUPERVISORY PERSONNEL	7	0	4	0	4	1.920	0.0	2.340
ENGINEERING PERSONNEL	2	0	5	0	5	0.240	0.0	1.100
<b>TOTAL</b>	<b>54</b>	<b>2</b>	<b>84</b>	<b>0</b>	<b>140</b>	<b>11.990</b>	<b>0.420</b>	<b>46.390</b>
<b>SPECIAL MAINTENANCE</b>								
MAINTENANCE PERSONNEL	127	11	166	0	166	33.040	8.060	28.740
OPERATING PERSONNEL	8	0	0	0	0	3.630	0.0	0.0
HEALTH PHYSICS PERSONNEL	13	0	14	0	14	2.100	0.0	2.300
SUPERVISORY PERSONNEL	1	1	4	0	4	1.160	0.100	3.020
ENGINEERING PERSONNEL	2	1	13	0	13	0.370	0.170	2.630
<b>TOTAL</b>	<b>152</b>	<b>13</b>	<b>197</b>	<b>0</b>	<b>362</b>	<b>40.300</b>	<b>8.330</b>	<b>36.690</b>
<b>WASTE PROCESSING</b>								
MAINTENANCE PERSONNEL	56	0	0	0	0	10.400	0.0	0.0
OPERATING PERSONNEL	12	0	0	0	0	2.590	0.0	0.0
HEALTH PHYSICS PERSONNEL	19	0	0	0	0	1.700	0.0	0.0
SUPERVISORY PERSONNEL	2	0	0	0	0	0.0	0.0	0.0
ENGINEERING PERSONNEL	0	0	0	0	0	0.0	0.0	0.0
<b>TOTAL</b>	<b>89</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>89</b>	<b>14.690</b>	<b>0.0</b>	<b>14.690</b>
<b>REFUELING</b>								
MAINTENANCE PERSONNEL	0	0	0	0	0	0.0	0.0	0.0
OPERATING PERSONNEL	0	0	0	0	0	0.0	0.0	0.0
HEALTH PHYSICS PERSONNEL	0	0	0	0	0	0.0	0.0	0.0
SUPERVISORY PERSONNEL	0	0	0	0	0	0.0	0.0	0.0
ENGINEERING PERSONNEL	0	0	0	0	0	0.0	0.0	0.0
<b>TOTAL</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>
<b>TOTAL BY JOB FUNCTION</b>								
MAINTENANCE PERSONNEL	325	13	233	0	571	77.030	8.480	70.280
OPERATING PERSONNEL	93	0	0	0	93	25.740	0.0	25.740
HEALTH PHYSICS PERSONNEL	93	0	22	115	15.810	0.0	3.710	19.520
SUPERVISORY PERSONNEL	13	1	8	22	3.820	0.100	5.360	9.280
ENGINEERING PERSONNEL	4	1	18	23	0.610	0.170	3.730	4.510
<b>GRAND TOTAL</b>	<b>528</b>	<b>15</b>	<b>281</b>	<b>824</b>	<b>123.010</b>	<b>8.750</b>	<b>83.080</b>	<b>216.840</b>

**APPENDIX C**

**PLANT: †SURRY 1,2\***      (PWR)      NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION

WORK & JOB FUNCTION	STATION EMPLOYEES			TOTAL			STATION EMPLOYEES			TOTAL		
	NUMBER OF PERSONNEL	NUMBER OF PERSONNEL (>100 M-REM)	CONTRACT	PERSONS	EMPLOYEES & OTHERS	PERSONS	EMPLOYEES	UTILITY CONTRACT	EMPLOYEES & OTHERS	EMPLOYEES	UTILITY CONTRACT	MAN-REMS
<b>REACTOR OPERATIONS &amp; SURV.</b>												
MAINTENANCE PERSONNEL	179	15	79				76.472	0.564	3.493			
OPERATING PERSONNEL	118	9	1	22			177.043	0.079	0.022			
HEALTH PHYSICS PERSONNEL	50	1					35.455	0.216	17.321			
SUPERVISORY PERSONNEL	69	1	7				42.586	0.701	0.074			
ENGINEERING PERSONNEL	40	17	57				3.135	1.212	3.824			
<b>TOTAL</b>	<b>456</b>	<b>43</b>	<b>166</b>	<b>665</b>	<b>334.691</b>	<b>2</b>	<b>772</b>	<b>24.734</b>	<b>362.197</b>			
<b>ROUTINE MAINTENANCE</b>												
MAINTENANCE PERSONNEL	181	26	79				341.647	8.584	71.469			
OPERATING PERSONNEL	105	7	1	22			48.022	0.025	1.038			
HEALTH PHYSICS PERSONNEL	47	1					9.912	0.019	7.995			
SUPERVISORY PERSONNEL	69	5	7				34.607	2.639	0.914			
ENGINEERING PERSONNEL	33	24	57				10.436	0.906	6.271			
<b>TOTAL</b>	<b>435</b>	<b>63</b>	<b>166</b>	<b>664</b>	<b>444.624</b>	<b>12</b>	<b>173</b>	<b>87.687</b>	<b>544.684</b>			
<b>IN-SERVICE INSPECTION</b>												
MAINTENANCE PERSONNEL	4	0		269			0.043	0.0	1.772			
OPERATING PERSONNEL	6	4	17				0.407	0.146	3.239			
HEALTH PHYSICS PERSONNEL	0	0	23				0.0	0.0	0.0			
SUPERVISORY PERSONNEL	2	0	22				0.395	0.0	0.0			
ENGINEERING PERSONNEL	1	2	56				0.037	0.153	0.411			
<b>TOTAL</b>	<b>13</b>	<b>6</b>	<b>387</b>	<b>406</b>	<b>0.882</b>	<b>0</b>	<b>299</b>	<b>5.422</b>	<b>6.603</b>			
<b>SPECIAL MAINTENANCE</b>												
MAINTENANCE PERSONNEL	91	2	7				11.986	0.165	298.370			
OPERATING PERSONNEL	6	1	3				0.213	0.106	0.383			
HEALTH PHYSICS PERSONNEL	6	1	0				0.091	0.699	2.842			
SUPERVISORY PERSONNEL	10	3	0				1.303	0.029	0.805			
ENGINEERING PERSONNEL	9	32	6				1.790	4.396	9.977			
<b>TOTAL</b>	<b>122</b>	<b>39</b>	<b>16</b>	<b>177</b>	<b>15.383</b>	<b>5</b>	<b>395</b>	<b>312.377</b>	<b>333.155</b>			
<b>WASTE PROCESSING</b>												
MAINTENANCE PERSONNEL	43	6		286			3.363	1.168	8.101			
OPERATING PERSONNEL	53	0	13				35.652	0.0	1.240			
HEALTH PHYSICS PERSONNEL	27	1	16				28.579	0.001	19.230			
SUPERVISORY PERSONNEL	11	0	18				6.374	0.0	0.023			
ENGINEERING PERSONNEL	6	0	71				0.421	0.0	0.053			
<b>TOTAL</b>	<b>140</b>	<b>7</b>	<b>404</b>	<b>551</b>	<b>74.389</b>	<b>1</b>	<b>169</b>	<b>28.647</b>	<b>104.205</b>			
<b>REFUELING</b>												
MAINTENANCE PERSONNEL	2	0	61				0.006	0.0	0.0			
OPERATING PERSONNEL	10	3	6				0.115	0.019	0.0			
HEALTH PHYSICS PERSONNEL	1	0	27				0.002	0.0	0.007			
SUPERVISORY PERSONNEL	2	0	2				0.045	0.0	0.0			
ENGINEERING PERSONNEL	0	1	6				0.0	0.026	0.029			
<b>TOTAL</b>	<b>15</b>	<b>4</b>	<b>102</b>	<b>121</b>	<b>0.168</b>	<b>0</b>	<b>0.045</b>	<b>0.036</b>	<b>0.249</b>			
<b>TOTAL BY JOB FUNCTION</b>												
MAINTENANCE PERSONNEL	500	49	781				433.517	10.481	383.205			
OPERATING PERSONNEL	298	24	41				261.452	0.375	5.922			
HEALTH PHYSICS PERSONNEL	131	4	110				74.039	0.935	47.395			
SUPERVISORY PERSONNEL	163	9	56				228	3.310	3.369			
ENGINEERING PERSONNEL	89	76	253				418	15.819	6.693			
<b>GRAND TOTAL</b>	<b>1181</b>	<b>162</b>	<b>1241</b>	<b>2584</b>	<b>870.137</b>	<b>21.853</b>	<b>458.903</b>	<b>1350.893</b>				

\*Workers may be counted in more than one category.

APPENDIX C

PLANT: THREE MILE ISLAND \* (PWR) NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION

WORK & JOB FUNCTION	STATION EMPLOYEES	NUMBER OF PERSONNEL (>100 M-REM)		TOTAL	STATION EMPLOYEES	TOTAL MAN-REMS		TOTAL MAN-REMS
		UTILITY CONTRACT	OTHERS			EMPLOYEES	CONTRACT & OTHERS	
<b>REACTOR OPERATIONS &amp; SURV.</b>								
Maintenance Personnel	141	1	62		1,210	0.0	0.406	
Operating Personnel	174	7	28		9,938	0.011	0.170	
Health Physics Personnel	166	12	28		0,847	0.026	0.104	
Supervisory Personnel	98	2	10		1,420	0.005	0.049	
Engineering Personnel	79	8	11		1,539	0.027	0.016	
<b>TOTAL</b>	<b>552</b>	<b>45</b>	<b>167</b>	<b>764</b>	<b>40,042</b>	<b>0.187</b>	<b>1.331</b>	<b>41,560</b>
<b>ROUTINE MAINTENANCE</b>								
Maintenance Personnel	170	2	62		24,147	0.291	0.946	
Operating Personnel	166	12	28		0,847	0.021	0.119	
Health Physics Personnel	98	2	10		1,420	0.005	0.049	
Supervisory Personnel	75	8	8		3,081	0.071	0.053	
Engineering Personnel	59	12	5		0,648	0.030	1.382	
<b>TOTAL</b>	<b>568</b>	<b>36</b>	<b>153</b>	<b>757</b>	<b>30,143</b>	<b>0.923</b>	<b>2.534</b>	<b>33,600</b>
<b>IN-SERVICE INSPECTION</b>								
Maintenance Personnel	78	1	31		1,056	0.0	0.912	
Operating Personnel	77	7	22		0,581	0.015	0.419	
Health Physics Personnel	56	0	9		1,406	0.0	0.114	
Supervisory Personnel	51	3	5		0,415	0.028	0.030	
Engineering Personnel	42	26	47		0,443	0.158	7.385	
<b>TOTAL</b>	<b>304</b>	<b>37</b>	<b>114</b>	<b>455</b>	<b>3,901</b>	<b>0.399</b>	<b>8.860</b>	<b>13,160</b>
<b>SPECIAL MAINTENANCE</b>								
Maintenance Personnel	204	8	260		146,546	5.801	135.278	
Operating Personnel	165	13	50		56,312	0.132	10.015	
Health Physics Personnel	68	0	10		15,209	0.0	0.084	
Supervisory Personnel	79	10	35		20,059	1.058	19.306	
Engineering Personnel	56	32	106		9,306	2.449	57.535	
<b>TOTAL</b>	<b>572</b>	<b>63</b>	<b>461</b>	<b>1096</b>	<b>247,432</b>	<b>9,440</b>	<b>222.218</b>	<b>479,900</b>
<b>WASTE PROCESSING</b>								
Maintenance Personnel	94	4	23		15,459	0.009	0.059	
Operating Personnel	59	0	7		5,300	0.0	0.331	
Health Physics Personnel	17	0	5		0,236	0.0	0.180	
Supervisory Personnel	25	2	3		0,878	0.011	0.266	
Engineering Personnel	16	1	8		1,397	0.0	0.011	
<b>TOTAL</b>	<b>211</b>	<b>7</b>	<b>46</b>	<b>264</b>	<b>23,270</b>	<b>0.020</b>	<b>0.847</b>	<b>24,137</b>
<b>REFUELING</b>								
Maintenance Personnel	0	0	0		0.0	0.0	0.0	
Operating Personnel	5	0	0		0,020	0.0	0.0	
Health Physics Personnel	0	0	0		0.0	0.0	0.0	
Supervisory Personnel	2	0	0		0,002	0.0	0.0	
Engineering Personnel	1	0	0		0,003	0.0	0.0	
<b>TOTAL</b>	<b>8</b>	<b>0</b>	<b>0</b>	<b>8</b>	<b>0,025</b>	<b>0.0</b>	<b>0.0</b>	<b>0.025</b>
<b>TOTAL BY JOB FUNCTION</b>								
Maintenance Personnel	687(221)	16(12)	438(276)	1141(509)	188,418	6,101	137,601	332,120
Operating Personnel	646(226)	39(26)	135(70)	820(322)	72,998	0,190	11,039	84,227
Health Physics Personnel	336(122)	4(4)	49(30)	389(156)	44,286	0,029	0,743	45,058
Supervisory Personnel	311(110)	31(15)	62(38)	404(163)	25,974	1,895	19,671	47,540
Engineering Personnel	235(98)	98(60)	257(151)	590(309)	13,137	2,754	66,736	82,627
<b>GRAND TOTAL</b>	<b>2215(777)</b>	<b>188(117)</b>	<b>941(565)</b>	<b>3344(1459)</b>	<b>344,813</b>	<b>10,969</b>	<b>235,790</b>	<b>591,572</b>

\* Workers may be counted in more than one category. Numbers in parentheses are total numbers of individuals.

**PLANT: THREE MILE ISLAND 2\* (PWR)**

**APPENDIX C**

**NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION**

**1982**

WORK & JOB FUNCTION	STATION EMPLOYEES			TOTAL CONTRACT PERSONS			STATION EMPLOYEES			TOTAL MAN-REMS		
	UTILITY EMPLOYEES	M-REM & OTHERS	EMPLOYEES	CONTRACT	PERSONS	EMPLOYEES	UTILITY EMPLOYEES	EMPLOYEES	CONTRACT	EMPLOYEES	OTHERS	MAN-REMS
<b>REACTOR OPERATIONS &amp; SURV.</b>												
MAINTENANCE PERSONNEL	118	6	92	1	1.593	0.070	1.353	0.070	1.353	0.070	0.0	1.353
OPERATING PERSONNEL	69	7	13	1	1.674	0.342	1.199	0.342	1.199	0.342	0.0	1.199
HEALTH PHYSICS PERSONNEL	105	3	38	1	1.382	0.005	2.752	0.005	2.752	0.005	0.0	2.752
SUPERVISORY PERSONNEL	54	4	6	1	0.801	0.005	0.213	0.005	0.213	0.005	0.0	0.213
ENGINEERING PERSONNEL	22	4	59	1	0.081	0.003	0.913	0.003	0.913	0.003	0.0	0.913
<b>TOTAL</b>	<b>368</b>	<b>24</b>	<b>208</b>	<b>600</b>	<b>11.531</b>	<b>0.425</b>	<b>7.430</b>	<b>0.425</b>	<b>7.430</b>	<b>0.425</b>	<b>0.0</b>	<b>19.386</b>
<b>ROUTINE MAINTENANCE</b>												
MAINTENANCE PERSONNEL	121	6	94	1	2.721	0.040	1.514	0.040	1.514	0.040	0.0	1.514
OPERATING PERSONNEL	68	4	11	1	1.191	0.016	0.221	0.016	0.221	0.016	0.0	0.221
HEALTH PHYSICS PERSONNEL	83	3	28	1	3.807	0.0	1.723	0.0	1.723	0.0	0.0	1.723
SUPERVISORY PERSONNEL	54	1	7	1	0.765	0.033	0.015	0.033	0.015	0.025	0.0	0.015
ENGINEERING PERSONNEL	18	7	27	1	0.052	0.025	0.095	0.025	0.095	0.025	0.0	0.095
<b>TOTAL</b>	<b>344</b>	<b>21</b>	<b>167</b>	<b>532</b>	<b>8.536</b>	<b>0.114</b>	<b>3.568</b>	<b>0.114</b>	<b>3.568</b>	<b>0.114</b>	<b>0.0</b>	<b>12.218</b>
<b>IN-SERVICE INSPECTION</b>												
MAINTENANCE PERSONNEL	25	0	17	1	0.413	0.0	0.087	0.0	0.087	0.0	0.0	0.087
OPERATING PERSONNEL	26	1	0	1	0.181	0.0	0.0	0.0	0.0	0.0	0.0	0.0
HEALTH PHYSICS PERSONNEL	46	1	13	1	0.336	0.0	0.054	0.0	0.054	0.0	0.0	0.054
SUPERVISORY PERSONNEL	8	0	1	1	0.025	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ENGINEERING PERSONNEL	3	0	4	1	0.164	0.0	0.0	0.0	0.0	0.0	0.0	0.0
<b>TOTAL</b>	<b>108</b>	<b>2</b>	<b>35</b>	<b>145</b>	<b>1.119</b>	<b>0.0</b>	<b>0.289</b>	<b>0.0</b>	<b>0.289</b>	<b>0.0</b>	<b>0.0</b>	<b>1.408</b>
<b>SPECIAL MAINTENANCE</b>												
MAINTENANCE PERSONNEL	142	13	173	1	59.477	7.845	122.387	7.845	122.387	7.845	0.0	122.387
OPERATING PERSONNEL	80	11	25	1	17.700	4.247	4.247	4.247	4.247	4.247	0.0	4.247
HEALTH PHYSICS PERSONNEL	104	10	51	1	53.541	6.586	14.427	6.586	14.427	6.586	0.0	14.427
SUPERVISORY PERSONNEL	60	4	12	1	9.071	0.410	8.335	0.410	8.335	0.410	0.0	8.335
ENGINEERING PERSONNEL	53	9	71	1	5.828	2.863	27.714	2.863	27.714	2.863	0.0	27.714
<b>TOTAL</b>	<b>419</b>	<b>47</b>	<b>332</b>	<b>798</b>	<b>145.617</b>	<b>22.449</b>	<b>345.676</b>	<b>22.449</b>	<b>345.676</b>	<b>22.449</b>	<b>0.0</b>	<b>345.676</b>
<b>WASTE PROCESSING</b>												
MAINTENANCE PERSONNEL	132	11	81	1	5.132	1.751	1.052	1.751	1.052	1.751	0.0	1.052
OPERATING PERSONNEL	94	12	37	1	3.410	0.659	0.573	0.659	0.573	0.659	0.0	0.573
HEALTH PHYSICS PERSONNEL	100	5	55	1	4.591	0.871	1.371	0.871	1.371	0.871	0.0	1.371
SUPERVISORY PERSONNEL	69	4	12	1	1.720	0.021	0.013	0.021	0.013	0.021	0.0	0.013
ENGINEERING PERSONNEL	39	9	82	1	0.592	0.072	0.270	0.072	0.270	0.072	0.0	0.270
<b>TOTAL</b>	<b>434</b>	<b>41</b>	<b>267</b>	<b>742</b>	<b>15.445</b>	<b>3.374</b>	<b>3.279</b>	<b>3.374</b>	<b>3.279</b>	<b>3.374</b>	<b>0.0</b>	<b>22.098</b>
<b>REFUELING</b>												
MAINTENANCE PERSONNEL	0	0	0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
OPERATING PERSONNEL	0	0	0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
HEALTH PHYSICS PERSONNEL	0	0	0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SUPERVISORY PERSONNEL	0	0	0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ENGINEERING PERSONNEL	0	0	0	0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
<b>TOTAL</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>
<b>TOTAL BY JOB FUNCTION</b>												
MAINTENANCE PERSONNEL	538(163)	36(14)	457(189)	1	1031(366)	69.336	9.706	9.706	126.393	126.393	9.706	205.435
OPERATING PERSONNEL	337(115)	35(16)	86(49)	1	458(180)	24.156	5.762	5.762	6.240	6.240	5.762	36.158
HEALTH PHYSICS PERSONNEL	438(125)	22(10)	185(65)	1	645(200)	69.657	7.462	7.462	20.327	20.327	7.462	97.446
SUPERVISORY PERSONNEL	245(86)	13(7)	38(22)	1	296(115)	12.382	9.076	9.076	9.076	9.076	9.076	21.927
ENGINEERING PERSONNEL	115(53)	29(16)	243(135)	1	387(204)	6.717	2.963	2.963	30.140	30.140	2.963	39.820
<b>GRAND TOTAL</b>	<b>1673(542)</b>	<b>135(63)</b>	<b>1009(460)</b>	<b>1</b>	<b>2817(1065)</b>	<b>182.248</b>	<b>26.362</b>	<b>192.176</b>	<b>400.786</b>	<b>400.786</b>	<b>192.176</b>	<b>400.786</b>

\* Workers may be counted in more than one category. Numbers in parentheses are total numbers of individuals.

**APPENDIX C**

**PLANT: TROJAN**      **(PWR)**      **NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION**

WORK & JOB FUNCTION	NUMBER OF PERSONNEL (>100 M-REM)			TOTAL			TOTAL MAN-REMS	
	STATION EMPLOYEES	UTILITY CONTRACT	TOTAL	STATION EMPLOYEES	UTILITY EMPLOYEES	CONTRACT OTHERS	MAN-REMS	
<b>REACTOR OPERATIONS &amp; SURV.</b>								
Maintenance Personnel	4	2	3		1.420	0.670	1.020	
Operating Personnel	33	0	1		15.100	0.070	0.240	
Health Physics Personnel	36	1	36		14.420	0.200	13.560	
Supervisory Personnel	2	0	31		1.080	0.030	9.620	
Engineering Personnel	6	7	3		2.310	2.870	1.100	
<b>TOTAL</b>	<b>81</b>	<b>10</b>	<b>74</b>	<b>165</b>	<b>34.330</b>	<b>3.840</b>	<b>25.540</b>	<b>63.710</b>
<b>ROUTINE MAINTENANCE</b>								
Maintenance Personnel	49	23	23		18.850	8.010	7.810	
Operating Personnel	3	0	0		0.710	0.0	0.0	
Health Physics Personnel	3	0	2		1.200	0.0	0.580	
Supervisory Personnel	0	0	0		0.030	0.050	0.280	
Engineering Personnel	1	3	14		0.740	0.830	2.820	
<b>TOTAL</b>	<b>56</b>	<b>26</b>	<b>39</b>	<b>121</b>	<b>21.530</b>	<b>8.890</b>	<b>11.490</b>	<b>41.910</b>
<b>IN-SERVICE INSPECTION</b>								
Maintenance Personnel	0	0	0		0.0	0.0	0.0	
Operating Personnel	0	0	0		0.0	0.0	0.0	
Health Physics Personnel	0	0	0		0.0	0.0	0.0	
Supervisory Personnel	0	0	0		0.0	0.0	0.0	
Engineering Personnel	0	0	0		0.0	0.0	0.0	
<b>TOTAL</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>
<b>SPECIAL MAINTENANCE</b>								
Maintenance Personnel	41	48	79		20.780	40.520	60.480	
Operating Personnel	6	0	0		1.580	0.0	0.020	
Health Physics Personnel	21	0	5		7.350	0.010	1.630	
Supervisory Personnel	5	1	16		2.140	0.350	5.010	
Engineering Personnel	7	9	6		3.500	1.770	3.430	
<b>TOTAL</b>	<b>78</b>	<b>58</b>	<b>106</b>	<b>242</b>	<b>35.350</b>	<b>42.650</b>	<b>70.570</b>	<b>148.570</b>
<b>WASTE PROCESSING</b>								
Maintenance Personnel	1	1	20		0.430	0.630	10.670	
Operating Personnel	0	0	0		0.570	0.0	0.0	
Health Physics Personnel	46	0	3		23.940	0.0	1.030	
Supervisory Personnel	0	0	3		0.020	0.0	0.540	
Engineering Personnel	0	0	0		0.070	0.0	0.0	
<b>TOTAL</b>	<b>47</b>	<b>1</b>	<b>26</b>	<b>74</b>	<b>25.030</b>	<b>0.630</b>	<b>12.240</b>	<b>37.900</b>
<b>REFUELING</b>								
Maintenance Personnel	22	0	18		14.520	0.050	12.630	
Operating Personnel	15	0	0		12.460	0.020	0.130	
Health Physics Personnel	13	0	7		5.900	0.0	1.780	
Supervisory Personnel	3	0	10		1.750	0.0	3.820	
Engineering Personnel	6	0	8		2.800	0.900	3.380	
<b>TOTAL</b>	<b>59</b>	<b>0</b>	<b>43</b>	<b>102</b>	<b>37.430</b>	<b>0.970</b>	<b>21.790</b>	<b>60.190</b>
<b>TOTAL BY JOB FUNCTION</b>								
Maintenance Personnel	117	74	143		56.000	49.880	92.660	198.560
Operating Personnel	55	0	1		30.420	0.090	0.390	30.900
Health Physics Personnel	119	1	53		52.810	0.210	18.580	71.600
Supervisory Personnel	10	1	60		5.020	0.430	19.270	24.720
Engineering Personnel	20	19	31		9.420	6.370	10.730	26.520
<b>GRAND TOTAL</b>	<b>321</b>	<b>95</b>	<b>288</b>	<b>704</b>	<b>153.670</b>	<b>56.980</b>	<b>141.630</b>	<b>352.280</b>

**APPENDIX C**

PLANT: TURKEY POINT 1,2*		(PWR)		NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION 1982				TOTAL			
WORK & JOB FUNCTION	REACTOR OPERATIONS & SURV.	STATION EMPLOYEES		NUMBER OF PERSONNEL (>100 M-REM)		TOTAL		STATION EMPLOYEES		TOTAL MAN-REMS	
		UTILITY EMPLOYEES	CONTRACT & OTHERS	PERSONS	PERSONS	EMPLOYEES	EMPLOYEES	EMPLOYEES	EMPLOYEES	EMPLOYEES & OTHERS	MAN-REMS
Maintainance Personnel	154	14	210	58.492	5.109	72.446					
Operating Personnel	26	1	0	31.806	1.290	0.0					
Health Physics Personnel	31	0	85	14.160	0.0	31.146					
Supervisory Personnel	21	1	7	8.002	0.310	3.900					
Engineering Personnel	38	0	43	17.452	1.158	14.735					
<b>TOTAL</b>	<b>270</b>	<b>16</b>	<b>345</b>	<b>129.912</b>	<b>7.867</b>	<b>122.227</b>	<b>260.006</b>				
ROUTINE MAINTENANCE											
Maintainance Personnel	151	19	113	92.851	6.025	72.955					
Operating Personnel	19	1	0	9.008	0.105	0.0					
Health Physics Personnel	11	0	107	3.695	0.0	50.638					
Supervisory Personnel	13	0	0	4.812	0.0	0.175					
Engineering Personnel	25	1	7	10.519	0.150	3.446					
<b>TOTAL</b>	<b>219</b>	<b>21</b>	<b>227</b>	<b>120.885</b>	<b>6.280</b>	<b>127.214</b>	<b>254.379</b>				
IN-SERVICE INSPECTION											
Maintainance Personnel	120	33	230	91.473	24.946	192.990					
Operating Personnel	2	0	0	0.985	0.0	0.0					
Health Physics Personnel	4	0	28	2.800	0.0	11.550					
Supervisory Personnel	4	1	4	1.230	0.505	1.875					
Engineering Personnel	43	3	8	37.070	1.040	4.327					
<b>TOTAL</b>	<b>173</b>	<b>37</b>	<b>270</b>	<b>133.558</b>	<b>26.491</b>	<b>210.742</b>	<b>370.791</b>				
** SPECIAL MAINTENANCE											
Maintainance Personnel	112	19	1379	49.643	7.207	1464.956					
Operating Personnel	5	0	0	2.490	0.0	0.0					
Health Physics Personnel	19	0	187	9.977	0.015	130.579					
Supervisory Personnel	16	2	51	8.944	1.555	30.839					
Engineering Personnel	25	5	96	13.405	2.141	6.2006					
<b>TOTAL</b>	<b>177</b>	<b>26</b>	<b>1713</b>	<b>1916</b>	<b>84.459</b>	<b>10.918</b>	<b>1688.380</b>	<b>1783.757</b>			
WASTE PROCESSING											
Maintainance Personnel	16	0	1	8.215	0.135	1.215					
Operating Personnel	4	0	0	0.790	0.0	0.0					
Health Physics Personnel	4	0	22	7.920	0.0	17.298					
Supervisory Personnel	2	0	0	0.340	0.0	0.0					
Engineering Personnel	25	0	1	4.045	0.0	0.260					
<b>TOTAL</b>	<b>29</b>	<b>0</b>	<b>24</b>	<b>53</b>	<b>21.310</b>	<b>0.135</b>	<b>18.773</b>	<b>40.218</b>			
REFUELING											
Maintainance Personnel	89	17	16	42.140	11.295	3.985					
Operating Personnel	25	1	0	5.920	0.365	0.0					
Health Physics Personnel	0	0	18	0.375	0.0	4.634					
Supervisory Personnel	10	0	9	3.365	0.0	4.330					
Engineering Personnel	8	0	4	5.170	0.0	1.355					
<b>TOTAL</b>	<b>132</b>	<b>18</b>	<b>47</b>	<b>197</b>	<b>56.970</b>	<b>11.660</b>	<b>14.304</b>	<b>82.934</b>			
TOTAL BY JOB FUNCTION											
Maintainance Personnel	642	(194)	102(47)	194.9(1536)	26.93(177)	342.814	54.717	1808.547	2206.078		
Operating Personnel	81	(42)	3(2)	84(44)	50.999	1.760	0.0	52.759			
Health Physics Personnel	69	(36)	0	44(21)	516(247)	38.927	0.015	245.845	284.787		
Supervisory Personnel	66	(40)	4(3)	71(53)	141(96)	26.693	2.370	41.119	70.182		
Engineering Personnel	142	(84)	9	159(125)	310(24)	87.661	4.489	86.129	178.279		
<b>GRAND TOTAL</b>	<b>1000(336)</b>	<b>1118(57)</b>	<b>2626(1925)</b>	<b>3744(2378)</b>	<b>547.094</b>	<b>63.351</b>	<b>2181.640</b>	<b>2792.085</b>			

\* Workers may be counted in more than one category. Numbers in parentheses are total numbers of individuals.

\*\* Steam generator replacement.

**APPENDIX C**

**PLANT: VERMONT YANKEE\***      (BWR)      **NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION**

WORK & JOB FUNCTION	NUMBER OF PERSONNEL ( $>100$ M-REM)			TOTAL	STATION EMPLOYEES	UTILITY CONTRACT	& OTHERS	PERSONS	STATION EMPLOYEES	UTILITY CONTRACT	& OTHERS	TOTAL
	STATION EMPLOYEES	UTILITY CONTRACT	EMPLOYEES & OTHERS									
<b>REACTOR OPERATIONS &amp; SURV.</b>												
MAINTENANCE PERSONNEL	14	0	4									
OPERATING PERSONNEL	72	0	0									
HEALTH PHYSICS PERSONNEL	24	0	5									
SUPERVISORY PERSONNEL	2	0	0									
ENGINEERING PERSONNEL	29	0	10									
<b>TOTAL</b>	<b>141</b>	<b>0</b>	<b>19</b>	<b>160</b>	<b>55,900</b>	<b>0</b>	<b>199</b>	<b>3,725</b>	<b>59,824</b>			
<b>ROUTINE MAINTENANCE</b>												
MAINTENANCE PERSONNEL	50	52	198									
OPERATING PERSONNEL	0	0	0									
HEALTH PHYSICS PERSONNEL	6	0	1									
SUPERVISORY PERSONNEL	3	0	0									
ENGINEERING PERSONNEL	2	0	0									
<b>TOTAL</b>	<b>61</b>	<b>52</b>	<b>199</b>	<b>312</b>	<b>44,194</b>	<b>0</b>	<b>192</b>	<b>51,894</b>	<b>115,301</b>			
<b>IN-SERVICE INSPECTION</b>												
MAINTENANCE PERSONNEL	0	0	0									
OPERATING PERSONNEL	0	0	0									
HEALTH PHYSICS PERSONNEL	0	0	0									
SUPERVISORY PERSONNEL	0	0	0									
ENGINEERING PERSONNEL	0	0	0									
<b>TOTAL</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>
<b>SPECIAL MAINTENANCE</b>												
MAINTENANCE PERSONNEL	2	1	76									
OPERATING PERSONNEL	0	0	0									
HEALTH PHYSICS PERSONNEL	0	0	0									
SUPERVISORY PERSONNEL	2	1	0									
ENGINEERING PERSONNEL	2	0	0									
<b>TOTAL</b>	<b>6</b>	<b>2</b>	<b>76</b>	<b>84</b>	<b>1,812</b>	<b>0</b>	<b>1,103</b>	<b>24,273</b>	<b>27,188</b>			
<b>WASTE PROCESSING</b>												
MAINTENANCE PERSONNEL	0	0	0									
OPERATING PERSONNEL	12	0	0									
HEALTH PHYSICS PERSONNEL	0	0	0									
SUPERVISORY PERSONNEL	0	0	0									
ENGINEERING PERSONNEL	0	0	0									
<b>TOTAL</b>	<b>12</b>	<b>0</b>	<b>0</b>	<b>12</b>	<b>3,007</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>3,007</b>			
<b>REFUELING</b>												
MAINTENANCE PERSONNEL	0	0	0									
OPERATING PERSONNEL	0	0	0									
HEALTH PHYSICS PERSONNEL	0	0	0									
SUPERVISORY PERSONNEL	0	0	0									
ENGINEERING PERSONNEL	0	0	0									
<b>TOTAL</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>
<b>TOTAL BY JOB FUNCTION</b>												
MAINTENANCE PERSONNEL	66	53	278									
OPERATING PERSONNEL	84	0	0									
HEALTH PHYSICS PERSONNEL	30	0	6									
SUPERVISORY PERSONNEL	7	1	0									
ENGINEERING PERSONNEL	33	0	10									
<b>GRAND TOTAL</b>	<b>220</b>	<b>54</b>	<b>294</b>	<b>568</b>	<b>104,913</b>	<b>20,515</b>	<b>79,892</b>	<b>205,320</b>				

\* Workers may be counted in more than one category.

**APPENDIX C**

**PLANT: YANKEE-ROWE (PWR) NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION**

WORK & JOB FUNCTION	STATION EMPLOYEES	UTILITIY EMPLOYEES	& OTHERS	NUMBER OF PERSONNEL (1982)		TOTAL PERSONS	STATION EMPLOYEES	UTILITIY EMPLOYEES	& OTHERS	TOTAL MAN-REM	
				REACTOR OPERATIONS & SURV.	MAINTENANCE PERSONNEL	OPERATING PERSONNEL	HEALTH PHYSICS PERSONNEL	SUPERVISORY PERSONNEL	ENGINEERING PERSONNEL	CONTRACT	MAN-REM
REACTOR OPERATIONS & SURV.				0	0	0	0	0	0	0.160	0.135
MAINTENANCE PERSONNEL	0	0	0	0	0	0	0	0	0	3.852	0.0
OPERATING PERSONNEL	8	0	0	0	0	1	1	0	0	0.915	0.0
HEALTH PHYSICS PERSONNEL	2	0	0	0	0	0	0	0	0	0.305	0.0
SUPERVISORY PERSONNEL	1	0	0	0	0	0	0	0	0	0.170	0.0
ENGINEERING PERSONNEL	1	1	0	0	0	0	0	0	0	0.400	0.0
<b>TOTAL</b>	<b>12</b>	<b>1</b>	<b>1</b>	<b>14</b>	<b>0</b>	<b>1</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>5.402</b>	<b>0.535</b>
ROUTINE MAINTENANCE											
MAINTENANCE PERSONNEL	19	33	5	5	6	0	0	6.668	10.420	0.0	2.552
OPERATING PERSONNEL	6	0	0	0	0	1	1	1.937	0.0	0.0	0.0
HEALTH PHYSICS PERSONNEL	4	0	0	0	0	1	1	1.140	0.0	0.0	0.950
SUPERVISORY PERSONNEL	0	0	0	0	0	0	0	0.015	0.0	0.0	0.040
ENGINEERING PERSONNEL	0	0	0	0	0	0	0	0.130	0.0	0.230	0.0
<b>TOTAL</b>	<b>29</b>	<b>33</b>	<b>6</b>	<b>6</b>	<b>0</b>	<b>68</b>	<b>68</b>	<b>9.890</b>	<b>10.650</b>	<b>0</b>	<b>3.542</b>
IN-SERVICE INSPECTION											
MAINTENANCE PERSONNEL	0	10	5	5	0	0	0	0.065	11.535	0.0	6.870
OPERATING PERSONNEL	1	0	0	0	0	0	0	0.915	0.0	0.0	0.0
HEALTH PHYSICS PERSONNEL	0	0	0	0	0	0	0	0.0	0.0	0.0	0.105
SUPERVISORY PERSONNEL	0	0	0	0	0	2	2	0.005	0.0	0.010	3.387
ENGINEERING PERSONNEL	2	2	5	5	0	0	0	1.077	0.745	0.0	5.355
<b>TOTAL</b>	<b>3</b>	<b>12</b>	<b>12</b>	<b>27</b>	<b>0</b>	<b>12</b>	<b>27</b>	<b>2.062</b>	<b>12.290</b>	<b>0</b>	<b>15.717</b>
SPECIAL MAINTENANCE											
MAINTENANCE PERSONNEL	28	107	116	116	0	0	0	26.521	87.989	0.0	120.262
OPERATING PERSONNEL	3	0	0	0	0	0	0	1.720	0.0	0.0	0.0
HEALTH PHYSICS PERSONNEL	9	0	29	0	0	0	0	3.535	0.0	0.0	12.175
SUPERVISORY PERSONNEL	2	0	2	0	0	0	0	2.775	0.0	0.0	0.690
ENGINEERING PERSONNEL	8	11	8	8	0	0	0	12.500	3.000	0.0	3.670
<b>TOTAL</b>	<b>50</b>	<b>118</b>	<b>155</b>	<b>155</b>	<b>0</b>	<b>323</b>	<b>323</b>	<b>47.051</b>	<b>90.989</b>	<b>0</b>	<b>136.797</b>
WASTE PROCESSING											
MAINTENANCE PERSONNEL	3	12	0	0	0	0	0	0.830	2.773	0.0	0.020
OPERATING PERSONNEL	15	0	0	0	0	0	0	3.897	0.0	0.0	0.0
HEALTH PHYSICS PERSONNEL	8	0	25	0	0	0	0	3.325	0.0	0.0	22.050
SUPERVISORY PERSONNEL	0	0	0	0	0	0	0	0.0	0.0	0.0	0.0
ENGINEERING PERSONNEL	0	0	0	0	0	0	0	0.045	0.0	0.0	0.0
<b>TOTAL</b>	<b>26</b>	<b>12</b>	<b>25</b>	<b>63</b>	<b>0</b>	<b>12</b>	<b>63</b>	<b>8.097</b>	<b>2.773</b>	<b>0</b>	<b>22.070</b>
REFUELING											
MAINTENANCE PERSONNEL	28	56	7	7	0	0	0	17.070	21.556	0.0	5.385
OPERATING PERSONNEL	33	0	0	0	0	0	0	12.840	0.0	0.0	0.0
HEALTH PHYSICS PERSONNEL	9	0	30	0	1	1	0	5.796	0.0	0.0	24.481
SUPERVISORY PERSONNEL	0	1	0	1	0	0	0	0.225	0.175	0.0	0.185
ENGINEERING PERSONNEL	4	5	1	1	0	0	0	1.093	2.580	0.0	0.95
<b>TOTAL</b>	<b>74</b>	<b>62</b>	<b>39</b>	<b>175</b>	<b>0</b>	<b>39</b>	<b>175</b>	<b>37.024</b>	<b>24.311</b>	<b>0</b>	<b>30.246</b>
TOTAL BY JOB FUNCTION											
MAINTENANCE PERSONNEL	78	218	133	429	0	0	0	51.314	134.408	0.0	135.151
OPERATING PERSONNEL	66	0	0	66	0	0	0	25.161	0.0	0.0	25.161
HEALTH PHYSICS PERSONNEL	32	0	86	118	1	1	0	14.711	0.0	60.021	74.732
SUPERVISORY PERSONNEL	3	1	5	9	0	0	0	3.325	0.0	4.392	7.902
ENGINEERING PERSONNEL	15	19	14	48	0	0	0	15.015	6.955	0.0	9.220
<b>GRAND TOTAL</b>	<b>194</b>	<b>238</b>	<b>238</b>	<b>670</b>	<b>0</b>	<b>109</b>	<b>526</b>	<b>141.548</b>	<b>208.784</b>	<b>0</b>	<b>459.858</b>

**APPENDIX C**

**PLANT: ZION 1,2 (PWR)**

WORK & JOB FUNCTION	NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION			TOTAL	TOTAL MAN-REMS			
	STATION EMPLOYEES	NUMBER OF PERSONNEL (>100 M-REM)	UTILITY CONTRACT					
REACTOR OPERATIONS & SURV.	EMPLOYEES	& OTHERS	PERSONS	EMPLOYEES	EMPLOYEES	& OTHERS	EMPLOYEES	EMPLOYEES
MAINTENANCE PERSONNEL	3	0	0	2.440	0.0	0.0	0.0	0.0
OPERATING PERSONNEL	34	0	0	15.040	0.0	0.0	0.0	0.0
HEALTH PHYSICS PERSONNEL	3	0	0	2.770	0.0	0.0	0.0	0.0
SUPERVISORY PERSONNEL	5	0	0	1.120	0.0	0.0	0.0	0.0
ENGINEERING PERSONNEL	37	0	0	17.260	0.0	0.0	0.0	0.0
<b>TOTAL</b>	<b>82</b>	<b>0</b>	<b>0</b>	<b>38.630</b>	<b>0.0</b>	<b>0.0</b>	<b>0.0</b>	<b>38.630</b>

ROUTINE MAINTENANCE	NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION			TOTAL	TOTAL MAN-REMS			
	STATION	NUMBER OF PERSONNEL (>100 M-REM)	UTILITY CONTRACT					
MAINTENANCE PERSONNEL	100	32	530	194.290	22.010	791.680		
OPERATING PERSONNEL	41	0	0	20.830	0.0	0.0	0.0	0.0
HEALTH PHYSICS PERSONNEL	23	0	0	20.780	0.0	0.0	0.0	0.0
SUPERVISORY PERSONNEL	45	0	0	32.320	0.0	0.0	0.0	0.0
ENGINEERING PERSONNEL	41	0	0	13.560	0.0	0.0	0.0	0.0
<b>TOTAL</b>	<b>250</b>	<b>32</b>	<b>530</b>	<b>281.780</b>	<b>22.010</b>	<b>791.680</b>	<b>1095.470</b>	

IN-SERVICE INSPECTION	NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION			TOTAL	TOTAL MAN-REMS			
	STATION	NUMBER OF PERSONNEL (>100 M-REM)	UTILITY CONTRACT					
MAINTENANCE PERSONNEL	0	0	0	0.0	0.0	0.0	0.0	0.0
OPERATING PERSONNEL	0	0	0	0.0	0.0	0.0	0.0	0.0
HEALTH PHYSICS PERSONNEL	0	0	0	0.0	0.0	0.0	0.0	0.0
SUPERVISORY PERSONNEL	16	0	0	8.080	0.0	0.0	0.0	0.0
ENGINEERING PERSONNEL	35	0	0	14.520	0.0	0.0	0.0	0.0
<b>TOTAL</b>	<b>51</b>	<b>0</b>	<b>0</b>	<b>23.980</b>	<b>0.0</b>	<b>0.0</b>	<b>234.210</b>	

SPECIAL MAINTENANCE	NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION			TOTAL	TOTAL MAN-REMS			
	STATION	NUMBER OF PERSONNEL (>100 M-REM)	UTILITY CONTRACT					
MAINTENANCE PERSONNEL	5	0	185	5.270	0.0	0.0	541.700	
OPERATING PERSONNEL	0	0	0	0.0	0.0	0.0	0.0	0.0
HEALTH PHYSICS PERSONNEL	0	0	0	2.430	0.0	0.0	0.0	0.0
SUPERVISORY PERSONNEL	0	0	0	2.770	0.0	0.0	0.0	0.0
ENGINEERING PERSONNEL	0	0	0	2.140	0.0	0.0	0.0	0.0
<b>TOTAL</b>	<b>5</b>	<b>0</b>	<b>185</b>	<b>5.270</b>	<b>0.0</b>	<b>0.0</b>	<b>541.700</b>	<b>546.970</b>

WASTE PROCESSING	NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION			TOTAL	TOTAL MAN-REMS			
	STATION	NUMBER OF PERSONNEL (>100 M-REM)	UTILITY CONTRACT					
MAINTENANCE PERSONNEL	0	0	0	0.0	0.0	0.0	0.0	0.0
OPERATING PERSONNEL	6	0	0	2.430	0.0	0.0	0.0	0.0
HEALTH PHYSICS PERSONNEL	3	0	0	2.770	0.0	0.0	0.0	0.0
SUPERVISORY PERSONNEL	2	0	0	2.140	0.0	0.0	0.0	0.0
ENGINEERING PERSONNEL	7	0	0	2.690	0.0	0.0	0.0	0.0
<b>TOTAL</b>	<b>18</b>	<b>0</b>	<b>18</b>	<b>10.030</b>	<b>0.0</b>	<b>0.0</b>	<b>10.030</b>	

REFUELING	NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION			TOTAL	TOTAL MAN-REMS			
	STATION	NUMBER OF PERSONNEL (>100 M-REM)	UTILITY CONTRACT					
MAINTENANCE PERSONNEL	0	0	0	0.0	0.0	0.0	0.0	0.0
OPERATING PERSONNEL	2	0	0	1.600	0.0	0.0	0.0	0.0
HEALTH PHYSICS PERSONNEL	0	0	0	0.0	0.0	0.0	0.0	0.0
SUPERVISORY PERSONNEL	1	0	0	0.880	0.0	0.0	0.0	0.0
ENGINEERING PERSONNEL	3	0	0	1.610	0.0	0.0	0.0	0.0
<b>TOTAL</b>	<b>6</b>	<b>0</b>	<b>6</b>	<b>4.090</b>	<b>0.0</b>	<b>0.0</b>	<b>4.090</b>	

TOTAL BY JOB FUNCTION	NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION			TOTAL	TOTAL MAN-REMS			
	STATION	NUMBER OF PERSONNEL (>100 M-REM)	UTILITY CONTRACT					
MAINTENANCE PERSONNEL	108	32	715	855	202.000	22.010	1567.590	1791.600
OPERATING PERSONNEL	83	0	0	83	39.900	0.0	0.0	39.900
HEALTH PHYSICS PERSONNEL	29	0	0	29	27.700	0.0	0.0	27.700
SUPERVISORY PERSONNEL	69	0	0	69	44.540	0.0	0.0	44.540
ENGINEERING PERSONNEL	123	0	0	123	49.640	0.0	0.0	49.640
<b>GRAND TOTAL</b>	<b>412</b>	<b>32</b>	<b>715</b>	<b>1159</b>	<b>363.780</b>	<b>22.010</b>	<b>1567.590</b>	<b>1953.380</b>



1. REPORT NUMBER (*Assigned by DDCI*)

NUREG-0713, Vol. 4

4. TITLE AND SUBTITLE (*Add Volume No., if appropriate*)Occupational Radiation Exposure at Commercial  
Nuclear Power Reactors - 1982  
Annual Report2. (*Leave blank*)

3. RECIPIENT'S ACCESSION NO.

## 7. AUTHOR(S)

Barbara G. Brooks

5. DATE REPORT COMPLETED

MONTH                   YEAR  
September              19839. PERFORMING ORGANIZATION NAME AND MAILING ADDRESS (*Include Zip Code*)Division of Data Automation & Management Information  
Office of Resource Management  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

DATE REPORT ISSUED

MONTH                   YEAR  
December               19836. (*Leave blank*)8. (*Leave blank*)

10. PROJECT/TASK/WORK UNIT NO.

11. FIN NO.

12. SPONSORING ORGANIZATION NAME AND MAILING ADDRESS (*Include Zip Code*)

Same as 9 above.

## 13. TYPE OF REPORT

Annual

PERIOD COVERED (*Inclusive dates*)

1982

## 15. SUPPLEMENTARY NOTES

14. (*Leave blank*)16. ABSTRACT (*200 words or less*)

This report summarizes the occupational radiation exposure information that has been reported to the U.S.N.R.C. by commercial nuclear power reactors during the years 1969 through 1982. The bulk of the data presented in the report was obtained from annual radiation exposure reports submitted in accordance with the requirements of 10 CFR 20.407 and license technical specifications. Data on workers terminating their employment at nuclear power facilities was obtained from reports submitted pursuant to 10 CFR 20.408. The annual reports submitted by the 75 nuclear power plants that had completed at least one full year of operation as of December 31, 1982, indicated that the number of personnel monitored during 1982 was 129,275 persons and the annual collective dose incurred by these individuals was 52,190 man-rems. The average annual dose for each worker that received a measurable dose was 0.6 rems, and the average collective dose per reactor was 705 man-rems. The termination reports revealed that some 65,700 individuals completed their employment with one or more reactor facilities during 1981.\* Approximately 5,300 of these workers could be considered transients and they received an average dose of about one rem.

\* The most recent year for which all of the termination data are available for analysis.

## 17. KEY WORDS AND DOCUMENT ANALYSIS

17a DESCRIPTORS

Not Applicable

## 17b. IDENTIFIERS/OPEN-ENDED TERMS

## 18. AVAILABILITY STATEMENT

Unlimited

19. SECURITY CLASS (*This report*)  
Unclassified

21 NO OF PAGES

20 SECURITY CLASS (*This page*)  
Unclassified22 PRICE  
S



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555

OFFICIAL BUSINESS  
PENALTY FOR PRIVATE USE, \$300

FOURTH CLASS MAIL  
POSTAGE & FEES PAID  
USNRC  
WASH D C  
PERMIT No 667