



NOTE:
 1. FOR NOTES SEE DWG. M-1072A.
 2. CHANGE SPEC. 8" JIC PIPING, USE SCH. 40S PIPE & FITTINGS, FOR SERVICE CONDITIONS SEE JBD-156.
 3. CHANGE SPEC. 8" JIC PIPING, USE SCH. 40S PIPING, FOR SERVICE CONDITIONS SEE JBD-155.

NO.	DATE	DESCRIPTION	BY	ENG	CHK	APP
010	AS-BUILT PER EC 11852	WE	N/A	N/A	SP	10-20-10
009	AS-BUILT PER 97/0939-00-00 & ER-GG-2003-0279-000-00	WE	SIGN-OFF	ON RECORD		

GRAND GULF NUCLEAR STATION
 UNIT 1
 NUCLEAR PLANT ENGINEERING

UPDATED FINAL SAFETY ANALYSIS REPORT
 FIGURE NUMBER - 09.2-023-02

P & I DIAGRAM
 PLANT SERVICE WATER SYSTEM UNIT 1

SCALE:	NONE	DRAWING No.	M-1072F	REV.	010
--------	------	-------------	---------	------	-----

COMPONENTS SUBJECT TO AMR

- STANDBY SERVICE WATER SYSTEM AMM12
- NON-SAFETY RELATED SYSTEMS & COMPONENTS AFFECTING SAFETY RELATED SYSTEMS AMM20
- PLANT SERVICE WATER SYSTEM AMM29

NO.	DATE	DESCRIPTION	BY	ENG	CHK	APP
REVISIONS						
LRA-M-1072F						
DRAWING No. m1072f.dgn						