



- NOTES:
- FOR LEGEND & GENERAL NOTES SEE DWG M-1098A.
 - THE FLOOR DRAIN FIXTURES IN THE RAILROAD BAY SHALL BE PERMANENTLY SEALED.
 - THIS P & I IS NOT "O" LISTED, "O" IDENTIFICATION IS FOR MINOR AREAS ONLY AS SHOWN.
 - R.R. BAY AREA DRAIN PIPING WITHIN THE DESIGNATED BOUNDARY SHALL BE SUPPORTED FOR SEISMIC CATEGORY I REQUIREMENTS. PIPING MATERIAL SUPPLIER SHALL SUBMIT MATERIAL CERTIFICATE OF CONFORMANCE. IN ADDITION ALL EXPOSED WELDS SHALL BE EITHER LIQUID PENETRANT OR MAGNETIC PARTICLE INSPECTED.
 - FLOOR DRAIN ADDED PER MCP 94/1063. SEE DWG. M-KA1399 FOR DRAINAGE PIPING.

No.	REVISIONS	DATE	BY	CHK	APP	DATE
013	AS-BUILT PER ER 2000-0240-000		WC	N/A	N/A	11-21-00
012	AS-BUILT PER DCP 92/0006		WC	N/A	N/A	12-05-00
011	AS-BUILT PER DRN 5406		AS	N/A	N/A	12-19-00
010	AS-BUILT PER MCP 94/1063		WC	N/A	N/A	11-21-00
009	AS-BUILT PER MNCR 0206-95					SIGN-OFF ON RECORD
008	AS-BUILT PER DCP 82/5074					SIGN-OFF ON RECORD

GRAND GULF NUCLEAR STATION
UNIT 1
NUCLEAR PLANT ENGINEERING

UPDATED FINAL SAFETY ANALYSIS REPORT
FIGURE NUMBER - 9.3-016

P & I DIAGRAM
EMBEDDED & SUSPENDED DRAINS
AUXILIARY BLDG.
UNIT 1

1P48 1015M
MPL No. 1P45 1045M
SCALE: NONE
DRAWING No.: M-1098B
REV: 013
DFN: m1098b.dgn

- COMPONENTS SUBJECT TO AMR
- NON-SAFETY RELATED SYSTEMS & COMPONENTS AFFECTING SAFETY RELATED SYSTEMS AMM20
 - FLOOR AND EQUIPMENT DRAIN SYSTEM AMM30

NO.	DATE	DESCRIPTION	BY	ENG	CHK	APP
REVISIONS						
LRA-M-1098B						
DRAWING FILE: m1098b.dgn						
PLOTTER FILE:						

DJSD