



- COMPONENTS SUBJECT TO AMR
- PLANT CHILLED WATER SYSTEM AMM14
  - HEATING, VENTILATION AND AIR CONDITIONING SYSTEMS AMM17
  - NON-SAFETY RELATED SYSTEMS & COMPONENTS AFFECTING SAFETY RELATED SYSTEMS AMM20
  - PLANT SERVICE WATER SYSTEM AMM29

- NOTES:
- ALL EQUIPMENT NUMBERS ON THIS DRAWING ARE PREFIXED BY N1141 UNLESS OTHERWISE NOTED.
  - FOR HVAC LEGEND SEE M-0047.
  - ALL INSTRUMENT NUMBERS ON THIS DRAWING ARE PREFIXED BY N1141 UNLESS OTHERWISE NOTED.
  - THIS DRAWING IS NOT "D" LISTED. "D" IDENTIFICATION IS FOR MINOR AREAS AS SHOWN.
  - DELETED
  - ALL RADIATION PIPING 2" & SMALLER IS CLASSIFIED AS III-"A" RADIATION LEVEL.
  - WHERE NO SUITABLE DUCT IS AVAILABLE FOR MOUNTING THESE THERMOCOUPLES, THEY WILL BE LOCATED IN THE AIR STREAM IN THE IMMEDIATE VICINITY OF THE ENTRANCE TO THE DUCT. DUCT EXTENSIONS SHALL NOT BE USED.
  - THESE THERMOCOUPLES SHOULD BE LOCATED OUTSIDE OF THE MAIN STEAM TUNNEL IN AN AREA WHERE THE TEMPERATURE IS STABLE.
  - DEVICES IDENTIFIED BY **M** HAVE BEEN ABANDONED IN PLACE. **TE** REMAINS WIRED FOR FUTURE DATA POINT USE.

012	AS-BUILT PER DRN 7214	WE	N/A	N/A	N/A	9/28/88
011	AS-BUILT PER DRN 6482	SP	N/A	N/A	N/A	3-17-99
010	AS-BUILT PER ER 96/0711-00-00	CH	N/A	N/A	N/A	5-12-98
009	REVISION	DR	BY	CHK	APP	DATE

GRAND GULF NUCLEAR STATION  
UNIT 1  
NUCLEAR PLANT ENGINEERING

**UPDATED FINAL SAFETY ANALYSIS REPORT**  
FIGURE NUMBER - 9.4-010

P & I DIAGRAM  
AUXILIARY BUILDING VENTILATION SYSTEM

SCALE: NONE DRAWING No. M-1103A REV. 012

NO.	DATE	DESCRIPTION	BY	ENG	CHK	APP
REVISIONS						
<b>LRA-M-1103A</b>						
001						
m1103a.DGN						

0 10-13-2011

MPL NO. 1T41 1015M M1103A.DGN