



# MONTICELLO NUCLEAR GENERATING PLANT

Minnesota

## — NOTICE —

THE ATTACHED FILES ARE OFFICIAL RECORDS OF THE DIVISION OF DOCUMENT CONTROL. THEY HAVE BEEN CHARGED TO YOU FOR A LIMITED TIME PERIOD AND MUST BE RETURNED TO THE RECORDS FACILITY BRANCH 016. PLEASE DO NOT SEND DOCUMENTS CHARGED OUT THROUGH THE MAIL. REMOVAL OF ANY PAGE(S) FROM DOCUMENT FOR REPRODUCTION MUST BE REFERRED TO FILE PERSONNEL. *5D-263*  
*4/12/85*

DEADLINE RETURN DATE 8504260222

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

RECORDS FACILITY BRANCH

INSERVICE INSPECTION - EXAMINATION SUMMARY

MONTICELLO NUCLEAR GENERATING PLANT-UNIT I

FEBRUARY 10, 1984 to January 12, 1985

REFUELING OUTAGE NO. 10

INSPECTION PERIOD 1

INTERVAL 2

**N O R T H E R N   S T A T E S   P O W E R   C O M P A N Y**

Commerical Service Date: MINNEAPOLIS, MINNESOTA  
June 30, 1971

Report Date:  
March 27, 1985

8504260227 850412  
PDR ADOCK 05000263  
Q PDR






# MONTICELLO NUCLEAR GENERATING PLANT

Monticello, Minnesota

UNIT I



INSERVICE INSPECTION - EXAMINATION SUMMARY

MONTICELLO NUCLEAR GENERATING PLANT-UNIT I

FEBRUARY 10, 1984 to January 12, 1985

REFUELING OUTAGE NO. 10

INSPECTION PERIOD 1

INTERVAL 2

**N O R T H E R N   S T A T E S   P O W E R   C O M P A N Y**

Commerical Service Date: MINNEAPOLIS, MINNESOTA  
June 30, 1971

Report Date:  
March 27, 1985


NORTHERN STATES POWER COMPANY  
MONTICELLO NUCLEAR GENERATION PLANT - UNIT 1

INSERVICE INSPECTION-EXAMINATION SUMMARY  
MONTICELLO NUCLEAR GENERATING PLANT - UNIT 1  
FEBRUARY 10, 1984 to JANUARY 12, 1985  
REFUELING OUTAGE NO. 10  
INSPECTION PERIOD 1  
INTERVAL 2

Report Date:  
March 27, 1985


Prepared by: J. Schanen

Reviewed by:

  
L.C. Dahlman,  
Materials & Special  
Processes Specialist

Commerical Service Date:  
June 30, 1971

Approved by:

  
G.T. Krause  
Superintendent  
Materials & Special  
Processes

INSERVICE INSPECTION - EXAMINATION SUMMARY  
MONTICELLO NUCLEAR GENERATING PLANT - UNIT 1  
- INDEX -

- 1.0 Introduction
  - 2.0 Inspection Summary
  - 3.0 Discussion of Examination Plan
    - 3.1 Inspection Boundary
    - 3.2 Examination Procedures
    - 3.3 Examination Methods
    - 3.4 Equipment and Materials
    - 3.5 Personnel
    - 3.6 Evaluation
    - 3.7 Examination Reports and Documentation
    - 3.8 Summary of Results
  - 4.0 Visual Examination of the Reactor Vessel Internals
  - 5.0 Augmented Examinations
  - 6.0 Piping Replacement
- Appendix A - ASME Class I Examination

Inservice Inspection - Examination Summary Tables:

- Table S1.1 - Reactor Vessel Welds
- Table S2.1 - Vessels and Heat Exchangers
- Table S3.1 - Nozzle Welds
- Table S4.1 - Partial Penetration Welds
- Table S5.1 - Dissimilar Metal Welds
- Table S6.1 - Pressure Retaining Bolting > 2"
- Table S7.1 - Pressure Retaining Bolting < 2"
- Table S8.1 - Vessel Supports
- Table S9.1 - Piping Pressure Boundary
- Table S10.1 - Support Members
- Table S11.1 - Component Supports
- Table S12.1 - Pump Casings and Valve Bodies
- Table S13.1 - Reactor Vessel Interior
- Table S14.1 - Control Rod Housing Welds
- Table S15.1 - Pressure Retaining Components

## Appendix B ASME Class II Examinations

### Inservice Inspection - Examination Summary Tables:

- Table S1.2 - Vessel Welds
- Table S2.2 - Nozzle Welds
- Table S3.2 - Support Members
- Table S4.2 - Pressure Retaining Bolting >2"
- Table S5.2 - Piping Pressure Boundary
- Table S6.2 - Pump Casings and Valve Bodies
- Table S7.2 - Pressure Retaining Components

## Appendix C

- Table I - Personnel Listing
- Table II - Ultrasonic Calibration Blocks
- Table III - Procedure Listing
- Table IV - Equipment and Materials

## Appendix D

Form NIS-1, Owner's Data Report for Inservice Inspections

INSERVICE INSPECTION - EXAMINATION SUMMARY  
MONTICELLO NUCLEAR GENERATING PLANT - UNIT 1  
FEBRUARY 10, 1984 to JANUARY 12, 1985

1.0 INTRODUCTION

This report is a summary of the Monticello Nuclear Generating Plant's Eleventh Inservice Inspection. This was the second inservice inspection to be conducted in inspection period one of the plant's second ten year interval. The examinations were performed during the tenth refueling outage from February 10, 1984 to January 12, 1985. The Monticello Nuclear Generating Plant began commercial operation on June 30, 1971.

The examinations were performed on pressure-retaining components and their supports of the reactor coolant and associated auxiliary systems classified as ASME Class I and ASME Class II.

2.0 INSPECTION SUMMARY

The evaluation of the results from the inservice examinations revealed several intergranular stress corrosion cracks in the weld heat affected zone of welds in the Residual Heat Removal and Jet Pump Instrumentation systems. Additional cracking on the Feedwater Sparger Flow Nozzles, attributed to thermal fatigue was revealed during the visual examination of the reactor vessel interior. All items identified as containing cracks were subsequently replaced.

3.0 DISCUSSION OF EXAMINATION PLAN

3.1 Inspection Boundary

The examination plan focused on the pressure-retaining components and their supports of the reactor core coolant systems, portions of the emergency core coolant systems, and portions of the reactor coolant associated systems that are classified as ASME Class I and ASME Class II.

The examination plan was based on the examination requirements of the ASME Boiler and Pressure Vessel Code Section XI, 1977 Edition through and including the Summer, 1978 Addenda, and complied with Monticello's Technical Specification, Section TS4.15. The examination plan is in accordance with the program submitted to the United States Nuclear Regulatory Commission on March 27, 1981 titled, "ASME Code Section XI, Inservice Inspection and Testing Program".

### 3.2 Examination Procedures

A listing of the procedures used for the examinations is shown in Table III of Appendix C. The Ultrasonic examination procedure for pipe welds complied with the requirements of Appendix III of ASME Section XI that were issued in the Summer, 1978 Addenda. All other examination procedures complied with the requirements of the 1977 Edition through and including the Summer, 1978 Addenda of ASME Section XI.

### 3.3 Examination Methods

Ultrasonic examination methods and techniques were used to perform volumetric examinations. The ultrasonic test system consisted of an ultrasonic digital analog tester and a two channel strip chart recorder. One channel of the recorder was calibrated to reflect the ultrasonic screen height (amplitude) and the second channel was calibrated to reflect the metal path (range) to the reflector. This approach gives a permanent record of the examination to the extent possible.

Liquid penetrant and magnetic particle examination methods were used to perform the surface examinations. The liquid penetrant examinations were performed using color contrast-solvent removable materials. Magnetic particle examinations were performed using a yoke and dry powder.

All visual examinations were aided, when necessary, with artificial lighting and verified for adequacy with an 18% neutral gray card with a 1/32 inch black line. Cold hanger load settings were visually verified (when applicable) and recorded on the report along with the piping system temperature.

### 3.4 Equipment and Materials

All equipment and expendable materials used in the examinations are listed by either serial number or type along with their respective calibration date or batch number in Table IV or Appendix C.

The ultrasonic calibration standards used in the examinations are listed in Table II of Appendix C. These standards are owned and maintained by NSP at the plant site.



### 3.5 Personnel

Northern States Power Company contracted General Electric Company to perform the reactor vessel visual examinations; and Lambert, MacGill, Thomas, Inc. to perform the balance of plant examinations. Hartford Steam Boiler Inspection and Insurance Company, representing ANI, provided the Authorized Inspection.

All personnel involved in the performance or evaluation of examinations are listed along with their title, organization and ANST level of certification in Table I of Appendix C.

All ultrasonic Level II examiners performing examinations in accordance with NSP-UT-16 Rev. 0 on stainless steel piping were EPRI qualified in the detection of IGSCC. Level I examiners were required to demonstrate scanning and detection proficiency on site.

Qualification records for examination personnel are maintained on file by Northern States Power Company.

### 3.6 Evaluation

Any indications disclosed in the examinations were evaluated by the examiner at the time, in accordance with the rules of the procedure and ASME Section XI.

The Ultrasonic examiner was aided in his evaluation by a calibration performed on a standard reference before each day's examination and checked before and after each individual examination and at intervals not exceeding four (4) hours. In addition, the ultrasonic data was recorded on strip charts, which were made part of the inspection report and permitted further evaluation.

### 3.7 Examination Reports and Documentation

All examination reports and documentation are maintained on file by Northern States Power Company. Table I of Appendices A and B identifies the examination report number(s) for each item examined. Many of the items identify more than one examination report number because of the different types of examinations performed on the individual item.

Table I of Appendices A and B summarizes all the examinations that have been performed to date and identifies the amount that will be performed to complete the Ten Year Examination requirements. For retrieval purposes, the prefix of the inspection report number corresponds with the year that the inspection was performed. The examination report numbers for this outage are prefixed with "84".

Table II of Appendices A and B compares the baseline examination results with the results obtained during the examinations. Table III of Appendices A and B identifies the isometric drawings that were used for the examinations. The personnel, ultrasonic calibration blocks, procedures, equipment and materials that were used for the inspections are identified in the tables of Appendix C. Appendix D contains the Form NIS-1, titled "Owners' Data Report for Inservice Inspections."

### 3.8 Summary of Results

The following is a list of all anomalies detected:

<u>System</u>	<u>Item I D</u>	<u>Exam Method</u>	<u>Type &amp; No. of Indications</u>
Core Spray "A"	A014-13B	VT	loose nut
	CSAK-35	VT	loose nut
	CSAK-31	VT	loose bolts
Core Spray "B"	CSP270-7	UT	1 spot indication
	TWH-69	VT	loose bolt
	TWH-70	VT	loose bolt
	TWH-113	VT	loose bolt
HPCI Steam	PSAF-2C	PT	Arc strike
RHR	RHBF-20	UT	1 spot Ind., 3 linear Ind.
	RHCF-20	UT	2 spot Ind., 2 linear Ind.
	RHBJ-21	UT	2 linear Ind.
	RHCJ-21	UT	Multiple spot indications
	TWH-7	VT	loose bolt
	TWH-73	VT	loose bolt
	TWH-102	VT	loose nut
Rx Support Skirt	HCAH-2	MT	9 linears
Jet Pump Instrumentation Canister "B"	W#1	UT	Multiple axial indications
Head Vent	HVAK-21	VT	loose nut, bent rod hanger
Feedwater System	Spargers	VT	Crack Ind. on N4C & N4D
RHR Service Water	SWAK-25	VT	loose nut
	SWAK-26	VT	loose nuts
	SWAK-34	VT	loose nut

### 3.8 (con't)

All anomalies with the exception HVAK-21 were corrected. The bent rod hanger on HVAK-21 was evaluated and accepted as is. All loose nuts and bolts were tightened. The PT arc strike and MT linear indications were removed by surface blending with a hand grinder. All items containing UT indications except CSP 270-7 were replaced. CSP 270-7 was subsequently radiographed and the UT indication appeared to be a machining mark on the I.D. surface. This weld will be inspected in future outages. The feedwater spargers were also replaced after several crack indications were noted on two of the flow nozzles.

### 4.0 Visual Examination of the Reactor Vessel Internals

A visual examination was performed on portions of the reactor vessel internal components utilizing an underwater TV camera, fiberscope, and a video recording system. The examinations were performed in accordance with Northern States Power Company's Procedure No. NSP-VT-4.0, Revision 0.

The examination procedure delineated the scope of the program and contained a separate appendix for each area to be examined. Each of the appendices contained a check-off list the examiners used during the examinations to identify areas examined and, abnormal conditions if found.

The examination program focused on the Core Spray Sparger System, Feedwater Sparger System, and the Shroud Support Welds. Examination areas for these systems included the following:

- Core Spray: Tee junction box at 90° and 270°; piping and welds; piping brackets and re clad area; sparger piping, nozzles, and brackets, and shroud penetrations.
- Feedwater: Inner radius of vessel nozzles at 45°, 135°, 225° and 315°, sparger piping and welds, end brackets and bolting, re clad areas, end pin and keeper box, and the individual flow nozzles on each sparger.
- Shroud Support Welds: Shroud support to shroud support, shroud support to shroud, and shroud support to bottom head welds.

General Electric Company was contracted to supply personnel to perform the examinations. There were two certified Level II Visual Examiners. One examiner was on the service platform and the other was on the refueling bridge. In addition a Northern States Power Company Level II was at the recording station. A video recording system was used to permanently document the abnormal conditions found during the examination, and to record system calibrations.

No abnormal conditions were noted on the Core Spray Sparger System and the shroud support welds.

Abnormal conditions found on the Feedwater Sparger System consisted of the following:

- Sparger N4C;           Crack like indications on the 5th spray nozzle, left side of the tee box.
- Sparger N4D;           Crack like indications on the 6th, 7th, and 8th spray nozzles, left side of the tee box.

These crack like indications were confirmed to be cracks by direct visual examination after lowering the reactor vessel water level, and by liquid penetrant examination after the spargers were removed from the reactor vessel.

All examinations reports and documentation are included with the balance of plant records and are maintained on file by Northern States Power Company.

#### 5.0 Augmented Examinations

Additional ultrasonic examinations, not in the examination plan for period 1, were performed to determine if Intergranular Stress Corrosion Cracking (IGSCC) existed in the 304 stainless steel and dissimilar metal welds not to be replaced during the 1984 outage. The systems examined were Jet Pump Instrumentation, Stand-by Liquid Control, Residual Heat Removal, High Pressure Coolant Injection, Head Vent and Core Spray.

These examinations determined the presence of IGSCC in the "B" and "C" loops of the RHR system and "B" Jet Pump Instrumentation. These welds along with "A" Jet Pump Instrumentation were subsequently scheduled for replacement during the outage. Although IGSCC was not found in the Standby Liquid Control safe end, the unloading of the reactor core for piping replacement provided an opportune time to replace this safe end.

#### 6.0 Piping Replacement

In conjunction with the refueling outage, piping was replaced in the recirculation, Residual Heat Removal, Jet Pump Instrumentation, Reactor Water Clean-up and Stand-by liquid control systems. Additionally the Feedwater Spargers were also replaced.

Further information regarding piping replacement and baseline examinations can be found under separate cover entitled "Baseline Examination Summary".

APPENDIX A

ASME CLASS 1 EXAMINATIONS

---

**NORTHERN STATES POWER CO.  
MONTICELLO NUCLEAR GENERATING PLANT  
INSERVICE INSPECTION-EXAMINATION SUMMARY**

TABLE S1.1

PAGE 1 OF 1

MAJOR ITEM: REACTOR VESSEL WELDS

SUB ITEM	EXAM CATE-GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B1.10	B-A	<u>SHELL WELDS</u>					
B1.11	B-A	<u>CIRCUMFERENTIAL</u>	ONE TWO THREE	10' 7' 9'	- - -		
B1.12	B-A	<u>LONGITUDINAL</u>	ONE TWO THREE	8' 9" 4' 12' 9"	- - -		
B1.20	B-A	<u>HEAD WELDS</u>					
B1.21	B-A	<u>CIRCUMFERENTIAL</u>					
		CLOSURE HEAD	ONE TWO THREE	8.5' 8' 8.5'	- - -		
		BOTTOM HEAD	ONE TWO THREE	3' 3' 3'	- - -		
B1.22	B-A	<u>MERIDONAL</u>	ONE TWO THREE	26' 21' 19'	- - -		
B1.30	B-A	<u>SHELL TO FLANGE WELD</u>	ONE TWO THREE	19' 19' 19'	- - -		
B1.40	B-A	<u>HEAD TO FLANGE WELD</u>	ONE TWO THREE	19' 19' 19'	- - -		
B1.50	B-A	<u>REPAIR WELDS</u>	-	-	-		

**NORTHERN STATES POWER CO.  
MONTICELLO NUCLEAR GENERATING PLANT  
INSERVICE INSPECTION-EXAMINATION SUMMARY**

**MAJOR ITEM: VESSELS & HEAT EXCHANGERS**

SUB ITEM	EXAM CATE- GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B2.10 & B2.20	B-B	<u>PRESSURIZER VESSEL</u>	-	-	-		
B2.30 & B2.40	B-B	<u>STEAM GENERATORS</u>	-	-	-		
B2.50 & B2.60	B-B	<u>HEAT EXCHANGERS</u>	-	-	-		

Form 9-0033, Rev. 0 (M&SP 5.2)  
**NORTHERN STATES POWER CO.**  
**MONTICELLO NUCLEAR GENERATING PLANT**  
**INSERVICE INSPECTION-EXAMINATION SUMMARY**

TABLE S3.1  
PAGE 1 OF 2  
MAJOR ITEM: NOZZLE WELDS

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B3.10 & B3.20	B-D	<u>NOZZLE-TO-VESSEL WELDS &amp; NOZZLE INSIDE RADIUS SECTION</u>					
		HEAD VENT	ONE	1	1	HVAD-1	84-140, 145, 147, 146, 155
		HEAD SPARE	TWO	1	-		
			THREE	1	-		
		STANDBY LIQUID CONTROL	TWO	1	-		
		MAIN STEAM	ONE	1	-		
			TWO	1	-		
			THREE	2	-		
		FEEDWATER	ONE	1	-		
			TWO	2	-		
			THREE	1	-		
		CORE SPRAY	ONE	1	1	CSBD-1	84-187, 190, 191, 158, 193
			THREE	1	-		
		CRD RETURN	ONE	1	1	CRAD-1	84-188, 189, 192, 168, 240
		RECIR OUTLET	ONE	1	1	RCAD-1	82-195, 255
			THREE	1	-		
		RECIR INLET	ONE	3	3	RRAD-1	82-170, 148
						RRDD-1	82-161, 171
				RRJD-1	82-160, 172		
		TWO	3	-			
		THREE	4	-			
JET PUMP INSTR	ONE	1	1	JPAD-1	84-194, 237, 238, 239, 241		
	THREE	1	-				



**NORTHERN STATES POWER CO.  
MONTICELLO NUCLEAR GENERATING PLANT  
INSERVICE INSPECTION-EXAMINATION SUMMARY**

TABLE S3.1

PAGE 2 OF 2

MAJOR ITEM: NOZZLE WELDS

SUB ITEM	EXAM CATE- GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B3.30 & B3.40	B-D	<u>PRESSURIZER VESSEL</u>	-	-	-		
B3.50 & B3.60	B-D	<u>STEAM GENERATORS</u>	-	-	-		
B3.70 & B3.80	B-D	<u>HEAT EXCHANGERS</u>	-	-	-		
B3.90 & B3.100							

**NORTHERN STATES POWER CO.  
MONTICELLO NUCLEAR GENERATING PLANT  
INSERVICE INSPECTION-EXAMINATION SUMMARY**

TABLE S4.1

PAGE 1 OF 1

MAJOR ITEM: PARTIAL PENETRATION WELDS

SUB ITEM	EXAM CATE-GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B4.10	B-E	<u>REACTOR VESSEL</u>	-	-	-		
B4.11	B-E	<u>PARTIAL PENT. WELDS</u>	-	-	-		
B4.12	B-E	<u>VESSEL NOZZLES</u>	THREE	1	-		
B4.13	B-E	<u>CRD PENETRATIONS</u>	ONE TWO THREE	10 10 11	- - -		
B4.14	B-E	<u>INSTR PENETRATIONS</u>	THREE	1	-		
B4.20	B-E	<u>PRESSURIZER</u>	-	-	-		

Form 9-0033, Rev. 0 (M&SP 5.2)  
**NORTHERN STATES POWER CO.**  
**MONTICELLO NUCLEAR GENERATING PLANT**  
**INSERVICE INSPECTION-EXAMINATION SUMMARY**

TABLE S5.1

PAGE 1 OF 3

MAJOR ITEM: DISSIMILAR METAL WELDS

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.		
B5.10	B-F	<u>REACTOR VESSEL</u>							
		<u>NOZZLE-TO-SAFE-END-WELDS</u>							
		HEAD VENT	ONE	1	2	HVAF-2 HSBF-2	84-134, 135 84-137, 138(Aug)		
		HEAD SPARE	TWO THREE	1 1	- -				
		STAND BY LIQUID CONTROL	TWO	1	1	CPAF-2	84-033, 061(Aug)		
		CORE SPRAY	ONE THREE	1 1	1 -	CSBF-2	84-162, 84-166		
		CRD RETURN	ONE	1	-				
		RECIRC OUTLET	ONE THREE	1 1	2 -	RCAF-2 RCBF-2 (Aug)	82-177, 196 82-257		
		RECIRC INLET	ONE	3	10	RRAF-2 RRDF-2 RRJF-2	82-70, 130 82-85, 151 82-84, 129		
						-----AUGMENTED-----			
						RRBF-2 RRCF-2 RREF-2 RRFF-2 RRGF-2 RRHF-2 RRKF-2	82-293 82-260 82-296 82-261 82-268 82-254 82-279		
				TWO THREE	3 4	- -			
				JET PUMP INSTR	ONE THREE	1 1	1 -	JPBF-2	84-043, 050

**NORTHERN STATES POWER CO.  
MONTICELLO NUCLEAR GENERATING PLANT  
INSERVICE INSPECTION-EXAMINATION SUMMARY**

TABLE S5.1

PAGE 2 OF 3

MAJOR ITEM: DISSIMILAR METAL WELDS

SUB ITEM	EXAM CATE-GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
35.10	B-F	(CONT'D)					
		INSTRUMENT LINES	ONE	1	4	VIAF-2 VIBF-2(Aug) VICF-2(Aug) VIDF-2(Aug)	84-070,075 84-071,074 84-161,164 84-163,165
			TWO	1	-		
			THREE	2	-		
35.20	B-F	<u>PRESSURIZER</u>	-	-	-		
35.30	B-F	<u>STEAM GENERATORS</u>	-	-	-		
35.40	B-F	<u>HEAT EXCHANGERS</u>	-	-	-		
35.50	B-F	<u>SAFE END WELDS</u>					
		CORE SPRAY	ONE	2	7	CSAF-14 CSAF-18 CSP-90-7(Aug) CSP-270-7(Aug) CSP-270-9(Aug) CSBF-12(Aug) CSBF-16(Aug)	84-096,103 84-094,098 84-220,259 84-182,184 84-156,213 84-093,102 84-101,105
			THREE	2	-		
		HPCI STEAM	ONE	-	2	PSAF-2B(Aug) PSAF-2C(Aug)	84-109,113 84-110,114
			TWO	1	-		
		RHR (REW10)	ONE	-	1	RHAF-4 (Aug)	82-274
			TWO	1	-		

Form 9-0033, Rev. 0 (M&SP 5.2)  
**NORTHERN STATES POWER CO.**  
**MONTICELLO NUCLEAR GENERATING PLANT**  
**INSERVICE INSPECTION-EXAMINATION SUMMARY**

TABLE S5.1  
PAGE 3 OF 3  
MAJOR ITEM: DISSIMILAR METAL WELDS

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.	
B5.10	B-F	(CONT'D)						
		RHR (TW20)	ONE	-	3	RHBF-4 (Aug)	82-241, 273	
							RHBF-20 (Aug)	82-242, 262
						2	RHBF-24 (Aug)	82-245, 272
							RHBF-20 (Aug)	84-085, 089
							RHBF-24 (Aug)	84-082
			TWO	1	-			
			THREE	2	-			
		RHR (TW30)	ONE	-	3	RHCF-4 (Aug)	82-265, 269	
							RHCF-20 (Aug)	82-246, 264
					RHCF-23 (Aug)	82-247, 263		
				2	RHCF-20 (Aug)	84-079, 087		
					RHCF-23 (Aug)	84-080		
		TWO	2	-				
		THREE	1	-				
	RWCU	ONE	1	1	CWAF-2	82-27, 28		

Form 9-0033, Rev. 0 (M&SP 5.2)  
**NORTHERN STATES POWER CO.**  
**MONTICELLO NUCLEAR GENERATING PLANT**  
**INSERVICE INSPECTION-EXAMINATION SUMMARY**

TABLE S6.1  
PAGE 1 OF 3  
MAJOR ITEM: PRESSURE RETAINING BOLTING > 2"

SUB ITEM	EXAM CATE-GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B6.10	B-G-1	<u>CLOSURE HEAD NUTS</u>	ONE TWO THREE	22 21 21	- - -		
B6.20	B-G-1	<u>CLOSURE STUDS, IN PLACE</u>	-	-	-		
B6.30	B-G-1	<u>CLOSURE STUDS, WHEN REMOVED</u>	ONE TWO THREE	22 21 21	- - -		
B6.40	B-G-1	<u>LIGAMENTS BETWEEN STUD HOLES</u>	ONE TWO THREE	22 21 21	- - -		
B6.50	B-G-1	<u>CLOSURE WASHERS AND BUSHINGS</u>					
		WASHERS	ONE TWO THREE	22 Prs 21 Prs 21 Prs	- - -		
		BUSHINGS	ONE TWO THREE	22 21 21	- - -		
B6.60	B-G-1	<u>PRESSURIZER</u>	-	-	-		
B6.90	B-G-1	<u>STEAM GENERATORS</u>	-	-	-		
B6.120	B-G-1	<u>HEAT EXCHANGERS</u>	-	-	-		
		<u>PIPING</u>	-	-	-		
		<u>PUMPS</u>	-	-	-		

**NORTHERN STATES POWER CO.  
MONTICELLO NUCLEAR GENERATING PLANT  
INSERVICE INSPECTION-EXAMINATION SUMMARY**

TABLE S6.1

PAGE 2 OF 3

MAJOR ITEM PRESSURE RETAINING BOLTING &gt; 2"

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B6.180	B-G-1	<u>BOLTS &amp; STUDS, IN PLACE</u>					
		RECIRC PUMP A FLANGE BOLTS	ONE TWO THREE	5 5 6	5 - -	Bolts, 1 thru 5	82-193 (VT only)
		RECIRC PUMP B FLANGE BOLTS	ONE TWO THREE	5 5 6	5 - -	Bolts, 1 thru 5	82-174, 194
B6.190	B-G-1	<u>BOLTS &amp; STUDS, WHEN REMOVED</u>					
		RECIRC PUMP A & B FLANGE BOLTS	- -	- -	- -		
B6.200	B-G-1	<u>BOLTING</u>					
		RECIRC PUMP A FLANGE BOLTS	ONE TWO THREE	5 5 6	5 - -	Bolts, 1 thru 5	82-173
		RECIRC PUMP B FLANGE BOLTS	ONE TWO THREE	5 5 6	5 - -	Bolts, 1 thru 5	82-192 (VT only)
B6.210	B-G-1	<u>BOLTS &amp; STUDS, IN PLACE</u>					
		RECIRC A	ONE TWO THREE	8 8 8	8 - -	M02-53A	82-180
		RECIRC A	ONE TWO THREE	8 8 8	8 - -	M02-43A	82-182

Form 9-0033, Rev. 0 (M&SP 5.2)  
**NORTHERN STATES POWER CO.**  
**MONTICELLO NUCLEAR GENERATING PLANT**  
**INSERVICE INSPECTION-EXAMINATION SUMMARY**

TABLE S6.1  
 PAGE 3 OF 3  
 MAJOR ITEM: PRESSURE RETAINING BOLTING > 2"

SUB ITEM	EXAM CATE-GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B6.210	B-G-1	(CONT'D)					
		RECIRC B	ONE TWO THREE	8 8 8	8 - -	M02-52B	82-179
		RECIRC B	ONE TWO THREE	8 8 8	8 - -	M02-43B	82-181
B6.220	B-G-1	<u>BOLTS, &amp; STUDS, WHEN REMOVED</u>					
		RECIRC A & B	-	-	-		
B6.230	B-G-1	<u>BOLTING</u>					
		RECIRC A	ONE TWO THREE	8 8 8	8 - -	M02-53A	82-180
		RECIRC A	ONE TWO THREE	8 8 8	8 - -	M02-43A	82-182
		RECIRC B	ONE TWO THREE	8 8 8	8 - -	M02-53B	82-179
		RECIRC B	ONE TWO THREE	8 8 8	8 - -	M02-43B	82-181



**NORTHERN STATES POWER CO.**  
**MONTICELLO NUCLEAR GENERATING PLANT**  
**INSERVICE INSPECTION-EXAMINATION SUMMARY**

TABLE S7.1  
 PAGE 1 OF 5  
 MAJOR ITEM: PRESSURE RETAINING BOLTING < 2"

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B7.10	B-G-2	<u>REACTOR VESSEL</u>					
		<u>BOLTS, STUDS, AND NUTS</u>					
		HEAD VENT	ONE	8	-		
		HEAD SPRAY	TWO	8	-		
		HEAD SPARE	THREE	8	-		
		CONTROL ROD HOUSINGS	ONE	41	-		
			TWO	40	-		
			THREE	40	-		
B7.20	B-G-2	<u>PRESSURIZER</u>	-	-	-		
B7.30	B-G-2	<u>STEAM GENERATORS</u>	-	-	-		
B7.40	B-G-2	<u>HEAT EXCHANGERS</u>	-	-	-		
		<u>PIPING</u>					
B7.50	B-G-2	<u>BOLTS, STUDS, AND NUTS</u>					
		MAIN STEAM A	ONE	1	-		
			THREE	3	-		
		MAIN STEAM B	TWO	1	-		
		MAIN STEAM C	ONE	1	-		
		MAIN STEAM D	ONE	1	-		
			TWO	1	-		
			THREE	2	-		
		RHR TW36	TWO	2	-		
		RECIRC A	ONE	1	1	Bolts @ RCAJ-20	82-357

Form 9-0033, Rev. 0 (M&SP 5.2)  
**NORTHERN STATES POWER CO.**  
**MONTICELLO NUCLEAR GENERATING PLANT**  
**INSERVICE INSPECTION-EXAMINATION SUMMARY**

TABLE S7.1  
PAGE 2 OF 5  
MAJOR ITEM: PRESSURE RETAINING BOLTING < 2"

SUB ITEM	EXAM CATE-GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B7.50	B-G-2	<u>(CONT'D)</u>  RECIRC B  RECIRC BYPASS A  RECIRC BYPASS B  HEAD VENT LINE  <u>PUMPS</u>	THREE  TWO  TWO  ONE	1  1  1  1	-  -  -  -		
B7.60	B-G-2	<u>BOLTS, STUDS, AND NUTS</u>  RECIRC PUMP A GLAND BOLTS  RECIRC PUMP B GLAND BOLTS  <u>VALVES</u>	ONE TWO THREE  ONE TWO THREE	3 3 4  3 3 4	- - -  - - -		
B7.70	B-G-2	<u>BOLTS, STUDS, AND NUTS</u>  MAIN STEAM A  MAIN STEAM B	ONE TWO THREE  ONE TWO THREE	2 - 2  - 2 2	- - -  - - -		

Form 9-0033, Rev. 0 (M&SP 5.2)  
**NORTHERN STATES POWER CO.**  
**MONTICELLO NUCLEAR GENERATING PLANT**  
**INSERVICE INSPECTION-EXAMINATION SUMMARY**

TABLE S7.1  
 PAGE 3 OF 5  
 MAJOR ITEM PRESSURE RETAINING BOLTING < 2"

SUB ITEM	EXAM CATE-GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B7.70	B-G-2	(CONT'D)					
		MAIN STEAM C	ONE TWO THREE	2 - 2	- - -		
		MAIN STEAM D	ONE TWO THREE	- 2 2	- - -		
		FEEDWATER A	ONE TWO THREE	1 1 1	- - -		
		FEEDWATER B	ONE TWO THREE	1 1 1	- - -		
		CORE SPRAY A	ONE  TWO THREE	2  1 -	2  - -	POS-1758 A014-13B	84-108 84-107
		CORE SPRAY B	ONE TWO THREE	1 - 2	1 - -	MO-1753	84-172
		HPCI STEAM	ONE TWO	1 1	1 -	MO-2035	84-128
		RWCU	ONE TWO THREE	1 1 1	1 - -	MO-2398	84-183
		RHR REW10	ONE TWO THREE	1 2 -	1 - -	MO-2029	84-216

Form 9-0033, Rev. 0 (M&SP 5.2)  
**NORTHERN STATES POWER CO.**  
**MONTICELLO NUCLEAR GENERATING PLANT**  
**INSERVICE INSPECTION-EXAMINATION SUMMARY**

TABLE S7.1  
PAGE 4 OF 5  
MAJOR ITEM: PRESSURE RETAINING BOLTING < 2"

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B7.70	B-G-2	(CONT'D)					
		RHR TW20	ONE TWO THREE	1 2 -	- - -		
		RHR TW30	ONE TWO THREE	1 1 1	1 - -	MO-2014	84-169
		RHR TW36	ONE TWO THREE	1 2 -	1 - -	MO-2026	84-173
		RCIC STEAM	TWO THREE	1 1	- -		
		RECIRC BYPASS A	THREE	1	-		
		RECIRC BYPASS B	THREE	1	-		
		RECIRC MANIFOLD	ONE THREE	2 2	2 -	MO2-65A MO2-66A	82-178 82-185
		HEAD VENT LINE	TWO THREE	1 2	- -		
		BOTTOM HEAD DRAIN	THREE	1	-		
		STANDBY LIQUID CONTROL	ONE TWO THREE	1 1 1	1 - -	XP-8	84-215
		MAIN STEAM DRAIN	ONE TWO	1 1	- -		

**NORTHERN STATES POWER CO.  
MONTICELLO NUCLEAR GENERATING PLANT  
INSERVICE INSPECTION-EXAMINATION SUMMARY**

TABLE S7.1

PAGE 5 OF 5

MAJOR ITEM PRESSURE RETAINING BOLTING < 2"

SUB ITEM	EXAM CATE- GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B7.70	B-G-2	<p><u>(CONT'D)</u></p> <p>CRD SCRAM HEADER DRAIN LINE</p> <p>RECIRC A DRAIN</p> <p>RECIRC B DRAIN</p>	<p>ONE</p> <p>ONE</p> <p>TWO</p>	<p>1</p> <p>2</p> <p>2</p>	<p>-</p> <p>2</p> <p>-</p>	<p></p> <p>XR-6-1 XR-7-1</p>	<p></p> <p>82-87 82-88</p>

**NORTHERN STATES POWER CO.  
MONTICELLO NUCLEAR GENERATING PLANT  
INSERVICE INSPECTION-EXAMINATION SUMMARY**

MAJOR ITEM: VESSEL SUPPORTS

SUB ITEM	EXAM CATE-GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B8.10	B-H	<u>REACTOR VESSEL</u> <u>INTEGRALLY WELDED ATTACHMENTS</u> SUPPORT SKIRT  STABILIZER LUGS	ONE TWO THREE  -	17 18 18  -	17% - -  -	8½" 120" - 180"	84-257, 257R
B8.20	B-H	<u>PRESSURIZER</u>	-	-	-		
B8.30	B-H	<u>STEAM GENERATORS</u>	-	-	-		
B8.40	B-H	<u>HEAT EXCHANGERS</u>	-	-	-		

**NORTHERN STATES POWER CO.  
MONTICELLO NUCLEAR GENERATING PLANT  
INSERVICE INSPECTION-EXAMINATION SUMMARY**

SUB ITEM	EXAM CATE-GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B9.10	B-J	<u>NOMINAL PIPE SIZE, 4 IN. AND GREATER</u>	-	-	-		
B9.11 & B9.12	B-J	<u>CIRCUMFERENTIAL AND *LONGITUDINAL WELDS</u>					
		MAIN STEAM A PS1-18"	ONE TWO THREE	3 - 3	- - -		
		PS1-6"	ONE TWO THREE	1 - 1	2 - -	MSAJ-16, 20 (Baseline)	82-311, 312
		MAIN STEAM B PS2-18"	ONE TWO THREE	- 4 3	- - -		
		PS2-6"	ONE TWO THREE	- 1 -	2 - -	MSBJ-15, 21 (Baseline)	82-313, 314
		MAIN STEAM C PS3-18"	ONE TWO THREE	2 2 3	- - -		
		PS3-6"	ONE TWO THREE	1 - -	2 - -	MSCJ-16, 21 (Baseline)	82-315, 318

**NORTHERN STATES POWER CO.  
MONTICELLO NUCLEAR GENERATING PLANT  
INSERVICE INSPECTION-EXAMINATION SUMMARY**

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B9.11 & B9.12	B-J	(CONT'D)					
		MAIN STEAM D PS4-18"	ONE TWO THREE	2 1 3	- - -		
		PS4-6"	ONE TWO THREE	1 - 1	2 - -	MSFJ-17, 21 (Baseline)	82-317, 316
		FEEOWATER A	ONE TWO THREE	2 - 1	- - -		
			ONE TWO THREE	- 2 1	- - -		
		FEEOWATER B	ONE TWO THREE	- 2 1	- - -		
			ONE TWO THREE	1 - 1	- - -		
		FEEOWATER C	ONE TWO THREE	2 - 1	- - -		
			ONE TWO THREE	2 - 1	- - -		
		FEEOWATER D	ONE TWO THREE	2 - 1	- - -		
			ONE TWO THREE	2 1 -	- - -		



Form 9-0033, Rev. 0 (M&SP 5.2)  
**NORTHERN STATES POWER CO.**  
**MONTICELLO NUCLEAR GENERATING PLANT**  
**INSERVICE INSPECTION-EXAMINATION SUMMARY**

TABLE S9.1  
PAGE 3 OF 14  
MAJOR ITEM: PIPING PRESSURE BOUNDARY

SUB ITEM	EXAM CATE-GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B9.11 & B9.12	B-J	(CONT'D)					
		CORE SPRAY A	ONE	1	3	CSAJ-19 CSAJ-16(Aug.) CSAJ-17(Aug.)	84-179, 180 84-095, 104 84-079, 106
			TWO	2	-		
			THREE	1	-		
		CORE SPRAY B	ONE	2	4	CSBJ-21 CSBJ-22 CSBJ-13(Aug.) CSBJ-14(Aug.)	84-170, 175 84-171, 174 84-092, 099 84-091, 100
			TWO	-	-		
			THREE	2	-		
		HPCI-STEAM	ONE	-	-		
			TWO	2	-		
			THREE	2	-		
		RWCU LINE	ONE	-	1	CWAJ-2A	82-320
			TWO	2	-		
			THREE	2	-		
		RHR REW10	ONE	3	6	RHAJ-1, 2, 3 RHAJ-25 RHAJ-26 RHAJ-27	82-252, 253, 275 84-195, 243 84-178, 245 84-242, 244
	TWO	-	-				
	THREE	2	-				
RHR TW20-16"	ONE	2	6	RHBJ-28, 29 RHBJ-1 (Aug) RHBJ-3 (Aug) RHBJ-21(Aug) RHBJ-22(Aug)	82-31, 53, 32, 52 82-277 82-276 84-084, 090 84-083		
	TWO	2	-				

Form 9-0033, Rev. 0 (M&SP 5.2)  
**NORTHERN STATES POWER CO.**  
**MONTICELLO NUCLEAR GENERATING PLANT**  
**INSERVICE INSPECTION-EXAMINATION SUMMARY**

TABLE S9.1  
PAGE 4 OF 14  
MAJOR ITEM: PIPING PRESSURE BOUNDARY

SUB ITEM	EXAM CATE-GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B9.11 & B9.12	B-J	(CONT'D)					
		RHR TW20-16"	THREE	1	-		
		RHR TW20-18"	ONE	-	2	RHBJ-21 (Aug) RHBJ-22 (Aug)	82-243 82-244
			TWO THREE	- 1	- -		
		RHR TW30-16"	ONE	2	4	RHCJ-7, 8 RHCJ-21 (Aug) RHCJ-22 (Aug)	82-33, 55, 34, 54 82-248, 84-086, 088 82-249, 84-083
			TWO THREE	2 1	- -		
		RHR TW30-18"	ONE	-	2	RHCJ-1 (Aug) RHCJ-3 (Aug)	82-250 82-251
			TWO THREE	1 -	- -		
		RHR TW36	ONE TWO THREE	- 3 3	1 - -	RHDJ-2 (Aug)	84-136, 139
		RECIRC A	ONE	1	17	RCAJ-13	82-071, 074
						-----AUGMENTED-----	
						RCAJ-3 RCAJ-4 RCAJ-5 RCAJ-6 RCAJ-9 RCAJ-11 RCAJ-15 RCAJ-17 RCAJ-20 RCAJ-21	82-225 82-120 82-099 82-121 82-226 82-227 82-080 82-228 82-357 82-081

Form 9-0033, Rev. 0 (M&SP 5.2)  
**NORTHERN STATES POWER CO.**  
**MONTICELLO NUCLEAR GENERATING PLANT**  
**INSERVICE INSPECTION-EXAMINATION SUMMARY**

TABLE S9.1  
PAGE 5 OF 14  
MAJOR ITEM: PIPING PRESSURE BOUNDARY

SUB ITEM	EXAM CATE-GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.		
B9.11 & B9.12	B-J	(CONT'D)							
		RECIRC A				RCAJ-23	82-147		
						RCAJ-24	82-229		
						RCAJ-28	82-230		
						RCAJ-30	82-082		
						RCAJ-32	82-083		
						RCAJ-35	82-256		
					TWO	2	-		
					THREE	2	-		
				RECIRC B	ONE	2	16	RCBJ-11, 13	82-069,095,065,094
								-----AUGMENTED-----	
								RCBJ-3	82-258
								RCBJ-4	82-231
								RCBJ-5	82-096
								RCBJ-6	82-232
						RCBJ-9	82-231		
						RCBJ-15	82-233		
						RCBJ-18	82-234		
						RCBJ-19	82-098		
						RCBJ-21	82-146		
						RCBJ-22	82-235		
						RCBJ-26	82-236		
						RCBJ-28	82-097		
						RCBJ-31	82-237		
						RCBJ-34	82-240		
			TWO	-	-				
			THREE	2	-				
		RECIRC BYPASS A	ONE	2	6	RBAJ-M12, M13	82-078,302,079,301		
						-----AUGMENTED-----			
						RBAJ-2	82-288		
						RBAJ-M3	82-289		
						RBAJ-M15	82-287		
						RBAJ-M16	82-286		

Form 9-0033, Rev. 0 (M&SP 5.2)  
**NORTHERN STATES POWER CO.**  
**MONTICELLO NUCLEAR GENERATING PLANT**  
**INSERVICE INSPECTION-EXAMINATION SUMMARY**

TABLE S9.1  
PAGE 6 OF 14  
MAJOR ITEM: PIPING PRESSURE BOUNDARY

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B9.11 & B9.12	B-J	(CONT'D)					
		RECIRC BYPASS A	TWO THREE	- 1	- -		
		RECIRC BYPASS B	ONE	2	6	RBBJ-M7, M8	82-076,213,077,186
						-----AUGMENTED-----	
						RBBJ-2	82-282
						RBBJ-M3	82-283
						RBBJ-M18	82-285
						RBBJ-19	82-284
		RECIRC MANIFOLD	TWO THREE	2 -	- -		
			ONE	2	21	RMAJ-2, 9	82-30,72,72A,72B,67,73
						-----AUGMENTED-----	
						RMAJ-3	82-214
						RMAJ-5	82-218
						RMAJ-7	82-217
						RMAJ-8	82-270
						RMAJ-10	82-113
						RMAJ-14	82-122
						RMAJ-15	82-216
						RMAJ-16	82-215
						RMBJ-2	82-131
						RMBJ-3	82-219
						RMBJ-5	82-220
						RMBJ-7	82-132
						RMBJ-8	82-271
						RMBJ-9	82-221
						RMBJ-10	82-133
						RMBJ-12	82-222
						RMBJ-14	82-358
						RMBJ-15	82-216
						RMBJ-16	82-224
			TWO THREE	2 1	- -		

**NORTHERN STATES POWER CO.  
MONTICELLO NUCLEAR GENERATING PLANT  
INSERVICE INSPECTION-EXAMINATION SUMMARY**

MAJOR ITEM: PIPING PRESSURE BOUNDARY

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B9.11 & B9.12	B-J	(CONT'D)					
		RECIRC RISERS					
		RISER F	ONE	-	4	RRFJ-3 RRFJ-4 RRFJ-5 RRFJ-7	-----AUGMENTED----- 82-238 82-209 82-119 82-190
			TWO	-	-		
			THREE	2	-		
		RISER G	ONE	-	4	RRGJ-3 RRGJ-4 RRGJ-5 RRGJ-7	-----AUGMENTED----- 82-267 82-207 82-208 82-280
			TWO	-	-		
			THREE	-	-		
		RISER H	ONE	1	4	RRHJ-7	82-187, 062, 062R
			TWO	2	-	RRHJ-3 RRHJ-4 RRHJ-6	-----AUGMENTED----- 82-333 82-205 82-206
			THREE	-	-		
		RISER J	ONE	-	4	RRJJ-3 RRJJ-4 RRJJ-5 RRJJ-7	-----AUGMENTED----- 82-266 82-118 82-204 82-188
	TWO	-	-				
	THREE	-	-				

**NORTHERN STATES POWER CO.  
MONTICELLO NUCLEAR GENERATING PLANT  
INSERVICE INSPECTION-EXAMINATION SUMMARY**

MAJOR ITEM: PIPING PRESSURE BOUNDARY

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B9.11 & B9.12	B-J	(CONT'D)					
		RISER K	ONE	-	4	RRKJ-3 RRKJ-4 RRKJ-5 RRKJ-7	-----AUGMENTED----- 82-278 82-203 82-117 82-189
			TWO THREE	- 2	- -		
		RISER A	ONE	-	4	RRAJ-3 RRAJ-4 RRAJ-5 RRAJ-7	-----AUGMENTED----- 82-295 82-114 82-197 82-191
			TWO THREE	- -	- -		
		RISER B	ONE	-	4	RRBJ-3 RRBJ-4 RRBJ-5 RRBJ-7	-----AUGMENTED----- 82-239 82-202 82-115 82-212
			TWO THREE	- 2	- -		
		RISER C	ONE	-	4	RRCJ-3 RRCJ-4 RRCJ-5 RRCJ-7	-----AUGMENTED----- 82-259 82-116 82-201 82-297
			TWO THREE	- -	- -		

**NORTHERN STATES POWER CO.  
MONTICELLO NUCLEAR GENERATING PLANT  
INSERVICE INSPECTION-EXAMINATION SUMMARY**

TABLE S9.1

PAGE 9 OF 14

MAJOR ITEM: PIPING PRESSURE BOUNDARY

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B9.11 & B9.12	B-J	(CONT'D)					
		RISER D	ONE	-	4	RRDJ-3 RRDJ-4 RRDJ-5 RRDJ-7	82-198 82-199 82-200 82-150
			TWO	-	-		
			THREE	-	-		
		RISER E	ONE	-	4	RREJ-3 RREJ-4 RREJ-5 RREJ-7	82-294 82-211 82-210 82-149
			TWO	-	-		
			THREE	-	-		
		HEAD VENT	ONE	1	-		
		JET PUMP INSTR	ONE	-	1	JPBJ-3 (Aug)	84-042, 051
			TWO	-	-		
			THREE	1	-		
		JET PUMP INSTR.(CANISTER)	-	-	3	Weld #1 (Aug) Weld #2 (Aug) Weld #3 (Aug)	84-041, 052 84-040, 053 84-039
		INSTRUMENT LINES FROM N11A & N11B	ONE	1	1	VIAJ-19	84-200, 214
			TWO	-	-		
	THREE	1	-				
CRD SCRAM HDR 8"	ONE	1	-				
	TWO	1	-				
	THREE	-	-				

**NORTHERN STATES POWER CO.  
MONTICELLO NUCLEAR GENERATING PLANT  
INSERVICE INSPECTION-EXAMINATION SUMMARY**

MAJOR ITEM: PIPING PRESSURE BOUNDARY

SUB ITEM	EXAM CATE. GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B9.11 & B9.12	B-J	(CONT'D)					
		CRD SCRAM HDR 6"	ONE TWO THREE	- 2 3	- - -		
		A LOOP	ONE	-	3	BASELINE EXAMS CDAJ-24, 18, 27	82-327, 328, 006
		B LOOP	ONE	-	3	CDBJ-21, 20, 15	82-005, 334, 335
		CRD SCRAM HDR 4"	ONE TWO THREE	2 2 3	- - -		
		A LOOP	ONE	-	11	BASELINE EXAMS CDAJ-1, 8, 10, 11, 12, 13, 15, 16, 36, 42, 43	82-353, 349, 350, 351, 001, 556, 355, 354, 020, 352, 348, 003
		B LOOP	ONE	-	9	CDBJ-1, 6, 7, 8, 9, 10, 28, 34, 37	82-347, 343, 344, 002, 341, 340, 342, 346, 345, 004
		SCRAM DISCHARGE VOLUME TANK	ONE TWO THREE	- - 1	- - -		
		A LOOP	ONE	-	2	BASELINE EXAMS CDAJ-54, 55	82-024, 023
		B LOOP	ONE	-	2	CDBJ-45, 46	82-022, 021



**NORTHERN STATES POWER CO.  
MONTICELLO NUCLEAR GENERATING PLANT  
INSERVICE INSPECTION-EXAMINATION SUMMARY**

MAJOR ITEM: PIPING PRESSURE BOUNDARY

SUB ITEM	EXAM CATE-GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B9.20	B-J	CRD SCRAM HEADER 12"				BASELINE EXAMS	
		A LOOP	ONE	-	11	CDAJ-17, 28, 29, 45, 33, 46, 49, 50, 51, 52, 53	82-323,012,016, 010,015,324,325, 326,008,007,013, 337
		B LOOP	ONE	-	-	CDBJ-11, 12, 22, 23, 39, 40, 43, 44	82-014,332,011,018, 009, 017, 331, 330, 336, 339
B9.21 & B9.22	B-J	<u>NOMINAL PIPE SIZE LESS THAN 4 IN.</u>					
		<u>CIRCUMFERENTIAL AND *LONGITUDINAL WELDS</u>					
		RCIC-STEAM	ONE	2	2	RSAJ-4 RSAJ-5	84-197 84-196
			TWO	-	-		
			THREE	2	-		
		STANDBY LIQUID CONTROL	ONE	-	3	CPAJ-3A (Aug) CPAJ-4 (Aug) CPAJ-6 (Aug)	84-035, 062 84-034, 063 84-036, 064
			TWO	1	-		
			THREE	-	-		
		MAIN STEAM CONDENSATE LEAKOFF	ONE	2	-		
			TWO	-	-		
			THREE	1	-		
B9.30	B-J	<u>BRANCH CONNECTION WELDS</u>					

**NORTHERN STATES POWER CO.  
MONTICELLO NUCLEAR GENERATING PLANT  
INSERVICE INSPECTION-EXAMINATION SUMMARY**

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B9.31	B-J	<u>NOMINAL PIPE SIZE GREATER THAN 2 IN.</u>					
		MAIN STEAM A	ONE	1	2	MSAJ-15, 19 (Baseline)	82-303, 304
			TWO	-	-		
			THREE	1	-		
		MAIN STEAM B	ONE	-	2	MSBJ-16, 20 (Baseline)	82-305, 306
			TWO	1	-		
			THREE	-	-		
		MAIN STEAM C	ONE	1	2	MSCJ-15, 20 (Baseline)	82-308, 307
			TWO	-	-		
			THREE	-	-		
		MAIN STEAM D	ONE	1	2	MSDJ-16, 20	82-310, 309
			TWO	-	-		
			THREE	1	-		
		RWCU	ONE	1	1	CWAJ-1	82-321
		RECIRC A	-	-	-		
RECIRC B	THREE	1	-				
RECIRC BYPASS A	TWO	2	-				
RECIRC BYPASS B	TWO	1	-				
	THREE	1	-				
RECIRC MANIFOLD	ONE	1	1	RMAJ-12	82-29, 123		
	TWO	1	-				

**NORTHERN STATES POWER CO.  
MONTICELLO NUCLEAR GENERATING PLANT  
INSERVICE INSPECTION-EXAMINATION SUMMARY**

MAJOR ITEM: PIPING PRESSURE BOUNDARY

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B9.32	B-J	<u>NOMINAL PIPE SIZE 2 IN. AND LESS</u>					
		MAIN STEAM B	THREE	1	-		
		RWCU	-	-	-		
		MAIN STEAM CONDENSATE LEAKOFF	ONE THREE	1 1	- -		
		CRD SCRAM HDR	-	-	-		
B9.40	B-J	<u>SOCKET WELDS</u>					
		HEAT VENT	ONE	4	4	50 51 58 59	84-143 84-142 84-141 84-144
			TWO THREE	5 5	- -		
		INSTRUMENT LINES	ONE	3	3	VIAJ-1 VIAJ-2 VIAJ-3	84-202 84-201 84-069
			TWO THREE	3 3	- -		
		BOTTOM HEAD DRAIN	ONE TWO THREE	3 3 4	- - -		

NORTHERN STATES POWER CO.

MONTICELLO NUCLEAR GENERATING PLANT

INSERVICE INSPECTION-EXAMINATION SUMMARY

TABLE S9.1

PAGE 14 OF 14

MAJOR ITEM: PIPING PRESSURE BOUNDARY

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B9.40	B-J	(CONT'D)					
		STANDBY LIQUID CONTROL	ONE	1	1	CPAJ-22	84-032
			TWO	1	-		
			THREE	2	-		
		MAIN STEAM CONDENSATE LEAKOFF	ONE	3	-		
			TWO	3	-		
			THREE	3	-		
		CRD SCRAM HDR DISCHARGES	ONE	3	-		
			TWO	3	-		
			THREE	3	-		
		CRD SCRAM HEADER DRAIN	ONE	-	-		
			TWO	1	-		
			THREE	1	-		
		RECIRC MANIFOLD BYPASS OF M02-65A AND M02-65B	ONE	4	4	VBBJ-8, 9, 10, 11	82-93, 90, 92, 91
	TWO	-	-				
	THREE	3	-				
RECIRC A & B DRAIN	ONE	2	2	6A, 7A	82-162, 89		
	TWO	2	-				
	THREE	3	-				

**NORTHERN STATES POWER CO.  
MONTICELLO NUCLEAR GENERATING PLANT  
INSERVICE INSPECTION-EXAMINATION SUMMARY**

MAJOR ITEM: SUPPORT MEMBERS

SUB ITEM	EXAM CATE- GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B10.10	B-K-1	<u>INTEGRALLY WELDED ATTACHMENTS AND B11.10 COMPONENT SUPPORTS</u>  MAIN STEAM A  MAIN STEAM B  MAIN STEAM C  MAIN STEAM D  FEEDWATER A & B  FEEDWATER A  FEEDWATER C & D  FEEDWATER D	ONE TWO THREE  ONE TWO THREE  ONE TWO THREE  ONE TWO THREE  ONE TWO THREE  ONE TWO THREE  ONE TWO THREE	1 - 1  - 2 -  - 1 1  - 1 1  - 2 1  1 2 -  1 - -	- - -  - - -  - - -  - - -  - - -  - - -  - - -		

Form 9-0033, Rev. 0 (M&SP 5.2)  
**NORTHERN STATES POWER CO.**  
**MONTICELLO NUCLEAR GENERATING PLANT**  
**INSERVICE INSPECTION-EXAMINATION SUMMARY**

TABLE S10.1  
 PAGE 2 OF 2  
 MAJOR ITEM: SUPPORT MEMBERS

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B10.10	B-K-1	(CONT'D)					
		RWCU	ONE TWO THREE	- - 1	- - -		
		RHR TW36	ONE TWO THREE	- 1 -	- - -		
		RECIRC A	ONE TWO THREE	3 2 3	3 - -	RCAK-16, 18 RCAK-33	82-42, 63, 41, 64 82-40, 40R, 176
		RECIRC B	ONE TWO THREE	2 2 4	2 - -	RCBK-10A, 14	82-36, 66, 35, 68
		RECIRC MANIFOLD	ONE TWO THREE	4 3 3	4 - -	RMAK-13, 13B RMAK-17A, 17B	82-47, 163, 49, 361 82-154, 175, 157, 164
		SCRAM DISCHARGE	ONE TWO THREE	1 - -	- - -		
B10.20	B-K-1	<u>PUMPS</u>	-	-	-		
B10.30	B-K-1	<u>VALVES</u>	-	-	-		

Form 9-0033, Rev. 0 (M&SP 5.2)  
**NORTHERN STATES POWER CO.**  
**MONTICELLO NUCLEAR GENERATING PLANT**  
**INSERVICE INSPECTION-EXAMINATION SUMMARY**

TABLE S11.1  
 PAGE 1 OF 5  
 MAJOR ITEM: COMPONENT SUPPORTS

SUB ITEM	EXAM CATE-GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B11.10	B-K-2	<u>COMPONENT SUPPORTS</u>					
		MAIN STEAM A	ONE TWO THREE	2 - 2	- - -		
		MAIN STEAM B	ONE TWO THREE	- 2 -	- - -		
		MAIN STEAM C	ONE TWO THREE	2 - -	- - -		
		MAIN STEAM D	ONE TWO THREE	1 2 1	- - -		
		FEEDWATER A	ONE TWO THREE	2 - 1	- - -		
		FEEDWATER A	ONE TWO THREE	1 - 2	- - -		
		FEEDWATER D	ONE TWO THREE	1 - 2	- - -		
		FEEDWATER D	ONE TWO THREE	1 1 1	- - -		
		CORE SPRAY A	ONE TWO THREE	1 1 -	- - -	CSAK-15	84-111

Form 9-0033, Rev. 0 (M&SP 5.2)  
**NORTHERN STATES POWER CO.**  
**MONTICELLO NUCLEAR GENERATING PLANT**  
**INSERVICE INSPECTION-EXAMINATION SUMMARY**

TABLE S11.1  
PAGE 2 OF 5  
MAJOR ITEM: COMPONENT SUPPORTS

SUB ITEM	EXAM CATE-GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B11.10	B-K-2	(CONT'D)					
		CORE SPRAY B	ONE TWO THREE	1 - 1	1 - -	CSBK-6	84-112
		HPCI-STEAM	ONE TWO THREE	- - 1	- - -		
		RWCU	ONE TWO THREE	- - 2	- - -		
		RHR REW10	ONE TWO THREE	- 4 2	- - -		
		RHR TW20	ONE TWO THREE	- 2 4	- - -		
		RHR TW30	ONE TWO THREE	2 3 -	2 - -	RHCK-10 RHCK-9	84-261 84-260
		RHR TW36	ONE TWO THREE	- 1 -	- - -		
		RCIC-STEAM	ONE TWO THREE	1 1 1	1 - -	RSAK-6	84-217



Form 9-0033, Rev. 0 (M&SP 5.2)  
**NORTHERN STATES POWER CO.**  
**MONTICELLO NUCLEAR GENERATING PLANT**  
**INSERVICE INSPECTION-EXAMINATION SUMMARY**

**TABLE S11.1**  
**PAGE 3 OF 5**  
**MAJOR ITEM: COMPONENT SUPPORTS**

SUB ITEM	EXAM CATE-GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B11.10	B-K-2	(CONT'D)					
		RECIRC A	ONE	4	4	RCAK-6, 34 PHA-5 PSSA-5	82-043, 039 82-44 82-48
			TWO	4	-		
			THREE	4	-		
		RECIRC B	ONE	4	4	RCBK-10, 12 PHB-6 PSSB-5	82-37, 37R, 38 82-360, 360R 82-359
			TWO	4	-		
			THREE	4	-		
		RECIRC BYPASS A & B	ONE	1	1	RBBK-14	82-75
			TWO	-	-		
			THREE	1	-		
		RECIRC MANIFOLD A & B	ONE	4	4	RMAK-11, 13A, 17 RMBK-17	82-45, 46, 159 82-158
			TWO	3	-		
			THREE	3	-		
		RECIRC RISERS MANIFOLD A & B	ONE	3	3	RRJK-6 RRKK-6 RRDK-6	82-50, 50R 82-51 82-155
			TWO	3	-		
			THREE	4	-		
		HEAD VENT LINE	ONE	1	1	HVAK-21	84-218
			TWO	-	-		
			THREE	1	-		
		BOTTOM HEAD DRAIN	ONE	3	-		
			TWO	2	-		
			THREE	-	-		

Form 9-0033, Rev. 0 (M&SP 5.2)  
**NORTHERN STATES POWER CO.**  
**MONTICELLO NUCLEAR GENERATING PLANT**  
**INSERVICE INSPECTION-EXAMINATION SUMMARY**

TABLE S11.1  
PAGE 4 OF 5  
MAJOR ITEM: COMPONENT SUPPORTS

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B11.10	B-K-2	(CONT'D)					
		STANDBY LIQUID CONTROL	ONE	1	1	CPAK-20	84-219
			TWO	1	-		
			THREE	-	-		
		CRD SCRAM HEADER A	ONE	4	-		
			TWO	5	-		
			THREE	5	-		
		CRD SCRAM HEADER B	ONE	5	-		
			TWO	5	-		
			THREE	5	-		
		CRD SCRAM HEADER DISCHARGES A & B	ONE	4	-		
			TWO	7	-		
			THREE	7	-		
		CRD SCRAM HEADER DRAIN	ONE	1	-		
	TWO	-	-				
	THREE	-	-				
SCRAM DISCHARGE VOLUME TANK	ONE	1	-				
	TWO	-	-				
	THREE	-	-				
RECIRC VALVE BYPASS A&B	ONE	1	1	VBBK-6A	82-156		
	TWO	1	-				
	THREE	-	-				
B11.20	B-K-2	<u>PUMPS</u>					
		<u>COMPONENT SUPPORTS</u>	-	-	-		

Form 9-0033, Rev. 0 (M&SP 5.2)  
**NORTHERN STATES POWER CO.**  
**MONTICELLO NUCLEAR GENERATING PLANT**  
**INSERVICE INSPECTION-EXAMINATION SUMMARY**

TABLE S11.1

PAGE 5 OF 5

MAJOR ITEM: COMPONENT SUPPORTS

SUB ITEM	EXAM CATE- GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B11.30	B-K-2	<u>VALVES</u>  <u>COMPONENT SUPPORTS</u>	-	-	-		

**NORTHERN STATES POWER CO.  
MONTICELLO NUCLEAR GENERATING PLANT  
INSERVICE INSPECTION-EXAMINATION SUMMARY**

TABLE S12.1

PAGE 1 OF 1

MAJOR ITEM: PUMP CASING & VALVE BODIES

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
		<u>PUMPS</u>					
B12.10	B-L-1	<u>PUMP CASING WELDS</u>	-	-	-		
B12.20	B-L-1	<u>PUMP CASING</u>					
		RECIRC PUMPS A & B	-	-	-		
		<u>VALVES</u>					
B12.10	B-L-1	<u>VALVE BODY WELDS</u>	-	-	-		
B12.20	B-L-1	<u>VALVES BODY, EXCEEDING 4 IN. NOMINAL PIPE SIZE</u>					
		ATWOOD MORRILL GLOBE VALVES	THREE	-	-		
		TARGET ROCK RELIEF VALVES	THREE	-	-		
		ANCHOR CHECK VALVES	THREE	-	-		
		ATWOOD MORRILL CHECK VALVE	THREE	-	-		
		ROCKWELL CHECK VALVE	THREE	-	-		
		ANCHOR GATE VALVE	THREE	-	-		
		CRANE CHAPMAN GATE VALVE	-	-	-		

**NORTHERN STATES POWER CO.  
MONTICELLO NUCLEAR GENERATING PLANT  
INSERVICE INSPECTION-EXAMINATION SUMMARY**

TABLE S13.1

PAGE 1 OF 1

MAJOR ITEM: REACTOR VESSEL INTERIOR

SUB ITEM	EXAM CATE-GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B13.10	B-N-1	<u>REACTOR VESSEL</u> <u>VESSEL INTERIOR</u>	ONE	*	*	Appendix H Core Spray Appendix I Feedwater *Inspected areas above and below the reactor core that is made accessible for examination by the removal of components during normal refueling.	84-149 84-148
B13.20 & B13.30	B-N-1	<u>INTERIOR ATTACHMENTS &amp; CORE SUPPORT STRUCTURES</u>	TWO THREE	- -	- -		
			ONE	*	*	Appendix J Shroud Supports *Inspected visually accessible attachments and supports	84-150
			TWO THREE	- -	- -		
B13.30	B-N-1	<u>REACTOR VESSEL (PWR)</u> <u>CORE SUPPORT STRUCTURES</u>	-	-	-		

**NORTHERN STATES POWER CO.  
MONTICELLO NUCLEAR GENERATING PLANT  
INSERVICE INSPECTION-EXAMINATION SUMMARY**

TABLE S14.1

PAGE 1 OF 1

MAJOR ITEM: CONTROL ROD HOUSING WELDS

SUB ITEM	EXAM CATE- GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B14.10	B-0	<u>REACTOR VESSEL</u>  <u>WELDS IN CRD HOUSING</u>	ONE TWO THREE	1 1 1	- - -		

Form 9-0033, Rev. 0 (M&SP 5.2)  
**NORTHERN STATES POWER CO.**  
**MONTICELLO NUCLEAR GENERATING PLANT**  
**INSERVICE INSPECTION—EXAMINATION SUMMARY**

TABLE S15.1  
PAGE 1 OF 1  
**MAJOR ITEM: PRESSURE RETAINING COMPONENTS**

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
B15.10	B-P	REACTOR VESSEL	-	-	-		
B15.50	B-P	PIPING	-	-	-		
B15.60	B-P	PUMPS	-	-	-		
B15.70	B-P	VALVES	-	-	-		
B15.11	B-P	REACTOR VESSEL	-	-	-		
B15.51	B-P	PIPING	-	-	-		
B15.61	B-P	PUMPS	-	-	-		
B15.71	B-P	VALVES	-	-	-		
B15.20	B-P	<u>PRESSURIZER</u>	-	-	-		
B15.30	B-P	<u>STEAM GENERATORS</u>	-	-	-		
B15.40	B-P	<u>HEAT EXCHANGERS</u>	-	-	-		

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	ISI INDICATIONS	EXAMINATION LIMITATIONS
<u>REACTOR VESSEL</u>							
<u>B3.10 NOZZLE TO VESSEL WELDS</u>							
Heat Vent (N7)	15	UT	HVAD-1	84-140	Low Level ID Clad Roll	None	None
				84-147 84-145		None S-1, 360°	No S-2 Config. No S-2 Config.
Core Spray (N5B)	6B	UT	CSBD-1	84-191 84-190 84-187	S-1 IDGEO S-2 IDGEO	None None S-1, IDGeo, 30%	No S-2, Nozzle No S-2, Nozzle No S-2, Nozzle
CRD Return (N9)	10	UT	CRAD-1	84-192 84-189 84-198	S-1, Spot, 50%	None S-1, IDGeo, 45% None	None No S-2 Config. No S-2 Config.
Jet Pump Instrument Nozzle (N8A)	16	UT	JPAD-1	84-194 84-238 84-237	None	None None None	None S1-4 Limited 5:00 to 7:00 Insulation S1-4 Limited 5:00 to 7:00 Insulation



COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	ISI INDICATIONS	EXAMINATION LIMITATIONS
<u>B3.20 NOZZLE INSIDE RADIUS SECTION</u>	15	UT	HVAD-1	84-146	Low Level ID Clad Roll	S-1 Bore Geo >100% 360°	None
				84-155		S-1 CW Bore Geo 100% 360° S-2 CCW Bore Geo 50% 360°	None
	6B	UT	CSBD-1	84-193	S-1, IDGeo	S-1 Bore Geo 100% 360°	S-1 Limited 3:00, 9:00, 12:00 Insulation None
				84-158		S-2, IDGeo S-1 Bore Geo 25% 360° S-2 Bore Geo 25% 360° S-3 Bore Geo 100% 360°	
	10	UT	CRAD-1	84-168	S-1 Spot 50%	S-3, Bore Geo 35% Int. S-4 Bore Geo 35% Int.	S1-4 Limited 9:00 Insulation None
				84-240		S-3 ID Geo Int. 50% S-4 ID Geo Int. 30%	
	16	UT	JPAD-1	84-241	None	S-1 IDGeo Int. 360° 30%	Scans Limited 4:30 to 7:30 Insulation None
				84-239		S-3 ID. Geo. Int. 360° 50% S-4 ID. Geo. Int. 360° 50%	

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	ISI INDICATIONS	EXAMINATION LIMITATIONS
<u>B3.90 &amp; B3.100</u> Nozzle Inside Radius							
Feedwater Nozzle "A"	5A	UT	N4A	84-160	None	S-3 Bore Geo >100% - 360°	None
Feedwater Nozzle "A"	5A	UT	N4A	84-167		S-4 Bore Geo >100% - 360° S-3,4 Bore Geo 35% 360° Intr.	None
Feedwater Nozzle "B"	5A	UT	N4B	84-151	S-1 Clad Noise	S-3,4 Bore Geo >100% 360°	S-1 Limited 2:00 to 4:00 & 8:00 to 10:00 due to Insulation
				84-153	S-2 Spot Ind.	S-3,4 Bore Geo <100% 360°	None
Feedwater Nozzle "C"	5B	UT	N4C	84-157	Spot Ind. 4:00, 6:00, 9:00	S-3,4 Bore Geo >100% 360°	S-1 Limited 2:00 to 4:00 Insulation
				84-159		S-3,4 Bore Geo >100% 360° Intr	Scans limited at 9:00 for 1" due to the thermocouple
Feedwater Nozzle "D"	5B	UT	N4D	84-152	None	S-3,4 Bore Geo >100% 360° Intr	S-1 Limited 2:00 to 4:00 8:00 to 10:00 due to Insulation
				84-154		S-3,4 Bore Geo <100% 360° Intr	None

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	ISI INDICATIONS	EXAMINATION LIMITATIONS
<b>B5.10 NOZZLE TO SAFE END WELDS</b>							
Head Vent(N7)	15	UT	HVAF-2	84-134	S-1, IDGeo 70%	S-1, IDGeo 10% 360°	No S-2, Flange
		PT		84-135	None	None	None
Head Spare	14	UT	HSBF-2	84-138	S-1, Geo 70%	S-2, ID Geo 40% Int.	No S-1, 1S & 2S Flange
		PT		84-137	None	None	None
Core Spray(N5B)	6B	UT	CSBF-2	84-236	None	None	None
		PT		84-181	None	None	None
CRD Return(N9)	10	UT	CRAF-2	84-166	None	S-1, IDGeo 40% S-3, ODGeo 30% S-1S, ODGeo 25% S-2S, ODGeo 25% S-3S, IDGeo 30% S-4S, IDGeo 30%	No S-2, Config.
		PT		84-162	None	None	None
Stand By Liquid Control	17	UT	CPAF-2	84-061	S-1, IDGeo 60%	S-1, IDGeo 25% 360° S-2, IDGeo 20% 360°	None
		PT		84-033	None	None	None
Jet Pump Instrumentation B (NFB)	16	UT	JPBF-2	84-050	S-2, Geo, 50%	S-2, ID Geo 25% S-3, ID Geo 15% CCW. 5:00to6:00 ID Geo 15% CCW. 5:00to8:00 ID Geo 30%	No S-5S & S-7S, Config.
		PT		84-043	None	None	None

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	ISI INDICATIONS	EXAMINATION LIMITATIONS
Instrumentation Lines 'A' (N11A)	18	UT	VIAF-2	84-075	S-1,Geo 25%	S-1,ID Geo 15% S-1,OD Geo 25% S-2,ID Geo 20% S-2,OD Geo 25%	None
		PT		84-070	None	None	None
'B' (N11B)	18A	UT	VIBF-2	84-074	S-1,Geo 20%	S-1,ID Geo 30%  S-2,ID Geo 20% S-2,OD Geo 25%	None
		PT		84-071	None	None	None
"A" (N12A)	19	UT	VICF-2	84-164	S-1,ODGeo 25% S-2,ODGeo 30%	None	None
		PT		84-161	None	None	None
"B" (N12B)	19	UT	VIDF-2	84-165	None	None	None
		PT		84-163	None	None	None
<u>B5.50 Safe-end Welds</u>							
Core Spray 'A' (TW7-8"EF)	6A	UT	CSP-90-7	84-220	S-1,IDGeo 50% ODGeo 60% S-2,IDGeo 55%	None	None
		PT		84-259	None	None	None
		UT	CSAF-14	84-096	S-1&2,Geo	S-1,IDGeo, 20% - 360° S-3,ODGeo 20% spot	S-2 B.E.,elbow inside radius
		PT		84-103	None	S-4,ODGeo 20% None	None

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	ISI INDICATIONS	EXAMINATION LIMITATIONS
Core Spray "A"		UT	CSAF-18	84-094	S-1&2, Geo	S-1, ID, ODGeo 35% - 360° S-2, ID, ODGeo 35% - 360° S-3, ODGeo. < 20% - 360°	S-2 B.E. elbow inside Radius
		PT		84-098	None	None	None
Core Spray "B" (TW11-8"EF)	6B	UT	CSP-270-7	84-184	S-1, IDGeo 90% OD, Geo 30%	S-1, ID, ODGeo 25% - 360° S-2, ID, ODGeo 20% - 360° S-3, 4, 1s, 2s Spot ID @3:00	None
		PT		84-182	None	None	None
		UT	CSP-270-9	84-213	S-1, IDGeo 60% S-2, IDGeo 105%	None	None
		PT		84-156	None	None	None
		UT	CSBF-12	84-093	S-1, S-2 Geo	S-1, IDGeo 20% 9:00 to 12:00 S-2, ODGeo 20% - 360° S-3, ODGeo 30% S-4s, ODGeo 20% - 360°	S-1 B.E. Elbow Inside Radius
		PT		84-102	None	None	None

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	ISI INDICATIONS	EXAMINATION LIMITATIONS
Core Spray "B" cont'd		UT	CSBF-16	84-105	S-1, S-2 Geo	S-1, ID/ODGeo 25/35%-360° S-2, ID/ODGeo 25/35%-360° S-3, ID/ODGeo 20/30%-360° S-4, ODGeo 20-30% @10:00 S-1s, ODGeo 20-25%-360° S-2s, ID/ODGeo 20/30%-360° S-3s, ODGeo 25-35%-360° S-4s, ODGeo 25-35%-360°	None
HPCI STEAM (PS 18-8"EF)	7	PT		84-101	None	None	None
		UT	PSAF-2B	84-113	None	S-1, OD Geo. 35% S-2, ID Geo. 35% S-2, OD Geo. 40% S-3, ID Geo. 25% S-3, OD Geo. 35% S-4, ID Geo. 25% S-4, OD Geo. 35% S-1s, OD Geo. 30% S-2s, OD Geo. 30% S-3s, ID Geo. 25% S-3s, OD Geo. 35% S-4s, ID Geo. 25% S-4s, OD Geo. 35%	None
		PT		84-109	None	None	None

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	ISI INDICATIONS	EXAMINATION LIMITATIONS
HDCI Steam cont'd	7	UT	PSAF-2C	84-114	S-1, ID, Geo.60%	S-1, ID Geo.100% S-1, OD Geo.100% S-2, OD Geo.35% S-3, OD Geo.25% S-4, ID Geo.25% S-4, OD Geo.25% S-1s, OD Geo.30% 9:00 to 12:00	None
		PT		84-110	None	Arc Strike at 7:00	None
		PT		84-110R		None Arc Strike Buffered Out	None
Residual Heat Removal (REW20-16"EF)	11B	UT	RHBF-20	84-089	S-1, ID Geo.45%	S-2, ID Geo 30% S-3, OD Geo 15% 12:00 S-2s, Spot, 15% 10:00 S-3s, OD Geo 20% 9:00 S-4s, 3 Linears 20% 11:00	None
		PT		84-085	None	None	None
		PT		84-082	None	None	None
		UT		84-087	S-1, ID/OD Geo.25%	S-1, ID/OD Geo 30% - 360° S-2, Spot At 12:00 & 3:00 25%	None
(REW30-16"DC)	11C	UT	RHCF-20	84-087	S-1, ID/OD Geo.25%	S-1, ID/OD Geo 30% - 360° S-2, Spot At 12:00 & 3:00 25%	None

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	ISI INDICATIONS	EXAMINATION LIMITATIONS
(REW30-16"DC)					S-2, ID/OD Geo 60%	S-3, Spot At 12:00 20% S-4, Linear at 6:00 20% S-2s Linear at 4:00-12:00 20%	
		PT		84-079	None	None	None
		PT	RHCF-23	84-080	None	None	None
B7.70 Bolts, Studs, and Nuts (Valve)							
Core Spray "A"	6A	VT	POS-1758	84-108	None	None	None
		VT	A014-13B	84-107 84-107R	None	Loose Nut None, tightened Nut	None
Core Spray "B"	6B	VT	M0-1753	84-172	None	None	None
High Pressure Coolant Injection - Steam	7	VT	M0-2035	84-128	None	None	None
Reactor Water Clean-Up	9	VT	M02398	84-183	None	None	None
Residual Heat Removal (REW10)	11A	VT	M02029	84-216	None	None	None
(REW30)	11C	VT	M02014	84-169	None	None	None
(TW-36)	11D	VT	M02026	84-173	N/A	None	None
Standby Liquid Control	22	VT	XP-8	84-215	N/A	None	None



COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	ISI INDICATIONS	EXAMINATION LIMITATIONS
B8.10 <u>Integrally Welded Attachments</u> Rx Support Skirt  120° - 180°	Fig S	MT	HCAH-2	84-257  84-257F	N/A	9 Linears between 170° - 180° None, Linears Removed	None
B9.11 & B9.12 <u>Circumferential &amp; Longitudinal Welds</u>							
Core Spray "A" (TW7-8"ED)	6A	UT	CSAJ-19	84-180	NONE	S-2, ID Geo. 25% - 360°	No S-1 due to location of penetration
(TW7-8"EF)		MT		84-179	N/A	None	Exam limited on upstream side of weld due to penetration
		UT	CSAJ-16	84-095	S-2, GEO	S-2, OD Geo. 20% - 360° S-3, OD Geo. 20% - 360° S-3s, OD Geo. 25% - 360° S-4s, OD Geo. 20% - 360°	No S-1, S-1s, S-2s Config. (Valve)
		PT		84-104	N/A	None	None

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	ISI INDICATIONS	EXAMINATION LIMITATIONS
Core Spray cont'd		UT	CSAJ-17	84-106	S-1,Geo.	S-1,OD Geo. 25-35%-360° S-4,OD Geo. 20-25%,@4:00 S-1s,OD Geo. 25-35%-360° S-2s,OD Geo. 25-35%-360°	No S-2,S-3s, S-4s,Config. (Valve)
		PT		84-097	N/A	None	None
Core Spray "B" (TW11-8"ED)	6B	UT	CSBJ-21	84-170	NONE	S-1,S-2,ID OD Geo.50% intermittent S-3,ID Geo. 30% - 12:00 S-4,OD Geo. 30% - 4:30	None
		MT		84-175	N/A	None	None
		UT	CSBJ-22	84-171	NONE	S-2,ID,OD Geo 50% intermittent S-4,ID,OD Geo 20% intermittent	No S-1 due to Config.(valve)
		MT		84-174	N/A	None	None
(TW11-8"EF)		UT	CSBJ-13	84-092	None	OD Geo. 20% @9:00	No S-1,S-1s, S-2s,Config. (Valve)
		PT		84-099	None	None	None

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	ISI INDICATIONS	EXAMINATION LIMITATIONS
(TW11-8"EF)		UT	CSBJ-14	84-091	S-1,Geo.	S-1,OD Geo. 30% - 360° S-4,OD Geo.. 20% - 4:00 S-1s,OD Geo. 40% - 360° S-2s,OD Geo. 30% - 360°	No S-2,S-3s, S-4s,Config. (Valve)
Residual Heat Removal (RE10-18"ED)		PT		84-100	None	None	None
	11A	UT	RHAJ-25	84-243	MISMATCH	None	None
		MT		84-195	N/A	None	None
	11A	UT	RHAJ-26	84-245	MISMATCH	S-1,ID/OD Geo 130%/60%-360° S-2,ID/OD Geo. 100%/25%-360°	None
		MT		84-178	N/A	None	None
		UT	RHAJ-27	84-244	N/A	None	No S-2 due to penetration S-3,S-4 limited because of penetration
(TW20-16"DB)	11B	MT		84-242	N/A	None	None
		UT	RHBJ-21	84-090	None	S-2 Linear 20% @11:00 S-3,ID.Geo. 15% @10:00 S-4s Linear 15% @11:00	No S-1,S-1s, S-2s due to Config.

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	ISI INDICATIONS	EXAMINATION LIMITATIONS
(TW20-16"DB)		PT		84-084	None	None	None
		PT	RHBJ-22	84-083	None	None	as welded condition
(TW30-16"DB)	11C	UT	RHCJ-21	84-088	None	S-2, Spot Ind. 15% @ 11:00 ID Geo. 15%-360° S-3 & 4, Spot, Ind 15% @ 9:00 ID Geo 15%-360° S-3s Spot Ind. 20% 11:00 ID Geo. 15%-360° S-4s, Multiple Spot Indications 15%-12:00 to 3:00 ID Geo. 10%-360°	No S-1, S-1s, S-2s due to Config.
		PT		84-086	None	None	None
		PT	RHCJ-22	84-081	None	None	As welded condition
RHR (TW36-4"ED)	11D	UT	RHDJ-2	84-139	None	S-2, ID Geo. 40% 360° Inter.	No S-1 due to flange
		PT		84-136	None	None	None
Jet Pump Instrumentation "B"	16	UT	JPBJ-3	84-051	ID, OD, Geo. 75%	S-2, 3, 4 ID/OD Geo. 20%/30%-360° S-9, 10, 11, 12 ID/OD Geo. 15%/25%-360°	No S-1 due to config.
		PT		84-042	None	None	None

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	ISI INDICATIONS	EXAMINATION LIMITATIONS
Jet Pump Instrumentation *NOTE: Not Specifically Listed Under Class 1 or Class 2	16	UT	Weld #1	84-052	N/A	S-1,2, ID Geo. 25%-360° Inter.	
		PT		84-041	N/A	S-3, S-4 Linear Axial indicat. 25%-360° Inter.	None
		UT	Weld #2	84-053	N/A	S-2, OD. Geo. 20% @8:00	None
		PT		84-040	N/A	None	None
Instrumentation Lines(N11A)	18	PT	Weld #3	84-039	N/A	None	None
		UT	VIAJ-19	84-214	N/A	S-1,3,4,1s, 2s,3s,4s,OD Geo 20%-360° Inter.	No Scan on weld crown due to roughness S-2 limited to 1" due to Config.
<u>B9.21 &amp; B9.22 Circumferential and Longitudinal Welds</u>		PT		84-200	N/A	None	None
Reactor Core Injection Coolant-Steam (PS17-3"ED)	12	MT	RSAJ-4	84-197	NONE	None	None
		MT	RSAJ-5	84-196	NONE	None	None
<u>B9.40 Socket Welds</u>							
Head Vent (V15-2"ED)	15	MT	50	84-143	N/A	None	None
		MT	51	84-142	N/A	None	None
		MT	58	84-141	N/A	None	None
		MT	59	84-144	N/A	None	None

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	ISI INDICATIONS	EXAMINATION LIMITATIONS
Instrumentation Lines	18	PT	VIAJ-3	84-069	None	None	None
		PT	VIAJ-2	84-201	None	None	None
		PT	VIAJ-1	84-202	None	None	None
Standby Liquid Control (CH2-1½"EF)	22	PT	CPAJ-22	84-032	None	None	None
<u>B11.10 Component Supports</u>							
Core Spray "A" (TW7-8"EF)	6A	VT	CSAK-15	84-111	None	None	None
Core Spray "B" (TW11-8"EF)	6B	VT	CSBK-6	84-112	None	None	None
Residual Heat Removal (TW30-16"DB)	11C	VT	RHCK-9	84-260	None	None	None
		VT	RHCK-10	84-261	None	None	None
Reactor Core Injection Coolant-Steam (PS17-3"ED)	12	VT	RS AK-6	84-217	N/A	None	None
Head Vent (V15-2"ED)	15	VT	HVAK-21	84-218	N/A	Loose Nut	Hangar Drawing Not Available
				84-218R		Loose nut tightened, bent hangar rod, NOTE: Bent hangar rod was evaluated and accepted as is.	
Standby Liquid Control (CH2-1½")	22	VT	CPAK-20	84-219	None	None	Hangar drawing not available

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	ISI INDICATIONS	EXAMINATION LIMITATIONS
<u>B13.10 Vessel Interior</u>							
Core Spray System		VT	Appendix H	84-149	None	None	None
Feedwater System		VT	Appendix I	84-148	None	N4C&N4D crack indications on sparger nozzles	None
<u>B13.2 Vessel Interior Attachments</u>							
Shroud Support welds		VT	Appendix J	84-150	None	None	None

APPENDIX B

ASME CLASS 2 EXAMINATIONS



**NORTHERN STATES POWER CO.  
MONTICELLO NUCLEAR GENERATING PLANT  
INSERVICE INSPECTION-EXAMINATION SUMMARY**

MAJOR ITEM: VESSEL WELDS

SUB ITEM	EXAM CATE-GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C1.10	C-A	<u>SHELL CIRCUMFERENTIAL WELDS</u>  RHR HEAT EXCHANGERS E-200A  E-200B	- ONE TWO THREE	(3) 1 1 1	- 1 - -	- W-1 - -	MULTIPLE VESSELS 84-037, 177 - -
C1.20	C-A	<u>HEAD CIRCUMFERENTIAL WELDS</u>  RHR HEAT EXCHANGERS E-200A E-200B	- TWO	(1) - 1	- - -	- - -	- - -
C1.30	C-A	<u>TUBE SHEET TO SHELL WELDS</u>	-	-	-	-	-

**NORTHERN STATES POWER CO.  
MONTICELLO NUCLEAR GENERATING PLANT  
INSERVICE INSPECTION-EXAMINATION SUMMARY**

MAJOR ITEM: NOZZLE WELDS

SUB ITEM	EXAM CATE- GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C2.10	C-B	<u>NOZZLES IN VESSELS 1/2 IN. OR LESS IN NOMINAL THICKNESS</u>	-	-	-	-	-
C2.20	C-B	<u>NOZZLES IN VESSELS OVER 1/2 IN. IN NOMINAL THICKNESS</u>  RHR HEAT EXCHANGERS E-200A  E-200B	ONE TWO TWO THREE	1 1 1 1	1 - - -	W-7 - - -	84-027, 84-176

Form 9-0033, Rev.0 (M&SP 5.2)  
**NORTHERN STATES POWER CO.**  
**MONTICELLO NUCLEAR GENERATING PLANT**  
**INSERVICE INSPECTION-EXAMINATION SUMMARY**

TABLE S3.2  
PAGE 1 OF 9  
SUPPORT MEMBERS

MAJOR ITEM:

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C3.10	C-C	<u>INTEGRALLY WELDED SUPPORT ATTACHMENTS</u>  RHR HEAT EXCHANGERS E-200A  E-200B	-  ONE TWO THREE	-  (3) 1 1 1	2	Support "A" & "B"	84-044
C3.20	C-C	<u>COMPONENT SUPPORTS</u>  RHR HEAT EXCHANGERS E-200A  E-200B	ONE TWO TWO THREE	2 1 1 2	2	Support "A" & "B"	84-044
C3.40	C-C	<u>SUPPORTS-MECHANICAL AND HYDRAULIC</u>  PIPING	-  -	-  -			
C3.40	C-C	<u>*INTEGRALLY WELDED SUPPORT ATTACHMENTS</u>  MAIN STEAM A  MAIN STEAM B  MAIN STEAM C	ONE TWO THREE  ONE TWO THREE  ONE TWO THREE	1 - -  - 1 -  - 1 -			*INCLUDES THE CORRESPONDING C3.50 (VT-3) & C3.60 (VT-4) EXAMINATIONS WHERE APPLICABLE

Form 9-0033, Rev. 0 (M&SP 5.2)  
**NORTHERN STATES POWER CO.**  
**MONTICELLO NUCLEAR GENERATING PLANT**  
**INSERVICE INSPECTION-EXAMINATION SUMMARY**

TABLE S3.2  
PAGE 2 OF 9  
SUPPORT MEMBERS

MAJOR ITEM:

SUB ITEM	EXAM CATE-GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C3.40	C-C	(CONTINUED)					
		MAIN STEAM D	ONE TWO THREE	- - 1			
		SUPPLY TO STEAM SEAL SYSTEM	ONE TWO THREE	- - 1			
		HPCI WATER DISCHARGE	ONE TWO THREE	1 1 -	1	CIAK-31	82-101
		HPCI STEAM	ONE TWO THREE	- 1 1			
		HPCI STEAM DISCHARGE	ONE TWO THREE	- 2 -			
		CORE SPRAY A DISCHARGE	ONE TWO THREE	1 1 -	1	CSAK-35	84-067, 067R
		CORE SPRAY B DISCHARGE	ONE TWO THREE	- - 2			
REACTOR WATER FROM SKIMMER SYSTEM	ONE TWO THREE	1 1 1					

Form 9-0033, Rev. 0 (M&SP 5.2)  
**NORTHERN STATES POWER CO.**  
**MONTICELLO NUCLEAR GENERATING PLANT**  
**INSERVICE INSPECTION-EXAMINATION SUMMARY**

TABLE S3.2  
PAGE 3 OF 9  
MAJOR ITEM: \_\_\_\_\_ SUPPORT MEMBERS \_\_\_\_\_

SUB ITEM	EXAM CATE- GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C3.40	C-C	<u>(CONTINUED)</u>  RHR SERVICE WATER  RHR SUCTION A  RHR DISCHARGE A  RHR SUCTION B  RHR DISCHARGE B TW19-10"GE  TW20-16"GE  CONTAINMENT SPRAY A & B	ONE TWO THREE  ONE TWO THREE  ONE TWO THREE  ONE TWO THREE  ONE TWO THREE	1 - -  - 2 -  - - 2  - 1 -  - - 1  1 1 2	1	SWAK-42	82-292, 109, 109R

**NORTHERN STATES POWER CO.  
MONTICELLO NUCLEAR GENERATING PLANT  
INSERVICE INSPECTION-EXAMINATION SUMMARY**

SUB ITEM	EXAM CATE-GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C3.50	C-C	<p><u>*COMPONENT SUPPORTS</u></p> <p>MAIN STEAM A</p> <p>MAIN STEAM B</p> <p>MAIN STEAM C</p> <p>MAIN STEAM D</p> <p>SUPPLY TO STEAM SEAL SYSTEM</p> <p>    PS11-6"ED</p> <p>    PS14-6"ED</p> <p>    PS7-10"ED</p> <p>    PS7-8"ED</p> <p>MAIN STEAM EQUALIZER HDR</p>	<p>ONE TWO THREE</p> <p>ONE TWO THREE</p> <p>ONE TWO THREE</p> <p>ONE TWO THREE</p> <p>ONE TWO THREE</p> <p>ONE TWO THREE</p> <p>ONE TWO THREE</p> <p>ONE TWO THREE</p> <p>ONE TWO THREE</p> <p>ONE TWO THREE</p>	<p>2 2 2</p> <p>2 2 2</p> <p>2 2 2</p> <p>2 2 2</p> <p>2 2 2</p> <p>2 2 3</p> <p>3 3 3</p> <p>2</p> <p>- 2 1</p>			<p>*INCLUDES THE CORRESPONDING C3.60 (VT-4) EXAMINATIONS WHERE APPLICABLE</p>

**NORTHERN STATES POWER CO.  
MONTICELLO NUCLEAR GENERATING PLANT  
INSERVICE INSPECTION-EXAMINATION SUMMARY**

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C3.50	C-C	(CONTINUED)					
		HPCI WATER DISCHARGE	ONE	6	7	TWH-38, CIAK-59 SR-69, SS-35 CIAK-26, 27A, 28	82-106, 82-086 84-011 84-019, 012, 013
			TWO	6			
			THREE	5			
		HPCI WATER SUCTION	ONE	-			
			TWO	2			
			THREE	2			
		HPCI STEAM	ONE	3	3	TDAK-23, 25, 26	82-108, 107, 103
			TWO	5			
			THREE	5			
		HPCI STEAM DISCHARGE	ONE	2			
			TWO	4			
			THREE	-			
		CORE SPRAY A SUCTION	ONE	2	2	TWH-53, 54	84-006, 010
	TWO	2					
	THREE	1					
CORE SPRAY A DISCHARGE	ONE	5	4	TWH-81, 82 CSAK-31, 32A	84-009, 008 84-066, 066R, 068		
	TWO	6					
	THREE	5					
CORE SPRAY B SUCTION	ONE	1	1	TWH-55	84-018		
	TWO	-					
	THREE	3					
CORE SPRAY B DISCHARGE	ONE	3	3	TWH-69, 70, 113	84-058, 058R, 016 016R, 015, 015R		
	TWO	4					
	THREE	5					

**NORTHERN STATES POWER CO.  
MONTICELLO NUCLEAR GENERATING PLANT  
INSERVICE INSPECTION-EXAMINATION SUMMARY**

MAJOR ITEM: \_\_\_\_\_

SUB ITEM	EXAM CATE-GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C3.50	C-C	(CONTINUED)					
		REACTOR WATER FROM SKIMMER SYSTEM	ONE TWO THREE	2 - 4			
		RCIC WATER SUCTION	ONE TWO THREE	1 1 -	1	TW-25	84-014
		RCIC STEAM DISCHARGE	ONE TWO THREE	2 2 2	3	SS-38A&B, RSH-13	82-102, 102R, 104, 105
		RHR SERVICE WATER	ONE  TWO THREE	5  5 6	5	SWAK-25, 26, 31 34, 43	84-235, 235R, 024, 024R, 017, 023, 023R 043
		RHR SUCTION A REW10-18"HE	ONE TWO THREE	2 2 -	2	SS-21, TWH-7	84-133, 131, 131R
		TW14B-20"HE	ONE TWO THREE	2 1 -	2	TWH-6, SS-24	84-031, 029
		TW28-20"HE	ONE TWO THREE	- - 3			



Form 9-0033, Rev.0 (M&SP 5.2)  
**NORTHERN STATES POWER CO.**  
**MONTICELLO NUCLEAR GENERATING PLANT**  
**INSERVICE INSPECTION-EXAMINATION SUMMARY**

TABLE S3.2  
PAGE 7 OF 9  
MAJOR ITEM: \_\_\_\_\_ SUPPORT MEMBERS

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C3.50	C-C	(CONTINUED)					
		RHR DISCHARGE A TW29-10"GE	ONE TWO THREE	1 1 2	1	TWH-61	84-030
		TW30-14"GE	ONE  TWO THREE	3  3 2	3	TWH-63,SS-25, TWH-73	84-028,132,076, 076R
		TW30-16"GE	ONE TWO THREE	- 1 -			
		TW30-16"DE	ONE TWO THREE	- 1 -			
		RHR SUCTION B REW10-18"HE	ONE TWO THREE	- - 4			
		TW14A-20"HE	ONE TWO THREE	2 - 2	2	TWH-16, TWH-58	82-291, 82-290
		TW27-20"HE	ONE TWO THREE	- 2 1			

**NORTHERN STATES POWER CO.  
MONTICELLO NUCLEAR GENERATING PLANT  
INSERVICE INSPECTION-EXAMINATION SUMMARY**

MAJOR ITEM: \_\_\_\_\_

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C3.50	C-C	(CONTINUED)					
		RHR DISCHARGE B TW29-10"GE	ONE TWO THREE	- - 2			
		TW19-14"GE	ONE TWO THREE	- 1 -			
		TW20-14"GE	ONE TWO THREE	3 2 4	3	TWH-100,101,102	84-057,055,056
		TW22-14"GE	ONE TWO THREE	1 - -	2	TWH-168,SR-23	84-054,059
		CONTAINMENT SPRAY A & B TW23-12"GE	ONE TWO THREE	2 1 3	2	SS-30, TWH-140	82-145, 140, 140R
		TW23-10"GE					
		TW33-12"GE	ONE TWO THREE	2 1 4	2	TWH-74, TWH-75	82-144, 82-143
		TW33-10"GE					
		C3.60	C-C	<u>*SUPPORTS - MECHANICAL AND HYDRAULIC</u>  <u>PUMPS</u>	-	-	

Form 9-0033, Rev. 0 (M&SP 5.2)  
**NORTHERN STATES POWER CO.**  
**MONTICELLO NUCLEAR GENERATING PLANT**  
**INSERVICE INSPECTION-EXAMINATION SUMMARY**

TABLE S3.2  
PAGE 9 OF 9  
MAJOR ITEM: \_\_\_\_\_ SUPPORT MEMBERS \_\_\_\_\_

SUB ITEM	EXAM CATE-GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C3.70	C-C	<u>*INTEGRALLY WELDED SUPPORT ATTACHMENTS</u>					<u>*INCLUDES THE CORRESPONDING C3.80 (VT-3) EXAMINATIONS</u>
		RHR PUMPS (P-202D)	TWO THREE TWO ONE	1 1 1 1	1	Support "D"	84-065, 073
		CORE SPRAY PUMPS (14-1B)	THREE ONE	1 1	1	Support "B"	84-001, 007
C3.80	C-C	<u>COMPONENT SUPPORTS</u>					
		HPCI TURBINE & PUMPS	ONE TWO THREE	3 3 5	1	Support "A"	82-110
		RCIC TURBINE & PUMP	ONE TWO THREE	1 1 2			
C3.90	C-C	<u>SUPPORTS - MECHANICAL AND HYDRAULIC</u>	-	-			
		<u>VALVES</u>					
C3.100	C-C	<u>INTEGRALLY WELDED SUPPORT ATTACHMENTS</u>	-	-			<u>*INCLUDED UNDER C3.40, C3.50, &amp; C3.60</u>
C3.110	C-C	<u>COMPONENT SUPPORTS</u>	-	-			
C3.120	C-C	<u>SUPPORTS - MECHANICAL AND HYDRAULIC</u>	-	-			

Form 9-0033, Rev. 0 (M&SP 5.2)  
**NORTHERN STATES POWER CO.**  
**MONTICELLO NUCLEAR GENERATING PLANT**  
**INSERVICE INSPECTION-EXAMINATION SUMMARY**

TABLE S4.2  
PAGE 1 OF 1

MAJOR ITEM: PRESSURE RETAINING BOLTING > 2"

SUB ITEM	EXAM CATE- GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C4.10	C-D	<u>BOLTS AND STUDS</u>	-	-			
C4.20	C-D	<u>PIPING</u> <u>BOLTS AND STUDS</u>	-	-			
C4.30	C-D	<u>PUMPS</u> <u>BOLTS AND STUDS</u>	-	-			
C4.40	C-D	<u>VALVES</u> <u>BOLTS AND STUDS</u>	-	-			



**NORTHERN STATES POWER CO.  
MONTICELLO NUCLEAR GENERATING PLANT  
INSERVICE INSPECTION-EXAMINATION SUMMARY**

MAJOR ITEM: PIPING PRESSURE BOUNDARY

SUB ITEM	EXAM CATE-GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.	
C5.11 & C5.12	C-F	<u>(CONTINUED)</u>						
		RHR DISCHARGE A & B						
		TW29-10"GE	TWO	2				
		TW19-10"GE	TWO THREE	1 2				
		TW29-14"GE	ONE	1	1	16	84-047	
		TW19-14"GE	TWO	2				
		TW30-14"GE	ONE	2	2	369, 370	84-049, 84-048	
		TW20-14"GE	TWO THREE	3 2 2				
		TW30-16"GE	TWO	1				
		TW20-16"GE	ONE	1	1	25	84-077	
		TW22-14"GE	ONE	1	1	348	84-078	
		<u>('75 CATEGORY C-G)</u>						
		HPCI WATER SUCTION						
		TW1-14"HE	TWO	2				
		C16-14"HE	THREE	1				
HPCI STEAM								
PS18-8"ED	TWO THREE	2 2						
HPCI STEAM DISCH								
RS2-16"HE	TWO THREE	2 1						

**NORTHERN STATES POWER CO.  
MONTICELLO NUCLEAR GENERATING PLANT  
INSERVICE INSPECTION-EXAMINATION SUMMARY**

MAJOR ITEM: PIPING PRESSURE BOUNDARY

SUB ITEM	EXAM CATE-GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C5.11 & C5.12	C-F	<u>(CONTINUED)</u>					
		RS2-18"HE RS2-20"HE	THREE -	1 -			
		CORE SPRAY A & B SUCTION TW6-12"HE TW10-12"HE	ONE THREE	2 2	2	18, 532	84-004,005
		CORE SPRAY A & B DISCHARGE TW7-10"GE TW11-10"GE	ONE TWO THREE	2 1 2	2	1, 4	84-003,002
		TW7-8"ED TW11-8"ED	ONE -	1 -	1	CSAJ-32	84-072
		TW8-8"GE TW12-8"GE	- THREE	- 1			
		REACTOR WATER FROM SKIMMER SYSTEM REW11-8"HE	ONE TWO THREE	1 2 1			
		RCIC WATER SUCTION TW5-6"HE C17-6"HE	ONE TWO THREE	1 1 1	1	14	82-100

Form 9-0033, Rev. 0 (M&SP 5.2)  
**NORTHERN STATES POWER CO.**  
**MONTICELLO NUCLEAR GENERATING PLANT**  
**INSERVICE INSPECTION-EXAMINATION SUMMARY**

TABLE 5.2  
PAGE 4 OF 7  
MAJOR ITEM: PIPING PRESSURE BOUNDARY

SUB ITEM	EXAM CATE-GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C5.11 & C5.12	C-F	(CONTINUED)					
		RCIC STEAM DISCHARGE RS3-8"HE	ONE TWO THREE	1 2 1			
		RHR SERVICE WATER SW9-8"GE	ONE TWO THREE	2 2 2	2	SWAJ-39,40	84-186,185
		RHR SUCTION A & B TW28-20"HE TW27-20"HE	ONE TWO	1 1	1	3	84-046
		CONTAINMENT SPRAY A & B TW23-12"GE TW33-12"GE	ONE TWO THREE	1 1 1	1	22	82-142
		C-F	TW23-10"GE TW33-10"GE	ONE THREE	1 1	1	28
		FEEOWATER TO RWCU TO HPCI	ONE		6	AUGMENTED W-1 W-2 W-3 W-4 W-12 W-12A	84-115, 121 84-116, 122 84-117, 123 84-120, 126 84-118, 124 84-119, 125



Form 9-0033, Rev. 0 (M&SP 5.2)  
**NORTHERN STATES POWER CO.**  
**MONTICELLO NUCLEAR GENERATING PLANT**  
**INSERVICE INSPECTION-EXAMINATION SUMMARY**

TABLE 5.2  
PAGE 5 OF 7  
**MAJOR ITEM: PIPING PRESSURE BOUNDARY**

SUB ITEM	EXAM CATEGORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C5.11 & C5.12	C-F	CONTROL ROD DRIVE TO REACTOR WATER CLEAN-UP	ONE		5	AUGMENTED W-7 W-11 W-12 W-13 W-14	84-247, 253 84-246, 258 84-250, 256 84-249, 254 84-248, 255
C5.20	C-F	<u>PIPING WELDS OVER 1/2 in. NOMINAL WALL THICKNESS</u>					
C5.21 & C.22	C-F	<u>CIRCUMFERENTIAL AND *LONGITUDINAL WELDS</u>  ( '75 CATEGORY C-F)  MAIN STEAM A,B,C,&D PS1-18"ED PS2-18"ED PS3-18"ED PS4-18"ED  SUPPLY TO STEAM SEAL SYSTEM PS7-8"ED  PS7-10"ED	ONE TWO TWO THREE	1 1 1 1			*2.5TMIN FROM EACH SCHEDULED CIRC WELD INTERSECTION WILL BE EXAMINED
			ONE	2	2	SSAJ-35; SSAJ-37	82-142,111; 82-153,112
			TWO THREE	3 2			

Form 9-0033, Rev. 0 (M&SP 5.2)  
**NORTHERN STATES POWER CO.**  
**MONTICELLO NUCLEAR GENERATING PLANT**  
**INSERVICE INSPECTION-EXAMINATION SUMMARY**

TABLE 55.2  
PAGE 6 OF 7  
**MAJOR ITEM: PIPING PRESSURE BOUNDARY**

SUB ITEM	EXAM CATE-GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C5.21 & C.22	C-F	(CONTINUED)					
		MAIN STEAM EQUALIZER HDR PS30-18"EDB	ONE TWO THREE	2 1 2			
		10"DRIPLEG	-	-			
		FEEDWATER A & B FW2A-14"ED FW2B-14"ED	ONE -	1 -	1	FWDJ-38	82-025, 026
		RHR DISCHARGE A & B TW30-16"DB TW20-16"DB	- TWO	- 1			
C5.30	C-F	( '75 CATEGORY C-G) HPCI WATER DISCHARGE TW3-12"ED	ONE ONE TWO THREE	1 2 3 1	3	CIAJ-62,29,30	84-129,130,22, 25,21,26
		PIPE BRANCH CONNECTIONS					
C5.31 & C5.32	C-F	CIRCUMFERENTIAL AND *LONGITUDINAL WELDS  ( '75 CATEGORY C-F)					*2.5T MIN FROM EACH SCHEDULED CIRC WELD INTER-SECTION WILL BE EXAMINED

Form 9-0033, Rev. 0 (M&SP 5.2)  
**NORTHERN STATES POWER CO.**  
**MONTICELLO NUCLEAR GENERATING PLANT**  
**INSERVICE INSPECTION—EXAMINATION SUMMARY**

TABLE S5.2  
PAGE 7 OF 7  
**MAJOR ITEM: PIPING PRESSURE BOUNDARY**

SUB ITEM	EXAM CATE- GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C5.31 & C5.32	CF	<p><u>(CONTINUED)</u></p> <p>SUPPLY TO STEAM SEAL SYSTEM PS11-6"ED PS12-6"ED PS13-6"ED PS14-6"ED</p> <p>RHR SUCTION A &amp; B TW16-14"HE TW18-14"HE TW15-14"HE TW17-14"HE</p> <p>RHR DISCHARGE B TW22-14"GE</p> <p>(CATEGORY C-G)</p> <p>REACTOR WATER FROM SKIMMER SYSTEM REW11-8"HE</p> <p>RHR SUCTION A &amp; B TW28-20"HE TW27-20"HE</p>	<p>-</p> <p>-</p> <p>THREE</p> <p>-</p> <p>TWO</p> <p>-</p> <p>-</p> <p>-</p> <p>-</p> <p>TWO</p> <p>ONE</p> <p>-</p>	<p>-</p> <p>-</p> <p>1</p> <p>-</p> <p>1</p> <p>-</p> <p>-</p> <p>-</p> <p>1</p> <p>1</p> <p>-</p>	<p>-</p> <p>-</p> <p>-</p> <p>-</p> <p>-</p> <p>-</p> <p>-</p> <p>-</p> <p>-</p> <p>1</p> <p>-</p>	<p>-</p> <p>-</p> <p>-</p> <p>-</p> <p>-</p> <p>-</p> <p>-</p> <p>-</p> <p>-</p> <p>820</p> <p>-</p>	<p>-</p> <p>MULTIPLE STREAMS</p> <p>-</p> <p>MULTIPLE STREAMS</p> <p>-</p> <p>MULTIPLE STREAMS</p> <p>-</p> <p>SINGLE STREAMS</p> <p>-</p> <p>84-045</p>

**NORTHERN STATES POWER CO.  
MONTICELLO NUCLEAR GENERATING PLANT  
INSERVICE INSPECTION-EXAMINATION SUMMARY**

MAJOR ITEM: PUMP CASINGS AND VALVE BODIES

SUB ITEM	EXAM CATE- GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C6.10	C-G	<u>PUMP CASING WELDS</u>	-	-			
C6.20	C-G	<u>VALVE BODY WELDS</u>	-	-			

Form 9-0033, Rev. 0 (M&SP 5.2)  
**NORTHERN STATES POWER CO.**  
**MONTICELLO NUCLEAR GENERATING PLANT**  
**INSERVICE INSPECTION-EXAMINATION SUMMARY**

TABLE       S7.2        
PAGE       1       OF       1        
**MAJOR ITEM: PRESSURE RETAINING COMPONENTS**

SUB ITEM	EXAM CATE-GORY	COMPONENT OR SYSTEM AND DESCRIPTION OF ITEM TO BE EXAMINED	INSP. PER.	REQ'D. AMT.	AMT. EXAM	ITEM IDENTIFICATION	INSPECTION REPORT NO.
C7.10	C-H	PRESSURE VESSELS	-	-			*SYSTEM PRESSURE TEST PERFORMED BY PLANT EACH INSPECTION PERIOD
C7.20	C-H	PIPING	-	-			
C7.30	C-H	PUMPS	-	-			
C7.40	C-H	VALVES	-	-			
C7.11	C-H	PRESSURE VESSELS	-	-			*SYSTEM HYDRO-STATIC TEST PERFORMED BY PLANT EACH INSPECTION INTERVAL
C7.21	C-H	PIPING	-	-			
C7.31	C-H	PUMPS	-	-			
C7.41	C-H	VALVES	-	-			

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	ISI INDICATIONS	EXAMINATION LIMITATIONS
<u>C1.10 Shell Circumferential Welds</u>							
RHR Heat Exchangers (E-200A)	50	UT	W-1	84-177	N/A	None	No S-2 due to configuration scans limited for 15" @0° due to reinforcing pad, scans limited @approx 200° due to 1" branch connection
		MT		84-037	N/A	None	None
<u>C2.20 Nozzle in Vessels over 1/2" in thickness</u>							
RHR Heat Exchangers (E-200A, Nozzle N3, Inlet)	50	UT	W-7	84-176	N/A	S-1 IDGeo > 100%	Used 70° Angle to reach root of weld No S-2 due to configuration, S-1,3,4, B.E. due to config.
		MT		84-027	N/A	None	None
<u>C3.10 Integrally Welded Support Attachments</u>							
RHR Heat Exchangers (E-200A)	50	MT	Support "A"	84-038	N/A	None	None
		MT	Support "B"	84-038	N/A	None	None

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	ISI INDICATIONS	EXAMINATION LIMITATIONS
<u>C3.20 Component Supports</u>							
RHR Heat Exchangers (E-200A)	50	VT	Support"A"	84-044	N/A	None	None
		VT	Support"B"	84-044	N/A	None	None
<u>C3.40 Integrally welded Support Attachments</u>							
Core Spray"A" (TW7-10"GE)	34A	MT	CSAK-35	84-060	N/A	None	None
		VT		84-067	N/A	Loose Nut	
		VT		84-067R		None, Loose nut tightened	None
<u>C3.50 Component Supports</u>							
HPCI Water Discharge (TW3-12"ED)	31	VT	SR-69	84-011	N/A	None	None
		VT	SS-35	84-011	N/A	None	None
		VT	CIAK-26	84-019	N/A	None	None
		VT	CIAK-27A	84-012	N/A	None	None
		VT	CIAK-28	84-013	N/A	None	None
Core Spray"A" Suction (TW6-12"HE)	34	VT	TWH-53	84-006	N/A	None	Hangar drawing not available
		VT	TWH-54	84-010	N/A	None	None

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	ISI INDICATIONS	EXAMINATION LIMITATIONS
<u>C3.50 Component Supports</u>							
Core Spray"A"Discharge (TW7-10"GE)	34	VT	TWH-81	84-009	N/A	None	None
		VT	TWH-82	84-008	N/A	None	None
(TW9-8"ED)	34A	VT	CSAK-31	84-066	N/A	Loose Bolts	None
		VT		84-066R		None,Bolts Repaired	None
		VT	CSAK-32A	84-068	N/A	None	Hangar drawing not available
Core Spray"B"Suction (TW10-12"HE)	35	VT	TWH-55	84-018	N/A	None	None
Core Spray"B"Discharge (TW11-10"GE)	35	VT	TWH-69	84-058	N/A	Loose Bolt	None
		VT		84-058R		None,Loose Bolt Repaired	None
		VT	TWH-70	84-016	N/A	Loose Bolt	None
		VT		84-016R		None,Loose Bolt Repaired	None
		VT	TWH-113	84-015	N/A	Loose Bolt	None
		VT		84-015R		None,Loose Bolt Repaired	None
RCIC Water Suction (TW5-6"HE)	38	VT	TW-25	84-014	N/A	None	None



COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	ISI INDICATIONS	EXAMINATION LIMITATIONS
<u>C3.50(cont.)</u>							
RHR Service Water (SW9-8"GE)	39	VT	SWAK-25	84-235	N/A	Loose Nut	Hangar drawing not available
		VT		84-235R		None, Loose Nut tightened	Hangar drawing not available
		VT	SWAK-26	84-024	N/A	Loose Nuts	None
		VT		84-024R		None, Loose Nuts Tightened	None
		VT	SWAK-31	84-017	NONE	None	None
		VT	SWAK-34	84-023	NONE	Loose Nut	None
		VT		84-23R		None, Nut Tightened	None
		VT	SWAK-43	84-043	N/A	None	None
RHR"A"Suction (REW10-18"HE)	40	VT	SS-21	84-133	N/A	None	None
		VT	TWH-7	84-131	N/A	Loose Bolt	None
		VT		84-131R		None, Loose Bolt Tightened	None
		VT	TWH-6	84-031	N/A	None	None
		VT	SS-24	84-029	N/A	None	None
(TW14B-20"HE)							

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	ISI INDICATIONS	EXAMINATION LIMITATIONS
<u>C3.50(Cont)</u>							
RHR"A"Discharge (TW29-10"GE)  (TW30-14"GE)	41	VT	TWH-61	84-030	N/A	None	None
		VT	TWH-63	84-028	N/A	None	None
		VT	SS-25	84-132	N/A	None	None
		VT	TWH-73	84-076	N/A	Loose Bolt	None
		VT		84-076R		None,Loose Bolt Repaired	None
RHR"B"Discharge (TW20-14"GE)    (TW22-14"GE)	43	VT	TWH-100	84-057	N/A	None	None
		VT	TWH-101	84-055	N/A	None	None
		VT	TWH-102	84-056	N/A	Loose Nut	None
		VT		84-056R		None,loose nut Tightened	None
		VT	TWH-168	84-054	N/A	None	None
		VT	SR-23	84-059	N/A	None	None
<u>C3.70 Internally Welded Support Attachments</u>							
RHR Pumps (P202D)	48	MT	Support D	84-073	N/A	None	None
		VT		84-065	N/A	None	None

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	ISI INDICATIONS	EXAMINATION LIMITATIONS
<u>C3.70 Internally Welded Support Attachments</u>							
Core Spray Pumps (14-1B)	49	MT	Support B	84-001	N/A	None	None
		VT		84-007	N/A	None	None
<u>C5.11 &amp; C5.12 Circumferent &amp; Longitudinal welds less than 1/2" wall thickness</u>	1						
RHR "A" & "B" Discharge (TW29-14"GE)	41	MT	16	84-047	N/A	None	None
(TW30-14"GE)		MT	369	84-049	N/A	None	None
		MT	370	84-048	N/A	None	None
(TW20-16"GE)	43	MT	25	84-077	N/A	None	None
(TW22-14"GE)		MT	348	84-078	N/A	None	None
Core Spray "A" Suction (TW6-12"GE)	34	MT	18	84-004	N/A	None	None
		MT	532	84-005	N/A	None	None
Core Spray "A" Discharge (TW7-10"GE)	34	MT	1	84-003	N/A	None	None
		MT	4	84-002	N/A	None	None
(TW7-8"ED)	34A	MT	CSAJ-32	84-072	N/A	None	None
RHR Service Water (SW9-8"GE)	39	MT	SWAJ-39	84-186	N/A	None	None
		MT	SWAJ-40	84-185	N/A	None	None

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	ISI INDICATIONS	EXAMINATION LIMITATIONS
<u>C5.11 &amp; C5.12(con.t)</u>							
RHR "A" Suction (TW28-20"HE)	40	MT	3	84-046	N/A	None	None
Feedwater to RWCU to HPCI	37	UT	W-1	84-115	NONE	None	None
		MT		84-121	NONE	None	None
		UT	W-2	84-116	NONE	S-1 IDGeo.100% 360° Inter.	S-2 limited 11:00 to 1:00 due to inside radius of tee
		MT		84-122	NONE	None	None
		UT	W-3	84-117	S-1 ID,OD Geo 30%, 360°	S-2 IDGeo.75% 360° Inter.	S-1 limited 11:00 to 1:00 & 5:00 to 7:00 due to inside radius of tee
		MT		84-123	NONE	None	None
		UT	W-4	84-120	S-1 ID,Geo 80° 360 Inter.	S-1 ODGeo 30% 360° Inter.	S-1 limited 11:00 to 1:00 due to inside radius of tee
		MT		84-126	NONE	None	None
		UT	W-12	84-118	S-1 OD GEO 9:00 to 10:00 80% S-2 ID,OD Geo 6:00 to 12:00 40%	S-1 ODGeo.75% 360° Int.	S-2 limited to 1 node due to adjacent weld

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	ISI INDICATIONS	EXAMINATION LIMITATIONS
C5.11 & C5.12(cont)  Control Rod Drive to Reactor Water Clean Up		MT		84-124	NONE	None	None
		UT	W-12A	84-119	NONE	None	No S-2 due to config.S-1 limited to 1 node due to adjacent weld
		MT		84-125	NONE	None	None
		UT	W-7	84-247	NONE	S-1 ID,ODGeo. 20% S-2 ID,ODGeo. 20%	S-1 limited 10:00 to 12:00 due to inner radius of elbow
		PT		84-253	NONE	None	None
		UT	W-11	84-246	NONE	S-1 ODGeo.120% 360° Inter.	No Scan 2,3s,4s due to tee config.
		PT		84-258	NONE	None	None
		UT	W-12	84-250	NONE	S-1 IDGeo.100% 360° S-2 ID,ODGeo 20% 360° Inter.	None
		PT		84-256	NONE	None	None
		UT	W-13	84-249	NONE	S-1 IDGeo 100% @12:00 S-2 ID,ODGeo. 20% 360° Inter.	No S-1 from 4:30 to 7:30 due to config. of tee

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	ISI INDICATIONS	EXAMINATION LIMITATIONS	
<u>C5.11 &amp; C5.12(cont)</u>		PT		84-254	NONE	None	None	
		UT	W-14	84-248	NONE	S-1, ID, ODGeo 20% 360° Inter. S-2 ID, ODGeo 20% 360° Inter.	S-2 limited from 10:00 to 2:00 due to inside radius of elbow	
		PT		84-255	NONE	None	None	
<u>C5.21 &amp; C5.22</u> <u>Circumferential &amp;</u> <u>Longitudinal Welds Over</u> <u>1/2" Wall Thickness</u>	31							
HPCI Water Discharge (TW3-12"ED)		UT	CIAJ-62	84-130	N/A	S-1, ODGeo. 50% 360° Inter.	None	
		MT			84-129	N/A	None	None
		UT	CIAJ-29		84-025	N/A	None	No S-2 due to config. of valve
		MT			84-022	N/A	None	None
		UT	CIAJ-30		84-026	N/A	None	No S-1 due to config. of valve
		MT			84-021	N/A	None	None

COMPONENT/SYSTEM	NSP ISO	NDE METHOD	BASELINE IDENT.	REPORT NO.	BASELINE INDICATIONS	ISI INDICATIONS	EXAMINATION LIMITATIONS
<p><u>C5.31 &amp; C5.32 Branch Connections</u></p> <p>RHR"A" Suction (TW28-20"HE)</p>	40	MT	820	84-045	N/A	None	None

APPENDIX C

TABLE I - PERSONNEL LISTING

TABLE II - ULTRASONIC CALIBRATION BLOCKS

TABLE III - PROCEDURE LISTING

TABLE IV - EQUIPMENT AND MATERIALS



PERSONNEL LISTING

EXAMINER	TITLE	ORGANIZATION	ASNT LEVEL				
			UT	PT	MT	VT	RT
G.R. ADAMS	SUPERVISOR	LMT (2)	III	III	III	III (1c)	-
R.G. AUER	TECHNICIAN	LMT	II	II	II	II (1c)	-
W.D. CARLIN	TECHNICIAN	LMT	I	II	-	II (1b)	-
J.D. ELLIOTT	TECHNICIAN	LMT	II	II	II	II (1b)	-
S.R. FETHERSTON	TECHNICIAN	LMT	I	-	I	-	-
D.A. HALL	TECHNICIAN	LMT	II	-	-	II (1c)	-
K.L. HALL	TECHNICIAN	LMT	I	-	-	-	-
R.A. KELLERHALL	SUPERVISOR	LMT	III	III	III	III (1a,c)	-
T. KIMBALL	TECHNICIAN	LMT	II	II	II	II (1b,c)	-
Q. LOREDO	TECHNICIAN	LMT	I	-	-	-	-
R.W. PECHACEK	TECHNICIAN	LMT	II	II	II	II (1a,b)	-
K.E. SCRIVNER	TECHNICIAN	LMT	I	-	-	-	-
R.A. SEALS	TECHNICIAN	LMT	II	II	II	II (1a,c)	-
E.L. THOMAS	SUPERVISOR	LMT	III	III	III	III (1a,c)	-
R.J. WATKINS	TECHNICIAN	LMT	-	II	-	II (1b)	-
A.S. WHEALDON	TECHNICIAN	LMT	II	II	II	II (1b)	-
K.S. ANDERSON	TECHNICIAN	G.E. (3)	-	-	-	II	-
E.C. TAILLET	SUPERVISOR	G.E.	-	-	-	II	-
L.C. DAHLMANN	MATERIALS AND SPECIAL PROCESS SPECIALIST	NSP	II	III	III	II (1a,b)	-
J.F. SCHANEN	MATERIALS AND SPECIAL PROCESS SPECIALIST	NSP	II	II	II	II (1b)	-

EXAMINER	TITLE	ORGANIZATION	ASNT LEVEL					
			UT	PT	MT	VT	ET	RT
R. HUGHES	ANII	HARTFORD STEAM BOILER INSPECTION INSURANCE COMPANY						

FOOTNOTES:

- (1a) Certified by NSP to perform visual determination of structural integrity for hangar assemblies in accordance with NSP-VT2.0.
- (1b) Inspection experience and NDE qualifications were determined to be adequate to perform visual examinations in accordance with NSP-VT1.0.
- (1c) Personnel certified in accordance with contractor's Quality Assurance Program.
- (2) Organization: Lambert, MacGill, Thomas, Inc. (LMT)  
515 Aldo Avenue  
Santa Clara, CA 95054
- (3) Organization: General Electric Company (GE)  
5353 Gamble Drive  
Minneapolis, MN 55416

NORTHERN STATES POWER COMPANY

MONTICELLO  
ULTRASONIC CALIBRATION BLOCKS

NSP No.	SIZE & DIA.	PIPE SCHEDULE & THICKNESS	MATERIAL	SERIAL OR HEAT NUMBER	CALIBRATION REPORTS	DATE
RPV-1		5 5/16" +Clad	A533 BC.L1	C2220/1	RGA-001 RGA-002 RGA-003 TK-015 TK-016 TK-017	4-14-84 4-19-84 4-16-84 3-20-84 3-20-84 3-19-84
RPV-3		3.66" +Clad	SA533 BC.L.1	C9220	RAS-003 RAS-004 RAS-006	3-2-84 3-1-84 3-2-84
4	4"	80 .337"	A106B	L42009	RAS-001	2-28-84
5	8"	80 .500"	A106B	N53114	TK-014 RAS-012	3-13-84 3-16-84
8	18"	80 .937"	A106B	122491	RGA-004	4-26-84
11	8"	80 .500"	304 S/S	15885	DAH-004 DAH-005 DAH-006 DAH-007 DAH-009 TK-005 TK-006 ELT-001	4-9-84 4-8-84 4-12-84 4-10-84 4-16-84 2-25-84 2-27-84 2-24-84

NORTHERN STATES POWER COMPANY

MONTICELLO

ULTRASONIC CALIBRATION BLOCKS

NSP No.	SIZE & DIA.	PIPE SCHEDULE & THICKNESS	MATERIAL	SERIAL OR HEAT NUMBER	CALIBRATION REPORTS	DATE
15	3"	80 .300"	304 S/S	03052	DAH-014	5-2-84
17	2"	80 .218"	A312	A4272	DAH-003	2-18-84
18	3"	160 .438"	A312	01598	TK-012	3-8-84
19	3"	160 .438"	A016B	T08300	DAH-013	5-3-84
24	16"	80 .843"	304 S/S	27DH136	TK-004	2-23-84
29	12"	80 .687"	A106B	L24489	RAS-002	2-29-84
30		5 5/16" +CLAD	A533B	C5571	DAH-011 DAH-012 TK-009 TK--010 TK-013 RAS-005 RAS-007 RAS-008 RAS-009 RAS-010 RAS-014	4-18-84 4-18-84 3-3-84 3-5-84 3-8-84 3-1-84 3-5-84 3-6-84 3-7-84 3-21-84 3-21-84

NSP No.	SIZE & DIA.	PIPE SCHEDULE & THICKNESS	MATERIAL	SERIAL OR HEAT NUMBER	CALIBRATION REPORTS	DATE
36	10" & 13.43"	80 .491" & .875"	B166 Inconel	BGM	DAH-010	4-17-84
37	24"	- .500"	A234 GR.WPB	L00543	RAS-015	3-29-84
43	12"	100 .844"	A106B	L81058	DAH-001	2-15-84
45	9"	- 1.6195"	A182 GRF S/S	CMB	TK-008	3-2-84
46	6.375"	- 1.2745"	A182 GRF S/S	CMB	TK-007	2-29-84
47	3"	- .530"	A336 C1F8S/S	CMB	TK-003 TK-018 ELT-002	2-20-84 4-14-84 3-8-84
48	3.75"	- .875"	A336 C1F8S/S	CMB	DAH-002	2-18-84
49	4.5"	- .275"	A336 C1F8 S/S	CMB	TK-002	2-17-84

NORTHERN STATES POWER COMPANY

MONTICELLO

ULTRASONIC CALIBRATION BLOCKS

APPENDIX C

TABLE II

PAGE 4 of 4

NSP No.	SIZE & DIA.	PIPE SCHEDULE & THICKNESS	MATERIAL	SERIAL OR HEAT NUMBER	CALIBRATION REPORTS	DATE
50	5.6"	- .875"	A336 C1F8S/S	CMB	TK-001	2-16-84
51	4'	- .875"	A515 GR70	89886-21	RAS-016	3-28-84
54	12"	- .640"	A530 GRLF-2	722248	DAH-008 RAS-013	4-16-84 3-17-84

NORTHERN STATES POWER COMPANY

MONTICELLO  
PROCEDURE LISTING

PROCEDURE NUMBER AND REVISION	FIELD CHANGE	PROCEDURE TITLE	PLANT APPROVAL DATE	FIELD CHANGE REMARKS	CHANGE DESCRIPTION
NSP-MT-1 Rev.3	NONE	MAGNETIC PARTICLE EXAMINATION	8-26-82	NONE	
NSP-PT-1 Rev. 3	FC 1 FC 2	LIQUID PENETRANT EXAMINATION	3-6-84 5-21-84		F.C.#1 Change rounded indication reporting requirements, INCREASE DWELL AND DEVELOPMENT TIME.  F.C.#2 Re-instate original procedure.
NSP-UT-1 Rev.2	None	ULTRASONIC EXAMINATION OF PIPE WELDS	8-26-82	NONE	
NSP-UT-2 Rev.2	NONE	AUTOMATIC DATA RECORDING	8-26-82	NONE	
NSP-UT-3 Rev.2	NONE	ULTRASONIC EXAMINATION OF FERRITIC VESSELS	2-28-84	NONE	
NSP-UT-4 Rev. 2	NONE	ULTRASONIC EXAMINATION OF STUDS, BOLTS & NUTS	8-26-82	NONE	
NSP-UT-5 Rev. 3	NONE	ULTRASONIC EXAMINATION OF REACTOR VESSEL NOZZLE FORGING INNER RADII.	8-26-82	NONE	

PROCEDURE NUMBER AND REVISION	FIELD CHANGE	PROCEDURE TITLE	PLANT APPROVAL DATE	FIELD CHANGE REMARKS	CHANGE DESCRIPTION
NSP-UT-6 Rev. 3	NONE	ULTRASONIC EXAMINATION OF REACTOR VESSEL NOZZLE BORE.	8-26-82	NONE	
NSP-UT-16 Rev.0	NONE	ULTRASONIC EXAMINATION FOR INTERGRANULAR STRESS CORROSION CRACKING (IGSCC)	2-17-84	NONE	
NSP-UT-16 Rev.1	NONE	ULTRASONIC EXAMINATION FOR INTERGRANULAR STRESS CORROSION CRACKING (IGSCC)	3-2-84	NONE	
NSP-VT-1.0 Rev.0	NONE	VISUAL EXAMINATION	8-26-82	NONE	
NSP-VT-2.0 Rev.0	NONE	VISUAL EXAMINATION OF HANGER ASSEMBLIES	9-2-82	NONE	
NSP-VT-3.0 Rev.0	NONE	VISUAL EXAMINATION OF PUMP AND VALVE INTERNAL PRESSURE BOUNDARY SURFACES	8-30-82	NONE	
NSP-VT-4.0 Rev.0	NONE	VISUAL EXAMINATION OF MONTICELLO REACTOR VESSEL INTERIOR	8-30-82	NONE	



MATERIAL OR EQUIPMENT	TYPE OR SERIAL NUMBER	CALIBRATION DATE OR BATCH NUMBER	REMARKS
<u>ULTRASONIC SCOPES</u>			
NORTEC 131D	S/N 111	12/10/83	OFFSITE 3/10/84
NORTEC 131D	S/N 126	3/13/84	OFFSITE 6/13/84
NORTEC 131D	S/N 129	2/24/84	OFFSITE 4/24/84
NORTEC 131D	S/N 129	4/25/84	OFFSITE 7/25/84
NORTEC 131D	S/N 129	10/18/84	
NORTEC 131D	S/N 167	2/27/84	OFFSITE 5/21/84
NORTEC 131D	S/N 167	5/22/84	OFFSITE 8/21/84
NORTEC 131D	S/N 167	8/23/84	OFFSITE 11/23/84
NORTEC 131D	S/N 269	3/12/84	OFFSITE 6/11/84
NORTEC 131D	S/N 269	6/12/84	OFFSITE 9/12/84
NORTEC 131D	S/N 287	12/29/83	OFFSITE 3/29/84
NORTEC 131D	S/N 287	6/27/84	OFFSITE 9/27/84
NORTEC 131D	S/N 287	10/2/84	OFFSITE 1/2/85
NORTEC 131D	S/N 291	12/21/83	OFFSITE 3/21/83
NORTEC 131D	S/N 311	1/27/84	OFFSITE 4/27/84
NORTEC 131D	S/N 311	10/31/84	
NORTEC 131D	S/N 322	1/26/84	OFFSITE 4/24/84
NORTEC 131D	S/N 322	4/25/84	OFFSITE 5/25/84
NORTEC 131D	S/N 322	6/26/84	OFFSITE 9/26/84
NORTEC 131D	S/N 371	2/27/84	OFFSITE 5/27/84
NORTEC 131D	S/N 410	3/28/84	OFFSITE 6/28/84
NORTEC 131D	S/N 410	9/19/84	OFFSITE 12/19/84
NORTEC 131D	S/N 409	5/21/84	OFFSITE 8/21/84
NORTEC 131D	S/N 417	6/12/84	OFFSITE 9/12/84
NORTEC 131D	S/N 530-B	2/1/84	OFFSITE 4/24/84
NORTEC 131D	S/N 530-B	4/25/84	OFFSITE 7/25/84
<u>ULTRASONIC SCOPES</u>			
SLAVE	S/N 1	3/1/84	
SLAVE	S/N 1	6/5/84	
SLAVE	S/N 2	8/20/84	
SLAVE	S/N 12	12/28/83	
SLAVE	S/N 13	1/12/84	
SLAVE	S/N 14	2/23/84	
SLAVE	S/N 14	6/5/84	
JFS032585WMH01			

MATERIAL OR EQUIPMENT	TYPE OR SERIAL NUMBER	CALIBRATION DATE OR BATCH NUMBER	REMARKS
<u>RECORDERS</u>			
GOULD BRUSH 220	S/N 3018	2/7/84	OFFSITE 8/7/84
GOULD BRUSH 220	S/N 8188-252	3/30/84	OFFSITE 9/30/84
GOULD BRUSH 220	S/N 08343	12/6/83	OFFSITE 6/6/84
GOULD BRUSH 220	S/N 08343	6/7/84	OFFSITE 12/7/84
GOULD BRUSH 220	S/N 15452	12/1/83	OFFSITE 6/1/84
GOULD BRUSH 220	S/N 18687	2/3/84	OFFSITE 8/3/84
GOULD BRUSH 220	S/N 18687	8/7/84	
GOULD BRUSH 220	S/N 18940	1/5/84	OFFSITE 6/21/84
GOULD BRUSH 220	S/N 18940	6/22/84	OFFSITE 12/22/84
GOULD BRUSH 220	S/N 19016	3/5/84	OFFSITE 8/29/84
GOULD BRUSH 220	S/N 19016	8/30/84	
GOULD BRUSH 220	S/N 19023	3/5/84	OFFSITE 9/5/84
GOULD BRUSH 220	S/N 19023	9/6/84	
<u>TEMPERATURE GAUGES</u>			
PTC Surface			
Thermometers			
0° to 300°F	S/N 555	Cal:10/21/83	CERTIFIED BY
	S/N 559	Cal:10/21/83	MANUFACTURER
	S/N 563	Cal:10/21/83	" "
	S/N 566	Cal:11/15/83	" "
	S/N 569	Cal:11/15/83	" "
	S/N 570	Cal:11/15/83	" "
	S/N 572	Cal:11/15/83	" "
	S/N 574	Cal:11/15/83	" "
	S/N 582	Cal:11/15/83	" "
	S/N 583	Cal:11/15/83	" "
	S/N 584	Cal:11/15/83	" "
	S/N 585	Cal:11/15/83	" "
	S/N 586	Cal:11/15/83	" "
	S/N 587	Cal:11/15/83	" "
	S/N 590	Cal:3/09/84	" "
	S/N 591	Cal:3/09/84	" "
	S/N 592	Cal:3/09/84	" "
	S/N 597	Cal:3/09/84	" "
	S/N 598	Cal:3/09/84	" "
	S/N 599	Cal:3/09/84	" "
	S/N 605	Cal:3/09/84	" "
	S/N 608	Cal:3/09/84	" "
	S/N 612	Cal:5/11/84	" "
JFS032585WMH01			

NORTHERN STATES POWER COMPANY  
MONTICELLO  
EQUIPMENT AND MATERIALS

APPENDIX C  
TABLE IV  
PAGE 3 OF 6

MATERIAL OR EQUIPMENT	TYPE OR SERIAL NUMBER	CALIBRATION DATE OR BATCH NUMBER	REMARKS
<u>Temperature Gauges</u> (Continued)	S/N 613	Cal:5/11/84	Certified By Manufacturer "
	S/N 614	Cal:5/11/84	
	S/N 616	Cal:5/11/84	
	S/N 617	Cal:5/11/84	
	S/N 618	Cal:5/11/84	
	S/N 619	Cal:5/11/84	
	S/N 621	Cal:5/11/84	
	S/N 625	Cal:5/11/84	
	S/N 631	Cal:7/19/84	
	S/N 632	Cal:7/19/84	
	S/N 633	Cal:7/19/84	
	S/N 634	Cal:7/19/84	
	S/N 635	Cal:7/19/84	
	S/N 636	Cal:7/19/84	
	S/N 637	Cal:7/19/84	
	S/N 630	Cal:7/19/84	
	S/N 655	Cal:7/19/84	
<u>MAGNETIC PARTICLE</u> Y-6 Yoke	S/N LMT-003	2/8/84	On Site Qualification
	S/N KBM-3	7/20/84	
<u>ROMPAS BLOCKS:</u>			
4140 C/S	S/N 403	7/6/82	Earle M. Jorgenson Orla's Machine Shop Orla's Machine Shop Orla's Machine Shop Orla's Machine Shop Dimac Machine Co. Orla's Machine Shop JR Design & Mfg.
4140 C/S	S/N LMT-012	9/8/77	
304 S/S	S/N LMT-008	9/8/77	
304 S/S	S/N 021	1/3/79	
304 S/S	S/N 3	9/13/76	
304 S/S	S/N LMT-026	4/28/81	
304 S/S	S/N 4	7/6/82	
304 S/S	S/N 310	8/19/83	
<u>IIW BLOCK:</u> A36	S/N LMT 002	5/22/80	Dimac Machine Co.
<u>THICKNESS CALIBRATION</u> <u>STEP B BLOCK:</u> c/s	S/N LMT-001	7/22/80	Dimac Machine Co.
JFS032585WMH01			

NORTHERN STATES POWER COMPANY  
MONTICELLO  
EQUIPMENT AND MATERIALS

MATERIAL OR EQUIPMENT	TYPE OR SERIAL NUMBER	CALIBRATION DATE OR BATCH NUMBER	REMARKS
<u>MATERIALS:</u>			
ULTRASONIC COUPLANT	LMT GEL	Batch # 61384 12484 1110812	
PENETRANT MATERIALS SPOTCHECK	PENETRANT	5F086 83M015 83M051 83M072	SKL-HF/SKL-S
DUBL-CHEK		40D-806 54A-531 329-D54	BY-Lux K017-Hi-Temp
SPOTCHECK	DEVELOPER	5F102 81K118 82G057 83L094 84C057	SKD-NF SKD-NF/ZP-9B
DUBL-CHEK		215C6 223-D71	D-100 D-350 Hi-Temp
SPOTCHECK	CLEANER/REMOVER	5G006 82G049 82G079 82L031 83A002 84B008 83C028 83M043 83M064 84D051	SKC-NF SKC-NF/ZC-7B
DUBL-CHECK		33-K4 329-D56	DR-60 K017-Hi-Temp
JFS032585WMH01			

MATERIAL OR EQUIPMENT	TYPE OR SERIAL NUMBER	CALIBRATION DATE OR BATCH NUMBER	REMARKS
<u>ULTRASONIC TRANSDUCERS:</u>			
AEROTECH	B17348	SIZE .5" DIA.	FREQUENCY 2.25 MHz
AEROTECH	C29610	.5" DIA.	2.25 MHz
AEROTECH	F26143	.5" DIA.	2.25 MHz
AEROTECH	G22167	.5" DIA.	2.25 MHz
AEROTECH	G22168	.5" DIA.	2.25 MHz
AEROTECH	54018	.375" DIA.	3.5 MHz
AEROTECH	54017	.375" DIA.	3.5 MHz
AEROTECH	016575	1.0" DIA.	2.25 MHz
AEROTECH	A30160	.5" DIA.	2.25 MHz
AEROTECH	E13044	.5" DIA.	2.25 MHz
AEROTECH	H10142	.5" DIA.	1.5 MHz
AEROTECH	54010	.375" DIA.	3.5 MHz
AEROTECH	012674	.5"x.5" DIA.	2.25 MHz
AEROTECH	H21033	.5" DIA.	2.25 MHz
HARISONICS	T10224	.5"x.5" DIA.	2.25 MHz
HARISONICS	P360V	.5" DIA.	2.25 MHz
HARISONICS	W1815	.25"x.25"DIA.	5.0 MHz
HARISONICS	W2123	.25" DIA.	5.0 MHz
HARISONICS	T3206	.25" DIA.	5.0 MHz
HARISONICS	R2147	.5"x.5" DIA.	2.25 MHz
HARISONICS	T7463	.5"x.5" DIA.	2.25 MHz
HARISONICS	W6207	.5"x.5" DIA.	2.25 MHz
HARISONICS	V11055	.5"x.5" DIA.	2.25 MHz
HARISONICS	S2285	.5" DIA.	1.5 MHz
HARISONICS	R1150	.25" DIA.	2.25 MHz
HARISONICS	S2286	.5" DIA.	1.5 MHz
HARISONICS	V10704	1.0"x1.0"DIA.	2.25 MHz
HARISONICS	V10705	1.0"x1.0"DIA.	2.25 MHz
HARISONICS	W2149	1.5" DIA.	1.0 MHz
HARISONICS	S5139	1.0" DIA.	2.25 MHz
HARISONICS	T8312	.25" DIA.	5.0 MHz
HARISONICS	8301	.25" DIA.	2.25 MHz
HARISONICS	V12038	.25" DIA.	2.25 MHz
HARISONICS	8402	.375" x .375" DIA.	5.0 MHz
HARISONICS	R30131	.375" x .375" DIA.	3.5 MHz
HARISONICS	W8561	.375" x .375" DIA.	2.25 MHz
HARISONICS	Y2880	.375" DIA. .25"x.25"DIA.	2.25 MHz
JFS032585WMH01			

NORTHERN STATES POWER COMPANY  
MONTICELLO  
EQUIPMENT AND MATERIALS

APPENDIX C  
TABLE IV  
PAGE 6 OF 6

MATERIAL OR EQUIPMENT	TYPE OR SERIAL NUMBER	CALIBRATION DATE OR BATCH NUMBER	REMARKS
ULTRASONIC TRANSDUC	S	Size	Frequency
HARISONICS	V11111	.5"x.5" DIA.	1.0 MHz
HARISONICS	V10600	.25" DIA.	5.0 MHz
HARISONICS	Y3410	.5"x.5" DIA.	2.25 MHz
HARISONICS	P928	1.0" DIA.	1.0 MHz
HARISONICS	P927	1.5" DIA.	1.0 MHz
HARISONICS	R3162	.5"x.5" DIA.	2.25 MHz
HARISONICS	R5239	.5"x1.0"DIA.	2.25 MHz
KRAUTKRAMER	56526	12MM x 6MM	2.0 MHz
KRAUTKRAMER	54576	12MM x 6MM	4.0 MHz
NORTEC	978	.75" DIA.	2.25 MHz
NORTEC	979	.75" DIA.	2.25 MHz
PANAMETRICS	11908	.25" DIA.	2.25 MHz
JFS032585WMH01			

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company  
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT  
 Address: MONTICELLO, MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
----------------------------------	----------------------------------	---	------------------------------	---------------------------

ASME CLASS I  
NOZZLE WELDS

B3.10 Nozzle-To-Vessel Welds &  
B3.20 Nozzle Inside Radius Section

Reactor Vessel Head Vent HVAD-1	CB&I	-----	-----	-----
Core Spray CSBD-1	CB&I	-----	-----	-----
CRD Return CRAD-1	CB&I	-----	-----	-----
Jet Pump Instrumentation JPAD-1	CB&I	-----	-----	-----

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company  
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT  
 Address: MONTICELLO, MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
<u>B3.90 &amp; B3.100</u>				
<u>Nozzle Inside Radius</u>				
Feedwater Nozzle	CB&I	-----	-----	-----
N4A				
N4B				
N4C				
N4D				
<u>B5.10 Nozzle To Safe End Welds</u>				
Head Vent	CB&I	-----	-----	-----
HVAF-2				
Head Spray	CB&I	-----	-----	-----
HSBF-2				
Core Spray	CB&I	-----	-----	-----
CSBF-2				



FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company  
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT  
 Address: MONTICELLO, MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
CRD Return CRAF-2	CB&I	-----	-----	-----
Standby Liquid Control CPAF-2	CB&I	-----	-----	-----
Jet Pump Instrumentation "B" JPBF-2	CB&I	-----	-----	-----
Instrumentation Lines (N11A) VIAF-2 (N11B) VIBF-2 (N12A) VICF-2 (N12B) VIDF-2	CB&I	-----	-----	-----
<u>B5.50 Safe End Welds</u>				
Core Spray "A" TW 7-8" EF CSP-90-7 CSAF-14 CSAF-18	Newport News/Bechtel		-----	-----

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company  
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT  
 Address: MONTICELLO, MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
Core Spray B (TW 11-8"EF) CSP-270-7 CSP-270-9 CSBF-12 CSBF-16	Newport News/Bechtel	-----	-----	-----
HPCI Steam (PS18-8"EF) PSAF-2B PSAF-2C	Bechtel	-----	-----	-----
Residual Heat Removal (REW 20-16"EF) (REW 30-16"DC) RHBF-20 RHBF-24 RHCF-20 RHCF-23	Bechtel	-----	-----	-----

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company  
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT  
 Address: MONTICELLO, MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
<u>PRESSURE RETAINING BOLTING</u>				
<u>B7.70 BOLTS, STUDS &amp; NUTS</u>				
Core Spray "A" Valves POS-1758 A014-13B	Bechtel	-----	-----	-----
Core Spray "B" Valves MO-1753	Bechtel	-----	-----	-----
High Pressure Coolant Injection-Steam Valve MO 2035	Bechtel	-----	-----	-----
Reactor Water Cleanup Valve MO 2398	Bechtel	-----	-----	-----

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company  
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT  
 Address: MONTICELLO, MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
Residual Heat Removal Valves MO 2029 MO 2014 MO 2026	Bechtel	-----	-----	-----
Standby Liquid Control Valve XP-8	Bechtel	-----	-----	-----
<u>B8.10 Integrally Welds Attachments</u>				
Reactor Vessel Support Skirt HCAH-2(120°-180°)	CB&I	-----	-----	-----

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company  
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT  
 Address: MONTICELLO, MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
<u>B9.11 &amp; B9.12 Circumferential &amp; Longitudinal Welds</u>				
Core Spray "A"	Bechtel	-----	-----	-----
CSAJ-19				
CSAJ-16				
CSAJ-17				
Core Spray "B"	Bechtel	-----	-----	-----
CSBJ-21				
CSBJ-22				
CSBJ-13				
CSBJ-14				
Residual Heat Removal "A"	Bechtel	-----	-----	-----
RHAJ-25				
RHAJ-26				
RHAJ-27				

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company  
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT  
 Address: MONTICELLO, MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
Residual Heat Removal "B" RHBJ-21 RHBJ-22	Bechtel	-----	-----	-----
Residual Heat Removal "C" RHCJ-21 RHCJ-22	Bechtel	-----	-----	-----
Residual Heat Removal "D" RHDJ-2	Bechtel	-----	-----	-----
Jet Pump Instrumentation "B" JPBJ-3	Bechtel	-----	-----	-----

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company  
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT  
 Address: MONTICELLO, MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
Jet Pump Instrumentation Cannister "B" Weld #1 Weld #2 Weld #3	Lamco	-----	-----	-----
Instrumentation Lines N11A  VIAJ-19	Bechtel	-----	-----	-----
<u>B9.21 &amp; B9.22 Circumferential &amp; Longitudinal Welds</u>				
Reactor Core Injection Coolant-Steam RSAJ-4 RSAJ-5	Bechtel	-----	-----	-----

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company  
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT  
 Address: MONTICELLO, MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
<u>B9.40 Socket Welds</u>				
Head Vent Welds	Bechtel	-----	-----	-----
50				
51				
58				
59				
Instrumentation Lines	Bechtel	-----	-----	-----
VIAJ-1				
VIAJ-2				
VIAJ-3				
Standby Liquid Control	Bechtel	-----	-----	-----
CPAJ-22				
<u>B11.10 Component Supports</u>				
Core Spray "A"	Bechtel	-----	-----	-----
CSAK-15				
Core Spray "B"	Bechtel	-----	-----	-----
CSBK-6				
Residual Heat Removal	Bechtel	-----	-----	-----
RHCK-9				
RHCK-10				



FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company  
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT  
 Address: MONTICELLO, MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
Reactor Core Injection Coolant RSAK-6	Bechtel	-----	-----	-----
Heat Vent HVAK-21	Bechtel	-----	-----	-----
Standby Liquid Control CPAK-20	Bechtel	-----	-----	-----
<u>B13.10 Vessel Interior</u>				
Core Spray Sparger System	GE	-----	-----	-----
Feedwater Sparger System	GE	-----	-----	-----
<u>B13.2 Vessel Interior Attachments</u>				
14 Shroud Support Welds	GE	-----	-----	-----

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company  
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT  
 Address: MONTICELLO, MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
<u>ASME CLASS II</u>				
<u>C1.10 Shell Circumferential Welds</u>				
RHR Heat Exchange (E-200A)	Bechtel	-----	-----	-----
<u>C2.20 Nozzles in Vessels over ½" thick</u>				
RHR Heat Exchange (E-200A)	Bechtel	-----	-----	-----
<u>C3.10 Integrally Welded Support Attachments</u>				
RHR Heat Exchanger (E-200A) Support "A" & "B"	Bechtel	-----	-----	-----

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company  
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT  
 Address: MONTICELLO, MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
<u>C3.20 Component Supports</u>				
RHR Heat Exchangers (E-200A) Support "A" & "B"	Bechtel	-----	-----	-----
<u>C3.40 Integrally Welded Support Attachments</u>				
Core Spray "A" CSAK-35	Bechtel	-----	-----	-----
<u>C3.50 Component Supports</u>				
High Pressure Coolant Injection Water Discharge SR-69 SS-35 CIAK-26 CIAK-27A CIAK-28	Bechtel	-----	-----	-----

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company  
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT  
 Address: MONTICELLO, MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
<u>C3.50(cont)</u>				
Core Spray "A" Suction TWH-53 TWH-54	Bechtel	-----	-----	-----
Core Spray "A" Discharge TWH-81 TWH-82 CSAK-31 CSAK-32A	Bechtel	-----	-----	-----
Core Spray "B" Suction TWH-55	Bechtel	-----	-----	-----
Core Spray "B" Discharge TWH-69 TWH-70 TWH-113	Bechtel	-----	-----	-----

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company  
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT  
 Address: MONTICELLO, MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
<u>C3.50(cont)</u>				
RCIC Water Suction TW-25	Bechtel	-----	-----	-----
RHR Service Water SWAK-25 SWAK-26 SWAK-31 SWAK-34 SWAK-43	Bechtel	-----	-----	-----
RHR "A" Suction SS-21 TWH-7 TWH-6 SS-24	Bechtel	-----	-----	-----

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company  
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT  
 Address: MONTICELLO, MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
<u>C3.50(cont.)</u>				
RHR"A" Discharge	Bechtel	-----	-----	-----
TWH-61				
TWH-63				
SS-25				
TWH-73				
RHR"B"Discharge	Bechtel	-----	-----	-----
TWH-100				
TWH-101				
TWH-102				
TWH-168				
SR-23				
<u>C3.70 Internally Welded Support Attachments</u>				
RHR Pumps(P202D)	Bechtel	-----	-----	-----
Support "D"				
Core Spray Pumps	Bechtel	-----	-----	-----
(14-1B)				
Support "B"				

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company  
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT  
 Address: MONTICELLO, MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
<u>C5.11&amp;C5.12 Circumferential &amp; Longitudinal Welds less than 1/2" Wall thickness</u>				
RHR"A"&"B" Discharge 16 369 270 25 348	Bechtel	-----	-----	-----
Core Spray"A" Suction 18 532	Bechtel	-----	-----	-----
Core Spray"A" Discharge 1 4 CSAJ-32	Bechtel	-----	-----	-----
RHR Service Water SWAJ-39 SWAJ-40	Bechtel	-----	-----	-----

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company  
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT  
 Address: MONTICELLO, MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
<u>C5.11 &amp; C5.12(cont.)</u>				
RHR"A"Suction 3	Bechtel	-----	-----	-----
Feedwater to Reactor Water Clean-up to High Pressure Coolant Injection W-1 W-2 W-3 W-4 W-12 W-12A	Bechtel	-----	-----	-----
Control Rod Drive to Reactor Water Clean-up W-7 W-11 W-12 W-13 W-14	Bechtel	-----	-----	-----



FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

(As Required by the Provisions of the ASME Code Rules)

- 1.) Owner: Northern States Power Company  
 Address: 414 Nicollet Mall, Minneapolis, Minnesota 55401
- 2.) Plant: MONTICELLO NUCLEAR GENERATING PLANT  
 Address: MONTICELLO, MINNESOTA 55362
- 3.) Plant Unit: 1 4.) Owner (Certificate of Authorization): --
- 5.) Commercial Service Date: 6-30-71 6.) National Board No. for Unit: --
- 7.) Components Inspected:

<u>Component or Appurtenance</u>	<u>Manufacturer or Installer</u>	<u>Manufacturer or Installer Serial No.</u>	<u>State or Province No.</u>	<u>National Board No.</u>
----------------------------------	----------------------------------	---	------------------------------	---------------------------

C5.21 & C5.22 Circumferential & Longitudinal Welds over 1/2" Wall Thickness

High Pressure	Bechtel	-----	-----	-----
Coolant Injection				
Water Discharge				
CIAJ-62				
CIAJ-29				
CIAJ-30				

C5.31 & C5.32 Branch Connections

RHR"A"Suction	Bechtel	-----	-----	-----
820				

FORM NIS-1(back)

8.) Examination Dates: 2/10/84 to 1/12/85

9.) Inspection Interval 6/30/81 to 6/30/91

10.) Abstract of Examinations

This was the second Inservice Inspection conducted in Inspection Period One of the Plant's second ten year interval. The examinations were performed on approximately 1/3 of the required examinations scheduled for inspection period one. The examinations were performed on pressure retaining components and supports of the reactor coolant and associated auxiliary systems classified as ASME Class I and II. Vessel interior visual examinations were performed on the core spray sparger system, feedwater sparger system and the shroud supports.

11.) Abstract of Conditions Noted

The following is a list of all anomalies detected.

<u>System</u>	<u>Item I.D.</u>	<u>Exam Method</u>	<u>Type&amp;number of Indications</u>
Core Spray"A"	A014-13B	VT	loose nut
	CSAK-35	VT	loose nut
	CSAK-31	VT	loose bolts
Core Spray"B"	CSP 270-7	UT	1 spot Indication
	TWH-69	VT	loose bolt
	TWH-70	VT	loose bolt
	TWH-113	VT	loose bolt
HPCI Steam	PSAF-2C	PT	Arc strike
RHR	RHBF-20	UT	1 spot Ind.,3 linear Ind.
	RHCF-20	UT	2 spot Ind.,2 linear Ind.
	RHBJ-21	UT	2 linear Ind.
	RHCJ-21	UT	multiple spot indications
	TWH-7	VT	loose bolt
	TWH-73	VT	loose bolt
	TWH-102	VT	loose bolt
Rx Support Skirt	HCAH-2	MT	9 linears
Jet Pump Instrumentation Canister"B"	W#1	UT	Multiple Axial indications
Head Vent	HVAK-21	VT	loose nut,bent rod hangar
Feedwater System	Spargers	VT	Crack indications on N4C & N4D
RHR Service Water	SWAK-25	VT	loose nut
	SWAK-26	VT	loose nuts
	SWAK-34	VT	loose nut

12.) Abstract of Corrective Measures Recommended and Taken

All anomalies with the exception of HVAK-21 were corrected. The bent rod hangar on HVAK-21 was evaluated and accepted as is. All loose nuts and bolts were tightened. The PT arc strike and MT linear indications were removed by surface blending with a hand grinder. All items containing UT indications except CSP 270-7 were replaced. CSP 270-7 was subsequently radiographed and the UT indication appeared to be a machining mark on the I.D. surface. This weld will be monitored in future outages. The feedwater spargers were also replaced after several crack indications were noted on two of the flow nozzles.

We certify that the statements made in this report are correct and the examinations and corrective measures taken conform to the rules of the ASME Code, Section XI.

Date March 27 19 85 Signed Northern States Power By J.F. Schanen  
Owner

Certificate of Authorization No. (if applicable) N/A Expiration Date N/A

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of MINNESOTA and employed by HSB I & I CO. of HARTFORD, CT have inspected the components described in this Owner's Data Report during the period 2-10-84 to 1-12-85, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owners' Data Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owners' Data report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Date March 27 19 85

A. A. Hughes  
Inspector's Signature

Commissions NB 9904 MN 85-34  
National Board, State,  
Province & No