

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
OFFICE OF INSPECTION AND ENFORCEMENT  
REGION III  
799 ROOSEVELT ROAD  
GLEN ELLYN, ILLINOIS 60137

Incident Notification From: Iowa Electric Light & Power 50-331  
(Licensee & Docket No. (or License No.))

Transmittal Date : October 20, 1975 Duane Arnold Center

Distribution:  
IE Chief, FC&EB  
IE:HQ (4)  
Licensing (4)  
DR Central Files  
IE Files

Distribution:  
IE Chief, FC&EB  
IE:HQ (4)  
L:D/D' for Fuels & Materials  
DR Central Files  
IE Files



NO-2

# IOWA ELECTRIC LIGHT AND POWER COMPANY

*General Office*

CEDAR RAPIDS, IOWA  
DUANE ARNOLD ENERGY CENTER

PALO, IOWA  
OCTOBER 14, 1975  
DAEC - 75 - 379

Mr. James G. Keppler, Director  
Office of Inspection and Enforcement-Region III  
U. S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

SUBJECT: Abnormal Occurrence Notification  
FILE: A-118a

Dear Mr. Keppler:

In accordance with DAEC Technical Specifications, Specification 6.11.2.A.1, this letter is a notification of an abnormal occurrence at the Duane Arnold Energy Center on October 13, 1975. This letter, telecopied to your office, is intended to satisfy the requirements for notification by telegram within 24 hours of an abnormal occurrence.

## Identification of Occurrence

Out-of-specification main steam line high flow switch, reportable in accordance with Appendix A to Operating License DPR-49, Specification 1.0.4.a.

## Description of Occurrence


During the performance of Surveillance Test No. 42A004 - Main Steam Line High Flow Instrument Functional Test and Calibration, PDIS 4432A was found to have a trip point of 120 psid. The limiting setpoint for operation is  $\leq 118$  psid ( $\leq 140\%$  flow).

At the time this notification was prepared, the surveillance test was not completed. If any additional switches are found to be out-of-calibration, they will be reported to the NRC by telephone.

Investigation of the occurrence is continuing.

A formal written report will be submitted to the Office of Inspection and Enforcement within 10 days of the subject abnormal occurrence.

Very truly yours,



G. G. Hunt  
Chief Engineer  
Duane Arnold Energy Center

DLW/GGH/mg  
75-52

cc: B. Rusche, D. Arnold, J. Wallace, L. Root, E. Hammond, B. York, D. Wilson,  
R. Rinderman, G. Cook, H. Rehrauer

RECEIVED  
DIVISION OF ACCOUNTING

1975 OCT 22 PM 2 33

U.S. NUCLEAR REGULATORY  
COMMISSION