

IOWA ELECTRIC LIGHT AND POWER COMPANY

General Office

CEDAR RAPIDS, IOWA
DUANE ARNOLD ENERGY CENTER

PALO, IOWA

JANUARY 17, 1975

DAEC - 75 - 21

Mr. James Keppler, Director
Regulatory Operations Regional Office
U. S. Atomic Energy Commission
79- Roosevelt Road
Glen Ellyn, Illinois 60137

SUBJECT: Abnormal Occurrence
FILE: A-118a
A-110

Dear Mr. Keppler:

In accordance with the DAEC Technical Specifications, Section 6.11.2A.1, this letter is intended as notification of an abnormal occurrence at the Duane Arnold Energy Center on January 17, 1975. This letter, telecopied to your office, is intended to satisfy the requirements for notification by telegram within 24 hours of an abnormal occurrence.

Identification of Occurrence

RHR A > B pressure differential indicating switch settings, reportable in accordance with Appendix A, Operating License DFR-49, Specifications 1.0.4.b and Table 3.2-B.

Description of Occurrence

During the performance of Surveillance Test Procedure No. 428017 - RHR A7B dP Across Riser Instrument Functional Test/Calibration (LPCI Loop Selection Logic) was determined that PDIS 4544 had a trip setting of 0.2 psid.

The Technical Specification Limit is $0.5 < p < 1.5$ psid. The switch was immediately recalibrated.

1/17/75 2 52 p Jee

1/17/75

As previously discussed with Mr. C. D. Feierabend of your office, the formal report on this abnormal occurrence will be included in the Supplemental Report for Abnormal Occurrence No.'s AO 50-331/74-48, 74-51 and 74-52.

Very truly yours,

E. L. Hammond

E. L. Hammond
Assistant Chief Engineer
Duane Arnold Energy Center

DLM:ELH:bh

CC: E. G. Case
C. M. Sandford
J. A. Wallace
G. G. Hunt
B. R. York
D. L. Wilson
R. E. Rinderman
L. D. Root
H. W. Rehrauer-Chairman, Safety Committee
G. A. Cook
B. L. Hopkins