



- NOTES:
1. FOR NOTES SEE DRAWING M-0034B.
 2. FIELD TO TERMINATE HOSE CONNECTION BELOW GRADE AND INSTALL AN EXTENSION PIPE AROUND VALVE.
 3. DELETED.
 4. PORTIONS OF THE DOMESTIC WATER SYSTEM (JUG PIPING IN THE WATER TREATMENT BLDG. MAY BE PVC PIPE LINE CLASS JKG WITH THE EXCEPTION OF 1/2" AND 3/4" JKG-47 AND 3/4" JKG-65 REF. MCP 95/1038).
 5. DESIGN CONTROLS DO NOT APPLY TO THIS SECTION OF PIPING.

- LEGEND:
- WH - WALL HYDRANT
 - CS - CURB STOP
 - YH - YARD HYDRANT
 - EDS - EMERGENCY DECONTAMINATION STATION - (SEE DETAIL "C" DWG. NUMBER M-0034B)
 - EDS-1 - HAWS MODEL 8600
 - EDS-2 - HAWS MODEL 8416
 - EDS-3 - HAWS MODEL 8417
 - EDS-4 - HAWS MODEL 8365-FP
 - SF - SERVICE FAUCET (INCLUDES VALVE W/HOSE CONNECTION)
 - PRV - PRESSURE REGULATING VALVE MUELLER TYPE OR EQUAL (SEE DETAIL "C" AND "D" DRAWING NO. M-0034B)
 - BPD - BACKFLOW PREVENTION DEVICE - (SEE DETAIL "B" DWG. NUMBER M-0034B)
 - WA - WATER HAMMER ARRESTOR

036	AS-BUILT PER EC'S 2180, AND 4666	SP	N/A	N/A	KMB	MM	3-5	-00
037	AS-BUILT PER DRN 06-470							
SIGN-OFF ON RECORD								
GRAND GULF NUCLEAR STATION UNIT 1 NUCLEAR PLANT ENGINEERING UPDATED FINAL SAFETY ANALYSIS REPORT FIGURE NUMBER - 9.2-013 P & I DIAGRAM DOMESTIC WATER SYSTEM UNIT 1								
COMMON - UNIT 1 CONTROLLED								
MPL No. SP66 1015M								
SCALE:	NONE	DRAWING No.	M-0034A			REV.	038	
DFN: m0034a.dgn								

COMPONENTS SUBJECT TO AMR
 NON-SAFETY RELATED SYSTEMS & COMPONENTS AFFECTING SAFETY RELATED SYSTEMS AMM20

NO.	DATE	DESCRIPTION	BY	ENG	CHK	APP
REVISIONS						
LRA-M-0034A						
DRAWING: m0034a.dgn						
REVISIONS						