



- NOTES:
1. FOR GENERAL NOTES SEE P & ID M-0035A.
 2. ALL PIPING, VALVES, CONTROLS, ETC. ARE SUPPLIED, DESIGNED AND INSTALLED BY THE CO₂ SYSTEM SUBCONTRACTOR, U.S.O.
 3. THESE SUPPRESSION SYSTEMS PROTECT AREAS IN THE UNIT 2 SIDE OF THE CONTROL BLDG. AND ARE NOT FUNCTIONAL FOR UNIT 1.
 4. UNIT 2 MAIN TANKS HAVE BEEN REMOVED AND THE HALON PANELS HAVE BEEN ABANDONED IN PLACE PER OG-CR-1997-0139-00 AND ER-GG-2003-0361.

COMPONENTS SUBJECT TO AMR
 FIRE PROTECTION CO₂ AND HALON SYSTEM AMM16

020	AS-BUILT PER EC-89145 (ER-GG-2003-0361, ERON-005)	SP	N/A	N/A	dh	CW	10-6-18
019	AS-BUILT PER DRN 05-1136	WE	N/A	N/A	SP	9-7-06	
GRAND GULF NUCLEAR STATION UNIT 1 NUCLEAR PLANT ENGINEERING UPDATED FINAL SAFETY ANALYSIS REPORT FIGURE NUMBER - 9.5-006							
P & I DIAGRAM FIRE PROTECTION SYSTEM UNITS 1 & 2							
SCALE:	NONE	DRAWING No.	M-0035F			REV.	020

NO.	DATE	DESCRIPTION	BY	ENG	CHK	APP
REVISIONS LRA-M-0035F CO2 FILE m0035f.dgn INSTR FILE						