



NOTE:
 1. FOR NOTES SEE DWG. M-1053C.
 2. THE PIPING UPSTREAM OF DRAIN VALVES F06A/B/C IS DUAL PURPOSE. IT IS USED FOR OXYGEN INJECTION DURING HWC SYSTEM (P73) OPERATION AND CAN BE USED FOR CONDENSATE SYSTEM DRAIN LINE DRAIN WHEN HWC SYSTEM OPERATION IS SECURED.

012	AS-BUILT PER EC 0992	SIP	N/A	N/A	W	MM	18-23
011	AS-BUILT PER EC 1484	SIGN-OFF	ON RECORD				

GRAND GULF NUCLEAR STATION
 UNIT 1
 NUCLEAR PLANT ENGINEERING
UPDATED FINAL SAFETY ANALYSIS REPORT
 FIGURE NUMBER - 10.4-010 (2 OF 2)
 P & I DIAGRAM
CONDENSATE SYSTEM UNIT I

SCALE:	NONE	DRAWING No.	M-1053E	REV.	012
--------	------	-------------	---------	------	-----

COMPONENTS SUBJECT TO AMR
 NON-SAFETY RELATED SYSTEMS & COMPONENTS AFFECTING SAFETY RELATED SYSTEMS AMM20

NO.	DATE	DESCRIPTION	BY	ENG	CHK	APP
REVISIONS						
LRA-M-1053E						
DRAWING FILE: m1053e.DGN						

D140