

8
7

Maier, Bill

From: Schwarz, Jon [jon.schwarz@nebraska.gov]
Sent: Sunday, June 26, 2011 8:28 AM
To: Berndt, Al; Canida Audie ; Fawl, Jodie; Hollingsead Greg; Imiler, Earl; Kirk Phil; Maier, Bill; McCabe Ron ; Newsham, Cindy; Ryan Laurel ; Valentine Norman ; Jansky, Doris; Jensen, Danielle; Loos, Jerry; Moon Guy; Willson, Ginger
Subject: FW: Daily event status at Fort Calhoun

FYI,

Outside of Scope

Jon

Jonathan (Jon) F. Schwarz
Technical Hazards Section Supervisor
Nebraska Emergency Management Agency
1300 Military Road
Lincoln, NE 68508-1090
Telephone: 402-471-7420
Cell: (b)(6)
Fax: 402-471-7433

005

From: BERCK, ALLEN [mailto:aberck@oppd.com]
Sent: Saturday, June 25, 2011 8:46 AM
To: Bill Pook; Dan; Eric Plautz; Jeff Clark; Jeff Theulen; Schwarz, Jon; Kathy Stodola; KIRKLAND, JOHN.NRC; Larry Oliver; Laurel Ryan; Paul Johnson; Whitney Shipley
Cc: BERCK, ALLEN; DEANGELIS, PETER A; HANKINS, RHONDA R; MOELLER, CHRISTOPHER J; RELLER, MARK H; SILKE, DEENA L
Subject: Daily event status at Fort Calhoun

Fort Calhoun Flooding Status (changes from yesterday's report are in **bold**)

Refer

1. Reactor Status: Shutdown
2. Reactor is covered with > 23-ft of cooling water
3. Offsite power and Emergency Diesel Generators are available. Both vital buses are energized at this time.
4. Spent Fuel Pooling cooling is in service and protected.
5. Shutdown cooling is in service and protected
6. **Current river level is 1006' 10" at Fort Calhoun Station** – the river has risen slightly over the last 24 hours. However, we are expecting another increase within the next 24-hrs based on increased flows from Gavins Point dam. **Heavy rains were received throughout the watershed basin last night, and additional rain is forecasted for today.**
7. **Current Blair gauge level is 32.6 ft.**
8. The site has implemented procedures to protect power supplies and vital equipment. Water is onsite, and flood barriers are protecting vital equipment.
9. No release of radioactivity has occurred.
10. Fort Calhoun has declared a Notification of Unusual Event at 08:00 6/6/11.
11. Backup evacuation route onsite is inundated however the primary route onsite is passable and not expected to be affected.

Information in this record was deleted
in accordance with the Freedom of Information
Act, exemptions
EOIA- 2411-1339

6/22

12. Power was removed from siren 257 and 260 in Pottawattamie Co. IA, which is just on the edge of the 10-mile EPZ south east of the plant. Siren 75, 76 in Desoto National Wildlife Refuge have no power. Currently the refuge is closed due to flooding. Siren 1 east of Fort Calhoun on county road 34 between Fort Calhoun and Boyer Chute Recreational Area is without power. This area is closed due to flooding. Power was removed to one additional siren in Washington County – sirens 69 was removed from service due to flooding and may require route alerting for any non-evacuated residents.
13. At this time no known major evacuation routes are affected without contingency actions planned. Interstate 29 in both directions: from Exit 54A (G Avenue) to Exit 71 (I-680 exit): I-680 road closed to traffic because of flooding -- follow the detour signs for the evacuation route to Bellevue. Interstate 680 in both directions: from before Exit 1 130th Street to Exit 62: I-29; Old Mormon Bridge Road --- road closed because of flooding.

Requested Information from states and counties:

1. When offsite evacuation routes are affected please contact emergency planning.
2. When the Blair Water plant is affected please contact emergency planning.
3. Authorized power outages that affect or could affect siren operability, please contact emergency planning.

The river flow rate and level have been relatively constant at Blair NE. The Corp of Engineers is releasing Gavin's Point dam at **160,000** cubic feet per second (cfs).

Emergency Planning Contacts at FCS:

Steve Gebers:

Pager: (b)(6)

Work Phone: 402-533-7308

Cell Phone: (b)(6)

Allen Berck:

Pager: (b)(6)

Work Phone: 402-636-2836

Cell phone: (b)(6)

Allen D. Berck

Supervisor - Emergency Planning

Fort Calhoun Station

Omaha Public Power District

phone: 402-533-6064

pager: (b)(6)

email: aberck@oppd.com

This e-mail contains Omaha Public Power District's confidential and proprietary information and is for use only by the intended recipient. Unless explicitly stated otherwise, this e-mail is not a contract offer, amendment, nor acceptance. If you are not the intended recipient you are notified that disclosing, copying, distributing or taking any action in reliance on the contents of this information is strictly prohibited.