



- NOTES:
1. ALL EQUIPMENT NUMBERS ON THIS DRAWING ARE PREFIXED BY NIP-43 UNLESS OTHERWISE NOTED.
 2. ALL INSTRUMENT NUMBERS ON THIS DRAWING ARE PREFIXED BY IP-43 UNLESS OTHERWISE NOTED.
 3. DELETED
 4. ALL PIPING 2" AND SMALLER IS CLASSIFIED AS III "A" RADIATION LEVEL.
 5. TWO COOLERS ARE REQUIRED DURING PLANT STARTUP.
 6. ALL START-UP STRAINERS SHALL BE REPLACED BY RING SPACERS IN ACCORDANCE WITH THE LATEST REVISION OF 9645-MS-03 GENERAL NOTE 17.

COMPONENTS SUBJECT TO AMR
 NON-SAFETY RELATED SYSTEMS &
 COMPONENTS AFFECTING SAFETY
 RELATED SYSTEMS AMM20

026	AS-BUILT PER ER 96/0678-00-00	C	N/A	N/A	JL	5-28-98
025	AS-BUILT PER DCP 89/0001 & CN 89/0367	PLG	N/A	N/A	CH	11-95

GRAND GULF NUCLEAR STATION
 UNIT 1
 NUCLEAR PLANT ENGINEERING
UPDATED FINAL SAFETY ANALYSIS REPORT
 FIGURE NUMBER - 9.2-024
 P & I DIAGRAM
 TURBINE BUILDING COOLING WATER SYSTEM

MPL No. 1P43 1015M
 SCALE: NONE
 DRAWING No. M-1062A
 REV. 026
 HYBRID DFN: m1062a.dgn

NO.	DATE	DESCRIPTION	BY	ENG	CHK	APP
REVISIONS						
LRA-M-1062A						
CAD FILE: m1062a.dgn						
PLOT FILE: m1062a.dgn						

D161