



9. No release of radioactivity has occurred.

10. Fort Calhoun has declared a Notification of Unusual Event at 08:00 6/6/11.

11. Backup evacuation route onsite is inundated however the primary route onsite is passable and not expected to be affected.

12. 9 sirens remain with no AC power. Power has been removed from siren 259, 257 and 260 in Pottawattamie County IA. Power has been removed from sirens 143 and 135 in Harrison County, IA. Power has been removed from sirens 1, 69, 75, 76 in Washington County, NE. Power was removed from these sirens due to flooding in the surrounding areas. The coverage areas for these sirens has been reviewed with state and county agencies. For those residents that do remain in these areas, the counties are responsible for route alerting.

13. The Reception and Care Center in Fremont is now official, replacing Bellevue; no evacuation routes to that location are affected at this time.

14. At this time no known major evacuation routes are affected without contingency actions planned. Interstate 29 in both directions: from Exit 54A (G Avenue) to Exit 71 (I-680 exit): I-680 road closed to traffic because of flooding. I-680 is closed in both directions: from before Exit 1 130th Street to Exit 62: I-29; Old Mormon Bridge Road --- road closed because of flooding.

Requested Information from states and counties:

1. When offsite evacuation routes are affected please contact emergency planning.
2. When the Blair Water plant is affected please contact emergency planning.
3. Authorized power outages that affect or could affect siren operability, please contact emergency planning.

The river flow rate and level have been relatively constant at Blair NE. The Corp of Engineers is releasing Gavin's Point dam at 160,200 cubic feet per second (cfs).

Emergency Planning Contacts at FCS:

Steve Gebers:

Pager: (b)(6) X 6

Work Phone: 402-533-7308

Cell Phone: (b)(6) X 6

Allen Berck:

Pager: (b)(6) X 6

Cell phone: (b)(6) X 6

Allen D. Berck  
Supervisor - Emergency Planning  
Fort Calhoun Station  
Omaha Public Power District  
phone: 402-533-6064  
pager: (b)(6)  
email: [aberck@oppd.com](mailto:aberck@oppd.com)