

onsite, repair efforts are underway. This section of the AquaDam is expected to be replaced in the next two weeks.

10. The site has implemented procedures to protect power supplies and vital equipment. Water is onsite, and flood barriers are protecting vital equipment.

11. No release of radioactivity has occurred.

12. Fort Calhoun has declared a Notification of Unusual Event at 08:00 6/6/11.

13. Backup evacuation route onsite is inundated however the primary route onsite is passable and not expected to be affected.

14. Power was removed from siren 257 and 260 in Pottawattamie Co. IA, which is just on the edge of the 10-mile EPZ south east of the plant. Siren 75, 76 in Desoto National Wildlife Refuge have no power. Currently the refuge is closed due to flooding. Siren 1 east of Fort Calhoun on county road 34 between Fort Calhoun and Boyer Chute Recreational Area is without power. This area is closed due to flooding. Power was removed to one additional siren in Washington County - sirens 69 was removed from service due to flooding and may require route alerting for any non-evacuated residents. Power was removed from siren 259. This siren is located in Pottawattamie County on DeSoto Trail, west of 110th street. County to verify evacuation route alerting capability if needed. Power has been removed from sirens 143 and 144 in Pottawattamie Co. IA due to flooding. This area has been evacuated and is not populated.

15. The Reception and Care Center in Fremont is now official, replacing Bellevue. This has been planned for quite some time, but also provides us with greater protection for the public, as no evacuation routes to that location are affected at this time.

16. At this time no known major evacuation routes are affected without contingency actions planned. Interstate 29 in both directions: from Exit 54A (G Avenue) to Exit 71 (I-680 exit): I-680 road closed to traffic because of flooding. I-680 is closed in both directions: from before Exit 1 130th Street to Exit 62: I-29; Old Mormon Bridge Road --- road closed because of flooding. Highway 30 from Blair to Missouri valley is re-opened; flood barrier work will restart on Tuesday, but does not impact evacuation routes.

Requested Information from states and counties:

1. When offsite evacuation routes are affected please contact emergency planning.
2. When the Blair water plant is affected please contact emergency planning.
3. Authorized power outages that affect or could affect siren operability, please contact emergency planning.

FW Daily Event Statut at Fort Calhoun 7-2.txt

The river flow rate and level have been relatively constant at Blair NE. The Corp of Engineers is releasing Gavin's Point dam at 160,300 cubic feet per second (cfs).

Emergency Planning Contacts at FCS:

Steve Gebers:

Pager: (b)(6) FAX

Work Phone: 402-533-7308

Cell Phone: (b)(6) FAX

Allen Berck:

Pager: (b)(6)

Cell phone: (b)(6) FAX

This e-mail contains Omaha Public Power District's confidential and proprietary information and is for use only by the intended recipient. Unless explicitly stated otherwise, this e-mail is not a contract offer, amendment, nor acceptance. If you are not the intended recipient you are notified that disclosing, copying, distributing or taking any action in reliance on the contents of this information is strictly prohibited.