

January 11, 2012

REGIS T. REPKO Vice President McGuire Nuclear Station

Duke Energy MG01VP / 12700 Hagers Ferry Rd. Huntersville, NC 28078

980-875-4111 980-875-4809 fax regis.repko@duke-energy.com

10 CFR 50.55a

U.S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, DC 20555-0001

Subject: Duke Energy Carolinas, LLC (Duke Energy) McGuire Nuclear Station, Unit 2 Docket No. 50-370 Relief Request Serial # 12-MN-002 Limited Weld Examinations during Refueling Outage 2EOC20

Pursuant to 10 CFR 50.55a(g)(5)(iii), Duke Energy hereby requests NRC approval of relief for the weld listed in Table 1 of the proposed relief request. This weld was required to be examined in accordance with Inservice Inspection Plan for McGuire Unit 2, Third 10-Year Inservice Inspection Interval. The details of the request are included in the enclosure.

This submittal contains no regulatory commitments.

If you have any questions or require additional information, please contact P.T. Vu at (980) 875-4302.

Sincerely,

T. BA

Regis T. Repko

Enclosure

AD47 NRR

U. S. Nuclear Regulatory commission January 11, 2012 Page 2

xc:

٠

٢

1

V. M. McCree, Region II Administrator U. S. Nuclear Regulatory Commission Marquis One Tower 245 Peachtree Center Ave., NE Suite 1200 Atlanta, GA 30303-1257

J. H. Thompson, Project Manager U. S. Nuclear Regulatory Commission 11555 Rockville Pike Mail Stop O-8G9A Rockville, MD 20852-2738

.

J. Zeiler NRC Senior Resident Inspector McGuire Nuclear Station

ENCLOSURE

٢

£

Relief Request 12-MN-002

.

1.0 Scope of Relief Request

1

r

Relief is requested pursuant to 10 CFR 50.55a(g)(5)(iii) for the weld listed in Table 1. This weld was required to be examined in accordance with Inservice Inspection (ISI) Plan for the following Unit:

McGuire Nuclear Station – Unit 2 Third 10-Year ISI Interval Interval Start Date: 03/01/2004

			Table 1		······
Relief Request Section Number	<u>McGuire</u> <u>Unit</u> <u>Numbe</u> r	Examination Performed (Refueling Outage)	<u>Weld ID</u> <u>Number</u>	<u>Item/Summary</u> <u>Number</u>	Examination Data
2.0	2	2EOC20	2NV2FW216- 60	M2.R1.11.0276	See Attachment A Pages 1-6

2.0 Weld #2NV2FW216-60

2.1 ASME Code Component(s) Affected

Unit 2, Pipe to Pipe Weld #2NV2FW216-60, Summary Number M2.R1.11.0276.

2.2 Applicable Code Edition and Addenda

ASME Boiler and Pressure Vessel Code, Section XI, 1998 Edition through the 2000 Addenda.

2.3 Applicable Code/Licensing Requirement

WCAP-14572, Rev. 1-NP-A, Supplement 2, Table 4.1-1, Examination Category R-A, Item Number R1.11, Figure IWB-2500-8(c), 100% Volume Coverage of Examination Volume C-D-E-F.

The NRC authorized the inclusion of the Risk Informed ISI program as an acceptable alternative to the ASME Code, Section XI requirements for ASME Code Class 1 piping welds, Examination Categories B-F and B-J and ASME Code Class 2 piping welds, Examination Categories C-F-1 and C-F-2 for the third ISI interval by letter dated 06/12/2002.

2.4 Impracticality of Compliance

Surface 1: Stainless Steel Pipe Surface 2: Stainless Steel Pipe Nominal Pipe Size: 2.0 inch Thickness: 0.344 inch

The limitations were due to proximity of a permanent welded pipe support that did not allow complete scanning from the pipe side (Scan 2). Scanning requirements are described in 10 CFR 50.55a(b)(2)(xv)(A)(1). The aggregate coverage was calculated as follows:

- 70° shear waves obtained 76.5% coverage in one axial direction (Scan 1- pipe).
- 70° shear waves obtained 53.0% coverage in one axial direction (Scan 2 – pipe).
- 45° shear and longitudinal waves obtained 76.5% coverage in one circumferential direction (Scan 3 clockwise).
- 45° shear and longitudinal waves obtained 76.5% coverage in one circumferential direction (Scan 4 counterclockwise).
- The aggregate coverage was calculated to be (76.5% + 53.0% + 76.5% + 76.5%)/4 = 70.625%.

In order to scan all of the required volume for this weld, the permanent welded pipe support would have to be redesigned to allow scanning from both sides of the weld, which is impractical. The McGuire ISI Plan allows the use of Code Case N-460, which required greater than 90% volumetric coverage of examination volume C-D-E-F. Therefore, the available coverage will not meet the acceptance criteria of this Code Case.

2.5 Proposed Alternative and Basis for Use

F

No alternative examinations are planned for the weld during the current inspection interval. Radiography (RT) is not a desired option because RT is limited in the ability to detect expected degradation mechanisms such as thermal fatigue cracking and stress corrosion crack initiating at the pipe inside surface. Additionally, RT has not been qualified through performance demonstrations.

2.6 Duration of Proposed Alternative

This request is for the duration of the third ISI interval, currently scheduled to end on 07/15/2014.

2.7 Justification for Granting Relief

Ultrasonic examination of the weld for the Item Number M2.R1.11.0276 was conducted using personnel, equipment and procedures qualified in accordance with ASME Section XI, 1998 Edition with the 2000 Addenda.

The system leakage test performed each inspection period in accordance with Table IWC-2500-1, Examination category C-H requires a VT-2 visual examination to detect evidence of leakage. This test and VT-2 examination provide additional assurance of pressure boundary integrity.

In addition to the above Code required examinations (volumetric and pressure test), Reactor Building Normal Sump monitoring provides additional assurance that, in the event that leakage did occur through this weld, it would be detected and proper action taken.

Duke Energy has examined the weld/component to the maximum extent possible utilizing approved examination techniques and equipment. Based on the acceptable results for the coverage completed by the volumetric examination, the pressure testing (VT-2) examinations required by Section XI, and the leakage monitoring, it is Duke Energy's position that the combination of examinations provides a reasonable assurance of quality and safety.

l o cne	v 9 J.	Site/Unit:	McGuire	1	2		Proce	edure:		PDI-UT-2			Outage	No.:	M2-20
	Sumr	nary No.:	M2.	R1.11.0276		_	Procedura	Rev.:		E			Report	No.: (T-11-159
	Wa	nkscope:		ISI		_	Work Orde	r No.:		01929201			P	age: 1	of
Code:		1998/2000	Addenda		Cat.	/Item:	R-A/R1.1	1		Location:			Rx Bidg.		
Drawing No.:		N	ICFI-2NV216			Description:	Pipe To Pl	pe							
System ID:	NV														
Component ID:	2NV2FW21	6-60	<u></u>					44.44999999999999999999999999999999999	Size/l	.ength:	N/A		Thickness/Di	ameler.	.344/2.0/5
Limitations:	Yes - See a	ttached sh	eets (welded pl	e support)		·····				Start	Time:	1613	Finis	h Time:	1642
	Instrume	nt Settings			S	earch Unit		Cal	Time	Data		Aria	Orientated S	iearch Unit	
Serial No.:		011MB	T	Serial No.	:	00DBVW		Checks	Time	Date	Calib	ration	Signat	Sweep	1
Manufacturer:		KRAUTKR	AMER	Manufactu	irer:	KBA		Initial Cal	1245	3/1/2011	Refi	ector	Amplitude %	Division	Sound P
Model:		USN-6	0	Size:	0.25	Shape:	Round	Inter. Cal.	1540	91412044	ID N	lotch	. 81	4.5	.446
Delay:	6.2497	Range:	1.0	Freq.:	5 MHz	Style:C	omp - G	Inter Cal	1012	3/1/2011					
M'll Cal/Vel:	.123	Pulser:	High	Exam Ang	le:4	5 # of Eleme	ints: JINGLE	Final Cal	1906	3/1/2011					-
Damping:	1K	Reject:		Mode:		SHEAR		ليستنت ستنتشب ا	ounlan		┣				
Rep. Rate;	Autonign	Mode:	 	Measured	Angle:	45		Col Boleby	, , ,				antial Orienta	tad Saarak	1
rater:	Fixed	Other	Fullwave	wedge St	yıe:	MSWQC		Cal. Balch;		GEL 11	0-11	Circumer	onnal Orienta	Contraction of the second seco	1
vollage.	35.7	Cito Gain	(dB): 52.5	-	Seam	h Unit Cable		Mfo ·	SONO	TECH	Refle	ector /	Signal Amplitude %	Sweep Division	Sound P
	10	in of	Sound Path		Court	RG-174					ID N	otch	.81	5,4	.540
- Scieen Di		···· 01	0.05	Length:	6'	No. Conn.:	0	Exam Baicr		09325 GEL N					
леату кероп	NO.:	L•11	-085		Scau	1 Coverage		Mfa.:	SONO	TECH					ļ
	Calibrati	on Block		Uostream (stream [2] Scan	dB: 41.4								<u> </u>
Cal. Block ND.	0.244	8219-04 Dia •	2 375	- cw i	3	CCW Z Scan	dB: 52.5	Refe	rence B	lock	Gain	Kere	Sional	Sweep	
	72 Temp		2.070 MCNDE40129		ace.	00		Serial No.:	97	-5590	dB	Reflector	Amplitude %	Division	Sound Pa
	67 Temp		MCNDE40129	Surface Co	andition:	Smool		Туре:	ROM	PAS	52.5	FSDH	80	9.6	.962
Somp. remp.		Ver (No 67	 (if Yes_Ref.	Attached	Litrasonic Indica	tion Report.)	1				<u> </u>	+		
		Bologt		(ii i co, i icii) nfo. □					Cor	i nments: Initi	ial Sectiv		<u></u>	- <u>I</u>	
(esulis: A	Accept []	појец	M	ш.					1				•		
Percent Of Cover	rage Obtaine	d > 90%:	No	Reviewed	Previous	Data: N			=						
Examiner	Level jj.	-N		Signature		Da 3/1/201	te Review	er Lie	Lo	user		Signati	Ure	3-9.	
xaminer	Level n.	N	1 min	Signature		Da	ite Site Re	View	<u>N</u>		<u> </u>	Signat	/ne		Dat
ester, Robert M	а. — т.		obf M	Jes Qu		3/1/201	11		Λ	1					
Other	Level N	1A 1	Ş	Signature		Da	te ANII Re	eview	11 -	-/		Signatu	ne	<i>.</i>	Dat
N/A		1							15	wan	<u> </u>	3.	-15-1	/	

-

•

.

ATTACHMENT A Page / OFG

......

.

.

. .

Du Du	7				UT	Calibrati	ion ^{,,} n	ninatio	n							
(ø Ene	⇒ .	Site/Unit:	McGuire	1	2		Proc	edure:		PDI-UT-2			Outage	No.:	M2-20	
	Sur	nma ry No.:	M2	.R1.11.0276			Procedure	Rev.:		E			Report	No.: 1	JT-11-15	9
	v	Vorkscope:	·····	ISI		· · · · · · · · · · · · · · · · · · ·	Work Orde	er No.:		01929201			P	age: Z	of	6
Code:	<u></u>	1998/2001) Addenda		Ca	t./item:	R-A/R1.1	1		Location:			Rx Bldg.			
Drawing No.:			MCFI-2NV216	*.		Descriptio	n: Pipe To Pi	pe								
System ID:	NV						-		·							
Component ID:	: 2NV2FW	216-60							Size/	Length:	N/A		Thickness/Di	ameler:	0.344/2.0	ISS
Limitations:	Yes - See	e attached s	heets (welded pi	pe support)				<u></u>		Start	Time:	1630	Finis	h Time;	1642	
	Instrun	nent Setting				Search Unit				 						
Serial No.:		011M	BT	Serial No.	:	000C6V	v	Checks	Time	Date		Axia	I Orientated S	earch Uni	t 	
Manufacturer:	` <u></u>	KRAUTK	RAMER	Manufact	mer;	KBA	<u>\</u>	Initial Cal	1312	3/1/2011	Refle	abon ector	Signal Amplitude %	Sweep Division	Sound	Path
Model:		USN-	60	Size:	0.25	Shape:	Round	Inter, Cal.	ļ		ID N	otch	B1	3.9	.95	2
Delay:	6.7906	Range:	2.5	Freq.:	2.25 MH	z Style:	Comp - G	Inter. Cal.	1630	3/1/2011						
M'tl Cal/Vel:	.123	Pulser:	High	Exam Ang	jle:	70 # of Ele	ments: JINGLE	Inter. Cal.	4005	DI di OD d d						
Damping:	1К	Reject	D%	Mode:		SHEAR		Final Car	1 1905	3/1/2011	ļ					
Rep. Rate:	Autohigh	_ Freq.:	2.25	Measured	Angle:	6	7		Couplai	nt	 		1		<u> </u>	
Filter:	Fixed	Mode:	PE	Wedge St	yle:	MSWO	<u>)C</u>	Cal. Batch:		09325		Circumfe	rential Orienta	ted Searc	h Unit	
Voltage:	Fixed	Other:	Fullwave		_			Туре:	ULTR/	AGEL II	Calibr	ation	Signal Amplihuda %	Sweep	Sound	Path
Ax. Gain (dB):	61.0	Circ. Gat	n (dB): <u>N/A</u>		Sea	rch Unit Cable		Mrg.:	SONO	отесн						
1 Screen D)iv. ≈ .25	in. of	Sound Path	Type:	i	RG-174		Exam Batch	h:	09325	<u> </u>	<u> </u>				
Linearity Repor	t Na.:	L-1	1-085	Length; _	<u> </u>	No. Conn.:	0	Type:	ULTR/	GEL N	<u> </u>			- <u></u>		
	Calibr	ation Block			Sci	an Coverage		Mfg.:	SONO	TECH				·		
Cal. Block No.		8279-0	41D	Upstream	Dow 🖸	nstream 🔽 So	an dB: <u>58.0</u>	Refe	erence E	Block		Ref	erence/Simula	tor Block		
Thickness	0.344	Dia.:	2.375	CW		ccw 🗌 sa	an dB: <u>N/A</u>	Serial No.:	9	7-5590	Gain	Rafacto	Signal	Sweep	Sound	Path
Cal. Blk. Temp.	. 72 Ten	np. Tool:	MCNDE40129	Exam Sur	lace:	1.0)	Type:	RON	APAS	52.6	NSDH	8D	3.8	.95(0
Comp. Temp.	67 Ten	np. Tool:	MCNDE40129	Surface C	ondition:	Sm	ooth							1		
Recordable in	dication(s):	Yes	□ Nº 🗹	(if Yes, Ref.	Attache	d Ultrasonic Ind	lication Report)						1		
Results:	Accept] Reje	ct 🖌	Info 📋					Co	mments: Init	ial Sectio	on XI Exa	m	ł		
Percent Of Cov	rerage Obtai	ined > 90%:	No	Reviewed	Previou	s Data:	Na		(
Examiner	Level	(I-N		Signature	27		Date Review	ver ME	11	7.04.0		Signal	ture	र २	0	Jale
Ellis II, Kenne	th R.		- charter	Stanhturn		3/1	Date Sile D	A A A A A A A A A A A A A A A A A A A	0	www		Simel	hine .	J.1	<u> </u>	
Examiner Lester, Robert	Level M.	11-N	Word M &	L'AL		3/1/	2011	UT 10 IV	A	0		ugna				
Other	Level	N/A		Signature			Date ANII R	eview	//			Signat	ure	· , ,	0	ale
N/A		1		·····				7	IE	Jua	n		5-15	<u>- 1/</u>		
								- 0								

•

ATTACHMENT A PAGE 3 OF 6

~

	ISI LIMITAT	ION REP	ORT			
Component/Weld ID: _2NV2FW	216-60 Ite	m No: <u>M2.</u> F			remarks:	<u></u>
NO SCAN	SURFACE	BEA	M DIRECTIO	N	Due to welded pipe s	upport.
LIMITED SCAN	1 2	21	🗋 2 🛛 cw	🖾 ccw		· ·
FROM L 0 to L+/-1.7	100 INCHES		CL to	Beyond		
ANGLE: 0 0 45 60	other <u>70°</u>	FROM N	A DEG to	N/A DEG		
NO SCAN	SURFACE	BEA	M DIRECTION	N		
LIMITED SCAN	1 2	1] 2 🗌 cw	🗌 ccw		
ROM L to L	INCHES FF	ROM WO	to			
NGLE: 0 0 45 0 60	other	FROM	DEG to	DEG		
NO SCAN	SURFACE	BEA	M DIRECTION	1		
LIMITED SCAN	1 2	1] 2 🗌 cw	ccw		<u>.</u>
ROM L to L	INCHES FF	ROM WO	to			
NGLE: 0 0 45 0 60	other	FROM	DEG to	DEG		3
NO SCAN	SURFACE	BEAN	M DIRECTION	J	-	
LIMITED SCAN	1 2] 2 🗌 .cw	🗌 ccw	UT-11-159	······
ROM L to L	INCHES FR	OM W0	to		Sketch(s) attac	ched
4 NGLE: □ 0 □ 5 □ 60	other	FROM	DEG to	DEG	🛛 yes	🗌 No
repared By: Kenneth Ellis	Level:	ll Date:	03/01/11	Shee	<u>3</u> of <u>6</u>	······································

, ÷1

 $\pm 1^{\circ}$: : . . :

 * at : F : i ii р

. .

AGGREGATE COVERAGE SHEET

Angle/Scan	% Length	% Volume	% Coverage
15° - Scan 1	53.0	100	55.0
70° - Scan 1	47.0	50	23.5
ggregate Covera	ige		76.5
70% Crop 2	63.0	100	53.0
70° - Scan 2	47.0	100	0.0
Aggregate Cover			53.0
AGBICBUIC COTON	-6+		
45° - Scan 3	53.0	100	53.0
45° - Scan 3	47.0	50	23.5
Aggregate Cover	age	•	76.5
45% Casa 4	620	100	53.0
45" - Scan 4	53.0	100	23.5
40 - Scan 4	1 47.0	1 20	76.5

• ·

3/1/2011 Contl. USZ

Page 4 of 6

· ...

PAGE 4 OF 6 ATTACHMENT A

··· •·.

. .-

· ·

•



Scale : 1" = 1"

% Coverage Calculations

Total	= 2	82.5/4	= <u>70.6 %</u> Aggregate Coverage
S4 = CCW	=	76.5%	(100% of the length x 76.5% of the volume)
S3 = CW	=	76.5%	(100% of the length x 76.5% of the volume)
S2 = Pipe =		53%	(100% of the length x 53% of the volume)
S1 = Pipe	-	76.5%	(100% of the length x 76.5% of the volume)

Inspector / Date: Inspector / Date: 1/1/1/

ì

:

Page 5 of 6

PABE

0 F

ATTACHMENT A



Determination of Percent Coverage for UT Examinations - Pipe

Site/Unit:	McGuire /	2	Procedu	re:PDI-UT-2	Outage No.:		12-20	
nary No.:	M2.R1.11	.0276	Procedure Re	v.: <u>E</u>	Report No.;	UT-11-159		
orkscope:	151	<u></u>	Work Order N	o.: 01929201	_ Page:	6	of	6
<u>45 deg</u>								
Scan 1		% Length X		% volume of length / 100 =	(% total f	or Scan	1
Scan 2		% Length X	······································	% volume of length / 100 =		% total f	or Scan	2
Scan 3	100.000	% Length X	76.500	% volume of length / 100 =	76.500	% total f	or Scar	13
				Number of leastly 1400 -			or Scar	
Scan 4	Add totals and	% Length X _	76.500	% volume of length / 100 =	76.500	76 10121 }	,	
Scan 4 Other de	Add totals and	% Length X _ I divide by # scar	76.500 18 = <u>76.500</u> supplemental sc	% volume of length / 100 = % total for 45 deg	76.500	76 10121)	,	
Scan 4 <u>Other de</u> The data	Add totals and	% Length X I divide by # scan I divide by # scan (to be used for w is for coverage	76.500 ns = 76.500 supplemental so that was not obt	% volume of length / 100 = _ % total for 45 deg cans) alned with the 45 deg scans.	76.500	76 10121)	,	
Scan 4 <u>Other de</u> The data Scan 1	<u>100.000</u> Add totals and <u>100.000</u> <u>100.000</u>	// Length X // Length X // Length X // Length X	76.500 ns =	% volume of length / 100 = % total for 45 deg cans) alned with the 45 deg scans. % volume of length / 100 =	76.500	_% tota	, I for Sci	an '
Scan 4 Other de The data Scan 1 Scan 2	<u>100.000</u> Add totals and <u>99 - 70</u> to be listed belo <u>100.000</u>	<pre>% Length X</pre>	76.500 ns =	% volume of length / 100 = % total for 45 deg alned with the 45 deg scans. % volume of length / 100 = % volume of length / 100 =	76.500	_% tota _% tota	i for Sci	an
Scan 4 Other de The data Scan 1 Scan 2 Scan 3	<u>100.000</u> Add totals and <u>a - 70</u> to be listed belo <u>100.000</u>	% Length X I divide by # scar	76.500 ns =	% volume of length / 100 = % total for 45 deg cans) alned with the 45 deg scans. % volume of length / 100 = % volume of length / 100 = % volume of length / 100 =	76.500	_ % tota _ % tota _ % tota	l for Sci l for Sci l for Sc	an ' an : an :

Add totals for each scan required and divide by # of scans to determine;

70.625 % Total for complete exam

Punik K. Z. TIL Site Fletd Supervisor:

Date: 03/08/11