

UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D.C. 20555-0001

February 24, 2012

Christopher L. Burton, Vice President Shearon Harris Nuclear Power Plant Progress Energy Carolinas, Inc. Post Office Box 165, Mail Code: Zone 1 New Hill, North Carolina 27562-0165

SUBJECT: SHEARON HARRIS NUCLEAR POWER PLANT, UNIT 1 – EXEMPTION REGARDING USE OF M5[™] ALLOY FUEL ROD CLADDING (TAC. NO ME5410)

Dear Mr. Burton:

The U.S. Nuclear Regulatory Commission has approved the enclosed exemption from certain requirements of Title 10 of the *Code of Federal Regulations*, Part 50, Section 50.46, "Acceptance criteria for emergency core cooling systems for light-water nuclear power reactors," and Appendix K to 10 CFR Part 50, "ECCS [Emergency Core Cooling System] Evaluation Models," for Shearon Harris Nuclear Power Plant (HNP), Unit 1.

This action is in response to your application dated January 19, 2011 (Agencywide Documents Access and Management System Accession No. ML110250473), requesting the exemption to allow the use of M5[™] alloy fuel rod cladding at HNP, Unit 1.

A copy of the exemption is enclosed. The exemption has been forwarded to the Office of the Federal Register for publication.

Sincerely,

Uhardi T. Billooh lali

Araceli T. Billoch Colón, Project Manager Plant Licensing Branch II-2 Division of Operating Reactor Licensing Office of Nuclear Reactor Regulation

Docket No. 50-400

Enclosure: Exemption

cc w/enclosure: Distribution via ListServ

U.S. NUCLEAR REGULATORY COMMISSION [NRC-20XX-XXXX] CAROLINA POWER & LIGHT COMPANY SHEARON HARRIS NUCLEAR POWER PLANT, UNIT 1 DOCKET NO. 50-400 EXEMPTION

1.0 BACKGROUND

Carolina Power & Light Company, the licensee, doing business as Progress Energy Carolinas Inc., is the holder of Renewed Facility Operating License No. NPF-63, which authorizes operation of the Shearon Harris Nuclear Power Plant (HNP), Unit 1. The license provides, among other things, that the facility is subject to all rules, regulations, and orders of the U.S. Nuclear Regulatory Commission (NRC, the Commission) now or hereafter in effect. The facility consists of one pressurized-water reactor (PWR) located in New Hill, North Carolina.

2.0 REQUEST/ACTION

Title 10 of the *Code of Federal Regulations* (10 CFR), 50.46, "Acceptance criteria for emergency core cooling systems for light-water nuclear power reactors," requires, among other items, that each boiling or pressurized light-water nuclear power reactor fueled with uranium oxide pellets within cylindrical zircaloy or ZIRLO cladding must be provided with an emergency core cooling system (ECCS) that must be designed so that its calculated cooling performance following postulated loss-of-coolant accidents (LOCAs) conforms to the criteria set forth in paragraph (b) of this section. Appendix K to 10 CFR Part 50, "ECCS Evaluation Models," requires, among other items, that the rate of energy release, hydrogen generation, and cladding oxidation from the metal/water reaction shall be calculated using the Baker-Just equation. The

regulations of 10 CFR 50.46 and 10 CFR Part 50, Appendix K, make no provisions for use of fuel rods clad in a material other than zircaloy or ZIRLO.

The licensee intends to load the M5[™] cladding fuel assemblies into the core of HNP, Unit 1 during Refueling Outage 17, currently scheduled for spring 2012. The AREVA fuel design consists of low enriched uranium oxide fuel within M5[™] zirconium alloy cladding. Since the chemical composition of the M5[™] alloy differs from the specifications for zircaloy or ZIRLO, a plant-specific exemption is required to allow the use of the M5[™] alloy as a cladding material or in other assembly structural components. Therefore, by letter dated January 19, 2011 (Agencywide Documents Access and Management System Accession No. ML110250473), the licensee requested an exemption from the requirements of 10 CFR 50.46 and Appendix K to 10 CFR Part 50 in order to use the fuel rods clad with AREVA's M5[™] alloy.

3.0 DISCUSSION

Pursuant to 10 CFR 50.12, the Commission may, upon application by any interested person or upon its own initiative, grant exemptions from the requirements of 10 CFR Part 50 when (1) the exemptions are authorized by law, will not present an undue risk to public health or safety, and are consistent with the common defense and security; and (2) when special circumstances are present.

Authorized by Law

This exemption would allow the use of M5[™] advanced alloy, in lieu of zircaloy or ZIRLO, for fuel rod cladding in fuel assemblies at HNP, Unit 1. As stated above, 10 CFR 50.12 allows the NRC to grant exemptions from the requirements of 10 CFR 50.46 and Appendix K to 10 CFR Part 50. The NRC staff has determined that granting of the licensee's proposed exemption will not result in a violation of the Atomic Energy Act of 1954, as amended, or the Commission's regulations. Therefore, the exemption is authorized by law.

- 2 -

No Undue Risk to Public Health and Safety

The underlying purposes of 10 CFR 50.46 and 10 CFR Part 50, Appendix K, are to ensure that facilities have adequate acceptance criteria for the ECCS, and to ensure that cladding oxidation and hydrogen generation are appropriately limited during a LOCA and conservatively accounted for in the ECCS evaluation model, respectively. Topical Reports (TRs) BAW-10227(P)-A, "Evaluation of Advanced Cladding and Structural Material (M5) in PWR Reactor Fuel," which was approved by the NRC in February 2000, and BAW-10240(P)-A, "Incorporation of M5 Properties in Framatome ANP Approved Methods," which was approved by the NRC in May 2004, demonstrated that the effectiveness of the ECCS will not be affected by a change from zircaloy to M5[™]. In addition, the TRs also demonstrated that the Baker-Just equation (used in the ECCS evaluation model to determine the rate of energy release, cladding oxidation, and hydrogen generation) is conservative in all post-LOCA scenarios with respect to the use of M5TM advanced alloy as a fuel rod cladding material or in other assembly structural components. Based on the above, no new accident precursors are created by using M5[™] advanced alloy, thus, the probability of postulated accidents is not increased. Also, based on the above, the consequences of postulated accidents are not increased. In addition, the licensee will use NRC-approved methods for the reload design process for HNP Unit 1 reloads with $M5^{TM}$. Therefore, there is no undue risk to public health and safety due to using $M5^{TM}$. Consistent with Common Defense and Security

The proposed exemption results in changes to the operation of the plant by allowing the use of the $M5^{TM}$ alloy as fuel cladding material or in other assembly structural components in lieu of zircaloy or ZIRLO. This change to the fuel material used in the plant has no relation to security issues. Therefore, the common defense and security are not impacted by this exemption request.

- 3 -

Special Circumstances

Special circumstances, in accordance with 10 CFR 50.12, are present whenever application of the regulation in the particular circumstances would not serve the underlying purpose of the rule, or is not necessary to achieve the underlying purpose of the rule. In this circumstance neither 10 CFR 50.46 nor 10 CFR Part 50, Appendix K, explicitly allows the use of M5[™] as a fuel rod cladding material or in use of other assembly structural components.

The underlying purpose of 10 CFR 50.46 is to ensure that facilities have adequate acceptance criteria for the ECCS. The staff's review and approval of TR BAW-10227(P)-A addressed all of the important aspects of M5[™] with respect to ECCS Performance Requirements: (1) applicability of 10 CFR 50.46(b) fuel acceptance criteria, (2) M5[™] material properties including fuel rod ballooning and rupture strains, and (3) steam oxidation kinetics and applicability of Baker-Just weight gain correlation. A subsequent NRC-approved TR, BAW-10240(P)-A, further addressed M5[™] material properties with respect to LOCA applications.

The underlying purpose of 10 CFR Part 50, Appendix K, paragraph I.A.5, is to ensure that cladding oxidation and hydrogen generation are appropriately limited during a LOCA and conservatively accounted for in the ECCS evaluation model. Appendix K requires that the Baker-Just equation be used in the ECCS evaluation model to determine the rate of energy release, cladding oxidation, and hydrogen generation. In TR BAW-10227(P)-A, Framatome demonstrated that the Baker-Just model is conservative in all post-LOCA scenarios with respect to the use of the M5[™] advanced alloy as a fuel rod cladding material or in other assembly structural components, and that the amount of hydrogen generated in an M5[™] core during a LOCA will remain within the HNP Unit 1 design basis.

The M5[™] alloy is a proprietary zirconium-based alloy comprised of primarily zirconium (~99 percent) and niobium (~1 percent). The elimination of tin has resulted in superior corrosion resistance and reduced irradiation-induced growth relative to both standard zircaloy (1.7 percent

- 4 -

tin) and low-tin zircaloy (1.2 percent tin). The addition of niobium increases ductility, which is desirable to avoid brittle failures.

The NRC staff has reviewed the licensee's advanced cladding material, M5[™], for PWR fuel mechanical designs as described in TR BAW-10227(P)-A. In the safety evaluation for TR BAW-10227(P)-A, the staff concluded that, to the extent specified in the staff's evaluation, the M5[™] properties and mechanical design methodology are acceptable for referencing in fuel reload licensing applications. Application of the requirements of 10 CFR 50.46 and 10 CFR Part 50 Appendix K, paragraph I.A. 5 is not necessary to achieve their underlying purpose. The underlying purposes of 10 CFR 50.46 and 10 CFR Part 50, Appendix K, paragraph I.A.5 are achieved through the use of the M5[™] advanced alloy as a fuel rod cladding material or in other assembly structural components. Thus, the special circumstances required by 10 CFR 50.12(a)(2)(ii) for the granting of an exemption from 10 CFR 50.46 and 10 CFR Part 50, Appendix K, exist.

<u>Summary</u>

The NRC staff has reviewed the licensee's request to use the M5[™] advanced alloy for fuel rod cladding and in other assembly structural components in lieu of zircaloy or ZIRLO. Based on the NRC staff's evaluation, as set forth above, the NRC staff concludes that the exemption is authorized by law, will not present an undue risk to public health and safety, and is consistent with the common defense and security. In addition, the NRC staff concludes that the application of 10 CFR 50.46 and 10 CFR Part 50, Appendix K, is not necessary to achieve the underlying purpose of the regulations. Therefore, pursuant to 10 CFR 50.12(a), the NRC staff concludes that the use of the M5[™] advanced alloy for fuel rod cladding and in other assembly structural components is acceptable and the exemption from 10 CFR 50.46 and 10 CFR Part 50, Appendix K, is justified.

- 5 -

4.0 <u>CONCLUSION</u>

Accordingly, the Commission has determined that pursuant to 10 CFR 50.12(a), the exemption is authorized by law, will not present an undue risk to the public health and safety, and is consistent with the common defense and security. Also, special circumstances are present. Therefore, the Commission hereby grants the licensee an exemption from the requirements of 10 CFR 50.46 and 10 CFR Part 50, Appendix K, for HNP Unit 1.

Pursuant to 10 CFR 51.32, the Commission has determined that the granting of this exemption will not have a significant effect on the quality of the human environment (February 15, 2012; 77 FR 8903). This exemption is effective upon issuance. Dated at Rockville, Maryland, this $\partial_{\mu} \frac{4}{4}$ day of February 2012.

FOR THE NUCLEAR REGULATORY COMMISSION

michele S. Evans

Michele G. Evans, Director Division of Operating Reactor Licensing Office of Nuclear Reactor Regulation

February 24, 2012

Christopher L. Burton, Vice President Shearon Harris Nuclear Power Plant Progress Energy Carolinas, Inc. Post Office Box 165, Mail Code: Zone 1 New Hill, North Carolina 27562-0165

SUBJECT: SHEARON HARRIS NUCLEAR POWER PLANT, UNIT 1 – EXEMPTION REGARDING USE OF M5[™] ALLOY FUEL ROD CLADDING (TAC. NO ME5410)

Dear Mr. Burton:

The U.S. Nuclear Regulatory Commission has approved the enclosed exemption from certain requirements of Title 10 of the *Code of Federal Regulations*, Part 50, Section 50.46, "Acceptance criteria for emergency core cooling systems for light-water nuclear power reactors," and Appendix K to 10 CFR Part 50, "ECCS [Emergency Core Cooling System] Evaluation Models," for Shearon Harris Nuclear Power Plant (HNP), Unit 1.

This action is in response to your application dated January 19, 2011 (Agencywide Documents Access and Management System Accession No. ML110250473), requesting the exemption to allow the use of M5[™] alloy fuel rod cladding at HNP, Unit 1.

A copy of the exemption is enclosed. The exemption has been forwarded to the Office of the Federal Register for publication.

Sincerely,

/**RA**/

Araceli T. Billoch Colón, Project Manager Plant Licensing Branch II-2 Division of Operating Reactor Licensing Office of Nuclear Reactor Regulation

02/20/12

02/24/12

02/24/12

Docket No. 50-400

02/14/12

Enclosure: Exemption

DISTRIBUTION

DATE

cc w/enclosure: Distribution via ListServ

02/14/12

DISTRIBUTION.			
PUBLIC	LPL2-2 R/F	RidsAcrsAcnw_MailCTR Resource	RidsNrrDorlDpr Resource
RidsNrrDorlLpl2-2	RidsNrrLABClayton	S. Wu, NRR	RidsNrrDssSnpb Resource
RidsOgcRp Resource	M. Kotzalas, EDO	RidsNrrPMShearonHarris Resource	RidsRgn2MailCenter Resource

ADAMS Accession Nos. PKG ML12025A160		LTR ML12025A161 Exemption: ML12025A162					
OFFICE	DORL/LPL2-2/PM	DORL/LPL2-2/LA	DSS/SNPB/BC	OGC	DORL/LPL2-2/BC	DORL/D	DORL/LPL2-2/PM
NAME	ABillochColón	BClayton	AMendiola	MSpencer	DBroaddus	MEvans	ABillochColón

02/08/12

OFFICIAL RECORD COPY

02/07/12