

PMTurkeyCOLPEm Resource

From: Comar, Manny
Sent: Wednesday, January 11, 2012 4:14 PM
To: orthen, Richard; Raymond Burski; Steve Franzone; STEVEN.HAMRICK; TurkeyCOL Resource; William Maher
Subject: (REVISED) Draft RAI 6258 related to SRP Section 06.02.02 - Containment Heat Removal Systems for the Turkey Point Units 6 and 7 combined license application (REVISED)
Attachments: draft RAI 6258_TPN.doc

To All,

The attached is the revised version compared to the one sent at 3:21 PM today . Please ignore that version, and use this attached version.

Attached is the draft of RAI No: 6258, regarding section 06.02. 02 Containment Heat Removal Systems for the Turkey Point Units 6 and 7 combined license application.

If you need a conference call to discuss the question(s) of the draft RAIs please contact me at 301-415-3863. Unless you request additional clarification we will normally issue the RAI as final within 3 to 5 days, from today.

Thanks

Manny Comar
Senior Project Manager
NRO/DNRL/NWE1
Nuclear Regulatory Commission
301-415-3863
<mailto:manny.comar@nrc.gov>

Hearing Identifier: TurkeyPoint_COL_Public
Email Number: 543

Mail Envelope Properties (377CB97DD54F0F4FAAC7E9FD88BCA6D0806FCB8DE6)

Subject: (REVISED) Draft RAI 6258 related to SRP Section 06.02.02 - Containment Heat Removal Systems for the Turkey Point Units 6 and 7 combined license application (REVISED)
Sent Date: 1/11/2012 4:14:19 PM
Received Date: 1/11/2012 4:14:20 PM
From: Comar, Manny

Created By: Manny.Comar@nrc.gov

Recipients:

"orthen, Richard" <richard.orthen@fpl.com>
Tracking Status: None
"Raymond Burski" <raymond.burski@fpl.com>
Tracking Status: None
"Steve Franzone" <steve.Franzone@fpl.com>
Tracking Status: None
"STEVEN.HAMRICK" <steven.hamrick@fpl.com>
Tracking Status: None
"TurkeyCOL Resource" <TurkeyCOL.Resource@nrc.gov>
Tracking Status: None
"William Maher" <William.maher@fpl.com>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	754	1/11/2012 4:14:20 PM
draft RAI 6258_TPN.doc		30202

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Request for Additional Information No. 6258 **(REVISED)**

Turkey Point Units 6 and 7
Florida P and L
Docket No. 52-040 and 52-041
SRP Section: 06.02.02 - Containment Heat Removal Systems
Application Section: 6.2.2

QUESTIONS from Containment and Ventilation Branch 1 (AP1000/EPR Projects) (SPCV)

06.02.02-***

In the PTN COL Application, Part 7, Departures and Exemption Requests, PTN DEP 2.0-3 increases the maximum safety wet bulb (noncoincident) air temperature from 86.1 °F to 87.4 °F. Although, Departures and Exemption Requests outlines departure justification for the containment pressure design limit evaluation, FSAR Section 6.2 is silent on PTN DEP 2.0-3.

Provide safety and design evaluations of PTN DEP 2.0-3 on the containment pressure design limit evaluation in FSAR Section 6.2.