Boyle, Patrick

From:Boyle, PatrickSent:Thursday, August 25, 2011 10:35 AMTo:Howe, Allen; Lund, LouiseSubject:FW: Request for North Anna InformationAttachments:RCorreia Aug 24.docx; CHunter 8 25 11 North Anna Questions.pdf

This is sounding like some of the task force stuff impacting current operating plants as mentioned during the staff meeting on Monday.

From: Martin, Robert WK Sent: Thursday, August 25, 2011 10:31 AM To: MacDonald, George Cc: Kolcum, Gregory; McCoy, Gerald; Hunter, Christopher; Wilson, George; Giitter, Joseph; Kulesa, Gloria; Boyle, Patrick Subject: Request for North Anna Information

Rich Correia, Office of Research, requests information as in the first attachment. Chris Hunter specified more details as in the second attachment.

In discussing it with the Senior Resident, he indicated that you/your group are likely to have already compiled much of the requested information. If so, could you respond to RES's request for information?

I considered requesting this from the licensee staff but refrained due to the burdens they are already responding to including the upcoming hurricane this weekend.

A comment regarding item 2 in C. Hunter's questions is that I understand the 2H DG was repaired but was not immediately returned to Operability, due to other higher priority items at the time. It was considered available and later the post-maintenance test activities were completed. If you can elaborate on that, it could be useful.

From: Correia, Richard To: Giitter, Joseph; Howe, Allen Sent: Wed Aug 24 09:15:41 2011 Subject: N Anna info

Joe, Allen,

a set a st

Do you have any information on the sequence of events that occurred at N. Anna yesterday when and after the earthquake hit? My ASP/PRA folks are interested and would like to evaluate the event. I'm not asking for anything to be created but if there is information you could share we would be grateful.

Thx

Rich

Richard Correia, PE Director, Division of Risk Analysis Office of Nuclear Regulatory Research US NRC

richard.correia@nrc.gov

From: <u>Hunter, Christopher</u> To: <u>Martin, Robert</u> Cc: <u>Demoss, Gary; Shen</u>

a strates

 Cc:
 Demoss, Gary; Shen, Song-hua

 Subject:
 North Anna Questions

 Date:
 Thursday, August 25, 2011 10:06:50 AM

Thanks Bob for your help. The main questions/information we are looking for right now is:

- 1. When was EDG 2H secured and the SBO diesel aligned to the 2H safety bus?
- 2. When was offsite power restored to the safety buses? When could it have been (i.e., was there damage that would have prevented it from being restored within 1 hour of the LOOP and prior to the battery depletion time)?
- 3. What safety equipment was out of service at the time (I saw the mention of the TDAFW pump be out, was it readily recoverable)?
- 4. Have we verified the battery depletion time of 4 hours?