

16

Martin, Robert

From: Kolcum, Gregory - *RA*
Sent: Friday, August 26, 2011 3:55 PM
To: Martin, Robert
Subject: FW: North Anna: TS issues just entered.

From: Kolcum, Gregory *RA*
Sent: Friday, August 26, 2011 3:05 PM
To: McCoy, Gerald
Cc: Franke, Mark; Rivera-Ortiz, Joel; Ninh, Son; Clagg, Rodney
Subject: North Anna: TS issues just entered. All safety related equipment inoperable U1

Engineering has determined that both units may have exceeded the Design Basis Earthquake. Unit one has entered the following technical specification actions:

U1

8/26 1340

1.) T.S. 3.4.12 Condition G two PRZR PORV's inoperable depressurize RCS and establish 2.07 square inches. An IOD is being developed to prove operability of the PORV's. NOED may be required.

U2

8/26 1340

Entered Limiting Action of T.S. 3.0.3 due to exceeding a Design Basis Earthquake and declaring all Safety Related equipment Inoperable. Unit is required to be in Mode 5 within 37 hours.

*Gregory Kolcum
Senior Resident Inspector
Region II, Division of Reactor Projects
U.S. Nuclear Regulatory Commission*

*North Anna Power Station Office: 540-894-5421
P. O. Box 490 Fax: 540-894-5650
Mineral VA 23117*

*E
39 (3)*