

From: Glitter, Joseph
To: Croteau, Rick; Wert, Leonard; Jones, William
Cc: Khanna, Meena; Martin, Robert; Kulesa, Gloria
Subject: RE: Just got a Call from Mr. Heacock, Dominion
Date: Friday, August 26, 2011 3:54:34 PM

Rick- I will confer with DE to make sure that we have a unified position in NRR. 10 CFR 100 Appendix A Paragraph a.2 states,

"If vibratory ground motion exceeding that of the Operating Basis Earthquake occurs, shutdown of the nuclear power plant will be required. Prior to resuming operations, the licensee will be required to demonstrate to the Commission that no functional damage occurred to those features necessary for continued operation without undue risk to the health and safety of the public."

I would interpret this requirement to mean that NRR would have the lead on the restart approval—of course with involvement and input from the Region.

From: Croteau, Rick
Sent: Friday, August 26, 2011 2:25 PM
To: Wert, Leonard; Jones, William; Glitter, Joseph
Subject: FW: Just got a Call from Mr. Heacock, Dominion

Who has lead on the approval may center on whether an SER from NRR is necessary. If an SER is needed, NRR would likely have the lead to issue the restart approval. If no SER is needed, RII would likely have the lead for restart approval. In either case, DE will have the heavy lifting regarding the acceptability of the licensee's technical evaluation and NRR/RII/OGC would be involved.

From: Grobe, Jack
Sent: Friday, August 26, 2011 2:14 PM
To: McCree, Victor; Leeds, Eric
Cc: McGinty, Tim; Wert, Leonard; Virgilio, Martin; Boger, Bruce; Glitter, Joseph; Croteau, Rick; Wilson, George; Khanna, Meena; Schwarz, Sherry
Subject: RE: Just got a Call from Mr. Heacock, Dominion

Eric and Vic,

While I was reading this email from Len, I received a call from Bill Borchardt that he had received an identical call to Len's from Dave Christian. Two additional bits of info that Bill shared:

- Since they exceeded their DBE, Christian indicated that they are now "required" to get NRC approval for restart
- The 50.72 reports would likely occur around 4:30

I had been asking about restart criteria and approval expectations and had not yet gotten to the bottom of the question – Sorry!!

Bill asked that Eric come to the 8:00 events meeting Monday morning with an understanding of the restart approval requirement and who specifically approves restart: Region II, NRR, EDO???

The staff was just beginning their 1:30 call to prepare for the AIT call with the licensee at 3:30 and I

F / 1

took that opportunity and informed both the NRR (DE and DORL) and RII staff of the expectation that they prepare Eric/Vic(?) for the 0800 Monday meeting. I would suggest that Eric get a pre-brief on the North Anna situation and restart requirements at 7:30. I will set up that meeting. Vic, you are, of course, welcome to participate in these discussions and meetings. (b)(6)

(b)(6)

Sherry, please schedule a 30 minute briefing for Eric in G20 at 7:30, subject: North Anna. Include Eric, Bruce, Vic, Giitter (and staff), and Hiland/Wilson (and staff). Also put an 0800 30 minute meeting on Eric's calendar to attend the "EDO events briefing" on Monday morning.

Thanks

From: Wert, Leonard *IRI*
Sent: Friday, August 26, 2011 1:23 PM
To: McCree, Victor; Virgilio, Martin
Cc: Sanfilippo, Nathan; Jones, William; Croteau, Rick; Grobe, Jack; McGinty, Tim; McCoy, Gerald; Wilson, George
Subject: Just got a Call from Mr. Heacock, Dominion

He informed me that the best information they have at this time is that the acceleration experienced at N. Anna could have been up to 1.5 X the vertical DBE and up to 2X the horz DBE (at some freqs). They are going to begin making the 50.72 reports (at least one 1 hr call) that are required now that this determination has been made and ensuring compliance with the applicable TS action statements. He also stated that the data aligns very closely with the GI 199 spectra. Licensee thinks the best information (most direct) regarding the acceleration experienced will be from the scratch plates in lower containment - expected to be available soon. I informed him that we were working towards a 3:30pm call with his organization to discuss our information to date and our reactive inspection decision (if we have made it). He stated that such a call would not impact their hurricane preps and they would stand by to support it.

Len

7.6