

**King, Mark**

---

**From:** Thomas, Eric *MYCK*  
**Sent:** Wednesday, August 24, 2011 7:12 AM  
**To:** Bernardo, Robert; Haskell, Russell  
**Cc:** NRR\_DIRS\_IOEB Distribution  
**Subject:** North Anna Status

Russ,

I just talked to Region II (Jim Hickey). The region is still in monitoring Mode and maintaining a bridgeline with the licensee.

North Anna is still in an Alert. Offsite power restored and all EDG's secured. The 2H EDG is still inoperable by available. They are awaiting results of post maintenance testing to declare it operable (there was a leak on a jacket water HX gasket).

Unit 1: Licensee restarted 1C RCP. They are using it to establish forced circulation and mix in the boron so they can verify adequate S/D boron concentration and proceed to cold S/D.

Unit 2: Making preps to start 2C RCP and stabilize the plant for Cold S/D. They will cool down the plants one at a time.

Once they establish forced circulation in Unit 2 w/2C RCP the licensee anticipates de-escalating from the Alert down to UE.

Eric

*Eric Thomas*  
U.S. Nuclear Regulatory Commission  
NRR/DIRS/IOEB  
OWFN-7E24  
[eric.thomas@nrc.gov](mailto:eric.thomas@nrc.gov)  
301-415-6772 (office)  
(b)(6) (mobile)

*EX. 6*

---

**From:** Bernardo, Robert *MYCK*  
**Sent:** Wednesday, August 24, 2011 6:59 AM  
**To:** Thomas, Eric; Haskell, Russell  
**Subject:** RE: Let us know when you arrive. EOM

Russ is here

*Bob Bernardo*  
Reactor Systems Engineer  
US Nuclear Regulatory Commission  
NRR/DIRS/IOEB  
Mail Stop: O-7C02A  
301-415-2621  
[Robert.Bernardo@nrc.gov](mailto:Robert.Bernardo@nrc.gov)

---

**From:** Thomas, Eric  
**Sent:** Wednesday, August 24, 2011 6:58 AM

1 Information in this record was deleted  
in accordance with the Freedom of Information  
Act, exemptions 6  
FOIA- 2011-0357

*F/6*

**To:** Haskell, Russell  
**Cc:** Bernardo, Robert  
**Subject:** Let us know when you arrive. EOM

*Eric Thomas*

U.S. Nuclear Regulatory Commission

NRR/DIRS/IOEB

OWFN-7E24

[eric.thomas@nrc.gov](mailto:eric.thomas@nrc.gov)

301-415-6772 (office)

(b)(6) (mobile)

9/23