

135

Dennig, Robert

From: Dennig, Robert *INRR*
Sent: Wednesday, September 14, 2011 12:33 PM
To: Khanna, Meena
Cc: Karipineni, Nageswara
Subject: RE: Questions/Issues related to North Anna Seismic Event
Attachments: RE: North Anna

Importance: High

Meena: We don't have questions per se, but recommendations sent to George Wilson as stated in the attachment. However, these could be re-worded as questions, i.e.,

Will you or have you performed IST tests on valves during the shutdown? Which valves and what were the results?

Will you or have you performed a general visual inspection of the containment consistent with Appendix J and industry guidance, NEI 94-01 and ANSI/ANS 56.8? What were the results? If not, what containment inspection will you or have you performed, and what were the results?

From: Khanna, Meena *INRR*
Sent: Wednesday, September 14, 2011 12:14 PM
To: Mendiola, Anthony; Ulses, Anthony; Casto, Greg; Dennig, Robert; Bailey, Stewart; Taylor, Robert; Lupold, Timothy; Mitchell, Matthew; McMurtray, Anthony; Wilson, George; Murphy, Martin; Mathew, Roy; Tate, Travis; Martin, Robert; Harrison, Donnie; Circle, Jeff; Klein, Alex; Pham, Bo; Auluck, Rajender; Pelton, David; Kulesa, Gloria; Manoly, Kamal; Miranda, Samuel; Mitman, Jeffrey; Karipineni, Nageswara; Rahn, David; McConnell, Matthew; Goel, Vijay; Sahay, Prem; Som, Swagata; Scales, Kerby; Matharu, Gurcharan; Laur, Steven; Snodderly, Michael; Sheikh, Abdul; Bedi, Gurjendra; Lin, Bruce; Franke, Mark; McCoy, Gerald; Boyle, Patrick; Martin, Robert; Kulesa, Gloria
Cc: Hiland, Patrick; Howe, Allen; Galloway, Melanie; Lubinski, John; Wilson, George; Lee, Samson; Evans, Michele; Giitter, Joseph; Farzam, Farhad
Subject: Questions/Issues related to North Anna Seismic Event
Importance: High

All,

Pls note that the licensee has indicated that they plan to submit their restart document to us this Friday. Having said that, we'd like to request that **all technical BCs, as applicable, identify any high priority questions, e.g., related to fuel, etc. be submitted to Bob Martin and myself by 2:30 pm today.** The plan is for us to share these questions with the licensee by COB, today, and provide them with an opportunity to hold conference calls with us tomorrow to discuss, as needed. We would like to send whatever high priority questions we have today, so that at least they can consider them prior to issuing their document. Pls. note that this is by no means intended to be an all inclusive list.

In going forward, we will discuss a "systematic" approach in issuing the questions to the licensee at the 1:30 pm meeting today.

Thanks so much for all of the support and we'll see you at 1:30.

Meena Khanna, Branch Chief
Mechanical and Civil Engineering Branch
Division of Engineering
Office of Nuclear Reactor Regulation

D
135

(301)415-2150
meena.khanna@nrc.gov