

February 29, 2012

Document Control Desk  
U. S. Nuclear Regulatory Commission  
11555 Rockville Pike  
Rockville, MD 20852

Attention: Andrew Hon

Subject: Project No. 704 – Draft NRC Safety Evaluation of BWRVIP-138, Revision 1

References: Letter from John R. Jolicoeur (NRC) to Mr. David Czufin (BWRVIP Chairman),  
“Electric Power Research Institute Draft Safety Evaluation for Technical Report  
1016574 BWRVIP-138, Revision 1: BWR [Boiling Water Reactor] Vessel and  
Internals Project Updated Jet Pump Beam Inspection and Flaw Evaluation  
Guidelines (TAC NO. ME2191),” dated January 30, 2012.

The NRC letter referenced above transmitted a draft NRC Safety Evaluation (SE) of the BWRVIP document entitled “BWRVIP-138, Revision 1: BWR Vessel and Internals Project, Updated Jet Pump Beam Inspection and Flaw Evaluation Guidelines” to the BWRVIP and requested the BWRVIP to identify any proprietary information in the draft SE.

The BWRVIP has reviewed the draft SE and has determined that there is EPRI proprietary information in the draft SE. Enclosed are two copies of a proprietary version of the draft SE with EPRI proprietary information identified with yellow shading and the letters TS in the margin indicating the information is considered “Trade Secrets” in accordance with 10CFR2.390. A letter requesting that the proprietary enclosure be withheld from public disclosure and an affidavit describing the basis for withholding this information are provided as Attachment 1.

Two copies of a non-proprietary version of the draft SE are also enclosed. This non-proprietary version is identical to the enclosed proprietary version except that the proprietary information has been deleted.

The BWRVIP has only one comment regarding factual errors or clarity concerns in the draft SE. Section 4.1.1 of the draft SE states: “As discussed in Section 3.1 of this SE, Table 2.1 of the submittal should be revised to reflect...” However, Section 3.1 of the draft SE does not discuss Table 2.1 of the submittal. Section 4.1.1 or Section 3.1 of the draft SE should be revised to correct the misstatement in the current Section 4.1.1.

Together . . . Shaping the Future of Electricity

*Extra copy sent to PM*

*Good  
NER*

BWRVIP 2012-058

If you have any questions on this subject please call Randy Schmidt (PSEG Nuclear, BWRVIP Assessment Committee Technical Chairman) at 856.339.3740.

Sincerely,

A handwritten signature in black ink, appearing to read "D. Czufin". The signature is stylized with a large, looped "C" and a long horizontal stroke extending to the right.

Dave Czufin  
Exelon  
Chairman, BWR Vessel and Internals Project

February 24, 2012

Document Control Desk  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Subject: Request for Withholding of the following Proprietary Document:  
Draft Safety Evaluation by the Office of Nuclear Reactor Regulation for Technical Report TR-1016574, "BWRVIP-138, Revision 1: Boiling Water Reactor Vessel and Internals Project, Updated Jet Pump Beam Inspection and Flaw Evaluation Guidelines" (TAC NO. ME2191)


To Whom It May Concern:

This is a request under 10 C.F.R. §2.390(a)(4) that the U.S. Nuclear Regulatory Commission ("NRC") withhold from public disclosure the information identified in the enclosed Affidavit consisting of the proprietary information owned by Electric Power Research Institute, Inc. ("EPRI") identified above (the "Report"). Proprietary and non-proprietary versions of the Correspondence and the Affidavit in support of this request are enclosed.

EPRI desires to disclose the Report in confidence to assist the NRC. The Report is not to be divulged to anyone outside of the NRC or to any of its contractors, nor shall any copies be made of the Report provided herein. EPRI welcomes any discussions and/or questions relating to the information enclosed.

If you have any questions about the legal aspects of this request for withholding, please do not hesitate to contact me at (704) 704-595-2630. Questions on the content of the Report should be directed to **Randy Stark** of EPRI at (650) 855-2122.

Sincerely,



Steven M. Swilley  
Senior Business Operations Manager, Nuclear

Attachment(s)

cc: Sheldon Stuchell, NRC (sheldon.stuchell@nrc.gov)

Together . . . Shaping the Future of Electricity

**CHARLOTTE OFFICE**

1300 West W.T. Harris Boulevard, Charlotte, NC 28262-8550 USA • 704.595.2000 • Fax 704.595.2860  
Customer Service 800.313.3774 • www.epri.com

## AFFIDAVIT

**RE: Request for Withholding of the Following Proprietary Document:**

Draft Safety Evaluation by the Office of Nuclear Reactor Regulation for Technical Report TR-1016574, "BWRVIP-138, Revision 1: Boiling Water Reactor Vessel and Internals Project, Updated Jet Pump Beam Inspection and Flaw Evaluation Guidelines" (TAC NO. ME2191)

I, Steven M. Swilley, being duly sworn, depose and state as follows:

I am the Senior Business Operations Manager for the Nuclear Sector at Electric Power Research Institute, Inc. whose principal office is located at 3420 Hillview Avenue, Palo Alto, CA 94304 ("EPRI") and I have been specifically delegated responsibility for the above-listed Report that is sought under this Affidavit to be withheld (the "Report"). I am authorized to apply to the U.S. Nuclear Regulatory Commission ("NRC") for the withholding of the Report on behalf of EPRI.

EPRI requests that the Report be withheld from the public on the following bases:

Withholding Based Upon Privileged And Confidential Trade Secrets Or Commercial Or Financial Information:

a. The Report is owned by EPRI and has been held in confidence by EPRI. All entities accepting copies of the Report do so subject to written agreements imposing an obligation upon the recipient to maintain the confidentiality of the Report. The Report is disclosed only to parties who agree, in writing, to preserve the confidentiality thereof.

b. EPRI considers the Report and the proprietary information contained therein (the "Proprietary Information") to constitute trade secrets of EPRI. As such, EPRI holds the Report in confidence and disclosure thereof is strictly limited to individuals and entities who have agreed, in writing, to maintain the confidentiality of the Report. EPRI made a substantial economic investment to develop the Report, and, by prohibiting public disclosure, EPRI derives an economic benefit in the form of licensing royalties and other additional fees from the confidential nature of the Report. If the Report and the Proprietary Information were publicly available to consultants and/or other businesses providing services in the electric and/or nuclear power industry, they would be able to use the Report for their own commercial benefit and profit and without expending the substantial economic resources required of EPRI to develop the Report.

c. EPRI's classification of the Report and the Proprietary Information as trade secrets is justified by the Uniform Trade Secrets Act which California adopted in 1984 and a version of which has been adopted by over forty states. The California Uniform Trade Secrets Act, California Civil Code §§3426 – 3426.11, defines a "trade secret" as follows:

"Trade secret" means information, including a formula, pattern, compilation, program device, method, technique, or process, that:

(1) Derives independent economic value, actual or potential, from not being generally known to the public or to other persons who can obtain economic value from its disclosure or use; and

(2) Is the subject of efforts that are reasonable under the circumstances to maintain its secrecy."

d. The Report and the Proprietary Information contained therein are not generally known or available to the public. EPRI developed the Report only after making a determination that the Proprietary Information was not available from public sources. EPRI made a substantial investment of both money and employee hours in the development of the Report. EPRI was required to devote these resources and effort to derive the Proprietary Information and the Report. As a result of such effort and cost, both in terms of dollars spent and dedicated employee time, the Report is highly valuable to EPRI.

e. A public disclosure of the Proprietary Information would be highly likely to cause substantial harm to EPRI's competitive position and the ability of EPRI to license the Proprietary Information both domestically and internationally. The Proprietary Information and Report can only be acquired and/or duplicated by others using an equivalent investment of time and effort.

I have read the foregoing and the matters stated herein are true and correct to the best of my knowledge, information and belief. I make this affidavit under penalty of perjury under the laws of the United States of America and under the laws of the State of California.

Executed at 1300 W WT Harris Blvd being the premises and place of business of Electric Power Research Institute, Inc.

Date: 2/24/2012

[Signature]  
Steven M. Swilley

(State of North Carolina)  
(County of Mecklenburg)

Subscribed and sworn to (or affirmed) before me on this 24<sup>th</sup> day of February, 2012 by Steven M. Swilley, proved to me on the basis of satisfactory evidence to be the person(s) who appeared before me.

Signature Deborah H. Rouse (Seal)

My Commission Expires 2<sup>nd</sup> day of April, 2016

Draft Safety Evaluation by the Office of Nuclear Reactor Regulation for Technical Report TR-1016574, "BWRVIP-138, Revision 1 Boiling Water Reactor Vessel and Internals Project, Updated Jet Pump Beam Inspection and Flaw Evaluation Guidelines" (TAC NO. ME2191)

(Non-Proprietary Version)

1  
2  
3 DRAFT SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION  
4 FOR TECHNICAL REPORT TR-1016574, "BWRVIP-138, REVISION 1 BOILING WATER  
5 REACTOR VESSEL AND INTERNALS PROJECT,  
6 "UPDATED JET PUMP BEAM INSPECTION AND FLAW EVALUATION GUIDELINES"  
7 (TAC NO. ME2191)

8  
9 1.0 INTRODUCTION

10  
11 1.1 Background

12  
13 By letter dated March 9, 2009, the Boiling Water Reactor (BWR) Vessel and Internals Project  
14 (BWRVIP) submitted for U.S. Nuclear Regulatory Commission (NRC) staff review and approval  
15 of Electric Power Research Institute (EPRI) Technical Report (TR) 1016574, "BWRVIP-138,  
16 Revision 1 "Updated Jet Pump Beam Inspection and Flaw Evaluation Guidelines" dated  
17 December 2008. This submittal was supplemented by letter dated May 17, 2011 (ADAMS  
18 Accession No. ML11139A150), in response to the staff's request for additional information (RAI)  
19 dated June 2, 2010 (ADAMS Accession No. ML101230464).

20  
21 The goal for BWRVIP-138, Revision 1 (referred to as the submittal) was to develop an updated  
22 inspection strategy for Jet Pump Beams (JPBs) to assure continued integrity of jet pump safety  
23 functions and to maintain the design basis. The recommendations included in the submittal  
24 supersede previously documented BWRVIP guidance for inspection of JPBs contained in  
25 preceding versions of BWRVIP-41, "BWR Vessel and Internals Project, BWR Jet Pump  
26 Assembly Inspection and Flaw Evaluation Guidelines", guidance for inspection of the remaining  
27 jet pump components can be found in preceding versions of BWRVIP-41 and remain  
28 unaffected. The BWRVIP-41 report did not provide sufficient detail on the key design  
29 parameters, heat treatments and stress state, or the new General Electric beam design. In  
30 addition, the BWRVIP-41 report did not cover the effect of water chemistry, and a new region of  
31 the beam has been shown to fail due to intergranular stress corrosion cracking (IGSCC) in the  
32 earlier design.

33  
34 In this submittal, BWRVIP compiled and evaluated information on JPB design and  
35 configurations, field experience with IGSCC in the three different regions of the beam, and  
36 inspection capabilities. BWRVIP performed stress and fracture mechanics analyses to establish  
37 the flaw tolerance of the designs currently installed in the BWR fleet, which in turn was used to  
38 demonstrate the effectiveness of nondestructive evaluation (NDE) techniques and for  
39 establishing appropriate inspection intervals. The two types of beams that are currently

1 installed in the BWR fleet were considered for both normal water chemistry (NWC) and  
2 hydrogen water chemistry (HWC) environments.

3  
4  
5 1.2 Purpose

6  
7 The staff reviewed the submittal and the supplemental information to determine whether the  
8 guidance in the document provides acceptable levels of quality for flaw inspection and  
9 evaluation (I&E) of the JPBs. The review considered the past service history, the potential  
10 degradation mechanism, consequences of failure, and the ability of the proposed inspections to  
11 detect degradation in a timely manner.

12  
13 1.3 Organization of this report

14  
15 Although the BWRVIP-138, Revision 1 TR is proprietary, this SE was written not to repeat  
16 proprietary information contained in the report. The staff does not discuss, in any detail, the  
17 provisions of the guidelines nor the parts of the guidelines that it finds acceptable. A brief  
18 summary of the contents of the submittal is given in Section 1.4 of this safety evaluation (SE,) with the  
19 evaluation presented in Sections 2.0 - 4.0. The conclusions are summarized in  
20 Section 5.0.

21  
22 1.4 Summary of BWRVIP-138, Revision 1 TR

23  
24 The submittal discusses the following topics:

25  
26 Section 1: Introduction and Background – provides a brief discussion of the history of JPB  
27 failures, states the objectives and scope of the submittal, and lists the installation status for the  
28 JPBs as of June 1, 2004, in the BWR fleet. This report supersedes guidance contained in  
29 previously documented versions of BWRVIP-41 related to JPBs.

30  
31 Section 2: Beam Susceptibility – explains the design/manufacturing history of JPBs, makes  
32 the point that all of the beams that have experienced IGSCC problems have been in the  
33 equalized and aged (EQA) condition, and states that all of the EQA beams have been replaced  
34 as of June 1, 2004. All of the beams currently used in the plants were manufactured with the  
35 high temperature anneal and aged (HTA) heat treatment instead of the EQA treatment. This  
36 section also describes the analysis for a conservative estimation of IGSCC initiation life that are  
37 used for justification for the baseline inspection intervals.

38  
39 The recommended baseline inspection intervals are shown in Table 1 and are good for both  
40 NWC and HWC conditions. The recommendations are based on the prediction of crack  
41 initiation in a Group 2 beam, which is a function of the maximum stress in the beam, supported  
42 by data obtained under NWC conditions. No credit was taken for any potential increase in the  
43 time required to initiate a crack in the HWC environment. While effective HWC is expected to  
44 increase the initiation time, at this point, the effect of HWC on crack initiation is difficult to  
45 quantify. The statistical analysis and inspection recommendations were originally included in



1 BWRVIP-41, Revision 1 (released in September of 2005) and have been used by the nuclear  
2 power industry since that time.

3  
4 Table 1. Recommendations for Baseline Inspection Intervals.  
5

	Group 2	Group 3
BB-1 & BB-2		
BB-3		

6  
7 Section 3: Field Experience – describes the IGSCC failures of JPBs, which were all beams  
8 with the EQA heat treatment. The earlier HTA-treated beams (referred to as the Group 2  
9 beams) are dimensionally identical to EQA-treated beams that had experienced failures  
10 (referred to as Group 1 beams in the report). The excellent field experience with the Group 2  
11 beams reflects the improved resistance to IGSCC of the HTA treatment, some of which have  
12 been in service since 1979. The later HTA-treated, Group 3 beams were made thicker in the  
13 center and the ends to reduce the applied stresses, thereby increasing the safety margins  
14 against IGSCC.

15  
16 Section 4: Inspection Regions – defines the IGSCC-susceptible regions of the JPBs and  
17 those inspection techniques that will be used to monitor the beams for cracking. For the  
18 thinnest section around the bolt hole (BB-1 location), inspection is performed with ultrasonic  
19 testing (UT) at \_\_\_\_\_ from an axis perpendicular to the beam axis, on both sides of  
20 the beam's center bolt hole. This is consistent with the observed field cracking pattern and the  
21 peak applied stress field. The UT inspection region for the BB-2 location is the transition region  
22 at each end of the beam, covering the entire radius region and extending to the hold down  
23 locations. For the BB-3 location, enhanced visual inspection (EVT-1), which can detect the fine  
24 cracking associated with IGSCC initiation, is recommended to cover the tapered region between  
25 BB-1 and BB-2 regions with the exception of the center of the top surface.

26  
27 Section 5: Alloy X-750 Crack Growth Rate – describes the IGSCC crack growth rate (CGR)  
28 for the fracture mechanics evaluation of the JPBs. The data are limited with the measurements  
29 made under high oxygen conditions in laboratory tests of compact tension specimens with a  
30 relatively high applied stress intensity factor, K (minimum applied K was \_\_\_\_\_). The report  
31 makes use of the extensive understanding of the IGSCC behavior of austenitic stainless steels  
32 and Alloy 600 to benchmark the limited Alloy X-750 data and to demonstrate the significant  
33 benefit imparted to austenitic stainless steels by the effective HWC environment that is present  
34 in many of the operating BWRs. The data for other austenitic alloys suggest a factor of  
35 reduction in CGR for HWC conditions compare to NWC conditions. For this report, a factor of  
36 reduction in CGR for the Alloy X-750 beams was assumed for all of the CGR calculations in  
37 HWC compared to NWC conditions.  
38

1 Section 6: Flaw Evaluation Methodology – summarizes the stress analysis and fracture  
2 mechanics evaluation of JPBs with different postulated flaw locations, nominally associated with  
3 the three inspection locations. The following items are key points to note:

- 4 • Analyses of the stresses from the preload (percentile of the maximum value,  
5 assumed to act for the life of the beam) were performed for each of the two designs with  
6 different crack locations.
- 7 • A compliance analysis on the Group 2 beam design shows that for most crack locations,  
8 there is no significant relaxation in load until the cracks grow significantly. Therefore, no  
9 load reduction was considered for the CGR analyses discussed in the next section.
- 10 • The allowable flaw size is calculated based on the hydraulic load with a safety factor of  
11 The calculation assumes that the final failure is due to plastic collapse in shear of  
12 the un-cracked ligament. Field experience from failed beams support the use of plastic  
13 collapse in shear as the failure method for the JPB.
- 14 • The results of CGR calculations, using linear elastic fracture mechanics (LEFM), for  
15 each design/crack location start from a small initial assumed flaw size such that the  
16 residual life of the beam, given any detectable flaw in the beam, could be determined  
17 from the results of the calculation.

18  
19  
20  
21  
22  
23 Section 7: Flaw Acceptance and Re-inspection Criteria – describes the crack growth  
24 predictions and proposed inspection intervals for JPBs. For the Group 2 and 3 beams, the  
25 dates for the 1<sup>st</sup> (baseline) recommended inservice inspection (ISI) were chosen based on  
26 results described in Section 2 of the submittal.

27  
28 The dates of subsequent ISI intervals depend on the new stress analysis and the CGR  
29 calculations from Section 6; the summary of the re-inspection intervals is shown below in  
30 Tables 2 and 3.

31  
32 Table 2. Recommendations for Group 2 JPB Re-inspection Intervals.

33

	NWC	HWC
BB-1 & BB-2		
BB-3		

34  
35  
TS

1 Table 3. Recommendations for Group 3 JPB Re-inspection Intervals.  
2

	NWC	HWC
All locations		

3  
4  
5 For the more aggressive NWC environment, the calculations use the best estimate of the upper-  
6 bound on the CGR data in Section 5. The specific conservatisms included in the selection of  
7 inspection intervals are:  
8

- 9 • choosing an "initial" flaw size significantly larger than the detection capabilities of current  
10 NDE methods,  
11
- 12 • for BB-1 and BB-2 locations, the re-inspection intervals are the same, based on the  
13 shortest predicted life from the CGR calculations at either of the two locations, and  
14
- 15 • when the predicted life from the CGR calculations is greater than the  
16 re-inspection interval is limited to  
17

18 For the less aggressive HWC environment, the submittal proposes longer re-inspection intervals  
19 than for the NWC environment, but less than would be supported by the CGR calculation results  
20 to retain additional conservatism in the approach.  
21

22 Appendix A: Details of the Group 2 JPB analysis are presented, which included the  
23 compliance analysis as well as the stress and crack growth analyzes. The CGR calculations  
24 were performed on different combinations of possible crack plane and crack geometry  
25 (corner crack or center crack) in order to identify the limiting case for each JPB region (BB-1,  
26 BB-2 and BB-3). The limiting crack locations represent the critical inspection points of the JPB.  
27 A six year re-inspection frequency for the NWC environment was selected as a starting point.  
28

29 For the BB-1 location and in the NWC environment, the limiting crack configuration is identified  
30 as a corner crack; smaller initial flaws would not cause failure within the re-  
31 inspection interval. The limiting crack size for the given interval is considered to be detectable  
32 with the procedures described in Section 4; therefore, a re-inspection interval should  
33 provide a reasonable opportunity to detect an existing IGSCC crack in a Group 2 HTA JPB.  
34

35 In the HWC environment, the evaluation would predict failure from IGSCC after of  
36 service; however, a limit of was selected for the BB-1 and BB-2 locations to retain  
37 additional conservatism in the approach.  
38

39 The analysis demonstrates that the stress in the BB-3 region is much lower in magnitude than  
40 for the BB-1 or BB-2 regions and thus supports much longer re-inspection intervals than

1 proposed for the BB-1 and BB-2 locations. Given these factors, the submittal recommends a  
2 maximum inspection interval of                    for the NWC environment and                    for the HWC  
3 environment, which are considered conservative and technically justified.

4  
5 Appendix B: Details of the Group 3 JPB analysis are presented, which included the  
6 compliance analysis as well as the stress and crack growth analyzes. The CGR calculations  
7 were performed on                    different combinations of possible crack plane and crack geometry  
8 (corner crack or center crack) in order to identify the limiting case for each JPB region (BB-1,  
9 BB-2 and BB-3). The limiting crack locations represent the critical inspection points of the JPB.  
10 An                    re-inspection frequency for the NWC environment was selected as a starting  
11 point.

12  
13 For the BB-2 location and in the NWC environment, the limiting crack configuration is identified  
14 as a                    center crack; smaller initial flaws would not cause failure within the                    re-  
15 inspection interval. The limiting crack size for the given interval is considered to be detectable  
16 with the procedures described in Section 4; therefore, an                    re-inspection interval should  
17 provide a reasonable opportunity to detect an existing IGSCC crack in a Group 3 HTA JPB.

18  
19 In the HWC environment, the evaluation would predict failure from IGSCC after                    of  
20 service; however, a limit of                    was selected for the BB-1 and BB-2 locations to retain  
21 additional conservatism in the approach.

22  
23 For the BB-3 location, the analysis demonstrates that the flaw tolerance is only slightly higher  
24 than that for the BB-1 and BB-2 locations; the section size at the BB-3 location is smaller than  
25 the size at the same location in the Group 2 JPB. Given these factors, the submittal  
26 recommends the same re-inspection intervals (                    for NWC and                    for HWC) for all  
27 three locations, which is conservative and can be technically justified.

TS

## 28 29 2.0 REGULATORY EVALUATION

30  
31 The BWRVIP guidance regarding JPB inspections is a voluntary program pursued by industry in  
32 order to address past failures in BWR units. These failures could cause significant damage to  
33 surrounding internal components, but do not represent a reactor safety issue. If a failure  
34 occurs, existing jet pump operability surveillance procedures required by plant Technical  
35 Specifications will detect a beam failure and shut down the reactor. The purpose of this  
36 inspection guideline is to avoid mid-cycle failures and possible damage to reactor internals. The  
37 creation of the BWRVIP was, at least in part, motivated by a desire to demonstrate that no  
38 increased specificity in NRC regulation for BWR internals aging management would be  
39 necessary.

## 40 41 3.0 TECHNICAL EVALUATION

42  
43 The staffs' review is focused on the technical basis for the recommended initial inspection  
44 intervals as well as the re-inspection intervals. During its review of the submittal, the staff  
45 issued one RAI that addressed technical issues. The details of the staff's RAI and the

1 corresponding responses are available in ADAMS. However, the staff did not include all the  
2 RAI questions and the responses in this SE; it included only those salient RAI questions and  
3 BWRVIP responses that address specific points of emphasis.

4  
5 3.1 Baseline Inspection Interval

6  
7 Section 2.4 of the submittal references the 1981 proprietary report that covers the testing that is  
8 the technical basis for setting the baseline inspection intervals for Groups 2 and 3 JPBs. The  
9 staff recognizes that the applied stress level is the main factor that will control the time to initiate  
10 an IGSCC crack and requested in RAI 2 that the BWRVIP summarize the maximum stress for  
11 each of the inspection locations in each beam design. The RAI response was included in the  
12 BWRVIP's May 17, 2011 letter. The salient information regarding IGSCC crack initiation from  
13 the RAI response and the original submittal are included below in Table 4. The applied loads  
14 for each design are the same and the highest stress is found in the BB-1 location for each beam  
15 design; the reported maximum stress in the BB-2 and BB-3 regions occurs at the boundary  
16 between the two regions, so therefore, the maximum stress is the same for both regions.

17  
18 The staff also asked in RAI questions 4 and 5 for additional information on the crack initiation  
19 testing and the statistical evaluation used to justify the recommended initial baseline inspection  
20 interval. In its May 17, 2011 response, the BWRVIP summarized the crack initiation testing and  
21 stated that the American Society of Mechanical Engineers specifications and General Electric-  
22 Hitachi internal material design specifications have been used to procure the materials for the  
23 JPBs. Tight control on manufacturing and procurement are vital to minimize the effect of  
24 material property variability in the actual hardware on the conclusions drawn from the statistical  
25 evaluation. Additionally, a re-assessment of the ratio of applied stress to yield stress (referred  
26 to as the stress ratio) versus time to initiate IGSCC was performed which accounted for material  
27 property variability. The staff accepts these responses to the RAI questions and the issues  
28 related to the stress analysis, crack initiation testing, and statistical evaluation are considered  
29 resolved.

30

Table 4. Summary of Stress Analysis for Baseline Inspection Intervals.

	Group 2	Group 3
Max stress @ BB-1, ksi		
Max stress @ BB-2/BB-3, ksi		
Max applied stress / Yield stress**		
<i>Statistical analysis for highest stress region</i>		
Mean IGSCC initiation life # of years		
Lower bound (Mean - 3σ) # of years		

\* Does not include thermal relaxation of the preload.

\*\* Yield stress at 550°F is a minimum of

### 3.1.1 Group 2 Beams

The recommended baseline inspection interval is based on the stress ratio of the higher stressed BB-1 region. The statistical evaluation showed that the mean time to failure for the maximum applied stress ratio is significantly greater than the recommended baseline interval, but when the scatter in results is considered (mean value minus 3σ), the time for initiation is slightly less than the baseline interval ( ). The baseline intervals for the BB-2 and BB-3 regions are less than the minimum (mean value minus 3σ) time to failure, given the maximum stress in these regions, and provide additional conservatism in the re-inspection frequencies.

For the BB-1 region, several factors need to be considered when comparing the discrepancy between the result from the analysis and the maximum recommended interval length ( ). The investigators noted that the crack initiation testing was performed in an environment with high oxygen ( ) and high conductivity water chemistry. The staff agrees that the dissolved oxygen (DO) environment is significantly more aggressive than typical NWC where the DO content could vary from: (Reference 1). The staff also notes that the IGSCC would have to grow a significant distance through the cross section after initiation before failure could occur. In the limited number of field failures of the EQA-treated JPBS, the beams demonstrated significant flaw tolerance before failure. Finally, the stress ratio

1 at the BB-1 location is less than the recommended [Reference 2] found in the  
2 current version of BWRVIP-84 (Reference 2). Finally, the staff notes that Group 2 JPBs have  
3 been used in 31 BWRs in the United States, some for as long as 30 years, without any  
4 confirmed cases of IGSCC.

5 Taking all of these factors into consideration, the staff agrees that the maximum recommended  
6 baseline inspection intervals for the Group 2 beams ( for the BB-1 and BB-2 locations  
7 and for the BB-3 locations) are acceptable.  
8

### 9 3.1.2 Group 3 Beams

10  
11 In Table 1, the stress analysis showed that the latest beam design does reduce the overall  
12 stresses in the beam; the highest stressed region is still around the center bolt hole (BB-1), but  
13 now the maximum stress in the rest of the beam (found at the boundary between regions BB-2  
14 and BB-3) is less. The recommended baseline inspection interval in Table 1 for all  
15 three regions ( ) is considerably less than the results from the statistical evaluation ( )  
16 ). The staff notes that Group 3 JPBs have been used in 6 BWRs in the United States  
17 without any confirmed instances of IGSCC; the longest service time is currently 10 years.

18 Based on the stress analysis and the May 17, 2011, response to RAIs, the staff agrees that the  
19 maximum recommended baseline inspection interval for the Group 3 beams ( for all  
20 locations) is acceptable.  
21

### 22 3.2 Re-inspection Intervals

23  
24 The recommended re-inspection intervals were based on the new crack growth calculations  
25 described in Section 6 of the submittal with the conservative assumptions summarized below:  
26

- 27 1) there is a small, pre-existing flaw present,
- 28 2) this small flaw will grow in a stable fashion due to IGSCC,
- 29 3) the stable IGSCC crack growth ends when the remaining ligament fails due to plastic  
30 collapse of the remaining ligament.  
31  
32

33  
34 The additional assumption that is made in the submittal is that the dependence of the CGR,  
35  $da/dN$ , on the stress intensity factor  $K$  can be represented by a power law of the form:  
36

$$37 \quad da/dN = \quad \text{Equation 1}$$

38  
39 where  $A$  for Alloy X-750 is a constant that depends on the water chemistry and  $n$  is . For the  
40 NWC environment, the value of  $A$  is assumed by the BWRVIP to be so that the

<sup>1</sup> BWRVIP-84 is in the process of being revised so that the maximum recommended stress ratio will be for TS threaded components and for non-threaded components like the JPBs.

1 curve will be an upper bound to the limited, existing test data. For the HWC environment, there  
2 are no test results for Alloy X-750, so the value of  $A$  is assumed to be a factor of less than  
3 that for NWC; data for other austenitic alloys suggest a factor of reduction  
4 in CGR in the HWC environment compared to that for NWC.

5  
6 In the submittal, the BWRVIP has compared the limited measured CGR for X-750 to the  
7 measured CGR for Alloy 600 and austenitic stainless steels (small range of applied K) as a  
8 function of yield strength (YS); the measured data is also compared to theoretical modeling of  
9 SCC to suggest that the effect of YS is consistent with the theory. In RAI 7, the staff has  
10 questioned why the YS dependence is important and if the theory supports the applied K  
11 dependence of CGR used in the submittal. In its May 17, 2011, response, the BWRVIP  
12 reviewed in more detail the comparisons made in the submittal and concludes that because the  
13 available data over the limited range of applied K values are similar, then the proposed CGR  
14 curves for Alloy X-750 are acceptable at this time; however, the BWRVIP has a project  
15 underway to measure CGRs on a representative heat of Alloy X-750 and plans to communicate  
16 those results to the NRC when they become available.

17  
18 To assess the adequacy of the proposed CGR curves for Alloy X-750, the staff has reviewed  
19 the available data, and the relationship of the proposed CGR curves to other NRC-approved  
20 approaches to make conservative estimates of CGRs that are relevant to the re-inspection  
21 intervals in the submittal. In this case, the minimum assumed detected flaw size is  
22 deep and the critical flaw sizes for plastic collapse is about deep, which translates  
23 into an applied K that ranges from about  
24

25 The staff has summarized in Figure 1 the CGRs for NWC from two other sources to compare  
26 with the assumed crack growth trends with those found in this submittal. The trend proposed in  
27 the submittal for Alloy X-750 has a lower absolute value than that which is used as an upper  
28 bound for sensitized pipe welds made from austenitic stainless steels (Reference 4); the trend  
29 for Alloy X-750 is equal to (at applied K ) or higher than (at applied K )  
30 that used for Alloy 600 and 182 welds in BWR internals (Reference 5). Given the BWRVIP  
31 response to RAI 7 and the information in Figure 1, the staff concludes that the proposed CGR  
32 curve for Alloy X-750 in the NWC environment may not represent an absolute upper-bound to  
33 the CGR, but does provide for a reasonable extrapolation to lower applied K values and, at this  
34 point in time, is acceptable to use in the LEFM calculations. If the results of the supplemental  
35 CGR testing on a representative heat of Alloy X-750 that the BWRVIP is currently conducting do  
36 not confirm the assumed X-750 CGRs, then the BWRVIP should re-evaluate the proposed re-  
37 inspection intervals using the results of the supplemental testing. This resolves the issues in TS  
38 RAI 7.  
39






Figure 1. CGR in NWC environment vs. applied K trends from different sources.

The proposed reduction of CGR for the HWC environment (factor of reduction in the value of  $\Delta$  in Equation 1) should be recognized as being dependent upon plant-specific factors. To take credit for an "effective" HWC environment, the staff considers the factor of reduction in the CGR acceptable when the plant operators follow the guidance included in BWRVIP-62 (Reference 6) and meet all of the conditions listed in the SE (Reference 7).

### 3.2.1 Group 2 JPBs

The proposed intervals are based on the crack growth analysis detailed in Appendix A of the submittal. The staff reviewed Appendix A and noted that the LEFM crack growth analysis, which determines how fast the crack will grow, and the limit-load analysis of plastic collapse, which controls how far the crack will grow, are based on different loads. In RAI 10, the staff asked for clarification on why the crack growth should be based solely on the preload while the plastic collapse should be based on the hydraulic load. In its May 17, 2011, response, the BWRVIP described the assumptions that were used. For crack growth, the maximum load that the beam would see in service is assumed to be the higher of the two loads (Table 1 in Appendix A of the submittal shows the bolt preload and the hydraulic load), which is the bolt preload. For plastic collapse to occur, the analysis assumes that the beam would experience significant distortion, which would indicate that the preload is relieved and only the hydraulic load would remain. The staff finds that the BWRVIP has adequately clarified the assumptions controlling crack growth and the issue is resolved.

1  
2 The staff reviewed the specific recommendations for Group 2 JPBs, which are summarized in  
3 Table 2 of this SE. The recommended re-inspection interval for the BB-1 region is based on the  
4 limiting case of crack growth from a corner crack in the BB-1 region. The recommended interval  
5 for the BB-2 region is slightly less than the results from the calculations; for the BB-3 region, the  
6 recommended interval is considerably less than the calculated service life  
7 (see Table 7 in Appendix A of the submittal) because the stress is significantly lower at this  
8 location and represents part of the additional conservatism in the recommendations.

9  
10 For the HWC environment, the results of the crack growth calculations at the BB-1 location  
11 would predict a remaining service life of (a factor of greater). The BWRVIP has  
12 recommended re-inspection in for the BB-1 and BB-2 locations, not taking full credit for  
13 the reduced CGR in the recommended re-inspection intervals to provide additional  
14 conservatism to the approach. Again, for the BB-3 location, the BWRVIP recommends re-  
15 inspection after , much less than predicted from the CGR results in the HWC  
16 environment.

17  
18 The staff performed similar, independent calculations of crack growth for the limiting case and  
19 verified the acceptable flaw tolerance performance for the recommended interval under  
20 NWC conditions with the CGR curve used in the submittal; however, the calculations are  
21 sensitive to the exact CGR curve used. If the more conservative CGR curve for NWC from  
22 NUREG-0313 were used, the staff's calculations would predict failure in approximately 3.6 years  
23 rather than reduction in service life. Given the limited data available for  
24 Alloy X-750 in the HTA heat treated condition, the staff finds the recommended re-inspection  
25 intervals for Group 2 beams acceptable; however, additional test results in the  
26 range of applied K are advisable to verify the acceptability of the proposed CGR curve for Alloy  
27 X-750 in the HTA heat treated condition.

### 28 29 30 3.2.2 Group 3 JPBs

31  
32 The proposed intervals are based on the crack growth analysis detailed in Appendix B of the  
33 submittal. The staff reviewed Appendix B and noted that the details are similar to those noted in  
34 Appendix A for the Group 2 JPBs.

35  
36 The staff reviewed the specific recommendations for Group 3 JPBs, which are summarized in  
37 Table 3. The recommended re-inspection interval for all three regions is based on the limiting  
38 case of crack growth from a center crack in the BB-2 region. The recommended intervals for  
39 the BB-1 and BB-3 regions are slightly less than the results from the CGR calculations, which  
40 adds to the overall conservatism in the recommendations.

41  
42 The results of the crack growth calculations for the HWC environment predict a factor of  
43 greater in the remaining service life. Again, the BWRVIP has chosen to not take full credit for  
44 the reduced CGR in the recommendations to provide additional conservatism to the approach.

TS

1 The staff finds the recommended re-inspection intervals for Group 3 beams acceptable;  
2 however, as stated above in the case of the Group 2 beams, additional test results in the  
3 range of applied K are advisable to verify the acceptability of the proposed CGR curve  
4 for Alloy X-750 in the HTA heat treated condition.

TS

5  
6 3.3 Adequacy of the Overall Approach to I&E Guidelines  
7

8 In the course of the staff's review of the submittal, two general questions were raised in the RAI  
9 regarding the scope and focus of the report. RAI 1 related to the effect of the surface condition  
10 on initiation of IGSCC. The initial Group 2 beams were manufactured from closed-die forgings,  
11 resulting in a combination of machined and as-forged surfaces on the installed beams. Most  
12 Group 2 beams manufactured after 1994 were supplied as open-die forgings and as a result  
13 were machined on all surfaces, removing any as-forged surfaces; Group 3 beams have always  
14 been manufactured from open-die forgings with all surfaces machined. In its May 17, 2011,  
15 response, the BWRVIP provided a thorough discussion of the effects of surface condition and  
16 surface films on the general corrosion and the initiation of IGSCC in Alloy X-750. The BWR  
17 industry, through the BWRVIP, has addressed these issues related to surface condition by  
18 publishing BWRVIP-84, which includes Alloy X-750 specifically and provides detailed  
19 manufacturing guidance. The staff has reviewed the response to RAI 1 and finds it acceptable  
20 because the proposed inspection schedule and inspection methodologies, along with the  
21 controls of the manufacturing process will provide adequate assurance that the surface  
22 condition of any Group 2 or Group 3 JPB will not adversely affect the performance of the beam.  
23

24 The second general question, RAI 11, from the NRC staff was related to the neutron radiation  
25 conditions in the vicinity of the JPB and whether irradiation-assisted stress corrosion cracking  
26 (IASCC) was a potential aging mechanism that should be considered. In its May 17, 2011,  
27 response, the BWRVIP provided a detailed account of testing that they have done to  
28 characterize the behavior of Alloy X-750 as a function of the neutron radiation conditions. They  
29 summarized the work by stating that IASCC is not considered a potential aging mechanism for  
30 the Groups 2 and 3 beams. The staff has reviewed the information provided in the May 17,  
31 2011, response and similar crack growth related issues in Ni-based alloys used in BWR internal  
32 components (BWRVIP-59). The staff agrees that the neutron radiation levels for these Alloy  
33 X-750 beams are low compared to other internal components and the impact of fluence on the  
34 JPBs would be limited; therefore, IASCC is not a significant issue for X-750 JPBs in the HTA  
35 heat treated condition.  
36

37 3.4 Summary of Staff's Evaluation  
38

39 Based on the review of the available information in the submittal, the May 17, 2011, response to  
40 the staff's RAIs, the extensive history of inspections on Group 2 and 3 JPBs, and the staff's  
41 independent calculations, the staff finds that the recommended inspection intervals are  
42 acceptable.  
43

1  
2 4.0 CONDITIONS/LIMITATIONS AND LICENSEE PLANT-SPECIFIC  
3 ACTION ITEMS  
4

5 Based on its review, the staff identified two issues and concerns in Section 3.0 of this SE that  
6 were not adequately addressed regarding the implementation of the submittal. The conditions  
7 and limitations address deficiencies in the submittal are identified in Section 4.1 of this SE. One  
8 plant-specific action item that addresses the implementation of the submittal is identified in  
9 Section 4.2 of this SE.

10  
11 4.1 Limitations and Conditions on the Use of BWRVIP-138, Revision 1  
12

13 4.1.1 Condition 1.  
14

15 As discussed in Section 3.1 of this SE, Table 2.1 of the submittal should be revised to reflect the  
16 May 17, 2011, response to RAI 2 in the approved (-A) version of this TR .  
17

18 4.1.2 Condition 2.  
19

20 As discussed in Section 3.2 of this SE, the staff requests that the BWRVIP reassess the  
21 proposed CGR curve for the applied K range of . If the results of the supplemental TS  
22 CGR testing on a representative heat of Alloy X-750 that the BWRVIP is currently conducting  
23 are not bound by the assumed X-750 CGRs, then the BWRVIP should re-evaluate the proposed  
24 re-inspection intervals using the results of the supplemental testing.  
25

26 4.2 Licensee Plant-Specific Action Items for the Use of BWRVIP-138, Revision 1  
27

28 As discussed in Section 3.2 of this SE, the staff requests that to take credit for an "effective"  
29 HWC environment and the longer re-inspection intervals described in the submittal, the plant  
30 operators must follow the guidance included in BWRVIP-62 (Reference 6) and meet all of the  
31 conditions listed in the SE.  
32

33 5.0 CONCLUSIONS  
34

35 The staff has reviewed the BWRVIP-138, Revision 1, TR and the supplemental information that  
36 was transmitted in the BWRVIP letter on May 17, 2011. The staff found that the TR, as clarified  
37 to incorporate the BWRVIP responses to RAI questions 2 and 8-11, provides an acceptable  
38 technical justification for the proposed I&E of the JPBs manufactured from Alloy X-750 in the  
39 HTA heat treated condition.  
40

41 As described previously in Section 3.2 of this SE, should the results of the supplemental testing  
42 not confirm the assumed X-750 CGRs, then the BWRVIP would need to re-evaluate the  
43 proposed re-inspection intervals using the results of the supplemental testing.  
44

1 6.0 REFERENCES  
2

- 3 1. H.-P. Seifert and S. Ritter, in Proceedings of the 12th International Conference on  
4 Environmental Degradation of Materials in Nuclear Power System – Water Reactors –  
5 Edited by T.R. Allen, P.J. King, and L. Nelson, TMS, 2005.  
6  
7 2. BWR Vessels and Internals Project, "Guidelines for Selection and Use of Materials For  
8 Repairs to BWR Internal Components, (BWRVIP-84)" October 2000.  
9  
10 3. W.S. Hazelton, W.H. Koo, NUREG-0313, Revision 2, "Technical Report on Material  
11 Selection and Processing Guidelines for BWR Coolant Pressure Boundary Piping," 1988.  
12  
13 4. BWR Vessels and Internals Project, "Evaluation of Crack Growth in BWR Nickel Base  
14 Austenitic Alloys in RPV Internals (BWRVIP-59-A)," May 2007.  
15  
16 5. BWR Vessels and Internals Project, "Technical Basis for Inspection Relief for BWR Internal  
17 Components with Hydrogen Injection (BWRVIP-62)," December 1998.  
18  
19 6. NRC Safety Evaluation by the Office of Nuclear Reactor Regulation, Boiling Water Reactor  
20 (BWR) Vessel and Internals Project (BWRVIP) Report TR-108705 (BWRVIP-62):  
21 "Technical Basis for Inspection Relief for BWR Internal Components with Hydrogen  
22 Injection," July 21, 2009.  
23  
24  
25

26 CONTACT: Patrick T. Purtscher