



FPL.

POWERING TODAY.
EMPOWERING TOMORROW.®

FEB 22 2012

L-2012-071
10 CFR 50.36

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555-0001

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
2011 Annual Report of Reactor Coolant Specific Activity Limits

The 2011 Turkey Point Units 3 and 4 Annual Reactor Coolant System (RCS) Specific Activity Report is submitted herein pursuant to Turkey Point Technical Specification (TS) 6.9.1.2.

The reactor coolant specific activity limits of less than or equal to 1.0 microcurie per gram Dose Equivalent I-131 and less than or equal to 100/E-bar microcuries per gram of gross radioactivity defined by Technical Specification 3.4.8.a and 3.4.8.b respectively were not exceeded for Turkey Point Units 3 and 4 during 2011.

Should there be any questions regarding this information, please contact Robert J. Tomonto, Licensing Manager, at (305) 246-7327.

Sincerely,

Michael Kiley
Vice President
Turkey Point Nuclear Plant

SM

cc: Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant

A001
NR