Attachment 9

# Redacted TVA calculation WCGACQ0766, Revision 1, " Required Response Spectra for Evaluation of Radiation Monitoring Equipment" (Letter Item 6)

# NPG CALCULATION COVERSHEET/CCRIS UPDATE

										÷		Page	1a	
REV 0 EDN	IS/RIMS N	0.					EDN	NS TY	PE:	EDMS ACCI	ESSION NO	(N/A for R	EV. C	
19311040	/ UUZ						calculat	tions(1	nuclear)	T 9	3120	113	. U	0 2
Calc Title: REQUIRE	D RESPC	ONSE SP	ECTF	A FOR I	EVAL	UATIO	ON OF R	ADL	ATION	MONITORIN	NG EQUIPN	<b>AENT</b>		
CALC ID	TYPE		G	PLANT	<u>BR</u> A	NCH	_		NUMBER		CUR REV	NEW F	REV	:
CURREN		NU	c	WBN	с	EB		WC	GACQ07	66	000	001		REVISION APPLICABILITY
NEW	CN	NU	c											Entire calc 🛛 Selected pages 🔲
ACTION	NEW REVISIO		DEL REN	ete IAMe		SUPER DUPLIC	SEDE		CCRIS (Verifie Require	UPDATE ON r Approval Sig ed)	LY 🔲 natures Not		No (Fo bée CC	CCRIS Changes [] r calc revision, CCRIS on reviewed and no RIS changes required)
<u>UNITS</u> 000, 002	<u>SY</u> 090	<u>STEMS</u> )						UNII WBN RE-0	<u>DS</u> N-2-PNL-0 090-0112	090-M030, WE , WBN-2-RE-0	3N-0-PNL-09 190-0130, WE	0-M12, W 3N-2-RE-0	BN-2- 990-0	-RE-090-0106, WBN-2- 131
DCN,EDC,I N/A	<u>N/A</u>		AP WE	PLICABLE	DES	IGN DC	CUMEN 6-5.10	T <u>(S)</u> :						CLASSIFICATION E
QUALIT RELATE Yes 🛛 N	Y <u>S</u> D? Io 🗆	AFETY R (If yes, Q Yes ⊠	ELATI R = ye No [	<u>=D?</u> <u> </u> s) <u>A</u> ] Y		RIFIED IPTION No 🛛		SPEC D/OR	CIAL REQ LIMITING Yes 🗌	UIREMENTS CONDITION No 🖾	IS? DESIG			SAR/TS and/or ISFSI SAR/CoC AFFECTED
PREPARE	R ID	PREF NO (423)	ARER 365-7	PHONE 769		PREPA	RING OF CEI	R <u>G (B</u> B	RANCH)	VERIFICAT METHOD DESIGN R	<u>FION</u> EVIEW	NEV	/ MET	THOD OF ANALYSIS ⊠ No
PREPAREF Robert G. E		JRE	Kr	for .		1/6	DATE	C E	HECKER ric Campl		ila	Del	1	DATE
VERIFIER S			n	leit		1/9		A T			Bin	Pentin	rs	DATE 1-10-12
STATEMEN	IT OF PRO	BLEM/A	BSTR	ACT						······································				
REVISION	001:							•						
THIS REVIS	SION DEVI OF EVALL	ELOPS A IATING \	DDITI ENDC	ONAL RE OR SEISM	QUIRE IC RE	ED RES PORTS	PONSE	SPEC	TRA FOR	R THE RADIA	TION MONIT	ORING E	QUIP	MENT FOR THE
NOTE: THIS	S REVISIO	N ALSO	CHAN	GES THE	CALC	ULATI		Ξ						
										LEGIBILI FOR ISSU	ITY EVAL IE ALL PA	UATED GES IN	AN RE	D ACCEPTED V. 001
										A	<u>J</u>	n	2	1/6/12
										SIGNATU	RE			DATE
														· · · ·
	OFICHE/E		Ye		X	FICH	E NUMBE	ER(S)		······································	······································			
	INTO ED	MS AND	RETU	RN CALC	ULATI	ION TO	CALCUL	ATIO	N	ADDRE	SS: EQB-1M	-WBN		
	INTO ED	MS AND	RETU	RN CALC	ULATI	ON TO								
VA 40532 [10	-2008]						Page	1 of 2	!			•	1	NEDP-2-1 [10-20-2008]

This Sheet Added By Revision 001

## NPG CALCULATION COVERSHEET/CCRIS UPDATE

				•				raye _2a	
CALC ID	TYPE	ORG	PLANT	BRANCH	NUMBE	R	REV		
	CN	NUC	WBN	CEB	WCGACQ	0766	001		· ·
			A	LTERNATE CAL	CULATION IDEN	TIFICATION		- <b>-</b>	• .
			·				· · · · · · · · · · · · · · · · · · ·		
·			· · · · · ·					·	
BLDG 03	RO N	IOM /A	<u>ELEV</u> N/A	COORD/AZIM N/A	<u>FIRM</u> BECHTEL	Print Report	Yes 🗌		
CATECORIE					· · · ·				

#### CATEGORIES: A09

## KEY NOUNS (A-add, D-delete)

ACTION	KEY NOUN	<u>A/</u>	D	KEY NOUN	•
(A/D)		ľ			
A	SKID				
A	RADIATION MONITORS				
· · · · ·		•			

# <u>CROSS-REFERENCES</u> (A-add, C-change, D-delete)

ACTION (A/C/D)	XREF CODE	XREF TYPE	XREF PLANT	XREF BRANCH	XREF NUMBER	XREF REV
A	Р	CN	WBN	CEB	WCGACQ0112	
· A	Р	VD	WBN	CEB	04031100	
A	Р	VD	WBN	CEB	04031500	
A	Р	VD	WBN	CEB	04031300	
Α	P	DN	WBN	EEB	EDCR 52341	
Α	Р	TR	WBN	CEB	04038903-1SP	
A	P	TR	WBN	, CEB	04038903-2SP	
` A	P	TR	WBN	CEB	04038903-4SP	
A	P	EP	WBN	EEB	WBN-2-PNL-090-M030	
A	P	EP	WBN	EEB	WBN-2-PNL-090-M031	
Α	P	EP	WBN	EEB	WBN-0-PNL-090-M12	
Α	P	EP	WBN	EEB	WBN-2-RE-090-0106	
Α	Р	EP	WBN	EEB	WBN-2-RE-090-0112	
A	P	EP	WBN	EEB	WBN-2-RE-090-0130	
A	Р	EP	WBN	EEB	WBN-2-RE-090-0131	
CCRIS ONLY L Following are re	JPDATES: equired only wh	en making key	word/cross refer	ence CCRIS up	dates and page 1 of form NEDP-2-1 is not inclu	ded:
F	PREPARER SI	GNATURE		DATE	CHECKER SIGNATURE	DATE
PREPARER PH	ONE NO.	• .	F	MS ACCESSIC		
TVA 40532 [10-2	0081		Page 2 of 2		NEDP-2-1 [10-20-2008]	

This Sheet Added By Revision 001

	NPG CALCULATION RECORD OF RE	EVISION
CALCULA	TION IDENTIFIER: WCGACQ0766	
Title	REQUIRED RESPONSE SPECTRA FOR EVALUATION OF RADIATI	ION MONITORING EQUIPMENT
Revision No.	DESCRIPTION OF REVISION	
001	THE PURPOSE OF THIS REVISION IS TO DEVELOP THE REQUIRE	D RESPONSE SPECTRA FOR THE
	RADIATION MONITORING EQUIPMENT FOR THE PURPOSE OF EV	ALUATING VENDOR SEISMIC REPORTS.
	PAGES ADDED:	
	SHEETS: 1a, 2a, 3a, A1-A42 (Appendix A, 42 Sheets), Attachment B (8	8 pages).
	PAGES REVISED.	
	SHEETS: None	
	PAGES REPLACED:	
	SHEETS: 4, Attachment Table of Contents	• *
÷	PAGES DELETED:	
	SHEETS: None	
	TOTAL NUMBER OF PAGES: 24+53 = <u>77</u>	
	TOTAL NUMBER OF PAGES: 24+53 = <u>77</u> THE WBN SAR, WBN2 FSAR AMENDMENT 107, TECHNICAL SPECI REQUIREMENTS MANUAL/ BASES HAVE BEEN REVIEWED BY / FOR APPLICABILITY TO UNIT 2, DUAL UNIT OPERATION AND THIS NOT AFFECT ANY OF THESE DOCUMENTS.	IFICATIONS/ BASES AND TECHNICAL 16/17 16/17 S REVISION OF THE CALCULATION DOES
· .	TOTAL NUMBER OF PAGES: 24+53 = <u>77</u> THE WBN SAR, WBN2 FSAR AMENDMENT 107, TECHNICAL SPEC REQUIREMENTS MANUAL/ BASES HAVE BEEN REVIEWED BY /2 FOR APPLICABILITY TO UNIT 2, DUAL UNIT OPERATION AND THIS NOT AFFECT ANY OF THESE DOCUMENTS.	IFICATIONS/ BASES AND TECHNICAL 16/17 20/07/2014 - August 16/17 S REVISION OF THE CALCULATION DOES
	TOTAL NUMBER OF PAGES: 24+53 = <u>77</u> THE WBN SAR, WBN2 FSAR AMENDMENT 107, TECHNICAL SPECI REQUIREMENTS MANUAL/ BASES HAVE BEEN REVIEWED BY / FOR APPLICABILITY TO UNIT 2, DUAL UNIT OPERATION AND THIS NOT AFFECT ANY OF THESE DOCUMENTS.	IFICATIONS/ BASES AND TECHNICAL 16/17 S REVISION OF THE CALCULATION DOES
	TOTAL NUMBER OF PAGES: 24+53 = <u>77</u> THE WBN SAR, WBN2 FSAR AMENDMENT 107, TECHNICAL SPECT REQUIREMENTS MANUAL/ BASES HAVE BEEN REVIEWED BY /2 FOR APPLICABILITY TO UNIT 2, DUAL UNIT OPERATION AND THIS NOT AFFECT ANY OF THESE DOCUMENTS.	FICATIONS/ BASES AND TECHNICAL 16/12 S REVISION OF THE CALCULATION DOES
	TOTAL NUMBER OF PAGES: 24+53 = <u>77</u> THE WBN SAR, WBN2 FSAR AMENDMENT 107, TECHNICAL SPECI REQUIREMENTS MANUAL/ BASES HAVE BEEN REVIEWED BY / FOR APPLICABILITY TO UNIT 2, DUAL UNIT OPERATION AND THIS NOT AFFECT ANY OF THESE DOCUMENTS.	IFICATIONS/ BASES AND TECHNICAL <i>Sobit He Record of Particular</i> S REVISION OF THE CALCULATION DOES
	TOTAL NUMBER OF PAGES: 24+53 = 77 THE WBN SAR, WBN2 FSAR AMENDMENT 107, TECHNICAL SPECI REQUIREMENTS MANUAL/ BASES HAVE BEEN REVIEWED BY /2 FOR APPLICABILITY TO UNIT 2, DUAL UNIT OPERATION AND THIS NOT AFFECT ANY OF THESE DOCUMENTS.	IFICATIONS/ BASES AND TECHNICAL Abert Brown A Marine 16/17 S REVISION OF THE CALCULATION DOES
	TOTAL NUMBER OF PAGES: 24+53 = 77 THE WBN SAR, WBN2 FSAR AMENDMENT 107, TECHNICAL SPECT REQUIREMENTS MANUAL/ BASES HAVE BEEN REVIEWED BY /2 FOR APPLICABILITY TO UNIT 2, DUAL UNIT OPERATION AND THIS NOT AFFECT ANY OF THESE DOCUMENTS.	IFICATIONS/ BASES AND TECHNICAL 16/17
	TOTAL NUMBER OF PAGES: 24+53 = 77 THE WBN SAR, WBN2 FSAR AMENDMENT 107, TECHNICAL SPECI REQUIREMENTS MANUAL/ BASES HAVE BEEN REVIEWED BY / FOR APPLICABILITY TO UNIT 2, DUAL UNIT OPERATION AND THIS NOT AFFECT ANY OF THESE DOCUMENTS.	IFICATIONS/ BASES AND TECHNICAL 16/17
	TOTAL NUMBER OF PAGES: 24+53 = 77 THE WBN SAR, WBN2 FSAR AMENDMENT 107, TECHNICAL SPECT REQUIREMENTS MANUAL/ BASES HAVE BEEN REVIEWED BY FOR APPLICABILITY TO UNIT 2, DUAL UNIT OPERATION AND THIS NOT AFFECT ANY OF THESE DOCUMENTS.	IFICATIONS/ BASES AND TECHNICAL Cobert - Contract - 16/17 S REVISION OF THE CALCULATION DOES
	TOTAL NUMBER OF PAGES: 24+53 = 77 THE WBN SAR, WBN2 FSAR AMENDMENT 107, TECHNICAL SPECT REQUIREMENTS MANUAL/ BASES HAVE BEEN REVIEWED BY /2 FOR APPLICABILITY TO UNIT 2, DUAL UNIT OPERATION AND THIS NOT AFFECT ANY OF THESE DOCUMENTS.	IFICATIONS/ BASES AND TECHNICAL 1/6/17
	TOTAL NUMBER OF PAGES: 24+53 = 77 THE WBN SAR, WBN2 FSAR AMENDMENT 107, TECHNICAL SPECI REQUIREMENTS MANUAL/ BASES HAVE BEEN REVIEWED BY / FOR APPLICABILITY TO UNIT 2, DUAL UNIT OPERATION AND THIS NOT AFFECT ANY OF THESE DOCUMENTS.	IFICATIONS/ BASES AND TECHNICAL 1/6/17
	TOTAL NUMBER OF PAGES: 24+53 = 77 THE WBN SAR, WBN2 FSAR AMENDMENT 107, TECHNICAL SPECT REQUIREMENTS MANUAL/ BASES HAVE BEEN REVIEWED BY /2 FOR APPLICABILITY TO UNIT 2, DUAL UNIT OPERATION AND THIS NOT AFFECT ANY OF THESE DOCUMENTS.	IFICATIONS/ BASES AND TECHNICAL 16/12
	TOTAL NUMBER OF PAGES: 24+53 = 77 THE WBN SAR, WBN2 FSAR AMENDMENT 107, TECHNICAL SPECI REQUIREMENTS MANUAL/ BASES HAVE BEEN REVIEWED BY FOR APPLICABILITY TO UNIT 2, DUAL UNIT OPERATION AND THIS NOT AFFECT ANY OF THESE DOCUMENTS.	IFICATIONS/ BASES AND TECHNICAL III/12 South Construction of the calculation does
	TOTAL NUMBER OF PAGES: 24+53 = 77 THE WBN SAR, WBN2 FSAR AMENDMENT 107, TECHNICAL SPECT REQUIREMENTS MANUAL/ BASES HAVE BEEN REVIEWED BY FOR APPLICABILITY TO UNIT 2, DUAL UNIT OPERATION AND THIS NOT AFFECT ANY OF THESE DOCUMENTS.	IFICATIONS/ BASES AND TECHNICAL 16/12 Sobe HE Brown of THE CALCULATION DOES
	TOTAL NUMBER OF PAGES: 24+53 = 77 THE WBN SAR, WBN2 FSAR AMENDMENT 107, TECHNICAL SPECT REQUIREMENTS MANUAL/ BASES HAVE BEEN REVIEWED BY FOR APPLICABILITY TO UNIT 2, DUAL UNIT OPERATION AND THIS NOT AFFECT ANY OF THESE DOCUMENTS.	IFICATIONS/ BASES AND TECHNICAL 16/17
	TOTAL NUMBER OF PAGES: 24+53 = <u>77</u> THE WBN SAR, WBN2 FSAR AMENDMENT 107, TECHNICAL SPECT REQUIREMENTS MANUAL/ BASES HAVE BEEN REVIEWED BY /2 FOR APPLICABILITY TO UNIT 2, DUAL UNIT OPERATION AND THIS NOT AFFECT ANY OF THESE DOCUMENTS.	IFICATIONS/ BASES AND TECHNICAL III/12 South Construction DOES

This Sheet Added By Revision 001

## NPG CALCULATION COVERSHEET/CCRIS UPDATE

		_							•	Page _	1
<u>revoedn</u> T9	<u>15/R</u>	<u>ims no.</u> 1 1 0	407	7002		EDM: calculatio	S TYPE: ons(nuclear)	EDMS ACCE N/A	SSION NO (I	V/A for REV	<u>′. 0)</u>
Calc Title: IN-CABIN	ET	REQUI	RED RE	SPONSE SPI	ECTRA FO	R RM-100	0 RADIATI	ON MONITO	RS IN MCR	PANEL 2	-M-30
<u>ÇALC ID</u>		<u>TYPE</u>	<u>ORG</u>	PLANT	BRANCH		NUMBER		CUR REV	NEW REV	<u>/</u>
CURREN	r	CN	NUC								REVISION APPLICABILITY
NEW		CN	NUC	WBN	CEB	<u> </u>	WCGACQO	766	000	•	Entire calc  Selected pages
ACTION	NE RE	W VISIÓN		delete ( Rename (	] SUPER	RSEDE CATE	CCRIS (Verifie Require	UPDATE ONL r Approval Sigr ed)	Y 🔲 natures Not		lo CCRIS Changes For calc revision, CCRIS een reviewed and no CCRIS changes required)
<u>UNITS</u> 002		<u>SYS1</u> 090	EMS				UNIDS WBN-2-PNL-( WBN-2-RM-0 WBN-2-RM-0	090-M30, WE 90-0272, WE 90-0273A, WE	3N-2-RM-090- 3N-2-RM-090- 3N-2-RM-090-	0271, W 0272A, W 0274, W	BN-2-RM-090-0271A BN-2-RM-090-0273, BN-2-RM-090-0274A
DCN.EDC.I N/A	<u>N/A</u>			APPLICABLE WB-DC-40-3	DESIGN DO	OCUMENT S-5.10	<u>(S)</u> :				CLASSIFICATION E
QUALIT RELATE Yes 🛛 🔊	Ƴ D? Io □	SAF (if   Y	ETY REL yes, QR es 🛛 🛛 N	<u>ATED?</u> <u> </u> = yes) <u>A</u> No □ Yo		AND	PECIAL REC /OR LIMITING Yes 🗌		S? DESIG ATTAC Yes [	N OUTPUT CHMENT? ] Nº ⊠	SAR/TS and/or ISFSI SAR/CoC AFFECTED
PREPAREI EHALI	םו א		PREPAR NO (423) 36	RER PHONE	PREPA	ARING ORC CEB	<u> (BRANCH)</u>	VERIFICAT METHOD DESIGN RE	<u>ion</u> view	<u>NEW M</u> Yes	IETHOD OF ANALYSIS
ODEDADE	RSIC	SNATUR	E			DATE		SIGNATURE	119	/	DATE
EYAD H. A		Æ	2		04	105/11	FORTO	Flown /		m	4/3/11
EYAD H. A VERIFIERS Loberty	LI SIGN	WTURE WWN/	AL	him	- 4/.	05/11 DATE 5/11	APPROVA BILL C. PE	L SIGNATURE	a porta	n R	9-/3/// DATE 4-5-11
EYAD H. A. VERIFIER S Lobert 6 STATEMEN THIS CALC WBNP UNIT		E PROB	LEM/ABS	STRACT THE IN-CABI	- 4/. NET REQUIR 2-M-30.	Cos / I) DATE Cos / II RED RESPO	APPROVA BILL C. PE	A FOR THE RN	4-1000 RADIA	TION MON	4-5-11
EYAD H. A VERIFIER S Lobert G STATEMEN THIS CALC WBNP UNIT		E PROB	LEM/ABS EVELOPS NTROL R	STRACT THE IN-CABI	- 4/. NET REQUIN	DATE	APPROVA BILL C. PE	A FOR THE RM	4-1000 RADIA	TION MON	4-5-11
EYAD H. A VERIFIER S Lobert & STATEMEN THIS CALC WBNP UNIT	LI SIGN TO ULA	E PROB TION DE TION DE	LEM/ABS EVELOPS NTROL R	STRACT THE IN-CABI	- 41. NET REQUIE 2-M-30.	DATE	APPROVA BILL C. PE	A FOR THE RN	4-1000 RADIA	TION MON	9-/3/11       DATE       4-5-11
EYAD H. A VERIFIER S Loberty STATEMEN THIS CALC WBNP UNIT		E PROB TION DE	LEM/ABS EVELOPS NTROL R	STRACT THE IN-CABI	- 4/. NET REQUIN	COS / 1) DATE	APPROVA BILL C. PE	LEGIBILI FOR ISSU	A-1000 RADIA	JATED A GES IN R	DATE 4-5-11 HITORS MOUNTED ON ND ACCEPTED EV. 0
EYAD H. A VERIFIER S Loberty STATEMEN THIS CALC WBNP UNIT		E PROB TION DE TAIN CO	LEM/ABS SVELOPS NTROL R	STRACT THE IN-CABI	- 4/. NET REQUIE	Cos / II	APPROVA BILL C. PE	LEGIBILI FOR THE RM FOR ISSU EYAD H. SIGNATU	A-1000 RADIA	JATED A GES IN R	DATE 4-5-11 HTORS MOUNTED ON ND ACCEPTED EV. 0 $-\frac{04/a5/11}{DATE}$
EYAD H. A VERIFIER S Lobert & STATEMEN THIS CALC WBNP UNIT		E PROB TION DE TION DE TAIN CO	LEM/ABS EVELOPS NTROL R	STRACT THE IN-CABI ROOM PANEL	- 4/. NET REQUIN 2-M-30.	E NUMBE	APPROVA BILL C. PE	LEGIBILI FOR THE RM FOR ISSU EYAD H. SIGNATU	A-1000 RADIA	JATED A GES IN R	DATE 4-5-11 HITORS MOUNTED ON ND ACCEPTED EV. 0 
EYAD H. A VERIFIER S Lobert & STATEMEN THIS CALC WBNP UNIT		E PROB TION DE TION DE TION DE TION DE TION DE TO EDMI	CHE S AND DI S AND DI S AND DI	Yes No ESTROY ETURN CALC	PH NET REQUIN 2-M-30.	ED RESPO	R(S)	A FOR THE RM LEGIBILI FOR ISSU EYAD H. SIGNATU	A-1000 RADIA	JATED A GES IN R	DATE 4-5-11 HITORS MOUNTED ON ND ACCEPTED EV. 0 $-\frac{04/25/11}{DATE}$

TVA 40532 [10-2008]

NEDP-2-1 [10-20-2008]

## NPG CALCULATION COVERSHEET/CCRIS UPDATE

								Page 2	
CALC ID	TYPE	ORG	PLANT	BRANCH	NUMBE	R	REV		
	CN	NUC	WBN	CEB	WCGACQ	0766	000		
			A	LTERNATE CALC	CULATION IDEN	TIFICATION			
				· · · · · · · · · · · · · · · · · · ·	· · · · · · · · · · · · · · · · · · ·	· · · · · · · · · · · · · · · · · · ·			
			· · · · · · · · · · · · · · · · · · ·						2
BLDG 05	<u>RO</u>	OM R	<u>ELEV</u> 755'	<u>COORD/AZIM</u> N/A	<u>FIRM</u> BECHTEL	Print Report	Yes 🗌		
CATEGORII	ES: A09				· ·				

# KEY NOUNS (A-add, D-delete)

ACTION	KEY NOUN	<u>A/D</u>	KEY NOUN
(A/D)			
A	SEISMIC QUALIF		
A	SEISMIC		
A	RESPONSE SPECTR		
Α	PANEL		

# <u>CROSS-REFERENCES</u> (A-add, C-change, D-delete)

ACTION (A/C/D)	XREF <u>CODE</u>	XREF TYPE	XREF <u>PLANT</u>	XREF BRANCH	XREF <u>NUMBER</u>		XREF REV		
A	Р	DN	WBN	EEB	EDCR-2 52338				
Α	P	CN	WBN	CEB	WCGACQ0177				
А	Р	CN	WBN	CEB	CEBCQS448				
A	· P	CN	WBN	CEB	CEBCQS447				
Α	Р	DB	WBN	CEB	CEB-SS-5.10				
A	Р	CE	WBN	CEB	CEB-80-27	.:			
Α	Р	VD	WBN	EEB	04034100				
				•					
		·							
			· .						
CCRIS ONLY L Following are re	JPDATES: equired only wh	en making keyv	word/cross refere	ence CCRIS upo	dates and page 1 of form NEDP-2-1 is not i	ncluded:			
						_			
F	PREPARER SI	GNATURE		DATE	CHECKER SIGNATURE	DAT	E		
PREPARER PH	IONE NO.		ED	MS ACCESSIC	NNO.				
TVA 40532 [10-2	008]		Page 2 of 2	of 2 NEDP-2-1 [10-20-2008]					

		3	-
Title	IN-CABINET REQUIRED RESPONSE SPECTRA FOR RM-1000 RADIATION MONITORS IN	MCR PAN	EL 2-M-30
Revision No.	DESCRIPTION OF REVISION		
000	ORIGINAL ISSUE		
	TOTAL NUMBER OF PAGES: <u>24</u>		
	THE WBN SAR, WBN2 FSAR AMENDMENT 103, TECHNICAL SPECIFICATIONS/ BASES AND REQUIREMENTS MANUAL/ BASES HAVE BEEN REVIEWED BY <b>EYAD H. ALISE</b> APPLICABILITY TO UNIT 2, DUAL UNIT OPERATION AND THIS REVISION OF THE CALCUL AFFECT ANY OF THESE DOCUMENTS.	TECHNICA	L FOI ES NOT
·			
		·	
		. *	
A 40709 [10	-2008] Page 1 of 1	NEDP-2-2	10-20-200

			Page	4
	NPG CALCULATION TA	ABLE OF CONT	ENTS	
Calculation	dentifier: WCGACQ0766	Revision:	001	
	TABLE OF C	ONTENTS	_	
SECTION	TIT	LE		PAGE
1.0	COVER SHEETS			1
2.0	<b>REVISION LOG</b>			3
3.0	TABLE OF CONTENTS			4
4.0	PURPOSE			5
5.0	APPLICABLE DESIGN BASIS			5
6.0	APPLICABLE REFERENCES	· ·		5
7.0	ASSUMPTIONS			6
8.0	SPECIAL REQUIREMENTS AND LIMITI	NG CONDITION	S	6
9.0	METHODOLOGY			6
10.0	JUSTIFICATION/ANALYSIS			7
11.0	CONCLUSION			18
11.1	APPENDIX A			A1
12.0	ATTACHMENTS (TOTAL No. OF PAGES	(14)		

SUPERSEDED PAGES: (0 Pages)

TVA 40710 [10-2008]

Page 1 of 1

NEDP-2-3 [10-20-2008]

This Sheet Replaced By Revision 001

Subjec	Calcula ct: IN-CABINET REQUIRED RESP RM-1000 RADIATION MONITO ed: SEE COVER SHEET	ation Sheet onse spectra for ors in mcr panel 2-m-30	Project Job No. Calc. No.	WBN2CCP 25402
Subjec	ct: <u>IN-CABINET REQUIRED RESP</u> <u>RM-1000 RADIATION MONITC</u> ed: <u>SEE COVER SHEET</u>	ONSE SPECTRA FOR IRS IN MCR PANEL 2-M-30	Job No. Calc. No.	25402
Subjec	ct: <u>IN-CABINET REQUIRED RESP</u> <u>RM-1000 RADIATION MONITO</u> ed: <u>SEE COVER SHEET</u>	<u>'ONSE SPECTRA FOR</u> IRS IN MCR PANEL 2-M-30	Calc. No.	WCGACO0766
	RM-1000 RADIATION MONITO	ORS IN MCR PANEL 2-M-30	1 1	wCGACQ0700
	ed: SEE COVER SHEET		Sheet No.	5
Prepare		Date	Sheet Rev.	000
Checke	ed: SEE COVER SHEET	Date	_	
		·		REFERENCE
4.0 <u>P</u> U	URPOSE			
This Radia These Instru	calculation develops the in-ca ation Monitors to be installed e radiation monitors together umentation Modules (NIM) b	binet required response spoin WBNP Unit 2 Main Conwith I/F Converters are instants in Panel 2-M-30.	ectra for the RM ntrol Room Pan talled in Nuclea	1-1000 el 2-M-30. r
5.0 <u>AP</u>	PLICABLE DESIGN BAS	<u>IS</u>	· · · ·	
1. W El	B-DC-40-31.2 Rev. 12, "Seis ectrical and Mechanical Equi	mic/Structural Qualificatio	on of Seismic Ca	ategory I
2. CI De	EB-SS-5.10 Rev. 3, "Seismic evices"	Qualification of Electrical,	, Mechanical, an	id I&C
6.0 <u>AP</u>	PPLICABLE REFERENCE	<u>s</u>		
1. EI	DCR-2 52338 Rev. A			
2. W (R	7CGACQ0177 Rev. 7, "Seism UMS# T93100515007).	ic Evaluation of Panel 2-M	1-30 & 2-M-31"	
3. CI Qu	EBCQS448 Rev. 0, "Definition ualification" (RIMS# B41960	on of Required Acceleration 425002)	n Input for Devi	ce Seismic
4. Cl De	EBCQS447 Rev. 2, "Standard evices" (RIMS# B410709050	l Equipment Seismic Quali 01)	fication Method	ls for
5. Cl Bi	EB-80-27 Rev. 5, "Dynamic l uilding and Response Spectra	Earthquake Analysis of the for Attached Equipment"	Auxiliary Contr	rol
6. G	eneral Atomics Dwg No. 040	34100 Rev. C	· ·	
7. D	RA No. 52374-13 Rev. 0			See Attachment
8. D	RA No. 52338-005 Rev. 0	· . · ·		for Copy of Refs 66-6
9. D	RA No. 52338-038 Rev. 0			1013. 0.0-0.

TEL				Project	WB	N2CCP
BECH	Calcu	lation Shee	t	Job No.	. 2	5402
Subject: IN-CABI	NET REOUIRED RES	PONSE SPECTR	A FOR	Calc. No.	WCG	ACQ0766
<u>RM-1000</u>	RADIATION MONIT	ORS IN MCR PA	NEL 2-M-30	Sheet No.	· · ·	6
Prepared: SEE COVI	ER SHEET	Date		Sheet Rev.	(	)00
Checked: SEE COVI	ER SHEET	Date			<u></u>	
						REFERENCES
5.0 APPLICAB	LE REFERENC	ES (CONT'D)				
10 Roark's For	nulas for Stress ar	d Strain 7 <sup>th</sup> Ed				
TO, ROAR STON	nulas for Sucss at		•			See
11. General Elec	tric Dwg No. 015	3D2768-1 Rev	. 1		5 - 5 <sup>-</sup> 5	Attachment A
12. TVA Dwg N	o. 47W605-1 Rev	. 15				Ref. 6.11
.0 <u>ASSUMPT</u> I	DNS					
None	•					
None	•					
3.0 <u>SPECIAL I</u>	REQUIREMENT	<u>'S AND LIMI</u>	TING COND	<b>ITIONS</b>		: 
None						
9.0 <u>METHOD</u>	<u>DLOGY</u>					
<b>0.0</b> <u>METHOD</u>	DLOGY	-COS-448 area	used to develo	n the in-cabit	net required	Ref 63
<b>0.0</b> <u>METHOD</u> The methods from response spectra	DLOGY om Calc No. CEB a at the RM-1000	-CQS-448 are mounting locat	used to develo ions for WBN	p the in-cabin Unit 2 MCR	net required Panel	Ref. 6.3
<b>.0 METHOD</b> The methods from response spectration 2-M-30.	DLOGY om Calc No. CEB a at the RM-1000	-CQS-448 are mounting locat	used to develo ions for WBN	p the in-cabin Unit 2 MCR	net required Panel	Ref. 6.3
<b>METHOD</b> The methods from response spectra 2-M-30.	DLOGY om Calc No. CEB a at the RM-1000	-CQS-448 are mounting locat	used to develo ions for WBN	p the in-cabin Unit 2 MCR	net required Panel	Ref. 6.3
.0 <u>METHOD</u> The methods from response spectra 2-M-30.	DLOGY om Cale No. CEB a at the RM-1000	-CQS-448 are mounting locat	used to develo ions for WBN	p the in-cabin Unit 2 MCR	net required Panel	Ref. 6.3
.0 <u>METHOD</u> The methods from response spectra 2-M-30.	DLOGY om Cale No. CEB a at the RM-1000	-CQS-448 are mounting locat	used to develo ions for WBN	p the in-cabin Unit 2 MCR	net required Panel	Ref. 6.3
.0 <u>METHOD</u> The methods from response spectra 2-M-30.	DLOGY om Cale No. CEB a at the RM-1000	-CQS-448 are mounting locat	used to develo ions for WBN	p the in-cabin Unit 2 MCR	net required Panel	Ref. 6.3
.0 <u>METHOD</u> The methods from response spectra 2-M-30.	DLOGY om Cale No. CEB a at the RM-1000	-CQS-448 are mounting locat	used to develo ions for WBN	p the in-cabin Unit 2 MCR	net required Panel	Ref. 6.3
.0 <u>METHOD</u> The methods from response spectra 2-M-30.	DLOGY om Calc No. CEB a at the RM-1000	-CQS-448 are mounting locat	used to develo ions for WBN	p the in-cabin Unit 2 MCR	net required Panel	Ref. 6.3
<b>9.0</b> <u>METHOD</u> The methods from response spectra 2-M-30.	DLOGY om Calc No. CEB a at the RM-1000	-CQS-448 are mounting locat	used to develo ions for WBN	p the in-cabin Unit 2 MCR	net required Panel	Ref. 6.3
<b>.0</b> <u>METHOD</u> The methods from response spectra 2-M-30.	DLOGY om Calc No. CEB a at the RM-1000	-CQS-448 are mounting locat	used to develo ions for WBN	p the in-cabin Unit 2 MCR	net required Panel	Ref. 6.3
<b>D.0</b> <u>METHOD</u> The methods from response spectra 2-M-30.	DLOGY om Cale No. CEB a at the RM-1000	-CQS-448 are mounting locat	used to develo ions for WBN	p the in-cabin Unit 2 MCR	net required Panel	Ref. 6.3
<b>9.0</b> <u>METHOD</u> The methods from response spectra 2-M-30.	DLOGY om Cale No. CEB a at the RM-1000	-CQS-448 are mounting locat	used to develo ions for WBN	p the in-cabin Unit 2 MCR	net required Panel	Ref. 6.3

	Calculation Sheet		Project	WBN2CCP
BEB	Galculation	Calculation Sheet		25402
Subject: IN	N-CABINET REQUIRED RESPONSE SI	PECTRA FOR	Calc. No.	WCGACQ0766
<u>R</u>	<b>RM-1000 RADIATION MONITORS IN MCR PANEL 2-M-30</b>		Sheet No.	7
Prepared: s	SEE COVER SHEET	_ Date	Sheet Rev.	000
Checked: s	SEE COVER SHEET	Date		

REFERENCES

Ref. 6.2

## 10.0 JUSTIFICATION/ANALYSIS

From Sheet 34 of Appendix I of Calc No. WCG-ACQ-0177, the first and second mode frequencies of Panel 2-M-30 are 13.35 Hz and 15.33 Hz respectively. Since WCG-ACQ-0177 does not define the direction of these modes, these frequencies are conservatively considered to be in the two horizontal directions and the vertical direction. The methods in sections 4.1.3.2 and 4.1.3.3 of Ref. 6.2 are used to compute the worst case maximum acceleration in each direction at the device locations on the panel. The equations to compute the input accelerations at the device locations are as follows:

For the Horizontal direction:

$$Ap_{k,h} := \sqrt{(2.1 \text{ S} \cdot Ap_{k,1})^2 + (1.3 \text{ S} \cdot Ap_{k,2})^2 + (1.6 \text{ A}p_{k,3})^2 + A_{zpa,k}^2}$$

For the Vertical direction:

$$Ap_{k,v} := \sqrt{(1.6 Ap_{k,3})^2 + A_{zpa,k}^2}$$

where,

 $S := \frac{x}{L}$ 

 $Ap_{k,1}$  is the panel acceleration at the first mode frequency.

is the device position ratio. x is the height from the ground to the device and L is the total height of the panel.

 $Ap_{k,2}$  Is the panel acceleration at the second mode frequency.

 $Ap_{k,3}$  is the acceleration corresponding to the panel local frequency at the device location.

 $\mathbf{A}_{\textbf{zpa.k}}$  is the panel acceleration at cut-off frequency (33 Hz).

According to Section 4.1.3.3 of Ref. 6.2; since the mass and stiffness distribution is reasonably uniform along the height of the host panel (as shown in Ref. 6.11), a  $1^{st}$  mode participation factor of 1.6 and a  $2^{nd}$  mode participation factor of 1.0 can be used.

Ca	Iculation Sheet	Project	WBI	N2CCP
U Ca		Job No.	Job No. 254	
Subject: <u>IN-CABINET REQUIREI</u>	D RESPONSE SPECTRA FOR	Calc. No.	WCGA	ACQ0766
RM-1000 RADIATION M	RM-1000 RADIATION MONITORS IN MCR PANEL 2-M-30 Sheet No.			8
Prepared: SEE COVER SHEET	Date	Sheet Rev.	0	00
Checked: SEE COVER SHEET	Date		.*	
				REFERENCES
0.0 JUSTIFICATION/ANA	LYSIS (CONT'D)		; ]	<u> </u>
Determination of Local Freq	uency:			·
Weight of Front Plate:		•		
$W_{\text{plate}} := 0.283 \frac{\text{lb}}{\text{in}^3} \cdot [(11.75 \text{ in } 30)]$	$(1.1) - (8.7 \text{ in } 18.25 \text{ in}) = \frac{1}{4} \cdot \text{in}$	W <sub>plate</sub> = 13.706lb		Ref. 6.6 & 6.
Weight of Radiation Monitoring	NIM bin:			
$W_{RM} := 35 \text{ lb}$ (each)				Ref. 6.6
Consider the Front Plate of the total weight to be uniformly loa	Panel to be simply supported on a ded over entire area:	II four sides and the		
$q \coloneqq \frac{W_{\text{plate}} + W_{\text{RM}}}{11.75 \text{ in } 30 \text{ in}}$	$q = 0.138 \frac{lb}{in^2}$			· · ·
The maximum local displacement Table 11.4 on Page 502 of Ref	ent of the Front Plate per Case No 6.10 is:	1 of		
a := 30 in b := 11.75 in	$\frac{a}{b} = 2.553 \implies 3.0  \alpha :=$	= 0.1335		
$t_{\text{plate}} := \frac{1}{4} \cdot \text{in}$ $E_{\text{steel}} :=$	29000 ksi	·		
	• · · · · ·			
$\mathbf{v} := \frac{\alpha \cdot \mathbf{q} \cdot \mathbf{b}^4}{\alpha \cdot \mathbf{q} \cdot \mathbf{b}^4}$	$y = 7.76 \times 10^{-4}$ in	· 、		
<sup>5</sup> max <sup>3</sup> Esteel <sup>t</sup> plate				
- -		. ·		i.
$f_{local} := \frac{1}{2 \cdot \pi} \sqrt{\frac{g}{y_{max}}}$	$f_{local} = 112.265Hz$			
As shown above, the frequen	ncy of the Front Plate where the	e device is mounted ( will be no contributio	local on to	· ·

	Calculation Sheet	Project	WBN2CCP
BLEE			25402
Subject: <u>IN-CABINET REC</u>	DUIRED RESPONSE SPECTRA FOR	Calc. No.	WCGACQ0766
RM-1000 RADIAT	ION MONITORS IN MCR PANEL 2-M-30	Sheet No.	9
Prepared: SEE COVER SHEET	Date	Sheet Rev.	000
Checked: SEE COVER SHEET	Date	, <sub>.</sub>	. *
		· · · ·	REFERENCES

# 10.0 JUSTIFICATION/ANALYSIS (CONT'D)

Therefore, the equations for the input acceleration from Sheet 7 is reduced to:

 $Ap_{k,h} := \sqrt{(1.6 \text{ S} \cdot Ap_{k,1})^2 + (1.0 \text{ S} \cdot Ap_{k,2})^2 + A_{zpa,k}^2}$ 

(Horizontal)

 $Ap_{k,v} := A_{zpa,k}$  (Vertical)

Determination of the Device Position Ratio (S):

The device at the higher elevation on the panel is only considered since it has a greater input acceleration. Per Ref. 6.7-6.9, the device position ratio is as follows:

 $x := 28.375 \text{ in} + 2 \cdot (11.75 \text{ in})$  x = 51.875 in  $L := 98 \cdot \text{in}$  $S := \frac{x}{L}$  S = 0.529

The accelerations corresponding to the  $1^{st}$ ,  $2^{nd}$ , and cut-off frequencies are as follows:

According to Ref. 6.3; 3% damping ratio for SSE is used since the actual damping ratio is not obtainable.

For N-S (Front-to-Back) Direction SSE:

 $Ap_{k,1,NS} := 1.93 g$   $Ap_{k,2,NS} := 1.24 g$ 

 $A_{zpa.k.NS} = 0.84 g$ 

For E-W (Side-to-Side) Direction SSE:

 $Ap_{k,1,EW} = 2.34g$   $Ap_{k,2,EW} = 1.39g$ 

 $A_{zpa.k.EW} \approx 0.87 \text{ g}$ 

For Vertical Direction SSE:

 $A_{zpa.k.V} = 0.84 g$ 

ALLEL A	Calculation Sheet	Project	WBN2CCP
	Calculation Onect	Job No.	25402
Subject: <u>IN-CABINET RE</u>	<b>QUIRED RESPONSE SPECTRA FO</b>	R Calc. No.	WCGACQ0766
RM-1000 RADIA	TION MONITORS IN MCR PANEL	2-M-30 Sheet No.	10
Prepared: _SEE COVER SHEE	rDate	Sheet Rev.	000
Checked: SEE COVER SHEE	г Date		
· · · · · · · · · · · · · · · · · · ·		· · · · ·	REFERENCE
0.0 JUSTIFICATIO	N/ANALYSIS (CONT'D)		
Using the methods pro (RRS) for the RM-100 in Panel 2-M-30 is de <i>N-S (Front-to-Back)</i>	ovided in Section 4.2 of Ref. 6 00 Radiation Monitors and I/F termined as follows: <b>Required Response Spectra</b> (S	.3, the Required Response Converters in NIM bins in SSE 5% Damping):	Spectra astalled
$Ap_{k.NS} := \sqrt{(1.6 \text{ S} \cdot \text{A})}$	$(1.0 \text{ S} \text{ Ap}_{k.2.\text{NS}})^2 + (1.0 \text{ S} \text{ Ap}_{k.2.\text{NS}})^2 + \text{ A}_{k.2.\text{NS}}$	$\frac{2}{2}$ Ap <sub>k,NS</sub> =	1.951g
From Page 33 of Re	ef. 6.3, m := 2.3314 b	:= 0.45 g	
$f_{NS_1} := 1 \cdot Hz$	$A_{NS_1} := b$	$A_{NS_1} = 0.45g$	
$A_{NS_2} := 5 \cdot Ap_{k.NS}$		$A_{NS_2} = 9.757g$	
$f_{NS_2} := \left(\frac{A_{NS_2}}{b}\right)^m.$	Hz $f_{NS_2} = 3.74$	2Hz	
f <sub>NS3</sub> := 16 Hz	$A_{NS_3} = A_{NS_2}$	$A_{NS_3} = 9.757g$	
$f_{NS_4} := 33 \cdot Hz$	$A_{NS_4} = 2 A_{pk,NS}$	$A_{NS_4} = 3.903g$	
f <sub>NS5</sub> := 33 Hz	$A_{NS_5} := Ap_{k.NS}$	$A_{NS_5} = 1.951g$	
$f_{NS_6} := 100 \text{ Hz}$	$A_{NS_6} := Ap_{k.NS}$	$A_{NS_6} = 1.951g$	

<b>FRIT</b>	Calculation Sheet	Project	WBN2CCP
			25402
Subject: <u>IN-CABINET</u>	REQUIRED RESPONSE SPECTRA FOR	Calc. No.	WCGACQ0766
<u>RM-1000 RA</u>	DIATION MONITORS IN MCR PANEL 2-M-30	Sheet No.	. 11
Prepared: SEE COVER S	HEET Date	Sheet Rev.	000
Checked: <u>SEE COVER S</u>	HEET Date		· · ·

REFERENCES 10.0 JUSTIFICATION/ANALYSIS (CONT'D) E-W (Side-to-Side) Required Response Spectra (SSE 5% Damping):  $Ap_{k.EW} = \sqrt{(1.6 \text{ S} \cdot Ap_{k.1.EW})^2 + (1.0 \text{ S} \cdot Ap_{k.2.EW})^2 + A_{zpa.k.EW}^2}$  $Ap_{k.EW} = 2.286g$ From Page 33 of Ref. 6.3, m := 2.3314  $b := 0.45 \, g$  $\mathbf{f}_{EW_1} \coloneqq 1 \cdot \mathbf{Hz}$  $A_{EW_1} := b_1$  $A_{EW_1} = 0.45g$  $A_{EW_2} := 5 \cdot A_{pk.EW}$  $A_{EW_2} = 11.43g$  $f_{EW_2} := \left(\frac{A_{EW_2}}{b}\right)^m \cdot Hz$  $f_{\rm EW_2} = 4.005 \rm Hz$  $f_{\dot{E}W_3} \coloneqq 16 \text{ Hz}$  $A_{EW_3} = 11.43g$  $A_{EW_3} := A_{EW_2}$  $f_{EW_4} := 33 \cdot Hz$  $A_{EW_4} := 2 \cdot A_{p_{k.EW}}$  $A_{EW_4} = 4.572g$  $f_{EW_5} := 33 \cdot Hz$  $A_{EW_5} := Ap_{k.EW}$  $A_{EW_5} = 2.286g$  $f_{EW_6} \coloneqq 100 \, \text{Hz}$  $\mathbf{A}_{\mathbf{EW}_{6}} \coloneqq \mathbf{Ap}_{\mathbf{k}.\mathbf{EW}}$  $A_{EW_6} = 2.286g$ 

	Coloulati	n Shoot	Project	WBN2CCP
B	Calculation Sneet		Job No.	25402
Subject: <u>IN-CA</u>	BINET REQUIRED RESPONS	SE SPECTRA FOR	Calc. No.	WCGACQ0766
<u>RM-10</u>	00 RADIATION MONITORS	IN MCR PANEL 2-M-30	Sheet No.	12
Prepared: SEE Co	OVER SHEET	Date	Sheet Rev.	000
Checked: SEE CO	OVER SHEET	Date		
I		· · · · · · · · · · · · · · · · · · ·		



	Calculation	Calculation Sheet	Project	WBN2CCP
	Calculation Sheet		Job No.	25402
Subject: <u>IN-CABINI</u>	ET REQUIRED RESPONSE S	PECTRA FOR	Calc. No.	WCGACQ0766
<u>RM-1000 R</u>	ADIATION MONITORS IN M	<u>1CR PANEL 2-M-30</u>	Sheet No.	13
Prepared: SEE COVER	SHEET	_ Date	Sheet Rev.	000
Checked: SEE COVER	SHEET	Date	_	
			· · · · ·	REFERENCES

# 10.0 JUSTIFICATION/ANALYSIS (CONT'D)

According to Section 4.1.1 of Ref. 6.4, the OBE Required Response Spectra (RRS) will be developed using 70% of SSE levels:

N-S (Front-to-Back) Required Response Spectra (OBE 5% Damping):

$$Ap_{k.NS} := 0.70 \sqrt{(1.6 \text{ S} \cdot Ap_{k.1.NS})^2 + (1.0 \text{ S} \cdot Ap_{k.2.NS})^2 + A_{zpa.k.NS}^2}$$

m := 2.3314

 $A_{NS_1} := b$ 

 $Ap_{k.NS} = 1.366g$ 

From Page 33 of Ref. 6.3,

 $f_{NS_1} := 1 \cdot Hz$ 

$$A_{NS_2} := 5 \cdot A_{pk.NS}$$

 $f_{NS_2} := \left(\frac{A_{NS_2}}{b}\right)^m \cdot Hz$ 

 $f_{NS_2} = 3.211 \text{Hz}$ 

b := 0.45 g

 $A_{NS_3} \coloneqq A_{NS_2}$  $f_{NS_3} := 16 \text{ Hz}$ 

 $f_{NS_4} := 33 \text{ Hz}$  $A_{NS_4} := 2 \cdot Ap_{k.NS}$ 

 $f_{NS_5} := 33 \cdot Hz$  $A_{NS_5} := Ap_{k.NS}$ 

 $f_{NS_6} \coloneqq 100 \text{ Hz}$  $A_{NS_6} := Ap_{k.NS}$ 

 $A_{NS_3} = 6.83g$ 

 $A_{NS_1} = 0.45g$ 

 $A_{NS_2} = 6.83g$ 

 $A_{NS_4} = 2.732g$ 

 $A_{NS_5} = 1.366g$ 

 $A_{NS_6} = 1.366g$ 

	Calculation Sheet		Project	WBN2CCP
BED			Job No.	25402
Subject: <u>IN-CABINE</u>	T REQUIRED RESPONS	E SPECTRA FOR	Calc: No.	WCGACQ0766
<u>RM-1000 R</u>	<b>RM-1000 RADIATION MONITORS IN MCR PANEL 2-M-30</b>		Sheet No.	14
Prepared: SEE COVER	SHEET	Date	Sheet Rev.	000
Checked: SEE COVER	SHEET	Date		

REFERENCES



	Calculation Sheet		Project	WBN2CCP
BED	Calculation	Job No.		25402
Subject: <u>IN-CABINI</u>	T REQUIRED RESPONSE	<u>SPECTRA FOR</u>	Calc. No.	WCGACQ0766
<u>RM-1000 R</u>	<b>RM-1000 RADIATION MONITORS IN MCR PANEL 2-M-30</b>		Sheet No.	15
Prepared: SEE COVER	SHEET	Date	Sheet Rev.	000
Checked: SEE COVER	SHEET	Date	_	•

REFERENCES

0.0 JUSTIFICATION/ANA	LYSIS (CONT'D)			 
Vertical Required Response	Spectra (OBE 5% Dampin	g):	-	
$Ap_{k,v} := 0.70 A_{zpa,k,v}$	$Ap_{k,v} = 0.588g$			•
From Page 33 of Ref	. 6.3, m := 2.3314	b := 0.45 g		· · ·
$\mathbf{f}_{\mathbf{V}_1} \coloneqq 1 \cdot \mathbf{H} \mathbf{z}$	$A_{V_1} := b$	$A_{V_1} = 0.45g$		
$A_{V_2} := 5 \cdot Ap_{k,v}$	· · ·	$A_{V_2} = 2.94g$		
· . <u>1</u>				
$\mathbf{f}_{\mathbf{V}_2} := \left(\frac{\mathbf{A}_{\mathbf{V}_2}}{\mathbf{b}}\right)^{\mathbf{m}} \cdot \mathbf{H}\mathbf{z}$	$f_{V_2} = 2.23$	7Hz		· .
$f_{V_3} \coloneqq 16 \text{ Hz}$	$A_{V_3} := A_{V_2}$	$A_{V_3} = 2.94g$		•
f <sub>V4</sub> := 33·Hz	$A_{V_4} := 2 \cdot Ap_{k.v}$	$A_{V_4} = 1.176g$		
f <sub>V5</sub> := 33 Hz	$A_{V_5} := Ap_{k,v}$	$A_{V_5} = 0.588g$		
$f_{V_6} := 100 \text{ Hz}$	$A_{V_6} := Ap_{k.v}$	$A_{V_6} = 0.588g$		
	·			

	Calculation Sh	oot	Project	WBN2CCP
	Calculation Sneet		Job No.	25402
Subject: <u>IN-CABINI</u>	ET REQUIRED RESPONSE SPEC	<u>TRA FOR</u>	Calc. No.	WCGACQ0766
<u>RM-1000 R</u>	<b>RM-1000 RADIATION MONITORS IN MCR PANEL 2-M-30</b>		Sheet No.	16
Prepared: SEE COVER	SHEET D	ate	Sheet Rev.	000
Checked: SEE COVER	SHEET D	ate	·	

REFERENCES



	Coloulation Shoot	Project	WBN2CCP
BLAND	Calculation Sheet	Job No.	25402
Subject: <u>IN-CABINE</u>	T REQUIRED RESPONSE SPECTRA FO	DR Calc. No.	WCGACQ0766
<u>RM-1000 RA</u>	ADIATION MONITORS IN MCR PANEL	<u>2-M-30</u> Sheet No.	17
Prepared: SEE COVER	SHEET Date	Sheet Rev.	000
Checked: SEE COVER	SHEET Date		

REFERENCES



Front-to-Back		Side-to-Side		Vertical	
f (Hz)	a (g)	f (Hz)	a (g)	f (Hz)	a (g)
1.0	0.45	1.0	0.45	1.0	0.45
3.2	6.83	3.4	8.00	2.2	2.94
16.0	6.83	16.0	8.00	16.0	<b>2.9</b> 4
33.0	2.73	33.0	3.20	33.0	1.18
33.0	1.37	33.0	1.60	33.0	0.59
100.0	1.37	100.0	1.60	100.0	0.59

	Calculation S	hoot	Project	WBN2CCP
	Calculation S		Job No.	25402
Subject: <u>IN-CABINE</u>	ET REQUIRED RESPONSE SPI	ECTRA FOR	Calc. No.	WCGACQ0766
<u>RM-1000 R</u>	ADIATION MONITORS IN MC	CR PANEL 2-M-30	Sheet No.	18
Prepared: SEE COVER	SHEET	Date	Sheet Rev.	.000
Checked: SEE COVER	SHEET	Date	-	
L				REFERENCES

# 11.0 <u>CONCLUSION</u>

The above curves are the in-cabinet required response spectra for the RM-1000's to be installed on WBN Unit 2 MCR Panel 2-M-30. These RRS curves can be used for comparison to vendor seismic test reports for qualification of the WBN Unit 2 safety related RM-1000 Radiation Monitors in Panel 2-M-30.

# 11.1 APPENDIX A

to Calculation WCG-ACQ-0766

Total pages

This Sheet Added By Revision 001

42

Page A1

Appendix A

Plant: WBN-2 Calculation ID: WCGACQ0766 This Sheet Added By Rev 1 Sheet No. A2

#### 1.0 Purpose:

This calculation develops the required response spectra for the Safety Related Radiation Monitoring Equipment to be installed in WBNP Unit 2 Main Control Room Panels 2-M-30 (previous revision 0), 0-M-12 and skids WBN-2-RE-090-0106, WBN-2-RE-090-0112, WBN-2-RE-090-0130 and WBN-2-RE-090-0131.

#### 2.0 References:

1. EDCR-2 52338 Rev. A (Information only)

- 2. WCGACQ0177 Rev. 7, "Seismic Evaluation of Panel 2-M-30 & 2-M-31" (Information only).
- WCGACQ0112 Rev. 3, "Control Room Design Review (CRDR) Panel 0-M-12 Seismic Qualification" (RIMS# T95100727503)
- CEBCQS448 Rev. 0, "Definition of Required Acceleration Input for Device Seismic Qualification" (RIMS# B41960425002)
- 5. CEBCQS447 Rev. 2, "Standard Equipment Seismic Qualification Methods for Devices" (Information only)
- 6. CEB-80-27 Rev. 5, "Dynamic Earthquake Analysis of the Auxiliary Control Building and Response Spectra for Attached Equipment"
- 7. General Atomics Dwg No. 04031100 Rev. B
- 8. General Atomics Dwg No. 04031500 Rev. C
- 9. General Atomics Dwg No. 04031300 Rev. C
- 10. DCN 53037 (Information only)
- 11. 47W605-28 Rev.V (as-constructed drawing panel 0-M-12)
- 12. not used
- 13. TVA Dwg No. 47W605-1 Rev. 15
- 14. EDCR 52341 (Information only)
- 15. DRA 52341-036
- 16. DRA 52341-037
- 17. DRA 52341-080
- 18. DRA 52341-081
- 19. DRA 52341-082
- 20. DRA 52341-084 (Information only)
- 21. DRA 52341-085 (Information only)
- 22. DRA 52341-013 (Information only)
- 23. General Atomics Qualification Basis Report 04038903-1SP for 2-RE-90-130 & -131

24. General Atomics Qualification Basis Report 04038903-2SP for 2-RE-90-106

25. General Atomics Qualification Basis Report 04038903-4SP for 2-RE-90-112

26. Limited Scope Walk Down LSWD-536 panel 0-M-12 (see Attachment B)

#### 3.0 Design Criteria:

1. WB-DC-40-31.2 Rev. 12, "Seismic/Structural Qualification of Seismic Category I Electrical and Mechanical Equipment"

2. CEB-SS-5.10 Rev. 3, "Seismic Qualification of Electrical, Mechanical, and I&C Devices"

## 4.0 Assumptions:

There are no assumptions that require further verification.

Revision	Revision	Revision
Originator:Date: Checker:Date:	Originator:Date: Checker: Date:	Originator:Date:Date:

#### **Calculation Sheet**

Appendix A

Plant: WBN-2 Calculation ID: WCGACQ0766 This Sheet Added By Rev 1 Sheet No. A3

#### 5.0 Special Requirements and Limiting Conditions:

There are no special requirements or limiting conditions.

## 6.0 Methodology:

The methods in sections 4.1.3.2 and 4.1.3.3 of Calc No. CEB-CQS-448 (Ref. 2.4) are used to develop the acceleration at device locations in the panels and on the skid mounted frames. Using these accelerations the required response spectra (RRS) for the device testing are computed using the methods in section 4.2 of Ref. 2.4.

Per section 4.1.3.2 of Ref. 2.4 the 3% damping SSE floor response spectra are used to determine the acceleration at device locations using the methods in section 4.1.3.2 of Ref. 2.4.

Since the mass and stiffness of the panels and skid frames are reasonably distributed uniformly per section 4.1.3.3 of Ref. 2.4, a 1st mode participation factor of 1.6 and a second mode participation factor of 1.0 can be used.

#### 7.0 Computations And Analysis:

#### In panel RRS for safety related NIM Bins in panel 0-M-12:

From WCG-ACQ-0112 page 38 (Ref. 2.3) the first and second mode panel frequency in the x direction are 1st mode 18.69 Hz and 2nd mode 21.27 Hz. The front plate local frequency x direction (perpendicular to the panel face plate) is 27.06 Hz. The z direction first mode frequency is 21.0 Hz and no second mode frequency is given. Since the z direction 1st mode frequency is greater than 1/2 of the cut off frequency (33 Hz) the 2nd mode frequency does not need to be considered (Ref. 2.4 section 4.1.3.3 sub item 2). From sheet 13 of Ref. 2.3 the panel x direction is front to back, the panel z direction is side to side and the panel y direction is vertical. From Ref. 2.13 for panel 0-M-12 front to back is north-south and side to side is east-west. The panel is rigid (no modes below 33Hz) in the vertical direction. Page 38 of Ref. 2.3 does not provide local panel frequency in the z and y directions since they are in the plane of the panel face plate and the face plate is rigid in these directions.

For these frequencies the SSE acceleration from the Auxiliary Control Building El 755.5 New Design/Modification ARS (Ref. 2.6) at 3% damping are as follows:

Ap <sub>k.1.NS</sub> :=	1.05 · g	Ap <sub>k.2.NS</sub> := 1.05 g	$Ap_{k.3.NS} := 0.91 g$	A <sub>zpa.k.NS</sub> := 0.84 · g (at 33 Hz)	
Ap <sub>k.1.EW</sub> :=	= 1.01 · g	Ap <sub>k.2.EW</sub> := 0.00 · g	A <sub>zpa.k.EW</sub> := 0.88 · g	(at 33 Hz)	
A <sub>zpa.k.V</sub> :=	0.84 g (a	t 33 Hz)	·		
Ap <sub>k.1</sub>	is the panel a	cceleration at the first mode	frequency.		
Ap <sub>k.2</sub>	is the panel a	cceleration at the second mo	ode frequency.	· · · · · · · · · · · · · · · · · · ·	
Ap <sub>k.3</sub>	is the acceler at the device	ation corresponding to the pa location.	anel local frequency		
A <sub>zpa.k</sub>	is the panel a	cceleration at cut-off frequen	icy (33 Hz).		
				· · · · · · · · · · · · · · · · · · ·	
Originato Checker	Revision or:Da	ite: Orig	Revision inator:Date: cker: Date:	Revision Originator:Date: Checker:Date:	

Checker:.....Date:.....

Checker: .....Date:.....

Subject:	Calculation Sheet	Plant: WBN-2
Required Response		Calculation ID: WCGACQ0766
Spectra For Evaluation Of	Appendix A	This Sheet Added By Rev 1
Radiation Monitoring Equipment		Sheet No. A4

Determination of the Device Position Ratio (S):

For panel 0-M-12 the top of the highest safety related RM23A NIM Bin was determined to be 52" above the bottom of the panel per Limited scope Walkdown Package LSWD-536 (see Attachment B). From Ref. 2.3 sheet 13 the height of panel 0-M-12 is 98.5".

 $S := \frac{x}{L}$  is the device position ratio. x is the height from the ground to the device and L is the total height of the panel.

 $x := 52 \cdot in$  L := 98.5  $\cdot in$  (Attachment B and Ref. 2.3 sheet 13)

 $S := \frac{x}{L}$  S = 0.528

The in panel acceleration of the NIM Bin and RRS curves for the SSE are computed as follows:

N-S (Front-to-Back) Required Response Spectra (SSE 5% Damping):

$$Ap_{k.NS} := \sqrt{(1.6 \cdot S \cdot Ap_{k.1.NS})^2 + (1.0 \cdot S \cdot Ap_{k.2.NS})^2 + (1.6 \cdot Ap_{k.3.NS})^2 + A_{zpa.k.NS}^2}$$

 $Ap_{k,NS} = 1.98 \cdot g$ 

From Page 33 of Ref. 2.4, m := 2.3314  $b := 0.45 \cdot g$   $f_{NS_1} := 1 \cdot Hz$   $A_{NS_1} := b$   $A_{NS_1} = 0.45 \cdot g$  $A_{NS_2} := 5 \cdot Ap_{k.NS}$   $A_{NS_2} = 9.899 \cdot g$ 

$$f_{NS_2} := \left(\frac{A_{NS_2}}{b}\right)^m \cdot Hz$$
  $f_{NS_2} = 3.765 \cdot Hz$ 

 $A_{NS_6} := Ap_{k.NS}$ 

 $f_{NS_3} := 16 \cdot Hz$   $A_{NS_3} := A_{NS_2}$ 

 $f_{NS_4} := 33 \cdot Hz$   $A_{NS_4} := 2 \cdot Ap_{k,NS}$ 

 $f_{NS_5} := 33 \cdot Hz$   $A_{NS_5} := Ap_{k.NS}$ 

f<sub>NS<sub>6</sub></sub> ≔ 100 Hz

 $A_{NS_5} = 1.98 \cdot g$  $A_{NS_6} = 1.98 \cdot g$ 

 $A_{NS_3} = 9.899 \cdot g$ 

 $A_{NS_4} = 3.959 \cdot g$ 

Revision	Revision	Revision
Originator:Date:	Originator:Date:	Originator:Date:
Checker:Date:	Checker:Date:	Checker:Date:

Plant: WBN-2 Calculation ID: WCGACQ0766 This Sheet Added By Rev 1 Sheet No. A5



Subject: Required Response	Calculation Shee	et	Plant: WBN-2 Calculation ID: WCGACQ0766	
Spectra For Evaluation Of Radiation Monitoring Equipment	Appendix A		This Sheet Added By Rev 1 Sheet No. A6	
1				
$f_{V_2} := \left(\frac{A_{V_2}}{b}\right)^{H} Hz$	$f_{V_2} = 2.607 \cdot Hz$			
f <sub>V3</sub> ≔ 16 · Hz	A <sub>V3</sub> := A <sub>V2</sub>	$A_{V_3} = 4.2 \cdot g$		
f <sub>V4</sub> := 33 ⋅ Hz	$A_{V_4} := 2 \cdot Ap_{k.v}$	A <sub>V4</sub> = 1.68 g	·	
f <sub>V5</sub> ≔ 33 Hz	$A_{V_5} \coloneqq Ap_{k.v}$	$A_{V_5} = 0.84 \cdot g$		
f <sub>V6</sub> ≔ 100 · Hz	A <sub>V6</sub> := Ap <sub>k.v</sub>	$A_{V_6} = 0.84 \cdot g$		
			•	

Revision ... Originator: .....Date:..... Checker:.....Date:..... Revision ... Originator:.....Date:..... Checker:....Date:..... Revision ... Originator: .....Date:..... Checker: .....Date:....



Front-to-Back		Side-t	o-Side	Ver	tical
f (Hz)	a (g)	f (Hz)	a (g)	f (Hz)	a (g)
1.0	0.45	1.0	0.45	1.0	0.45
3.8	9.90	3.1	6.13	2.6	4.20
16.0	9.90	16.0	6.13	16.0	4.20
33.0	3.96	33.0	2.45	33.0	1.68
33.0	1.98	33.0	1.23	33.0	0.84
100.0	1.98	100.0	1.23	100.0	0.84

Revision ... Originator: .....Date:..... Checker:.....Date:..... Revision ... Originator.....Date:..... Checker:.....Date:..... Revision ... Originator: .....Date:.... Checker: .....Date:....

Plant: WBN-2 Calculation ID: WCGACQ0766 This Sheet Added By Rev 1 Sheet No. A8

According to Section 4.3.1 of Ref. 2.5, the OBE Required Response Spectra (RRS) will be developed using 70% of SSE levels: N-S (Front-to-Back) Required Response Spectra (OBE 5% Damping):  $Ap_{k,NS} := 0.70 \sqrt{\left(1.6 \cdot S \cdot Ap_{k,1,NS}\right)^2 + \left(1.0 \cdot S \cdot Ap_{k,2,NS}\right)^2 + \left(1.6 \cdot Ap_{k,3,NS}\right)^2 + A_{zpa,k,NS}^2}$  $Ap_{k.NS} = 1.386 \cdot g$ From Page 33 of Ref. 2.4, m := 2.3314 b := 0.45 ⋅ g  $A_{NS_1} = 0.45 \cdot g$ A<sub>NS₁</sub> ≔ b  $f_{NS_1} := 1 \cdot Hz$  $A_{NS_2} := 5 \cdot Ap_{k.NS}$  $A_{NS_2} = 6.929 \cdot g$  $f_{NS_2} := \left(\frac{A_{NS_2}}{b}\right)^{\frac{1}{m}} Hz$  $f_{NS_2} = 3.231 \cdot Hz$  $f_{NS_3} := 16 \cdot Hz$  $A_{NS_3} = 6.929 \cdot g$  $A_{NS_3} \coloneqq A_{NS_2}$ f<sub>NS<sub>4</sub></sub> := 33 · Hz  $A_{NS_4} = 2.772 \cdot g$  $A_{NS_4} := 2 \cdot Ap_{k.NS}$ f<sub>NS5</sub> ≔ 33 · Hz  $A_{NS_5} = 1.386 \cdot g$  $A_{NS_5} \coloneqq Ap_{k,NS}$ A<sub>NS<sub>6</sub></sub> := Ap<sub>k.NS</sub> A<sub>NS<sub>c</sub></sub> = 1.386 ⋅ g  $f_{NS_{e}} \coloneqq 100 \cdot Hz$ E-W (Side-to-Side) Required Response Spectra (OBE 5% Damping):  $Ap_{k.EW} := 0.70 \cdot \sqrt{(1.6 \cdot S \cdot Ap_{k.1.EW})^2 + (1.0 \cdot S \cdot Ap_{k.2.EW})^2 + A_{zpa.k.EW}^2}$  $Ap_{k,EW} = 0.858 \cdot g$ From Page 33 of Ref. 2.4, m := 2.3314 b := 0.45 · g  $A_{EW_1} = 0.45 \cdot g$  $f_{EW_1} \coloneqq 1 \cdot Hz$ A<sub>EW₁</sub> ≔ b Revision ... Revision ... Revision ... Originator: .....Date:..... Originator: .....Date:..... Originator:.....Date:..... Checker: .....Date:..... Checker:.....Date:..... Checker:......Date:.....

Plant: WBN-2 Calculation ID: WCGACQ0766 This Sheet Added By Rev 1 Sheet No. A9

• • •	A <sub>EW2</sub> := 5 Ap <sub>k.EW</sub>		$A_{EW_2} = 4.29 \cdot g$
	$f_{EW_2} := \left(\frac{A_{EW_2}}{b}\right)^m \cdot Hz$	f <sub>EW2</sub> = 2.63 ⋅ Hz	
	f <sub>EW3</sub> ≔ 16 · Hz	$A_{EW_3} = A_{EW_2}$	A <sub>EW3</sub> = 4.29 · g
	f <sub>EW₄</sub> ≔ 33 Hz	$A_{EW_4} \coloneqq 2 \cdot Ap_{k.EW}$	A <sub>EW4</sub> = 1.716 ⋅ g
	f <sub>EW5</sub> ≔ 33 · Hz	A <sub>EW5</sub> := Ap <sub>k.EW</sub>	$A_{EW_5} = 0.858 \cdot g$
	f <sub>EW<sub>6</sub></sub> ≔ 100 Hz	A <sub>EW6</sub> := Ap <sub>k.EW</sub>	A <sub>EW<sub>6</sub></sub> = 0.858 g
Vert	ical Required Response Spe	ectra (OBE 5% Damping):	
	$Ap_{k.v} := 0.70 \cdot A_{zpa,k.V}$	$Ap_{k.v} = 0.588 \cdot g$	
	From Page 33 of Ref. 2	.4, m := 2.3314 b :=	0.45 g
	f <sub>V1</sub> ≔ 1 Hz	A <sub>V1</sub> := b	$A_{V_1} = 0.45 \cdot g$
	$A_{V_2} := 5 \cdot Ap_{k.v}$		$A_{V_2} = 2.94 \cdot g$
	<u>1</u>		
	$f_{V_2} := \left(\frac{A_{V_2}}{b}\right)^m \cdot Hz$	f <sub>V2</sub> = 2.237 ⋅ H	<b> </b> 2
	f <sub>V3</sub> := 16 ⋅ Hz	$A_{V_3} \coloneqq A_{V_2}$	$A_{V_3} = 2.94 \cdot g$
	f <sub>V₄</sub> ≔ 33 · Hz	$A_{V_4} := 2 \cdot Ap_{k.v}$	$A_{V_4} = 1.176 \cdot g$
	f <sub>V5</sub> := 33 ⋅ Hz	A <sub>V5</sub> := Ap <sub>k.v</sub>	A <sub>V5</sub> = 0.588 g
	f <sub>V6</sub> ≔ 100 · Hz	$A_{V_6} := Ap_{k.v}$	$A_{V_6} = 0.588 \cdot g$

Revision	Revision	Revision	
Originator:Date:	Originator:Date:	Originator:Date:	
Checker:Date:	Checker:Date:	Checker:Date:	



Appendix A

## Plant: WBN-2 Calculation ID: WCGACQ0766 This Sheet Added By Rev 1 Sheet No. A10



Front-	to-Back	Side-t	o-Side	Ver	tical
f (Hz)	a (g)	f (Hz)	a (g)	f (Hz)	a (g)
1.0	0.45	1.0	0.45	1.0	0.45
3.2	6.93	2.6	4.29	2.2	2.94
16.0	6.93	16.0	4.29	16.0	2.94
33.0	2.77	33.0 <sup>-</sup>	1.72	33.0	1.18
33.0	1.39	33.0	0.86	33.0	0.59
100.0	1.39	100.0	0.86	100.0	0.59

Revision ... Originator: .....Date:..... Checker:....Date:..... Revision ... Originator:.....Date:..... Checker:.....Date:..... Revision ... Originator: .....Date:..... Checker: .....Date:.....

#### Calculation Sheet.

Appendix A

Plant: WBN-2 Calculation ID: WCGACQ0766 This Sheet Added By Rev 1 Sheet No. A11

## Safety related system 090 skids:

The skids for 2-RE-090-0106 (Ref. 2.9 & 2.15), -0112 (Ref. 2.8 & 2.15), -0130 (Ref. 2.7 & 2.16) and -0131 (Ref. 2.7 & 2.16) consist of a rigid skid base fabricated from structural steel which is bolted to the building floor slabs. A welded steel frame is attached to each skid base to support various system 090 components for each skid. The heavier components (detectors, pumps and blowers) are attached directly to the rigid skid base and can be seismically qualified using the building ARS since the skid base is rigidly attached to the floor slabs. Based on this General Atomics (GA) was provided the building floor ARS curves for the seismic qualification of the skid mounted equipment.

The final GA qualification reports 04038903-1SP, 04038903-2SP and 04038903-4SP have shown that the welded frames attached to the skids have first and second mode fundamental frequencies less than 33 Hz. Therefore the frame frequencies determined by the GA reports are used to determine the RRS required for evaluation of the seismic qualification of components mounted to the skid frames.

For skids 2-RE-090-0106 and -0112, the in panel RRS will be computed at 34" above the base of the skid and at the top of the frame (59" above the base of the skid) since components are installed at or below these levels of the frames (Ref. 2.8 and 2.9).

For skids 2-RE-090-0130 and -131, the in panel RRS will only be computed at the top of the frame (68" above the base of the skid) since components are installed at or below this level of the frames (Ref. 2.7).

In panel RRS for safety related skid 106 and 112 (@ 34"):

From GA Report 04038903-2SP and -4SP section 3.3.1 a resonance search of the tested skid frame between 1 and 33 HZ found the 1st mode panel frequency in the front to back direction (east west for WBN2) to be 21 Hz and in the side to side direction (north south for WBN2) to be 18 Hz. From Ref. 2.18 for skid 106 and 112 front to back is east-west and side to side is north-south and the skids are attached to floor El. 737. There are no 2nd mode frequencies between 1 and 33 Hz and since the 1st mode frequencies are greater than 1/2 of the cut off frequency 2nd mode frequency need be considered (Ref. 2.4 section 4.1.3.3). The frame is rigid in the vertical direction. The frame is a tube steel structure and local panel frequency need not be considered since the seismic testing of components provided by GA 04038903-2SP and -4SP has accounted for the local effects (i.e. boxes housing the components).

For these frequencies the SSE acceleration from the Auxiliary Control Building El 736.5 New Design/Modification ARS (Ref. 2.6) at 3% damping are as follows:

Ap <sub>k.1.NS</sub> ≔	0.85 g	$Ap_{k.2.NS} \coloneqq 0.00 \cdot g$	$A_{zpa.k.NS} := 0.71 \cdot g$	(at 33 Hz)		
Ap <sub>k.1.EW</sub> :=	0.84 · g	$Ap_{k.2.EW} \coloneqq 0.00 \cdot g$	$A_{zpa.k.EW} \coloneqq 0.77 \cdot g$	(at 33 Hz)		
	· .		$A_{zpa.k.V} \coloneqq 0.59 \cdot g$	(at 33 Hz)	•	
Ap <sub>k.1</sub>	is the panel acceleration at the first mode frequency.					
Ap <sub>k.2</sub>	is the panel acceleration at the second mode frequency.				• .	
Ap <sub>k.3</sub>	is the acceleration corresponding to the panel local frequency at the device location.					
A <sub>zpa.k</sub>	is the panel acc	celeration at cut-off frequency (33 H	z).			
			· · · · · · · · · · · · · · · · · · ·			

Revision	Revision	Revision
Originator:Date: CheckerDate:	Originator:Date: Checker:Date:	Originator:Date:Date:

Plant: WBN-2 Calculation ID: WCGACQ0766 This Sheet Added By Rev 1 Sheet No. A12

Determination of the Device Position Ratio (S) @ 34":  $S := \frac{x}{L}$  is the device position ratio. x is the height from the ground to the device and L is the total height of the panel. (Ref. 2.8 & 2.9) x := 34 · in L := 59 · in  $S := \frac{x}{1}$  S = 0.576The RRS curves for the SSE are computed as follows: N-S (Side-to-Side) Required Response Spectra (SSE 5% Damping):  $Ap_{k,NS} := \sqrt{(1.6 \cdot S \cdot Ap_{k,1,NS})^2 + (1.0 \cdot S \cdot Ap_{k,2,NS})^2 + A_{zpa,k,NS}^2}$  $Ap_{k,NS} = 1.058 \cdot g$ From Page 33 of Ref. 2.4, m := 2.3314 b := 0.45 · g  $A_{NS_1} = 0.45 \cdot g$  $f_{\mathsf{NS}_1} \coloneqq 1 \cdot \mathsf{Hz}$  $A_{NS_1} := b$  $A_{NS_2} = 5.288 \cdot g$  $A_{NS_2} := 5 \cdot Ap_{k.NS}$  $f_{NS_2} := \left(\frac{A_{NS_2}}{b}\right)^{m} \cdot Hz$ f<sub>NS₂</sub> = 2.877 · Hz  $f_{NS_3} := 16 \cdot Hz$  $A_{NS_3} = 5.288 \cdot g$  $A_{NS_3} := A_{NS_2}$  $f_{NS_4} := 33 \cdot Hz$  $A_{NS_4} := 2 \cdot Ap_{k.NS}$  $A_{NS_4} = 2.115 \cdot g$  $f_{NS_5} := 33 \cdot Hz$  $A_{NS_5} = 1.058 \cdot g$  $A_{NS_{5}} := Ap_{k.NS}$ A<sub>NS<sub>6</sub></sub> = 1.058 · g  $f_{NS_e} := 100 \cdot Hz$  $A_{NS_{c}} := Ap_{k.NS}$ Revision ... Revision ... Revision ... Originator: .....Date:..... Originator:.....Date:..... Originator: ......Date:..... Checker: .....Date:..... Checker:.....Date:..... Checker:.....Date:.....

Appendix A

Truncated N-S (Side-to-Side) Required Response Spectra (SSE 5% Damping) Ref. 2.4 section 4.2.2:

 $A_{TNS_1} := b$ 

Between 1 Hz and 90% of the first natural frequency of the skid frame the truncated RRS must not intersect the 5% building ARS. To prevent this, Ref. 2.4 section 4.2.2.2 d requires the truncated RRS to be adjusted to clear the first peak of the broadened floor spectra at 90% of the lower boundary of the broadened plateau of the first peak. Using digitized north-south SSE from the Auxiliary Control Building El 736.5 New Design/Modification ARS (Ref. 2.6) at 3% damping the first peak occurs at 5.13 Hz with an acceleration of 3.078 G. Adjusting the truncated RRS to clear the 5% ARS plateau at 90% of 5 HZ the second point of the truncated RRS is computed as follows:

 $f_{TNS_2} := .9 \cdot 5Hz$   $f_{TNS_2} = 4.5 \cdot Hz$   $A_{TNS_2} := \sqrt{\frac{3}{5}} \cdot 3.078 \cdot g$   $A_{TNS_2} = 2.384 \cdot g$ 

NOTE: Square root of 3/5 is used to convert digitized 3% damping ARS to 5% damping ARS. Refer to Ref.2.4 section 4.1.3.4 second paragraph which shows this method of converting a peak 5% damped floor spectra to a peak 3% damped floor spectra. In this case we are converting a 3% damped peak to a 5% damped peak.

The acceleration value for 90% of the first natural frequency of the skid frame is computed as follows:

 $f_{TNS_3} := .9 \cdot 18Hz$   $f_{TNS_3} = 16.2 \cdot Hz$   $A_{TNS_3} := 5.29 \cdot g$  (conservatively using RRS value for 16 Hz computed above)

The truncated RRS between 90% of the first natural frequency of the skid frame and the ZPA is the same as the non-truncated RRS as follows:

$$f_{TNS_4} := 33 \cdot Hz$$
 $A_{TNS_4} := 2 \cdot Ap_{k,NS}$ 
 $A_{TNS_4} = 2.115 \cdot g$ 
 $f_{TNS_5} := 33 \cdot Hz$ 
 $A_{TNS_5} := Ap_{k,NS}$ 
 $A_{TNS_5} = 1.058 \cdot g$ 
 $f_{TNS_6} := 100 \cdot Hz$ 
 $A_{TNS_6} := Ap_{k,NS}$ 
 $A_{TNS_6} = 1.058 \cdot g$ 

E-W (Front-to-Back) Required Response Spectra (SSE 5% Damping):

$$Ap_{k.EW} := \sqrt{\left(1.6 \cdot S \cdot Ap_{k.1.EW}\right)^2 + \left(1.0 \cdot S \cdot Ap_{k.2.EW}\right)^2 + A_{zpa.k.EW}^2}$$

 $Ap_{k.EW} = 1.092 \cdot g$ 

From Page 33 of Ref. 2.4, m := 2.3314 b := 0.45 · g

A<sub>EW1</sub> := b

 $f_{\mathsf{EW}_1} \coloneqq 1 \cdot \mathsf{Hz}$ 

 $A_{EW_2} := 5 \cdot Ap_{k.EW}$ 

 $A_{EW_2} = 5.461 \cdot g$ 

 $A_{EW_1} = 0.45 g$ 

Revision	Revision		Revision	
Originator:Date:	Originator:	Date:	Originator:	Date:
Checker:Date:	Checker:	Date:		Date:

# Subject: **Required Response Spectra For Evaluation Of**

**Radiation Monitoring Equipment** 

Appendix A

 $f_{EW_2} \coloneqq \left(\frac{A_{EW_2}}{b}\right)^{\overline{m}} \cdot Hz$  $f_{EW_2} = 2.917 \cdot Hz$ f<sub>EWa</sub> ≔ 16 · Hz  $A_{EW_3} := A_{EW_2}$  $A_{EW_3} = 5.461 \cdot g$ f<sub>EW4</sub> := 33 Hz  $A_{EW_{4}} := 2 \cdot Ap_{k.EW}$  $A_{EW_A} = 2.184 \cdot g$  $A_{EW_5} = 1.092 \cdot g$ f<sub>EW5</sub> ≔ 33 · Hz  $A_{EW_{5}} := Ap_{k.EW}$  $A_{EW_6} = 1.092 \cdot g$  $f_{EW_6} \coloneqq 100 \cdot Hz$  $A_{EW_6} := Ap_{k.EW}$ 

Truncated E-W (Front-to-Back) Required Response Spectra (SSE 5% Damping):

$$f_{TEW_1} := 1Hz$$
  $A_{TEW_1} := b$   $A_{TEW_1} := 0.45 \cdot g$ 

Between 1 Hz and 90% of the first natural frequency of the skid frame the truncated RRS must not intersect the 5% building ARS. To prevent this, Ref. 2.4 section 4.2.2.2.d requires the truncated RRS to be adjusted to clear the first peak of the broadened floor spectra at 90% of the lower boundary of the broadened plateau of the first peak. Using digitized east-west SSE from the Auxiliary Control Building El 736.5 New Design/Modification ARS (Ref. 2.6) at 3% damping the first peak occurs at 5.13 Hz with an acceleration of 5.2 G. Adjusting the truncated RRS to clear the 5% ARS plateau at 90% of 5 HZ the second point of the truncated RRS is computed as follows:

$$f_{TEW_2} := .9 \cdot 5Hz$$
  $f_{TEW_2} = 4.5 \cdot Hz$   $A_{TEW_2} := \sqrt{\frac{3}{5}} \cdot 5.2 \cdot g$   $A_{TEW_2} = 4.028 \cdot g$ 

NOTE: Square root of 3/5 is used to convert digitized 3% damping ARS to 5% damping ARS. Refer to Ref.2.4 section 4.1.3.4 second paragraph which shows this method of converting a peak 5% damped floor spectra to a peak 3% damped floor spectra. In this case we are converting a 3% damped peak to a 5% damped peak.

The acceleration value for 90% of the first natural frequency of the skid frame is computed as follows:

$$f_{TEW_3} := .9 \cdot 21Hz$$
  $f_{TEW_3} = 18.9 \cdot Hz$ 

Conservatively using linear Interpolation between the 16 Hz and 33 Hz values of the non-truncated RRS for 18.9 Hz (comparing slope of line on sheet A17 with that on sheet A18 shows this to be conservative):

$$A_{\text{TEW}_3} \coloneqq A_{\text{EW}_4} + \frac{f_{\text{EW}_4} - f_{\text{TEW}_3}}{f_{\text{EW}_4} - f_{\text{EW}_3}} \cdot \left(A_{\text{EW}_3} - A_{\text{EW}_4}\right)$$

 $A_{TEW_3} = 4.902 \cdot g$ 

Revision	Revision	Revision	
Originator:Date: Checker:Date:	Originator:Date: Checker:Date:	Originator:Date:Date:	
The truncated RRS between 90% of the first natural frequency of the skid frame and the ZPA is the same as the non-truncated RRS as follows:  $A_{TEW_4} = 2.184 \cdot g$  $f_{TEW_A} = 33$  Hz  $\mathsf{A}_{\mathsf{TEW}_4} \coloneqq 2 \cdot \mathsf{Ap}_{\mathsf{k}.\mathsf{EW}}$  $A_{\text{TEW}_5} = 1.092 \cdot g$  $f_{TEW_6} := 33 \cdot Hz$  $A_{TEW_5} \coloneqq Ap_{k.EW}$  $A_{\text{TEW}_{6}} = 1.092 \cdot g$ f<sub>TEW<sub>6</sub></sub> := 100 · Hz A<sub>TEW6</sub> := Ap<sub>k.EW</sub> Vertical Required Response Spectra (SSE 5% Damping):  $Ap_{k,v} := A_{zpa,k,V}$  $Ap_{k,v} = 0.59 \cdot g$ From Page 33 of Ref. 2.4, m := 2.3314 b := 0.45 · g  $A_{V_1} = 0.45 \cdot g$  $f_{V_1} := 1 \cdot Hz$ A<sub>V₁</sub> ≔ b  $A_{V_2} = 2.95 \cdot g$  $A_{V_2} := 5 \cdot Ap_{k.v}$  $f_{V_2} := \left(\frac{A_{V_2}}{b}\right)^{m} \cdot Hz$  $f_{V_2} = 2.24 \cdot Hz$  $f_{V_3} := 16 \cdot Hz$  $A_{V_3} = 2.95 \cdot g$  $A_{V_3} \coloneqq A_{V_2}$  $A_{V_4} := 2 \cdot Ap_{k.v}$ f<sub>V₄</sub> := 33 · Hz A<sub>V₄</sub> = 1.18 · g A<sub>V5</sub> := Ap<sub>k.v</sub>  $A_{V_5} = 0.59 \cdot g$  $f_{V_{z}} := 33 \cdot Hz$ A<sub>V6</sub> := Ap<sub>k.v</sub>  $A_{V_6} = 0.59 \cdot g$  $f_{V_{e}} := 100 \cdot Hz$ Truncated Vertical Required Response Spectra (SSE 5% Damping):  $A_{TV_1} \coloneqq 0.45 \cdot g$  $f_{TV_1} \coloneqq 1Hz$ A<sub>TV₁</sub> ≔ b Revision ... Revision ... Revision ... Originator: .....Date:..... Originator:.....Date:..... Originator: .....Date:..... Checker: .....Date:.... Checker:.....Date:..... Checker:.....Date:.....

**Calculation Sheet** 

Plant: WBN-2 Calculation ID: WCGACQ0766 This Sheet Added By Rev 1 Sheet No. A16

Since the skid frame is rigid in the vertical direction the first natural frequency is conservatively taken as 33 Hz. The acceleration value for 90% of the first natural frequency of the skid frame is computed as follows:

$$f_{TV_2} := .9 \cdot 33Hz$$
  $f_{TV_2} = 29.7 \cdot Hz$ 

Conservatively using linear Interpolation between the 16 Hz and 33 Hz values of the non-truncated RRS for 18.9 Hz (comparing slope of line on sheet A17 with that on sheet A18shows this to be conservative):

$$A_{TV_{2}} := A_{V_{4}} + \frac{f_{V_{4}} - f_{TV_{2}}}{f_{V_{4}} - f_{V_{3}}} \cdot \left(A_{V_{3}} - A_{V_{4}}\right)$$

 $A_{TV_2} = 1.524 \cdot g$ 

Hz

The truncated RRS between 90% of the first natural frequency of the skid frame and the ZPA is the same as the non-truncated RRS as follows:

f <sub>TV3</sub> ≔	= 33
--------------------	------

 $f_{TV_4} := 33 \cdot Hz$ 

 $f_{TV_5} := 100 \cdot Hz$ 

A<sub>TV5</sub> := Ap<sub>k.v</sub>

 $A_{TV_4} := Ap_{k.v}$ 

 $\mathsf{A_{TV}}_3 \coloneqq 2 \cdot \mathsf{Ap}_{k.v}$ 

## $A_{TV_5} = 0.59 \cdot g$

 $A_{TV_{2}} = 1.18 \cdot g$ 

 $A_{TV_4} = 0.59 \cdot g$ 

Revision	Revision	
Originator:Date:	Originator:Date:	
Checker:Date:	Checker:Date:	

Revision ... Originator: .....Date:..... Checker: ......Date:.....

**Calculation Sheet** 

Appendix A

Plant: WBN-2 Calculation ID: WCGACQ0766 This Sheet Added By Rev 1 Sheet No. A17



Side-t	o-Side	Front-1	to-Back	Ver	tical
f (Hz)	a (g)	f (Hz)	a (g)	f (Hz)	a (g)
1.0	0.45	1.0	0.45	1.0	0.45
2.9	5.29	2.9	5.46	2.2	2.95
16.0	5.29	16.0	5.46	16.0	2.95
33.0	2.12	33.0	2.18	33.0	1.18
33.0	1.06	33.0	1.09	33.0	0.59
100.0	1.06	100.0	1.09	100.0	0.59

Revision ... Originator: .....Date:..... Checker:.....Date:..... Revision ... Originator:.....Date:..... Checker:.....Date:..... Revision ... Originator: .....Date:.... Checker: .....Date:.....



Side-t	o-Side	Front-1	o-Back	Ver	tical
f (Hz)	a (g)	f (Hz)	a (g)	f (Hz)	a (g)
1.0	0.45	1.0	0.45	1.0	0.45
4.5	2.38	4.5	4.03	29.7	1.52
16.2	5.29	18.9	4.9	33.0	1.18
33.0	2.12	33.0	2.18	33.0	0.59
33.0	1.06	33.0	1.09	100.0	0.59
100.0	1.06	100.0	1.09		

Revision ... Originator: .....Date:..... Checker:....Date:.... Revision ... Originator:.....Date:..... Checker:.....Date:..... Revision ... Originator: .....Date:.... Checker: .....Date:....

Plant: WBN-2 Calculation ID: WCGACQ0766 This Sheet Added By Rev 1 Sheet No. A19



Subject: Required Response Spectra For Evaluation Of Radiation Monitoring Equipment	Calcula Appe	tion Sheet endix A	Plant: WBN-2 Calculation ID: WCGACQ0766 This Sheet Added By Rev 1 Sheet No. A20
From Page 33 of Ref. 2.4,	m := 2.3314	b := 0.45 · g	· · · · · · · · · · · · · · · · · · ·
f <sub>EW1</sub> ≔ 1 ⋅ Hz	A <sub>EW1</sub> := b	A <sub>EW1</sub> = 0.45 · g	,
A <sub>EW2</sub> ≔ 5 · Ap <sub>k.EW</sub>		A <sub>EW2</sub> = 3.822 ·	9
$f_{EW_2} := \left(\frac{A_{EW_2}}{b}\right)^m$ Hz	f <sub>EW2</sub> =	= 2.503 · Hz	
f <sub>EW3</sub> ≔ 16 Hz	A <sub>EW3</sub> := A <sub>EW2</sub>	A <sub>EW3</sub> = 3.822 ·	g
f <sub>EW4</sub> ≔ 33 · Hz	$A_{EW}_4 \coloneqq 2 \cdot Ap_{k.EW}$	A <sub>EW4</sub> = 1.529 ·	9
f <sub>EW5</sub> ≔ 33 · Hz	$A_{EW}_5 \coloneqq Ap_{k.EW}$	A <sub>EW5</sub> = 0.764 ·	9
f <sub>EW6</sub> ≔ 100 · Hz	$A_{EW_6} := Ap_{k,EW}$	A <sub>EW6</sub> = 0.764	g
Vertical Required Response Spe	ectra (OBE 5% Dampi	ng):	
$Ap_{k.v} \coloneqq 0.70 \cdot A_{zpa.k.v}$	Ap <sub>k.v</sub> = 0.4	13 · g	· · · ·
From Page 33 of Ref. 6.	4, m := 2.3314	b := 0.45 · g	
f <sub>V1</sub> ≔ 1 Hz	$A_{V_1} \coloneqq b$	A <sub>V1</sub> = 0.45	g
$A_{V_2} := 5 \cdot Ap_{k.v}$		$A_{V_2} = 2.065$	g
$(\mathbf{A}, \mathbf{A})^{m}$			
$f_{V_2} := \left(\frac{H_{V_2}}{b}\right) + Hz$	f <sub>V2</sub>	= 1.922 · Hz	
f <sub>V3</sub> ≔ 16 · Hz	$A_{V_3} \coloneqq A_{V_2}$	A <sub>V3</sub> = 2.065	g
f <sub>V4</sub> ≔ 33 · Hz	$A_{V_4} := 2 \cdot Ap_{k.v}$	A <sub>V4</sub> = 0.826	·g
f <sub>V5</sub> ≔ 33 · Hz	$A_{V_5} := Ap_{k.v}$	A <sub>V5</sub> = 0.413	·g
f <sub>V6</sub> ≔ 100 · Hz	A <sub>V6</sub> ≔ Ap <sub>k.v</sub>	A <sub>V6</sub> = 0.413	· g
Revision Originator:Date: Checker:Date:	Revi Originator:	sion Date: Or Date: Cl	Revision riginator:Date: pecker: Date:

Appendix A

Plant: WBN-2 Calculation ID: WCGACQ0766 This Sheet Added By Rev 1 Sheet No. A21



Revision ... Originator: ......Date:..... Checker:.....Date:.... 33.0

100.0

0.74

0.74

Revision ... Originator:.....Date:..... Checker:....Date:.....

33.0

100.0

0.76

0.76

33.0

100.0

0.41

0.41

Revision ... Originator: .....Date:..... Checker: .....Date:.....

In panel RRS for safety related skid 106 and 112 (@ 59"):

$$S := \frac{x}{L}$$

The RRS curves for the SSE are computed as follows:

S = 1

N-S (Side-to-Side) Required Response Spectra (SSE 5% Damping):

$$Ap_{k.NS} := \sqrt{\left(1.6 \cdot S \cdot Ap_{k.1.NS}\right)^2 + \left(1.0 \cdot S \cdot Ap_{k.2.NS}\right)^2 + A_{zpa.k.NS}^2}$$

 $A_{NS_1} \coloneqq b$ 

 $Ap_{k.NS} = 1.534 \cdot g$ 

From Page 33 of Ref. 2.4, m := 2.3314

1

 $f_{NS_1} := 1 \cdot Hz$ 

A<sub>NS2</sub> := 5 Ap<sub>k.NS</sub>

$$A_{NS_2} = 7.671 \cdot g$$

 $A_{NS_4} = 3.068 \cdot g$ 

 $A_{NS_5} = 1.534 \cdot g$ 

 $A_{NS_6} = 1.534 \cdot g$ 

 $A_{NS_1} = 0.45 \cdot g$ 

 $b := 0.45 \cdot g$ 

$$f_{NS_2} \coloneqq \left(\frac{A_{NS_2}}{b}\right)^{\overline{M}} \cdot Hz$$
  $f_{NS_2} = 3.375 \cdot Hz$ 

 $f_{NS_3} := 16 \cdot Hz$   $A_{NS_3} := A_{NS_2}$   $A_{NS_3} = 7.671 \cdot g$ 

 $f_{NS_4} := 33 \cdot Hz$   $A_{NS_4} := 2 \cdot Ap_{k,NS}$ 

 $f_{NS_5} := 33 \cdot Hz$   $A_{NS_5} := Ap_{k.NS}$ 

$$NS_{e} := 100 \cdot Hz$$
  $A_{NS_{e}} := Ap_{k,NS}$ 

 Revision ...
 Revision ...
 Revision ...

 Originator: ......Date:.....
 Originator: .....Date:.....
 Originator: .....Date:.....

 Checker: ......Date: ......Date: ......Date: ......
 Checker: ......Date: ......Date: ......Date: ......

Truncated N-S (Side-to-Side) Required Response Spectra (SSE 5% Damping) Ref. 2.4 section 4.2.2:

A<sub>TNS</sub> := b

$$A_{TNS_1} := 0.45 \cdot g$$

Between 1 Hz and 90% of the first natural frequency of the skid frame the truncated RRS must not intersect the 5% building ARS. To prevent this, Ref. 2.4 section 4.2.2.2 d requires the truncated RRS to be adjusted to clear the first peak of the broadened floor spectra at 90% of the lower boundary of the broadened plateau of the first peak. Using digitized north-south SSE from the Auxiliary Control Building El 736.5 New Design/Modification ARS (Ref. 2.6) at 3% damping the first peak occurs at 5.13 Hz with an acceleration of 3.078 G. Adjusting the truncated RRS to clear the 5% ARS plateau at 90% of 5 HZ the second point of the truncated RRS is computed as follows:

$$f_{TNS_2} := .9 \cdot 5Hz$$
  $f_{TNS_2} = 4.5 \cdot Hz$   $A_{TNS_2} := \sqrt{\frac{3}{5} \cdot 3.078 \cdot g}$   $A_{TNS_2} = 2.384 \cdot g$ 

NOTE: Square root of 3/5 is used to convert digitized 3% damping ARS to 5% damping ARS. Refer to Ref.2.4 section 4.1.3.4 second paragraph which shows this method of converting a peak 5% damped floor spectra to a peak 3% damped floor spectra. In this case we are converting a 3% damped peak to a 5% damped peak.

The acceleration value for 90% of the first natural frequency of the skid frame is computed as follows:

 $f_{TNS_3} := .9 \cdot 18Hz$   $f_{TNS_3} = 16.2 \cdot Hz$   $A_{TNS_3} := 7.67 \cdot g$  (conservatively using RRS value for 16 Hz computed above)

The truncated RRS between 90% of the first natural frequency of the skid frame and the ZPA is the same as the non-truncated RRS as follows:

$$f_{TNS_4} := 33 \cdot Hz$$
  $A_{TNS_4} := 2 \cdot Ap_{k.NS}$   $A_{TNS_4} = 3.068 \cdot g$ 

f<sub>TNS<sub>5</sub></sub> ≔ 33 · Hz

 $A_{TNS_5} := Ap_{k.NS}$   $A_{TNS_5} = 1.534 \cdot g$ 

A<sub>TNS<sub>6</sub></sub> = 1.534 g

E-W (Front-to-Back) Required Response Spectra (SSE 5% Damping):

 $f_{TNS_6} := 100 \cdot Hz$   $A_{TNS_6} := Ap_{k.NS}$ 

$$Ap_{k.EW} := \sqrt{\left(1.6 \cdot S \cdot Ap_{k.1.EW}\right)^2 + \left(1.0 \cdot S \cdot Ap_{k.2.EW}\right)^2 + A_{zpa.k.EW}^2}$$

 $Ap_{k.EW} = 1.549 \cdot g$ 

Revis	sion
Originator:	Date:
Checker:	Date:

Revision ... Originator:.....Date:..... Checker:.....Date:.....

R	evision
Originator:	Date:
Checker:	Date:

Subject: Required Response Spectra For Evaluation Of Radiation Monitoring Equipmer	Calc A nt	ulation Sheet ppendix A	Plant: WBN-2 Calculation ID: WCGACQ0766 This Sheet Added By Rev 1 Sheet No. A24
From Page 33 of Ref. 2.4,	m := 2.3314	b := 0.45 · g	
f <sub>EW1</sub> ≔ 1 Hz	A <sub>EW1</sub> := b	$A_{EW_1} = 0.45 \cdot g$	
A <sub>EW2</sub> := 5 ⋅ Ap <sub>k.EW</sub>		A <sub>EW2</sub> = 7.745 ⋅ g	
$f_{EW_2} := \left(\frac{A_{EW_2}}{b}\right)^{m} Hz$	f <sub>EW2</sub> =	3.389 Hz	
f <sub>EW3</sub> ≔ 16 Hz	A <sub>EW3</sub> := A <sub>EW2</sub>	$A_{EW_3} = 7.745 \cdot g$	
f <sub>EW₄</sub> ≔ 33 · Hz	$A_{EW_4} \coloneqq 2 \cdot Ap_{k.EW}$	$A_{EW_4} = 3.098 \cdot g$	
f <sub>EW5</sub> ≔ 33 · Hz	A <sub>EW5</sub> ≔ Ap <sub>k.EW</sub>	A <sub>EW5</sub> = 1.549 ⋅ g	
f <sub>EW<sub>6</sub></sub> ≔ 100 · Hz	A <sub>EW6</sub> := Ap <sub>k.EW</sub>	A <sub>EW<sub>6</sub></sub> = 1.549 ⋅ g	

Truncated E-W (Front-to-Back) Required Response Spectra (SSE 5% Damping):

 $f_{TEW_1} := 1Hz$   $A_{TEW_1} := b$   $A_{TEW_1} := 0.45 \cdot g$ 

Between 1 Hz and 90% of the first natural frequency of the skid frame the truncated RRS must not intersect the 5% building ARS. To prevent this, Ref. 2.4 section 4.2.2.2.d requires the truncated RRS to be adjusted to clear the first peak of the broadened floor spectra at 90% of the lower boundary of the broadened plateau of the first peak. Using digitized north-south SSE from the Auxiliary Control Building El 736.5 New Design/Modification ARS (Ref. 2.6) at 3% damping the first peak occurs at 5.13 Hz with an acceleration of 5.2 G. Adjusting the truncated RRS to clear the 5% ARS plateau at 90% of 5 HZ the second point of the truncated RRS is computed as follows:

$$f_{TEW_2} := .9 \cdot 5Hz$$
  $f_{TEW_2} = 4.5 \cdot Hz$   $A_{TEW_2} := \sqrt{\frac{3}{5}} \cdot 5.2 \cdot g$   $A_{TEW_2} = 4.028 \cdot g$ 

NOTE: Square root of 3/5 is used to convert digitized 3% damping ARS to 5% damping ARS. Refer to Ref.2.4 section 4.1.3.4 second paragraph which shows this method of converting a peak 5% damped floor spectra to a peak 3% damped floor spectra. In this case we are converting a 3% damped peak to a 5% damped peak.

Revision	Revision	Revision
Originator:Date:	Originator:Date:	Originator:Date:
Checker:Date:	Checker:Date:Date:	Checker:Date:

Plant: WBN-2 Calculation ID: WCGACQ0766 This Sheet Added By Rev 1 Sheet No. A25

The acceleration value for 90% of the first natural frequency of the skid frame is computed as follows:

$$f_{TEW_3} := .9 \cdot 21 Hz$$
  $f_{TEW_3} = 18.9 \cdot Hz$ 

Conservatively using linear Interpolation between the 16 Hz and 33 Hz values of the non-truncated RRS for 18.9 Hz (comparing slope of line on sheet A27 with that on sheet A28shows this to be conservative):

$$A_{\text{TEW}_3} \coloneqq A_{\text{EW}_4} + \frac{f_{\text{EW}_4} - f_{\text{TEW}_3}}{f_{\text{EW}_4} - f_{\text{EW}_3}} \cdot \left(A_{\text{EW}_3} - A_{\text{EW}_4}\right)$$

 $A_{\text{TEW}_3} = 6.952 \cdot g$ 

The truncated RRS between 90% of the first natural frequency of the skid frame and the ZPA is the same as the non-truncated RRS as follows:

f <sub>TEW4</sub> := 33 Hz	$A_{TEW_4} = 2 \cdot Ap_{k.EW}$	$A_{\text{TEW}_4} = 3.098 \cdot g$
f <sub>TEW5</sub> ≔ 33 · Hz	A <sub>TEW5</sub> ≔ Ap <sub>k.EW</sub>	$A_{\text{TEW}_5} = 1.549 \cdot g$

 $f_{TEW_6} := 100 \cdot Hz$   $A_{TEW_6} := Ap_{k.EW}$   $A_{TEW_6} = 1.549 \cdot g$ 

Vertical Required Response Spectra (SSE 5% Damping):

$$Ap_{k,v} := A_{zpa,k,v} \qquad Ap_{k,v} = 0.59 \cdot g$$

From Page 33 of Ref. 2.4, m := 2.3314 b := 0.45 g

$f_{V_1} := 1 \cdot Hz$	A <sub>V1</sub> := b	$A_{V_1} = 0.45 \cdot g$
$A_{V_2} := 5 \cdot Ap_{k,v}$		$A_{V_2} = 2.95 \cdot g$
<u>1</u>		
$(A_{V_{\alpha}})^{\cdots}$		· · ·

$$f_{V_2} := \left( \begin{array}{c} 2 \\ b \end{array} \right) + Hz \qquad f_{V_2} = 2.24 + Hz$$

$$f_{V_3} := 10 \cdot Hz$$
  $A_{V_3} := A_{V_2}$   
 $f_{V_4} := 33 \cdot Hz$   $A_{V_4} := 2 \cdot Ap_{k,v}$ 

 $\mathsf{A}_{\mathsf{V}_5} \coloneqq \mathsf{Ap}_{k.\mathsf{v}}$ 

 $A_{V_{e}} := Ap_{k.v}$ 

f<sub>V5</sub> := 33 ⋅ Hz

f<sub>Ve</sub> := 100 ⋅ Hz

Revision ...

Originator: .....Date:.....

Checker:.....Date:.....

 $A_{V_3} = 2.95 \cdot g$ 

 $A_{V_4} = 1.18 \cdot g$ 

 $A_{V_5} = 0.59 \cdot g$ 

Revision ... Originator: .....Date:..... Checker: ......Date:.....

**Calculation Sheet** 

Plant: WBN-2 Calculation ID: WCGACQ0766 This Sheet Added By Rev 1 Sheet No. A26

Truncated Vertical Required Response Spectra (SSE 5% Damping):

 $A_{TV_1} \coloneqq b$ 

$$f_{TV_1} := 1Hz$$

$$A_{TV_1} := 0.45 \cdot g$$

Since the skid frame is rigid in the vertical direction the first natural frequency is conservatively taken as 33 Hz. The acceleration value for 90% of the first natural frequency of the skid frame is computed as follows:

$$f_{TV_2} := .9 \cdot 33Hz$$
  $f_{TV_2} = 29.7 \cdot Hz$ 

Conservatively using linear Interpolation between the 16 Hz and 33 Hz values of the non-truncated RRS for 18.9 Hz (comparing slope of line on sheet A27 with that on sheet A28shows this to be conservative):

$$A_{TV_{2}} := A_{V_{4}} + \frac{f_{V_{4}} - f_{TV_{2}}}{f_{V_{4}} - f_{V_{3}}} \cdot \left(A_{V_{3}} - A_{V_{4}}\right)$$

$$A_{TV_2} = 1.524 \cdot g$$

The truncated RRS between 90% of the first natural frequency of the skid frame and the ZPA is the same as the non-truncated RRS as follows:

$$f_{TV_3} := 33 \cdot Hz$$
 $A_{TV_3} := 2 \cdot Ap_{k.v}$  $A_{TV_3} = 1.18 \cdot g$  $f_{TV_4} := 33 \cdot Hz$  $A_{TV_4} := Ap_{k.v}$  $A_{TV_4} = 0.59 \cdot g$  $f_{TV_5} := 100 \cdot Hz$  $A_{TV_5} := Ap_{k.v}$  $A_{TV_5} = 0.59 \cdot g$ 

Revision	Revision	Revision
Originator:Date: Checker:Date:	Originator:Date: Checker:Date:	Originator:Date:Date:Date:

**Calculation Sheet** 

Appendix A

Plant: WBN-2 Calculation ID: WCGACQ0766 This Sheet Added By Rev 1 Sheet No. A27



•			
Fr	equ	ency	(Hz)

Side-t	o-Side	Front-	to-Back	Ver	tical
f (Hz)	a (g)	f (Hz)	a (g)	f (Hz)	a (g)
1.0	0.45	1.0	0.45	1.0	0.45
3.4	7.67	3.4	7.75	2.2	2.95
16.0	7.67	16.0	7.75	16.0	2.95
33.0	3.07	33.0	3.10	33.0	1.18
33.0	1.53	33.0	1.55	33.0	0.59
100.0	1.53	100.0	1.55	100.0	0.59

Revision ... Originator: .....Date:..... Checker:.....Date:..... Revision ... Originator:.....Date:..... Checker:.....Date:..... Revision ... Originator: .....Date:..... Checker: .....Date:.....

Appendix A

Plant: WBN-2 Calculation ID: WCGACQ0766 This Sheet Added By Rev 1 Sheet No. A28



Side-to-Side		Front-to-Back		Vertical	
f (Hz)	a (g)	f (Hz)	a (g)	f (Hz)	a (g)
1.0	0.45	1.0	0.45	1.0	0.45
4.5	2.38	4.5	4.03	29.7	1.52
16.2	7.67	18.9	6.95	33.0	1.18
33.0	3.07	33.0	3.10	33.0	0.59
33.0	1.53	33.0	1.55	100.0	0.59
100.0	1.53	100.0	1.55		

Revision ... Originator: ......Date:..... Checker:.....Date:..... Revision ... Originator:.....Date:..... Checker:.....Date:..... Revision ... Originator: .....Date:.... Checker: .....Date:....

Plant: WBN-2 Calculation ID: WCGACQ0766 This Sheet Added By Rev 1 Sheet No. A29



Appendix A

From Page 33 of Ref. 2.4, m := 2.3314 b := 0.45 · g  $f_{EW_1} := 1 \cdot Hz$  $A_{EW_1} = 0.45 \cdot g$  $A_{EW_1} := b$  $A_{EW_2} := 5 \cdot Ap_{k.EW}$  $A_{EW_2} = 5.421 \cdot g$  $f_{EW_2} := \left(\frac{A_{EW_2}}{b}\right)^m \cdot Hz$  $f_{EW_2} = 2.908 \cdot Hz$  $f_{EW_3} := 16 \cdot Hz$  $A_{EW_3} = 5.421 \cdot g$  $A_{EW_2} \coloneqq A_{EW_2}$ f<sub>EW₄</sub> ≔ 33 · Hz  $A_{EW_{A}} := 2 \cdot Ap_{k.EW}$  $A_{EW_A} = 2.169 \cdot g$  $A_{EW_5} = 1.084 \cdot g$ f<sub>EW5</sub> := 33 · Hz  $A_{EW_g} := Ap_{k.EW}$ f<sub>EW6</sub> := 100 ⋅ Hz  $A_{EW_{c}} := Ap_{k.EW}$  $A_{EW_6} = 1.084 \cdot g$ Vertical Required Response Spectra (OBE 5% Damping):  $Ap_{k.v} := 0.70 \cdot A_{zpa.k.V}$  $Ap_{k,v} = 0.413 \cdot g$ From Page 33 of Ref. 2.4, m := 2.3314  $b := 0.45 \cdot g$  $A_{V_1} \coloneqq b$  $f_{V_1} \coloneqq 1 \cdot Hz$  $A_{V_1} = 0.45 \cdot g$  $A_{V_2} := 5 \cdot Ap_{k.v}$  $A_{V_2} = 2.065 \cdot g$  $f_{V_2} := \left( \begin{array}{c} A_{V_2} \\ \hline b \end{array} \right)^m \cdot Hz$  $f_{V_2} = 1.922 \cdot Hz$  $f_{V_3} \coloneqq 16 \cdot Hz$   $A_{V_3} \coloneqq A_{V_2}$  $A_{V_3} = 2.065 \cdot g$  $A_{V_4} = 0.826 \cdot g$  $A_{V_4} := 2 \cdot Ap_{k,v}$ f<sub>V₄</sub> := 33 · Hz  $A_{V_5} := Ap_{k,v}$ f<sub>V5</sub> := 33 ⋅ Hz  $A_{V_{E}} = 0.413 \cdot g$  $A_{V_6} = 0.413 \cdot g$  $f_{V_{e}} := 100 \cdot Hz$  $A_{V_6} := Ap_{k.v}$ 

Revision	Revision	Revision	
Originator:Date:	Originator:Date:	Originator:Date:	
Checker:Date:	Checker:Date:	Checker:Date:	



Side-t	Side-to-Side		Front-to-Back		tical
f (Hz)	a (g)	f (Hz)	a (g)	f (Hz)	a (g)
1.0	0.45	1.0	0.45	1.0	0.45
2.9	5.37	2.9	5.42	1.9	2.07
16.0	5.37	16.0	5.42	16.0	2.07
33.0	2.15	33.0	2.17	33.0	0.83
33.0	1.07	33.0	1.08	33.0	0.41
100.0	1.07	100.0	1.08	100.0	0.41

Revision ... Originator: .....Date:..... Checker:.....Date:..... Revision ... Originator:.....Date:..... Checker:.....Date:..... Revision ... Originator: .....Date:..... Checker: .....Date:.....

		•
Subject:	Calculation Sheet	Plant: WBN-2
Required Response		Calculation ID: WCGACQ0766
Spectra For Evaluation Of	Appendix A	This Sheet Added By Rey 1
Radiation Monitoring Equipment		Sheet No. A32

In panel RRS for safety related skid 130 and 131;

From GA Report 04038903-1SP section 3.3.1 Table 3-6 the 1st mode frame frequency is 27.9 Hz in the side to side direction (north south skid 130 and east west skid 131). The 2nd mode frame frequency is 35.4 Hz. in the front to back direction (north south skid 131 and east west skid 130). See Ref. 2.17 and 2.19 for skid orientation and elvation. Since the 1st mode frequencies are greater than 1/2 of the cut off frequency no 2nd mode frequency need be considered. The frame was rigid in the vertical direction. The frame is a tube steel structure and local panel frequency need not be considered since the seismic testing of components provided by GA 04038903-1SP has accounted for the local effects (i.e. boxes housing the components).

For these frequencies the SSE acceleration from the Auxiliary Control Building El 711.5 New Design/Modification ARS (Ref. 2.6) at 3% damping are as follows:

$Ap_{k.1.NS} \coloneqq 0.44 \cdot g$	$Ap_{k,2,NS} \coloneqq 0.00 \cdot g$	$A_{zpa.k.NS} := 0.43 \cdot g$
$Ap_{k.1.EW} \coloneqq 0.49 \cdot g$	$Ap_{k.2.EW} \coloneqq 0.00 \cdot g$	A <sub>zpa.k.EW</sub> ≔ 0.49 · g
		$A_{zpa,k,V} := 0.25 \cdot g$

 $Ap_{k,1}$  is the panel acceleration at the first mode frequency.

Ap<sub>k,2</sub> is the panel acceleration at the second mode frequency.

Ap<sub>k.3</sub> is the acceleration corresponding to the panel local frequency. at the device location.

Azoa.k is the

is the panel acceleration at cut-off frequency (33 Hz).

Determination of the Device Position Ratio (S):

The device location at the top of the panel is only considered since it has a greater input acceleration.

 $S := \frac{x}{L}$  is the device position ratio. x is the height from the ground to the device and L is the total height of the panel.

 $x := 68 \cdot in$  L := 68  $\cdot in$  (Ref. 2.7)

=1

$$S := \frac{x}{L}$$
 S

The RRS curves for the SSE are computed as follows:

N-S Required Response Spectra (SSE 5% Damping):

$$Ap_{k.NS} := \sqrt{\left(1.6 \cdot S \cdot Ap_{k.1.NS}\right)^2 + \left(1.0 \cdot S \cdot Ap_{k.2.NS}\right)^2 + A_{zpa.k.NS}^2}$$

 $Ap_{k,NS} = 0.825 \cdot g$ 

Revision	Revision	Revision
Originator:Date:	Originator:Date:	Originator:Date:
Checker:Date:	Checker:Date:	Checker:Date:

Subject: Required Response Spectra For Evaluation Of Radiation Monitoring Equipment		Ca	Appendix A	Plant: WBN-2 Calculation ID: WCGACQ0766 This Sheet Added By Rev 1 Sheet No. A33	
	From Page 33 of Ref. 2.4,	m := 2.3314	b:= 0.45 · g		
	f <sub>NS1</sub> ≔ 1 · Hz	A <sub>NS1</sub> ≔ b	$A_{NS_1} = 0.45 \cdot g$		
	A <sub>NS2</sub> := 5 · Ap <sub>k.NS</sub>		A <sub>NS2</sub> = 4.125 g		
	$f_{NS_2} := \left(\frac{A_{NS_2}}{b}\right)^{m} Hz$	f <sub>NS2</sub> =	2.586 Hz		
	f <sub>NS3</sub> := 16 ⋅ Hz	A <sub>NS3</sub> := A <sub>NS2</sub>	$A_{NS_3} = 4.125 \cdot g$		
	f <sub>NS₄</sub> ≔ 33 · Hz	$A_{NS_4} \coloneqq 2 \cdot Ap_{k.NS}$	A <sub>NS<sub>4</sub></sub> = 1.65 ⋅ g		
	f <sub>NS5</sub> := 33 Hz	$A_{NS_5} := Ap_{k.NS}$	A <sub>NS5</sub> = 0.825 ⋅ g		
	f <sub>NS<sub>6</sub></sub> := 100 Hz	A <sub>NS<sub>6</sub></sub> := Ap <sub>k.NS</sub>	$A_{NS_6} = 0.825 \cdot g$		

Truncated N-S Required Response Spectra (SSE 5% Damping):

$$f_{TNS_1} := 1Hz$$

A<sub>TNS1</sub> ≔ b

4.05 · Hz

 $A_{TNS_1} := 0.45 \cdot g$ 

Between 1 Hz and 90% of the first natural frequency of the skid frame the truncated RRS must not intersect the 5% building ARS. To prevent this, Ref. 2.4 section 4.2.2.2.d requires the truncated RRS to be adjusted to clear the first peak of the broadened floor spectra at 90% of the lower boundary of the broadened plateau of the first peak. Using digitized north-south SSE from the Auxiliary Control Building El 711.5 New Design/Modification ARS (Ref. 2.6) at 3% damping the first peak occurs above 4.5 Hz with an acceleration of 1.663 G. Adjusting the truncated RRS to clear the 5% ARS plateau at 90% of 4.5 HZ the second point of the truncated RRS is computed as follows:

 $f_{TNS_2} := .9 \cdot 4.5Hz$ 

$$A_{TNS_2} := \sqrt{\frac{3}{5} \cdot 1.633 \cdot g}$$
  $A_{TNS_2} = 1.265 \cdot g$ 

NOTE: Square root of 3/5 is used to convert digitized 3% damping ARS to 5% damping ARS. Refer to Ref.2.4 section 4.1.3.4 second paragraph which shows this method of converting a peak 5% damped floor spectra to a peak 3% damped floor spectra. In this case we are converting a 3% damped peak to a 5% damped peak.

The acceleration value for 90% of the first natural frequency of the skid frame is computed as follows:

$$f_{TNS_3} := .9 \cdot 27.9 Hz$$
  $f_{TNS_3} = 25.11 \cdot Hz$ 

Revision	Revision	Revision
Originator:Date:	Originator:Date:	Originator:Date:Date:
Checker:Date:	Checker:Date:	Checker:Date:Date:

#### **Calculation Sheet**

Appendix A

Plant: WBN-2 Calculation ID: WCGACQ0766 This Sheet Added By Rev 1 Sheet No. A34

Conservatively using linear Interpolation between the 16 Hz and 33 Hz values of the non-truncated RRS for 18.9 Hz (comparing slope of line on sheet A38 with that on sheet A39shows this to be conservative):

$$A_{TNS_3} := A_{NS_4} + \frac{f_{NS_4} - f_{TNS_3}}{f_{NS_4} - f_{NS_3}} \cdot \left(A_{NS_3} - A_{NS_4}\right)$$

$$A_{TNS_3} = 2.798 \cdot g$$

The truncated RRS between 90% of the first natural frequency of the skid frame and the ZPA is the same as the non-truncated RRS as follows:

$$f_{TNS_{4}} := 33 \cdot Hz \qquad A_{TNS_{4}} := 2 \cdot Ap_{k.NS} \qquad A_{TNS_{4}} = 1.65 \cdot g$$

$$f_{TNS_{5}} := 33 \cdot Hz \qquad A_{TNS_{5}} := Ap_{k.NS} \qquad A_{TNS_{5}} = 0.825 \cdot g$$

$$f_{TNS_{6}} := 100 \cdot Hz \qquad A_{TNS_{6}} := Ap_{k.NS} \qquad A_{TNS_{6}} = 0.825 \cdot g$$

E-W Required Response Spectra (SSE 5% Damping):

 $Ap_{k,EW} := \sqrt{(1.6 \cdot S \cdot Ap_{k,1,EW})^2 + (1.0 \cdot S \cdot Ap_{k,2,EW})^2 + A_{zpa,k,EW}^2}$  $Ap_{k,EW} = 0.925 \cdot g$ From Page 33 of Ref. 2.4, m := 2.3314 b := 0.45 · g A<sub>EW1</sub> := b  $A_{EW_1} = 0.45 \cdot g$  $f_{EW_1} := 1 \cdot Hz$  $A_{EW_2} = 4.623 \cdot g$  $A_{EW_2} := 5 \cdot Ap_{k.EW}$  $f_{EW_2} := \left(\frac{A_{EW_2}}{b}\right)^{m} Hz$  $f_{EW_2} = 2.716 \cdot Hz$  $A_{EW_3} = 4.623 \cdot g$  $f_{EW_3} \coloneqq 16 \cdot Hz$   $A_{EW_3} \coloneqq A_{EW_2}$ A<sub>EW₄</sub> = 1.849 ⋅ g f<sub>EW₄</sub> := 33 · Hz  $A_{EW_4} := 2 \cdot Ap_{k.EW}$ f<sub>EWc</sub> ≔ 33 · Hz  $A_{EW_s} := Ap_{k,EW}$  $A_{EW_5} = 0.925 \cdot g$ f<sub>EW6</sub> := 100 ⋅ Hz  $A_{EW_6} = 0.925 \cdot g$  $A_{EW_{e}} := Ap_{k.EW}$ 

Revision	Revisi	on	Revision
Originator:Date:	Originator:	Date:	Originator:Date:
Checker:Date:	Checker:	Date:	Cilecker

Truncated E-W Required Response Spectra (SSE 5% Damping):

$$f_{TEW_4} := 1Hz$$
  $A_{TEW_4} := b$ 

Between 1 Hz and 90% of the first natural frequency of the skid frame the truncated RRS must not intersect the 5% building ARS. To prevent this, Ref. 2.4 section 4.2.2.2.d requires the truncated RRS to be adjusted to clear the first peak of the broadened floor spectra at 90% of the lower boundary of the broadened plateau of the first peak. Using digitized east-west SSE from the Auxiliary Control Building El 711.5 New Design/Modification ARS (Ref. 2.6) at 3% damping the first peak occurs at 5.0 Hz with an acceleration of 2.56 G. Adjusting the truncated RRS to clear the 5% ARS plateau at 90% of 5 HZ the second point of the truncated RRS is computed as follows:

 $A_{TEW_4} := 0.45 \cdot g$ 

 $f_{TEW_2} := .9 \cdot 5Hz$   $f_{TEW_2} = 4.5 \cdot Hz$   $A_{TEW_2} := \sqrt{\frac{3}{5}} \cdot 2.56 \cdot g$   $A_{TEW_2} = 1.983 \cdot g$ 

NOTE: Square root of 3/5 is used to convert digitized 3% damping ARS to 5% damping ARS. Refer to Ref.2.4 section 4.1.3.4 second paragraph which shows this method of converting a peak 5% damped floor spectra to a peak 3% damped floor spectra. In this case we are converting a 3% damped peak to a 5% damped peak.

The acceleration value for 90% of the first natural frequency of the skid frame is computed as follows:

$$f_{TEW_3} := .9 \cdot 27.9 Hz$$
  $f_{TEW_3} = 25.11 \cdot Hz$ 

Conservatively using linear Interpolation between the 16 Hz and 33 Hz values of the non-truncated RRS for 18.9 Hz (comparing slope of line on sheet A38 with that on sheet A39shows this to be conservative):

$$A_{TEW_3} := A_{EW_4} + \frac{f_{EW_4} - f_{TEW_3}}{f_{EW_4} - f_{EW_3}} \cdot (A_{EW_3} - A_{EW_4})$$

$$A_{\text{TEW}_2} = 3.136 \cdot g$$

The truncated RRS between 90% of the first natural frequency of the skid frame and the ZPA is the same as the non-truncated RRS as follows:

f <sub>TEW4</sub> := 33 · Hz	$A_{\text{TEW}_4} := 2 \cdot Ap_{k.EW}$	$A_{\text{TEW}_4} = 1.849 \cdot g$
f <sub>TEW5</sub> ≔ 33 · Hz	A <sub>TEW5</sub> := Ap <sub>k.EW</sub>	$A_{\text{TEW}_5} = 0.925 \cdot g$
f <sub>TEW<sub>6</sub></sub> ≔ 100 · Hz	A <sub>TEW6</sub> := Ap <sub>k.EW</sub>	$A_{\text{TEW}_6} = 0.925 \cdot g$

	Bevision	Revision
Originator:Date: Checker:Date:	Originator:Date: Checker:Date:	Originator:Date:Date:Date:

Vertical Required Response Spectra (SSE 5% Damping):  $Ap_{k,v} := A_{zpa,k,v}$  $Ap_{k,v} = 0.25 \cdot g$ From Page 33 of Ref. 2.4, m := 2.3314 b := 0.45 · g A<sub>V1</sub> := b  $f_{V_1} \coloneqq 1 \cdot Hz$  $A_{V_1} = 0.45 \cdot g$  $A_{V_2} := 5 \cdot Ap_{k.v}$  $A_{V_2} = 1.25 \cdot g$  $f_{V_2} := \left(\frac{A_{V_2}}{b}\right)^{m} \cdot Hz$ f<sub>V₂</sub> = 1.55 · Hz f<sub>V3</sub> := 16 ⋅ Hz  $A_{V_3} \coloneqq A_{V_2}$ A<sub>V3</sub> = 1.25 ⋅ g  $f_{V_4} \coloneqq 33 \cdot Hz \qquad \qquad A_{V_4} \coloneqq 2 \cdot Ap_{k.v}$  $A_{V_A} = 0.5 \cdot g$  $A_{V_5} := Ap_{k.v}$ f<sub>Ve</sub> := 33 ⋅ Hz  $A_{V_5} = 0.25 \cdot g$  $A_{V_6} := Ap_{k.v}$  $f_{V_e} := 100 \cdot Hz$  $A_{V_6} = 0.25 \cdot g$ 

Truncated Vertical Required Response Spectra (SSE 5% Damping):

$$f_{TV_1} := 1Hz$$
  $A_{TV_1} := b$   $A_{TV_1} := 0.45 g$ 

Since the skid frame is rigid in the vertical direction the first natural frequency is conservatively taken as 33 Hz. The acceleration value for 90% of the first natural frequency of the skid frame is computed as follows:

$$f_{TV_2} := .9 \cdot 33Hz$$
  $f_{TV_2} = 29.7 \cdot Hz$ 

Conservatively using linear Interpolation between the 16 Hz and 33 Hz values of the non-truncated RRS for 18.9 Hz (comparing slope of line on sheet A38 with that on sheet A39shows this to be conservative):

$$A_{TV_{2}} := A_{V_{4}} + \frac{f_{V_{4}} - f_{TV_{2}}}{f_{V_{4}} - f_{V_{3}}} \cdot \left(A_{V_{3}} - A_{V_{4}}\right)$$

$$A_{TV_{a}} = 0.646 \cdot g$$

Revision	Revision	Revision
Originator:Date:	Originator:Date:	Originator:Date:
Checker:Date:	Checker:Date:	Checker:Date:

# Subject:Calculation SheetPlant: WBN-2Required ResponseCalculation ID: WCGACQ0766Spectra For Evaluation OfAppendix AThis Sheet Added By Rev 1Radiation Monitoring EquipmentSheet No. A37

The truncated RRS between 90% of the first natural frequency of the skid frame and the ZPA is the same as the non-truncated RRS as follows:

 $f_{TV_3} := 33 \cdot Hz$ 

 $f_{TV_A} \coloneqq 33 \cdot Hz$ 

A<sub>TV4</sub> := Ap<sub>k.v</sub>

 $A_{TV_{3}} \coloneqq 2 \cdot Ap_{k,v}$ 

 $A_{TV_4} = 0.25 \cdot g$ 

 $A_{TV_3} = 0.5 \cdot g$ 

 $f_{TV_5} := 100 \cdot Hz$ 

 $A_{TV_5} := Ap_{k.v}$ 

## $A_{TV_5} = 0.25 \cdot g$

Revision ... Originator: ......Date:..... Checker:.....Date:.....

Revision ... Originator:.....Date:..... Checker:.....Date:..... Revision ... Originator: .....Date:..... Checker: .....Date:....



North	-South	East-West		Ver	tical
f (Hz)	a (g)	f (Hz)	a (g)	f (Hz)	a (g)
1.0	0.45	1.0	0.45	1.0	0.45
2.6	4.13	2.7	4.62	1.6	1.25
16.0	4.13	16.0	4.62	16.0	1.25
33.0	1.65	33.0	1.85	33.0	0.50
33.0	0.83	33.0	0.93	33.0	0.25
100.0	0.83	100.0	0.93	100.0	0.25

For Skid 2-RE-90-130, North-South is side to side and East-West is front to back. For Skid 2-RE-90-131, North-South is front to back and East-west is side to side.

Revisi	on
Originator:	Date:
Checker:	Date:

Revision ... Originator.....Date:..... Checker.....Date:..... Revision ... Originator: .....Date:..... Checker: ......Date:.....

**Calculation Sheet** 

Appendix A

Plant: WBN-2 Calculation ID: WCGACQ0766 This Sheet Added By Rev 1 Sheet No. A39



North	South	East-West		uth East-West Vertical		tical
f (Hz)	a (g)	f (Hz)	a (g)	f (Hz)	a (g)	
1.0	0.45	1.0	0.45	1.0	0.45	
4.1	1.27	4.5	1.98	29.7	0.65	
25.1	2.80	25.1	3.14	33.0	0.50	
33.0	1.65	33.0	1.85	33.0	0.25	
33.0	0.83	33.0	0.93	100.0	0.25	
100.0	0.83	100.0	0.93			

For Skid 2-RE-90-130, North-South is side to side and East-West is front to back. For Skid 2-RE-90-131, North-South is front to back and East-west is side to side.

Revisio	on
Originator:	Date:
Checker:	Date:

Revision ... Originator:.....Date:..... Checker:.....Date:.....

Revi	sion
Originator:	Date:
Checker:	Date:

Plant: WBN-2 Calculation ID: WCGACQ0766 This Sheet Added By Rev 1 Sheet No. A40



Subject:	Calculat	ion Sheet		Plant: WBN-2
Required Response Spectra For Evaluation Of Radiation Monitoring Equipment	Арре	ndix A		This Sheet Added By Rev 1 Sheet No. A41
From Page 33 of Ref. 2.4,	m := 2.3314	b := 0.45	· g	
f <sub>EW1</sub> ≔ 1 Hz	A <sub>EW1</sub> := b		$A_{EW_1} = 0.45 \cdot g$	
$A_{EW_2} \coloneqq 5 \cdot Ap_{k.EW}$			A <sub>EW2</sub> = 3.236 ⋅ g	
$\frac{1}{m}$				
$f_{EW_2} := \left(\frac{A_{EW_2}}{b}\right) + Hz$	f <sub>EW2</sub> =	2.331 · Hz		
f <sub>EW3</sub> ≔ 16 · Hz	$A_{EW}_3 \coloneqq A_{EW}_2$		A <sub>EW3</sub> = 3.236 ⋅ g	
f <sub>EW₄</sub> ≔ 33 · Hz	$A_{EW_4} \coloneqq 2 \cdot Ap_{k.EW}$		$A_{EW_4} = 1.294 \cdot g$	
f <sub>EW5</sub> ≔ 33 · Hz	$A_{EW_5} := Ap_{k.EW}$		$A_{EW_5} = 0.647 \cdot g$	
f <sub>EW<sub>6</sub></sub> ≔ 100 · Hz	A <sub>EW6</sub> := Ap <sub>k.EW</sub>		$A_{EW_6} = 0.647 \cdot g$	
Vertical Required Response Sp	ectra (OBE 5% Dampir	ng):		
$Ap_{\mathbf{k}.\mathbf{v}} \coloneqq 0.70 \cdot A_{\mathbf{zpa}.\mathbf{k}.\mathbf{V}}$	Ap <sub>k.v</sub> = 0.1	75 · g		
From Page 33 of Ref. 2	4, m := 2.3314	b := 0	.45 · g	
f <sub>V1</sub> := 1 ⋅ Hz	A <sub>V1</sub> := b	<i>.</i>	$A_{V_1} = 0.45 \cdot g$	
$A_{V_2} = 5 \cdot Ap_{k.v}$	· •	, ·	$A_{V_2} = 0.875 \cdot g$	) <sup>* •</sup> •
$\frac{1}{m}$				
$f_{V_2} := \left(\frac{A_{V_2}}{b}\right)^{H_2} \cdot H_2$	f <sub>V2</sub>	= 1.33 · Hz		
f <sub>V3</sub> ≔ 16 · Hz	$A_{V_3} \coloneqq A_{V_2}$		A <sub>V3</sub> = 0.875 ⋅ g	
f <sub>V₄</sub> ≔ 33 · Hz	$A_{V_4} := 2 \cdot Ap_{k.v}$		$A_{V_4} = 0.35 \cdot g$	
f <sub>V5</sub> ≔ 33 · Hz	A <sub>V5</sub> := Ap <sub>k.v</sub>		A <sub>V5</sub> = 0.175 ⋅ g	l.
f <sub>V6</sub> := 100 ⋅ Hz	$A_{V_6} := Ap_{k.v}$		A <sub>V<sub>6</sub></sub> = 0.175 ⋅ g	
	· · · · · · · · · · · · · · · · · · ·			·

Appendix A

Plant: WBN-2 Calculation ID: WCGACQ0766 This Sheet Added By Rev 1 Sheet No. A42



North	-South	East-West		Ver	tical
f (Hz)	a (g)	f (Hz)	a (g)	f (Hz)	a (g)
1.0	0.45	1.0	0.45	1.0	0.45
2.2	2.8 <del>9</del>	2.3	3.24	1.3	0.88
16.0	2.89	16.0	3.24	16.0	0.88
33.0	1.16	33.0	1.29	33.0	0.35
33.0	0.58	33.0	0.65	33.0	0.18
100.0	0.58	100.0	0.65	100.0	0.18

#### 8.0 Conclusion:

The above curves are the required response spectra for the safety related radiation monitoring equipment to be installed on WBN Unit 2 MCR Panels 2-M-30 (provided with Rev. 0 of this calc.), 0-M-12 and skids for WBN-2-RE-090-0106, WBN-2-RE-090-0112, WBN-2-RE-090-0130 and WBN-2-RE-090-0131. These RRS curves can be used for comparison to vendor seismic test reports for qualification of the WBN Unit 2 safety related Radiation Monitoring equipment.

Revision	Revision	Revision
Originator:Date:	Originator:Date:	Originator:Date:
Checker:Date:	Checker:Date:	Checker:Date:

<b>A</b> E	Coloulation Shoot	Project	WBN2CCP
BUD	Calculation Sheet	Job No.	25402
Subject: <u>REQUIRED F</u>	RESPONSE SPECTRA FOR EVALUATION OF	Calc. No.	WCGACQ0766
<b>RADIATION MONITORING EQUIPMENT</b>		Sheet No.	1 of 1
Prepared: SEE COVER SI	IEET Date	Sheet Rev.	This Sheet Replaced By 001
Checked: <u>SEE COVER SI</u>	IEET Date		

#### REFERENCES

12.0 <u>ATTACHM</u>	ENTS		· · ·
	ATTACHMENT TABLE OF	CONTENTS	
	· · ·	No. of Pages	
Attachment Tal	ble of Contents	1	
Attachment A:	Copy of Refs. 6.6-6.9 & 6.11	5	
Attachment B:	Copy of LSWD-536	8	:
· · ·			
	TOTAL No. OF ATT	ACHMENT PAGES <u>14</u>	

BECHT	E	DRAWING REVISION AUTHORIZATION (DRA)				EDCR NUMBER 52338-A PAGE (40 DRA NUMBER 52338-005 PAGE 1 OF 1		
JOB NO.	DWG TYPE	DRAWING NUM	BER	REV. NO.	DWG T (NEW [	TITLE & CATEGORY DWGS ONLY)		
OTHER DOCU	JMENTS AFFEC	TED BY THIS	CHANGE		Att	tachment NoA	- - - - - - - - - - - - - - - - - - -	
SEE EDCR	INDEX				Cal	alculation No. <u>L/CG ACQ 0164</u>	<u></u>	
			3     132     134       3     132     134       4     90     2     84       -273     2     84       1     90     -273       -273     1     2       1     1       1     1       1     1       1     1       1     1       1     1       1     1       1     1       1     1       1     1       1     1       1     1       1     1			REVISE		
	NO DR	TE TO D A 52374	2-R0-90 			CORPORATE ) DR DRA		
REV PRI 0 D/ 28402-30P-6046-0	EPARED BY Origh V. Style WZO W. SETE 00040-008	DATE 4-14-10	CHECKED BY / DA Joe Temples bet. Temples	te 9 4/14/10	CHAN	NGE REFERENCE R 52338-A		



### General Atomics Electronic Systems Drawing

## 04034100, Revision C, Outline High Range Area Monitor System



\_\_\_\_\_.



LSWD-536 Watts Bar Unit 2 Construction Completion Project Walkdown Procedure for **GENERAL WALKDOWN REQUIREMENTS** WDP-GEN-1 Appendix E PAGE 1 OF 8 LIMITED SCOPE WALKDOWNS LIMITED SCOPE WALKDOWN PACKAGE COVER SHEET Attachment E2 Page 1 of 1 PACKAGE NUMBER LSWD - 536 This Sheet Added By Rev. 001 REVISION 0 TITLE Verify dimensions of Panel 0-M-12 for CALC WCGACQ-0766. Attachment No. SCOPING DOCUMENT (IF APPLICABLE) N/A 1/12 Sheet / -<del>0</del>f-Calculation No. WCGACO 0766 PREPARED BY ingothy R Belk 12/22/1 **APPROVALS/ REVIEW** Robert G Brown RESPONSIBLE **ORGANIZATION SUPERVISOR Bill C Perkins** LEGIBILITY EVALUATED AND ALL PAGES Date: 12/22 Initia 12/22/2011 WALKDOWN TEAM LEA (Verifier)

Watts Bar Unit 2

WDP-GEN-1

Rev 14

Page 44 of 44

LSWD-536

PAGEZOF8

#### Watts Bar Unit 2 Construction Completion Project Walkdown Procedure for GENERAL WALKDOWN REQUIREMENTS WDP-GEN-1 Appendix E LIMITED SCOPE WALKDOWNS

#### LIMITED SCOPE WALKDOWN REQUEST AND DATA COLLECTING FORM Attachment E1 PAGE 1 OF 2

INITIATING DOCUMENT WCGACQ-0766 LOCATION (Unit, Building, Elevation, Room, Column Lines) UNIT 0, CONTROL BLDG, EL.-755', CONTROL ROOM, 6'Nof P & 12' W of C6. This Sheet Added By Rev. \_\_\_\_\_\_ SCOPE Engineering Walkdown for actual dimension to top of 2-RM-90-106 -NIM BIN on Front Face of Panel 0-M-12 in Main Control Room for CIVIL Calculation WCGACQ-0766 Attachment No. Sheet 2 -OF-116/12 Calculation No. WCFACQ 0766 DATA TOLERANCE REQUIREMENTS Current Design Criteria BECHTEL CIVIL ESQ 12/22/11 DATE Robert & Brown K REQUESTING ORGANIZATION

Watts Bar Unit 2

WDP-GEN-1

Rev 14
Watts Bar Unit 2 Construction Completion Project Walkdown Procedure for **GENERAL WALKDOWN REQUIREMENTS** WDP-GEN-1 Appendix E PAGE 3 OF 8 LIMITED SCOPE WALKDOWNS

# LIMITED SCOPE WALKDOWN REQUEST AND DATA COLLECTING FORM Attachment E1 PAGE 2 OF 2

PERFORMING ORGANIZATION BECHTEL CIVIL DESIGN **RESULTS See attached DATA Sheets** This Sheet Added By Rev. 001 Attachment No. 6/12 Sheet 3 Of Calculation No. WCGAC& 0766 TINCH K BELK WALKDOWN TEAM MEMBER 2011 SIGN 12/22/11 Javier Burgoa WALKDOWN TEAM LEADER SIG URE (Verifier)

LSWD-536

## Watts Bar Unit 2 Construction Completion Project Walkdown Procedure for **GENERAL WALKDOWN REQUIREMENTS** WDP-GEN-1 Appendix C

#### Walkdown Package

#### Attachment C7

Page 4 of 8 WP No. LSWD- 536 Rev. 0 **Unit 1/Unit 0 Operations Review** Circle item number(s) below that apply and obtain appropriate signatures. A. Walkdown Package requires Critical Evolutions review. 1. Unit 1/Unit 0 component with risk of Unit 1 reactor/turbine trip/ OR ESF ACTUATION. 2. Unit 1/Unit 0 component with risk of Unit 1 runback. This Sheet Added By Rev. \_ 001 3. Other B. Walkdown requires coordination with Unit 1 and 2 Operations Department. Attachment No. Sheet 4 -OF (1)U2 equipment energized for U1 operation. Calculation No. WCGACR 0 766 2. Personnel required in Unit 1/Unit 0 area other than normal egress. 3. Close proximity to electrical boards, panels, or components that could cause a Unit 1 Alarm condition or perturbation. 4. Unit 1/Unit 0 component in train/channel room outside normal work week. 5. Other UZ AUO Support C. Walk down requires Unit 2 Operations Department review only \_ 1. Unit 2 de-energized mechanical equipment in Unit 2 space 2. Unit 2 de-energized electrical equipment in Unit 2 space with no nearby Unit 1/Unit 0 electrical equipment. 3. Other W/ 12 W15 12-22-11 Unit 2 Operations Review Date 12/22 Unit 1 Operations Coordination **Critical Evolutions Review** 

WDP-GEN-1

LSWD-536

LSWD-536

### WDP-GEN-1 Appendix C Attachment C2 Walkdown Package Record of Revision

Page 5 of 8

## SCOPE OR TITLE OF WALKDOWN PACKAGE

### DESCRIPTION: VERIFY DIMENSIONS ON PANEL 0-M-12

Rev\_

Revision	Date	Description of Revision
No.		
• • 0	12/22/11	INITIAL ISSUE
	T	
	1	
·	<u>i</u>	
	· · · · · · · · · · · · · · · · · · ·	
·	1.	
	1	
	1	
	÷	
	÷	
	·	
·		

This Sheet Added By Rev. \_ 001

Attachment No. RGB1161 12 \_Of Calculation No. WCFACQ 0766

Watts Bar Unit 2

WDP-GEN-1

Rev 14





LSWP-536 PAGE 80+8 TOP OF Z-RM-90-106 NIM BIN 0 0 О 162 TH 306 BLAK BLANK BLANK 84-90-205/ 0 Ó -307 182 2-10-120, BLANK HLANK M-30-206/ BLANK BL AND 0 0 226 264 102 203 0000 2-84-60-119 EDCR 55801 BLANK SLANK SZ SZ 0000 CONSTRUCTION NOTE: (DO H A. CANTION: This Sheet Added By UNIT 1 COMPONENTS AR TERMINALS TO BE WORK MAY BE ADJACENT TO O TERMINALS. IMPLEMENT FOR WORKING INSIDE A ELECTRICALLY ENERGIZ Rev. 001 Attachment No. Sheet 8 -05-RG-B 116112 Calculation No. WCFACQ 0766 DAVIDW. SLIFE FLOOR BOTTOM OF PANEL N/A CONTRACT NO: OCA INVERSIONISTICAL art acca (60) <u>N/A</u> FI FOTOTOA FRONT FACE OF PANEL O-M-12

WDTM Burgoa

WOTL STREEL 12/22/2011