

UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D.C. 20555-0001

April 4, 2012

LICENSEE: Pacific Gas and Electric Company

FACILITY: Diablo Canyon Power Plant, Unit Nos. 1 and 2

SUBJECT: SUMMARY OF MARCH 21, 2012, TELECONFERENCE MEETING WITH PACIFIC GAS AND ELECTRIC COMPANY ON DIGITAL REPLACEMENT OF THE PROCESS PROTECTION SYSTEM PORTION OF THE REACTOR TRIP SYSTEM AND ENGINEERED SAFETY FEATURES ACTUATION SYSTEM AT DIABLO CANYON POWER PLANT (TAC NOS. ME7522 AND ME7523)

On March 21, 2012, a Category 1 teleconference public meeting was held between the U.S. Nuclear Regulatory Commission (NRC) and representatives of Pacific Gas and Electric Company (PG&E, the licensee) at NRC Headquarters, One White Flint North, 11555 Rockville, Maryland. The purpose of the teleconference meeting was to discuss the license amendment request (LAR) submitted by PG&E on October 26, 2011, for the Digital Replacement of the Process Protection System (PPS) Portion of the Reactor Trip System and Engineered Safety Features Actuation System at Diablo Canyon Power Plant, Unit Nos. 1 and 2 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML113070457). A list of attendees is provided in Enclosure 1.

The teleconference meeting is one in a series of publicly noticed teleconference meetings to be held approximately every 2 weeks to discuss issues associated with the NRC staff's LAR review. Preliminary issues that the NRC staff identified during its initial review and the licensee's responses to these preliminary issues were discussed during the teleconference meeting. The list of preliminary issues is provided in Enclosure 2.

During the discussion, the NRC staff indicated that in the near future it expects to address some of the issues identified in Enclosure 2 as requests for additional information. There was also a discussion that some detailed design information that would help the staff understand the LAR will be provided through a secure internet site that is password protected. The staff will review the material and determine if any of the documents need to be placed on the docket as part of the review.

Please direct any inquiries to me at 301-415-1132 or at Joseph Sebrosky@nre.gov.

Joseph M. Sebrosky, Senior Project Manager Plant Licensing Branch IV Division of Operating Reactor Licensing Office of Nuclear Reactor Regulation

Docket Nos. 50-275 and 50-323

Enclosures:

- 1. List of Attendees
- 2. Staff Identified Issues

cc w/encls: Distribution via Listserv

LIST OF ATTENDEES

MARCH 21, 2012, TELECONFERENCE MEETING WITH

PACIFIC GAS AND ELECTRIC COMPANY REGARDING

DIGITAL UPGRADE AT DIABLO CANYON POWER PLANT, UNITS 1 AND 2

DOCKET NOS. 50-273 AND 50-323

<u>NAME</u>

Scott Patterson Bob Lint John Hefler J. Basso Steve Seaman Roman Shaffer Bill Kemper Rich Stattel Bernard Dittman Joe Sebrosky Shiattin Makor Geoffrey Miller James Byam Gordon Clefton

ORGANIZATION

Pacific Gas and Electric Altran Altran Westinghouse Westinghouse Invensys/Triconex U.S. Nuclear Regulatory Commission U.S. Nuclear Regulatory Commission U.S. Nuclear Regulatory Commission U.S. Nuclear Regulatory Commission U. S. Nuclear Regulatory Commission U. S. Nuclear Regulatory Commission Exelon Nuclear Energy Institute

March	19, 12	Display="block-system: system:				Page 1 of 25		
No	Src/RI	Issue Description	P&GE response:	Status	RAI No. (Date Sent)	RAI Response (Due Date)	Comments	
001	AR (BD)	 [ISG-06 Enclosure B, Item 1.3] Draw The Diablo Canyon Specific Apples equence and provide corresponse time performance. This enable the NRC staff to determine a. has been implemented in condesign basis, b. is deterministic, and c. the response time is derive requirements and in full conhave been observed during. As stated in the LAR, information will be submitted as a Phase 2 do addressed accordingly. P&GE response: ALS Diablo Canyon PPS document 61 Specification", Section 7.5, identifiprovides an analysis associated with the qualification requirements b) The analysis in Diablo Casyon PPS A with the qualification requirements b) The analysis in Diablo Casyon PPS A with the qualification requirement b) The analysis in Diablo Casyon PPS A with the qualification requirement for the requirements for the requirementation (from input conditing specified as not to exceed 0.409 Scanyon Power Plant Units 1 & 2 Functional Requirements Specification (IRS) the LAR, the 0.409 seconds PPS is allocated between the ALS and 	eterministic Nature of Software: ication should identify the board access ding analysis associated with digital s analysis should be of sufficient detail to e that the logic-cycle; conformance with the ALS Topical Report d from plant safety analysis performance nsideration of communication errors that g equipment qualification. pertaining to response time performance ocument. Please ensure this matter is 16-00011, "ALS System Design fies the ALS board access sequence and with digital response time performance. ALS system is configured in accordance s of the ALS platform topical report, inyon PPS document 6116-00011, "ALS oction 7, describes a logic cycle that is response time of the PPS processing tioner to conditioned output signal) is seconds in Section 3.2.1.10 of the "Diablo Process Protection System Replacement cation (FRS)", Revision 4 submitted as tion 1.5.8 of the "Diablo Canyon Power ion System Replacement Interface ", Revision 4, submitted as Attachment 8 of processing instrumentation response time I Tricon as follows:	Open	N/A		Response acceptable; waiting on PG&E to provide the time response calculation for the V10 Tricon PPS Replacement architecture by April 16, 2012.	

Marc	March 19, 12 DCPP PPS O		DCPP PPS Open Item Summary Table	Open Item Summary Table			Page 2 of 25
No	Src/RI	Issue Description	P&GE response:	Status	RAI No. (Date Sent)	RAI Response (Due Date)	Comments
		ALS: 175 ms for RTD processing Tricon: 200 ms Contingency: 34 ms					
		 value that is currently allocated to PPS processing instrumentation. As long as the 0.409 second PPS processing instrumentation value is not exceeded, the total response time values assumed in the plant safety analyses contained in FSAR Table 15.1-2 will not be exceeded; 7 seconds for Overtemperature ΔT RT and Overpower ΔT RT functions, 2 seconds for High pressurizer pressure RT, Low pressurizer pressure RT, and Low Low SG water level RT functions, 1 second for Low reactor coolant flow RT function, 25 seconds for Low pressurizer pressure, High containment pressure, and Low steam line pressure Safety Injection initiation, 60 seconds for Low low SG water level auxiliary feedwater initiation, 18 seconds for High containment pressure, Low pressurizer pressure, and Low steam line pressure containment spray initiation, 7 seconds for High High containment pressure steam line isolation, 66 seconds for Low steam line pressure steam line isolation, and 8 seconds for Low steam line pressure steam line isolation. The ALS response time will be verified as part of the FAT and the results will be included in the FAT summary report to be submitted by 12/31/12. 					
		Included in the FAT summary report to be submitted by 12/31/12. Tricon Invensys provided detailed information on the deterministic operation of the V10 Tricon in Invensys Letter No. NRC V10-11-001, dated January 5, 2011. In support of the V10 Tricon safety evaluation, Invensys submitted document 9600164-731, Maximum Response Time Calculations, describing the worst- case response time for the V10 Tricon Qualification System. Included in document 9600164-731 are the standard equations for calculating worst- case response time of a given V10 Tricon configuration. The time response calculation for the V10 Tricon PPS Replacement architecture will be submitted by April 16, 2012. The System Response Time Confirmation Report, 993754-1-818, will be submitted to the staff as part of the ISG-06 Phase 2 submittals at the completion of factory acceptance testing of the V10 Tricon PPS Replacement. The Tricon response time will be verified as part of the EAT and the results will					The staff will likely need the Tricon time response calc's submitted on the docket. It is not efficient for the staff to travel to a remote facility to

March 19, 12

DCPP PPS Open Item Summary Table

No	Src/RI	Issue Description	P&GE response:	Status	RAI No.	RAI	Comments
					(Date Sent)	(Due Date)	
		be included in the FAT summary report to I	be submitted by 12/31/12.				audit SP calc's.
							PG&E stated that
							they will provide the
							Tricon Time
							response calc's in a
							document
							submitted on the
							docket.
002		[ISG-06 Enclosure B, Item 1.4]	Cuide (DC) 1 169 Devision 1	Open	N/A		
	(RA)	Software Management Plan. Regulatory	dite for Digital Computer Software				
		Used in Safety Systems of Nuclear Power	alls for Digital Computer Software				
		endorses IEEE (Institute of Electrical and	Electronics Engineers) 1012-1998				
		"IEEE Standard for Software Verification	and Validation " and IEEE 1028-				
		1997. "IEEE Standard for Software Revie	ws and Audits." with the exceptions				
		stated in the Regulatory Position of RG 1	.168. RG 1.168 describes a method				
		acceptable to the NRC staff for complying	g with parts of the NRC's regulations				
		for promoting high functional reliability an	d design quality in software used in				
		safety systems. Standard Review Plan(S	RP) Table 7-1 and Appendix 7.1-A				
		identify Regulatory Guide 1.168 as SRP	acceptance criteria for reactor trip				
		systems (RTS) and for engineered safety	r features				Response
		Westinghouse/ALS 6116-00000 Diablo C	anvon PPS Management Plan				on revised W/AI S
		Figure 2-2, shows the Verification and Va	alidation (V&V) organization				PPS MP, which is
		reporting to the Project Manager. This is	inconsistent with the information				due on March 29.
		described in the ALS Management Plan	for the generic system platform,				2012.
		where the V&V organization is independed	ent form the Project Manager. This				
		reconciled during the LAR and ALS LTR	reviews				
		P&GE response:					

Marc	h 19, 12	19, 12 DCPP PPS Open Item Summary Table					Page 4 of 25	
No	Src/RI	Issue Description	P&GE response:	Status	RAI No. (Date Sent)	RAI Response (Due Date)	Comments	
		ALS The PPS Replacement LAR refe 00000 Diablo Canyon PPS Man based on CSI document 6002-0 Revision 4. CS Innovations sub "6002-00003 ALS Verification at 11, 2011, that revised the requir management of the verification management of the developmen Diablo Canyon PPS Managemen organization structure in which t is separate and independent of personnel. PG&E will submit th Canyon PPS Management Plan	erenced Westinghouse document 6116- hagement Plan, dated July 25, 2011, that was 00003 ALS Verification and Validation Plan, osequently submitted a revised V&V plan, and Validation Plan", Revision 5, on November red V&V organization structure such that the personnel is separate and independent of the at personnel. The Westinghouse 6116-00000 and Plan is being revised to require a V&V the management of the verification personnel the management of the development e revised Westinghouse 6116-00000 Diablo a document by March 29, 2012.					
3	AR (RA)	[ISG-06 Enclosure B, Item 1.9] <u>Software V&V Plan:</u> The ALS V supplier is responsible for provid activities. Also, the organization Management Plan shows the IV The ALS V&V plan described in Diablo Canyon PPS Manageme about the activities to be perforn Plan states that for project spec on a project by project basis and Plan, in this case, 6116-00000, However, the 6116-00000 Diabl "See the ALS V&V Plan for more IV&V team and the PPS Replac The Triconex V&V plan states the scope for V&V activities. As me in the ISG6 matrix.	/&V plan states that Project Manager of the ding directions during implementation of V&V in chart in the Diablo Canyon PPS /V manager reporting to the PM. ISG6 matrix for the ALS platform and the ent Plan do not provide sufficient information med during V&V. For example, the ALS V&V ific systems, V&V activities are determined d are described in the project Management "Diablo Canyon PPS Management Plan." to Canyon PPS Management Plan states: e information and the interface between the ement project team."	Open	N/A		Status: Fig. 3 of the PPS SVVP (Pg. 16/46) indicates sufficient organizational independence between the Nuclear Delivery (Design) Organization and the IV&V Organization. Fig. 3 of the PPS PMP (993754-1- 905) (pg. 22/81)	
		demonstrate compliance with R	egulatory Guide (RG) 1.168, Revision 1,				also denotes the	

	Μ	arch	ı 19.	12
--	---	------	-------	----

DCPP PPS Open Item Summary Table

No	Src/RI	Issue Description	P&GE response:	Status	RAI No. (Date Sent)	RAI Response (Due Date)	Comments
		"Verification, Validation, Reviews Used in Safety Systems of Nuclea	and Audits for Digital Computer Software ar Power Plants,"				DCPP PPS project organization, and
		ALS The Westinghouse 6116-00000 Diablo Canyon PPS Management Plan is being revised to include details on how the IV&V team has an independent organizational reporting structure from the design and implementation team the Scottsdale Operations Director and the ALS Platform & Systems Director report to different Westinghouse Vice Presidents. The IVV Manager and Scottsdale Operations Director both report to the same Westinghouse Vice President, but via independent reporting structures. Description of 6116-00000 Diablo Canyon PPS Management Plan V&V activity updates - IN PROGRESS					sufficient independence between the ND and IV&V Organizations. Close the Invensys part of the OI.
		activity updates - IN PROGRESS PG&E will submit the revised Wes Management Plan that includes th	stinghouse 6116-00000 Diablo Canyon PPS he above changes by March 29, 2012.	5			W/ALS response acceptable; waiting on revised
		Tricon The organizational structure of Inv in part, Engineering and Nuclear I a specific role in the V10 Tricon a Engineering is responsible for des	vensys Operations Management comprises Delivery. Each of these organizations plays application project life cycle. Invensys signing and maintaining the V10 Tricon	,			W/ALS PPS MP, which is due on March 29. 2012.
		Platform, and Nuclear Delivery is customers on safety-related V10 ⁻⁷ Invensys Engineering department Plans (EPP)," whereas Nuclear D "Project Plans." Invensys Engine integration, but Nuclear Delivery n issues related to the V10 Tricon p	responsible for working with nuclear Tricon system integration projects. t procedures require "Engineering Project Delivery department procedures require ering is not directly involved in system may consult with Engineering on technical Delatform.				Status: Fig. 3 of the PPS SVVP (Pg. 16/46) indicates sufficient organizational independence
		The NRC applied ISG-06 to the V submitted a number of documents platform as well as process and p	/10 Tricon safety evaluation. Invensys s pertaining to the design of the V10 Tricon procedure documents governing Invensys				between the Nuclear Delivery (Design)

March 19, 1	2	DCPP PPS Open Item Summary Table				Page 6 of 25
No Src/I	RI Issue Description	P&GE response:	Status	RAI No. (Date Sent)	RAI Response (Due Date)	Comments
	Engineering activities, including the related documents are preceded we platform-level documents reviewed evaluation will not be resubmitted specific system integration project. In support of the PG&E LAR for the Nuclear Delivery is required to sub defined in ISG-06. These project of number 993754. The Phase 1 sub 993754-026T, dated October 26, 2 PPS Replacement Project Manage Management Plan" was used to me "management Plan" was used to me "management Plan" and PPS Replacement Software Verific 993754-1-802. The PMP describes the PPS Reple within the Invensys scope of supper NUREG/CR-6101 were used as in With regard to compliance with RC SVVP both describe the organizate Replacement Project. The document design team structure and response Verification and Validation (IV&V) interfaces between ND and Nuclear independence between ND and Nuclear inde	 e EPP. In most cases, these platform- with document number 9600164. The d by the staff during the V10 Tricon safety by Nuclear Delivery during application- s. e DCPP PPS Replacement, Invensys point the application design documents as documents are preceded by document bomittal under Invensys Project Letter 2011, contained, in part, the following: ement Plan (PMP), 993754-1-905. "Project hore closely match BTP 7-14 with regard to cation and Validation Plan (SVVP), acement Project management activities ly. The guidance documents BTP 7-14 and input during development of the PMP. G 1.168, the PPS Replacement PMP and ional structure and interfaces of the PPS tents describe the Nuclear Delivery (ND) sibilities, the Nuclear Independent team structure and responsibilities, the ar IV&V, lines of reporting, and degree of uclear IV&V. In addition, the PMP es between Invensys and the other PS Replacement project: PG&E, Altran, oliers. The combination of the PMP and the Invensys organization with RG 1.168. 				Organization and the IV&V Organization. Fig. 3 of the PPS PMP (993754-1- 905) (pg. 22/81) also denotes the DCPP PPS project organization, and provides sufficient independence between the ND and IV&V Organizations. Close the Invensys part of the OI.

March 19, 12 DCPP PPS Ope			DCPP PPS Open Item Summary Table	Dpen Item Summary Table Page			
Νο	Src/RI	Issue Description	P&GE response:	Status	RAI No. (Date Sent)	RAI Response (Due Date)	Comments
4	AR (RA)	[ISG-06 Enclosure B, Item 1.10] <u>Software Configuration Management</u> CF2.ID2, "Software Configuration Mar Operations Support," in Attachment 12 Attachment 12 only provides a guideli Management (SCM) and SQA plans. licensee will not perform development become responsible for maintaining co delivery from the vendor. The staff requires the actual plan to be configuration control over PPS softwa acceptance criteria of the SRP. For ex Management (CM) Plan (6002-00002) related to ALS generic boards. This p management activities to be used for ALS platform for the Diablo Canyon P configuration management for this des specific plan. These items will need for review to demonstrate compliance wit P&GE response: PG&E will develop a SyCMP procedu shipment of equipment from the vendor 31, 2012.	Plan: The LAR includes PG&E hagement for Plant Operations and 2. However, the document provided in ne for preparing Software Configuration Though it is understood that the of software, PGE personnel will onfiguration control over software upon e used by the licensee for maintaining re in order to evaluate against the cample, the ALS Configuration describes initial design activities and does describe the configuration the development and application of the PS System. The staff requires that sign be described in the DCPP project urther clarification during the LAR h BTP-14.	Open	N/A		

Marc	h 19, 12	DCPP PPS Open Item Summary Table				Page 8 of 25		
No	Src/RI	Issue Description	P&GE response:	Status	RAI No. (Date Sent)	RAI Response (Due Date)	Comments	
5	AR (RA)	[ISG-06 Enclosure B, Item 1.11] Software Test Plan: The V10 platfor	n documents identified in ISG6 matrix	Closed	N/A		NGIO Core	
		state that the interface between the N	IGIO (Next Generation Input Output)				software is tested	
		when and how this interface will be to	ested, and why this test is not part of the				and qualified as a platform	
		Software unit testing and integration testing activities.					component. As such it does not	
		states that the DCPP's TSAP will not	be loaded on the system; instead				need to be	
		DCPP's TSAP will not be used for the	e validation test. It is not clear why the validation test or when the DCPP's				separately tested during the	
		System. These items will need furthe	nd validated for the Diablo Canyon PPS or clarification during the LAR review to				application	
	(=10)	demonstrate compliance with BTP-14	l.				process.	
		 Follow-on question pertaining to the PPS VTM: Section 1.4.4 (pg. 12/38) states "The network equipment, including media converter, NetOptics Network Aggregator Tap, and gateway hub, and the MWS will not be within the test scope of this VTP. The Nuclear Delivery (ND) group will coordinate with Pacific Gas & Electric for system staging prior to turn over to Nuclear IV&V. The Nuclear IV&V group will confirm proper operation of network communications system interfaces before beginning testing addressed in this VTP." When, where, and what procedures will be used to test the network equipment?? Also, section 5.1.4 (3) Hardware Validation Tests states that the ALS equipment will not be included in the FAT (pg. 27/38). Where, when, and what procedures will be used to fully test the Integrated RPS system (both 					TSAP is a Test Specimen Application Program used for purposes of platform qualification.	
		Tricon V10 and ALS platforms togeth	er) be subjected to FAT.				Invensys stated that The Diablo Canyon	
		P&GE response:					Application will be loaded onto plant	
		Tricon The next-generation input/output (I/O) modules qualified for the V10 Tricon are the 3721N 4-20 mA, 32-point analog input (AI) module, and the 3625N 24 Vdc, 32-point digital output (DO) module. Technical data on these two					system hardware during FAT.	
		are the 3721N 4-20 mA, 32-point ana 24 Vdc, 32-point digital output (DO) r	log input (AI) module, and the 3625N nodule. Technical data on these two					

Marc	h 19, 12	DCPP PPS Open Item Summary Table					Page 9 of 25
No	Src/RI	Issue Description	P&GE response:	Status	RAI No. (Date Sent)	RAI Response (Due Date)	Comments
		modules was provided to the NRC	C in support of the V10 Tricon safety				
		evaluation. Configuration and fur	nctional testing is performed when the I/O				
		modules (hardware and embedde	ed core firmware) are manufactured. From				Staff re-examined
		the factory the I/O modules are sh	nipped to Invensys Nuclear Delivery for use				Invensys doc.
		in nuclear system integration proj				"Validation Test	
		Because the module hardware an	Because the module hardware and embedded core firmware are within the				Plan (VTP),
		scope of the V10 Tricon safety ev	aluation, the verification and validation of				993754-1-813,"
		the embedded core firmware will	not be repeated as part of application-				Section 1.3.2 of the
		specific system integration projec	ts.				VTP that describes
							the Hardware
		There are certain design items that	at must be done with TriStation 1131				Validation Test
		(TS1131), such as specifying white	ch I/O module is installed in a particular				activities and
		physical slot of the Tricon chassis	s, resulting in each module having a unique				Section 1.3.3 of the
		hardware address in the system.	hardware address in the system. Also, TS1131 is used to specify which				VTP and
		application program parameters (i.e., program variable tagnames) are				determined that the
		assigned to a particular point on a	a given I/O module. The design items				application
		configured in TS1131 will be withi	in the scope of validation activities				program TSAP
		conducted by Invensys Nuclear IV	/&V for application-specific system				will be used for
		integration projects. The necessa	ary collateral (system build documents,				the FAT (Section
		configuration tables, test procedu	res, test results, etc.) will be submitted to				5.1.5 FAT)
		the NRC to support the staff's tec	hnical review of the PPS Replacement LAR				Close this portion
		in accordance with ISG-06.					of the OI.
		The Phase 1 submittal under Inve	ensys Project Letter 993754-026T, dated				
		October 26, 2011, contained, in p	art, the Validation Test Plan (VTP), 993754-				
		1-813. This document describes	the scope, approach, and resources of the				
		testing activities that are required	for validation testing of the V10 Tricon				
		portion of the PPS Replacement,	including:				
		Preparing for and conducting syst	tem integration tests				
		Defining technical inputs to valida	tion planning				
		Defining the test tools and enviror	nment necessary for system validation				
		Esting	of the echodule)				
1	1			1		1	1

Marc	h 19, 12	DCPP PPS Open Item Summary Table				Page 10 of 25		
No	Src/RI	Issue Description	P&GE response:	Status	RAI No. (Date Sent)	RAI Response (Due Date)	Comments	
		Section 1.3.2 of the VTP describe and Section 1.3.3 of the VTP des Acceptance Test activities for the Replacement. Details on the app to be provided to the staff separat						
6	AR (SM)	 [ISG-06 Enclosure B, Item 1.14] Equipment Qualification Testing Plans - The LAR Sections 4.6, 4.10.2.4 and 4.11.1.2 provide little information on the plant specific application environmental factors. The Tricon V10 Safety Evaluation, ML 11298A246, Section 6.2 lists 19 application specific actions Items (ASAI's) that the licensee should address for plant specific applications. The licensee should address for plant specific applications. The licensee should address each of these for Tricon portion of the PPS replacement. Similar information for the ALS portion of the PPS replacement will also be required. P&GE response: ALS PG&E will respond to ALS ASAI's when they are available. Tricon IN PROGRESS. All of the Application Specific Action Items for the Tricon V10 will be addressed by March 29 2012 in a submittal to the NRC. 		Closed	Develop a generic RAI to provide a respons e to ASAIs for both platform s when the SERs are issued.		Staff agreed that PG&E should submit a separate submittal (LAR amendment) to address the ASAIs for both platforms. it is not necessary to delineate exactly what will be done for each ASAI in this OI matrix.	
7	AR (BK)	[ISG-06 Enclosure B, Item 1.16] <u>Design Analysis Reports:</u> The LA (ISG-04) regarding the connectivi PPS. The TriStation V10 platform disconnection of the TriStation's of software. Based on the information determined that the Tricon V10 platform	AR does not appear to comply with the SRP ty of the Maintenance Work Station to the n relies on software to effect the capability to modify the safety system on provided in the LTR, the NRC staff atform does not comply with the NRC	Open	N/A		Waiting for t he the V10 Tricon portion of the PPS Replacement Failure Modes and Effects Analysis, an	

Marc	h 19, 12	2 DCPP PPS Open Item Summary Table				Page 11 of 25	
No	Src/RI	Issue Description	P&GE response:	Status	RAI No. (Date Sent)	RAI Response (Due Date)	Comments
		guidance provided in ISG-04, Hig Communications Issues, (ADAMS Position 1, Point 10, hence the DC comply with this guidance. In order for the NRC staff to accer deviation to this staff position, the specific system communications of operation of the keyswitch, the so testing performed on failures of the the keyswitch. The status of the A time and will be resolved as the A Moreover, the Tricon V10 system keyswitch does change operation the TriStation 1131 PC to change related to the application program or division being in bypass or in tr V10 SER, the TriStation 1131 PC the Tricon V10 is operational and However, it is physically possible times, and this should be strictly of place the respective channel out parameters, etc). The LAR does such as this to control the operati- keyswitch. Furthermore, in order attached to the SR Tricon V10 sys- position, a detailed FMEA of the T to ascertain the potential effects the execution of the safety application division. These issues must be a determine that the DCPP PPS co provided in Staff Position 1, Point	hly Integrated Control Rooms— S Accession No. ML083310185), Staff CPP PPS configuration does not fully of this keyswitch function as an acceptable staff will have to evaluate the DCPP PPS control configurationincluding the ftware affected by the keyswitch, and any e hardware and software associated with ALS platform on this matter is unclear at this LS LTR review is completed. Operational Mode Change (OMC) al modes of the 3008N MPs and enables parameters, software algorithms, etc, of the safety channel without the channel ip. As stated in Section 3.1.3.2 of the Tricon should not normally be connected while I performing safety critical functions. for the TriStation PC to be connected at all controlled via administrative controls (e.g., of service while changing the software, not mention any administrative controls on of the OMC (operational mode change) to leave the non-safety TriStation 1131 PC stem while the key switch is in the RUN TriStation 1131 PC system will be required his non-safety PC may have on the n program/operability of the channel or ddressed in order for the NRC staff to mplies with the NRC Staff Guidance 11. The status of the ALS platform on this			(Due Date)	ISG-06 Phase 2 document to be submitted to NRC in May 2012. PG&E/Invensys needs to provide a technical explanation of how the MP3008N processor actually ignores all commands when in RUN—address the items in the OI. This issue will also have to be addressed for the ALS platform.
		P&GE response:		-			
1	1				1	1	

No Src/RI Issue Description P&GE response: Status RAI No. (Date Sent) RAI Response (Due Date) Com Tricon The OMC keyswitch controls only the mode of the V10 Tricon 3008N MPs. In RUN position the 3008N MPs ignore* all commands from external devices, whether WRITE commands from external operator interfaces or program- related commands from TS1131. Multiple hardware and software failures would have to occur on the V10 Tricon (in combination with human- performance errors in the control room and at the computer with TS1131 Image: Command the computer with TS1131 Image: Command the computer with TS1131	age 12 of 25
Tricon The OMC keyswitch controls only the mode of the V10 Tricon 3008N MPs. In RUN position the 3008N MPs ignore* all commands from external devices, whether WRITE commands from external operator interfaces or program- related commands from TS1131. Multiple hardware and software failures would have to occur on the V10 Tricon (in combination with human- performance errors in the control room and at the computer with TS1131	nments
installed) in order for the application program to be inadvertently reprogrammed. Therefore, there is no credible single failure on the V10 Tricon that would allow the safety-related application program to be inadvertently programmed, e.g., as a result of unexpected operation of the connected computer with TS1131 installed on it. The above conclusion will be confirmed (for the V10 Tricon portion of the PPS Replacement) in the Failure Modes and Effects Analysis, an ISG-06 Phase 2 document planned for submittal to NRC in May 2012. Additionally, Invensys Operations Management will support the staff's review of the hardware and software associated with the OMC keyswitch by making all of the technical data available for audit. *TS1131 contains function blocks that allow WRITE-access to a limited set of parameters programmed into the application software, but only for a limited duration after which the capability is disabled until WRITE-access is re- enabled. However, without these function blocks programmed into the application program neither the application program nor application program parameters can be modified with the OMC keyswitch in the RUN position. PG&E Administrative controls on use of keyswitch will be provided with commitment to include in procedures in response. explanati the MP30 processo is on processo is ginores a ignores a	ivensys o provide a l tion of how 008N or actually all

Marc	h 19, 12		DCPP PPS Open Item Summary Tab	le			Page 13 of 25
No	Src/RI	Issue Description	P&GE response:	Status	RAI No. (Date Sent)	RAI Response (Due Date)	Comments
							RUN-address the
							items in the OI.
8	AR (RS)	AR [ISG-06 Enclosure B, Item 1.21] (RS) <u>Setpoint Methodology:</u> The NRC staff understands that a summary of SP (setpoint) Calculations will be provided in Phase 2, however, section 4.10.3.8 of the LAR also states that PGE plans to submit a separate LAR to adopt TSTF 493. The NRC cannot accept this dependency on an unapproved future licensing action. The staff therefore expects the licensee to submit a summary of setpoint calculations which includes a discussion of the methods used for determining as-found and as-left tolerances. This submittal should satisfy all of the informational requirements set forth in ISG6 section D.9.4.3.8 without a condition of TSTF 493 LAR approval			N/A		
		P&GE response: The evaluation of the setpoints for the PPS replacement will need to be performed by Westinghouse in two phases in order to provide sufficient documentation to support 95/95 two-sided uncertainty values for the setpoints. This is because the NRC staff has been requesting additional information and additional data and analysis to demonstrate that the uncertainties used in the setpoint calculation have been based on a statistically sufficient quantity of sample data to bound the assumed values (to justify the confidence level of the calculation is appropriate) during recent Westinghouse projects involving setpoints. Significant information is required from the transmitter and RTD vendors, that has never been obtained before, to support development of calculations that can support 95/95 two-sided uncertainty values. The first phase of the evaluation of the setpoints will include evaluation of the PPS replacement setpoints for the Tricon and ALS architecture using expected bounding uncertainty values. A setpoint summary evaluation which includes a discussion of the methods used for determining the as-found and as-left tolerances will be submitted by May 31, 2012. This is a change to the					

Marc	h 19, 12	19, 12 DCPP PPS Open Item Summary Table					Page 14 of 25		
No	Src/RI	Issue Description	P&GE response:	Status	RAI No. (Date Sent)	RAI Response (Due Date)	Comments		
		LAR. The second phase of the evalu of Westinghouse calculations of Tricon and ALS architecture us substantiate that the setpoints values. The Westinghouse cal 2012 and will be available for in support provided by Westingho inspection of Westinghouse cal performed for another recent u	ation of the setpoints will include developmen of the PPS replacement setpoints for the sing sufficient information from vendors to are based on 95/95 two-sided uncertainty culations will be completed by December 31, hspection by NRC staff in Washington DC with buse setpoint group personnel. The NRC staff lculations in Washington DC has been tility project involving setpoints.	t T F					
9	AR (BK)	LTR Safety Conclusion Scope the DCPP PPS LAR refer the re- to demonstrate compliance of t 1991, IEEE 7-4.3.2-203, and IS the ALS LTR state that complia and ISG-04 are application spe specific license amendment su The staff has not yet had time t and compare this information we there is no missing information encouraged to review these two compliance with these IEEE St within both licensing document	and Applicability - Many important sections of eader to the ALS licensing topical report (LTR the system with various Clauses of IEEE 603- SG-04. However, many important sections of ance with various Clauses of these IEEE Stds ecific and refer the reader to an application bmittal (i.e., the DCPP PPS LAR in this case) to evaluate all the LAR information in detail with that provided in the ALS LTR to ensure . However, PG&E and its contractors are o licensing submittals promptly to verify that ds and ISG-04 are adequately addressed s.	Open	N/A				
		P&GE response: IN PROGRESS, review by Westinghouse and PG&E to date has not found a clause where no justification is provided in LAR.		I					
10	RS	Plant Variable PPS Scope - In 4.1.3, nine plant variables are o 4.1.4 lists seven plant variables additional plant variables were	the Description section of the LAR, section defined as being required for RTS and section s that are required for the ESFAS. Three also listed in section 4.10.3.4.	Closed	1				

Marc	arch 19, 12 DCPP PPS Open Item Summary Table				Page 15 o		
No	Src/RI	Issue Description	P&GE response:	Status	RAI No. (Date Sent)	RAI Response (Due Date)	Comments
		plant parameters. It is therefore assumed that these parameters are provided as direct inputs to the SSPS and that the PPS is not relied upon for the completion of required reactor trip or safety functions associated with them. Please confirm that these plant parameters and associated safety functions will continue to operate independently from the PPS and that the replacement PPS will not adversely impact the system's ability to reliably perform these functions.					
		P&GE response: The PPS Replacement LAR Sevariables from which RTS and I The initiation signal outputs to t the PPS or other, independent s devices. Section 4.1.3 items 6 (Main Turbine trip fluid pressure acceleration) are generated by direct contact inputs to the SSP Radiation) and 7 (RT breaker pro- outside the PPS and are direct signals associated with these pl the PPS. The replacement PPS performance of the safety funct The three signals (Wide Range Impulse Chamber Pressure) no monitored by the PPS per Section and Temperature signals are us in DCPP FSAR Section 5. The Pressure to generate an initiation				Neutron Flux is an input to Tricon but it is not listed in Table 4-2 "Process Variable inputs to Tricon" Signals not associated with PPS functions will be designated as such in the SE and they will not be described since they are not in scope.	

Marc	h 19, 12	9, 12 DCPP PPS Open Item Summary Table					Page 16 of		
No	Src/RI	Issue Description	P&GE response:	Status	RAI No. (Date Sent)	RAI Response (Due Date)	Comments		
		coincidence logic to develop Permi	ssive P-13 as discussed in RAI 3, below.						
		Neutron Flux should be added to S	ection 4.2 Table 4-2 as follows:						
		Neutron Flux (Power	Input to Overtemperature Δ Temperature (OTDT) RT						
		Range, Upper & Lower)	Input to Overpower Δ Temperature (OPDT) RT						
1	RS	 <u>Power Range NIS Function</u> - Section Range NIS Protection Functions ar instrumentation provides input to the It is not entirely clear whether any of will be performed by the PPS system the PPS system is for these NIS Prince P&GE response: Power range analog inputs are provide the PPS and the calculation of the Delta-T Setpoint in the Delta-T/Tavi interface with the PPS. The NIS Prince permissives) are generated independent bistable comparators. The NIS bisting and have no physical interface with the PPS in the prince 	on 4.1.7 describes the Existing Power nd it states that the Power Range nuclear ne OTDT, and OPDT protection channels. of the described NIS protection functions em. Please clarify exactly what the role of rotection functions. vided by the NIS to each PPS Protection Overtemperature Delta-T and Overpower g channels. No other NIS signals rotection functions (RT and power range ndently by Nuclear Instrumentation table outputs are sent directly to the SSPS in the PPS.	Closed* *RAI still needs to be sent.	2		Only PPS Functions will be described in the SE.		
2	RS	Permissive Functions - Several Per LAR. It is not clear to the staff whe performed by the PPS or if the PPS systems that in turn perform the per Section 4.1.9 states that "Settings of develop the permissives are not aff which implies that all of these perm other than the PPS. However, it is permissive functions described three	rmissive functions are described within the ther any of these functions are to be S will only be providing input to external rmissive logic described in the LAR. of the bistable comparators used to fected by the PPS Replacement Project", hissive functions are performed by systems still unclear if this statement applies to all purposit the LAR or if it applies only to	Open	3				

Marc	h 19, 12	DCPP PPS Open Item Summary Table			Page 17 of 25			
No	Src/RI	Issue Description	P&GE response:	Status	RAI No. (Date Sent)	RAI Response (Due Date)	Comments	
		those permissives relating to Pr the permissive functions are be continue to be performed by the "not affected" by the PPS replace Please provide additional inform clearly define what the role of the P-4 Reactor Trip P-6 Intermediate Range Perm P-7 Low Power Permissive (E P-8 Loss of Flow Permissive P-9 Power Permissive P-10 Power Range Power Low P-11 Low Pressurizer Pressure P-12 No-Load Low-Low T _{ave} Te P-13 Turbine Low Power Perm P-14 Hi-Hi Steam Generator Low	D					
		P&GE response:						
		Permissive function initiation signals generated within the existing PPS will continue to be performed by the replacement PPS and therefore remain "not affected" by the PPS replacement project. Permissive function initiation signals that are generated independently of the existing PPS will continue to be generated independently.						
		 Permissive P6, P-8, P-9 comparator outputs from no interface with the PP Permissive P-4 initiation coincidence logic genera Breakers (RTB). There Permissive P-11, P-12, I 	, and P-10 initiation signals are bistable in the independent NIS to the SSPS. There is S. signals are direct contact inputs to the SSPS ated from contacts in the Reactor Trip is no interface with the PPS. P-13, and P-14 initiation signals are	5			The response states that P14 is generated in the NIS independently from PPS and it states that P14 is generated by the	

Marc	h 19, 12	D	CPP PPS Open Item Summary Table	ble			Page 18 of 25	
No	Src/RI	Issue Description	P&GE response:	Status	RAI No. (Date Sent)	RAI Response (Due Date)	Comments	
	-	generated by bistable comparate	or outputs generated in the PPS and				PPS. Which is it?	
		 Permissive P-7 is generated in the NI channels (from NIS - P-10) be chamber pressure channels below. The bistable initiation signals described. The SSPS generates the Permissive where initiation signals is detected. No SSPS coincidence logic is changed by the PPS Permissives P-6, P-7, P-8, P-9, P-10, and FSAR Table 7.2-2. Permissives P-4, P-described in FSAR Table 7.3-3. The bistable comparator setpoints for the expected to change at this time. 	he SSPS from 3 out of 4 power range elow setpoint and 2/2 turbine impulse ow setpoint (From PPS – P13). above are monitored by the SSPS. nen appropriate coincidence of permissive or safety function S replacement project. and P-13 are functionally described in -11, P-12, and P-14 are functionally he above-listed permissives are not				The coincidence of P7 is not performed as a function of PPS. The NRC understands that only P11, P13, and P14 are developed within the PPS system. All other permissives are generated by external systems independently of the PPS.	
							See 13 below.	
13	RS	P12 <u>Permissive Contradiction</u> - The sec describes the P-12 interlock and states the PPS". This statement is then contra following statement; "These valves are not safety-related, bu from the SSPS."	ond paragraph of section 4.1.20 that "These signals are developed in adicted in the third paragraph by the at are interlocked with the P-12 signal	Open	4			
		In conjunction with the response to RAI contradiction in section 4.1.20 of the LA	3, please provide a resolution for this R.				The NRC understands that the P12 signal is	
		P&GE response:					SSPS using signals	
		The word "signals" in the referenced Se	ction 4.1.20 sentence, "These signals				PPS.	

Marc	March 19, 12 DCPP PPS Open Item Summary Table					Page 19 of 25		
Νο	Src/RI	Issue Description	P&GE response:	Status	RAI No. (Date Sent)	RAI Response (Due Date)	Comments	
		are developed " is referring to the I	pistable comparator outputs which are	1				
		monitored by the SSPS. The PPS of	loes not generate the P-12 Permissive				Does this response	
		itself. The actual P-12 Permissive is	s generated by the SSPS when				also apply to the	
		appropriate coincidence of initiation	signals is detected. The SSPS output is				P11, P13, and P14	
		interlocked with the valves as stated	in the third paragraph of Section 4.1.20.				permissives? If so then no	
		The LAR Section 4.1.20 is clarified to "The P-12 Permissive is developed the P-12 bistable comparator output				permissives are generated by the PPS. Is that		
		Protection System Permissives (P-1 power permissive from Tricon, and F from Tricon) are generated by coince initiating signals (bistable outputs) fr OI #12. Permissive development, in coincidence is shown in FSARU Tate The PPS does not perform coincider any protection system permissives.	1 unblock SI from ALS, P13 Turbine P-14 Steam Generator Level high-high ident logic in the SSPS based on om the PPS as noted in the response to including initiating signals and logic bles 7.2-2 (RTS) and 7.3-3 (ESFAS). Int logic functions and does not "generate"				correct?	
14		Section 4.1.1 SSPS contains the foll	owing statement in the last paragraph;	New				
		"Information concerning the PPS status lamps and annunciators by way demultiplexer and to the PPS by way	atus is transmitted to the control board ay of the SSPS control board of the SSPS computer demultiplexer."					
		Why would the PPS status need to a sentence suggests in the last phrase	be transmitted to the PPS as the e?					
		PG&E response:						
		The sentence in Section 4.1.1 conta sentence should read: "Information concerning the PPS sta status lamps and annunciators by w demultiplexer and to the <i>Plant Proce</i>	ins a a typographical error. The itus is transmitted to the control board ay of the SSPS control board ess <i>Computer (PPC)</i> by way of the SSPS					
	L	computer demultiplexer."						

March	19, 12	12 DCPP PPS Open Item Summary Table					Page 20 of 25		
Νο	Src/RI	Issue Description	P&GE response:	Status	RAI No. (Date Sent)	RAI Response (Due Date)	Comments		
		As used in the Section 4.1.1. pa Trip Status."	aragraph, "PPS Status" means "PPS Channel						
15	(BK)	An ISG-04 compliance matrix for with, or referenced in, the LAR for compliance section 4.8 of the Land nearly all the points of ISG-04. 1E and non-1E communication Maintenance Work Station, plan aggregator, and 4-20 ma temper all application specific features of ALS document to be submitted ELECTRIC COMPANY NUCLE PROTECTION SYSTEM REPL PLANT DI&C-ISG-04 CONFOR 912 Revision 0, to be submitted portion of the PPS application complexity March 31, 2012 and PG&E will for March 31, 2012 and PG&E will for the PG&E response:	or the DCPP PPS system was not submitted for the W/ALS platform. Instead the ISG-04 AR refers the reader to the ALS LTR for Fig. 4.4 and 4.5 of the LAR indicate various pathways to and from ALS processor (e.g., at computer, prococess control, port erature signal to Tricon processor). These are of the PPS and the staff expects a W/CSI similar to the Invensys "PACIFIC GAS & AR SAFETY-RELATED PROCESS ACEMENT DIABLO CANYON POWER MANCE REPORT" Document No. 993754-1- I on the docket, which explains how the ALS comforms with the guidance of ISG-04.	New					

h 19, 12	D, 12 DCPP PPS Open Item Summary Table					
Src/RI	Issue Description	P&GE response:	Status	RAI No. (Date Sent)	RAI Response (Due Date)	Comments
(BK)	Section 1.4.4 (pg. 12/38) of document 99 PPS Validation Test Plan (VTM) states " media converter, NetOptics Network Agg the MWS will not be within the test scope (ND) group will coordinate with Pacific G to turn over to Nuclear IV&V. The Nuclea operation of network communications sys testing addressed in this VTP." When, w used to test the network equipment?? PG&E response: IN PROGRESS	03754-1-813 Diablo Canyon Triconex The network equipment, including gregator Tap, and gateway hub, and e of this VTP. The Nuclear Delivery as & Electric for system staging prior ar IV&V group will confirm proper stem interfaces before beginning where, and what procedures will be	New			
(BK)	Section 5.1.4.3, Hardware Validation Tes 1-813 Diablo Canyon Triconex PPS Valid the ALS equipment will not be included ir procedures will be used to fully test the In V10 and ALS platforms together) be subj	sts, (pg. 27/38) of document 993754- dation Test Plan (VTM) states that in the FAT. Where, when, and what integrated PPS system (both Tricon jected to FAT.	New			
	(BK)	Issue Description (BK) Section 1.4.4 (pg. 12/38) of document 99 PPS Validation Test Plan (VTM) states " media converter, NetOptics Network Agg the MWS will not be within the test scope (ND) group will coordinate with Pacific G to turn over to Nuclear IV&V. The Nuclear operation of network communications systesting addressed in this VTP." When, w used to test the network equipment?? PG&E response: IN PROGRESS (BK) Section 5.1.4.3, Hardware Validation Test 1-813 Diablo Canyon Triconex PPS Valid the ALS equipment will not be included in procedures will be used to fully test the II V10 and ALS platforms together) be subj PG&E response: IN PROGRESS	Is, 12 DCPP PPS Open item Summary Table Src/RI Issue Description (BK) Section 1.4.4 (pg. 12/38) of document 993754-1-813 Diablo Canyon Triconex PPS Validation Test Plan (VTM) states "The network equipment, including media converter, NetOptics Network Aggregator Tap, and gateway hub, and the MWS will not be within the test scope of this VTP. The Nuclear Delivery (ND) group will coordinate with Pacific Gas & Electric for system staging prior to turn over to Nuclear IV&V. The Nuclear IV&V group will confirm proper operation of network communications system interfaces before beginning testing addressed in this VTP." When, where, and what procedures will be used to test the network equipment?? PG&E response: IN PROGRESS (BK) Section 5.1.4.3, Hardware Validation Tests, (pg. 27/38) of document 993754- 1-813 Diablo Canyon Triconex PPS Validation Test Plan (VTM) states that the ALS equipment will not be included in the FAT. Where, when, and what procedures will be used to fully test the Integrated PPS system (both Tricon V10 and ALS platforms together) be subjected to FAT. PG&E response: IN PROGRESS	In 19, 12 DCPP PPS Open item summary table Src/Rl Issue Description P&GE response: Status (BK) Section 1.4.4 (pg. 12/38) of document 993754-1-813 Diablo Canyon Triconex PPS Validation Test Plan (VTM) states "The network equipment, including media converter, NetOptics Network Aggregator Tap, and gateway hub, and the MWS will not be within the test scope of this VTP. The Nuclear Delivery (ND) group will coordinate with Pacific Gas & Electric for system staging prior to turn over to Nuclear IV&V. The Nuclear IV&V group will confirm proper operation of network communications system interfaces before beginning testing addressed in this VTP." When, where, and what procedures will be used to test the network equipment?? PG&E response: IN PROGRESS New (BK) Section 5.1.4.3, Hardware Validation Tests, (pg. 27/38) of document 993754- 1-813 Diablo Canyon Triconex PPS Validation Test Plan (VTM) states that the ALS equipment will not be included in the FAT. Where, when, and what procedures will be used to fully test the Integrated PPS system (both Tricon V10 and ALS platforms together) be subjected to FAT. PG&E response: IN PROGRESS PG&E response: IN PROGRESS PG&E response: IN PROGRESS PG&E response: IN PROGRESS	Src/RI Issue Description P&GE response: Status RAI No. (Date Sent) (BK) Section 1.4.4 (pg. 12/38) of document 993754-1-813 Diablo Canyon Triconex PPS Validation Test Plan (VTM) states "The network equipment, including media converter, NetOptics Network Aggregator Tap, and gateway hub, and the MWS will not be within the test scope of this VTP. The Nuclear Delivery (ND) group will coordinate with Pacific Gas & Electric for system staging prior to turn over to Nuclear IV&V. The Nuclear IV&V group will confirm proper operation of network communications system interfaces before beginning testing addressed in this VTP." When, where, and what procedures will be used to test the network equipment?? New PG&E response: IN PROGRESS IN PROGRESS New (BK) Section 5.1.4.3, Hardware Validation Tests, (pg. 27/38) of document 993754- 1-813 Diablo Canyon Triconex PPS Validation Test Plan (VTM) states that the ALS equipment will not be included in the FAT. Where, when, and what procedures will be used to fully test the Integrated PPS system (both Tricon V10 and ALS platforms together) be subjected to FAT. New PG&E response: IN PROGRESS PG&E response: IN PROGRESS New	Src/RI Issue Description P&GE response: Status RAI No. (Øate Sort) RAI Response (Due Date) (BK) Section 1.4.4 (pg. 12/38) of document 993754-1-813 Diablo Canyon Triconex PPS Validation Test Plan (VTM) states "The network equipment, including media converter, NetOptics Network Aggregator Tap, and gateway hub, and the MWS will not be within the test scope of this VTP. The Nuclear Delivery (ND) group will coordinate with Pacific Gas & Electric for system staging prior to turn over to Nuclear IV&V. The Nuclear IV&V group will confirm proper operation of network communications system interfaces before beginning testing addressed in this VTP." When, where, and what procedures will be used to test the network equipment?? New PG&E response: IN PROGRESS New (BK) Section 5.1.4.3. Hardware Validation Tests, (pg. 27/38) of document 993754- 1-813 Diablo Canyon Triconex PPS Validation Test Plan (VTM) states that the ALS equipment will not be included in the FAT. Where, when, and what procedures will be used to fully test the Integrated PPS system (both Tricon V10 and ALS platforms together) be subjected to FAT. New PG&E response: IN PROGRESS PG&E response: IN PROGRESS Network and the trick of the subjected to FAT.

Marc	h 19, 12	DCPP PPS Open Item Summary Table				Page 22 of 25	
No	Src/RI	Issue Description	P&GE response:	Status	RAI No. (Date Sent)	RAI Response (Due Date)	Comments
18	(BK)	Software Management Plan: Regu "Verification, Validation, Reviews a Used in Safety Systems of Nuclea endorses IEEE (Institute of Electric "IEEE Standard for Software Verifi 1997,"IEEE Standard for Software stated in the Regulatory Position o acceptable to the NRC staff for con for promoting high functional reliab safety systems. Standard Review I identify Regulatory Guide 1.168 as systems (RTS) and for engineered (ESFAS) The Invensys PPS Replacement S (SVVP), 993754-1-802 does not po Invensys SVVP complies with IEEI reference table that explains how to of IEEE 1012-1998. Also, the Westinghouse/ALS 6116 Plan, does not provide a clear expl with IEEE 1012-1998. Please prov how the W/CSI SVVP implements	ulatory Guide (RG) 1.168, Revision 1, and Audits for Digital Computer Software r Power Plants," dated February 2004 cal and Electronics Engineers) 1012-1998, cation and Validation," and IEEE 1028- Reviews and Audits," with the exceptions f RG 1.168. RG 1.168 describes a method mplying with parts of the NRC's regulations ility and design quality in software used in Plan (SRP) Table 7-1 and Appendix 7.1-A SRP acceptance criteria for reactor trip safety features actuation systems oftware Verification and Validation Plan rovide a clear explanation of how the E 1012-1998. Please provide a cross he Invensys SVVP implements the criteria -00000 Diablo Canyon PPS Management anation of how the CSI SVVP complies vide a cross reference table that explains the criteria of IEEE 1012-1998.	New			

Marc	h 19, 12		DCPP PPS Open Item Summary Table	;		Page 23 of 25		
No	Src/RI	Issue Description	P&GE response:	Status	RAI No. (Date Sent)	RAI Response (Due Date)	Comments	
		PG&E response:				1	()	
		Westinghouse will provide an I	EEE-1012 compliance map by May 4, 2012 to					
		PG&E and PG&E will submit the	ne matrix to the staff by May 31, 2012.					
19	RS	Section 4.1.1 of the LAR stat	es that:	New				
		"The SSPS evaluates the signa	als and performs RTS and ESFAS functions to					
		described in FSAR [26] Chap	ar Occurrences and Design Basis Events					
		·····						
		however,						
		Chapter 15 of the DCPP FSAR	does not use the terms Abnormal Operational					
		Occurrence (AOO) or Design E	Basis Accident (DBE). Instead, the accident					
		analysis in chapter 15 identifies	s conditions as follows;					
		OPERATIONAL TRANSIENTS	j					
		CONDITION IL-FAULTS OF N	NUDERATE FREQUENCY					
		CONDITION III - INFREQUEN	T FAULTS					
L		CONDITION IV - LIVITING FA	<u>ULIO</u>			<u> </u>		

March 19, 12		DCPP PPS Open Item Summary Table					Page 24 of 25
No	Src/RI	Issue Description	P&GE response:	Status	RAI No. (Date Sent)	RAI Response (Due Date)	Comments
		As such, the statement that AC appears to be inaccurate. Plea Conditions described in FSAR Occurrences, and Design Basi	DO's and DBE's are described in the FSAR ase explain the correlation between the chapter 15 and the Abnormal Operational is Events described in the LAR.				
		PG&E response: IN PROGRE	ESS				

Marc	h 19, 12	DCPP PPS Open Item Summary Table					Page 25 of 25
Νο	Src/RI	Issue Description	P&GE response:	Status	RAI No. (Date Sent)	RAI Response (Due Date)	Comments
20	RS	 The system description provided in Section 4 of the LAR includes "functions performed by other protective systems at DCPP in addition to the PPS functions". In many cases, there is no explanation of what system is performing the functions described nor is there a clarification of whether the described functions are being performed by the PPS system. As an example, Section 4.1.16 describes a bypass function to support testing of the high-high containment pressure channel to meet requirements of IEEE 279 and IEEE 603. The description of this function does not however, state whether this latch feature is being implemented within the PPS system or in the SSPS. The staff needs to have a clear understanding of the functional scope of the PPS system being modified in order to make its regulatory compliance determinations. Please provide additional information such as PPS function diagrams to help the staff distinguish PPS functions from functions performed by other external systems. PG&E Response: IN PROGRESS 		New			The NRC could consider auditing the system Function Diagrams in lieu of having them submitted.
21	RA	Westinghouse/CSI document 6116-0000 Plan," states that the ALS-102 FPGA des System. Further, Section 5.3.3 states: "T requirements as possible." Please identify what document describes board.	5, "Diablo Canyon PPS System Test sign is changed for the DCPPS est as many of the ALS-102 the design verification test for this	New			
		PG&E response: The ALS-102 product subsystem-level te Innovations document 6116-70140, "Dial Design Specification". Document 6116-7 by TBD.	st verification will be covered in CS blo Canyon PPS System Test 70140 will be submitted to the NRC				

Please direct any inquiries to me at 301-415-1132 or at Joseph.Sebrosky@nrc.gov.

/RA/

Joseph M. Sebrosky, Senior Project Manager Plant Licensing Branch IV Division of Operating Reactor Licensing Office of Nuclear Reactor Regulation

`

Docket Nos. 50-275 and 50-323

Enclosures:

- 1. List of Attendees
- 2. Staff Identified Issues

cc w/encls: Distribution via Listserv

DISTRIBUTION: PUBLIC LPLIV Reading RidsAcrsAcnw_MailCTR Resource RidsNrrDeEicb Resource **RidsNrrDorl Resource** RidsNrrDorlLpl4 Resource RidsNrrLAJBurkhardt Resource RidsNrrPMDiabloCanyon Resource RidsOgcRp Resource RidsRgn4MailCenter Resource WMaier, RIV TWertz. NRR WKemper, NRR/DE/EICB RStattel, NRR/DE/EICB SMakor, RIV/DRS/EB2 LChang, EDO RIV

ADAMS Accession Nos. Meeting Notice ML120530074; Meeting Summary ML120900688 *per email

OFFICE	DORL/LPL4/PM	DORL/LPL4/LA	NRR/DE/EICB	DORL/LPL4/BC	DORL/LPL4/PM
NAME	JSebrosky	JBurkhardt	WKemper*	MMarkley (JSebrosky for)	JSebrosky
DATE	4/4/12	4/2/12	4/2/12	4/4/12	4/4/12

OFFICIAL RECORD COPY