

generation

mPower

Electrical Power Systems Overview

(Redacted)

February 1, 2012

© 2012 Babcock & Wilcox Nuclear Energy, Inc. All Rights Reserved. No part of this work may be published, translated, or reproduced in any form or by any means, or incorporated into any information retrieval system, without the written permission of Babcock & Wilcox Nuclear Energy, Inc.

- Purpose
 - Discuss AC & DC electrical power systems design features for the mPower reactor and applicability to the Standard Review Plan (SRP)
- Topics to be discussed
 - Simplified electrical single line diagram
 - AC Power System design & Equipment Layout
 - Standby Diesel Generators layout
 - DC/UPS Power System design & Equipment Layout
 - Island mode operation
 - SRP Applicability
 - NRC Informal Questions (10/11/11)

[

]

[

[

]

[CCI per Affidavit 4(a)-(d)]

[

]

[

]

[CCI per Affidavit 4(a)-(d)]

AC Equip. Layout RSB Annex

[

[CCI per Affidavit 4(a)-(d)]

[

]

AC Equip. Layout RSB Annex

[

[CCI per Affidavit 4(a)-(d)]

[

]

[

]

[CCI per Affidavit 4(a)-(d)]

[

]

[CCI per Affidavit 4(a)-(d)]

[

]

[CCI per Affidavit 4(a)-(d)]

DC/UPS Equip. Layout RSB Annex

[

]

[CCI per Affidavit 4(a)-(d)]

[

]

DC/UPS Equip. Layout RSB Annex

[

]

[CCI per Affidavit 4(a)-(d)]

generation
mPower

DC/UPS Equip. CR Air Supply System

[

]

[CCI per Affidavit 4(a)-(d)]

[

]

[CCI per Affidavit 4(a)-(d)]

[

[CCI per Affidavit 4(a)-(d)]

SRP Applicability

Section	Title	Remarks
8.1	ELECTRIC POWER - INTRODUCTION	
8.2	OFFSITE POWER SYSTEM	[
8.3.1	AC POWER SYSTEMS (ONSITE)	
8.3.2	DC POWER SYSTEMS (ONSITE)	
8.4	STATION BLACKOUT	

[CCI per Affidavit 4(a)-(d)]

[

]

[CCI per Affidavit 4(a)-(d)]

Electrical Design Questions to Support Staff Development of DSRS

1. In the event of a Loss of Off-site Power (LOOP) or other anticipated operational occurrences, is onsite AC power planned to be used (in the short term before 72 hrs) to support operation of decay heat removal, RCIPS, or other risk-significant functions? If so, please describe.

Response

[

] [CCI per Affidavit 4(a)-(d)]

2. A B&W presentation dated April 21, 2011, entitled “Design considerations for Fukushima-type Events,” identifies Auxiliary Power Units (APUs) located inside reactor building to recharge battery system in the event of an Station Blackout.
- a. Please provide a more detailed functional description of the APUs (type, number, function, the batteries they charge, etc.)
 - b. Are they in addition to the standby DGs?

Response

[

] [CCI per Affidavit 4(a)-(d)]

3. What is the total number of standby / backup electrical power generators (e.g., EDGs) that are included in the design, and are any of them considered to be risk significant?

Response

The standard design will be based upon a two unit facility. [

]

[CCI per Affidavit 4(a)-(d)]

4. Are backup/standby power sources shared between modules/units? If so, please describe.

Response

[

]

[CCI per Affidavit 4(a)-(d)]

5. Are AC and DC electrical support system components for RTNSS or non-safety-related but risk-significant SSCs (e.g., DHR pump), also designated as RTNSS or non-safety-related but risk significant? Please describe.

Response

The required support systems for RTNSS components are classified appropriately [

] [CCI per Affidavit 4(a)-(d)]

6. The April 21, 2011 B&W presentation also identifies a “*Long duration ‘station keeping’ 7+ Day battery supply]for plant monitoring/control.*” Please provide a more detailed functional description of this equipment

Response

[

]

[CCI per Affidavit 4(a)-(d)]