

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
US-APWR Subcommittee

Docket Number: (n/a)

Location: Rockville, Maryland

Date: March 22-23 2012

Work Order No.: NRC-1512

Pages 1-340

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1 UNITED STATES OF AMERICA

2 NUCLEAR REGULATORY COMMISSION

3 + + + + +

4 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

5 (ACRS)

6 + + + + +

7 US-APWR SUBCOMMITTEE

8 + + + + +

9 THURSDAY

10 MARCH 22, 2012

11 + + + + +

12 ROCKVILLE, MARYLAND

13 + + + + +

14 The Subcommittee met at the Nuclear
15 Regulatory Commission, Two White Flint North, Room
16 T2B1, 11545 Rockville Pike, at 8:30 a.m., John
17 Stetkar, Chairman, presiding.

18 SUBCOMMITTEE MEMBERS PRESENT:

19 JOHN W. STETKAR

20 SAID ABDEL-KHALIK

21 DENNIS C. BLEY

22 CHARLES H. BROWN, JR.

23 WILLIAM J. SHACK

24

25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 NRC STAFF PRESENT:

2 ILKA BERRIOS, Designated Federal Official

3 HOSSEIN HAMZEHEE

4 PAUL KALLAN

5 LARRY WHEELER

6 RAUL HERNANDEZ

7 GORDON CURRAN

8 EILEEN MCKENNA

9 ANGELO STUBBS

10 DAVID NOLD

11

12 ALSO PRESENT:

13 RYAN SPRENGEL

14 JAMES CURRY

15 YOSHIYUKI TANIGAWA

16 BRET BRICKNER

17 CHARLES BULLARD

18 NAOKI KAWATA

19 SHINJI KAWANAGO

20 HIROKI NISHIO

21 MOTOHISA KITAMORI

22 JUNYA HATTORI

23 KEVIN LYNN

24 MARC HOTCHKISS

25 HIROSHI HAMAMOTO

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

RONALD REYNOLDS
HIDEKI TANAKA
MASASHI ITO

NEAL R. GROSS
COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

T-A-B-L-E O-F C-O-N-T-E-N-T-S

Opening Remarks and Objectives,
 John Stetkar, ACRS5
 Staff Introduction
 Discussion of the US-APWR DCD Chapter 9 "Auxiliary
 Systems"7
 Continuation of the discussion of the US-APWR DCD
 Chapter 951
 Staff - Continuation of the discussion of th US-APWR
 DCD Chapter 9178

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

P-R-O-C-E-E-D-I-N-G-S

8:32 a.m.

CHAIR STETKAR: The meeting will now come to order. This is a meeting of United States Advanced Pressurized Water Reactor Subcommittee. I'm John Stetkar, Chairman of the Subcommittee meeting.

ACRS members in attendance are Dennis Bley, Said Abdel-Khalik, Bill Shack, and Charles Brown.

Ilka Berrios of the ACRS staff is the designated federal official.

The Subcommittee will review Chapter 9, Auxiliary Systems of the Safety Evaluation Report with Open Items associated with the US-APWR design certification application. We'll hear presentations from Mitsubishi Heavy Industries and the NRC staff. We have received no written comments or request for time to make oral statements from members of the public regarding today's meeting.

The Subcommittee will gather information, analyze relevant issues and facts and formulate proposed positions and actions as appropriate for deliberation by the full Committee.

The rules for participation in today's meeting have been announced as part of the notice of this meeting previously published in the Federal

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Register. Parts of this meeting may need to be closed
2 to the public to protect information proprietary to
3 Mitsubishi Heavy Industries or other parties.

4 I'm asking the NRC staff and the Applicant
5 to identify the need for closing the meeting before we
6 enter into such discussions, and to verify that only
7 people with a required clearance and need to know are
8 present.

9 A transcript of the meeting is being kept
10 and will be made available as stated in the Federal
11 Register notice. Therefore, we request that
12 participants in this meeting use the microphones
13 located throughout the meeting room when addressing
14 the Subcommittee. The participants should first
15 identify themselves and speak with sufficient clarity
16 and volume so that they may be readily heard.

17 First, regarding -- before we start, we
18 scheduled this meeting for two days because there's a
19 lot of material to cover. I wanted to make sure that
20 you had enough opportunity for discussions and
21 questions and understanding. I don't think we'll
22 finish today. I don't think that we will require all
23 day tomorrow.

24 I want to emphasize I don't want to keep
25 -- make sure there's enough time so don't rush to try

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 to finish today. If you need tomorrow morning, that's
2 fine.

3 I doubt that we'll run all day tomorrow if
4 we're kind of thinking of things so it's a little bit
5 difficult to schedule the timing with this volume of
6 material because you really don't know how much
7 discussion will be necessary. I didn't want to
8 artificially compress that discussion just by
9 scheduling it for one day. Keep that in mind and I
10 think everything will go okay.

11 We'll now proceed with the meeting. I
12 call upon Hossein Hamzehee.

13 MR. HAMZEHEE: Thank you, sir. Thank you
14 again. I think, as you said, we are ready for two
15 days, although our preference is to finish everything
16 today but the staff at MHI are available in case there
17 is a need for the second day.

18 With that I am going to turn it to Paul.
19 He's the Chapter PM.

20 MR. KALLAN: Hi. Good morning. My name
21 is Paul Kallan. I'm the Senior Project Manager and
22 also the Chapter PM for the US-APWR Chapter 9. I
23 would like to thank the Subcommittee for having us
24 here today. I would like to also thank MHI MNES for
25 being here and also for making their presentations.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 I would also like to thank staff for being here today.

2 This is the US-APWR DCD certification
3 which was submitted to Mitsubishi Heavy Industries on
4 December 31, 2007. We are currently on Revision 3
5 which was submitted March 31, 2011. We have taken
6 eight chapter to the ACRS which is 2, 16, 8, 13, 11,
7 12, 5, and 10 previously to the ACRS. It has gone
8 through the Subcommittee and full Committee. Although
9 there's two COLAs associated with this chapter, today
10 we are only going to present the DCD.

11 CHAIR STETKAR: Just for the record, parts
12 of the review of this are based on Interim Revision 4
13 of the DCD. Is that correct?

14 MR. KALLAN: Correct.

15 CHAIR STETKAR: Okay. Thanks.

16 MEMBER BROWN: Do we have that yet?

17 MS. BERRIOS: In the CD that I sent you.

18 MEMBER BROWN: I didn't get it.

19 MEMBER BLEY: It was surreptitious.

20 CHAIR STETKAR: It was a stealth
21 transmittal.

22 MEMBER BROWN: I only have Rev. 3. That's
23 why I asked. My Chapter 7 stuff is only Rev. 3 so --

24 CHAIR STETKAR: That's okay. This was
25 just -- the staff will explain it, I'm sure, when we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 come up. I just wanted to get on the record what it
2 is we're reviewing here.

3 With that, I'll turn it over to MHI.

4 MR. SPRENGEL: This is Ryan Sprengel with
5 MNES, DC licensing manager. Thank you all,
6 Subcommittee members. I think we've had many good
7 interactions in the past and look forward to hopefully
8 a lot of interactions this year. I think we've got a
9 lot of chapters getting ready to come through you guys
10 so we'll look for continued good interactions.

11 For today we are looking at Chapter 9, as
12 was mentioned. I want to touch on that real quick.
13 We are on DCD Chapter 3 -- Rev. 3, but we did do a
14 markup. We had a lot of changes through our
15 interactions with the staff and to facilitate looking
16 at all these changes we submitted a compilation and it
17 just showed a markup. It's what would become Rev. 4
18 but we have not submitted Rev. 4.

19 CHAIR STETKAR: You haven't, but just for
20 clarity what we'll hear today from the SER and what
21 we'll hear from you today is the status of the design
22 as of that markup Interim Rev. 4. Is that correct?

23 MR. SPRENGEL: That is correct.

24 CHAIR STETKAR: The only reason I want to
25 make that clear is because in at least the Component

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Cooling Water System there were substantive changes.

2 MR. SPRENGEL: Absolutely.

3 CHAIR STETKAR: We're going to be talking
4 the Interim Rev. 4 version of that.

5 MR. SPRENGEL: That is correct.

6 MEMBER BLEY: I wonder if it's possible
7 when you make your presentations to highlight the
8 things that have changed across that revision.

9 MR. SPRENGEL: I think that will be a
10 focus.

11 MEMBER BLEY: It might preclude some
12 questions.

13 MR. SPRENGEL: Yes. Agreed.

14 CHAIR STETKAR: If they don't, I'll try
15 because I compared the two.

16 MEMBER BLEY: Thank you.

17 MR. SPRENGEL: Okay. As you can see, we
18 brought many people to support many experts and we are
19 prepared for today and tomorrow so whatever you guys
20 need we are ready to support. Hopefully we don't go
21 into Saturday.

22 CHAIR STETKAR: We won't do that. I have
23 a flight Saturday morning.

24 MR. SPRENGEL: As we've done in the past,
25 if there is anything that we are not able to get back

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to you on today or tomorrow, we'll follow up in the
2 future with written responses.

3 For now I will go and turn it over to Jim
4 Curry.

5 MR. CURRY: Good morning. My name is Jim
6 Curry and we are representing Mitsubishi Energy
7 Systems and Mitsubishi Heavy Industries, the team here
8 today, to discuss Chapter 9, Auxiliary Water Systems.

9 As Mr. Prengel said, we appreciate the opportunity to
10 meet with the Subcommittee.

11 The MHI team today includes system
12 experts, contractors, licensing personnel, and members
13 of the MNES and MHI management team. Each Chapter 9
14 section, 9.1 through 9.5, will be represented by a
15 subset of this MHI team and the subset will be
16 primarily at this table or at the end of the table
17 over to my right.

18 There are also additional key folks who
19 are present in the audience and we can access
20 documentation on our servers as necessary to get the
21 best information for the Committee.

22 Today we plan to focus on Chapter 9
23 subsections that we believe would be of most interest
24 to the Committee. As you have heard, Chapter 9 covers
25 a spectrum of systems. Some systems are safety

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 related and many are not. We'll probably focus on
2 those that have safety-related implications and spend
3 less time on other subsections. However, the team
4 here today includes members that can speak to any
5 subsection.

6 The presentation materials that we are
7 going to go through have the same general format which
8 includes introductory slides with an acronym list and
9 the names of the folks at this table and the table to
10 my right, some summary information including
11 simplified system schematics, and a table of SER open
12 items and confirmation items.

13 We can give you the current status as we
14 see it if you need for those open items. We also have
15 some additional backup information slides which we may
16 use if needed. If it's acceptable to the Committee,
17 we plan to proceed in numerical order starting with
18 Section 9.1, Fuel Storage and Handling.

19 CHAIR STETKAR: That would be wonderful.

20 MR. CURRY: Good news. Off to a good
21 start. Okay. 9.1, as you know, is Fuel Storage and
22 Handling so I would like to introduce Naoki Kawata who
23 is here. Mr. Kawata is the deputy manager, MHI Water
24 Reactor Systems Engineering Section. He will be
25 supporting this presentation. I would also like to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 introduce Mr. Yoshiyuki Tanigawa. Mr. Tanigawa is an
2 engineer, MHI Plant Layout Engineering Section.

3 Then the next three folks are with Holtec
4 International who are the designers of our fuel racks
5 and they are here to support us; Mr. Thomas
6 Fitzpatrick, Mr. Charles Bullard. Mr. Fitzpatrick is
7 the project manager. Mr. Bullard is the manager of
8 the structural group so he'll be here to answer rack
9 structural questions. Mr. Bret Brickner who is the
10 criticality expert on the team.

11 The acronym list, as we talked about.
12 We'll be going through each of these subsections of
13 9.1 in order as indicated. Let's start with the
14 criticality safety of the new and spent fuel pool
15 storage. You may find it helpful to take a look at
16 the second slide in this, which is labeled Slide No.
17 5, the second technical slide.

18 In summary, the new and spent fuel storage
19 facilities are located in the fuel handling area of
20 the reactor building. The US-APWR has the containment
21 vessel, pre-stressed concrete containment vessel
22 surrounded by a reactor building. We call this the
23 fuel storage area.

24 CHAIR STETKAR: Jim, just be sure you
25 don't get too far away from the microphones. We need

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 it for the transcript. A lot of times it's easier if
2 you use your mouse to point to things.

3 MR. CURRY: Thank you.

4 CHAIR STETKAR: The microphones are pretty
5 sensitive but if you stray too far away, we have
6 problems.

7 MR. CURRY: Thank you, Mr. Chairman.
8 That's helpful.

9 Okay. So, in any event, the new and spent
10 fuel storage facilities again, as I said, are located
11 in the fuel-handling area of the reactor building.
12 The reactor building is seismic Category I. New fuel
13 is stored in low density racks. Spent fuel is stored
14 in moderate density racks. The new fuel is stored
15 dry. Spent fuel is stored in borated water.

16 In the new fuel storage pit, as we call
17 it, we have the capability for 180 fuel assemblies.
18 That corresponds to approximately one refueling batch,
19 normal refueling plus an additional 50 locations.

20 In the spent fuel area, spent fuel pit --
21 sorry. The spent fuel pit area we have the capacity
22 for 900 fuel assemblies which is about the amount of
23 spent fuel from 10 years of operation assuming a two-
24 year fuel cycle plus a full-core off-load.

25 CHAIR STETKAR: Jim.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. CURRY: Yes, sir.

2 CHAIR STETKAR: For configuration of
3 things, in the DCD that explains what you just said
4 pretty clearly, but it also mentions that there's a
5 rack with a capacity for 12 damaged fuel assemblies.
6 Where is that located?

7 MR. CURRY: The damaged fuel rack. Mr.
8 Tanigawa.

9 MR. TANIGAWA: Damaged fuel racks is
10 located in this area.

11 CHAIR STETKAR: Oh, okay. Okay. Because
12 the drawing showed the configuration of the spent fuel
13 racks, the 900. I didn't know whether that consumed
14 the entire volume for all practical purposes of the
15 spent fuel pit. It's over in one end of the spent
16 fuel pit. Thanks.

17 MR. CURRY: The cooling and water quality
18 of the spent fuel pit is maintained by the spent fuel
19 pool cooling -- spent fuel pit cooling and
20 purification system which we'll be discussing as part
21 of Subsection 9.1.3.

22 The new and spent fuel storage, as I
23 mentioned, these are in Category I structures designed
24 to withstand the design basis external event
25 conditions there defined in Chapter 2 of the DCD.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Spent fuel and new fuel racks are designed to maintain
2 subcriticality requirements consistent with 10 CFR
3 50.68 and we'll talk about that in a second.
4 Equipment could potentially damage fuel if it were to
5 fail is designed as seismic Category I. So sorry,
6 seismic Category II.

7 MEMBER BROWN: You're talking about the
8 cranes?

9 MR. CURRY: Yes, sir. Yes, sir.

10 The next couple of slides will kind of
11 summarize the criticality analysis and will also
12 summarize the structural requirements for the racks.

13 As I mentioned, criticality requirements
14 are specified in 10 CFR 50.68 so we meet those
15 requirements for the new fuel racks. New fuel racks
16 are stored -- new fuel is stored dry. Spent fuel
17 storage rack we do use soluble boron. Once again, we
18 comply with these requirements which are 10 CFR 50.68.

19 Kind of some key points of the analysis
20 conditions. The maximum enrichment 5 percent
21 specified in the regulation. The appropriate assembly
22 tolerances were considered in a criticality
23 evaluation. Credit is taken for a neutron absorption
24 in the racks. I think metallic is fundamentally what's
25 used here. And, of course, dimensions are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 appropriately considered.

2 New fuel storage is constructed of
3 stainless steel with the assumption of concrete
4 reflectors in the calculations. Spent fuel storage
5 rack stainless steel metamic.

6 MR. BRICKNER: There's no metamic in the
7 refuel.

8 MR. CURRY: Spent fuel?

9 MR. BRICKNER: Spent fuel.

10 MR. CURRY: Yes. Spent fuel, right, is
11 metamic, and the assumption of an infinite rack array
12 in the lateral direction.

13 MEMBER SHACK: With the metamic, that's a
14 naked aluminum, right?

15 MR. BRICKNER: It's a powder metallurgy.

16 MEMBER SHACK: It's a powder metallurgy
17 but, I mean, it's boron carbide and aluminum matrix.

18 MR. BRICKNER: Yes.

19 MEMBER SHACK: So it's essentially exposed
20 to the environment as unclad aluminum. There's no
21 stainless steel clad on this stuff.

22 MR. BRICKNER: There is a sheathing. It's
23 encapsulated in a sheathing but it's not sealed.

24 MEMBER BROWN: What do you mean by
25 sheathing?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. BRICKNER: There's a stainless steel
2 covering. The metamic is not mechanically fastened to
3 the rack structure.

4 MEMBER SHACK: But it's exposed to the
5 coolant.

6 MR. BRICKNER: It is. Correct.

7 MEMBER SHACK: And the pH of this stuff
8 is? The pH limits in the pool is?

9 CHAIR STETKAR: It's 4,000 ppm boric acid.

10 MEMBER SHACK: Whatever that is.

11 MR. BRICKNER: I can't answer the pH
12 levels in the pool.

13 MR. CURRY: If you give us a second, we'll
14 look that up for you and get back to you.

15 MEMBER SHACK: Fine. It just seems like
16 you're in a corrosive region for aluminum.

17 MR. BULLARD: There is a topical report
18 that's been submitted to the NRC specifically on the
19 use of metamic and spent fuel rack applications that I
20 would point you to. It has been used and is installed
21 in many spent fuel pools.

22 CHAIR STETKAR: At this types of pH
23 levels, though? A lot of spent fuel pools don't quite
24 have this boron concentration.

25 MR. BULLARD: That I don't know. I cannot

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 confirm your answer.

2 MEMBER BROWN: Does the sheathing really
3 encapsulate the metamic or is it -- you said it's not
4 bonded.

5 MR. BULLARD: It's not sealed so the
6 sheathing covers the metamic and then the sheathing
7 itself is stainless steel like the rack so wall
8 material. That sheathing is fillet-welded and spot-
9 welded along its perimeter. There's a flange.

10 MEMBER BROWN: But water can get between
11 it and the --

12 MR. BULLARD: But there are openings at
13 the corners where there is access where the coolant
14 can get beneath the sheathing. Metamic is also used
15 in dry storage cask applications as well.

16 MR. CURRY: So we'll take as an action the
17 pH requirements for the pool and see if we can get
18 back to you on that.

19 CHAIR STETKAR: Do you happen -- the
20 topical report had the same type of configuration open
21 where the metamic is exposed to the coolant. It
22 wasn't a sealed --

23 MR. BULLARD: Seam rack construction.

24 CHAIR STETKAR: Seam rack construction.

25 MEMBER SHACK: Now, do you sometimes

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 anodize this or is this always used in an untreated
2 condition? Here it says it will not be anodized so it
3 sort of sounds as though that maybe sometimes you do.

4 MR. BULLARD: I would have to confirm
5 that. I think the condition that is used here --

6 MEMBER SHACK: Is the standard condition?

7 MR. BULLARD: -- is the standard
8 condition. I'm not aware of any applications where
9 it's anodized.

10 MR. CURRY: All right. I would propose we
11 move onto the structural requirements. The design and
12 stress analysis of all the racks is consistent with
13 Reg Guide 1.29 for seismic design. The load
14 combinations, as indicated, are consistent with SRP
15 Section 3.8.4.

16 The racks are free-standing. They can
17 withstand a maximum uplift force based on the lifting
18 capacity of the suspension hoist and the refuel
19 machine which I think is 4,400 pounds. Of course, we
20 can maintain a subcritical array in the event of any
21 fuel handling accident. That's kind of a summary of
22 the structural piece. Does anyone have any questions
23 on the structural design?

24 CHAIR STETKAR: No, I think I'll wait
25 until we bring up slides -- a few slides ahead before

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I ask a couple of questions. Continue.

2 MR. CURRY: Okay. We have some
3 confirmatory items and one open item, I think, which
4 we're working on with the staff. We recently received
5 an RAI response March 5th so we'll be replying to that
6 within 60 days. I think that's fundamentally what we
7 had to say about new and spent fuel storage.

8 CHAIR STETKAR: Let me ask one -- I was
9 trying to think about the most appropriate place to
10 ask it and I can't decide so I'll ask it now. You
11 might want to, just for reference, bring up your slide
12 No. -- okay. I've lost track here. No. 15, I think,
13 unless you have a better one. There's a figure in the
14 CDC that is Figure 9.1.4-2 that a bit better
15 illustrates the question I was going to ask, but this
16 one might do.

17 The question is, and it's difficult to
18 look at this elevation view and the plan view at the
19 same time. There are -- in this elevation view there
20 are weir walls. There are gates that separate the
21 spent fuel pit from the transfer canal and irrigates
22 that separate the cask pit and the fuel inspection pit
23 from the transfer canal.

24 Those weir walls, the gates, as best as I
25 can tell the bottom of the slot of the gate, in other

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 words if you remove the gate, the bottom of that slot
2 appears to be about, and I didn't have all of the
3 dimensions available, but about two-and-a-half feet
4 roughly above the top of the active fuel. It might be
5 a little bit more, might be a little bit less. I was
6 curious whether you know what that elevation
7 difference is.

8 MR. CURRY: Let me confirm, but in all
9 cases we really have, I think, 11.1 feet above the top
10 of the fuel but let me confirm with Mr. Tanigawa.

11 CHAIR STETKAR: In other words, the reason
12 I brought up this elevation if, for example, the top
13 of the gray area was the bottom of that gate as if
14 this is shown with the gates removed, the water level
15 at that elevation, I think, is about 2.5 feet above
16 the top of active fuel.

17 I don't know exactly where the top of
18 active fuel is so it might be 2.75 feet or something
19 like that. The key is it's not 12 feet. I just
20 wanted to confirm that elevation because if I'm wrong,
21 then some of the questions, follow-on questions, that
22 I was going to ask are less significant.

23 MEMBER BROWN: The SER says 10 feet.

24 MR. CURRY: I think that's the minimum
25 requirement.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SHACK: That's the number I sort of
2 had in my head.

3 CHAIR STETKAR: That's fine. That's
4 minimum required water level for shielding and
5 cooling.

6 MEMBER SHACK: Since there was a gate
7 failure, the SFP will maintain 10 feet.

8 CHAIR STETKAR: I want to ask what the
9 elevation of the bottom of the slot is.

10 MR. CURRY: Okay, Mr. Chairman. We have
11 that slide of figure 9.1.4-2. Look on that figure.
12 Unfortunately, we don't have it up on the screen here
13 for everyone to see.

14 CHAIR STETKAR: The elevation of what it
15 says weir is 47 feet 10 inches. The bottom of the
16 spent fuel pool is 30 feet one inch. The height of a
17 fuel assembly, if you look at the assembly that's in
18 the grappling hook there, is about 15 feet roughly.
19 If I add 15 feet to 30 feet, I come up to 45 feet
20 which gives me about 2.5 feet. That's sort of what I
21 was estimating but I didn't know if I was
22 misinterpreting something on this drawing.

23 MR. CURRY: Your real concern is if we had
24 a failure of that gate, we'd only have two feet above.

25 CHAIR STETKAR: Not a failure. My concern

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 is if I have the dimension -- I want to make sure I
2 have the dimensions correct first. Let me -- perhaps
3 you can study the drawings and get back to keep the
4 discussion going. Here's the genesis of my question.

5 I understand basic refueling operations.
6 I understand fuel movements. I understand minimum
7 pool water levels. I understand anti-siphon devices.

8 I kind of understand all of those things. I also
9 know that there can be failures that may occur. I'm
10 not saying anything about the probability of those
11 failures.

12 There can be failures that may occur while
13 the weir gates are removed that could conceivably
14 drain the spent fuel pool level down to the height of
15 that weir wall, whatever that is. The questions that
16 I had, if those -- have you looked at -- do you have
17 any information about the time until boiling would
18 occur if you were drained to that level and the time
19 until fuel uncovering would start if drained to that
20 level?

21 Because you've uncovered the cooling water
22 -- you know, the cooling system suction lines are much
23 higher than that. Basically once you drain down to
24 that level the only cooling you have available is
25 through some alternate makeup supply and times to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 boil-off.

2 If you have information about starting
3 from that level, the time to reach boiling and the
4 time to uncover -- to start uncovering of the fuel, or
5 more accurately the time to start damaging the fuel
6 because just fuel uncovering in this configuration won't
7 necessarily start damage. I'm interested in those
8 times. It's a way to sense under kind of the most
9 extreme conditions what kind of time margins we have
10 available.

11 MR. CURRY: We do have information on the
12 time to boil which given loss of all spent fuel pool
13 cooling.

14 CHAIR STETKAR: But starting at the
15 initial --

16 MR. CURRY: Right. But I don't have it
17 starting at the level that you're talking about. I
18 think what we need to do is follow up on your
19 suggestion and let us take a look at this figure and
20 make sure we can give you a good answer on the
21 potential water level given the failure -- you're
22 postulating a failure of this.

23 CHAIR STETKAR: It would require some
24 drain-down condition. As I said, at the moment I
25 don't want to enter into probabilities of these things

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 happening. I'm just trying to get a sense of what the
2 margins might be and what sort of times are available.

3 Don't necessarily read anything more into this than
4 simply trying to understand what those times and
5 margins are.

6 MR. CURRY: From this particularly
7 configuration that you're referring to?

8 CHAIR STETKAR: Level at the weir.

9 MR. CURRY: Right.

10 CHAIR STETKAR: Whatever the water volume
11 is.

12 MR. CURRY: Okay.

13 CHAIR STETKAR: And as kind of a related
14 question to that, we may get into a little bit more of
15 the systems in the coming slides here but this is
16 useful. Do you know whether the fuel transfer tube
17 has a drain line from it? I couldn't find any
18 detailed information.

19 I'll tell you, my experience is some of
20 them do and some of them don't. It's kind of a
21 design-specific issue. That's why I ask. Is there a
22 drain line connection to the bottom of the transfer
23 tube or is this simply a tube?

24 MR. CURRY: One moment. No, the fuel
25 transfer canister. That's really your question.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: Well, the fuel transfer --
2 again, if you've got that 9.1.4-2 slide, I'm talking
3 about the tube itself that goes through the wall
4 between the transfer canal and the refueling cavity,
5 the tube that the little car goes through.

6 As I said, some plant designs I've seen
7 have a drain line in that transfer tube connection and
8 many plants don't. It doesn't show on this 9.1.4-2 but
9 that's not the purpose of this figure. The purpose of
10 this figure is just to show the general configuration.

11 I was curious about is there a drain line. I don't
12 need the answer right now. If you don't have it, just
13 take it.

14 The other questions that I had about
15 possibly drain lines is are there drain lines from the
16 three volumes that you show on the right-hand side of
17 this figure, in particular a drain line from the
18 transfer canal, a drain line from the cask -- the pit,
19 and a drain line from the fuel inspection pit. I'm
20 assuming that there are because you need to drain
21 those somehow usually.

22 MR. CURRY: Okay. We'd like to confirm
23 that answer.

24 CHAIR STETKAR: As long as -- when you go
25 back I'm interested in are there drain lines, yes or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 no, and, if there are drain lines, how large are they
2 in terms of just size.

3 MR. CURRY: Yes, sir. We'll look at it in
4 more detail.

5 CHAIR STETKAR: That's fine. The purpose
6 of these meetings is to raise questions, as many as we
7 can get answered during the meeting. That's good for
8 everyone. If we can't get them answered, you know,
9 they're take-aways.

10 Thank you. Oh, one other question. Some
11 of these questions are basic configuration questions
12 that I had. This drawing -- just a simple question.
13 I think I know the answer to this. I just want to
14 confirm it. On Figure 9.1.3-1 of the DCD, it's the
15 drawing -- it's essentially the DCD drawing of what
16 you have on the screen here.

17 The containment spray RHR cooling line
18 suction elevations on that drawing are shown lower
19 than the spent fuel pit cooling suction lines at a
20 lower elevation. I didn't know whether that's
21 actually the case or whether it's just the way to show
22 both suction lines on the same drawing if they are at
23 the same elevation.

24 My question is are the containment spray
25 RHR suction lines located at the same elevation as the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 spent fuel pit suction lines? I found a lot of
2 information in the DCD about the elevation of the
3 spent fuel pit suction lines. It may just be an
4 artifact of the way that drawing was put together to
5 show the two of them.

6 MR. CURRY: Mr. Kawata.

7 MR. KAWATA: Yes. This is Naoki Kawata.
8 Section related to containment spray RHR pump is same
9 as spent fuel pit suction lines.

10 CHAIR STETKAR: Thank you. That helps.
11 Thank you. With that I think now I'm pretty happy.
12 You can start talking about the cooling system.

13 MR. CURRY: Okay. Thank you. All right.

14 I think we understand we need to do a little research
15 and we'll get back to you on those issues that you
16 cited.

17 I think now we want to go to 9.1.3 and
18 perhaps -- just to confirm with the Committee, our
19 Holtec folks, structural criticality, we are going to
20 replace them at this table at the moment, if the
21 Committee has no objection, and talk from a system
22 level perspective. Mr. Kawata will join us at this
23 table.

24 Okay. As we mentioned before, Mr. Kawata
25 is the deputy manager, MHI Water Reactor Systems

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Engineering Section. Let us talk about the SFPCS,
2 Spent Fuel Pit Cooling and Purification System. We've
3 already taken a peek at the slide that we'll be
4 referring to.

5 Two redundant cooling and purification
6 trains. Fundamentally the system has a safety-related
7 function and a non-safety-related function. Safety-
8 related function is the cooling function. The non-
9 safety-related function is the purification and
10 cleanup function.

11 Each train includes a pump, heat
12 exchanger, a plate-type heat exchanger, a filter, and
13 a demineralizer. They can be powered from our Class
14 1E sources. Obviously the SFPCS removes heat
15 generated by spent fuel assemblies and it purifies
16 water for several sources including the RWSP and
17 refueling water storage auxiliary tanks.

18 Again, we need to follow up on your
19 question from earlier but the piping and dates are
20 arranged so that a failure will not result in a level
21 less than 11.1 feet above the top of the assembly. We
22 do have a seismic makeup source from the RWSP and the
23 emergency feed-water pits.

24 The emergency feed-water pit could be a
25 gravity-feed source. The design capability of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 system is that the trains in conjunction with two
2 trains of the RHR we can maintain spent fuel pool
3 temperature below 120 degrees even with a full core
4 off-load.

5 CHAIR STETKAR: The seismic we qualified,
6 the makeup is from the fuel and water storage pit.
7 Right?

8 MR. CURRY: That is a seismically
9 qualified source.

10 CHAIR STETKAR: And that's the only one.
11 Right?

12 MR. CURRY: No. The emergency feedwater
13 it is also a seismic one.

14 CHAIR STETKAR: The pit is qualified, the
15 piping isn't. In an earthquake the pit may remain
16 full of water. The pipe in between may be broken so
17 it's hard to figure out how to get water from point A
18 to point B.

19 MR. CURRY: Right.

20 CHAIR STETKAR: It's my understanding that
21 the connecting pipe from the EFP, the emergency
22 feedwater pit, to this connection that's shown up here
23 is not seismically qualified. Is that correct?

24 MR. KAWATA: Yes, that is correct because
25 SRP is second water source, the makeup water source.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 It is not seismic.

2 CHAIR STETKAR: I just want to make sure
3 that I understood that -- I understand that the line
4 that you show coming from the RWSP recirculation pump
5 is fully qualified all the way, and that the other
6 sources from -- although the EFW pit itself is a
7 seismic structural -- structurally seismically
8 qualified, the piping between those is not, as is not
9 the demineralized water supply. I think there is an
10 alternate even from the Fire Protection System you can
11 pipe in somehow. You do have one seismically
12 qualified from the RWSP.

13 MR. CURRY: Yes, sir.

14 CHAIR STETKAR: Fully qualified the whole
15 length. Okay.

16 MR. CURRY: So you see the schematic here.
17 I think one of the members mentioned earlier we were
18 referring to Interim Rev. 4. What that really was is
19 a response to RAIs so the schematic here shows the
20 isolation of the non-safety portion which is indicated
21 by the equipment classification from 3 to N. This
22 shows only a single valve but we replaced that in
23 response to an RAI with double-valve isolation. On
24 the supply side automatically closed valves, check
25 valves.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIR STETKAR: And they are automatically
2 closed valves now?

3 MR. CURRY: Yes, sir.

4 CHAIR STETKAR: Yes, sir.

5 MR. CURRY: Low-low spent fuel pool level.

6 CHAIR STETKAR: Low-low spent fuel pool
7 level. Okay. Is that true?

8 MR. CURRY: The spent fuel pit level, yes.

9 CHAIR STETKAR: Terminology. SFP is
10 always spent fuel pool to me so you'll have to excuse
11 me.

12 MR. CURRY: I understand.

13 CHAIR STETKAR: That's interesting because
14 that still makes my question relevant. The spent fuel
15 pit demineralizers, as is shown on this drawing, can
16 be aligned for cleanup of the refueling water storage
17 pit. The line is coming in at the top. You go
18 through the demineralizer and go back out to the
19 refueling water storage pit recirculation pump --
20 pumps, plural.

21 If you're aligned in a refueling water
22 storage pit cleanup mode so that you have one or, in
23 the principle, it could be both of the demineralizers
24 aligned to the refueling water storage pit, and you
25 have a break in this section of the system, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 nonseismically-qualified section of the system, how do
2 you isolate that break and prevent the refueling water
3 storage pit from draining down into the fuel building?

4 MR. CURRY: One moment.

5 CHAIR STETKAR: When the valves are manual
6 I was going to ask where the scuba tanks are but since
7 they are automatic, I can ask other questions.

8 Jim, in the interest of time, I mean, you
9 know, you guys can discuss this during the break or
10 lunchtime.

11 MR. CURRY: Thank you, sir.

12 CHAIR STETKAR: We have, you know, at
13 least all day today and probably until tomorrow to
14 scheduled for the meeting. Even if you want to take
15 some of these away and even discuss them this evening
16 if we go into tomorrow, we can kind of cleanup loose
17 ends that way.

18 MR. CURRY: Thank you, sir. We appreciate
19 it.

20 CHAIR STETKAR: I'm sure we'll have time.
21 There is also the danger of trying to answer
22 questions on the fly sometimes because you may not get
23 the right information on the record. Since everything
24 is on the record, it's good to have the information
25 correct.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. CURRY: Yes, sir.

2 CHAIR STETKAR: As you're thinking about
3 that in terms of to kind of follow along just so you
4 have the entire notion of what the question was going
5 to be, the question is how will it be isolated if
6 you're taking credit for manual isolation somehow,
7 it's important to understand where those valves are
8 located.

9 For example, if you do get flooding in a
10 compartment and the valves are under water, it's
11 pretty difficult for somebody to operate those valves
12 manually. Even if they're automatic isolation valves,
13 if they are in the flooded compartment, they may not
14 operate. I would like to know physically where those
15 valves are.

16 If they are in the same compartment with
17 the nonqualified piping that could be broken, they may
18 be submerged in a flood which could make it fairly
19 difficult to isolate under either condition.

20 I mean, whether it's spent fuel pit or the
21 RWSP. Also to kind of follow that line, if you had
22 some estimate from at least operating experience, is
23 this configuration similar to plants that are
24 currently operating in Japan in terms of the spent
25 fuel pit cooling and cleanup and connection to an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 RWSP?

2 MR. KAWATA: It is similar.

3 CHAIR STETKAR: It is similar? Okay. If
4 you had some information about how frequently the
5 spent fuel pit demineralizers are aligned for cleaning
6 the RWSP, I mean, is it something that's done two days
7 every month or is it only done during preparations for
8 refueling?

9 That type of information would also help
10 in terms of understanding if you are vulnerable to a
11 break in this location that could be connected to the
12 RWSP what fraction of the year, at least from actual
13 operating experience. That I'm sure you won't be able
14 to have in terms of time for this meeting. Those were
15 all sort of subsidiary questions to the first issue.

16 Thank you.

17 MR. CURRY: All right. Well, I think
18 basically we've kind of summarized the system just
19 to --

20 MEMBER BROWN: If you're done, I'm not
21 quite finished yet, I guess. You did address
22 instrumentation when you talked about this. Looking
23 at the DCD and then the SER as well, I didn't find any
24 real definition but it appeared that there was no
25 definition of how many level and/or temperature

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 sensors you have installed in the spent fuel pool.

2 The drawing you reflect, if you take the
3 one out of the DCD, gave the impression that there
4 were two level sensors but only one temperature
5 sensor. There's only one little stalk in there.
6 There's two things off of it but I don't know what --
7 I don't know the convention for that particular symbol
8 as to how many they are.

9 The second question associated with that
10 relative to temperature is if you've only got one and
11 it's only in one place, how do you know that's
12 representative of the overall bulk temperature in the
13 spent fuel pool? I often try to look at the flow
14 rates and I couldn't tell what the flow rates were.
15 There were numbers like 200 or 300 GPM and then I saw
16 the pumps were for 3,000 GPM or some large number like
17 that.

18 I'm an electrical guy so I couldn't relate
19 to what the actual requirements were. Obviously if
20 there's some flow, but I don't know what that is to
21 maintain a reasonable uniform temperature throughout
22 the spent fuel pool.

23 The question that falls from that is if
24 you lose power and you don't have any flow, how do you
25 know you don't have one part of the pool since the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 fuel is not all uniformly hot? Some of it is older
2 than newer spent fuel. How do you know you're not
3 hotter in some locations you could be damaging than
4 you have in another?

5 MR. CURRY: Let's start with the
6 instrumentation piece of that, the leveling
7 temperature indication.

8 MR. KAWATA: No, we have two temperature
9 gauge.

10 MEMBER BROWN: You have two temperatures
11 and two levels. Is there an RAI? I don't have the
12 number for that. I didn't find it. I presume you all
13 could tell me what the RAI is looking at that where
14 they changed their design for that. I don't want it
15 right now. It's just a matter of --

16 MR. HAMZEHEE: When the staff gets here
17 we'll try to get you the RAI number for that.

18 MEMBER BROWN: Then we can look at it and
19 see what it is. Also, the location relative to the
20 overall one end of the pool vice the other. Then
21 maybe if somehow you can address if there was no
22 power.

23 Has somebody done an analysis that natural
24 circulation is going to maintain a temperature of
25 uniformity or are you going to have a big disparity

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 from one point to another? Again, if it's not quick,
2 I don't want to drag us. This is just a question that
3 does not have to be answered right now.

4 MR. CURRY: Okay. We can look that up
5 then.

6 MEMBER BROWN: I don't want to drag the
7 meeting out while everybody looks the thing up.

8 MR. CURRY: We'll see what we can do.

9 MEMBER BROWN: The second question --
10 another question associated with that. What are the
11 types? Are they continuous measurements for
12 temperature or are they just a high and a low single-
13 point measurements to say, "Hey, look. I'm too high,"
14 and, therefore, I tell somebody I got an alarm, or do
15 I have a continuous readout on it? The same thing
16 goes for the level.

17 Are they continuous or just a pressure
18 switch type of arrangement which just says it's too
19 low because I don't have a certain pressure? That's
20 the second part to go along with that. That can be
21 answered, again, at the same time that you answer the
22 other one. Thank you.

23 MR. KAWATA: I understand.

24 MR. CURRY: All right. We would -- if
25 there are no other questions --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: Yeah, there are. You'll
2 learn. Related to -- the reason I wanted you to keep
3 the drawing up there is I had a couple of other
4 questions about the system and go back to the makeup.

5 There are statements in the DCD about the seismically
6 qualified makeup from the refueling water storage pit
7 recirculation pumps. That is the qualified makeup
8 supply.

9 Are the -- I couldn't find much
10 information about the RWSP recirculation pumps in the
11 DCD. There is a drawing that shows the configuration
12 of the piping and so forth and there's a discussion of
13 the containment isolation valves for them and things
14 like that.

15 In particular, I went through the
16 electrical load list in Chapter 8 and I couldn't find
17 the power supplies for those pumps. Are they powered
18 from Class 1E electrical buses or are they non-Class
19 1E power supplies?

20 MR. KAWATA: Yes.

21 CHAIR STETKAR: They are? Do you know
22 what buses they are supplied from? I couldn't find
23 them.

24 MR. KAWATA: The table shows --

25 CHAIR STETKAR: If it's in the DCD, just

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 point me to the place in the DCD. I probably missed
2 it.

3 Just identify yourself for the record.

4 MR. KAWANAGO: Shinji Kawanago from MNES.

5 Basically that's in the pump and the power supply
6 from the Class 1E load center. It's a roll bore
7 gauge. It's a full load center so you cannot find --

8 CHAIR STETKAR: Oh, it's from an MCC down
9 below the load center? Okay. Because I looked at the
10 load centers and I couldn't find them. Thank you.
11 Thank you. That answers basically that question. In
12 the interest of keeping us going, I have pages of
13 things here but I'm a slow reader and I think I got
14 most of the information I wanted. I'll stop holding
15 you up.

16 MR. CURRY: No problem.

17 All right. We would propose moving to
18 light load handling system.

19 CHAIR STETKAR: Oh, I did -- I'm sorry.
20 I'm trying to look ahead in your slides to see what
21 the topics are and get my babbling into the process at
22 the appropriate time. Since you're going to the light
23 load handling system, I wanted to kind of get the
24 questions that I had about not only the cooling system
25 configuration but some of the cooling system success

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 criteria. This is just a question. As I understand
2 it, your refueling is that basically it's a two-year
3 fuel cycle and you replace about half the core. Is
4 that right?

5 MR. CURRY: About 130.

6 CHAIR STETKAR: One third?

7 MR. CURRY: 130.

8 CHAIR STETKAR: Oh, yeah, 130 elements.
9 There are statements in the DCD about heat loads
10 related to normal -- either a normal refueling or a
11 full core off-load. I understand that the cooling
12 system capacity is based on full 10-year complement of
13 spent fuel in the pool with a full core off-load so
14 I'm not questioning that.

15 I was just curious is it normal practice
16 in similar plants in Japan when you do a refueling to
17 full off-load the core? Many plants in the U.S. do
18 that. They do a full core off-load. It's just a lot
19 easier.

20 It gives you more flexibility during the
21 outage because there's no full in the core and it's a
22 lot easier to move the fuel back in. I was curious
23 whether that's a similar practice in Japan when you do
24 a refueling. Do you do a full core off-load and then
25 reload the core, or do you only off-load the 130

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 elements and do a fuel shuffle?

2 MR. KAWATA: In Japan usually a full core
3 off-load.

4 CHAIR STETKAR: Okay. So essentially in a
5 normal refueling outage we'll have the full core in
6 the spent fuel pool for some number of days during
7 that outage so the full core off-load is actually the
8 normal refueling outage. That's basically what I
9 wanted to get on the record. Thank you.

10 MR. CURRY: I'm slower and slower to turn
11 the slides.

12 CHAIR STETKAR: This is an ACRS
13 Subcommittee. Often times we spend a lot of time with
14 just blank screens in front of us.

15 MR. CURRY: 9.1.4 Light Load Handling
16 System. Basically there are two cranes involved in
17 this system, two hoists; the refueling machine and
18 spent fuel handling machine. They are shown on these
19 -- on your following schematic.

20 The only safety-related function is really
21 the isolation of the fuel transfer tube for
22 containment purposes. The permanent cavity seal is
23 used to retain water in the refueling cavity during
24 refueling. The system is designed to meet the
25 referenced ANSI/ANS standard. As we talked about,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 subcriticality is maintained even if the pool was
2 flooded with unborated water.

3 We would go to Heavy Load Handling System.

4 CHAIR STETKAR: Okay. I was reading my
5 notes. Can you go back to Slide 20?

6 MR. CURRY: Slide 20?

7 CHAIR STETKAR: Yeah. Maybe you can help
8 me out. The DCD discusses -- this is the rapid cavity
9 seal. The DCD discusses a leakage detection system
10 for the cavity seal but I got -- there was not a
11 drawing or a very clear discussion of that leakage
12 detection system.

13 In some places I got the impression that
14 the leakage detection system was actually just
15 monitoring of level in the refueling cavity. I don't
16 know whether this drawing shows it or not. Is there a
17 separate leakage detection system that collects
18 leakage through the deal?

19 MR. CURRY: Directly under the seal?

20 CHAIR STETKAR: Yes, directly under the
21 seal. If there is, where is it?

22 MR. CURRY: I think if we could blow up
23 this slide --

24 CHAIR STETKAR: We can see it pretty well.

25 MR. CURRY: Mr. Tanigawa-san, just to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 confirm, leakage detection system underneath the
2 permanent cavity seal. Correct? Yes, there is.

3 CHAIR STETKAR: There is? Okay. Is it
4 just a set of channels? I don't care too much about
5 the design but there is a separate under the seal some
6 sort of collection system that you can monitor for
7 level or flow?

8 MR. CURRY: Through the ceiling.

9 CHAIR STETKAR: Leakage through the
10 ceiling. That's good. That's basically what I was
11 trying to confirm. In some of the discussion I kind
12 of got the incorrect impression that -- there was
13 discussions about level in the spent fuel pit is
14 monitored and alarmed in the control.

15 The refueling cavity is monitored and
16 alarmed in the control room and the operators will
17 have time to align makeup which is all true, but it's
18 not the same as a leakage detection system. Thank
19 you. Go to Heavy Load.

20 MR. CURRY: Okay. The Overhead Heavy Load
21 Handling System. Fundamentally, again, two cranes,
22 the Polar Crane and the Spent Fuel Cask Handling Crane
23 fall under this scope. These cranes are non-safety
24 related seismic II, single-failure-proof consistent
25 with NUREG-0554 requirements. Of course, we have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 limitations on the crane movements.

2 CHAIR STETKAR: Can you go back to where
3 you show the plan view of the fuel building. You have
4 a couple of slides that show that. There. The
5 cask -- the spent fuel cask, whatever it's called --
6 crane. I'll call it crane -- can operate over the
7 right-hand side of this figure. There are some
8 drawings in the DCD that are pretty good that show
9 normal routes of that crane.

10 My question was can it physically move
11 over the spent fuel pit? I understand that it's not
12 normally required to do that but, for example, do the
13 crane rails for that crane extend to the left of the
14 center line of the transfer canal over the spent fuel
15 pit? Is it physically possible to move that crane
16 over -- be careful of the paper with the --

17 MR. TANIGAWA: I'm sorry.

18 CHAIR STETKAR: -- over the spent fuel pit
19 or is it physically limited to only the right-hand
20 side of this drawing?

21 MR. TANIGAWA: Spent fuel cannot extend
22 over the spent fuel pit physically and operate.

23 CHAIR STETKAR: That's all that matters.
24 Thank you.

25 I'll ask the staff about the other one.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Okay. Thank you.

2 MR. CURRY: I think that is fundamentally
3 what we had to say about the Overhead Heavy Load
4 Handling System. We have one open item which we're
5 working on with the staff.

6 CHAIR STETKAR: Let me -- you'll have to
7 excuse me. I have paper all over the place and I'm
8 trying to read my notes. The spent fuel cask handling
9 crane there is a discussion in the DCD that
10 specifically notes that the polar crane in the
11 containment has seismic restraints that prevent the
12 crane from coming off the rails.

13 In other words, there are seismic
14 restraints that prevent the crane from tipping and
15 sliding off the rails. There was no mention of a
16 similar seismic restraint on the spent fuel cask
17 crane. I was curious whether that crane has a similar
18 restraint to prevent lateral motion of the crane or
19 tipping and sliding off the rails.

20 I didn't have drawings of that crane so I
21 didn't know how it's configured. I don't even know
22 what the rails look like. Since it wasn't mentioned
23 and it was mentioned for the polar crane, I was
24 curious whether it exist.

25 MR. CURRY: Well, it is seismic II but let

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 us look.

2 CHAIR STETKAR: Even though it's seismic
3 II, it's kind of an additional confidence about
4 lateral motion and things like that.

5 MR. CURRY: One moment.

6 CHAIR STETKAR: Okay.

7 MR. CURRY: We would like to take that as
8 an item and --

9 CHAIR STETKAR: That's fine. Understand
10 fully.

11 MR. CURRY: I think that's all we have,
12 sir, on 9.1, in this case, the Overhead Load Handling
13 System. That concludes our presentation on 9.1.j

14 CHAIR STETKAR: Do any of the members have
15 any questions about -- any further questions about
16 spent fuel pit? Heavy load, light load handling? I
17 think we're scheduled to have a break at 10:00 but I
18 don't want to -- you look concerned.

19 MEMBER BLEY: Well, I've been hanging on
20 one thing since the beginning with the heavy boron
21 concentration in the water. I know we don't have
22 emergency procedures or SAMGs as yet but what I've
23 been thinking about is -- I looked through the PRA and
24 the PRA dismisses everything about the spent fuel pool
25 for reasons stated.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 If there should be something in an
2 external event that manages to somehow drain the water
3 lower than the design would let it drain, what
4 capabilities for refilling it and maintaining boron
5 exist? If you didn't maintain the boron, is there any
6 analysis of what would happen anywhere in the DCD? I
7 looked all over it and I couldn't find anything.

8 CHAIR STETKAR: We'll let them answer.

9 MEMBER BLEY: It looked like you were
10 waving your arms.

11 CHAIR STETKAR: No, I thought I found
12 something but I thought it's probably better for them
13 to --

14 MR. KAWATA: We can provide additional
15 boron water.

16 CHAIR STETKAR: Well, I think the question
17 is, you know, back to the criticality stuff can you
18 achieve criticality? What's the boron level in the
19 spent fuel pit that's required to prevent criticality?

20 Right, Dennis?

21 MEMBER BLEY: That's right. The kind of
22 thing I'm worried about it's certainly beyond the
23 design basis of that. We need to look harder and
24 harder at those.

25 CHAIR STETKAR: If you couldn't get

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 criticality with pure water in there with no boron,
2 that --

3 MEMBER BLEY: My question would certainly
4 go away.

5 MR. KAWATA: For normal fuel storage there
6 is no boron present.

7 MEMBER BLEY: I'm sorry?

8 MR. KAWATA: For normal fuel storage there
9 is no boron present.

10 MEMBER BLEY: Normally you would need no
11 boron?

12 MR. KAWATA: That's right.

13 MEMBER BLEY: Why is it there?

14 MR. KAWATA: Can you explain why we don't
15 need boron?

16 MR. CURRY: And we have Mr. Brickner.

17 MR. BRICKNER: This is Bret Brickner with
18 Holtec. We don't take credit for the soluble boron to
19 maintain criticality under normal conditions. We do
20 credit some partial soluble boron for the accident
21 condition.

22 MEMBER BLEY: And that accident condition
23 is?

24 MR. BRICKNER: Is a misplaced fuel
25 assembly outside the storage rack.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: Ah, okay. So assuming that
2 isn't the case, and even in a severe case dumping pure
3 water in is fine?

4 MR. BRICKNER: That's correct.

5 MEMBER BLEY: That makes me happier.
6 Thank you.

7 MR. BRICKNER: That's good.

8 CHAIR STETKAR: I thought I read that.

9 MEMBER BLEY: I was looking all over for
10 it and I hadn't found it.

11 CHAIR STETKAR: Any other questions on
12 fuel flow, fuel storage, anything?

13 Let's take a break because I don't want to
14 interrupt -- we're going to start talking about
15 cooling water systems and I don't want to stop us mid-
16 stream in that. I think what we'll do is we'll take a
17 break until 10:05.

18 (Whereupon, at 9:50 a.m. off the record
19 until 10:07 a.m.)

20 CHAIR STETKAR: We're back in session.

21 MEMBER ABDEL-KHALIK: Mr. Chairman, before
22 we move to the next section, just one question. What
23 dictates the 4,000 bpm concentration of boron?

24 MR. CURRY: One moment. I think we want
25 to know the basis for the 4,000 BPM boron in the spent

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 fuel pit.

2 MR. NISHIO: The concentration of the SFP
3 is the same as the RWSP.

4 MEMBER ABDEL-KHALIK: Right.

5 MR. NISHIO: It doesn't state it is a
6 concentration of the RWSP from the safety analysis
7 based on the MSLB.

8 MEMBER ABDEL-KHALIK: Steamline break?

9 MR. NISHIO: Steamline break. We will
10 check on that. Based on the safety analysis we
11 defined the most critical, the highest requirement of
12 boron concentration of RWSP.

13 MEMBER ABDEL-KHALIK: So I guess we'll get
14 that when we talk about Chapter 15?

15 CHAIR STETKAR: Chapter 15, I think, is
16 coming up in June if I remember correctly, so we'll be
17 sure to try to understand that when we hear that
18 result.

19 MEMBER ABDEL-KHALIK: Thank you.

20 MR. CURRY: All right, 9.2. We have some
21 additional folks that will be participating in this
22 discussion. Marc Hotchkiss is representing MNES/MHI.
23 His specialty is chilled water and ventilation
24 systems. Junya Hattori-san. Mr. Hattori is the
25 deputy manager, MHI Turbine Plant Engineering Section.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Mr. Kawata-san you already met.

2 Motohisa Kitamori-san, please join us.

3 Mr. Kitamori is an engineer, Water Reactor
4 Systems, Engineering Section. Keita Otani. Mr. Otani
5 is an engineer in the Plant Layout Engineering
6 Section, HVAC System and Fire Protection. We'll be
7 calling on these gentlemen as we need for each of the
8 systems covered here.

9 First few slides are acronyms. The water
10 systems 9.2.1, 9.2.5, 9.2.7, 9.2.2. Essential Service
11 Water System, 9.2.1; Component Cooling Water System
12 9.2.2; 9.2.5 Ultimate Heat Sink; and 9.2.7 Chilled
13 Water System have safety-related implications. The
14 other systems do not.

15 Essential Service Water System, as I
16 mentioned, is a safety-related system. It transfer
17 heat from the safety-related loads to the ultimate
18 heat sink. It's obviously designed to mitigate the
19 consequences of a design basis event and for safe
20 shutdown, assuming a single failure and one train
21 unavailable due to maintenance.

22 The Essential Service Water System is
23 interlocked with the Component Cooling Water System on
24 a train-by-train basis. The system consist of four
25 50-percent-capacity Essential Service Water pumps

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 divided into four independent trains. In each line
2 there are two 100-percent-capacity strainers.

3 The system consistent with Reg. Guide
4 1.189 provides backup to the fire service system.
5 Again, you have a simplified schematic showing the
6 design. Part of the design of the Essential Service
7 Water System is plant specific. A good part of the
8 design is a conceptual design.

9 As I indicated, there are four. You see
10 the A, essential service water pump. There are four
11 of those pumps. You also see the two 100-percent-
12 capacity strainers in each line. The safety-related
13 loads are the component cooling water heat exchanger,
14 plate-type heat exchanger in the essential chiller
15 unit. The heavy black line is standard plant design.

16 CHAIR STETKAR: Before you move from this
17 slide, I found a statement in the DCD in Section
18 9.2.1.2.2.6. The statement says, "To avoid concerns
19 with potential downstream pipe wall thinning,
20 butterfly valves provided in the ESWS piping are not
21 used for excessive throttling of the water flow.

22 The valves are sized such they are near
23 the full open position during various modes of plant
24 operation. Orifices having adequate differential
25 pressures are installed downstream of the heat

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 exchangers to prevent excess throttling of the
2 butterfly flow control valves." What particular
3 valves in this system are actually butterfly valves?

4 MR. CURRY: One moment.

5 CHAIR STETKAR: Only because I couldn't
6 find something that I would normally consider a flow
7 control valve. I saw a lot of locked-open manual
8 valves and I got confused. I'm always interested in
9 butterfly valves.

10 MEMBER BLEY: Just a quirk?

11 CHAIR STETKAR: Just a quirk.

12 MR. KAWATA: Okay. There are several.

13 CHAIR STETKAR: They may not show on this
14 simply drawing but, if they do, I would appreciate it.

15 MR. KAWATA: For the standard design
16 butterfly valves.

17 CHAIR STETKAR: They are all butterfly?

18 MR. KAWATA: Yes. The reason is the
19 butterfly valve is for isolation valve for flow
20 control.

21 CHAIR STETKAR: So if I look at -- let me
22 make sure I understand. If I look at Figure 9.2.1-1
23 in the DCD, the actual flow diagram, and I look around
24 the heat exchangers, there are valves that are shown
25 around the heat exchangers as locked-open manual

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 valves. Those are butterfly valves?

2 MR. KAWATA: Yes.

3 CHAIR STETKAR: Okay. Okay. I have to
4 ask. Why do you use butterfly valves as isolation
5 valves? Why not -- since they are locked open. Are
6 they locked in a throttled position or are they locked
7 fully open?

8 MR. KAWATA: Usually ESWS has piping over
9 24 inches. We use other types such as groves or gate.
10 It would really be difficult to procure the bar.

11 CHAIR STETKAR: Okay. It's just because
12 of the size of the piping it's a lot easier to find --
13 it's true it's a lot easier to find a large butterfly
14 valve. Okay. Okay. Thank you. Thank you. I
15 understand.

16 MR. CURRY: All right. Next system,
17 Component Cooling Water System.

18 CHAIR STETKAR: One kind of strange
19 question that I have. This is not particularly
20 related -- well, I'll wait until we get to the
21 ultimate heat sink. I'll wait until then. Sorry.

22 MR. CURRY: No problem, sir. Again, you
23 may want to refer to the simplified P&ID.

24 The Component Cooling Water System is a
25 closed, intermediate system between the essential

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 service water system. It's cooled by the essential
2 service water system. The system has a safety-related
3 portion and also has non-safety-related portions of
4 the system, non-essential loads. The non-essential
5 portions are isolated automatically with redundant
6 valving. I will point that out in a moment.

7 The Component Cooling Water System consist
8 of 200 percent cooling subsystems. On this chart each
9 of these two main sections is a subsystem served by
10 one surge tank separated by a partition in the middle
11 to divide the surge tank up.

12 Each subsystem consist of two 50-percent-
13 capacity trains, each train containing a pump and a
14 heat exchanger. Once again, the question came up
15 about Interim with the Rev. 4. That was what we had
16 submitted to the staff in terms of our DCD markups in
17 response to RAI questions.

18 If we were to look at this drawing, you
19 will see this double-valve isolation for the non-
20 safety portions. That was a result, for example, of
21 an RAI response and a change. That would be the
22 summary. I don't know if there are any particular
23 questions on that system.

24 CHAIR STETKAR: I have several questions
25 so you'll just have to bear with me. Just keep the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 drawing up here so that we can use it as a reference.

2 The valves -- the valves that connect the two trains
3 to the common header so, Jim, on your -- those motor-
4 operated valves there, the 20 valves and the seven
5 valves, in Rev. 3 those valves received automatic
6 isolation signals.

7 They do not receive -- you've added the
8 isolation signal valves for the A2 and C2 headers that
9 you pointed out, those air-operated valves, and you
10 removed all of the isolation signals from those motor-
11 operated valves that you're showing there. Is that
12 correct?

13 MR. CURRY: That is correct.

14 CHAIR STETKAR: Okay. And it's noted in
15 the DCD that says, "In the event of an accident the
16 header tie-line valves, those motor-operated valves,
17 are closed by operator action from the main control
18 room to achieve independence between trains."

19 Essentially you're taking credit for a manual
20 action to replace a previously automated isolation
21 function. My question was I'm always concerned about
22 placing more burden on operators based on design
23 consideration. Why were the automatic isolation
24 signals removed from those valves?

25 MR. CURRY: The basic reason is that it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 would isolate the thermal barriers. There is an SRP
2 requirement which the staff pointed out in an RAI. We
3 removed the automatic closure of the 20 and seven
4 valves, the header tie-line valves that you're
5 referring to that we would not automatically isolate
6 the thermal barriers.

7 CHAIR STETKAR: That's basically in
8 response to a question by the staff and we'll ask
9 about that later. Given the fact that they are now
10 manually operated from the main control room, and it
11 says in the DCD that they are closed when an operator
12 determines train separation is required, what
13 conditions require the operators to close those
14 valves?

15 I'm trying to understand now that the
16 operators are faced with a requirement to close these
17 valves under some conditions. I knew the conditions
18 before because I knew what the isolation signals were.

19 What conditions now would require the operators to
20 close those valves? I mean, the word accident is used
21 but I don't know what that means. Have you --

22 MR. CURRY: No particular accident
23 requirement. It's just to achieve train separation
24 and independence between trains.

25 CHAIR STETKAR: Does that mean if I'm an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 operator in the control room, every time I have an
2 ECCS actuation, I must immediately go and close those
3 valves to achieve train separation? I mean, is that
4 something that's going to be in my emergency
5 procedures because that's an accident?

6 MR. CURRY: There is some guidance. I
7 mean, that will achieve train separation. There is
8 some guidance on the timing in which that should be
9 performed in order to achieve train separation.

10 CHAIR STETKAR: What's that guidance?

11 MR. CURRY: It's a SECY paper and I don't
12 have --

13 CHAIR STETKAR: I don't care about SECY
14 papers. I care about real plants and real designs.

15 MR. CURRY: But in order to achieve, you
16 know, guidance, train separation even to account for a
17 passive failure in a component, the SECY paper gives
18 us some guidance, some timeline for the operator
19 action.

20 CHAIR STETKAR: That's fine. What I'm
21 hearing is the staff had better be prepared to answer
22 my questions for this particular design what types of
23 accidents and what types of guidance will be included
24 in the emergency operating procedures for operator
25 actions to close those valves. I hope the staff will

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 be ready for that when we come to this system because
2 I'm going to ask about that.

3 MR. HAMZEHEE: Yes, sir.

4 CHAIR STETKAR: And --

5 MEMBER ABDEL-KHALIK: What if these valves
6 are automatically isolated or manually isolated?
7 Wouldn't you have the same concern about the thermal
8 barriers?

9 MR. CURRY: The -- right. The automatic
10 isolation is just to separate the trains. We
11 initially, I think, closed all those valves so that we
12 wouldn't and so we would -- we were interrupting flow
13 to the RCP thermal barrier.

14 MEMBER ABDEL-KHALIK: Okay.

15 CHAIR STETKAR: Let me make a quick note
16 here. Now, if I now follow on this drawing header A1,
17 there are -- the motor-operated valves that we just
18 talked about, let's say on the supply line, there are
19 motor-operated valves at the -- if I follow it down,
20 two motor-operated valves at the outboard side of the
21 containment penetration and then motor-operated valves
22 in the return line. None of those valves have any
23 automatic isolation signals. Is that correct?

24 MR. CURRY: That would be correct.

25 CHAIR STETKAR: There were formerly

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 isolation signals for the containment isolation valves
2 and they've been removed so the entire flow path now
3 from train A and B through the A1 header back to the
4 train A and B are all manually operated valves.
5 Right?

6 MR. CURRY: That is correct. Let me
7 confirm with Kawata-san but I believe the only
8 automatic isolation we have in this system now is that
9 one.

10 CHAIR STETKAR: That was my understanding
11 trying to go through Interim Rev. 4. Now, I
12 understand all of that piping is seismic Category I.
13 Is that correct or not?

14 MR. CURRY: Well, not in the --

15 CHAIR STETKAR: No, no, no. In the A1
16 header.

17 MR. CURRY: Yes, sir.

18 CHAIR STETKAR: Okay. If I have a break
19 in that header anywhere, though, without operator
20 intervention I will disable both of the associated
21 component cooling water trains. Right?

22 MR. CURRY: Just to be clear, a break in
23 the safety-related portion?

24 CHAIR STETKAR: Yes. I mean, to emphasize
25 it, you go down to the lower left-hand corner and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 break it where it says A1 header inside CV. In
2 principle, anywhere in that common header I'll disable
3 both of those component cooling water trains.

4 MR. CURRY: I should say we do have an
5 RAI.

6 CHAIR STETKAR: I was going to ask. There
7 is an RAI and an open item. Is the open item
8 specifically addressing that issue because it wasn't
9 clear. I was kind of bouncing back and forth from the
10 SER. So it does address -- so there is --

11 MR. CURRY: That's the subject of that
12 RAI.

13 CHAIR STETKAR: Right. That's the subject
14 of this one.

15 MR. CURRY: 878-6200.

16 CHAIR STETKAR: Good. I just wanted to
17 make sure that we're talking -- that I understood the
18 subject of that RAI. The problem is we don't get all
19 the RAIs, and I emphasize to the staff that we don't
20 want them because if we ask for all of them, we'll get
21 them and we already have 2,000 pages of things to read
22 through. Good, thanks. We'll hear about that
23 resolution once the open item is closed.

24 Let's see. I'm trying to see -- I'm
25 looking at the DCD figures and trying to relate the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 valves to this drawing up here. If you -- there's
2 discussions in the DCD about alignment of alternate
3 cooling. For example, let's just take the A and B
4 side of the drawing here.

5 If we're in a configuration with, let's
6 say, B component cooling water pump out of service for
7 maintenance so that A component cooling water pump is
8 supplying all of the loads on the left-hand side here.

9 For some reason A component cooling water
10 pump then fails, there are cross-tied possibilities
11 you've outlined in that green dotted line that allow
12 me to connect from the C&D loop so that I can maintain
13 cooling for the A and B reactor coolant pumps.

14 I understand that. Those are also
15 manually operated valves so the operators would need
16 to open the two supply valves. Right? And open the
17 two return valves and then close the return valve, the
18 one in the upper left-hand corner of the green box, so
19 that the water goes back to the C/D side and not to
20 the A. You don't pump C/D water over to the A/B surge
21 tanks. There's basically five valves that the
22 operator has to reconfigure to establish that
23 alternate cooling alignment.

24 In the DCD it talks about the fact that
25 there's a 10-minute available time window to perform

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 those actions after the loss of component cooling
2 water based on overheating of the reactor coolant pump
3 motors.

4 Is that the most limiting time limit?
5 Because when you disable that cooling, you disable
6 cooling to the motor coolers, the thermal barrier,
7 which is not a big deal because you still have
8 charging flow to the seals. And you disable cooling
9 to the upper and lower bearing oil coolers for the
10 motor upper bearing and the bottom bearing, the radial
11 bearing between the motor and the pump.

12 Is the motor heating the most limiting
13 time or -- that heats up first? You get into problems
14 with the motor before you get into problems with the
15 bearings? You have analyses that show that is
16 actually your time window is 10 minutes?

17 MR. CURRY: One moment. Let me check on
18 the analysis. You are correct that in the DCD we talk
19 about 10 minutes. Let us check on what the basis for
20 the 10 minutes is.

21 CHAIR STETKAR: If you're going to do
22 that, check also if there's an analysis to show what
23 is the time. I'm interested in realistic times. I'm
24 not interested in licensing type 10 minutes. I'm
25 trying to understand what the real requirements on the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 operators might be. One question is what is the time
2 to heat up the motor to unacceptable conditions,
3 whatever those are.

4 The other question is what is the time to
5 heat up the bearing oil system so that the bearing
6 lubrication is affected and you might start to have
7 vibration problems on the reactor coolant pumps? The
8 concern here is if you start to have mechanical
9 vibrations on the pumps, you can mechanically damage
10 the pump seals, or you might be able to mechanically
11 damage the pump seals depending on their clearances
12 and exactly how they're designed.

13 Of course, if you have mechanical damage
14 to the pump seals, we now have a LOCA condition. I'm
15 interested in terms of the analyses to justify the
16 time window for protection of the reactor coolant pump
17 which is this motor protection issue. Actually, more
18 importantly, what is the time window for protection of
19 the pump seals, mechanical damage to the pump seals
20 which is a bearing lubrication issue more than the
21 motor itself.

22 MR. CURRY: There are a couple of issues.

23 Seal cooling, as you pointed out, would continue to
24 be provided by CVCS so we wouldn't operate
25 indefinitely in this configuration because you've lost

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 two trains so we would be in an LCO.

2 CHAIR STETKAR: But the LCO is like 72
3 hours or something like that. I suspect that the
4 bearings might be into trouble before then. I think
5 it's 72 hours. I'm not sure. I may be shooting from
6 the hip but those are typical times for most of the
7 tech specs, I think, on this plant. One train
8 indefinitely and two trains for 72 hours.

9 MR. CURRY: Let us check. We will check.
10 In any event, we wouldn't operate indefinitely. We
11 still have seal injection in this--

12 CHAIR STETKAR: You do but the seal
13 injection doesn't necessarily help you if you're
14 getting mechanical vibrations on the shaft. That is
15 the concern there. There are no automatic trips of
16 the reactor coolant pumps. Is that correct? I think
17 we asked that question once before. I seem to recall
18 that there are not but I might not be remembering this
19 correctly because we look at too many designs.

20 MR. CURRY: One moment.

21 MR. KAWATA: We have only one automatic
22 trip from ECCS actuation.

23 CHAIR STETKAR: Oh, yeah. That's right.
24 I remember that logic.

25 MR. KAWATA: We do not like to trip RCP

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 because we make some --

2 CHAIR STETKAR: Right. Yeah. I remember
3 that part of the logic. There is an ECCS. I can't
4 remember the coincidence logic. I was thinking more
5 in terms of normal -- I know there's over-current and
6 under-voltage and the basic electrical trips but there
7 are no protection trips for the reactor coolant pumps
8 on high lube oil temperature or bearing vibration or
9 motor high temperature or any of those types of trips
10 that I remember. Anyway, if you've got -- the
11 concerns are what are the real available time windows
12 for those operator actions to open those cross ties.

13 MR. CURRY: Right. Just to rephrase your
14 question, really it's the justification for the 10
15 minutes and the basis that we're not going to damage a
16 pump if we are able to get cooling back over.

17 CHAIR STETKAR: That's right.

18 MR. CURRY: Okay.

19 CHAIR STETKAR: But, I mean, there are
20 two. One is the 10 minutes, regardless of the basis,
21 is based on motor cooling which is a motor protection
22 issue. If I start to overheat the motor, I may not
23 necessarily get mechanical damage, you know, to the
24 mechanical vibration.

25 The 10 minute for motor protection, if

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 it's 10 minutes, is protection of the pump itself so
2 that the pump can stay running. The time window that
3 we don't have any information about for overheating of
4 the bearings is also a pump protection issue but, more
5 specifically, it's a LOCA prevention issue. I don't
6 know what that time is. It's probably longer than 10
7 minutes. If it's 11 minutes, it would be interesting.

8 Oh, and this is just confirmation. I
9 think this answer is simple. The signals for I'll
10 call them new, the air-operated isolation valves for
11 the non-safety header, A2, C2, those, I saw a couple
12 of different markups of Interim Rev. 4.

13 It's my understanding that those levels,
14 those valves, are closed by low-low level in the
15 respective surge tank, a containment spray or P
16 signal, or an ECCS actuation S signal. Is that S
17 signal interlocked with loss of off-site power or is
18 it simply the S signal?

19 MR. KAWATA: S means simply ECCS
20 actuation.

21 CHAIR STETKAR: Okay. Because I saw an
22 interim markup. There used to be coincidence logic
23 with an S and under-voltage and this is strictly ECCS.

24 Okay. Good. I was hoping that was true so thank
25 you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Okay. This one is going to be difficult
2 with this drawing but this is all we have. There is a
3 fairly long discussion in the SER and the DCD
4 regarding water hammer. Let me read something just to
5 get it in context. In the SER -- I wasn't going to
6 ask the staff about it, I will later, but I wanted to
7 make sure I understood from the plant perspective what
8 the concern and what the operation was.

9 In the SER, and I'll quote from the --
10 it's SER Section 9.2.2.4 under GDC-4 if you want to go
11 find that section of the SER. It's quite a long quote
12 but I need to kind of paraphrase everything.

13 It says, "Related to possible pressure
14 transients on the plate type heat exchangers over-
15 pressurizations, the typical operating practice when
16 starting and stopping the CCW pumps is as follow: pump
17 discharge valves, NCS, VLV-018A, B, C, D, are first
18 closed.

19 The discharge valves are manually
20 controlled by plant personnel at the valve location.
21 Because of their large size, 24 inches, the rate of
22 closure of a manual discharge valve is not so fast as
23 to cause sudden increase i pressure or pressure
24 differentials in the pump discharge piping. Thus, the
25 potential for water hammer is minimized."

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Then there's discussions about, you know,
2 the fact the check valves close slowly as flow
3 decreases. The valves in question are not shown on
4 this drawing but, for the benefit of people who don't
5 have the PNIDs pulled up in front of them, they are on
6 the discharge side of the heat exchanger.

7 There is really no discharge valve for the
8 pump. On this drawing they are between the heat
9 exchanger outlet and the connection that goes either
10 to the safety-related loads or the motor-operated
11 valves for the cross ties.

12 Jim, if you could just put -- I know
13 you're looking for the reference section. At this
14 point put your -- just move up to the discharge side
15 of the heat exchanger right there. That's where that
16 valve is. Now, does this mean that every time I shut
17 down a component cooling water pump, an operator has
18 to physically go and slowly manually close that 24-
19 inch valve?

20 MR. CURRY: First thing, Nishio-san or
21 Kawata-san can be very helpful with regard to Japanese
22 experience, but there is no requirement to do that. I
23 think we are talking about Japanese experience.

24 Mr. Nishio.

25 MR. NISHIO: On the Japanese plant,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 normally such a high -- when operator actuate or start
2 high temperature pump, operator will open -- first he
3 will close the valve and then start up the pump and
4 gradually open the valve. This is not a requirement,
5 just a practice of the Japanese plant.

6 CHAIR STETKAR: This is on pump start-up.

7 When they start the pump manually, they first go
8 close that valve and then start the pump and open it
9 up kind of like you do on the service water pump.

10 MEMBER BLEY: So you don't over-current.

11 CHAIR STETKAR: Yeah, I understand that.
12 But if these pumps are started automatically by a
13 safety signal, those valves are open.

14 MR. NISHIO: This is not a requirement,
15 just a practice.

16 CHAIR STETKAR: Okay. So the discussion
17 -- I got confused because I thought that you were
18 closing those valves to somehow throttle flow as you
19 shut the pump down. Follow me? I was getting
20 confused there. But that's the normal practice that
21 they will be instructed when they start the pump
22 manually to close the valve and then open it manually.

23 All right. The answer to that is yes.
24 Thank you. I think -- let me read the questions that
25 I have here for myself to make sure that -- the way it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 was written, I had somehow convinced myself that it
2 was a pump shutdown evolution and that bothered me a
3 little bit because it's kind of hard to close those
4 valves under -- it's not good for the valves.

5 It's not good for the operators. I'll ask
6 that staff that, too. Some of these things are more
7 staff-oriented and I just have to show that I have it.

8 I think I'm done with component cooling water. Thank
9 you.

10 Anybody else, by the way? I don't
11 necessarily want to dominate here. Please speak up.

12 Thanks.

13 MR. CURRY: Okay. The next section is
14 non-safety-related system, the Potable and Sanitary
15 Water. We hadn't planned to say much on this one but
16 Mr. Kitamori is here if we have any detailed
17 questions. This is a non-safety-related system. I
18 think the key points are that the system uses check
19 valves to prevent any radioactive contamination from
20 interfacing with the system or any back-flow and then
21 it has no connection to systems containing radioactive
22 material.

23 CHAIR STETKAR: The DCD does mention that
24 the source of the potable water is wells. Does that
25 mean that any COL applicant who is going to implement

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the design will need to take an exception if they hook
2 up to a normal city water system or some other supply?

3 MR. KITAMORI: Yes, for COL applicant we
4 decide exception.

5 CHAIR STETKAR: Okay. I just wanted to
6 make sure that was the case. A lot of plants don't
7 have wells for these things. Most of them don't.

8 MR. CURRY: Okay. We will move on to
9 9.2.5 if there are no additional questions on 9.2.4.
10 Ultimate heat sink is conceptual design information,
11 although we have interface requirements. The ultimate
12 heat sink is typical in that it dissipates heat from
13 the ESWS.

14 We comply with the requirements of Reg.
15 Guide 1.27 with regards to capacity. Seismic Category
16 I structure and designed to withstand conditions
17 defined in Chapter 2.

18 The ultimate heat sink consist of four 50-
19 percent capacity mechanical draft cooling towers.
20 Again, this is conceptual design information but this
21 is what we have in the DCD. So four 50-percent
22 capacity mechanical draft cooling towers, one
23 associated with each ESWS train and three one-third
24 capacity basins.

25 MEMBER BROWN: You said three 30-percent

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 basins?

2 MR. CURRY: Thirty-three and a third. I
3 could have said 30.

4 MEMBER BROWN: That's fine. You didn't.

5 CHAIR STETKAR: Jim, I came across -- it's
6 in the DCD and it's in the SER. You missed it in
7 other designs but there are statements that say
8 essentially that the capacity of the ultimate heat
9 sink should be sufficient for 30 days of cooling
10 without makeup. This says, "Or a minimum of 36 days
11 for cooling pond."

12 Why are there different requirements if I
13 have something that I'll call an ultimate heat sink
14 which might look like what's inside the dotted lines
15 on this drawing? That has to have a 30-day capacity.

16 Or if I have something that's called a cool pond that
17 might look different but other people would call an
18 ultimate heat sink, that has to be 36 days.

19 MR. CURRY: Mr. Chairman, that's from the
20 Reg. Guide maybe. I'm not sure if anyone --

21 CHAIR STETKAR: I'll ask the staff then.
22 That's fine. I was just curious whether you had any
23 insights because it is stated in the DCD so,
24 therefore, if I build my plant with a cooling bond, I
25 have to make sure whatever I call a cooling -- I want

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 to make sure we're not getting into semantics and that
2 there's an actual technical basis for this because
3 I've seen many people designate concrete ponds as an
4 ultimate heat sink. It doesn't necessarily have to
5 have cooling towers and look like what's in this
6 dotted box here. I'll ask the staff about that.
7 Thank you.

8 MEMBER BROWN: One -- just to pick on your
9 diagram, you said three basins. Yet, your diagram say
10 there's an A ultimate heat sink basin and little
11 diagram on the left says to/from B, C and D which
12 implies there are four heat sink basins. Which is it?

13 CHAIR STETKAR: I was a bit surprised you
14 said three also because I thought I'd seen four. The
15 conceptual drawing figure 9.2.5-1 in the DCD seems to
16 show four.

17 MR. CURRY: Four 33 and a third percent
18 capacity basins. Right?

19 CHAIR STETKAR: I don't know what the
20 capacities are. I'm just looking at a drawing.

21 MR. CURRY: Four 33 and a third. Thank
22 you, sir.

23 CHAIR STETKAR: Ah, okay.

24 MR. CURRY: Right.

25 CHAIR STETKAR: Each has enough water in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it for a third of the design basis. Ah, okay.
2 Physically there are four separated basins. Okay.
3 Thank you. One for Brown.

4 Anybody have anything more on the ultimate
5 heat sink? Again, this is all going to be COL so
6 we'll visit this in detail depending on whatever
7 specific design the COL applicant proposes.

8 MR. CURRY: All right. Condensate Storage
9 Facilities, also a non-safety-related system. Mr.
10 Hattori-san is here to help us with that. Really
11 three -- all non-safety related but three subsections;
12 demin water, condensate storage and transfer, and
13 primary makeup water system.

14 I think it's outlined here starting from
15 the raw water supply. The demin water treatment plant
16 is a COL item. Then the demin water storage tank
17 provides makeup to the condensate storage tank, the
18 two primary water tanks as well. Then off to turbine
19 island users or nuclear island users.

20 CHAIR STETKAR: All four of those tanks,
21 the two primary water makeup tanks, the CST and the
22 demineralized water storage tank, are all outside in
23 the yard. Is that correct?

24 MR. KITAMORI: Primary makeup tank is
25 inside of the tank house.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: Tank house?

2 MR. KITAMORI: Yes. In that tank house we
3 have the primary makeup water tank and RWST.

4 CHAIR STETKAR: Ah, okay. That primary
5 water tank house is a separate building from obviously
6 the reactor building and the auxiliary building?

7 MR. KITAMORI: Located outside of the
8 reactor building.

9 CHAIR STETKAR: Okay. I guess -- uh,
10 okay. I had a question here but I need to kind of
11 rethink how to ask it. There is a statement that says
12 the piping to and from -- this is in the DCD section
13 on the condensate storage facilities. It's 9.2.6.2.6.

14 The statement says, "The piping to and
15 from the primary makeup water tank is a single wall
16 stainless piping designed to run above ground and
17 penetrates the building wall directly into the tank.
18 This piping is mostly inside the auxiliary building in
19 pipe chases. For piping between buildings,
20 penetration sleeves are provided to collect and direct
21 any leakages back into the building for further
22 processing."

23 Since we are now talking about piping that
24 goes between two different buildings, are the
25 buildings next to one another or is there open space?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 I didn't look at the footprint of the plant layout to
2 see where these buildings are, quite honestly, because
3 I didn't have time.

4 MR. HATTORI: Hattori speaking. The
5 condensate storage tank and the turbine building are
6 separated.

7 CHAIR STETKAR: Yes. I'm talking in
8 particular about the primary makeup water tanks.
9 Where I'm going to is collection of radioactive
10 leakages and how they are taken care of. There is
11 quite a bit of discussion about condensate storage
12 tank and demineralized water storage tank. Those are
13 not likely to contain any radioactive fluids.

14 The primary makeup water tank may. It
15 receives return flow from boric acid evaporators, at
16 least, and other potentially radioactive users. We
17 don't necessarily know that the primary makeup water
18 tank is by definition clean water the same way as the
19 demineralized water tank or the condensate storage
20 tank.

21 So because this is non-safety related
22 equipment with regard to collection and control of
23 potentially radioactive fluid releases to the outside
24 environment is why I'm asking about these piping
25 sections because that's where this whole discussion

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 evolved from the SER.

2 What I would like to understand is how
3 that piping from -- between the primary water makeup
4 building and whatever other buildings those pipes go
5 into whether that's double-wall piping, whether it's
6 single-wall piping, and what provisions there are for
7 collection of potential leakage from that piping.

8 There are some discussions about -- it
9 says there are sleeves from buildings that collect
10 water and put it back into places where it goes into a
11 radioactive sump. I'm not sure how that works in this
12 particular configuration.

13 MR. NISHIO: Hiroki Nishio. Sometimes in
14 the primary makeup water is located next to that
15 auxiliary building.

16 CHAIR STETKAR: Oh, okay.

17 MR. NISHIO: The sleeve is a double pipe.

18 CHAIR STETKAR: Thank you. Good enough.
19 Thanks.

20 MR. CURRY: So if there are no questions,
21 may I proceed to 9.2.7?

22 CHAIR STETKAR: Any other questions?

23 MR. CURRY: 9.2.7. Chilled Water System.
24 Mr. Hotchkiss is also our system expert on that.
25 Basically the definition includes essential chilled

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 water and non-essential chilled water. You see the
2 loads that the chilled water system and we'll talk
3 about non-essential chilled water systems shortly.

4 You see the chilled water system loads
5 listed up there and also in the following slide, if
6 you wish to look at it. The system, again, is for 50-
7 percent capacity chiller units in four trains. I
8 think those are the key points of that system.

9 CHAIR STETKAR: Couple questions on
10 essential chilled water. This is beyond design basis
11 accident but it's addressed in the DCD so it's fair
12 game. In Interim Rev. 4, Section 9.2.7.2.1 it says
13 that during loss of off-site power each of the
14 essential chilled water systems is powered from
15 respective safety emergency power source.

16 The essential filler units stop for one
17 hour after a station blackout occurs until the
18 alternate ac gas turbine generator restores power.
19 We've reviewed Chapter 8 so we are familiar with the
20 alternate ac gas turbines and how they're configured.

21 My question was I understand the licensing
22 connotation of the one hour to restore power from the
23 alternate ac gas turbine. Fortunately the ACRS
24 doesn't necessarily have to think in those licensing
25 terms. We like to understand how the plants work.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 The question I had, the essential chilled
2 water system cools several loads and I have questions
3 about a couple loads later. One of the loads it cools
4 are the air-handling units for the turbine-driven
5 emergency feedwater pumps rooms. Those are trains A
6 and D of the emergency feedwater system.

7 I was curious, and I would like to know,
8 if I stop ventilation cooling for those rooms for one
9 hour, what would be the temperature in that room at
10 the end of that one-hour period? That's a room heat-
11 up calc. The second part of that question is what is
12 the most limiting qualification temperature for any of
13 the components in that room?

14 In particular I'd be concerned about
15 possible electronic governors for the turbine or any
16 instrumentation. Or if you have any digital
17 processing local units in there for instrumentation
18 for control signals, what are their design
19 qualification temperatures? The question is, you
20 know, do we exceed those temperatures under this
21 nominal one-hour period?

22 MR. CURRY: I think we got a similar
23 question from the Chapter 8 Subcommittee.

24 CHAIR STETKAR: Yeah. Unfortunately I
25 didn't have time to go back and see that. It sounded

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 familiar but I thought I'd ask it again here. If you
2 did go back and look it up, I don't recall getting an
3 answer on that. I'm not sure.

4 MR. CURRY: Well, actually, I think it's
5 going to be the subject of an audit but we do have a
6 room heat-up calculation.

7 CHAIR STETKAR: Okay.

8 MR. CURRY: And I believe, Kevin Lynn, you
9 may be able to help us out but I think it's going to
10 be the subject of an audit with the staff. Do you
11 have a scheduled date on that?

12 MR. LYNN: Yes, this is Kevin Lynn, MNES.

13 There is going to be an audit under Chapter 8 for an
14 RAI that is related to the turbine-driven EFW pump and
15 room heat-up calculation. MHI is currently preparing
16 the calculation results and we've gotten some feedback
17 from the staff on what specific items they want to
18 see.

19 We are revising the calculation to make
20 sure we address each of those items with the date of
21 being able to complete that by the end of March and
22 then the audit would most likely be sometime in April
23 but it's not officially scheduled at this time.

24 CHAIR STETKAR: Okay. That's good. As
25 long as I know the staff is tracking it. I apologize,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 I didn't have time. I thought it sounded familiar
2 with we look at so many different plants and I tend to
3 ask similar questions for each plant and I get lost.
4 I apologize for the repetition.

5 MR. CURRY: No apology necessary.

6 CHAIR STETKAR: There is a table in the
7 DCD and it's Table 9.2.7-2 that lists -- what it does
8 is it lists the flow rates and heat loads under normal
9 and abnormal operation for the essential chill water
10 system. I think I understand most of this but I had a
11 question that the -- this is probably just because I'm
12 not familiar enough with the plant.

13 The heat load for the A and D (dog)
14 emergency feedwater pump area air-handling units,
15 those are the turbine-driven emergency feedwater pump
16 rooms, are 62,000 BTUs per hour. I understand there
17 is heat load during normal operation because you have
18 a steamline in that room, but the same heat load
19 applies under abnormal operation when we actually have
20 steam flowing through the turbine and we're heating up
21 all of the turbine components and things.

22 Is that correct? Am I misunderstanding
23 the sources of that heat load? The question is why
24 are they the same during normal and abnormal
25 operation? I understand why there's normally a heat

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 load there of some amount.

2 MR. CURRY: And just to confirm, we're
3 talking about 60, right?

4 CHAIR STETKAR: Mine says 62 because I'm
5 looking at Interim Rev. 4 of the DCD.

6 MR. CURRY: Okay. Fine.

7 CHAIR STETKAR: I was politely instructed
8 to look at that and not at Rev. 3. In Rev. 4 the 60
9 is crossed out and a new value of 62 is inserted.

10 MR. CURRY: Thank you, sir. We're on the
11 same page.

12 CHAIR STETKAR: But it is 62 under both
13 normal and abnormal. My basic question is why are
14 they the same. Why isn't -- I don't know what basis
15 went into determining that 62,000 BTUs per hour.

16 MR. KITAMORI: This is Kitamori speaking.
17 Heat load in the worst-case condition so actually
18 during normal operation if different heat load
19 abnormal condition. But to determine chill water unit
20 capacity, we considered the worst condition
21 achievable.

22 CHAIR STETKAR: So are you saying -- so I
23 understand, does that mean that the 62,000 is the
24 actual heat load when the turbine-driven pump is
25 operating under whatever assumptions you made about,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you know, conductive heat removal or whatever, so that
2 during normal operation the real heat load would be
3 less than 62?

4 MR. KITAMORI: Yes.

5 CHAIR STETKAR: Okay. Thanks. I
6 understand that.

7 MEMBER ABDEL-KHALIK: Is that right? So
8 if you have the chilled water system operating versus
9 the case of a station blackout, you expect the heat
10 load in the room to be smaller?

11 MR. HOTCHKISS: This is Marc Hotchkiss. I
12 think what we're saying is we just assumed that this
13 accident heat load for normal and accident conditions
14 decides the chiller. In effect, under a normal
15 condition, the heat load may be smaller. It probably
16 would be smaller if we were not operating the
17 emergency feedwater pump.

18 MEMBER ABDEL-KHALIK: Right.

19 MR. HOTCHKISS: But assume that under
20 normal conditions decides the chiller so there's
21 excess capacity essentially.

22 MEMBER ABDEL-KHALIK: No, but the question
23 is if the pumps are operating and the chiller is
24 operating, what is the heat load? That is the maximum
25 heat load.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. HOTCHKISS: The pump -- the steam-
2 driven emergency feedwater pump is the source of the
3 heat load.

4 MEMBER ABDEL-KHALIK: Correct. But if the
5 chiller is operating, that means the temperature in
6 the room is at its lowest value which means heat
7 losses from the system are at their highest value so
8 that gives you the highest heat load on which you base
9 the sizing of the system. The question is is that the
10 same heat load you're assuming during the station
11 blackout when the chiller is not operating?

12 MR. HOTCHKISS: The chiller operates on a
13 station blackout after one hour after ac gas turbine
14 generator starts.

15 MEMBER ABDEL-KHALIK: No, during that room
16 heat-up period.

17 MR. HOTCHKISS: Well, there is no heat
18 removal taking place during that one hour because the
19 chiller's not operating if I'm understanding your
20 question. After an hour we load the chiller back onto
21 the electrical bus, start the chiller again and start
22 cooling the room back down to an equilibrium value.
23 These are equilibrium head load values accident
24 conditions.

25 MEMBER ABDEL-KHALIK: Maybe I should ask

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the question, the 62,000 BTU per hour heat load
2 calculation, what room temperature is assumed in that
3 calculation?

4 MR. HOTCHKISS: It assumes to be the
5 normal temperature range which for that room is 50 to
6 105 degrees. We would take the worst-case temperature
7 condition to maximize the heat load and make sure --

8 MEMBER ABDEL-KHALIK: Which is the lowest
9 temperature?

10 MR. HOTCHKISS: Yes.

11 MEMBER ABDEL-KHALIK: All right.

12 CHAIR STETKAR: One other question I had
13 on that same table, if you have it in front of you.
14 The motor-driven emergency feedwater pump areas, which
15 are B and C, do not show the heat load during normal
16 operation which I understand because they are motor-
17 driven pumps.

18 During abnormal operation those areas
19 showed heat load of 110,000 BTUs per hour which is not
20 quite but almost twice the heat load in the turbine-
21 driven emergency feedwater pump room. I was curious
22 why the emergency feedwater pump rooms have a much
23 higher heat load than the turbine-driven emergency
24 feedwater pump rooms.

25 I've been around motors and turbines and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it strikes me that rooms that have turbines in them
2 are usually a lot warmer, unless the motor-winding
3 resistance of these motors is really high. You may
4 want to go back and check that if you don't have a
5 quick answer. My problem is I have no absolute feel
6 for any of these heat loads so the only thing I can do
7 is look at relative values.

8 MR. CURRY: We'll take that as an item.

9 CHAIR STETKAR: I mean, I don't understand
10 the reasons for that relative difference.

11 MEMBER ABDEL-KHALIK: Does the turbine-
12 driven emergency feedwater pump room have a door?

13 MR. NISHIO: Yes, of course.

14 MEMBER ABDEL-KHALIK: It does have a door?
15 Does the heat load calculation assume the door is
16 open or closed?

17 MR. NISHIO: Closed.

18 MEMBER ABDEL-KHALIK: Assumes the door
19 closed and you still get 62,000 BTUs per hour. Okay.

20 CHAIR STETKAR: I guess what we're asking
21 is what justification there are for both of those
22 values, both the 62 and -- I understand why the same
23 value is being used in the turbine driven during
24 normal operations. I'm happy with the fact that those
25 two numbers are the same but I guess we would like

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 justification for the basis for the 62 and the 110 so
2 we understand why the difference and understand --

3 MR. CURRY: You're surprised the
4 electrical --

5 CHAIR STETKAR: I'm surprised the electric
6 is much higher than the turbine which brings into
7 question what assumptions were made regarding the
8 analyses for both of those rooms. The question is is
9 the electric somehow really conservatively estimated
10 by a different set of assumptions or in principle
11 could the turbine driven heat load be optimistically
12 estimated through a different set of assumptions
13 because it just doesn't feel right.

14 MR. CURRY: We'll have to look at the
15 calculations.

16 MEMBER ABDEL-KHALIK: I'm actually
17 surprised by the 62,000 BTUs per hour number.

18 MR. CURRY: You think it's high?

19 MEMBER ABDEL-KHALIK: It's low.

20 MR. CURRY: It's low. Okay. We'll look
21 at the calculation and get back to the Committee.

22 CHAIR STETKAR: Thank you. And I have to
23 ask a question that is probably a very stupid question
24 and it will show you that I perhaps didn't spend as
25 much time with the normal ventilation systems as I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 should have. There are several areas that are
2 supplied by the essential trobe water system that do,
3 indeed, have heat loads under normal plant operation;
4 component cooling water area, the essential chilled
5 water area, charging pumps, spent fuel pit.

6 Are those normally supplied by different
7 ventilation systems and that's why there's no normal
8 heat load shown in those areas? As I said, I have to
9 apologize because I just didn't have a chance to do
10 that kind of cross correlation. Do you follow my
11 question? Those areas have normally operating
12 equipment.

13 At any given time two of the component
14 cooling water pumps will be running. I don't know
15 whether they're -- it's either A or B and either C or
16 D will be running. At any given time two of those
17 rooms actually during normal operation will have a
18 heat load. Yet, during normal operation there is no
19 heat load shown on the essential chilled water system
20 for those rooms, or any of the other; the charging
21 pump rooms, spent fuel pit cooling pump rooms, annulus
22 penetration, the penetration areas. The pipes don't
23 know.

24 MR. HOTCHKISS: Mr. Chairman, this is Marc
25 Hotchkiss. You are correct. They are supplied by

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 normal auxiliary ventilation system normally.

2 CHAIR STETKAR: Thank you.

3 MR. HOTCHKISS: And then switch over to
4 the emergency.

5 CHAIR STETKAR: Okay. Thanks. I
6 apologize. I just didn't have a chance to cross-
7 correlate that. Thank you.

8 MEMBER ABDEL-KHALIK: Experience in
9 Japanese plants, do you ever have leaks in the
10 turbine-driven aux feedwater pump rooms? Steam leaks?

11 MR. CURRY: So your question is Japanese
12 experience.

13 MEMBER ABDEL-KHALIK: Right. During
14 testing.

15 MR. CURRY: During testing.

16 MEMBER ABDEL-KHALIK: Right.

17 MR. CURRY: Turbine-driven feedwater pump.

18 MR. NISHIO: I have to -- we have to -- we
19 did not hear of this. Some turbine-driven pump leak
20 but we did not hear such a big steam leak.

21 MEMBER ABDEL-KHALIK: I'm wondering how
22 much margin there is in that 62,000 BTU per hour
23 calculated heat load.

24 MR. CURRY: I think if we look at the
25 calculation and get you some more detail, it may

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 answer a lot of questions. We'll be looking at that
2 heat load calculation.

3 MEMBER ABDEL-KHALIK: Thank you.

4 MR. CURRY: Mr. Chairman, I was thinking
5 of going to the non-essential chilled water system.

6 CHAIR STETKAR: That is an excellent
7 thought.

8 MR. CURRY: All right, non-safety system
9 with the exception of the containment isolation
10 function. I think, once again, you have kind of a
11 detailed or simplified schematic of the loads.

12 I think maybe the point of interest to the
13 Committee might be the last bullet here for severe
14 accidents we have the capability to connect the non-
15 essential system to this component cooling water
16 system to provide alternate cooling to the charging
17 pumps and component cooling water system can also
18 supply cooling water to the fan coolers.

19 CHAIR STETKAR: Jim, I want to ask about
20 that connection. I have a couple of questions about
21 it. First, in general, you don't have -- you do. If
22 you pull up -- that doesn't help. One of the loads
23 off the non-essential chilled water system are the --
24 I'm looking for what it's called here.

25 The main steam and feedwater piping area

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 air handling units, do those -- I think I know the
2 answer but I want to make sure I understand the plant
3 layout. Are the areas that are cooled by those air
4 handling units, do those areas contain the main steam
5 isolation valves, main feedwater isolation valves,
6 main steam depressurization valves, and main steam
7 relief valves? Is that the section of the piping
8 area?

9 MR. CURRY: Yes, that's correct.

10 CHAIR STETKAR: Okay. So if I lose
11 ventilation in there, do you have any idea how those
12 pieces of equipment respond? The main steam isolation
13 valves and the feedwater isolation valves, if I
14 remember right, are -- I don't remember if they are
15 pneumatically or hydraulically operated valves but the
16 point is they are not motor-operated valves.

17 The main steam depressurizations valves
18 are motor-operated valves. The main steam relief
19 valves are air-operated valves that fail in a closed
20 position. I was curious about whether loss of
21 ventilation for that area would have an affect on
22 operation of any or all of those valves? In
23 particular, you know, would they fail in specific
24 positions?

25 Would motor operators or other

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 instrumentation be disabled that could affect any of
2 the safety-related functions from any of those
3 components? I think the main steam relief valves are
4 not safety related but the main steam depressurization
5 valves are, if I recall.

6 MR. KAWATA: These are qualified in the
7 main steam line break condition.

8 CHAIR STETKAR: Okay. They are qualified
9 under main steam line break. Okay. Correct answer.
10 Thank you.

11 Now, on the -- you don't have a drawing
12 for the non-essential chilled water system, do you?
13 Yes, you do. I'm sorry. The connections -- it's
14 doesn't show on this one. Down in the lower left-hand
15 corner of this drawing shows the connections between
16 non-essential chilled water and component cooling
17 water, those two little arrows that come in and out.

18 Unfortunately, this drawing you need to
19 look at the component cooling water PNID and this
20 drawing at the same time to understand my question.
21 The SER says that the connection between the component
22 cooling water system, and this is -- it comes from
23 component cooling water system Header C1 so it's off
24 that Header C1.

25 The design of this, as I understand it, is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you can either supply component cooling water to the
2 containment fan coolers, or you can supply non-
3 essential chilled water back over to the charging
4 pumps. It's a bi-directional sort of flow
5 possibility.

6 In the SER it says that connection,
7 because this is non-safety related piping, is -- what
8 it says is, "There are redundant normally closed
9 motor-operated valves to isolate the systems." I
10 could find only one normally closed motor-operated
11 valve on each of the supply and the -- it's bad to
12 call it supply and return but in each of the lines
13 between component cooling water and non-essential
14 chilled water.

15 In other words, there is only one normally
16 closed valve between Header C1 and what is shown as an
17 in-going arrow here from CCW, and only one normally
18 closed motor-operated valve on what is shown as
19 outgoing. I wasn't sure whether I was missing
20 something or whether I'm misinterpreting the
21 connotation of redundant normally closed motor-
22 operated valves. To me that normally means two valves
23 in series.

24 MR. CURRY: Right. We don't think you're
25 misinterpreting. Kawata-san -- I don't know, Mr.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Chairman, if you have Figure 9.2.2-1.

2 CHAIR STETKAR: Oh, yes, I do. 9.2.2-1?

3 MR. CURRY: Yes, sir.

4 CHAIR STETKAR: I have it. Finding it is
5 something else. I do and it's Sheet 5. I'm sorry,
6 Sheet 6. Is it 6? Sheet 5 according to my notes.

7 MR. CURRY: And we're looking at the
8 living --

9 CHAIR STETKAR: We're looking at Interim
10 Rev. -- I'm looking at Interim Rev. 4, Sheet 5 with
11 9.2.2-1 down in the lower left-hand corner of that
12 sheet.

13 MR. CURRY: We're looking at Sheet 6.

14 CHAIR STETKAR: Six?

15 MR. CURRY: The valves we're looking at
16 are MOV-322A, 321A.

17 CHAIR STETKAR: No, those are the wrong
18 valves. You're looking at the wrong valves. That's
19 from the fire protection system.

20 MR. CURRY: Okay. Well, I'm sorry. I
21 apologize. You are looking at the connection, yes.
22 Yes. You're looking at the connection. What
23 connection are you looking at? I thought I understood
24 the way this worked and now I don't understand the way
25 it works because I didn't look at Sheet 6.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I thought that the only connection was on
2 Sheet 5 down in the lower left-hand corner. In other
3 words, I'm trying to understand where these two single
4 arrows on this drawing connect in the real world.

5 I thought they connected on Sheet 5 in the
6 lower left-hand corner and that the flow from non-
7 essential chilled water to the charging pumps came
8 through these valves back up through the header and
9 over to the charging pumps and I didn't look at Sheet
10 6 which shows another connection that says non-
11 essential chilled water. Now I'm even more confused
12 because -- I'm just confused.

13 MR. CURRY: One moment. We're checking.

14 MEMBER BLEY: You need to pick one.

15 CHAIR STETKAR: That's why I said you kind
16 of need to look at both. I'm finding I needed to look
17 at more drawings at the same time because I thought I
18 knew how it worked and I was apparently wrong.

19 MR. WHEELER: This is Larry Wheeler from
20 the staff. The Interim Rev., I think, has some
21 Chapter 19 figures that might show that information on
22 it a little clearer so that's something you can take a
23 look at.

24 CHAIR STETKAR: I didn't even think of
25 looking there. Thank you. Why would the PRA have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 anything useful in it? If anybody happens to know the
2 number of that figure, it might help. There it is.

3 MR. CURRY: Do you have an electronic
4 copy, Mr. Chairman, or just a paper copy?

5 CHAIR STETKAR: Of which? Yes. The
6 answer is yes. I have electronic. If you can just
7 point me to which drawing.

8 MR. CURRY: Right. Okay.

9 CHAIR STETKAR: If that Chapter -- I'm
10 look at, I think, the -- there is a figure in Chapter
11 9 that is 9.1-2, Sheet 34. I'm not sure if that is
12 the one I should be looking at. It's entitled
13 Simplified System Diagram: Alternate Component Cooling
14 by Non-Essential Chilled Water System which may or may
15 not -- yeah.

16 I was going to say which may or may --
17 it's got a nice sounding title but I'm having
18 difficulty understanding what it's trying to tell me.

19 What I was going to suggest -- quickly I'm not
20 learning anything from this that's going to help me.
21 Let's leave this.

22 In the interest of time maybe you can help
23 me understand. Even sketches on a piece of paper or
24 some drawing that might show all of the valves. I
25 admit I didn't look at Sheet 6, 9.2.2-1, but, quite

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 honestly, that's only confusing me a little bit more
2 because I thought I understood how it worked just
3 looking on Sheet 5.

4 Just looking on Sheet 5 I could -- the
5 concern I originally had is looking at Sheet 5 if I
6 broke the piping on the drawing that you have here in
7 front of me, I could only find one isolation valve to
8 isolate the CCW header from that break.

9 MR. CURRY: You're talking about right
10 where I'm pointing. You're talking about a break
11 there.

12 CHAIR STETKAR: Exactly.

13 MR. CURRY: Okay.

14 CHAIR STETKAR: As I said, in the SER it's
15 characterized as that interface, whatever it is, is
16 isolated by redundant normally closed MOV.

17 MR. HAMAMOTO: This is Hiroshi Hamamoto.
18 The interconnection line between the CCW and non-
19 essential chilled water system has two connections.
20 One is cooling tower for non-essential. Two is
21 charging pump. Connection is between cooling tower to
22 charging pump. Charging pump, cooling line is safety.

23 9.2.2-1, Sheet 6 is between safety and
24 non-safety. The valve is double isolation. The
25 other, Chapter 5, is a connection between CCW to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 containment cooling -- cooling pump. That is a
2 connection between the non-safety. That line is
3 containment non-safety line to non-safety containment
4 cooling. Isolation valve is only one.

5 CHAIR STETKAR: Thank you. I'm starting
6 to understand it. I see now if I look at DCD Figure
7 9.2.7-2, Sheet No. 3, and Figure 9.2.2-1, Sheet No. 6,
8 I at least see where I misinterpreted how I can get
9 non-essential chilled water to the charging pumps so
10 that the line on Sheet 6 of 9.2.2-1 connected to lines
11 that are shown on 9.2.7-2, Sheet 3, and those lines,
12 indeed contain two normally closed motor-operated
13 valves.

14 I've isolated the non-essential stuff on
15 the -- I'm sorry, the non-safety things on Sheet 3 of
16 the non-essential from the safety related that's shown
17 on the component cooling water. I see where that is.

18 Now, what I -- because I was looking at
19 drawings I didn't quite understand the second part
20 because this -- is the piping that's shown on this
21 drawing seismically qualified? If it is, where is it
22 seismically qualified? Because the way to supply
23 component cooling water now to the fan coolers, that
24 connection is shown on Sheet 5 of 9.2.2-1.

25 MR. HAMAMOTO: Sheet 5?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: Sheet 5.

2 MR. HAMAMOTO: Cooling containment.

3 CHAIR STETKAR: That only has one.

4 MR. HAMAMOTO: Yes. This chilled water
5 system is non-essential. Non-essential means non-
6 safety-related. Also this is connection to non-safety
7 related CCW line so that we don't need double
8 isolation.

9 CHAIR STETKAR: Okay. The reason -- this
10 may be something I need to ask the staff for
11 clarification, but in the SER there are a couple of
12 statements regarding connections and there is a reason
13 I'm confused. One says the non-ECWS includes a
14 connection to the CCWS to allow chilled water use as
15 alternate cooling for the charging pumps in the event
16 of the failure of CCWS during severe accident
17 conditions.

18 As indicated in Section 9.2.2 of the DCD,
19 at the boundary of the non-ECWS and CCWS there are
20 redundant normally closed motor-operated valves to
21 isolate the system and those I now understand where
22 they are. I got that.

23 It's also noted, though, that in addition
24 the CCWS can be used as an alternative supply of
25 cooling water to the containment fan coolers of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 non-ECWS in the event of a severe accident. In order
2 to provide isolation between the seismic Category I
3 CCWS and the non-seismic non-ECWS two locked closed
4 valves are provided as indicated in Section 9.2.2.2 of
5 the DCD. Therefore, CCW system integrity and
6 operability is assured by these isolation valves.

7 Now, given the fact that I'm slowly
8 starting to understand these interconnections, my
9 question now is the two locked closed valves that are
10 mentioned in the SER, are those the two normally
11 closed motor-operated valves that appear on Figure
12 9.2.2-1, Sheet 5, of the DCD in the lower left-hand
13 corner?

14 MR. CURRY: Mr. Chairman, can you just
15 give us the SER page reference?

16 CHAIR STETKAR: Yes, I can. Page
17 reference, unfortunately, if you look for SER Section
18 9.2.7.4.1 under GDC2.

19 MEMBER SHACK: Bill. 118.

20 CHAIR STETKAR: I was going to say Bill
21 can find the page number quicker than I can.

22 MR. CURRY: Okay. Maybe we should look at
23 these diagrams but that's the statement that we're
24 trying to --

25 CHAIR STETKAR: I was trying to resolve

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 these two statements. The first one I now understand
2 because I was misunderstanding where that connection
3 was from non-ECWS to the charging pumps in particular.

4 I was getting flow in a different direction. That
5 one I'm happy with. I understand that. The one that
6 I am concerned -- questioning now is the second one
7 that cites two locked closed valves.

8 MR. CURRY: From CCWS to the fan coolers.

9 CHAIR STETKAR: In particular, this supply
10 that's shown on this drawing here from CCWS to the fan
11 cooler which I now understand is a different
12 connection. I'm trying to understand the subtleties
13 of what two locked closed valves mean in the
14 connotation of a break somewhere in this piping
15 system.

16 MR. CURRY: Okay. So, just to repeat, we
17 are looking for the two locked closed valves in CCWS
18 to the fan coolers.

19 CHAIR STETKAR: Yes.

20 MR. CURRY: And we have an SER reference.

21 CHAIR STETKAR: There is an SER reference.

22 MR. CURRY: Thanks.

23 CHAIR STETKAR: Yes. That's all I have on
24 non-ECWS. Thanks for your patience. That's one of
25 the reasons why -- the fortunate thing is we do have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 enough time. As I said, sometimes it takes a while to
2 get the questions sorted out. It's useful to have
3 time so you can look up references. Thank you.

4 MR. CURRY: Absolutely. All right. I
5 think we're on 9.2.8, Turbine Component Cooling Water
6 System. It's a non-safety system and simply provides
7 cooling water to various turbine loads. You see the
8 three heat exchangers there at 50 percent capacity, as
9 are the pumps.

10 That system is serviced by the non-
11 essential service water system. The non-essential
12 service water system provides cooling water to the
13 turbine cooling water system. It's a once-through
14 system discharging -- taking in-take water and
15 discharging to the circ water system connections.

16 Just to avoid any confusion for those of
17 you who have this piece on your slide, that is some
18 kind of a ghost. I don't know why that's there but it
19 shouldn't be there.

20 CHAIR STETKAR: It's just other pumps.

21 MR. CURRY: I thought we got rid of those.

22 So that concludes what we had planned to
23 say on 9.2.

24 CHAIR STETKAR: We are exhausted so we're
25 going to take a break for lunch now. We're doing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 pretty well on time so I'm going to be really
2 generous. We'll reconvene at 1:00. We are recessed
3 for lunch.

4 (Whereupon, at 11:49 a.m. off the record
5 for lunch to reconvene at 1:02 p.m.)
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

A-F-T-E-R-N-O-O-N S-E-S-S-I-O-N

1:02 p.m.

CHAIR STETKAR: We're back in session.

MR. CURRY: Mr. Chairman, I think we left off of 9.2. We plan to start with 9.3.

CHAIR STETKAR: Yes.

MR. CURRY: Our Holtec consultants, Mr. Bullard, Mr. Brickner and Mr. Fitzpatrick will have to leave soon, but we do have an answer to the questions you asked this morning about Metamic.

CHAIR STETKAR: Good. Jim, thanks. You reminded me of something. We will plan to adjourn today at around 5:00. I mean, it depends on when we come to a stopping point. We will plan to come back tomorrow. I don't think necessarily we can cover all of the material today, and coming back tomorrow will also give you folks an opportunity, perhaps, to also do some more research tonight if that's necessary to answer some of the other questions.

So, for just administrative purposes, plan that we'll end around 5:00. It might be a little more, it might be a little later. We probably will not go to 5:30 today, and we should plan to come back tomorrow

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 morning. But that doesn't change what you're going to
2 say now.

3 MR. CURRY: No, and that's helpful in
4 planning.

5 CHAIR STETKAR: But it's just for
6 everyone's planning.

7 MR. CURRY: That's helpful. It also will
8 be helpful if we can at least get through the
9 presentation so we know what the Committee's questions
10 are.

11 CHAIR STETKAR: Absolutely. We'll
12 certainly shoot to do that. I don't know whether we'll
13 finish, you know all of the staff's presentations by
14 the end of this afternoon.

15 MR. CURRY: Okay.

16 CHAIR STETKAR: But certainly we'll get
17 through yours.

18 MR. CURRY: That would be great.

19 MR. HAMZEHEE: We don't plan to talk too
20 much.

21 CHAIR STETKAR: You don't plan to talk too
22 much.

23 MR. HAMZEHEE: No.

24 CHAIR STETKAR: Okay.

25 MEMBER SHACK: The best laid plans of mice

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and men.

2 CHAIR STETKAR: Then make sure you have
3 sharp pencils so you take notes.

4 MR. CURRY: Okay. So, where we left off
5 this morning with the criticality, there was a
6 Committee question regarding the anodized Metamic and
7 the borated water and the potential pH associated with
8 it. And so I think Mr. Bullard and Mr. Brickner have
9 some information for us.

10 MR. BULLARD: Yes. Thanks, Jim.

11 I did want to confirm, I spoke with
12 colleagues at our office. The Metamic material as
13 fabricated and as installed in the racks is in the
14 unanodized condition. And that is typical of Holtec-
15 designed spent fuel racks installed at many nuclear
16 power plants. So while it is not analyzed, it is not a
17 first of a kind installation or application of that
18 material.

19 And we will provide to MHI the ADAMS
20 accession number so that you can review the topical
21 report to find out more information about the
22 material.

23 I think Bret is going to add more
24 information with regard to the pH.

25 MR. BRICKNER: There was a question

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 related to the soluble boron concentration and the pH,
2 and while we don't report pH inside the boron
3 concentration is very similar which we did in the
4 testing, about 2500 ppm. And I've been told that the
5 pH is about five for that testing. And I was told the
6 pH was 4.9, is that correct?

7 MR. NISHIO: Around five.

8 MR. BRICKNER: About five? So it's a very
9 comparable pH.

10 And I'm looking at our report that Chuck
11 just mentioned. The testing was actually done with
12 deionized water also, and the results showed that the
13 deionized water was a harsher environment than the
14 soluble boron in the testing

15 MEMBER SHACK: I'd like to see the
16 accession number. But, yes, I'll have to look at
17 that. I'm a little surprised at those results, but
18 there's aluminum and there's aluminum, of course.

19 MR. BRICKNER: Yes.

20 MEMBER SHACK: I'm not exactly sure just
21 precisely what alloy you're probably using, although
22 there is a type earlier, it is some alloy. But, okay.

23 But there is a report, and so you're in
24 that range for the report?

25 MR. BULLARD: Yes. I can show you through

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the Holtec number, but that's probably not as much
2 use--

3 MEMBER SHACK: It's not. Oh, well give me
4 the Holtec number, I can probably -- even that will be
5 good enough.

6 CHAIR STETKAR: Well, we should probably
7 get the topical report with the staff's --

8 MEMBER SHACK: Well, I'll get out it of
9 ADAMS, but I'll look for it under the Holtec number.
10 If they have it.

11 The only concern I have is --

12 MR. BULLARD: Would you liked the Holtec
13 number?

14 MEMBER SHACK: -- if that's a proprietary
15 thing versus a topical report that might not be
16 proprietary. I mean it's good for you, but --

17 MR. BRICKNER: There is some proprietary
18 information, but I do believe that there is -- I'm,
19 almost certain there's a nonproprietary version that's
20 in ADAMS.

21 CHAIR STETKAR: It's just we have to be a
22 little careful of what we discuss in open session in
23 case this, you know this gets into information that's
24 a proprietary session, that's the only concern I had.

25 MR. BULLARD: We can certainly share with

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 you the Holtec report number at this time. It's Holtec
2 Report No. HI-2022871. And there is an SE --

3 MEMBER SHACK: There's even an SE on it?

4 MR. BRICKNER: -- for that report. Yes.

5 MR. CURRY: So when these gentlemen leave,
6 and this will be the last chance to ask any questions
7 on criticality.

8 CHAIR STETKAR: Well, fellas, we have
9 anymore?

10 I think you can leave. We know where to
11 find you. Okay.

12 MR. BRICKNER: Thank you.

13 CHAIR STETKAR: Thank you very much. That
14 was helpful.

15 MR. BULLARD: Thank you very much.

16 MR. CURRY: Okay. Next, I think we're
17 going to Process Auxiliaries, which fundamentally is a
18 nonsafety-related system with the exception of
19 isolation functions. Mr. Kitamori-san is our expert
20 here. And you know Mr. Kawata.

21 I said Mr. Kitamori-san. It should be Mr.
22 Kitamori. Sorry.

23 All right. As usual, we have the names of
24 the folks at this table, the acronym list for you, the
25 process auxiliaries and our definition consists of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 compressed air and gas systems, the sampling systems,
2 the floor drain system and the CVC, that's the
3 chemical and volume control system. The only safety-
4 related function relates to isolation of these
5 systems, containment isolation of these systems.

6 The compressed air and gas system is
7 further divided up into three subsystems:

8 Instrument air;

9 Station service air, and;

10 Compressed gas.

11 And just flipping back, you have a
12 simplified schematic also in your package there.

13 Instrument air consists of two 100 percent
14 trains with a compressor, an air receiver, and an air
15 dryer in each train.

16 Safety related AOVs fail in a safe
17 position on loss of instrument air, and that of course
18 is why it's not a safety-related function.

19 Station service air system consists of
20 three 50 percent trains with compressors. As shown,
21 we really have only two compressors but, you know two
22 receives, three compressor packages I guess is the
23 right way to say it.

24 The station service we can provide
25 instrument air if additional air is needed.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Compress gas station. Gas, high pressure
2 nitrogen gas which is used for the SIS accumulators
3 and then the rest of the pressure gas systems are low
4 pressure systems, nitrogen and hydrogen primarily.

5 Well, that summarizes that system.

6 The air compressors, I think I recall are
7 all oil-free air compressors, is that correct? Do they
8 use oil lubricants?

9 MR. HAMAMOTO: This is Hiroshi Hamamoto.

10 Compressor is oil-free.

11 CHAIR STETKAR: They are oil free? Thank
12 you.

13 MR. CURRY: Thank you, Hamamoto-san.

14 All right, moving on to 9.3.2 the sampling
15 systems. Again, no safety-related function. You see
16 a list of sampling systems there, and there's a range
17 of them. And their function is pretty much as
18 expected: RCS sampling, containment atmosphere
19 sampling, et cetera.

20 Equipment and floor drain systems. Again,
21 no safety function except isolation valves. The
22 equipment and floor drain system we have radioactive
23 sumps on, radioactive sumps. The following subsystems
24 as indicated:

25 Radioactive;

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Non-radioactive;
2 Chemical and detergent, and;
3 Oily;
4 Liquid waste;
5 Radioactive liquid waste goes to the
6 liquid waste management system.

7 CHAIR STETKAR: This drawing shows in the
8 center of the drawing or left center of the drawing as
9 we're looking at it the two normally closed manual
10 valves that show there at the outlet of the ESF room
11 floor drains. Could you tell us a little bit more
12 about those valves and why they're normally closed? I
13 mean, I think I understand but it was a bit difficult
14 for me to follow the whole rationale through
15 everything I read about them.

16 MR. KITAMORI: I am Motohisa Kitamori.

17 This manual valve is normally closed. And
18 this manual valve is classified as safety-related to
19 prevent from flooding.

20 So we have some -- drain -- this drain has
21 piping, so we open this valve.

22 CHAIR STETKAR: So, the reason that
23 they're normally closed, as I understand it, is to
24 prevent flooding of the room through reverse flow in
25 the drain line, is that right?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. KITAMORI: That is correct.

2 CHAIR STETKAR: Do these rooms have --
3 well, we'll have time to prejudice things. It's not
4 clear to me how that valve normally being closed is
5 necessarily good to prevent flooding in that room.
6 Because if the water comes into the room from any
7 other source other than backflow through the drain, it
8 would seem to me that having that valve closed isn't
9 necessarily a good thing for that room.

10 So, I'm curious. The ACRS does not design
11 systems; it's not our job. We ask questions. I'm
12 curious what decisions were made and whether you
13 looked at all possible sources of flooding in those
14 rooms to justify the decision to have those valves
15 normally closed, which would require an operator if
16 you had water entering the room from another source,
17 like a broken pipe; why that would require an operator
18 then to go try to drain that room or perhaps the
19 broken pipe -- and I don't know which pipes run
20 through those rooms. I mean, obviously if it's only
21 the pipes related to the equipment in the room, I
22 don't care if I fail it because its flooded or fail it
23 because its -- but I also don't know exactly what's in
24 those rooms either. I only know that it's called an
25 essential service or essential equipment room. So I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 don't know what's in those rooms. I don't know what
2 other pipes run through those rooms. I don't know if
3 there are other drain lines that run through the
4 rooms. I don't know if there's fire protection water
5 that's runs. I don't know what's in there.

6 So, if you could kind of explain what sort
7 of process you went through to conclude that the
8 likelihood of reverse flooding through the drain
9 system outweighed the likelihood of inlet -- you know,
10 other sources of flooding in the room, I think that
11 would be useful.

12 MR. CURRY: One moment.

13 MR. NISHIO: This is Hiroki Nishio.

14 So, in the room there is a second or a
15 return from safety-related group only. And so in the
16 US-APWR we divided into two areas, divided two
17 portions, two safety-related pumps, two areas, safety-
18 related. And so we did it to prevent the potential
19 clogging effect to the -- for example, east side
20 flooding does not effect go to the west side. East
21 side to west side. To prevent that, we close that
22 drain pipe.

23 To create this we can take a credit that
24 one side flooding does not effect to the next side.

25 CHAIR STETKAR: I think I understand that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. NISHIO: Yes.

2 CHAIR STETKAR: And as I said, as the ACRS
3 we don't design systems. There is another design that
4 I can think of that would accomplish the same function
5 and leave a manual valve normally open. I'll just
6 leave it at that.

7 And I'm interested in the rationale that
8 said this is the best way to achieve that type of
9 protection that you're talking about, either back flow
10 through the drains or cross-tie or cross-flow from the
11 different divisions through the drain system.

12 MR. CURRY: And I think we understand your
13 question, which is well gee if you leave the valves
14 open, then you have many sources of flooding in one
15 drain, a drain valve that's open would drain the room.

16 CHAIR STETKAR: It would.

17 MR. CURRY: And not cause such a problem.

18 So, I don't know if we -- maybe we need to
19 check on the flooding analysis. So we made a decision
20 to close the valves --

21 CHAIR STETKAR: Yes.

22 MR. CURRY: -- which prevents, as Mr.
23 Nishio said, losing both sides of the system but the
24 question is what was more important.

25 CHAIR STETKAR: That's right: What was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 more important? Because in order to get cross -- I
2 had no idea about the elevations of the rooms. I mean,
3 as shown on this simplified schematic here, those
4 rooms drain into lines that eventually go through a
5 sump. And I'm not sure how gravity works, because I
6 don't know how the different configurations are. But,
7 you know are you protecting against essentially a
8 plausible but quite unlikely condition and making
9 yourself vulnerable to a more likely condition?

10 MR. CURRY: Do we have flooding sources
11 for each area, or maybe we need to do some research to
12 see if potential flooding sources --

13 CHAIR STETKAR: Yes, I don't know what --
14 you know, I don't know whether your PRA has done that
15 type of internal flooding analysis. I don't, Dennis,
16 you looked a little.

17 MEMBER BLEY: There's some flooding, but I
18 don't remember details.

19 CHAIR STETKAR: Okay. I mean, you'd need
20 to look at, as I said, not only the safety-related
21 piping in that room but are there any fire protection
22 lines that happen to transit through the rooms or
23 other drain lines, or -- you know -- I don't know what
24 level of detail you have it at.

25 I was just curious. That one level I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 think I understand the kind of reaction to or
2 licensing question, but sometimes those reactions may
3 not necessarily be the best solution.

4 MR. CURRY: And the question is the basis
5 for the valves being closed or open and what is more
6 important?

7 CHAIR STETKAR: Right.

8 MR. CURRY: The back floor versus
9 individual room flooding. So we can discuss that.

10 MR. KAWANAGO: This is Shinji Kawanago.

11 Yes, and we understand the question and
12 what is the point. But what we want to emphasize
13 again, and basically on a design-basis we need to
14 think about, And it's internal flooding. And for
15 example, the fire and it's a piping break, and the
16 drain would come. And even if there is -- and -- even
17 if we don't need to assume some piping tank break or
18 potential -- and a tank went out, however we need to
19 think about the fire piping break or as a source of
20 the internal flooding.

21 CHAIR STETKAR: Right.

22 MR. KAWANAGO: And also, and this really
23 we needed to have the -- and the division on the east
24 side and the west side so that -- and in your point of
25 those is our protection that internal flooding to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 effect the other division, and nobody's ready to quote
2 this one. So, of course -- and usually there is no --
3 actually the -- the water. However, and to keep the
4 safety --

5 CHAIR STETKAR: You know, I understand,
6 and I'll stop trying to be cagey. Why didn't you put
7 two series check valves in there that would allow
8 water to flow this way and not water flow that, and
9 keep the valves open? I mean, that would accomplish--

10 MEMBER BLEY: The same thing.

11 CHAIR STETKAR: -- that would allow water
12 to flow this direction and not allow water to flow
13 that direction and it would seem to accomplish both
14 functions?

15 MR. KAWANAGO: Okay.

16 And as I said, we don't design things
17 here, but I'll toss that as sort of my first thought
18 of why didn't you do that? Somebody made the decision
19 to do this and there must be some basis for that. One
20 series check valve would probably be good enough, but
21 for double isolation you might need two.

22 MR. KAWANAGO: We understand your point.
23 And maybe that is one -- a resolution of the -- you
24 know--

25 CHAIR STETKAR: But honestly, I mean you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 know that -- I have to be careful here because it is
2 not our function to suggest designs. That's not our
3 purpose. Our purpose is, however, to understand the
4 technical rationale behind a specific design decision
5 and make sure that from kind of an integrated safety
6 perspective we have assurance that people have thought
7 of all these different possibilities. How you solve it
8 is your side.

9 MR. KAWANAGO: And to show the safety-
10 related evaluation and whether or not we don't use a
11 check valve. So this is a safety-related function, so
12 we need to check the integrity of the value. So the--
13 we use to check valve, we can't check the integrated
14 fuel degrade --

15 CHAIR STETKAR: And as I said, it's not
16 our job to kind of design the system. It's just --
17 anyway, we'll leave it, but I'm still kind of
18 interested to see if you looked, you know all sources
19 of flooding and basis for that.

20 MR. CURRY: I understand.

21 And finally the last part of 9.3 is the
22 CVCS. A typical chemical and volume control system
23 maintaining coolant inventory:

24 Seal-water flow, we talked about it
25 earlier as a function;

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Capability of makeup for small leaks.

2 Controlling chemistry;

3 Safety-related functions are really
4 maintaining the containment boundaries.

5 A simplified schematic showing the 200
6 percent charging pumps and the letdown line.

7 CHAIR STETKAR: Interpret silence and move
8 on as quickly as you can. I don't have any questions
9 on this one.

10 MR. CURRY: Thank you, sir.

11 All right. That concludes what we have to
12 say about 9.3.

13 And I think we are ready to move to 9.4.
14 So thank you.

15 So we are going to change the team a
16 little bit. Mr. Hotchkiss is going to come up and
17 Junya Hattori-san will be back and Keita Otani.

18 Mr. Hattori, Mr. Hotchkiss and Mr. Otani.

19 MR. HOTCHKISS: Okay. Good afternoon.

20 As Jim indicated, my name is Marc
21 Hotchkiss. We're going to be talking about section
22 9.4 of the DCD, the ventilation systems. Okay. Okay.

23 This section is a similar format to the
24 other ones you've seen today with we do introduce the
25 technical experts: Otani-san, Hattori-san. And then

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we have a list of acronyms to refer to if necessary.

2 DCD Section 9.4 ventilation systems
3 includes this list of systems and there's an
4 indication of safety-related functions for each of
5 these.

6 The main control room heating, ventilating
7 and air conditioning system has safety-related
8 functions, as you'd expect.

9 There is a section 9.4.2 for spent fuel
10 pool area ventilation system, however the US-APWR does
11 not have a separate defined spent fuel pool area
12 ventilation system. That spent fuel pool area
13 ventilation is accomplished by the aux building
14 ventilation system, which is 9.4.3.

15 And we also discuss turbine building
16 ventilation system, 9.4.4. Engineered safety feature
17 ventilation system, 9.4.5 and containment ventilation
18 systems 9.4.6.

19 So, we'll begin with the Main Control Room
20 HVAC.

21 The Main Control Room HVAC system designed
22 for US-APWRs is typical of U.S. plants, actually, very
23 much as we'll see when we get to the flow diagram.

24 The functions of the system are to control
25 the environment within the control room envelop, of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 which the Main Control Room is a part. And it is a
2 safety-related system and functions to exclude entry
3 of airborne radioactivity into the control room
4 envelope from the outside air intake. And removed any
5 radioactivity within the CRE environment.

6 How the system supports and maintains
7 habitability and functioning of instrumentation during
8 normal conditions and design basis accidents.

9 And this is a simplified diagram,
10 representation. I guess just one other system
11 description type point. There are three modes of
12 operation for the system. There's a normal mode,
13 which essentially takes outside air as makeup air,
14 circulates it through air handling units, conditions
15 the air and exhausts through the kitchen/toilet
16 exhaust fan. That's normal conditions.

17 There's a pressurization mode which is
18 essentially the emergency condition which also uses
19 outside air to pressurize the control room envelop,
20 but filters that air through the emergency filtration
21 units. I think I can get a mouse up here, which is
22 this section, 200 percent trains emergency filtration
23 units. And also recirculates a portion of the control
24 room envelop air through those units during
25 pressurization mode.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 And the third mode of operation is
2 isolation mode, and that occurs in the event of smoke
3 detection or gas detection outside of the control
4 room. And that isolates the outside air intake and
5 recirculates the control room environment atmosphere
6 through the air handling units for the conditioning of
7 the air.

8 That's the description of the system.

9 CHAIR STETKAR: Marc, you characterized on
10 the exhaust fan, you show smoke purge-- I'm sorry.
11 Smoke purge. Is that initiated automatically, do you
12 know?

13 MR. HOTCHKISS: Smoke purge?

14 CHAIR STETKAR: Yes.

15 MR. HOTCHKISS: No.

16 CHAIR STETKAR: It's manual?

17 MR. HOTCHKISS: On a smoke signal it's
18 shutdown as it was running, which it normally wouldn't
19 be.

20 CHAIR STETKAR: Okay. Okay.

21 MR. HOTCHKISS: But once the condition is
22 cleared, then it's manually maturated to clear smoke.

23 CHAIR STETKAR: Okay. Thank you.

24 MR. HOTCHKISS: And the exhaust fans are
25 here not labeled, I guess on this drawing.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: They're different
2 diagrams.

3 MR. HOTCHKISS: Any other questions on
4 this system. Okay.

5 CHAIR STETKAR: Speaking about the
6 ventilations, there are a lot of them, but they're
7 pretty simple.

8 MR. HOTCHKISS: Yes. And they're very
9 similar to what you're used to.

10 CHAIR STETKAR: Yes. Yes.

11 MR. HOTCHKISS: Okay. The next slide or
12 two are related to open items that we are working with
13 the staff on to close. They're documents in the SER.

14 Okay. The next system is auxiliary
15 building ventilation system consisting of a number of
16 subsystems:

17 The aux building HVAC system;

18 The non-Class 1E electrical room HVAC
19 system;

20 The main steam/feedwater piping area HVAC
21 system, which we discussed a little earlier, and;

22 The tech support center, TSC HVAC system.

23 The aux building and ventilation system is
24 a nonsafety-related system, again very similar or the
25 HVAC subsystem is nonsafety-related, very similar to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 US-PWR clients. The only safety-related function for
2 this system is there are some isolation valves that
3 close to allow safety-related ventilation systems to
4 assume the ventilation functions during an accident.
5 And there's also an isolation in front of the main
6 vent stack during an accident condition.

7 The aux building HVAC system functions to
8 maintain a proper operating environment within the
9 auxiliary building, the reactor building, the power
10 source building and the access control building during
11 normal plant operation.

12 The system also functions to keep dose
13 levels due to airborne radioactive material in
14 normally occupied spaces below allowable values during
15 normal conditions. And it does so by maintaining a
16 slightly negative pressure within the controlled areas
17 relative to the outside atmosphere. And that's
18 accomplished by a greater exhaust flow than a supply
19 flow.

20 And the system maintains air flow from
21 areas of low radio activity to areas of potentially
22 higher radioactivity by exhausting from the higher
23 radiative, potentially higher radioactive areas.

24 And the next slide is a little busy, but
25 it's a schematic representation of the system. On the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 left side are the supply fans, two 50 percent fans
2 normally operating. And the center portion is just a
3 representation of the spaces that are ventilated with
4 supply on the left center and exhaust on the right
5 side. And then the three exhaust fans, two of which
6 are normally operating are shown on the right hand
7 side of the drawing.

8 CHAIR STETKAR: Something I hadn't really
9 thought about, so I have to be careful here, the
10 center part of this drawing, for example the lines
11 that feed the Safeguards component areas are shown
12 with isolation dampers or valves that I think you said
13 goes closed on an accident sequence, ECCS or whatever.

14 MR. HOTCHKISS: ECCS, yes.

15 CHAIR STETKAR: There are lines at the top
16 that go to, for example, the CCW up pump areas and
17 emergency feedwater pump areas and the essential
18 chiller areas that don't have similar isolation
19 valves. And yet I know, for example, there's essential
20 chilled water cooling goes to air handling units in
21 those areas. Can you tell us a little bit about the
22 difference? I mean, I kind of asked the question
23 earlier, but I -- I wasn't putting some of the pieces
24 together correctly about, you know what provides
25 normal ventilation and is there a transfer from what's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 called normal auxiliary building ventilation to
2 safety-related room cooling? In particular, I
3 understand the ones down below that are isolated. I'm
4 more curious about the ones up above that don't show
5 similar isolation valves for the component cooling and
6 EFW and the chillers themselves.

7 MR. HOTCHKISS: Understand. Can I confer
8 just briefly?

9 Okay. I think we're clear on this. What's
10 indicated with the dampers --

11 CHAIR STETKAR: Yes.

12 MR. HOTCHKISS: -- those are actuated on a
13 high radiation signal in order to line up the
14 containment low volume purge exhaust filtration units--
15 -

16 CHAIR STETKAR: Okay.

17 MR. HOTCHKISS: -- if there's high
18 radiation in those spaces.

19 CHAIR STETKAR: Okay.

20 MR. HOTCHKISS: In the other ares, an
21 excellent condition to safety-related air handling
22 units start and provide cooling to the area, but
23 auxiliary building ventilation is maintained. Only on
24 a high radiation would we isolate the are.

25 CHAIR STETKAR: Okay. Okay. Than you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And so to make sure I understand, are any
2 of the dampers that are shown on this drawing I assume
3 would show up on the figure in the DCD, are any of
4 these dampers automatically closed by an ACCS signal?

5 MR. HOTCHKISS: No.

6 CHAIR STETKAR: No?

7 MR. HOTCHKISS: They would be closed on--

8 CHAIR STETKAR: Only high radiation?

9 Thank you.

10 MR. HOTCHKISS: And there's a remote
11 manual right there.

12 CHAIR STETKAR: Okay. That explains the
13 differentiation about which areas show. Thank you.

14 MR. HOTCHKISS: Anything else on auxiliary
15 building HVAC system?

16 Okay. The next systems to discuss,
17 there's three on this slide on the aux building
18 ventilation of the non-Class 1E electrical room HVAC
19 system, it's nonsafety-related and it cools the non-
20 Class 1E electrical room. It maintains ME conditions
21 acceptable for electrical equipment and component
22 operation, and it has the additional function of
23 maintaining the hydrogen concentration in the room
24 below one percent in the battery rooms, actually.

25 And the next bullet in the slide, the TSC,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the Tech Support Center HVAC system, is also nonsafety
2 -related. And that functions to limit the airborne
3 radioactive material in the TSC envelope environment
4 and remove radioactive material from the environment's
5 refiltration.

6 And maintains proper environmental
7 conditions for habitability and equipment operation
8 within TSC.

9 The third system on this slide is the main
10 steam/feedwater piping area HVAC. It's also nonsafety-
11 related and maintains proper environment for the
12 components within the main steam/feedwater piping
13 area.

14 And that's it for the auxiliary building
15 ventilation system. An any question or we can move to
16 turbine building ventilation.

17 The turbine building area ventilation
18 system is nonsafety-related. Basically the turbine
19 building is not expected to have any airborne
20 radioactive material in the ambient or in the
21 environment. And there are no safety-related
22 components in the turbine building.

23 The system functions to maintain a
24 suitable environment for operation of equipment within
25 the turbine building.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: I've read a couple, and I
2 don't remember whether I asked this before and it's
3 not a ventilation system question. But the statement
4 has been made a couple of times that there are no
5 safety-related components in the turbine building. And
6 "no," is a very big word.

7 Are there other safety-related instruments
8 or signals that communicate from, for example, turbine
9 trip to reactor protection system; are those located
10 in the turbine building?

11 MR. HOTCHKISS: There is equipment
12 providing that function within the turbine building.
13 We actually have an open item that's on this next
14 slide related to that question.

15 CHAIR STETKAR: Okay.

16 MR. HOTCHKISS: And we're working with the
17 staff now to resolve that.

18 CHAIR STETKAR: Okay. Okay. I just
19 wanted to make sure I understood that. Thanks.

20 MR. HOTCHKISS: Okay. The next
21 ventilation system is the engineered safety features
22 ventilation system. It also consists of a number of
23 subsystems:

24 The annulus emergency exhaust system;

25 The Class 1E electrical room HVAC system;

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Safeguards component area HVAC system;
2 Emergency feedwater pump area HVAC system,
3 and;

4 Safety-related component area HVAC system.

5 And we'll go through each one of these. A
6 couple of these we talked about back when we were
7 talking water.

8 Again, the annulus emergency exhaust
9 system is safety-related, it's an ESF ventilation
10 system. And it functions to remove and retain through
11 filtration fission products that may enter the air
12 from the penetration areas and Safeguards components
13 areas following an accident.

14 I'll just skip to the next slide just
15 briefly while we're talking about annulus emergency
16 exhaust, just to show the simplified run.

17 The system consists of potentially along
18 the left side of the drawing two exhaust filtration
19 units, each with a high efficiency filter and a high
20 efficiency particulate air filter, a HEPA filter. And
21 those components automatically start to filter the
22 exhaust air from, as I mentioned, the penetration
23 areas and the Safeguard component areas following an
24 accident. Exhaust to the bench stack.

25 Okay. So back in the previous slide, we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 got a couple of the systems listed. The Class 1E
2 electrical room HVAC systems functions to maintain
3 proper operating environment for Class 1E to electric
4 equipment in the rooms. And also maintains a hydrogen
5 concentration below one percent by volume in the Class
6 1E battery rooms.

7 And the other three subsystems we
8 discussed on the previous slide have the same
9 function, and they're also safety-related, but they
10 function to just provide the proper cooling and
11 environment for operation of the equipment within the
12 rooms.

13 We do have some simplified drawings of the
14 Class 1E electric room HVAC system. I guess that's the
15 only one we have.

16 Any questions on ESF ventilation?

17 Okay. The last ventilation system to
18 present is the containment ventilation system. And
19 that system consists of four subsystems:

20 The containment fan cooler system, we
21 touched on that back when we discussed chilled water
22 earlier this morning;

23 The control rod mechanism cooling system;

24 Reactor cavity cooling system, and;

25 The containment purge system.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 We've got a brief description of each of
2 those systems.

3 The containment fan cooler system
4 functions to maintain a proper environment within
5 containment during normal plant operation in the LOOP
6 condition.

7 The CRDM cooling system removes heat from
8 the CRDMs.

9 The reactor cavity cooling system
10 functions to remove heat from the reactor vessel, the
11 reactor vessel support structure and the primary
12 shield wall. And it also functions to cool the
13 supports for the primary shield in the reactor vessel
14 to prevent concrete dehydration.

15 The containment purge system has two
16 subsystems to it as well. The low volume purge and
17 the high volume purge.

18 The low volume purge system functions to
19 minimize the spread of radioactive contamination from
20 areas serviced by the aux building HVAC system, which
21 was what we just talked about on that figure of aux
22 building ventilation. And essentially on a high
23 radiation signal we can line up the affected area to
24 this containment low volume purge system, which
25 includes a HEPA filter and charcoal filter.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 The system also provides relief from
2 pressure buildup within containment cause by
3 instrument air leakage and containment temperature
4 fluctuations.

5 The high volume purge system is used to
6 maintain low concentrations of radioactive airborne
7 material in containment atmosphere to allow access
8 during maintenance and inspection activities.

9 The next slide is a simplified floor
10 diagram of all of those containment ventilation
11 systems. On the left side is what we just discussed,
12 the low volume purge and high volume purge on the
13 upper part of the left are the air handling units
14 which provide cooling or heating for the air in
15 containment. And the lower portion of that slide on
16 the left is the air cleanup portion, which includes
17 high efficiency filters, HEPA and charcoal filtration
18 for the low volume purge. And then a high efficiency
19 filter and a HEPA for the high volume purge.

20 And to the right are the other three
21 systems we discussed: The fan coolers, the CRDM
22 cooling and the cavity cooling.

23 CHAIR STETKAR: I don't understand the
24 function and the classification of the containment fan
25 coolers in this part, and maybe you can help me.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 The fan coolers are not safety-related?

2 MR. HOTCHKISS: That's correct.

3 CHAIR STETKAR: And you mentioned it,
4 their function as stated is to provide normal
5 environmental temperatures inside the containment,
6 which everybody does that. But one of their functions
7 is to maintain, and it's cited specifically, to
8 maintain temperatures during a loss of offsite power,
9 and it can be powered from the alternate ac gas
10 turbines. So, they're kind of more than just normal
11 nonsafety things, but they're not safety-related. Plus
12 you've plumbed up some safety-related component
13 cooling water supply to them, but not for a safety-
14 related function.

15 So, I'm trying to understand -- I guess,
16 you know they're not safety-related so that means we
17 haven't seen the safety, you know Chapter 15 or
18 Chapter 6 analyses yet. It hasn't come before us yet.
19 So, apparently, the safety analyses do not include
20 credit for them.

21 MR. HOTCHKISS: Correct.

22 CHAIR STETKAR: But do the analyses of
23 loss of offsite power event include credit for that
24 who have maintained environmental conditions inside
25 the containment?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. HOTCHKISS: Now the loss of offsite
2 power event that is not the loss of all ac event --

3 CHAIR STETKAR: That's right.

4 MR. HOTCHKISS: -- is the loss of offsite
5 where we were loading 1E buses onto the GTGs.

6 CHAIR STETKAR: Right.

7 MR. HOTCHKISS: And in that event you
8 still would need to shutdown the plant, cool down the
9 containment, not a natural circulation, most likely so
10 there's still going to be some containment atmosphere
11 cooling required. So that's why these have a function
12 of loss of offsite power containment cooling.

13 The other two -- well, the other events
14 you were talking about you referred to as we have a
15 cross connect to provide cooling to this from CCW is a
16 severe accident mitigation alternative. And for the
17 purpose of, you know in a severe accident, preventing
18 -- or some sort of cooling if we don't have the normal
19 design-basis containment protection system of
20 containment spread. That's the safety-related
21 containment protection , over pressure protection
22 system is containment spread.

23 CHAIR STETKAR: What happens if I have a
24 loss of offsite power and I do not have the fan
25 coolers?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. HOTCHKISS: There is still a
2 considerable amount of heat being generated from the
3 equipment within containment, so the temperature would
4 increase.

5 CHAIR STETKAR: Okay. Would I -- as I
6 said, we haven't seen the accident analyses and I
7 guess this is more appropriate for that discussion.
8 But I'm just curious. On this plant they're somewhere
9 between something that sounds like the purely
10 nonsafety-related and something that sounds like it's
11 safety-related.

12 So, I guess we'll just table that
13 discussion for until we get the accident analyses--

14 MR. HOTCHKISS: The safety-related --

15 CHAIR STETKAR: -- for loss of offsite
16 power.

17 MR. HOTCHKISS: The safety-related
18 containment protection function is accomplished by
19 containment spread.

20 CHAIR STETKAR: I understand. And if it
21 were not for the point that you made and the point
22 that's in the DCD that says "The containment fan
23 cooler system is designed to satisfy the following
24 design-basis:

25 Maintain containment air temperature below

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 120 degrees Fahrenheit during normal operations and
2 below 150 degrees during LOOP condition." If it was
3 not for that last phrase about some requirement for
4 LOOP, I'd better understand.

5 MEMBER BLEY: Well, apparently they don't
6 need for it that purpose, so you know classify it.

7 CHAIR STETKAR: Bit it's specifically
8 designed for that purpose, so I --

9 MR. HOTCHKISS: But if -- okay.

10 CHAIR STETKAR: You're following --

11 MR. HOTCHKISS: Yes.

12 CHAIR STETKAR: LOOP is a design-basis
13 event.

14 MEMBER BLEY: Actually, I think we'll see
15 it better looking in the PRA. I don't think we're
16 going to see it in Chapter 15, because if you just
17 lose the sprays over it, it's great.

18 CHAIR STETKAR: Yes, but you don't want to
19 lose the sprays on a loss of offsite power, do you?
20 Good God, I hope not.

21 MEMBER BLEY: That's right.

22 CHAIR STETKAR: Yes.

23 MR. HOTCHKISS: Really the question is
24 you're kind of poking at is are they risk significant.

25 CHAIR STETKAR: And I didn't want to raise

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that question. I originally thought about asking that
2 question, but that's not appropriate for this group.

3 MEMBER BLEY: I think that's what it's
4 complete.

5 CHAIR STETKAR: And I wouldn't necessarily
6 have asked it in this forum, except for the fact that
7 the LOOP design function is explicitly identified in
8 the DCD.

9 MR. KAWANAGO: This is Shinji Kawanago
10 from MNES.

11 And this is just in our information for
12 the design -- to get it to the rest of offsite power.

13 And as you stated, basically it is not a safety-
14 related requirement. However, and when actually we
15 have the loss of offsite power and you -- and after --
16 and after -- after the finish and it resolves loss of
17 offsite power, immediately linked to restart the power
18 plant immediately so that -- and if we don't have this
19 cooling function of the reactor vessel, cooling, CRD
20 cooling found, and temperature will increase, I mean
21 with over and around 150 and we needed to shape -- of
22 the CRDM and the coil and allowing the reactor --so
23 again, it is not safety-related --

24 CHAIR STETKAR: It's not safety -- it's
25 more, if you will, investment protection type?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. KAWANAGO: Sure, sure, sure.

2 CHAIR STETKAR: Okay. Okay. That helps.
3 That helps. Thank you. Thank you.

4 MR. HOTCHKISS: Okay. So that was it for
5 containment ventilation, unless there's other
6 questions. Actually, that concluded 9.4.

7 MR. CURRY: All right. Mr. Chairman, we're
8 going to change to 9.5 and change the team up here. So
9 we know Mr. Otani. And we're really starting with
10 9.5.1, so Mr. Ron Reynolds will be the leading
11 presenter for this. And then for 9.5.2 our technical
12 expert will be Mr. Tanaka for 9.5.2 to 9.5.8.

13 MR. REYNOLDS: Are we ready? Okay. Good
14 afternoon. I'm Ron Reynolds. I have Otani-san as a
15 technical expert with Chapter 9.5.1.

16 We have, again, a list of acronyms that we
17 an go through. I think they're fairly
18 straightforward.

19 And, of course, I'll be talking on this
20 9.5.1.5 protection program, and we'll start with that
21 first section.

22 Again, as you are all aware, that the US-
23 APWR is a four-train, 50 percent-train system. And
24 during the construction of the US-APWR, for me I guess
25 I could say but I had 25 years of experience, over 25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 years in the nuclear industry and worked on
2 construction of some, and worked on NUREG-0800 type
3 plants, and worked on the pre-1979 plants. And this
4 is a dream come true if you look at the US-APWR how
5 it's compartmentalized. So, it's a good backbone for a
6 fire protection program to start.

7 And with that- of course, the requirements
8 of 10 CFR 50.48, Appendix A; the NUREG-0800, Reg.
9 Guide 1.189; all the NFPA codes including NFPA 804
10 we're using those requirements and that guidance
11 you'll probably see are very similar to most other
12 fire protection programs in that respect.

13 And so the primary objective of the fire
14 protection:

15 To minimize the potential for fires and
16 explosions to occur;

17 Rapidly detect, control and extinguish any
18 of those fires that do occur, and;

19 Assure that any fire that is not properly
20 extinguished by the fire suppression system will not
21 prevent safe-shutdown of the plant and will minimize
22 the potential for radiological release to the
23 environment.

24 Pretty straightforward for all fire
25 protection programs.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 The fire protection program describes:

2 The defense-in-depth approach. We have the
3 detection, suppression, separation, administrative
4 controls; all of that adds up to the defense-in-depth
5 approach in fire protection.

6 The program has got:

7 Describes overall fire protection program
8 for the facility;

9 The positions and responsibilities for the
10 program the fire brigade, their training, the
11 requirements, the protocol, the fire protection
12 engineers requirements and so forth;

13 Interface with control room and security
14 as well.

15 The program describes automatic detection
16 and the manual and automatic suppression systems. And
17 as I did mentioned earlier, the administrative
18 controls are also a big part of the fire protection
19 program, Hot works permits, transit combustible
20 permits, and even general housekeeping is a big part
21 of it just to maintain control of combustibles, any
22 transient combustibles into the plant.

23 Many of these programmatic issues do rely,
24 or are the responsibility, I should say, of the COL
25 Applicant to maintain and establish those programmatic

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 controls.

2 Fire protection design features for the
3 US-APWR:

4 Prevent fire initiation by controlling,
5 separating and limiting the quantities of combustibles
6 and sources of ignition. Again, that's the same thing
7 as saying we have fire barriers, we're going to have
8 administrative controls to ensure that we could reduce
9 the sources of ignition and try to contain a fire if
10 it does occur.

11 And again, that goes onto the next bullet.

12 Isolate combustible materials and limit the spread of
13 fire by subdividing the plant structures into fire
14 areas. No further separated into fire zones.

15 Separate redundant safe-shutdown
16 components and associated electrical divisions by 3-
17 hour fire rated barriers. That's to preserve the
18 capability to achieve and maintain safe shutdown of
19 the plant following a fire. First we need two trains
20 for safe shutdown of the plant. And you could assume
21 one train is a maintenance, we could have a fire in
22 one train.

23 Preserve the capability to achieve and
24 maintain safe shutdown of the plant using the controls
25 external to the Main Control Room. Should a fire

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 require the occupants of the main control to leave, we
2 have the remove shutdown room that's completely
3 electrically separated, it's quite a distance away. I
4 think it's three levels from the main control isolated
5 with its own ventilation and isolation.

6 Separate redundant trains of safety-
7 related equipment used to mitigate the consequences of
8 a design-basis accident.

9 CHAIR STETKAR: Ron, before you slip
10 through this, a couple of questions. And I don't now
11 if you're the right person to ask, but I'll ask it to
12 get on the table.

13 MR. REYNOLDS: Yes.

14 CHAIR STETKAR: How are the cables from
15 the four safety divisions configured as they flow to
16 the control room? What sort of barriers or separation
17 do you have?

18 I mean, I haven't studied the physical
19 layout of the plant. I'm close enough to understand
20 whether you have, you know the traditional large cable
21 spreading room, which I assume you may not. And if you
22 do, what sort of barriers do you have there to prevent
23 multi-division fire impacts?

24 MR. REYNOLDS: I understand.

25 First of all, of course you know that we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 have the four-trains; they're all separated by fire
2 barriers. And even within each train, there's
3 additional separation of fire barriers. So, it's not
4 just one fire area per train.

5 And, of course, all of those cables are
6 separated. There's no interaction to the train.

7 Now, the question is: How do they all come
8 together to the control room?

9 CHAIR STETKAR: Right.

10 MR. REYNOLDS: And that's --

11 CHAIR STETKAR: I've actually worked on
12 four-train plants.

13 MR. REYNOLDS: And fire is an issue
14 because eventually they have to come to one point.

15 CHAIR STETKAR: Right.

16 MR. REYNOLDS: We do have four electrical
17 rooms that are separated for Train A, B, C and D that
18 have fire barrier separation. And these cables will be
19 coming up through that floor -- or through the ceiling
20 of that room into the floor of the --

21 CHAIR STETKAR: So under the control room
22 there are actually four individual rooms?

23 MR. REYNOLDS: There's four electrical --
24 electrical rooms. Yes, I don't know what the relation
25 is, I guess they're directly under where the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 electrical rooms are located. They're under the
2 control room

3 CHAIR STETKAR: I'm just curious, because
4 I have yet to see a four-train plant that doesn't
5 somehow have a place where these things come together.

6 MR. REYNOLDS: Well, and even with this
7 plant as they come through, there's a portion that
8 will have -- at this point in the design there is a
9 portion, I understand, that will have some close
10 proximity and would possibly need fire wrapping on a
11 cable or a conduit containing cable.

12 MEMBER BLEY: This is after they come out
13 of this electrical rooms?

14 MR. REYNOLDS: Yes.

15 MEMBER BLEY: Somewhere like under the
16 floor?

17 MR. REYNOLDS: Yes. I'm probably not able
18 to describe exactly the routing of these cables
19 clearly. I apologize for that.

20 CHAIR STETKAR: Maybe tomorrow. And the
21 problem is if we start showing building layouts,
22 occasionally you get into safe security related
23 issues. But there's some configuration that you could
24 show us, it might help, you know both a planned view
25 and an elevation view. In principle we have those

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 someplace, because as I said I didn't have enough time
2 myself to do some homework and I was just curious
3 because, you know you make a point about separation by
4 barriers.

5 MR. REYNOLDS: Yes.

6 CHAIR STETKAR: And typically, as I said,
7 I have yet to see a four-train plant that doesn't face
8 the problem of multi-divisions in a single space.

9 MR. REYNOLDS: It is one of the more
10 difficult hurdles to overcome. And --

11 CHAIR STETKAR: And the only reason I ask
12 that is if, indeed, you do have that space what in
13 your design -- you know, how are you protecting things
14 within your design? You mentioned five wraps, for
15 example.

16 MR. REYNOLDS: Right. That would be the
17 protection of choice would be to put a qualified fire
18 wrap on. And my understanding is that it's a very
19 short segment of electrical conduit that would need to
20 have potential for that to have a fire wrap. I mean,
21 so we would put either a three-hour fire wrap on or a
22 one-hour automatic suppression detection. We would
23 meet the requirements, that would be for certain.
24 Okay.

25 CHAIR STETKAR: And here I have to admit I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 gave up. I didn't read the complete Fire Hazards
2 Analysis.

3 In some designs that I've seen, I'm
4 talking about the fourth checkmark here about
5 abandoning the Main Control Room and going to remote
6 shutdown.

7 In some designs that I've seen the plant
8 design facilitates a fire in the control room that
9 requires the operators to relocate to the Remote
10 Shutdown Room, and does that quite well.

11 I've seen some plants where a fire in the
12 Remote Shutdown Room because of the way the circuits
13 are configured, not only disables the Remote Shutdown
14 Room but also disables the Main Control Room. And
15 design-basis is not that people live in the Remote
16 Shutdown Room and relocate to the Main Control Room.
17 So, I was curious whether you know, and this is kind
18 of an electrical question but it comes upon the
19 purview of the Fire Hazards Analysis, whether or not
20 you've looked at fire in the Remote Shutdown Room
21 because it's another place where several things
22 together, that may affect not only the Remote Shutdown
23 Room, obviously, but because of the way the circuits
24 are configured, disable controls in the Main Control
25 Room.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. REYNOLDS: Well as I mentioned before,
2 and I could give the answer to the best that I know
3 because it is more into the electrical I&C area, but
4 it is electrically separated, the Remote Shutdown Room
5 from the, Main Control Room. And in order to isolate
6 the Main Control Room and then initiate actions from
7 the Remote Shutdown Room, there's a series of actions
8 that need to take place. Of course, there's a
9 permissive switch. And I'm being able to tell you
10 this in a general sense that allows you to disconnect
11 the Main Control Room and the connect to the Remote
12 Shutdown Room. Then there is another switch that
13 severs the Main Control Room from that and allows that
14 complete electrical separation.

15 CHAIR STETKAR: And that at a high level
16 is kind of what I was looking for in the sense that if
17 that's true, you have to actively, let's say,
18 activate--

19 MR. REYNOLDS: That's correct.

20 CHAIR STETKAR: -- the Remote Shutdown
21 Room, that's fine. There's some plants that have a
22 Remote Shutdown Room essentially continuous but
23 online.

24 MR. REYNOLDS: Right.

25 CHAIR STETKAR: The control signals kind

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of go through there and out to the equipment, or an
2 active part of the system. And if this design doesn't
3 do that, that kind of answers my question.

4 MR. REYNOLDS: That's right.

5 CHAIR STETKAR: Thanks. Thank you.

6 MR. REYNOLDS: Sure.

7 CHAIR STETKAR: I'm still curious to see
8 how that room under -- that one is still open. I'm
9 still curious to see how the room is configured and
10 where the cables come together.

11 MR. REYNOLDS: Okay. To go on to the next
12 slide, clarification design features. That is to
13 prevent fire initiation, detect and locate fires and
14 provide operator indication of the location of the
15 fire.

16 Okay. The detection system is going to
17 also provide local, audible and visual alarms for
18 occupants of the building. We'll follow NFPA
19 requirements.

20 Provide the capability to extinguish fires
21 in any plant area, to protect site personnel, limit
22 fire damage, and enhance safe-shutdown capabilities.

23 Supply fire suppression water at a
24 sufficient flow rate and pressure in accordance with
25 NFPA codes. And that's basically looking at our

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 largest sprinkler demand plus our 500 gallons for
2 water hose allowance for a duration of two hours.
3 We'll follow that with NFPA codes for the fire pumps,
4 tanks if they're used and the fire main.

5 Maintain a 100 percent design capacity for
6 the fire pumps, assuming the failure of one of the
7 pumps or loss of offsite power. US-APWR uses two pumps
8 and so one is electric and one is diesel driven.

9 The fire protection system is nonsafety-
10 related, of course with the exception of the piping
11 between and including the containment isolation
12 valves. However, there are seismic design
13 requirements that are applied to portions of the fire
14 protection system; that's basically the standpipe
15 systems that are in areas containing equipment
16 required for safe shutdown following the SSE.

17 Okay. The Fire Hazards Analysis. The
18 purpose of the Fire Hazards Analysis or FHA is to:

19 Evaluate the potential in-situ and
20 transient fire and explosion hazards;

21 Also to define the fire barrier locations;
22 Identify detection and suppression
23 coverage throughout the plant;

24 Confirm that the effects of a fire in any
25 location in the plant do not adversely impact the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 ability to shutdown the plant or release
2 radioactivity to the environment;

3 Select appropriate measures for fire
4 prevention, fire detection, fire suppression, and
5 containment within each of the areas that contain
6 system structures and components important to safety.

7 The FHA is performed for areas of the
8 plant containing safety-related components and for
9 other areas. It's also for the turbine building, other
10 areas that may not contain safety-related equipment,
11 but for the generation of electricity.

12 The FHA is performed on a fire area by
13 fire area basis in fire zones. Again, it's fire areas
14 that are bounded by fire barriers: Floor, ceiling,
15 walls and within those fire areas we're separating
16 again up to five zones. It gives a better feel for
17 the fire protection engineer in the ongoing years
18 even, to see where the concentration even within a
19 fire area, where these combustibles are concentrated.

20 So that's helpful.

21 The approach provides confidence that the
22 plant safety is achieved and the intended fire
23 protection program requirements are satisfied.

24 MEMBER SHACK: That is curious. Whenever
25 you do reference 1.189 in that fire thing, it's always

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Rev 1. There's is a current version is Rev. 2.

2 MR. REYNOLDS: Well, it's kind of the
3 code, its the regulation of when we were in --

4 MEMBER SHACK: Okay. When you submitted
5 this.

6 MR. REYNOLDS: When we submitted Rev. 1
7 was the -- same with many of the fire -- NFPA codes
8 that we used for the standard plant design. Of course,
9 as the applicant --

10 MEMBER SHACK: Even though you haven't
11 received your certification yet, it goes on to when
12 you submitted it? Oh, okay.

13 MR. REYNOLDS: That concludes my
14 presentation of 9.5.1. I know we have one open
15 question that we have to look at when we get a chance,
16 if you want to do that.

17 MR. CURRY: No. If staff brings it up,
18 we'll --

19 MR. REYNOLDS: Okay. Okay. That's it.
20 Any other questions?

21 I thank you very much.

22 CHAIR STETKAR: Yes. I was just looking
23 through. As I said, I didn't have a chance to read
24 all of the Fire Hazards Analysis. It's a number of
25 pages. And I'm looking at the drawings.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 I see on the planned view drawings, the
2 four electrical rooms, I know where the control room
3 is. But there's slices between. You know, there are
4 slices at certain elevation and I suspect that there's
5 something in between there that I'm not seeing, just
6 because of the way the slices were taken. So, I'm
7 still curious about that.

8 MR. REYNOLDS: Okay.

9 CHAIR STETKAR: That's a good point,
10 though. I will ask the staff about that.

11 MEMBER SHACK: Well, the staff is
12 referencing Rev. 3, which is a really interesting one.
13 Okay.

14 CHAIR STETKAR: 1189?

15 MEMBER SHACK: Oh, okay. One and three
16 but not 2.

17 CHAIR STETKAR: Well, but the transition
18 to two was a change -- you know, things like multiple
19 spurious operations and how you have to consider
20 those.

21 MEMBER SHACK: Right. Again, the DCD
22 references the NEI document and Rev. 2 has a rather
23 substantial --

24 CHAIR STETKAR: It does reference --

25 MEMBER SHACK: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: -- because we're on -- not
2 on hotwire.

3 MEMBER SHACK: Yes, it referenced. Again,
4 that's really left to the COL Applicant to do. But it
5 references that document as the basis for the COL
6 Applicant's analysis.

7 CHAIR STETKAR: And that does treat the
8 multiple --

9 MEMBER SHACK: Rev. 2 has some
10 reservations about the NEI document --

11 CHAIR STETKAR: Rev. 2 of the Reg. Guide--

12 MEMBER SHACK: Right. Right.

13 CHAIR STETKAR: But it doesn't
14 reservations in the --

15 MEMBER SHACK: And I don't know when the
16 COLA submitted its application, so --

17 CHAIR STETKAR: Well, we'll sort that out.

18 MR. CURRY: All right. To finish up with
19 9.5; 9.5.2 to 9.5.8 I'd like to introduce Mr. Hideki
20 Tanaka who is our technical expert in this area -- in
21 these areas. So, back on the original slide, I'm not
22 going to try to go back to that, but it indicated that
23 9.5.1, 9.5.2, 9.5.3 they're not safety-related
24 functions. The support system for the gas turbine
25 generators do have safety-related functions.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So where Mr. Reynolds left off, we'll pick
2 up, I think, on 9.5.2 Communications Systems. There
3 are a variety of communications capabilities outlined
4 in the DCD and fundamental ideas that there'll at
5 least be two methods of communicating with outside
6 agencies and internal to the plant provided by all of
7 these different mechanisms which I'm sure the
8 Committee is familiar with.

9 So, I will move on to lighting systems.

10 Yes, sir?

11 MEMBER BROWN: This is the first time I've
12 ever asked this question in the light of this
13 particular discussion, because I didn't think of it;
14 the communications issue. You list a whole list of
15 them here, and this is not unusual for the other tank
16 designs. But in terms of the connection of offsite
17 communication system is it possible for somebody
18 offsite to commandeer a communication system, hack it,
19 and make onsite announcements the way your all system
20 is configured?

21 MR. CURRY: I don't know.

22 MEMBER BROWN: Well, I mean if you look at
23 it from a telephone system that goes to a telephone.
24 I'm talking about the public address type system or
25 the offsite communication, or plant radio systems that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 could be compromised. It's not hard to hack into radio
2 systems so if could have some guy out there giving
3 counter- information that was done -- I just threw
4 that out. It just occurred to me.

5 MR. CURRY: Let me --

6 MEMBER BROWN: I'm not asking you. That's
7 totally off-the-wall.

8 MR. CURRY: Yes, that was a sabotage-type
9 question which I'm not sure that --

10 CHAIR STETKAR: It is. It is.

11 MEMBER BROWN: It's different from cyber
12 because it's not on the computer, necessarily.

13 MR. CURRY: True.

14 MEMBER BROWN: Unless you've got Verizon,
15 which you don't know what's going to happen. Oh, I'm
16 not supposed to say that.

17 MR. CURRY: It's okay. They're find your
18 phone number.

19 MEMBER BROWN: Anyway, it'd be interesting
20 to have some idea of the independence of the ability
21 to communicate public address system-wise from
22 offsite, insite and/or the radio system. The
23 telephone system is kind of commercial, I imagine.

24 CHAIR STETKAR: We just may need to be a
25 little bit careful because we're getting into that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 gray area --

2 MEMBER BROWN: I understand that.

3 CHAIR STETKAR: -- if you know security-
4 related stuff. But we can --

5 MEMBER BROWN: I'm just putting it on the
6 table for discussion at the appropriate time.

7 MR. CURRY:

8 MR. KLINE: Thank you. We'll note that
9 comment.

10 MEMBER BROWN: I knew that would be
11 appreciated.

12 MR. CURRY: All right. Lighting systems.
13 Lighting nonsafety-related system. We've got normal
14 lighting, emergency lighting, emergency lights divided
15 up into those three subsets, including the third
16 bullet titled "Normal/emergency lighting. But that's
17 intended to be all lighting except the Main Control
18 Room and the shutdown area.

19 So, as you would expect, normal lighting
20 is non-Class 1E, emergency lighting --

21 MEMBER BROWN: Let me backtrack.

22 MR. CURRY: Sure.

23 MEMBER BROWN: Because when you get to do
24 Chapter 7 this next question will come up, and you
25 might as well be aware that I will be asking the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 question then. This is on your Slide 8 where you talk
2 about communications between the MCR and the Technical
3 Support Center and the Offsite Emergency Operations
4 Facility. When you were describing the overall
5 architecture, and you may not be doing it but
6 somebody will be, of the I&C system, how that
7 communicates between what I call plant MCR/TSC complex
8 and what I call the business or corporate entity
9 that's at the site also will be of interest. That's
10 talking about the firewalls and things.

11 MR. CURRY: That's right.

12 MEMBER BROWN: And I know that goes into a
13 little bit a cyber, but there's still some questions
14 that can be asked in that vein without venturing into
15 the whole cyber security plan. So, I'm just giving
16 you a heads up or I've giving Mitsubishi a heads up --

17 MR. CURRY: Somebody.

18 MEMBER BROWN: -- that questions will be
19 forthcoming.

20 MR. CURRY: Right. And again, the
21 relationship and the independence of the onsite
22 communication system from offsite sources?

23 MEMBER BROWN: Yes, right. I mean data
24 moving from the site systems to other. And I'm not
25 going to go any farther until we see the architecture

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 layout.

2 MR. CURRY: Yes.

3 MEMBER BROWN: I mean I took a look at it
4 real quick and it wasn't real crisp as to all that.
5 Just one of your diagrams kind of very high level.

6 MR. CURRY: Okay. I think we understand
7 the issue.

8 MEMBER BROWN: Thank you.

9 MR. CURRY: Yes. All right. Lighting,
10 again, just to -- and we were on the quick summary of
11 the lighting and the emergency lighting. And I think I
12 was down to the last bullet, the normal/emergency
13 lighting is backed up by the alternate ac power
14 source.

15 If we talk about the gas turbine gas-
16 generator support system, fuel oil storage and
17 transfer, I should have mentioned I think -- well,
18 we'll get to that. 9.5.5 is not applicable because
19 the GTGs are approved, so we won't be discussing
20 9.5.5.

21 The 9.5.4, you know basically is a summary
22 of the fuel oil storage and transfer system. And as
23 you see, typical components. Here's your simplified
24 drawing that follows. We have a fuel oil storage tank,
25 seven day tank with a day tank for 1.5 hours.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Redundant fuel oil transfer pumps supplying each GTG
2 set.

3 MEMBER BLEY: Because they're powered off
4 of their own GTG, the transfer pumps?

5 MR. CURRY: The transfer pumps? Tanaka-
6 san.

7 MR. TANAKA: The transfer pumps is
8 separated from own trained.

9 MEMBER BLEY: Untrained? So that -- okay.

10 MR. TANAKA: Yes, sir.

11 MEMBER BLEY: So if the generator is
12 working, you got power for the pump?

13 MR. CURRY: Starting system, starting air
14 system criterion is less than 100 seconds.

15 CHAIR STETKAR: Jim, I'm sorry.

16 MR. CURRY: Sure.

17 CHAIR STETKAR: Could you go back to the
18 drawing there? Are the fuel oil storage tank rooms,
19 they're below grade, right? Are they sealed against
20 flooding?

21 MR. TANAKA: Yes. Underground.

22 CHAIR STETKAR: They're underground now.
23 Are they completely sealed against flooding?

24 MR. TANAKA: Yes.

25 CHAIR STETKAR: The answer is yes? Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Thank you. Concern being, obviously, that they're
2 electrically driven pumps that have to work to support
3 the combustion gas turbine. So if the room is full of
4 water, it's not so good, unless they're really good
5 pumps.

6 MEMBER SHACK: Hermetically sealed
7 generators.

8 CHAIR STETKAR: Well, no. I mean the
9 generators can be above flood level. If you fill up
10 the generator rooms until the day tank is dry, and
11 then it starts to really --

12 MR. CURRY: Okay. Starting air, the
13 capacity -- and I should mention this all is related
14 to the Class 1E GTGs, and there are four of them.

15 Starting air capacity, three consecutive
16 GTG starts. Each system consists of air compressors
17 and the associated drain chambers and receivers and
18 staging. And there's a little schematic.

19 MEMBER SHACK: Is there some reason you
20 chose not to meet the SRP requirements for five
21 starts?

22 MR. CURRY: We think we do. And we have
23 some explanation for that.

24 I will point out we have four, four gas
25 turbines as opposed to diesel, so fundamentally that's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 where the answer lies.

2 MEMBER SHACK: Okay.

3 MR. CURRY: Okay?

4 CHAIR STETKAR: I think we did have some
5 discussion with that back in Chapter 8. I don't
6 remember the answer, but I know there was some
7 discussion. The staff asked it. There was some
8 discussion about, you know, why 3 is good enough.

9 MEMBER SHACK: Okay. So we've been there.

10 CHAIR STETKAR: So I think we've been
11 there.

12 MR. CURRY: All right. Lubrication.
13 Lubrication system is explanatory. Probably the
14 interesting bullet might be the last one: We do not
15 need a keep-warm system because the lube oil is
16 qualified under cold conditions.

17 CHAIR STETKAR: How cold is cold? How
18 cold? What temperature?

19 MR. TANAKA: Minus 20C.

20 MR. CURRY: Fahrenheit?

21 MR. TANAKA: Huh?

22 CHAIR STETKAR: Minus 20C is about what?
23 Minus 15 Fahrenheit?

24 MEMBER BLEY: That's about minus 5.

25 CHAIR STETKAR: Maybe minutes 5. Yes,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 about minus 4 or 5.

2 MR. TANAKA: But actually lubrication
3 system is contained in the -- is kept by the --

4 CHAIR STETKAR: Okay. Right, right,
5 right.

6 MEMBER SHACK: Minus four.

7 MEMBER BLEY: Minus four. I'm sorry.

8 CHAIR STETKAR: Okay. I'm sorry. It's
9 all installed in the gas turbine generator room,
10 right? Thank you.

11 MR. CURRY: And there's your simplified
12 schematic.

13 Air supply. Typical air supply system.
14 Conventional air and exhaust system, screens, louvers,
15 ventilation fans, duct work connections.

16 And that is the end of our presentation
17 for 9.5.

18 CHAIR STETKAR: Excellent. Do any of the
19 members have any other questions, comments for MHI?
20 We're waiting.

21 MEMBER BROWN: Can we go all the way back
22 to the beginning?

23 CHAIR STETKAR: Yes. You have even less
24 of a life than I do. This is great.

25 MEMBER BROWN: While I was multi-tasking

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 while I didn't know what you all were talking about,
2 or even less than what you all were talking about --

3 CHAIR STETKAR: Let's go back to the
4 beginning.

5 MEMBER BROWN: The water level gauges and
6 the temperature gauges, I should put under either
7 RAI--

8 CHAIR STETKAR: Spent fuel --

9 MEMBER BROWN: Spent fuel all the way back
10 -- way back to the beginning. This is all the way
11 back to the beginning of time. And I just wondered,
12 there seemed to be some inconsistencies or differences
13 between the original design and the change you made as
14 a result of the RAI. And then as a result of those
15 changes, then you changed the DCD Tier 1 and Tier 2
16 sections appropriately, and there's some
17 inconsistencies there. So, I thought I'd ask a couple
18 of questions.

19 Number 1, before there were two level
20 gauges, I'll talk about level first, and they
21 annunciated a high-low and low-low water level from
22 the MCR locally. That's what you all said in your
23 answer. That's not explicitly stated in the DCD, but
24 that is what you all said in your answer.

25 The new thing, instead of two level

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 gauges, you say you're going to have two level
2 switches to provide a low-low setpoint which will
3 annunciate to the MCR locally. So I presume the gauges
4 that monitor level have disappeared and now you just
5 have a low-low level alone, which also not only
6 annunciate, it also interlocks with the SFP pumps, the
7 spent fuel pumps to trip them off or to prevent their
8 starting if the water level is down there?

9 Okay. Just a difference. No gauges, and
10 you put a local, which sounds like a local nonsafety-
11 related, continuous monitoring gauge. And I presume
12 that's in the spent fuel pool area. And it measures
13 the rounds of levels, but it didn't appear to be that
14 you had any MCR, Main Control Room indication on that.

15 It wasn't clear.

16 MR. CURRY: So just to repeat, we have an
17 action item from this morning to clarify the level and
18 the temperature indication. And you're pointing out
19 that there's maybe an inconsistency in our --

20 MEMBER BROWN: Yes, and I'm going to
21 mention a few other ones --

22 MR. CURRY: Okay.

23 MEMBER BROWN: -- just to -- and if we're
24 going to clarify it at some point, I thought we
25 might--

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SHACK: Clarify it all?

2 MEMBER BROWN: Pardon?

3 MEMBER SHACK: Yes, clarify it all instead
4 of doing it twice. Okay. So that's just on the level
5 gauges. And I know I went faster than you could
6 write, so don't worry; I wrote this all down.

7 MR. CURRY: Okay. Appreciate that.

8 Yes. I was just going to ask you for the
9 references on the two items.

10 MEMBER BROWN: The RAI is 756-5763
11 Revision 3, dated August 10th. And that's your alls
12 response to the -- your alls response is August 10th.

13 MR. CURRY: Of 2011?

14 MEMBER BROWN: Yes, 2011.

15 MR. CURRY: Okay.

16 MEMBER BROWN: And it has all the other
17 detail as well as the original RAI in it, plus the
18 Tier markups for the Tier 1 and Tier 2 pages.

19 MR. CURRY: Okay.

20 MEMBER BROWN: Okay? So that's on the
21 level.

22 The second thing was on the temperature
23 gauges you went from one temperature gauge to two
24 temperature gauges Class 1E. Okay. My question on
25 that was related to: Where are they?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. CURRY: Right.

2 MEMBER BROWN: Are they distributed within
3 the pool somehow such that you can -- I mean, if
4 they're both stuck in the same, it's kind of useless.

5 MR. CURRY: That's right. And we
6 discussed and are pulling some detail on this.

7 MEMBER BROWN: Yes, that was the part of
8 that question.

9 MR. CURRY: Right.

10 MEMBER BROWN: The level gauges where
11 water goes up and down, so I wasn't -- maybe I should
12 be worried about that, but I wasn't.

13 CHAIR STETKAR: Well, the only question
14 that comes up is if they only alarm at low-low level,
15 you know what is low-low level?

16 MEMBER BROWN: The cavitation point.

17 CHAIR STETKAR: Yes, that's pretty high
18 level --

19 MEMBER BROWN: The cavitation.

20 CHAIR STETKAR: -- pretty high level in
21 the pool. It's not a continuous --

22 MEMBER BROWN: I don't know where the
23 pumps take suction, so --

24 CHAIR STETKAR: Pretty high up.

25 MEMBER BROWN: Well, that's the other

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 point I hadn't gotten to yet. They do have a -- there
2 is a topical report for the thermal hydraulic analysis
3 that says without -- boil in about 22 hours.

4 MR. CURRY: Okay.

5 MEMBER BROWN: So, that's a number.

6 CHAIR STETKAR: That's for the Design-
7 Basis heat load ten years worth of spent fuel --

8 MEMBER BROWN: Whatever it is, yes.

9 CHAIR STETKAR: -- and full core offload.
10 But, yes, I remember that number.

11 MEMBER BROWN: But they also apparently
12 trips -- the ECCS system trips the SFPs off, the load
13 sequencer does, and it does not restart them. They
14 have to be restarted manually. I have no idea what we
15 do in other plants, but I don't know if that's
16 consistent or not. The loss of offsite power trips
17 then on under voltage, that's kind of obvious. But
18 then the low-low setpoint locks out. And I guess my
19 concern, because it's interlocked. Now, I'm to come
20 with an interlock, per se, because you obviously don't
21 want to burn up the pumps if you can help it before
22 you have water back in there that you can do something
23 with, but if you have an interlock failure of -- you
24 ought to be able to override some types of interlocks.
25 And whether that's done manually or how that's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 accomplished, but you ought not be permanently locked
2 out.

3 CHAIR STETKAR: Charlie, you're reading or
4 you have something that I don't think I've seen.

5 MEMBER BROWN: Well, this is the RAI.

6 CHAIR STETKAR: Yes. You used the term
7 "locks out." Is that --

8 MEMBER BROWN: Used the term interlock.

9 CHAIR STETKAR: An interlock? Okay.

10 MEMBER BROWN: Okay. And when I read an
11 interlock, to me that's an interlock for the pumps.
12 It turns it off. If you're running the pumps and the
13 level goes down, it interlocks them in, turns them off
14 and they use the term "interlock" in here. So I
15 presume an interlock means it's interlocked, you can't
16 start them if the load is below that. And they don't
17 talk about an override.

18 CHAIR STETKAR: Well, yes.

19 MEMBER BROWN: What if the interlock
20 fails, you get water pump back in and now you want to
21 run it but you can't start them? That's the point.

22 MR. CURRY: Right.

23 MEMBER BROWN: In one of your paragraphs,
24 someone tends to look at one of your answers, it was
25 on the discussion of the operational -- during the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 loss of offsite power the pumps trip off. Then you go
2 through a scenario of 22 hours and what it needs to do
3 to restart them. And you talk about when the level is
4 -- of the low level alarm setpoint, not a low level.
5 And it looks like low-low and high have all been water
6 level -- it looks like they've disappeared. They were
7 in some of your previous discussions, but not in the
8 revised one.

9 So I'm just saying you ought to go --
10 somewhere along the line you and the staff ought to
11 come to congruence as to consistency as to
12 consistency. And I don't know if this has been
13 resolved yet or it's still an open.

14 CHAIR STETKAR: We'll ask the staff when
15 they come in.

16 MEMBER BROWN: Yes. Because it's just a
17 matter of getting consistency. I mean, I kind of
18 piddled around with this and since I was interested in
19 it while we were talking.

20 CHAIR STETKAR: Yes. So, Jim, kind of
21 what I've taken away, there's kind of an open issue
22 and we'd kind of at a high level we'd like to
23 understand details. But if I can characterize it at a
24 high level, we'd like to understand how the level
25 instrumentation, you know the current concept of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 design, how it's designed, what signals does it
2 provide, does it provide continuous displays, where
3 are those displays and how do the trip and interlock
4 signals for the spent fuel pit cooling pumps interact
5 with those levels? In other words, does the low-low
6 level signal -- or whatever it is, trip and lock out
7 the pump, do the operators have to reset that signal,
8 does it reset automatically at some other level, what
9 is it? So basically, the kind of design of those of
10 those level signals and what they do.

11 And, you know less complex, but for the
12 temperature signals at what places in the spent fuel
13 pit are those temperature measurements taken?

14 MR. CURRY: Yes.

15 CHAIR STETKAR: Are they somewhat
16 representative?

17 MEMBER BROWN: There was one other.
18 Again, this might just be editorial. When you talked
19 about a revision piece in Tier 2 DCD describing the
20 temperature instruments, you talk about two
21 temperature instruments are installed. If it's high,
22 they would annunciate it to MCR and locally. Then
23 you use singular temperature transmitter is provided
24 to monitor the temperature. Does that different? Are
25 the other ones just alarm units only? For some reason

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 you got one that's monitoring over the range? I just
2 couldn't -- it's just inconsistency in terminology.
3 That's why we really would like to know what are the
4 ranges. Are they all continuous, whether they display,
5 et cetera? And it's a little bit cryptic as you try
6 to dig through the tables and stuff; that's all.

7 MR. CURRY: Yes. Thank you. I appreciate
8 that.

9 And just to clarify, the inconsistency in
10 terminology within the RAI response or are you
11 comparing to some other --

12 MEMBER BROWN: I'm comparing here. What
13 you all -- you're very clear. Okay. Your answer went
14 through a discussion of what you had and what you were
15 going to change to in the discussion. Then you
16 provided an impact on DCD write-up which showed what
17 changes you were going to do to the DCD to incorporate
18 your discussion part of the write-up of what you're
19 going to do. So, there's some inconsistencies between
20 them, and it looks like you went from level gauges to
21 just level switches. And there's only one local
22 continuous monitor, and that's in the spent fuel pool
23 within the reactor building.

24 CHAIR STETKAR: I mean, some of it if we
25 had a better understanding of what the current design

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 really looks like, some of that might --

2 MEMBER BROWN: And my personal interest is
3 that we get something laid down fairly concretely so
4 that two different people looking at the designs can
5 interpret it such that you don't end up with what we
6 really thought we were getting in the end. So, you
7 don't have to say what they are, but what are they
8 supposed to do and how many of them, and where are
9 they. Okay. And where they indicate and annunciate,
10 et cetera.

11 So, that was overall -- thanks for
12 bearing --

13 CHAIR STETKAR: You want to go to like
14 page 2 now?

15 MEMBER BROWN: No, that's it.

16 CHAIR STETKAR: Any other comments,
17 questions by any of the Members? If not, I like to
18 thank MHI, MNES and Holtec in their absence for what I
19 think a really, really good discussion. Good
20 presentation. We'll probably have more discussion
21 late, you know tomorrow if we get some of the
22 questions answered in kind of a real time.

23 But I'd like to thank you very much. I
24 thought it was a well structured presentation, and I
25 think we had a good discussion.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 And we will recess until 3:05, and then
2 hear from the staff.

3 (Whereupon, at 2:49 p.m. off the record
4 until 3:08 p.m.)

5 CHAIR STETKAR: We are back in session.
6 It's time to hear from the staff.

7 Paul?

8 MR. KALLAN: Okay. Thank you.

9 My name is Paul Kallan, again.

10 CHAIR STETKAR: I'm sorry. Do we have your
11 handouts? Thank you.

12 MR. KALLAN: All right. Now this is the
13 presentation to the Subcommittee on Chapter 9 for the
14 Safety Evaluation with open items.

15 Just quickly, the staff team it's the
16 staff that will be presenting today is Larry Wheeler,
17 and he's a reactor systems engineer. He'll be going
18 over 9.2.1 and 9.2.2.

19 Angelo Stubbs, he's a senior reactor
20 systems engineer and he'll be going over DCD Section
21 9.2.6.

22 And David Nold, he's a reactor systems
23 engineer and he'll be going over Sections 9.4.1 and
24 9.4.5.

25 The Lead Project Manager is Jeff Clocco,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and he's not here today. And I'm just basically
2 running the show.

3 Slide 3 and 4 is just the staff team.
4 There's a large number of staff that worked on this
5 document. And so I just listed them all in there.

6 Slide 5 is a table that basically what I
7 did is I put the SRP, the section, the number of
8 questions and the open items that related. And I think
9 I'm not going to go over each section, but I just
10 wanted to make sure that we listed all the sections
11 with the open items and the questions, the amount of
12 questions we get for each section.

13 There was approximately on Slide 10, we
14 had 603 questions and 20 open items. We decided that
15 staff wanted to only talk about certain significant
16 open items which we're going to be presenting today
17 that were of interest to the ACRS. And we're not going
18 to go over all 20 of them.

19 And with that, I'm going to go to Slide 11
20 and turn it over to Larry Wheeler.

21 CHAIR STETKAR: Actually, Larry, no you're
22 not. Because you're not going to skip over the fuel
23 pool stuff, but we -- at least I have some questions
24 about it. So, I hope you have somebody here to answer
25 them.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 In SER Section 9.1.3.4 under GDC 61
2 there's a statement that says DCD Tier 2 Section
3 9.1.3.1 Design Basis states that the spent fuel pool
4 pit -- I'm sorry, cooling system is designed to
5 maintain the water temperature below 48.9 degrees C,
6 120 degrees F with a newly operated half core and a
7 fully loaded spent fuel pool with a single active
8 failure preventing the use of one cooling train. With
9 the additional capacity the residual heat removal
10 system an entirely newly off loaded core can be
11 handled without the water temperature rising above 60
12 degrees C, 140 degrees F. This also accounts for the
13 possibility of a single active failure, therefore the
14 spent fuel pool cooling system design meets the
15 recommendations of SRP Section 9.1.3(iii)(1)(D).

16 And I'm not going to do the quote from the
17 DCD because that's even longer. But if I read the DCD
18 and read your statement, they're not consistent. And
19 the reasons that they're not consistent are that the
20 DCD seems to say that with a fully loaded spent fuel
21 pit and the head load from a newly off loaded partial
22 core, it can maintain -- the spent fuel pit cooling
23 system can maintain spent fuel pit temperature at 140
24 degrees with a single active failure. You say a 120.

25 And I'm not sure about the other

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 conditions with full core.

2 So, I'm curious about whether the
3 conclusions of your analysis about what a single
4 active failure is and what the temperature would be,
5 because the statements in the DCD and the statements
6 in the SER don't seem to be consistent. Now I'm not
7 concerns about boiling here, but I'm concerned about
8 is there a consistent understanding of the conditions.

9 And quite honestly, I had to craft myself a little
10 table that said if I have a half core or a full core
11 and how many trains of spent fuel pit cooling system
12 do I have running, what is the resulting temperature.

13 And from the DCD I get one train of spent fuel pit
14 cooling, what half core gives me 140. You say 120.
15 And then I'm not sure under the full core conditions
16 what a single failure means because I'm not quite sure
17 how many trains are RHR and core spray are accounted
18 for.

19 So, I'm not sure if you have anybody here
20 to address that part of the --

21 MR. HERNANDEZ: I'm really here from the
22 spent fuel pool.

23 CHAIR STETKAR: Give your name first.

24 MR. HERNANDEZ: Yes. My name is Raul
25 Hernandez.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 You gave a lot of quotes there, so I'm
2 going to ask you in a break give me the exact system
3 failures, the exact areas of your scenario, so I can
4 look it up and give you a straight answer.

5 CHAIR STETKAR: Yes. Let me give it to
6 you on kind of the record here. It's Section 9.1.3.4
7 of the SER. Because my recollection is that that's a
8 long section. It's under GDC-61. And the
9 corresponding section of the DCD is .1.3.1.

10 MR. HERNANDEZ: Okay.

11 CHAIR STETKAR: And so you may want to go
12 look at those.

13 MR. HERNANDEZ: Basically right here we're
14 talking about the normal offload scenario, that one is
15 the partial offload --

16 CHAIR STETKAR: Okay.

17 MR. HERNANDEZ: Maybe you weren't here
18 when we discussed the full core of load we consider
19 like the abnormal emergency scenario.

20 CHAIR STETKAR: That may be the way you
21 think about it, but this morning I asked MHI the
22 question about what is the practice in Japan, and
23 currently the practice of many plants in the United
24 States is for every refueling outage they offload the
25 whole core. So therefore, the normal condition is a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 full core sitting in the spent fuel pit for some
2 period of time.

3 MR. HERNANDEZ: And many designs are like
4 that, but the way it was presented on the DCD the
5 normal offload is like partial, the way that it was
6 presented in the DCD.

7 CHAIR STETKAR: Okay. I guess we need to
8 get clarification of that because I don't think it
9 makes any difference -- I don't know. I mean, in terms
10 of decisions about adequacy of cooling systems, except
11 for the fact that it's fairly clear that if you have a
12 full core offload, you need to supplement the cooling
13 with at least one train of contain the spray RHR.

14 MR. HERNANDEZ: Yes.

15 CHAIR STETKAR: So that enters the mix.
16 Apparently the normal spent fuel pit cooling system,
17 even with both trains, I don't know what the
18 temperature is with the full core offload. And if,
19 indeed, the normal practice will be to offload the
20 full core during every refueling outage, those then
21 become the normal success criteria for the compliment
22 of cooling systems. Follow me? I mean if that's the
23 way the plant will do business is to offload the full
24 core, that in my mind is the normal way to offload.

25 Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: Which part of the DCD did
2 you read?

3 CHAIR STETKAR: 8.1.3.1.

4 MEMBER BROWN: Well, I looked at 9.1.3.3.1
5 and it looked like that was maybe even inconsistent
6 within the DCD. But --

7 CHAIR STETKAR: I didn't try to look for
8 consistency within the DCD.

9 MEMBER BROWN: Yes. It says in case of a
10 single SFPS cooling system failure, one SFPS pump and
11 one heat exchanger in service will maintain a
12 temperature below 140 with a half core offload. That's
13 with one spent fuel --

14 CHAIR STETKAR: And that's what I got.
15 Sorry.

16 MEMBER BROWN: Then it goes on with a full
17 core offload you have to have one train plus two RHRs
18 or two trains and one RHR --

19 CHAIR STETKAR: Right.

20 MEMBER BROWN: -- at 140.

21 CHAIR STETKAR: Right.

22 MEMBER BROWN: So the numbers stayed the
23 same, whereas if you look the SER they had a number
24 like 124 or --

25 CHAIR STETKAR: Right. The DCD, as far as

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I could tell, hung together consistently. It was the
2 SER's quoted configuration and temperatures didn't
3 seem to --

4 MEMBER BROWN: For the half core looked to
5 be --

6 CHAIR STETKAR: For the half core seemed
7 to be low and --

8 MEMBER BROWN: But they didn't use just
9 the -- they said "a newly" -- that's where the SER was
10 fuzzy. So it says "Designed to maintain water
11 temperature below 120 with a newly offloaded half core
12 and a fully loaded SRP with the single failure." And
13 the DCD didn't talk about a fully loaded SRP. It just
14 talked about a --

15 CHAIR STETKAR: Well, all the conditions
16 are done with a fully loaded --

17 MEMBER BROWN: Okay. It just stated --

18 CHAIR STETKAR: That's ten years of spent
19 fuel, basically plus whether you have the half core

20 MEMBER BROWN: That's fine. That just
21 quoted the standard assumption then.

22 CHAIR STETKAR: Anyway, if you could go
23 back at that. The key is a single failure of what and
24 what temperatures apply under what core loading, you
25 know fuel pit loading conditions.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 As I said, it's not a concern in terms of
2 fundamental safety. It's a concern of making sure
3 that the staff and the applicant are both
4 understanding all of these combinatorics accurately.

5 MR. HERNANDEZ: Yes. It's not a limiting
6 condition, but it's a consistency issue, I understand.

7 CHAIR STETKAR: Right. Right. Okay.

8 Let's see. Do I have any more on -- yes, I
9 do.

10 MR. KALLAN: Do you have any other
11 questions?

12 CHAIR STETKAR: Yes, I do and I'm not sure
13 -- you know, this is curiosity. There was a
14 confirmatory item. Charlie brought it up earlier and
15 I was going to wait to ask you.

16 We know that the spent fuel pit cooling
17 pumps are not automatically reloaded onto the Class 1E
18 buses. They must be loaded manually. And apparently
19 under the design loading conditions, apparently
20 there's a time window of about 2.7 hours to restore
21 spent fuel pit cooling before you start to boil
22 starting from the minimum level conditions.

23 And there's a confirmatory item, 8.1.3-8
24 that apparently addresses sort of design related
25 things.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 I don't see any COL information items, and
2 I don't know how those things work about specific
3 procedural guidance so that the operators know that
4 they need to do this. And the reason this is
5 curiosity is I don't know what level of -- I know the
6 plant has to develop emergency operating procedures.
7 I'm presuming that they would capture this, but
8 sometimes presuming is dangerous.

9 MR. HERNANDEZ: This item came about of
10 having a lost of offsite power coincident with a LOCA.

11 That was the condition that initiated this scenario.

12 You have a LOCA and a loss of offsite power at the
13 same time. That's more than the sequencing for the
14 ECCS kicks in and the spent fuel pumps were not in
15 that sequence. That was exactly the thing.

16 I'll ask the applicant on a RAI to clarify
17 why the pumps were not loaded --

18 CHAIR STETKAR: Yes.

19 MR. HERNANDEZ: -- in the sequence and
20 they credit the -- it's not a timing issue. There is
21 plenty of time; that's where you see the two hours for
22 maximum heat load. And then we asked them if that's
23 the approach that we're going to take, that they get
24 plenty of time, how are they monitoring the
25 conditions? And that's where they upgraded the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 temperature and that would indicate a --

2 CHAIR STETKAR: Safety redundancy.

3 MR. HERNANDEZ: -- a safety redundant
4 level.

5 In the RAI response they mentioned that
6 the operator in the control room checks the level on
7 the spent fuel pool before initiating the pumps again.
8 If makeup is needed, they can initiate that from the
9 spent fuel pool.

10 The description of the procedure is, it
11 wasn't lengthy or complicated, it was simply a couple
12 of actions. But I understand why you're asking that.

13 CHAIR STETKAR: Yes, and a couple of
14 questions since you've obviously looked at this in
15 more detail than I have. Is it only under the, let's
16 call it a LOCA plus loss of offsite power condition
17 where the spent fuel pit pumps are not reloaded? In
18 other words, suppose I just have a loss of offsite
19 power? Are the spent fuel pit pumps reloaded onto the
20 gas turbines for only a loss of offsite power?

21 MR. HERNANDEZ: It's my understanding that
22 they are, yes.

23 MEMBER BROWN: And again, that's not clear
24 from reading the --

25 CHAIR STETKAR: Can I get somebody from

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MHI to confirm that?

2 MR. HERNANDEZ: They are powered from a
3 Class 1E power, so it's just in the scenario that it
4 wasn't that they specified that they had this loaded
5 sequence in the spent fuel pool --

6 CHAIR STETKAR: Okay. They had a couple
7 of loaded sequences.

8 MEMBER BROWN: Okay. You're in loss of
9 offsite power, the SFP pump will trip under the LOCAs
10 and then will not be automatically reactivated by the
11 sequencer?

12 CHAIR STETKAR: That would be pretty
13 clear. Thank you. So therefore, I don't care about
14 the coincident LOCA. I care about anytime I lose
15 offsite power, I lose --

16 MEMBER BROWN: But there's that point:
17 There was an inconsistency between the DCD --

18 CHAIR STETKAR: Yes.

19 MEMBER BROWN: -- within the DCD and they
20 clarify that and they came back and said "Oh, no.
21 This is the way it is. And so they rewrote it and that
22 was the proposed change to 9.1.3.3.1

23 CHAIR STETKAR: Okay.

24 MEMBER BROWN: And also the ECCS also
25 trips them off in the load sequence.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: Yes, I mean that makes
2 sense.

3 MEMBER BROWN: The header for loss of
4 offsite power didn't make a lot of sense.

5 CHAIR STETKAR: So now I understand, you
6 know when they don't work and I understand that we
7 have safety-related instruments. My question is I
8 don't know because I haven't been through enough of
9 these at what level -- what trips the staff concerns
10 about COL information items? In other words, there
11 are no EOPs for this plant. The EOPs are the
12 responsibility of the COL Applicant.

13 One can take the approach of presuming
14 that people write the EOPs perfectly or one can flag
15 things that ought to be considered by the COL
16 Applicant. And I don't know what the staff does in
17 those issues.

18 In other words, simply have safety-related
19 instrumentation, simply having the ability to close a
20 switch, everybody always likes to take credit for the
21 operators always doing a perfect thing at the perfect
22 time because they have perfect information and perfect
23 knowledge. We know better now. They don't, unless
24 they have training procedures to tell them that they
25 ought to be concerned about these functions.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 So I think what I'm asking from the staff
2 is ought there be a COL information item to flag the
3 fact that instructions for restoration of spent fuel
4 pit cooling should be integrated into their emergency
5 operating procedures, or is that simply a presumption?

6 MEMBER BROWN: Well, with the change in
7 the level indication there's only one level
8 indication. The others ones are switches now as
9 opposed to gauges. So I don't know how the Main
10 Control Room operators is going to know unless there's
11 somebody out in the reactor building, if that's where
12 it is. That's why we've asked for the clarification.

13 So all we've got is the annunciator having
14 told him there's him there's a low-low level alarm.
15 It's not on, so you can manually restart the pump if
16 he knows to do it.

17 CHAIR STETKAR: If he know to do it?

18 Okay. Well, I'm not hearing anything
19 back, so I'll just -- and I'm not necessarily
20 proposing that -- you know, we don't propose
21 anything. I'm just sort of raising the generic
22 question that as you go through these reviews and you
23 identify in this case a function that relies
24 completely on operator action, is it the presumption
25 that the procedures will know that and take care of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that simply because people say "Well, it's really easy
2 to do" and they'll have a lot of indications
3 available, and there's a couple of hours available to
4 do it? And that's kind of a generic question to the
5 staff.

6 MR. HERNANDEZ: I don't have an answer for
7 you right now.

8 CHAIR STETKAR: I think the point has been
9 made.

10 This is kind of a minor thing, but again
11 it's a question about kind of consistency. This talks
12 about there is some concerns about the time and
13 capability to clean up the spent fuel pit and the
14 RWSP. And apparently this comes back to, I guess
15 there's some 72 hour time limit required by ANSI/ANS
16 57.2 Sections 6.3.2.10. Something I'm intimately
17 familiar with, I guess.

18 So there is analyses done here that says
19 that the purification stream is designed for -- I'm
20 not going to quote the thing, but 265 gallons a
21 minute. And if you take the total volume of the
22 refueling water storage pit plus the volume of the
23 spent fuel pit, it says you can pump that water,
24 circulate the entire volume once in 64 hours. And then
25 the SER goes on to say that since there are two

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 independent streams, the entire system could be
2 processed in about 32 hours. And all of that is true
3 except for the fact that there is a pinch point in the
4 system where there is a single pipe where you come
5 back from the two purification streams, go through a
6 single pipe and then go back to the two refueling
7 water storage pit recirculation pump.

8 So, the question is is that pipe big
9 enough to actually pass twice the flow rate? If it
10 isn't, you know your assertions about 32 hours about
11 32 hours don't quite hold because they're not two
12 completely independent parallel trains. They are on
13 both ends of this single pipe systems.

14 So, I'm wondering if you thought about it?
15 It doesn't make any difference, because even with a
16 single train, you get under the 72 hour magic number,
17 which apparently is important.

18 MR. HERNANDEZ: That is --

19 CHAIR STETKAR: But if that 32 hours is
20 something that you used in your decision as confidence
21 of additional margin, that may be an artificial level
22 of confidence depending on the limitation flow through
23 that common line

24 MR. HERNANDEZ: I cannot answer that
25 question. That is reviewed by the Chemical Engineering

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Branch, is a different reviewer who looks at that
2 aspect, at the purification portion of the system.

3 CHAIR STETKAR: Okay. Take that away.
4 I'm just searching for things where the SER may -- and
5 I want to make sure that the SER doesn't impart an
6 artificial sense of confidence or margin where that
7 margin may not be available. Okay.

8 IF you're looking at it, the reference
9 section of the SER is 9.1.3.4 under the chemistry
10 stuff. It's GDC 14 and 16. Okay.

11 Bear with e here. I've got too many pieces
12 of paper.

13 This again, there's statements, they sound
14 like petty things, but again these are public
15 documents that indeed express our level of
16 understanding and review. And in SER Section 9.1.4.4,
17 which is light load handling system, but it's in
18 particular reactor cavity sealed, and I don't know who
19 was responsible for that Apparently there's shuffling
20 going on. And while the shuffling goes on -- this
21 statement says "The staff evaluated the RAI response
22 and determined that the refueling cavity and connected
23 openings are designed with features that preclude the
24 rapid draindown of the reactor cavity. The staff also
25 determined that any refueling cavity leakage will be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 less than the available makeup capability."

2 Now, the staff has made this
3 determination. I didn't find that statement anywhere
4 in the DCD, I looked for it; that's why I didn't ask
5 MHI.

6 I'd like to understand how you determined
7 that any, meaning any possible refueling cavity
8 leakage will be less than the available makeup
9 capability. I'd like to see the supporting analysis
10 for that.

11 You probably don't have it available, so
12 if you can find it, we'd like to see it.

13 MR. KALLAN: No.

14 CHAIR STETKAR: Well, it says "The staff
15 determined that any refueling cavity leakage," so you
16 must have looked at all the leakage pathways, the
17 possibility that they can be opened and compared them
18 to the makeup capability, and there must be some
19 justification for that. I'd like to see it, or
20 perhaps that statement is a bit overstating the real
21 world. Okay.

22 Let' see -- now, heavy load handling
23 system? Suddenly there's a sigh of relief and the
24 pitter-patter of feet running out the back.

25 And I had a question. The basic question I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 had is that I think you had some question RAIs about
2 the scope of the heavy load handling cranes that were
3 evaluated. Initially, I think they talked about the
4 Polar Crane and the Cask Transfer Crane. And there
5 might have been one more, I've forgotten. And they,
6 indeed, you know added a number of local cranes'
7 place, whatever you want to call them, to that list
8 and addressed those.

9 The DCD tables specifically, and it's
10 Table 9.1.5-3 in the DCD addresses cranes in place
11 installed over safe shutdown equipment. And one of my
12 questions is in the SER, and this is the SER Section
13 9.1.5.4, there's constantly in my mind this question
14 about what our SSCs important to safety versus safe
15 shutdown equipment. In particular, I'll ask you I'm
16 assuming that there's a very large overhead crane in
17 the turbine building, and are there any SSCs important
18 to safety, not safe shutdown, not safety-related, but
19 SSCs important to safety in the turbine building that
20 could be damaged by drops from that crane?

21 MR. CURRAN: This is Gordon Curran from
22 Balance of Plant.

23 I think that was an open item that they
24 had earlier where they were discussing where you asked
25 if there was any safety-related equipment in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 turbine building, if that's what you're asking.

2 CHAIR STETKAR: No. I'm getting a little
3 broader than that because it's this notion of -- I did
4 ask that question, and I believe -- and I heard that
5 there is an open item on that. In some sense, I'm
6 asking about what is the -- you're going to quote
7 directly from the SER. In its response, dated May 25,
8 2009, MHI referenced UAP-HF-09260. "The Applicant
9 acknowledged the need for more detail on the cranes
10 and hoists installed where load drops could result in
11 damage to SSCs important to safety. Included in the
12 DCD is Table 9.1.5-3 Cranes and Hoists Installed over
13 Safety Shutdown Equipment identifying cranes and
14 hoists including their respective seismic category and
15 single failure proof status."

16 My question is, is important to safety in
17 the staff's mind equivalent to safety-related and
18 equivalent to safe shutdown?

19 MR. CURRAN: Safe shutdown equipment?

20 CHAIR STETKAR: Right.

21 MR. CURRAN: Yes. I was writing as if
22 there was no components that would be effected by a
23 drop -- excuse me. No safe shutdown equipment that
24 would be effected by the drop in the turbine building.

25 CHAIR STETKAR: Okay. Okay. I understand

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that now. That's a bit different, though, then there
2 have been numbers of discussions about the issue of
3 SSCs important versus -- and for example some safety-
4 related equipment may not be considered safe shutdown
5 equipment. So we're really talking about kind of three
6 categories of equipment here.

7 Safe shutdown is typically something that
8 in a deterministic analysis somebody identifies as
9 this is my minimum compliment of equipment that's
10 required to achieve safe shutdown.

11 Safety-related has to with the -- you
12 know, it's actually a broader set of equipment that's
13 required to satisfy the Design-Basis Accident
14 Analysis.

15 And then I see this in several staff
16 reviews, is this issue of SSCs important to safety.
17 And the only reason I bring it up, it's not a
18 semantics issue; is that as part of the Design
19 Certification there will be developed a Design
20 Reliability Assurance Program. And that Design
21 Reliability Assurance Program will have a population
22 of SSCs in it. And those SSC are sometimes they're
23 called risk-significant, sometimes they're called
24 important to safety, but it's more than the safety-
25 related equipment. It's a set of nonsafety-related

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 equipment that's for a variety of quantitative and
2 qualitative issues that's determined to be important
3 enough to safety that it requires additional assurance
4 of its reliability, typically through the Maintenance
5 Rule PProgram. And I want to be sure if, for example,
6 that there's something in the turbine building that
7 makes it onto that D-RAP list, do we then need to
8 worry about dropping really heavy loads onto it?

9 And I don't know. As I said, I'm not
10 familiar enough with how the whole review process
11 goes. But that's sort of the genesis of my question.

12 And I understand now a little bit about
13 what you were doing a little bit better. And I don't
14 know what the D-RAP list is yet, because I don't think
15 we've seen it and it may not exist yet.

16 So leave that as kind of a question. I'm
17 not sure how you approach that yet, because it's one
18 of these sort of integration issues that we don't
19 necessarily identify equipment that requires
20 additional scrutiny for its reliability, but then
21 ignore the fact that it might be damaged by other
22 things.

23 Okay. Let's talk about Essential Service
24 Water.

25 MR. WHEELER: Okay. 9.2.1.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Good afternoon. My name is Larry Wheeler
2 with the Balance of Fleet Branch. Let's talk about
3 9.2.1, Essential Service Water.

4 MHI previously described the ESW system.
5 That design included the conceptual design of the
6 four-trains of ESW, blowdown, strainer backwash
7 connected to a common safety-related header. One
8 isolation valve, the AOV-577 provided the safety-
9 related to nonsafety-related boundary to the
10 circulating water blowdown main header.

11 During the review of the Comanche Peak COL
12 application it was discovered that neither of the COL
13 Applicant nor the DCD Applicant had adequately
14 described the power supplies, the I&C logic, the
15 failures and effects analysis for this boundary. So
16 we kind of got on the phone, we talked about it and
17 decided that an RAI would go to MHI and DCD, and they
18 would evaluate the AOV-577 and give us additional
19 information.

20 CHAIR STETKAR: So essentially the DCD
21 owns that valve now, is that the way to understand it
22 or am I -- it's not quite that simple?

23 MR. WHEELER: I would say that the COL
24 Applicants determine whether that conceptual design
25 information applies to them.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIR STETKAR: Okay.

2 MR. WHEELER: And then they get design
3 description.

4 CHAIR STETKAR: Okay. Okay.

5 MR. WHEELER: That's why I was hoping that
6 Comanche would pick this up. But during the phone
7 call --

8 CHAIR STETKAR: Yes, it's right at -- yes.
9 I read that.

10 MR. WHEELER: Because that AOV is
11 described in the DCD under the thermal effects
12 analysis, it kind of drowns out the DCD.

13 CHAIR STETKAR: Yes. Okay. Okay.

14 MR. WHEELER: But then North Anna has
15 decided not to use that valve, so that's another
16 story.

17 CHAIR STETKAR: Okay. But essentially if
18 I understand it, you're saying that the functional
19 requirements for that valve if it exists, are
20 specified in the DCD?

21 MR. WHEELER: That's correct. It should--

22 CHAIR STETKAR: Whether or not somebody
23 actually uses the valve or has that configuration as
24 part of the COL --

25 MR. WHEELER: Because the DCD --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: -- but if they do have
2 something that looks like that, they need to meet
3 those functional requirements?

4 MR. WHEELER: The conceptual design I
5 believe.

6 CHAIR STETKAR: Yes, conceptual design.
7 Okay.

8 MR. WHEELER: That's all I have on 9.2.1.
9 I'm going to go on to 9.2.2. What I'd like to do, Mr.
10 Chairman is talk about 9.2.1 and 9.2.2, then talk
11 about some of the questions you had from the staff
12 from this morning. And then I can turn that on to
13 Angelo.

14 CHAIR STETKAR: Okay. I know you'd like
15 to do that. You're probably not going to be able to
16 do that.

17 MR. WHEELER: Okay.

18 CHAIR STETKAR: The reason I wanted to
19 flip ahead is I didn't know if you had a slide on of
20 the ultimate heat sink, and you don't.

21 MR. WHEELER: I do not.

22 CHAIR STETKAR: So I'll bring it up under
23 the Essential Service Water System.

24 I asked it this morning, and if you're
25 going to address it later as part of the plan, this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 notion of why 30 hours for an ultimate heat sink and
2 36 hours for a cooling pond.

3 MR. WHEELER: You mean 30 days or --

4 CHAIR STETKAR: I'm sorry. Days -- days.
5 I can't read my own writing. Were you going to
6 address that later?

7 MR. WHEELER: Yes.

8 CHAIR STETKAR: Okay. Good. I'll wait
9 then and you can continue with your plan.

10 MR. WHEELER: Okay. Moving on to 9.2.2
11 Component Cooling. Of course, MHI previous described
12 the CCWS system. That design includes a 3100 gallon
13 surge tank between the CCWS trains. The CCWS train or
14 pumps take a section from that common surge tank, and
15 there's no safety-related make-up to that surge tank.
16 In addition, there is no automatic valves that
17 separate the trains out during an accident.

18 There are plant conditions in which bulk
19 CCWS pumps coming off the common surge tank may be
20 operated at the same time, unless for example during a
21 plant startup and cool down.

22 The CCWS system is considered a moderate-
23 energy system. A pipe break in the moderate-energy
24 system has potential to draw in the common CCWS surge
25 tank. Details of the postulated pipe break and the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 common CCWS header has not been adequately addressed
2 by MHI, thus this is an open item.

3 We did receive the RAI response at the
4 beginning of this month. The staff is still looking at
5 the evaluation of that RAI response. It looks
6 favorable that we'll be able to close this item out.

7 A little bit of the details of the RAI
8 response is if the stress level for a safety-related
9 Class 3 component, if the stress levels are low enough
10 below a threshold, you don't need to postulate a pipe
11 leak. And that's still being reviewed by the staff.

12 CHAIR STETKAR: Okay. They're going to
13 take the approach that you don't have to postulate it?

14 MR. WHEELER: You don't have to postulate
15 it if the stretch levels are below a certain value.

16 CHAIR STETKAR: Well, that make sense, but
17 I'll have to see.

18 MR. WHEELER: Yes. Of course, that's
19 different than high energy line break.

20 CHAIR STETKAR: I'm sure. That's right.

21 MR. WHEELER: So that closes the 9.2.1 and
22 9.2.2 discussions. So what I'd like to do is kind of
23 get over some of the items from this morning. And one
24 of the items to the staff that I had heard was the DCD
25 roughly versus this interim Rev. 4. What happened was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the staff had asked MHI for an interim Rev. 4 to
2 simplify the staff's the SER on the safety-related
3 systems. And this kind of follows suits with what we
4 did on EPR.

5 CHAIR STETKAR: Yes.

6 MR. WHEELER: For some of these four
7 safety-related systems, the staff generated over 150
8 RAIs. So for the staff to go through and talk about
9 150 RAIs through the SER would be very confusing.

10 When I started off doing the EPR 9.2.2
11 review, the SER turned out to e 120 pages. And by
12 going on this type of concept, being able to shrink
13 that SER down to less than 20 pages. So that's a
14 little explanation of why the interim Rev. was so
15 important to the staff. It shortened our review and
16 OGC's review and, obviously, your review.

17 MEMBER BLEY: Yes. I would say we
18 appreciate it too, but there were some other design
19 similar so that every time you'd raise a question, it
20 had already been solved. So thank you.

21 MR. WHEELER: Yes. The other question
22 that I picked up from this morning is related to this
23 cross-typing of CCWS trains that these NOV 7 series
24 and 20 series valves. Originally I think in Rev. 2
25 that these valves got local signals to close and you'd

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 have separation A and Train B, C and C and D.

2 Because the concerns with the loss of flow
3 to the thermal barrier, this was MHI's design approach
4 to ensure flow to the thermal barrier, but it causes
5 other issues. And at the end, the train separation.

6 So for this issue there is a COL
7 information item, 13.5.6. And there's operator action
8 that's required by the COL to address isolating the
9 trains within 24 hours. And in my SER there's a kind
10 of a discussion about where the 24 hour came from the
11 discussion was related to a SECY paper.

12 The other question that you had was --

13 CHAIR STETKAR: Can I stop you --

14 MR. WHEELER: Sure.

15 CHAIR STETKAR: -- because I want to
16 follow-up on that a little bit. First of all when I
17 asked the applicant this morning about the change to
18 the design, they essentially said "Well, it was
19 initiated because the Standard Review Plan says that
20 you shall not have any automatic isolation for the
21 CCWS flow to the reactor coolant pump thermal
22 barriers. Is that true? I mean is that explicit that
23 the--

24 MR. WHEELER: That is very clear in 9.2.2
25 SRP.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: Mm, okay. Even if I had
2 the smartest, best designed automatic isolation
3 signal, I have to rely on operator actions?

4 MR. WHEELER: The concern is, for example,
5 the APR design CCDS is nonsafety, so you totally are
6 relying on CCWS for seal coolant.

7 In this case CCDS and component cooling
8 are both safety-related, so they're complimenting each
9 other.

10 CHAIR STETKAR: So for a better design, I
11 still because of a regulatory Standard Review Plan but
12 the onus on the operators to save the day?

13 MR. HAMAMOTO: Hossein Hamzehee --

14 MR. WHEELER: I don't understand saving
15 the day for --

16 CHAIR STETKAR: You know, I'm going to get
17 to why they have to close these valves. I just sort of
18 am curious about why the NRC -- it's interpreted that
19 the NRC says certain functions shall be performed by
20 the operators even, you know regardless of the design,
21 regardless of how the signals might be designed and
22 automated; that this is something that the operators,
23 yet another thing that we need to burden the operators
24 with.

25 MR. HAMAMOTO: Let me just clarify this to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 give you a detailed technical justification. Maybe
2 later on we can do that because within this SRP as
3 Larry said, but again this SRP also says this is the
4 guidance preference. However, the applicant can
5 propose other designs, but then they have to justify
6 why they believe it's better and safer. And then the
7 staff will review and either approve or disapprove.

8 CHAIR STETKAR: And I'm glad you put that
9 on the record. Thank you.

10 MR. WHEELER: The Rev. 2 design for this
11 system, had those valves gone closed and there was an
12 operator action within an hour to re-establish CCWS
13 flow to the thermal barriers, but that resulted in a
14 whole bunch of other questions about water hammer. So
15 this design was their fix for what the SRP says. Of
16 course the SRP is guidance.

17 CHAIR STETKAR: Right. I thought about the
18 Rev. 3 design and there was some fairly clever things
19 that they put in the Rev. 3 design for isolating those
20 lines. I didn't think much about water hammer.

21 MR. WHEELER: Yes.

22 CHAIR STETKAR: And a bit of my concern is
23 that people get focused on specific issues. It's like
24 the reverse flow through the drain line; that you try
25 to make things perfect for one issue and, perhaps, not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 so good for more likely things.

2 MR. WHEELER: Okay.

3 CHAIR STETKAR: So protection against
4 water hammer is certainly something that we need to
5 think about. Burden on operators in also something
6 that we need to think about. And I recognize that
7 there was a need for --

8 MR. WHEELER Okay.

9 CHAIR STETKAR: -- the operators to
10 restore cooling, you know if it was isolated
11 automatically. So there may not be a design that
12 completely removes the operators, you know the perfect
13 design, if you will. But I'm trying to understand
14 this notion of on the one hand the applicant perhaps
15 taking an expedient approach because it's consistent
16 with the SRP --

17 MR. WHEELER: Yes.

18 CHAIR STETKAR: -- for a particular issue
19 that may be focused on water hammer, and yet
20 introducing perhaps some additional burden on the
21 operators which may not necessarily be in the best
22 interest of overall, you know plant response.

23 But at least you've answered the first
24 part of my question about the SRP. So I understand
25 that a little bit better.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Now, I read the story, I didn't read the
2 SECY papers; I didn't have enough time. But explain to
3 me what the magic 24 hours is.

4 Now the current design says that they need
5 to manually close those isolation or cross-tie valves,
6 whatever you want to call them, the 7 and the 20
7 valves. In the DCD it's left nebulous under accident
8 conditions. You know, basically determined by the
9 operators.

10 MR. WHEELER: Right.

11 CHAIR STETKAR: In the SER there is this
12 notion of they have to be closed within 24 hours based
13 on a SECY paper.

14 MR. WHEELER: Right.

15 CHAIR STETKAR: What's the basis for that
16 24 hours?

17 MR. WHEELER: That was the proposal from
18 MHI to use the 24 hour and use up. The SECY paper and
19 the staff looked at that as being reasonable. The
20 separation that I see, I only see two conditions in
21 which we're really going to need to define the
22 separation.

23 And the first one is when you have
24 maintenance. If you have a Train A that's out and you
25 want to keep B running, you obviously would isolate

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the A and the B side.

2 Two is if you have an accident signal and
3 one pump is running and the other one's in standby,
4 and the second pump actually comes on during the
5 safety injection signals, and now you got two pumps
6 running. And then, for example, A or B trips. So now
7 you have one pump trying to supply the B loads, the
8 common header loads and then it's also trying to
9 support flow to the alpha ECCS loads.

10 And we asked MHI to evaluate whether there
11 would be a degraded condition for the heat load and
12 the pump's flow. And they came back and said that
13 there was adequate margin in the heat exchanger,
14 that's a plate-type heat exchanger. They had about a
15 20 percent margin in the heat exchanger. And that
16 there was adequate flow in the pump; and I think it's
17 somewhere in the five to seven percent range.

18 So right off the bat they said even if
19 this scenario happened which both pumps were running
20 and then one trips, you're supplying flow to the
21 opposite header, do we have margin?

22 CHAIR STETKAR: Well --

23 MR. WHEELER: So then we looked at that
24 and said "Well, okay. That's good that we have this
25 margin, but let's put some type of time table of when

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it'll be a good idea to actually make that separation
2 to get away from using that margin in --"

3 CHAIR STETKAR: Before we talk about the
4 good idea and the time, I want to make sure that I
5 understand the design and what you said earlier. And
6 let me say it back so that I can actually see if I
7 understand it.

8 Are you saying that they've done an
9 analysis that shows if I have one pump running, let's
10 call it the A pump --

11 MR. WHEELER: Yes. Right.

12 CHAIR STETKAR: -- supply flow now in
13 parallel to all of the Train A loads --

14 MR. WHEELER: Right.

15 CHAIR STETKAR: -- all of the Train B
16 loads.

17 MR. WHEELER: Right. Yes.

18 CHAIR STETKAR: -- now safety loads and
19 the common header, the A1 common header --

20 MR. WHEELER: Yes.

21 CHAIR STETKAR: -- with the A2 common
22 header isolated --

23 MR. WHEELER: Right.

24 CHAIR STETKAR: -- that I'm okay?

25 MR. WHEELER: You're okay. That's in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 SER.

2 CHAIR STETKAR: Fine. I thought I
3 understand that, but good.

4 MR. WHEELER: Yes. But keep in mind the
5 biggest flow on the opposite header would be to the
6 RHR heater exchanger.

7 CHAIR STETKAR: Yes.

8 MR. WHEELER: And that valve hasn't
9 opened.

10 CHAIR STETKAR: I'm sorry, it has if I've
11 had a LOCA, hasn't it?

12 MR. WHEELER: But that system is just
13 isolated.

14 CHAIR STETKAR: It has?

15 MR. WHEELER: Let me backup. I'm trying
16 to remember in the RAI response, MHI took credit for
17 that valve not being opened.

18 CHAIR STETKAR: Ah, well that's special.

19 MR. WHEELER: And maybe they looked at it
20 at a range of failures that maybe is not complete.

21 CHAIR STETKAR: I mean, that's right. In
22 the initial scenario -- what got me thinking, and the
23 reason I wanted to say it back is your scenario said
24 well suppose I have a condition where both pumps come
25 on--

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. WHEELER: Yes.

2 CHAIR STETKAR: You know A and B on, and
3 let's call that call that a LOCA.

4 MR. WHEELER: Okay.

5 CHAIR STETKAR: Or a steam line break, or
6 you know some ECCS actuation thing. Let's call it a
7 LOCA where you actually need heat removal. And then
8 pump B trips.

9 MR. WHEELER: Right.

10 CHAIR STETKAR: You know, well the outlet
11 -- I haven't looked at all of the logic diagrams and
12 things. Will the outlet valve from the Train B heat
13 exchanger then go closed or will it stay open? You
14 know, can you get into a configuration where have an
15 ECCS actuation signal --

16 MR. WHEELER: Yes.

17 CHAIR STETKAR: -- such that Pump A, let's
18 call it, are supplying flow to all three of those
19 lines --

20 MR. WHEELER: Right.

21 CHAIR STETKAR: -- you know with heat
22 being removed from both the A and B heat exchangers --

23 MR. WHEELER: Yes.

24 CHAIR STETKAR: -- or not only, you know
25 just the component cooling, from all of the Train A

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and B ECCS loads, the pump coolers and all of that
2 other stuff out there.

3 MR. WHEELER: Right. I think there's
4 check valves that are going to prevent flow from the B
5 side to go back through the alpha heat exchanger, so
6 you're not going to get flow to that heat exchanger.
7 Was that your question?

8 CHAIR STETKAR: No. If I just take a
9 single pump --

10 MR. WHEELER: Yes.

11 CHAIR STETKAR: -- and connect it to --

12 MR. WHEELER: Yes, I got the flow diagram
13 right in front of me.

14 CHAIR STETKAR: Yes. Okay. Well, let me
15 find my flow diagram so that I can -- I've lost it.

16 Can I come to an alignment if I'm looking
17 at Sheet 1 where the A component cooling water pump is
18 supplying flow through the A -- what's called on the
19 drawing the A supplied header --

20 MR. WHEELER: Yes.

21 CHAIR STETKAR: -- the A1 supply header --

22 MR. WHEELER: Yes.

23 CHAIR STETKAR: -- and the B supply
24 header--

25 MR. WHEELER: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: -- where the heat loads on
2 the A supply header and the B supply header are all
3 running? In other words, the pumps that are cooled,
4 the chillers that are cooled and the -- I'm sorry, not
5 the chillers because this is CCWS. And the heat
6 exchanger, you know like the RHR heat exchangers.
7 Because all of those kind of come back together into
8 the common return header at the -- you know, we're not
9 going to worry about reverse flow in LOOPS.

10 MR. WHEELER: Yes.

11 CHAIR STETKAR: I'm assuming there are
12 check valves out there anyway someplace, but that you
13 now have one pump's worth of flow going through the
14 three parallel sets of heat loads.

15 MR. WHEELER: Yes.

16 CHAIR STETKAR: And is that the analysis
17 that they did?

18 MR. WHEELER: We'd have to go back and
19 look at the RAI response. But I'm fairly certain that
20 that's is correct.

21 CHAIR STETKAR: Okay. If that is, then
22 that's a big confidence builder because if indeed the
23 system doesn't get into trouble in terms of
24 temperatures or, you know flow characteristics of the
25 pump, or anything under those conditions, then it's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 not clear to me that the operators ever have to close
2 the cross-tie valves. If indeed the RAI response
3 doesn't address those conditions, if they made some
4 assumptions about flow through the -- you know Train B
5 let's call it in this case being isolated, and you
6 know and particularly through the RHR heat exchanger
7 because that will be the largest load, then that
8 determines conditions under which perhaps the
9 operators may need to close those cross-tie valves if
10 that becomes unacceptable. And that might be less than
11 24 hours. But I don't know what the unacceptable
12 conditions would become.

13 MR. WHEELER: Yes. I thought I did a
14 fairly good job in the SER explaining the margins that
15 were available during this scenario which one pump had
16 tripped off and the other pump was supplying all the
17 loads. And I'm trying to find that in the SER right
18 now.

19 CHAIR STETKAR: Yes. And I did read the
20 SER. I tried to understand it. And it wasn't, I
21 guess--

22 MR. WHEELER: There's 1.32 E to the sixth
23 BTU per hour added load to the heat exchanger during
24 this duration in which one pump had tripped off and
25 the other pump was supplying all the loads. And

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that's pretty insignificant against the heat
2 exchangers that are designed for 190 E to the sixth.

3 CHAIR STETKAR: With that sort of flow
4 rate, though, on the CCW side -- okay.

5 Well maybe -- we're going to get back
6 together again tomorrow. Maybe you can --

7 MR. WHEELER: Okay. Yes.

8 CHAIR STETKAR: -- point me to the places.
9 It may be there and I'm not -- you know, I'm being
10 dense. I've been dense in the past. Ad it will
11 continue in the future.

12 MR. WHEELER: Well, I'll go back over the
13 RAI response.

14 CHAIR STETKAR: Now, Larry, the 24 hours
15 from what you were saying earlier, is that -- I think
16 you characterized it as something like well it would
17 be a good idea at some time to separate these things.

18 MR. WHEELER: Yes.

19 CHAIR STETKAR: Is that basically what
20 that SECY paper says? I mean, what's the basis for
21 that 24 hours? If indeed this configuration gives you
22 stable heat removal with no challenge to either heat
23 removal or equipment survivability, why would the
24 operators need to close those valves at all?

25 MR. WHEELER: In the SER we talked about

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the SECY-77-439 and it references this as that 24
2 hours or greater for long term cooling. So I can go
3 back and then for tomorrow's discussion --

4 CHAIR STETKAR: Because I didn't go back--

5 MR. WHEELER: -- we can pull that document
6 together and --

7 CHAIR STETKAR: Unfortunately, I didn't
8 have time to go back and look that up. And I'm
9 curious about it because it says SECY-77, which is a
10 while ago.

11 Thanks. I'd appreciate it.

12 MR. WHEELER: Okay. I can do that.

13 The other question we had for these was 30
14 days versus 36 days --

15 CHAIR STETKAR: Yes.

16 MR. WHEELER: -- and the ultimate heat
17 sink. And in the DCD it is not very clear what it
18 means, but 30 days supply versus 36 day supply. And
19 in the Reg. Guide, I believe, it essentially is
20 talking about the analysis for meteorological
21 conditions for 36 days for a cooling ponds. And that's
22 because it takes if you're using cooling pond, an
23 additional five days for that heat load to actually
24 get to the cooling pond to its maximum temperature.
25 So that's a difference between doing a meteorological

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 review for 30 days versus the 36 days. And that's why
2 I said the DCD is kind of unclear for the 36 day heat
3 pump.

4 CHAIR STETKAR: Well, yes. And for
5 example--

6 MR. WHEELER: And it says you have a 30
7 days supply.

8 CHAIR STETKAR: Right. And I understand
9 the 30 days. That's --

10 MR. WHEELER: And then it starts talking
11 about doing an analysis of 36 days meteorological data
12 for the cooling pond design.

13 I'll this with you.

14 CHAIR STETKAR: What's the date on the
15 Reg. Guide?

16 MR. WHEELER: '76.

17 CHAIR STETKAR: Yes. The only reason it
18 honestly doesn't effect the subject of this meeting --

19 MR. WHEELER: Of the DCD, right.

20 CHAIR STETKAR: -- it doesn't effect the
21 DCD at all. I'm just curious about the fact that if
22 I'm now in the COL world, given these words in the
23 DCD--

24 MR. WHEELER: Yes.

25 CHAIR STETKAR: -- given the words in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 SER for the DCD --

2 MR. WHEELER: Yes.

3 CHAIR STETKAR: -- if I want to use a
4 mechanical draft, cooling towers with things that look
5 like large swimming pools --

6 MR. WHEELER: Yes.

7 CHAIR STETKAR: -- and call that my
8 ultimate heat sink, I need to have 30 days worth of
9 water in there accounting for what meteorological
10 conditions.

11 If I instead want to dig a big hole out
12 there in the south 40 and line it with some really
13 good clay --

14 MR. WHEELER: Yes.

15 CHAIR STETKAR: -- and fill it full of
16 water and have pumps take suction from it and allow
17 for just normal evaporative cooling --

18 MR. WHEELER: Yes.

19 CHAIR STETKAR: -- the implications are I
20 need to account for 36th days worth of inventory.

21 MR. WHEELER: Right.

22 CHAIR STETKAR: Even though I might call
23 that other thing out there my ultimate heat sink.

24 MR. WHEELER: That's right.

25 CHAIR STETKAR: but I might call the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Mississippi River my ultimate heat sink. So --

2 MR. WHEELER: For example, the EPR only
3 has 72 hours of ultimate heat sink on site.

4 CHAIR STETKAR: Yes.

5 MR. WHEELER: They have safety-related
6 pumps that bring in water from the Chesapeake Bay. So
7 that's their approach to Reg. Guide 1.27. So --

8 CHAIR STETKAR: Calvert Cliffs' version of
9 the EPR, not the EPR?

10 MR. WHEELER: That's right.

11 CHAIR STETKAR: But if I wanted to dig a
12 pond, I'll call the site South Texas for example --

13 MR. WHEELER: Yes.

14 CHAIR STETKAR: -- where they built dug a
15 big pond, that pond would need to supply 36 days worth
16 of water according to that Reg. Guide?

17 MR. WHEELER: No. It says you need to do
18 an analysis for 36 days of meteorological.

19 CHAIR STETKAR: Okay. Okay. Okay.

20 That's a Reg. Guide, now I know you said
21 you'd leave it with me, but --

22 MR. WHEELER: 1.27.

23 CHAIR STETKAR: 1.27.

24 MR. WHEELER: Yes. And it's going through
25 revision right now.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: That number sounds
2 familiar.

3 You remember everything, Bill. Have we
4 seen that?

5 MEMBER SHACK: 1.27, no.

6 CHAIR STETKAR: Okay.

7 MEMBER SHACK: That's a number that would
8 stick in your head. I mean that's getting back there.

9 CHAIR STETKAR: Okay. All right. There is
10 some explanation. And you said it is being revised
11 now?

12 MR. WHEELER: Yes, it is.

13 CHAIR STETKAR: Okay.

14 MR. WHEELER: I'm not quite sure what
15 we're doing with the 36 day thing, but now we'll have
16 to look at in detail.

17 CHAIR STETKAR: Apparently, a timely
18 question.

19 Component Cooling Water, since the slide
20 is still up there, the SER discusses gas accumulation
21 in the component cooling water system. And it seems
22 to focus primarily on the surge tank. There's a
23 discussion about the fact that there's a nitrogen
24 cover gas on it, but because the piping arrangement,
25 the elevation and things like that, that it's unlikely

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that that nitrogen would become entrained and cause
2 any gas accumulation in the system.

3 Did you look at other possible ways that
4 gas, not nitrogen, air could become entrained in the
5 system in local high spots in the systems? For
6 example, after maintenance if high points in the
7 system were not vented. In other words, did you go
8 through the system to assure yourself that it contains
9 high point vents in local places where you might have
10 essentially LOOPS created where you could accumulate
11 gas? Not necessarily from nitrogen, but in leakage --

12 MR. WHEELER: Yes.

13 CHAIR STETKAR: -- maintenance, you know
14 things like that?

15 MR. WHEELER: That wasn't the extent of my
16 review. That would apply to any system across the
17 board that if you don't have high point vents, then
18 you can't hydrostatically test the system adequately.

19 So you really can't meet ASME code. So kind of goes
20 without saying that you're going to have to have high
21 point vents in any ASME section 3 piping system.

22 CHAIR STETKAR: The only reason I raised
23 it is I did see words like "high point vents" in other
24 systems. I didn't see it in this.

25 MR. WHEELER: Yes. I kind of think it goes

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 without saying that the systems have to have high
2 point vents in their pockets.

3 One of the other comments you made was
4 about a half hour ago about the spent fuel pool loss
5 of cooling and the temperature alarms. And I think it
6 kind of goes without saying that the COL is going to
7 develop alarm responses for all those alarms that are
8 going to deal with details, actions to the control
9 room operators know what to do. So in the case of a
10 high temperature alarm on the spent fuel pool, he's
11 going to hit the alarm, he's going to get out the
12 instruction and it's going to say, you know, verify
13 pumps are running. If not, start a pump. I think that
14 kind of goes without saying that the COLs have to
15 develop alarm instructions for any alarm that comes
16 into the control room

17 MEMBER BLEY: Could you clarify something
18 for me?

19 MR. WHEELER: Yes.

20 MEMBER BLEY: At what point in time will
21 the new orders that were issued as a result of
22 Fukushima apply to these new plants?

23 MR. WHEELER: Well, I --

24 MS. McKENNA: This is Eileen McKenna.

25 We are still evaluating how we're going to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 apply the positions taken for Fukushima to new
2 reactors. We think in general we have time to try to
3 deal with these in a measured way and we are
4 considering whether we ask questions. And we -- get
5 new licenses get issued, have orders. But we're
6 obviously in a position to have discussions.

7 MEMBER BLEY: I'm sure you are.

8 MS. McKENNA: We're not prepared today to
9 say how we're going to approach it for this particular
10 applicant.

11 MEMBER BLEY: Okay. So we don't know yet
12 whether it will be before dual load or --

13 MS. McKENNA: Well, certainly I think
14 before that. I think the question is at what point in
15 the licensing process will these things be --

16 MEMBER BLEY: Yes, but there's a number of
17 them that already have their --

18 MS. McKENNA: Yes. And in the case of
19 Vogtle, I think the plan was to send -- and I think
20 also a 50.54(f) letter on certain position. And we're
21 also considering for all the other applicants --

22 MEMBER BLEY: Okay. So that might be
23 before the COL?

24 MS. McKENNA: It could well be, yes.

25 MEMBER BLEY: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. WHEELER: So do you have any other
2 questions?

3 CHAIR STETKAR: Let me just check my notes
4 here. No.

5 MR. KALLAN: Okay. Thank you, Larry.

6 I turn it over to Angelo Stubbs.

7 MR. STUBBS: Okay. Good afternoon.

8 My name is Angelo Stubbs. I'm with the
9 Balance of Plant Branch and I performed the review for
10 FSAR Section 9.2.6 Condensate Storage Facilities.

11 I guess this morning the Applicant gave
12 you a quick overview of that system. They also had a
13 slide in there about the open item, but they didn't
14 present it, unfortunately. But just some of the
15 features. "Key," may not be really the word, but some
16 of the ones that I wanted to bring up for saying this
17 is as they told you this morning, the Condensate
18 Storage Facility has three systems. It has a big bin
19 water system, the condensate storage and transfer
20 system and the primary makeup water system.

21 It basically supplies and receives
22 condensate from the -- to and from the condensate
23 hotwell as required. The system is a nonsafety-
24 related system and has no safety-related functions.
25 And a lot of the Condensate Storage systems, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 condensate storage tank is used as a primary water
2 source for aux feedwater and emergency feedwater. But
3 for this design there is dedicated emergency feedwater
4 pits that contains, I think, it's combined of 400,000
5 gallons of water that's used to support the operation
6 of the emergency feedwater system. And also that
7 supports the Station Blackout, which is the other
8 thing that we looked at the condensate storage tank
9 for.

10 According to the table they have in
11 Chapter 9, the tank is about 750,000 gallons. It's a
12 non-seismic tank. It has a dyke which they say it can
13 contain the whole contents of the tank, but the dyke
14 is a nonseismic dyke, so that -- and they say that's
15 used to mitigate the environmental effects of system
16 leakage or storage tank failure.

17 For our evaluation, I evaluate this as our
18 SRP 9.2.6, and this is for general condensate storage
19 facilities. And in some cases they have safety-
20 related functions and some cases there's condensate
21 storage facilities with no safety-related functions.

22 In the application in Chapter 1 Table
23 1.9.2 they indicated that the SRP 9.2.6 is not
24 applicable for this plant, which is different for me
25 because all the licensing plants I've seen and all the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 new reactors I've seen to some extent you use 9.2.6
2 and there is some GDCs that apply, and often they'll
3 point out what doesn't apply and then just how to meet
4 what does apply.

5 While we're reviewing this the heat
6 transfer functions were not required, the GDC 44, 45,
7 46 is a plant that is a one-unit plant. So the GDC
8 doesn't apply. But based on our review, I felt that
9 GDC 2 and GDC 60 applied, also they needed to meet the
10 requirement of the 10 CFR 20.1406.

11 So, after looking at what was presented in
12 their design, those were the things that I felt needed
13 to be meant.

14 In a slide I just took something out of
15 the SRP, it doesn't show everything, but one of the
16 things it indicates in the SRP is that outside designs
17 should be compliant with GDC 60 and Reg. Guide 1.143.

18 So their denial that GDC 60 applies, that was to
19 point that out.

20 And also, in that same one it says that
21 for nonsafety-related storage facilities there's a
22 need for a seismic category 1 dyke or retention basin
23 review. So I reviewed that.

24 The GDC 2 comes in, and in this case if
25 there was an earthquake, you wouldn't be able to take

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 credit for the tank not filling or the dyke containing
2 the contents of the tank.

3 So we issued an RAI, and this is what the
4 open item is, and we request that they provide
5 justification for use of a nonseismic dyke in
6 conjunction with the nonseismic tank. And we asked
7 them how they would comply with GDC 2 and 60 if you
8 had such a failure and what would happen with the
9 resulting flooding that could occur if you had a
10 seismic event that resulted in that failure.

11 MEMBER BLEY: And have they responded to
12 that yet?

13 MR. STUBBS: They did respond to it. And
14 their initial response to it in an RAI letter that
15 they gave us on December 15th, 2011. And in that
16 response they basically came to the conclusion that
17 GDC 2 and GDC 60 were not applicable.

18 But what they said was "The condensate
19 storage tank is classified as nonsafety-related as the
20 system does not perform any safety-related function.
21 Hence, GDC 2 is not applicable. The CST, its dyke and
22 pump house are strategically located away from the
23 other structures, systems and components, particularly
24 the safety-related SSCs, the flat site grading and the
25 nuclear island area, and the yard drainage from the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 area minimizes any adverse impacts of any safety-
2 related SSCs due to the failure of the tank and/or the
3 dyke. Hence the CST and the CST dykes are designed as
4 nonseismic."

5 So they credited that it was out in the
6 yard away from other safety-related SSCs, and they
7 talked about the site drainage. And in their slides
8 this morning they have other things about entrance is
9 being located one foot above, but -- and greater slope
10 and drainage. And they have a conclusion that
11 therefore the failure of the tank and dyke does not
12 impact safety-related SSCs.

13 So, we did talk to them and try to explain
14 what our concerns was. And I think they're going to be
15 providing us a revised or a supplement to that RAI
16 response. But at that time they still -- they seemed
17 to be willing to address GDC 60, but they still was
18 taking the stance that the way they read GDC 2 it
19 doesn't apply. But I think they recognize the fact
20 that the flooding issue needs to be addressed.

21 I looked at the site arrangement, and the
22 reason I was focusing on the condensate storage tank
23 is it seems to be located over in the yard just
24 outside of the turbine building, not too far from the
25 turbine building. And also in their response they

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 talk about slope and drainage systems should be
2 provided as site-specific plant design.

3 One of the things is this doesn't seem --
4 this feels like they're making conclusions there, but
5 it seems like this is a site-specific issue. Well, a
6 COL would need to be -- there would need to be a COL
7 item.

8 MEMBER BLEY: And this is ground water. I
9 mean --

10 CHAIR STETKAR: Well, and if it is though,
11 if I'm the COL, I think I'd need to know that I need
12 to consider this. Right? So at a minimum, there would
13 to be an explicit COL information item that, you know

14 MR. STUBBS: I think that there needs to
15 be a COL --

16 CHAIR STETKAR: I mean, that's -- I mean
17 we don't do that kind of thing.

18 MR. STUBBS: No, you know that's something
19 that I think needs to be done.

20 But looking at the plan, though, and
21 looking at it the concern I had was with the power
22 source building and the power source volts, both. And
23 when I looked at the two COLs, one looked like
24 everything looked okay and everything drained away.
25 The other looked like it sort of drained back, it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 drains downhill which would pass by those building.
2 And so it seems like that the statement seems fine,
3 but it just has to be verified. If it's not verified,
4 there needs to be a flooding evaluation that we can
5 look at and that we can confirm the conclusion that's
6 being drawn. And so far I've asked about that, I
7 haven't seen that, and I have seen the COL item. So
8 we still have work to do on that and it's one of those
9 things that it's just like the turbine building when
10 you have a break in the circ water line, there's a lot
11 of water there. And in the case for one of the COLs
12 where there's a dual site, you basically have two of
13 these things side-by-side. SO you really have lots of
14 water.

15 But when I look at what they have here,
16 there's some recognition that there's a problem that
17 has to be addressed, but to this point I don't see
18 that it's fully addressed because the site grading is
19 something is something that's going to be different
20 from plant-to-plant. I think the COL has to be
21 involved. Because either that or, you know they set up
22 where they can't do it, then they're going to have to
23 make a decision on their design whether to depart and
24 make a dyke or something seismic. But that's the open
25 issue. It was something that I, you know when I first

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 read through it it looked okay, but then as I -- you
2 know, as I went back to the site plan and started
3 looking at thing, it seemed like we may have a problem
4 there.

5 The other tanks, the demin storage tank
6 was located sufficiently away in the general plan.

7 CHAIR STETKAR: That's what I was going to
8 ask. You know, we're just about to muddy the waters,
9 if you will, and ask about the demin storage tank
10 because I meant to ask MHI this morning there's no
11 mention of a dyke around that tank.

12 MR. STUBBS: No, I think --

13 CHAIR STETKAR: And it's equally
14 nonseismic. It's 500,000 gallons --

15 MR. STUBBS: Right.

16 CHAIR STETKAR: -- instead of 750,000
17 gallons.

18 MR. STUBBS: Right.

19 CHAIR STETKAR: But it's still a
20 considerable amount of water.

21 MR. STUBBS: It is. It is. And when I
22 looked at the general layout, from what I looked at
23 the location of it, it looked like it was a little bit
24 down from the --

25 CHAIR STETKAR: With things like the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 locations of tanks, is that an R-COLs? I mean, could
2 the R-COLA decide that they want to move it up there
3 in the corner someplace --

4 MR. STUBBS: Well, here's the thing --

5 CHAIR STETKAR: -- if they'd like to do
6 that?

7 MR. STUBBS: The other thing with both is
8 tanks as part of the flood analysis of 3.4.1.2, the
9 external outdoor tanks and piping should be evaluated.
10 And they do talk about in 3.4.1 -- in 3.4.1.2 I think
11 they actually put an example and they have the primary
12 makeup storage tank, refueling water storage tank,
13 demin water storage tanks, fire water storage tank --
14 they don't mention the condensate water tank at all,
15 but they do talk about it as part of the flooding
16 analysis and the flood evaluation they should be
17 addressed. So, that's why I didn't bring it up there.

18 And maybe the condensate storage tank
19 should also be addressed as part of it also.

20 CHAIR STETKAR: But recognize that if we
21 get the right kind of seismic event we're talking
22 about not only the 750,000 gallons in the condensate--

23 MR. STUBBS: In the -- right.

24 MR. STUBBS: We're talking about the
25 condensate storage tank and the demin storage tank.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. STUBBS: Right.

2 CHAIR STETKAR: Both of them, because
3 they're equally nonseismic.

4 MR. STUBBS: Right.

5 CHAIR STETKAR: We're talking about the
6 primary water makeup tanks --

7 MR. STUBBS: Right.

8 CHAIR STETKAR: -- which are in a
9 building, but I don't know -- what, that is another
10 280,000 gallons of water.

11 MR. STUBBS: Yes. They're over by the
12 refueling water storage tank at the end of the
13 auxiliary building. So these in terms of location,
14 they're sort of at the opposite ends of the plant --
15 the makeup water and the refueling water storage tank.

16 But you're right: If you have nonseismic
17 tanks, all of them would be assumed to have failed.

18 CHAIR STETKAR: I mean, you know they're
19 not necessarily exactly equal, but --

20 MR. STUBBS: Right, right. But that would
21 also be part of -- you know in the flooding analysis
22 you would be looking at the failure on your nonseismic
23 tanks and looking --

24 CHAIR STETKAR: Do they do that with all
25 of them or do they do one-by-one and say "Okay, this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 one's got two gallons in it so that's not a problem,
2 this one has eight gallons in it and that one's not a
3 problem?

4 MR. STUBBS: Well, obviously the inventory
5 isn't large enough, they probably don't look at it.
6 But thinks that have large inventories, they should
7 look at. And that's still part of our flood evaluation
8 that we're trying to get to the point we've requested
9 to have the calculations available for it to do a
10 audit of. But whatever they can't do as part of the
11 standard design, they need to make sure that the COL
12 do. And because these locations may vary based on COL
13 it seems like that may be something that the COL will
14 end doing. It would be, you know put into as a bigger
15 COL item in Chapter 3 to either verify that the
16 slopping takes it away or do an analysis to show that
17 the flooding don't affect safety-related SSCs or
18 buildings.

19 CHAIR STETKAR: Okay.

20 MR. STUBBS: And that's really all I had.
21 If you have questions, I'll be glad to answer them.

22 CHAIR STETKAR: I don't. Anyone else?

23 MR. KALLAN: Thank you, Angelo.

24 I guess I'll turn it over to David Nold.

25 CHAIR STETKAR: I'm sorry, Angelo. Does

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the demin tank had a dyke around, do you know?

2 MR. STUBBS: The only thing, in their DCD
3 they're saying their dykes are at a primary water
4 storage tank --

5 CHAIR STETKAR: I read that, yes. Let me
6 ask MHI just to --

7 MR. STUBBS: There was no mention of a
8 dyke around the demin.

9 CHAIR STETKAR: Can someone from MHI
10 clarify? Is there a dyke -- I don't care of it's
11 seismic or nonseismic. I'm just trying to find out at
12 the moment whether there's a dyke around the
13 demineralized water storage tank.

14 MR. MASASHI: I am Masashi Ito, MNES.
15 The primary makeup of the tank.

16 CHAIR STETKAR: Demineralized water tank.
17 I know there's a DWST.

18 MR. MASASHI: Excuse me.

19 CHAIR STETKAR: If you don't have it,
20 we're coming back tomorrow morning. If you don't have
21 a quick answer, you know it's something we can find
22 out tomorrow. Let's leave it at that. The staff
23 doesn't have too much left, but I want to make sure
24 that if we do have questions, we do need to finish by
25 about 5:00. So we'll just leave it on the to do list

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 for tomorrow morning.

2 MR. KALLAN: Okay. I'll turn it over to
3 Dick.

4 MR. NOLD: Good afternoon. My name is
5 David Nolan. I'm with the Containment and Ventilation
6 Branch.

7 When the SER is submitted --

8 CHAIR STETKAR: I'm sorry, Dave.

9 MR. NOLD: Yes, sir.

10 CHAIR STETKAR: I'm trying to keep ahead.
11 You guys are not talking about all of the stuff --

12 MR. NOLD: Right.

13 CHAIR STETKAR: -- in this chapter. And
14 there was one issue that kind of bothers me, and it's
15 on the essential chilled water system. So I don't
16 know who the appropriate person to drive into this is,
17 but --

18 MR. KALLAN: Yes. We have him --

19 CHAIR STETKAR: Ah. Hopefully, at least I
20 can frame the question a little --

21 MR. KALLAN: -- for you.

22 CHAIR STETKAR: -- bit better on this one
23 than I did earlier.

24 In the SER in Section 9.2.7.4.2, which is
25 the tech specs regarding the chilled water system,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 there's the following statement: The US-APWR does not
2 include any technical specifications for the ECWS or
3 the non-ECWS. This is consistent with SRP Section 15
4 NUREG-1431 Standard Technical Specification for
5 Westinghouse Plants and is acceptable to the staff."

6 I'm really curious why you don't need
7 technical specifications for the essentially chilled
8 water system, which is a safety-related system that
9 supplies support to maintain acceptable environmental
10 conditions for the operation of safety-related
11 mechanical, electrical, instrumentation control and
12 Main Control Room habitability systems, and the US-
13 APWR technical specifications bases in Section B.3.7.8
14 for the essential service water system and B.3.7.9 for
15 the ultimate heat sink specifically note that ESWS
16 needs to supply cooling to the ECWS chillers. So, if I
17 need supply cooling to the ECWR chillers, and that's
18 in the tech specs and ECWS provides cooling to safety-
19 related systems that are in the tech specs, I really
20 don't understand why ECWS isn't in the tech specs
21 simply because somebody who had never looked at at
22 chilled water system wrote generic tech specs for a
23 Westinghouse plant. So if you could explain to me why
24 that's acceptable to the NRC staff, I'd be really
25 interested in that explanation?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. CURRAN: What you read right there is
2 from the SER?

3 CHAIR STETKAR: What I read from the SER
4 is the quote "That the US-APWR does not include any
5 tech specs for the ECWS or non-ECWS. This is
6 consistent with SRP Section 16, NUREG-1431, Standard
7 Technical Specifications for Westinghouse plants is
8 acceptable to the staff." That's a direct quote from
9 the SER.

10 MR. CURRAN: I don't --

11 CHAIR STETKAR: And no further
12 justification.

13 MR. CURRAN: I don't have a good answer
14 for you right now.

15 CHAIR STETKAR: Okay. I'd suggest you go
16 back and look at that and think about it, because --

17 MR. CURRAN: That's in a different branch,
18 and I will get back to you on that.

19 CHAIR STETKAR: Okay. Okay. I don't
20 normally read those tech specs' actions, but I was
21 skimming through it and wait a minute, no tech specs.
22 And, indeed, there are no tech specs because I went to
23 Chapter 16 and there aren't any tech specs. But if you
24 do a word search on "chilled," you'll find out indeed
25 there's a requirement -- you know, the tech spec bases

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 for ESWS, surface water. Note that one of its
2 functions is to cool those chillers.

3 Check with the tech spec folks, please.

4 MR. CURRAN: Okay.

5 CHAIR STETKAR: And now we can talk about
6 Main Control Room spec.

7 MR. NOLD: Good afternoon. My name is
8 david Nold, I'm from the Containment and Ventilation
9 Branch.

10 When the SER was compiled last Fall, it
11 was submitted with 13 open items. And probably most of
12 the 20 listed, I have 13. Since last Fall the good
13 news is that seven of those have either been moved to
14 confirmatory items or closed. So we're down to the
15 significant six, I guess is the best way to put it.

16 We're going to talk about three of those
17 open items in two slides today. And let me start from
18 there.

19 The staff's concern is captured in this
20 slide as the ability of the US-APWR plant to maintain
21 design temperatures within areas housing safety-
22 related systems and components following the onset of
23 Station Blackout. The staff seeks assurance that an
24 alternate AC power source will be available within 60
25 minutes from the onset of Station Blackout.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 This slide actually represents two open
2 items or RAIs against DCD sections 9.4.1 and 9.4.5.

3 Section 9.4.1 pertains to the Main Control
4 Room HVAC system which maintains design temperature
5 limits within the Main Control Room envelop.

6 Section 9.4.5 pertains to subsystems of
7 the engineered safety feature of ventilation system,
8 maintains design temperature limits within areas
9 housing safety-related equipment in the reactor
10 building and the power source building.

11 The governing regulations are 10 CFR 50.63
12 Loss of All Alternating Power which reads in part:
13 "The alternating AC power sources as defined by 50.2
14 will constitute acceptable capability to withstand
15 Station Blackout provided in analysis performed which
16 demonstrates that the plant has this capability from
17 the onset of Station Blackout until the alternate Ac
18 sources and required shutdown equipment are started
19 and lined up to operate."

20 GDC 4 reads, in part, "Structures and
21 systems more important to safety shall be designed to
22 accommodate the effects of and to be compatible with
23 the environmental conditions associated with the
24 normal operation, maintenance, testing, including loss
25 of cooling accidents."

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Then we roll up into regulation.
2 Essentially Reg. Guide 1.155 Station Blackout, by
3 arriving in that Section C.3.3.5 provides specific
4 guidance with respect to alternate AC power sources.
5 Criteria 3 of Reg. Guide 1.155 "The time required for
6 making this equipment available shall not be more than
7 one hour as demonstrated by tests."

8 Criteria 5 reads: "The alternating AC
9 power system which should be inspected, maintained and
10 tested periodically to demonstrate operability and
11 reliability. The reliability alternate AC power system
12 should be or exceed 95 percent as determined in
13 accordance with NSAC 108 or equivalent methodology."

14 Currently the DCD Chapter 14 test entitled
15 "Alternate AC Power Sources for Station Blackout Pre-
16 Operational Tests" contains pre-requisite No. 5 which
17 reads: "A report exists that demonstrates the
18 reliability of the actual AC power sources and meets
19 or exceeds 95 percent as determined with NSAC 108 by
20 equivalent methodology to meet Criterion 5 as Section
21 C.3.3.5 of Reg. Guide 1.155 based on historical data
22 of a similar type of the alternate AC power sources."

23 To make its regulatory finding, the staff
24 seeks further clarification and enhancement of this
25 pre-operational test to ensure it satisfies the intent

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 of 10 CFR 50.63 and Reg. Guide 1.155.

2 I open the floor to questions on that
3 slide.

4 CHAIR STETKAR: Yes. And I understand
5 what you've just said. As part of this, are you also
6 asking about whether the 60 minutes is an appropriate
7 time for startup of the alternate AC source based on
8 heatup of the Main Control Room environment? In other
9 words, are there analyses to show that the maximum
10 temperature in the Main Control Room does not exceed
11 habitability -- suppose, for example, it got up to 190
12 degrees within 20 minutes? One would say that perhaps
13 I should start the alternate AC gas turbines in
14 something less than 20 minutes. Are you also
15 questioning that 60 minute time with respect to heatup
16 of the Main Control Room or are you just questioning
17 whether or not the pre-operational tests and --

18 MR. NOLD: There was one RAI initiated
19 that asks for calculations of that.

20 CHAIR STETKAR: Okay.

21 MR. NOLD: And they provided not a formal
22 calculation, but a calculation that made sense in my
23 mind. So there was no audit of their calculation, to
24 answer your question. It seemed reasonable what they
25 were telling me, is the best way to put it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: And it substantially
2 longer than 60 minutes until they --

3 MR. NOLD: The maximum temperature they
4 calculated, I think was like one degree less than the
5 limit of 122, I think it was. That's the maximum
6 you'll ever get, and it will take forever to get
7 there, several hours to get there.

8 CHAIR STETKAR: Oh, that's not the
9 temperature at 60 minutes? That's the steady state--

10 MR. NOLD: Yes. That's the temperature
11 after that.

12 CHAIR STETKAR: Okay. Thanks.

13 MR. NOLD: Yes. Right.

14 CHAIR STETKAR: And it takes much longer
15 than 60 minutes to get there?

16 MR. NOLD: Yes, that was in our
17 conclusion. Right.

18 CHAIR STETKAR: Okay. Thanks. That shows
19 margin on the 60 minutes.

20 MR. NOLD: Any other questions?

21 CHAIR STETKAR: No. Any other questions
22 on this one?

23 MR. KALLAN: We'll go to the next one.

24 MR. NOLD: Okay. This slide here, it
25 captures the staff's concern pertaining to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 potential effects on Main Control Room instrumentation
2 and controls on a worse case essential chilled water
3 system leak within a Main Control Room HVAC system air
4 handling unit.

5 Again, GDC 4 reads in part, and I'm going
6 to read a little bit further this time with it:
7 "Structures and systems, components important to
8 safety shall be designed to accommodate the effects of
9 and to be compatible with the environmental conditions
10 associated with manual operation, maintenance testing,
11 possibly accidents including loss of coolant
12 accidents. These structures, systems and components
13 shall be appropriately protected against dynamic
14 effects, including the effects of missiles and
15 discharging fluids that may result in equipment
16 failures and for events and conditions outside the
17 nuclear unit."

18 Could you put in a figure of reactor
19 control room --

20 CHAIR STETKAR: Oh, yes. That helps.

21 MR. NOLD: Off in the right-hand corner
22 there are four air handling units. Below is the
23 actual control room envelope itself.

24 As this figure shows, there are four 50
25 percent capacity air handling units in the Main

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Control Room HVAC system. These air handling units
2 are part of the control envelope and located directly
3 above the Main Control Room at the next higher plant
4 elevation.

5 The essential chilled water system design
6 filter to the four handling units equals 45 gallons
7 per minute. In the available worse case chilled water
8 leak, the supply and return HVAC trunk lines are
9 connected to the air handling units with the Main
10 Control Room below could provide a path for an
11 internal flood of the Main Control Room. The
12 potential exists for multiple divisions of safety-
13 related equipment being in the path of such failure.

14 The equipment drain line from each air
15 handling unit is nonsafety-related. Nonetheless, the
16 equipment drain line from the air handling unit to the
17 sump below should be adequately sized to assure that
18 it can dissipate by gravity the worst case leak of 45
19 gallons per minute. It cannot be cited as based on a
20 noncondensate role of a air handling unit which would
21 be significantly less.

22 The relevant performance of the Main
23 Control Room HVAC system and the essential chilled
24 water system will satisfy GDC 2 requirements. In
25 particular, these components are to be installed as

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 seismic Category 1 safety-related equipment Class 3.

2 To make its regulatory finding, the staff
3 seeks further standing of the air handling unit design
4 to ensure it satisfies the requirements of GDC 2 or
5 GDC 4.

6 Any questions?

7 CHAIR STETKAR: I don't have any. This is
8 an interesting one. I read something in the last six
9 months or so. It's just relevant in terms of water
10 that there actually was a flooding induced fire at a
11 nuclear power plant where water from a leak found its
12 way through things and down into some switchgear and
13 caused some arcing. And it wasn't a bad fire or
14 anything, but it's the first flooding induced fire
15 I've ever heard of.

16 MR. NOLD: Yes.

17 CHAIR STETKAR: And there had been events
18 -- I've forgotten the plan, that were leaks into I&C
19 cabinets and things like that and caused those fires.
20 So this is a good one.

21 Any other member comments, questions? If
22 not, I thank you very, very much for your
23 presentation. I think we had some good discussions.

24 There are --

25 MR. HAMAMOTO: John, a quick -- you had a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 couple of questions that I didn't provide the
2 responses. Do you want to go over now

3 CHAIR STETKAR: Tomorrow. Tomorrow
4 morning. Because we have several. I think MHI will
5 come back with their responses. You folks can come
6 back. Staff can come back with responses.

7 Obviously, we're going to finish I think
8 well probably before noontime tomorrow morning. I
9 don't want to change the start time. We start at 8:30
10 only because there's a notice of the times that we
11 have to start and we kind of have to adhere to that a
12 bit. So we'll start at 8:30 tomorrow morning. I expect
13 to finish, you know mid-morning or so depending on
14 much of the discussions are.

15 And, again, I thank everybody: MHI and
16 the staff. And we'll reconvene tomorrow morning.

17 And we are adjourned for today.

18 (Whereupon, at 4:56 p.m. the ACRS
19 Subcommittee was adjourned to reconvene arch 23, 2012
20 at 8:30 a.m.)

21
22
23
24
25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

US-APWR SUBCOMMITTEE

+ + + + +

FRIDAY

MARCH 23, 2012

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Subcommittee met at the Nuclear
 Regulatory Commission, Two White Flint North,
 Room T2B1, 11545 Rockville Pike, at 8:30 a.m., John
 Stetkar, Chairman, presiding.

SUBCOMMITTEE MEMBERS PRESENT:

- JOHN W. STETKAR, Chairman
- CHARLES H. BROWN, JR., Member
- WILLIAM J. SHACK, Member

NRC STAFF PRESENT:

- ILKA BERRIOS, Designated Federal Official
- PAUL KALLAN

1 NRC STAFF PRESENT: (cont'd)

2 HOSSEIN HAMZEHEE

3 LARRY WHEELER

4 RAUL HERNANDEZ

5 EILEEN MCKENNA

6

7 ALSO PRESENT:

8 RYAN SPRENGEL

9 JAMES CURRY

10 NAOKI KAWATA

11 SHINJI KAWANAGO

12 RON REYNOLDS

13

14

15

16

17

18

19

20

21

22

23

24

25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

TABLE OF CONTENTS

PAGE

1.	Opening Remarks and Objectives	4
2.	Staff Introduction	5
3.	Discussion of the SER Related to the US-APWR DCD Chapter 9, "Auxiliary Systems"	8

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1
2
3 P-R-O-C-E-E-D-I-N-G-S

4 (8:35 a.m.)

5 CHAIRMAN STETKAR: The meeting will now
6 come to order.

7 Today is the second day of a meeting of
8 the United States Advanced Pressurized Water Reactor
9 Subcommittee.

10 I'm John Stetkar, Chairman of the
11 Subcommittee meeting.

12 ACRS members in attendance are Charles
13 Brown and Bill Shack. Ilka Berrios of the ACRS staff
14 is the designated federal official.

15 The Subcommittee will review Chapter 9,
16 Auxiliary Systems, of the Safety Evaluation Report
17 with open items associated with US-APWR design
18 certification application.

19 Yesterday we heard presentations from
20 Mitsubishi Heavy Industries and the NRC staff. Today
21 we are going to discuss questions that were raised
22 yesterday during our meeting.

23 We have received no written comments or
24 requests for time to make oral presentations from
25 members of the public regarding today's meeting. The

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Subcommittee will gather information, analyze relevant
2 issues and facts, and formulate proposed positions and
3 actions, as appropriate, for deliberation by the full
4 Committee.

5 The rules for participation in today's
6 meeting have been announced as part of the notice of
7 this meeting previously published in the Federal
8 Register. Parts of this meeting may need to be closed
9 to the public to protect information proprietary to
10 Mitsubishi Heavy Industries or other parties.

11 I am asking the NRC staff and the
12 applicant to identify the need for closing the meeting
13 before we enter into such discussions, and to verify
14 that only people with the required clearance and need
15 to know are present.

16 A transcript of the meeting is being kept
17 and will be made available as stated in the Federal
18 Register notice. Therefore, we request that
19 participants in this meeting use the microphones
20 located throughout the meeting room when addressing
21 the Subcommittee. The participants should first
22 identify themselves and speak with sufficient clarity
23 and volume so that they may be readily heard.

24 We will now proceed with the meeting, and
25 I will call upon I don't know who. Do you want to say

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 anything?

2 MR. KALLAN: Well, this is Paul Kallan. I
3 am the Senior Project Manager, and it is good to have
4 us back here again today. Staff is going to answer
5 the questions that you -- followup questions and also
6 MHI's, too. So --

7 CHAIRMAN STETKAR: Good. Thanks, Paul.

8 With that, I will turn it over to MHI
9 and --

10 MEMBER BROWN: Do we have to give him CPR
11 or resuscitate him over there?

12 CHAIRMAN STETKAR: No, but I heard the --

13 (Laughter.)

14 -- click into place.

15 Before we start, we will take as long as
16 we need this morning to address whatever answers that
17 both MHI and the staff have.

18 If we -- you know, I don't think anybody
19 will complain if we finish early, but whatever
20 discussion it takes to make sure that we have
21 understanding of whatever you have been able to
22 address in the last, you know, 15 or 18 hours, or
23 however long it has been, we would appreciate that. I
24 think that the process works a lot better if we can
25 get things resolved in this context.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So with that, I will turn it over to MHI.

2 MR. SPRENGEL: Well, good morning. This
3 is Ryan Sprengel. I'm an ASDC licensing manager.

4 I would like to, again, thank the members
5 and the NRC staff for continuing to support this
6 meeting. We did work into either the wee hours of the
7 night or the earlier hours of the morning, depending
8 on how you look at it.

9 So this is a fortunate case where we do
10 have, you know, this extra day that we can go ahead
11 and address these instead of putting them off to an
12 official transmittal later. We can go ahead and get
13 these responses now and get them on the record.

14 So hopefully it provides some good
15 clarification and responses to some of the comments we
16 heard yesterday. And I think we have some good
17 discussion material to present, and I will turn it
18 over to Jim Curry.

19 MR. CURRY: Thank you, Mr. Sprengel.
20 Okay. Good morning, Mr. Chairman. Again, my name is
21 Jim Curry. And we have some folks here at the table
22 which we will reintroduced, and some folks at the side
23 table, and, as yesterday, some additional expertise in
24 the audience. So our plan is to get you the best
25 information that we can.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Okay. So at the table you recall Mr.
2 Kawata, Mr. Tanigawa, and Mr. Otani. Okay. And then,
3 we have Mr. Nishio, you know Mr. Sprengel and Mr.
4 Kawanago over there at the side.

5 So what I propose is we will just go down
6 our list of what we perceive to be the Committee's
7 questions and give you some feedback.

8 CHAIRMAN STETKAR: Good.

9 MR. CURRY: And, again, in order of the
10 presentation yesterday, I think, Mr. Chairman, you
11 asked a question with regard to DCD Figure 9.1.4-2.

12 CHAIRMAN STETKAR: Yes.

13 MR. CURRY: And if I recall, your comment
14 was about the weir wall and failure of the weir wall
15 that is shown in that figure, and, really, what would
16 the water level be and time to boiling if we did
17 reduce the water level based on that weir wall
18 failure.

19 I would point you to RAI 132-1538.

20 CHAIRMAN STETKAR: 132-1538?

21 MR. CURRY: Yes, sir. Question 9.1.2-7.

22 CHAIRMAN STETKAR: I can't write that
23 fast. 9.1.2 --

24 MR. CURRY: Dash 7.

25 CHAIRMAN STETKAR: -- dash 7.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. CURRY: Right. So we provided the
2 information that I am just going to summarize for you
3 in that RAI response. Big picture is that if we fail
4 that weir wall, the water level is reduced to about
5 six feet below the starting point, the existing water
6 level.

7 So that gives us quite a bit of room,
8 still. And it's because that water isn't lost, it
9 just flows into the refueling canals.

10 CHAIRMAN STETKAR: Okay. I think you
11 misunderstood my question. My question was simply,
12 suppose that the level is at the height of the weir
13 wall. I'll worry about how it got there. Suppose
14 that it is a level at the height of the weir wall.
15 How long does it take to reach boiling? And how long
16 does it take to reach fuel damage? I'll worry about
17 how it got there.

18 MR. CURRY: Okay. And --

19 CHAIRMAN STETKAR: Because I will
20 guarantee that there -- in a probabilistic sense there
21 are draindown scenarios that can drain the water to
22 that level, that involve flow paths that do not just
23 involve failure of the weir wall and filling the
24 adjacent -- immediately adjacent volume. I guarantee
25 you that there are drain-down paths.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. CURRY: Okay.

2 CHAIRMAN STETKAR: I haven't personally
3 identified all of them. That was my follow-on
4 question to try to get a handle on where they might
5 be. But I will guarantee you that there are drain-
6 down paths.

7 MR. CURRY: Well, with that --

8 CHAIRMAN STETKAR: They may require human
9 errors during refueling operations when the weir --
10 when weir gates are removed. But I guarantee you that
11 there are drain-down paths somewhere. I have never
12 seen a plant where I haven't been able to find at
13 least one.

14 MR. CURRY: Okay.

15 CHAIRMAN STETKAR: So the question was not
16 presuming some combination of failures. The question
17 was simply suppose that the level is at the height of
18 the weir wall. I wanted to confirm what that level
19 really is. And given that, what is the time to heat
20 up to boiling and the time to heat up -- let's call it
21 fuel damage rather than fuel uncovering.

22 MR. CURRY: We appreciate that. Let me
23 just kind of mention -- I mentioned the failure of one
24 weir wall. Our analysis included complete connection
25 of all cavities with all --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: Okay.

2 MR. CURRY: -- weir walls out.

3 CHAIRMAN STETKAR: Okay.

4 MR. CURRY: So --

5 CHAIRMAN STETKAR: So you at least filled
6 the other cavities.

7 MR. CURRY: Yes, sir.

8 CHAIRMAN STETKAR: Not just the --

9 MR. CURRY: Now, that's a different
10 number.

11 CHAIRMAN STETKAR: Sure.

12 MR. CURRY: That still gives us about 12
13 feet above the fuel --

14 CHAIRMAN STETKAR: Yes. I understand
15 that, because of --

16 MR. CURRY: Okay.

17 CHAIRMAN STETKAR: -- volumes of those
18 cavities, yes.

19 MR. CURRY: Okay. So having said that, so
20 that we have connected everything and we have done
21 that analysis, your thought is that you would still
22 like to know, well, let's just say we are at a
23 level --

24 CHAIRMAN STETKAR: That's right.

25 MR. CURRY: Okay. Let me --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: It can't get any --
2 see, the point is that it can't be any worse than
3 that. And as long as there are drainage pathways that
4 can get you to that water level, I am trying to
5 understand what the bounds are in terms of your
6 relative times. I know what the heatup time is given
7 minimum water level.

8 You've done a heat-up calculation now at
9 that -- or perhaps it is in this RAI response -- at
10 that -- what is called an intermediate level given
11 just transference of the upper part of the volume into
12 the adjacent -- you know, what do you want to call
13 them -- cavities or adjacent volumes.

14 MR. CURRY: Right. If you connected all
15 of those volumes, we know what the level would be.

16 CHAIRMAN STETKAR: Yeah, yeah. And I'm
17 asking for the most -- the limiting, if the -- if you
18 were draining to the bottom of the weir wall.

19 The reason I ask this is that we are not
20 talking about PRA here. This is not a risk-informed
21 licensing application, so I don't want to bring in the
22 notion of PRA. However, people have performed PRAs of
23 shutdown modes that indeed have examined
24 configurations where the core is off-loaded into the
25 spent fuel pool the same way that you do it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 You have a fuel transfer tube, you are
2 connected to the reactor cavity, which is flooded up
3 -- I mean, it is a standard plant design -- and have
4 identified, based on plant-specific configurations and
5 operational evolutions, errors or equipment failures
6 that can open up drain paths.

7 Now, some of those drain paths may be from
8 the primary system, but if the transfer gate is open
9 you are now in an interconnected volume. So
10 essentially you can drain the fuel pool into the
11 containment through the transfer canal.

12 Now, you have a time available for that,
13 so, like I said, I don't want to get into the
14 probabilistics of all of this stuff, but indeed you
15 can drain down to those weir wall elevations. In some
16 cases, it requires drainage into the containment.

17 In some cases it requires drainage --
18 that's why I asked you about the drain lines from the
19 transfer canal -- the transfer tube itself, or drain
20 lines from the interconnected volumes, the fuel
21 transfer -- the refueling canal and the other -- the
22 cask volume, things like that.

23 They may be very rare events. And as I
24 said, I am not getting into PRA space here. On the
25 other hand, understanding what the margins may be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 under those conditions gives you a sense of timing and
2 design margin for those types of events. That's the
3 reason I asked the question.

4 You know, I don't want to prejudice
5 studies. I have seen studies where indeed the bottom
6 of the weir wall was below the top of the active fuel,
7 which obviously is not here --

8 MR. CURRY: Not the case here.

9 CHAIRMAN STETKAR: -- because people had
10 never thought of that.

11 MR. CURRY: Right. Well, I think as long
12 as the Committee understands what we have done --

13 CHAIRMAN STETKAR: Yes.

14 MR. CURRY: -- and that is what we want to
15 be sure. Let me just give a nod to the folks in the
16 audience, you know, or my colleagues here. I do not
17 believe that we have a heat-up calculation for the
18 water at that level, at the weir wall level. So we
19 are not prepared to give that to you --

20 CHAIRMAN STETKAR: Okay. Thanks.

21 MR. CURRY: -- today.

22 CHAIRMAN STETKAR: Thanks. As I said, I
23 have to apologize, we don't get all of the RAIs,
24 mostly because we ask for specific ones as they come
25 up either in discussions like this or if they clearly,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 during our reviews of the major -- of the SER identify
2 specific issues. The problem is if we ask for all of
3 them, we would get all of them, and we'd now have
4 10,000 pages to read.

5 Does the response to this RAI question
6 include the heat-up time, or does it only include the
7 equilibrium water level?

8 MR. CURRY: I think it includes only the
9 equilibrium water. The heat-up time is in another
10 calculation.

11 CHAIRMAN STETKAR: Okay.

12 MR. CURRY: And of course, once again,
13 we'll point out we haven't lost the water.

14 CHAIRMAN STETKAR: No, that's right.
15 That's right.

16 MR. CURRY: In these situations, you still
17 have a heat sink.

18 CHAIRMAN STETKAR: Yes. And if you only
19 do -- well, I guess if you are only doing a heat-up to
20 boiling calculation, it doesn't make any difference.

21 MR. CURRY: Right.

22 CHAIRMAN STETKAR: Heat-up to fuel damage,
23 once you get down below the weir wall, it --

24 MR. CURRY: Right.

25 CHAIRMAN STETKAR: -- then becomes

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 different.

2 MR. CURRY: Right.

3 CHAIRMAN STETKAR: Okay.

4 MR. CURRY: But the scenario that you are
5 talking about, I do not think we are prepared to talk
6 about that scenario today.

7 CHAIRMAN STETKAR: Okay.

8 MR. CURRY: Agreed?

9 MR. KAWATA: Yes.

10 CHAIRMAN STETKAR: And for the benefit of
11 the record and the benefit of the staff, I am not
12 necessarily talking about something that is in the
13 licensing basis for the plant either, because, as I
14 said, we have identified these things during
15 probabilistic risk assessment.

16 So I don't want to -- you know, I don't
17 necessarily want the staff to raise this as a
18 particular concern and go on a witch hunt for draining
19 pathways. I'm just trying to understand the plant
20 design for our Committee's benefit.

21 MR. CURRY: Well, and we appreciate that,
22 because clearly -- clearly, it is not a design basis.

23 CHAIRMAN STETKAR: Exactly.

24 MR. CURRY: We probably think it is not a
25 credible event. But that would be our view.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: The word "credible" is
2 something we try not to use in the Subcommittee, so --

3 MR. CURRY: Mr. Kawanago?

4 MR. KAWANAGO: We understand your comment.
5 Could you give me a little bit of time?

6 CHAIRMAN STETKAR: Sure.

7 MR. KAWANAGO: It is a long meeting.

8 CHAIRMAN STETKAR: So, you know, the good
9 and bad things about the Subcommittee presentations
10 especially is that in many cases we are trying to
11 understand perhaps some details or interconnectivity
12 in the plant design that you may not necessarily enter
13 into in the licensing process, the design -- you know,
14 the compartmentalized licensing process.

15 And some of these things kind of help us
16 to understand that a little bit, and that is the
17 genesis of some of these questions. We recognize
18 that, you know, this has visibility, and things like
19 that. And, again, I encourage the staff to take the
20 context of our Subcommittee meetings into
21 consideration.

22 So in this particular instance, I would
23 hope that it is -- it doesn't generate RAIs and other
24 areas of concern, because I don't see anything in the
25 design that makes this plant any more or less

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 vulnerable to these types of drain-down scenarios than
2 any other currently operating plant or any other new
3 reactor that we have seen.

4 So it is not -- you know, it is not a
5 design-specific vulnerability. It is not anything.
6 It is just simply a question.

7 MR. KAWANAGO: We tried to understand your
8 question. This is Shinji Kawanago from MNES. We
9 tried to confirm again what it is you are exactly
10 asking on that question point. And because we would
11 like to explain what is actually the drain line of
12 this spent fuel pit. And the spent fuel is the data
13 you also asked about and drain line in the spent fuel
14 pit. And the spent fuel pit or this cask pit,
15 basically we don't have any drain line.

16 CHAIRMAN STETKAR: There are no drain
17 lines in the cavity? The cask --

18 MR. KAWANAGO: No. No.

19 CHAIRMAN STETKAR: How do you drain those?

20 MR. KAWANAGO: It is a pump out.

21 CHAIRMAN STETKAR: Oh, you pump it out.
22 You put a submersible --

23 MR. KAWANAGO: Yeah.

24 CHAIRMAN STETKAR: Oh, okay. Good.

25 MR. KAWANAGO: That is the basic system.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: You are better than
2 some people.

3 (Laughter.)

4 MR. KAWANAGO: And what we needed to
5 assume -- and how do you say it is not the PRAs --

6 CHAIRMAN STETKAR: Right.

7 MR. KAWANAGO: -- and the discussion.
8 However, I mean, we need to assume the gate failure
9 and the water go to the -- a canal or cask pit.
10 Basically, I don't want to say the PRA scope, but in a
11 single failure, the water will go to the canal. And
12 if we assume the additional gate failure and the water
13 going to the -- in a cask pit, okay, that is basically
14 worst case.

15 So, again, there is no drain piping, so
16 now if they are willing to assume some failure --
17 operational, misoperational, or something like that --
18 the water will go to the canal or cask pit. Okay?
19 So, but still keep the total volume of the water,
20 inventory still keep.

21 So of course when we calculate the boiling
22 time, and then it is reduced from the 2.5 hours to the
23 two hours or -- we have those -- such calculations.
24 And, basically, we still keep the boiling time with --
25 it's approximate two hours. That is our calculation

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we have.

2 CHAIRMAN STETKAR: And I understand that,
3 and I was not trying to -- I'm glad to hear you don't
4 have drain lines from those other volumes. That is a
5 good thing. I will still stand by my initial
6 statement that I guarantee you I can find a drain
7 path.

8 And to give you a hint of what I'm
9 thinking about is if you look at Figure 9.1.4-2, the
10 elevation of the top of the reactor vessel -- I'm
11 assuming this isometric is about right -- seems to be
12 just about the same elevation as the bottom of the
13 slots in the weir wall.

14 There was an event at a nuclear powerplant
15 in the United States a number of years ago. This is
16 not the specific configuration for that event. But
17 because of a valving error during maintenance, they
18 managed to drain the refueling water storage tank into
19 the containment through the residual heat removal
20 system, because of a valving error during maintenance.

21 So that -- and the residual heat removal
22 system, for example, will be connected to the loops in
23 the reactor coolant system. It will be operating
24 during refueling. The fuel transfer tube will be
25 open. You now have a completely connected volume of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 water.

2 And there are drainage paths through
3 maintenance errors or equipment failures that indeed
4 could drain that volume down to the top of the reactor
5 vessel through the loops into the containment at full
6 connected volume. That is one way you can get down to
7 the bottom of that weir wall.

8 Now, I'm not talking about time. I'm not
9 talking about time available for, you know, operators
10 to isolate things. But there is a drainage path.
11 There are mitigation possibilities, but, as I said, I
12 guarantee I can find you a drainage path that will get
13 you to the bottom of the weir wall.

14 MR. CURRY: And I think we understand your
15 concern. If you could just give us one moment to
16 confer --

17 CHAIRMAN STETKAR: Sure.

18 MR. CURRY: -- we'll make sure we have a
19 path forward here.

20 (Pause.)

21 MR. KAWANAGO: We understand.

22 CHAIRMAN STETKAR: You understand? Okay.

23 MR. KAWANAGO: We understand your point.

24 CHAIRMAN STETKAR: I was going to say, in
25 the interest of -- the problem is we are on the public

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 record here, and long silences --

2 MR. CURRY: Absolutely. We appreciate it,
3 sir. We understand the question, and we --

4 CHAIRMAN STETKAR: Okay, good.

5 MR. CURRY: -- will take that as an
6 action.

7 CHAIRMAN STETKAR: Again, I will say it
8 again for the record, for the staff, I personally hope
9 that there aren't any RAIs that come out of this,
10 because it is simply us trying to understand a bit
11 about margins.

12 MR. CURRY: And that is very helpful, and
13 we appreciate you putting it in that context.

14 CHAIRMAN STETKAR: Yes.

15 MR. CURRY: Thank you.

16 CHAIRMAN STETKAR: And you did confirm
17 there are no drain lines from the refueling canal, the
18 cask pit, or the fuel inspection pit, or the transfer
19 tube itself.

20 MR. CURRY: That is correct.

21 CHAIRMAN STETKAR: Good.

22 MR. CURRY: As Mr. Kawanago said.

23 CHAIRMAN STETKAR: Good. And as I said
24 there, in that case, you are indeed -- this design is
25 indeed less vulnerable to some of these drain-down

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 events than some others that we have looked at.

2 MR. CURRY: Okay. Thanks.

3 CHAIRMAN STETKAR: So that is -- that's
4 why we ask these questions. You know, this gives us
5 confidence that you are even less vulnerable than
6 other designs to these types of events.

7 MR. CURRY: We appreciate that insight.
8 That is great.

9 All right. Let us -- so we have discussed
10 basically two of your questions from yesterday, the
11 weir wall and the drain lines.

12 I think the question that Mr. Brown had
13 was about the instrumentation. So as long as we are
14 talking about the spent fuel pool, location of
15 instrumentation, so why don't we go to that
16 discussion.

17 So Mr. Kawata put together this -- and his
18 team put together this slide for us, which kind of
19 summarizes a little bit of the history. So in DCD
20 Rev 3, in terms of level indication, we had two non-
21 safety indications, and they were continuous.

22 All right. And we had a low low level
23 pump trip -- pump trip on low low level. In RAI 756-
24 5753, that was changed to make two or to add two
25 safety grade level switches for the pump stop. We now

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 have -- correct?

2 MR. KAWATA: That's right.

3 MR. CURRY: Okay.

4 CHAIRMAN STETKAR: And those -- Jim, just
5 before -- and do those same safety grade level
6 switches also initiate isolation of the non-safety --

7 MR. CURRY: Well, I think you are
8 anticipating that --

9 CHAIRMAN STETKAR: I'm sorry. Never mind.
10 Never mind. I'm in the wrong system. I'll be quiet.
11 Go on. I'm sorry.

12 MR. CURRY: Not a problem, because you are
13 probably anticipating maybe the third line.

14 CHAIRMAN STETKAR: Yeah.

15 MR. CURRY: We do have an open item.

16 CHAIRMAN STETKAR: Okay.

17 MR. CURRY: And which adds isolation of
18 non-seismic --

19 CHAIRMAN STETKAR: Okay. That's -- I'm
20 sorry, and I was getting ahead of you.

21 MR. CURRY: Right. So that is where we
22 are in terms of the level indication.

23 Now, the locations -- I think there was a
24 question on locations. So near --

25 MEMBER BROWN: Physical locations?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. CURRY: Physical locations --

2 CHAIRMAN STETKAR: And temperature?

3 MR. CURRY: That's true. I mean, do we
4 have a temperature? Yeah.

5 MEMBER BROWN: I'm not finished with the
6 level one yet.

7 MR. CURRY: Okay. Let's finish with the
8 level.

9 MEMBER BROWN: Where the continuous type
10 -- where is that read out?

11 MR. CURRY: Control room.

12 MR. KAWATA: Yes, both control room and
13 the LOCA.

14 MEMBER BROWN: Okay. The reason I ask
15 that is that in the RAI where it talks about in your
16 all's discussion the DCD change, in your all's answer
17 you talked about if you had to recover, it would be
18 done with confirmation of SSP, SFP temperature, and
19 the water level locally.

20 So there was an inconsistency between your
21 answer in the 5753 -- that's why I was asking for, you
22 know, just a little tabular readout of wherever these
23 go, and then make sure it's reflected. When I looked
24 at the table that you all modified, I did not see the
25 continuous one even listed. It was just the two low

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 level switches that was in -- let me find the right
2 table number.

3 MR. KAWATA: Table 3D --

4 MEMBER BROWN: 3D-3. Two, excuse me.
5 There is only two level gauges listed there. And
6 based on the designation, those appear to be the two
7 switches.

8 MR. KAWATA: We only show the safety-
9 related, Table 3D-3. The continuous -- whatever it
10 is, non-safety data. So we don't show that non-safety
11 data needs to be mentioned in 3D.

12 CHAIRMAN STETKAR: I can kind of see the
13 evolution of this thing. The questions were raised
14 about need for safety-related instrumentation, so it
15 has evolved from two non-safety, and now the RAI
16 responses are focused on what they are making safety,
17 and now the follow-on things are what functions are
18 going to be performed by the safety-related. And
19 apparently the single remaining non-safety-related
20 continuous readout channel has been --

21 MEMBER BROWN: Lost in the shuffle.

22 CHAIRMAN STETKAR: Yeah. It's still --
23 it's there, but it has been lost, you know, out of the
24 context of the discussions regarding, in particular,
25 safety-related instrumentation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: Well, I am just kind of
2 curious. We don't have a safety-related, you know,
3 gauge that you can read. It's a non-safety-related,
4 with nothing but a low level switch. I mean, to me it
5 went from two non-safety-related gauges to no safety-
6 related gauges, no visibility of the level in the main
7 control room other than with a non-safety-related
8 gauge.

9 And they used to have multiple levels of
10 -- well, actually they have a high and a low level,
11 although the figure that was provided in there only
12 showed a low.

13 MEMBER SHACK: That's non-safety.

14 MEMBER BROWN: What?

15 MEMBER SHACK: That's non-safety.

16 MEMBER BROWN: No, I'm -- yeah, on the
17 continuous one. And on the safety ones it is only a
18 low low amount. It's not a low as well. So there is
19 only one level indicator. I mean, I'm assuming --

20 MR. CURRY: The redundant safety level
21 switches, right?

22 MEMBER BROWN: Well, they each feed their
23 trains --

24 MR. CURRY: Right.

25 MEMBER BROWN: -- for the interlock

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 purposes. I mean, at least that's the words said,
2 that they were interlocked with their -- with one --
3 each with one of the two trains, whichever way you
4 define them.

5 MR. CURRY: So you are correct, that is
6 where we are at this point. We are done at safety
7 level switches, non-safety, continuous readout.

8 MEMBER BROWN: The annunciation -- you say
9 a setpoint. How low on the non-safety gauge?

10 MR. KAWATA: Yes.

11 MEMBER BROWN: I presume that is an alarm
12 setpoint?

13 MR. KAWATA: Yes. We have alarms.

14 MEMBER BROWN: Annunciating?

15 MR. KAWATA: In safety items.

16 MEMBER BROWN: Well, those annunciate
17 also. I think you said that in the words. The safe
18 ones do annunciate also in the main control room.

19 MR. KAWATA: That's right. We use a non-
20 safety-related instrument for normal makeup of SFP, so
21 setpoint of the load for the non-safety, the loads are
22 about four inches for the normal water level. The
23 setpoint is low low for safety-related. The setpoint
24 is below -- about four feet from the normal water
25 level.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 The purpose of that low low setpoint is to
2 maintain the water level above the suction level --

3 MEMBER BROWN: I understand that.

4 MR. KAWATA: -- over the suction rate for
5 pump protection. So for safety-related, to have only
6 one setpoint is adequate, because -- so only one
7 setpoint to maintain the pump integrity.

8 MEMBER BROWN: So I presume it is higher
9 than the low low, the setpoint would be higher?

10 MR. CURRY: One moment.

11 CHAIRMAN STETKAR: I think that's what he
12 said. He said the low level setpoint is four inches
13 below the normal level, and the low low is four feet I
14 think is what they said.

15 MEMBER BROWN: All right.

16 MR. CURRY: The low low is for the pump
17 protection.

18 MEMBER BROWN: Yeah. No, I understand
19 that point. I just -- I missed the specific level. I
20 didn't catch that. Well, if that's what it is, I just
21 --

22 CHAIRMAN STETKAR: I mean, in some sense,
23 someone yesterday asked the question about, how does
24 all of the current orders --

25 MEMBER BROWN: Well, that's ultimately

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 where I was going with --

2 CHAIRMAN STETKAR: -- comply to a design
3 certification. And the answer we got is the staff
4 doesn't know yet.

5 MEMBER BROWN: Yeah. And --

6 CHAIRMAN STETKAR: So I'm hoping that by
7 the time we see the final SER, with no open items, I'm
8 hoping that the staff has the resolution of how the
9 orders apply, either to the design certification or to
10 the COL applicant, resolved by that time. Otherwise,
11 I suspect we are going to have -- you know, the
12 Committee may have questions about that.

13 MEMBER BROWN: Well, there are several of
14 us that have brought up the issue of the
15 instrumentation and the lack of, you know, continuous
16 implementation and the circumstances under which the
17 orders are being issued. And we -- so, yes, there's a
18 couple of level gauges, that's fine if they're non-
19 safety-related. But there are a couple of level
20 gauges and then all of a sudden we don't have them
21 anymore. So --

22 CHAIRMAN STETKAR: I mean, at least for me
23 this clarifies --

24 MEMBER BROWN: Yes, I --

25 CHAIRMAN STETKAR: -- the current concept

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of the design. Now, how that may or may not change
2 moving forward in light of the orders, in the context
3 of the design certification, I don't think any of us
4 know that.

5 MEMBER BROWN: No, I understand.

6 CHAIRMAN STETKAR: And the message is,
7 this is still Phase 3 of the staff's review with open
8 items, and we will see this again, you know, in
9 Phase 4. And as I said, I hope that by the time we
10 see Phase 4 the staff will have sorted out the
11 applicability of the orders, you know, in particular
12 to the two in progress. I mean, the same questions
13 apply equally to USEPR.

14 MEMBER BROWN: Yes. I'm just respective
15 of at least one other Committee member who, along with
16 me, has raised this particular point, trying to make
17 it clear that this -- there will probably be raised
18 eyebrows at the -- during the full Committee.

19 I would argue that the full Committee may
20 or may not agree with this, but, I mean, it will be
21 brought up again in terms of the -- I don't want to
22 say lack of, but the reduced amount of indication or
23 the -- that may be available under some circumstances
24 if you needed it. So it's -- and its ability to
25 service people in the main control room.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Right now when I look at this, and I have
2 finished reading the words, plus one other
3 supplemental RAI that was given to me by the staff
4 after our other conversation yesterday, there were --
5 there are still a few inconsistencies. I'm not going
6 to sit here and grind through those.

7 This clarifies exactly what you are saying
8 you are going to, and I would just encourage the staff
9 and you all to make sure that the DCD changes are
10 consistent. And I -- like you say, you only address
11 safety-related stuff in the tables, but it would seem
12 in the DCD, in the Tier 2 stuff, you ought to at least
13 give an indication of where the non-safety unit reads
14 out. Is it remote shutdown console as well as the
15 main control room, etcetera? That just seemed to be
16 lacking relative to where those are.

17 Same thing -- and I think both the
18 temperatures, if you can flip over to the temperature,
19 I think both of those are continuous, and they are
20 both safety-related. And, again, where is that
21 temperature indication clearly articulated as opposed
22 to just locally?

23 A couple of your words in your
24 discussions talked about recovering locally, which
25 gave the implication that there was no remote

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 indication. Whereas -- and that's why I'm saying on
2 the other one, the level one, it just says, "I've got
3 continuous," but where is it? That wasn't -- it
4 wasn't crisply stated. In fact, it wasn't explicitly
5 stated.

6 MR. CURRY: We appreciate that, and we
7 understand your point about -- I think just to repeat
8 back to you -- where is this instrument? Where can
9 operators see and have this information?

10 MEMBER BROWN: And where the temperature
11 was located in the pool itself. That was the other
12 question.

13 MR. CURRY: Fairly high, two of them,
14 safety-related at diagonal --

15 MEMBER BROWN: Diagonally across the pool.
16 You say "fairly high." What does that mean?

17 MR. CURRY: I don't know if we -- I don't
18 know the exact elevation, but I --

19 MEMBER BROWN: It didn't seem to be
20 specified. I couldn't find any --

21 MR. CURRY: Right. And I don't --

22 MEMBER BROWN: -- numbers.

23 MR. CURRY: I don't have that information
24 here, but I guess I just wanted to get across the
25 point that it is high in the pool and, you know,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 indicative of, you know, temperature in the pool area.

2 But it is not high and low.

3 MEMBER BROWN: Still above the fuel level,
4 top of the fuel --

5 MR. CURRY: Oh, yes, sir. Oh, yes, sir.

6 MEMBER BROWN: -- both of them above the
7 top --

8 MR. CURRY: Oh, yes, sir. Absolutely.

9 MEMBER BROWN: So once the water level got
10 below the fuel, or the top of the fuel, you would not
11 have any indication of temperature, is that correct?

12 MR. CURRY: That is absolutely true.

13 CHAIRMAN STETKAR: Yes, you would probably
14 be measuring air.

15 MEMBER BROWN: Pardon?

16 CHAIRMAN STETKAR: You would be measuring
17 air at that point.

18 MEMBER BROWN: Well, no, you would be. If
19 you don't have any sensors below that level, then you
20 would be measuring air, which would be kind of
21 useless.

22 CHAIRMAN STETKAR: Well, I suspect until
23 that point it will be somewhere around 100 degrees C.

24 MEMBER BROWN: Well, once it starts
25 boiling, it is what it is. It doesn't go any -- it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 doesn't change.

2 MEMBER SHACK: 100 degrees C is probably a
3 pretty good guess, yes.

4 MEMBER BROWN: Okay.

5 CHAIRMAN STETKAR: Anyway, to kind of
6 summarize this, I --

7 MEMBER BROWN: We are probably not
8 finished with it, that is the --

9 CHAIRMAN STETKAR: I don't think we are
10 finished, but I think that this information at least
11 gives us enough to understand what the current
12 snapshot of the design is.

13 MEMBER BROWN: Can we get a copy of these
14 viewgraph pages?

15 CHAIRMAN STETKAR: We will get them. It's
16 part of the public record now, so -- by the way, make
17 sure -- you do realize that anything you show today is
18 part of the public record. That's the caution that I
19 read earlier regarding proprietary information. Keep
20 that in mind as we get into some of these discussions,
21 because everything that is shown here and anything
22 that is said is part of the public record.

23 So if during these discussions -- and I
24 would emphasize -- be sensitive if we delve into
25 proprietary design information, let us know. We can

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 close the meeting. We have the latitude to do that.
2 It is simple to do. But I want to caution you about
3 that, because we are getting into some details.

4 So far you have only mentioned things that
5 are RAI responses, which are also, you know, on the
6 docket. But if we get too far afield here, be
7 sensitive to that.

8 MR. CURRY: Thank you, sir. We appreciate
9 that.

10 CHAIRMAN STETKAR: And to just summarize,
11 you know, it is all we can do at Phase -- we now have
12 a snapshot of the current version of the design to
13 support Phase 3 of our review. We will see the SER
14 during Phase 4 with no open items, and I hope that by
15 that time the whole integration or decisions regarding
16 the integration of the orders with respect to this
17 particular, either design certification or COLA, will
18 have been ironed out.

19 And, you know, at that point in Phase 4 we
20 can take that information, plus whatever the final
21 resolution of the remaining RAIs and open items are,
22 into consideration when we write our final letter, you
23 know, on this chapter.

24 MEMBER BROWN: Could you flip back to the
25 previous slide for just a minute? There is another

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 RAI down there, 57.23, which I wanted to make a note
2 of. That's the open one.

3 MR. CURRY: One moment. Is this the right
4 -- yeah, okay.

5 MEMBER BROWN: I take it you all have
6 either answered that and it hasn't been resolved with
7 the staff, or what have you? It says open, so --

8 MR. CURRY: Yes. It is open. I'm not
9 sure whether we've given a draft to the staff or
10 whether we have formally submitted that, but yeah.

11 MEMBER BROWN: That's fine. That's good
12 enough. Okay. I have it, so --

13 MR. CURRY: Okay. All right. Related to
14 the fuel pool, if you recall yesterday there was a
15 question -- I think it was yours, Mr. Chairman --
16 about the RWSP line, the cleanup of the RWSP, and
17 fundamentally how do we isolate that cleanup line, the
18 purification loop around --

19 CHAIRMAN STETKAR: Yes.

20 MR. CURRY: -- the spent fuel pool cooling
21 system. And on one of our slides we showed a
22 connection to the RWSP and explained that we use the
23 system for RWSP cleanup.

24 So we have confirmed there is no automatic
25 isolation on that line. We would expect that line to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 be used only rarely during or after coming out of an
2 outage. If there were leakage from that line, we
3 would probably notice it first on some sump-level
4 indication. We don't think the operation of the
5 valves would be affected. I think you questioned
6 whether they would be underwater if we had to close
7 the valves.

8 CHAIRMAN STETKAR: Yeah. Either the inlet
9 valves -- you replaced the -- you have automatic
10 isolation valves.

11 MR. CURRY: You're talking about that
12 connection to the RWSP.

13 CHAIRMAN STETKAR: The automatic isolation
14 valves -- and I've forgotten -- the problem is I only
15 have a Rev 3 -- you had it yesterday on one of your
16 slides I think.

17 MR. CURRY: Yes, if I could get the
18 presentation up from yesterday. Thanks, Ilka.

19 CHAIRMAN STETKAR: And I've forgotten --
20 unfortunately, the only thing I have printed out is --
21 and I know -- is the Rev 3 -- it's Slide 15 of your
22 SFPS -- SFPCS presentation. There you go.

23 Now, did I recall yesterday that in
24 interim Rev 4 the -- did you say you changed the
25 outlet valves? Right there. Those are now automatic

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 isolation valves. That doesn't help the RWSP.

2 MR. CURRY: This one.

3 CHAIRMAN STETKAR: Yeah, yeah. And the
4 inlet valves up at the top are still manual valves?

5 MR. CURRY: So sorry. So this is the path
6 that we are talking about.

7 CHAIRMAN STETKAR: Yes.

8 MR. CURRY: Right? Okay.

9 CHAIRMAN STETKAR: Yes. Inlet there
10 through the demineralizer back through the common
11 cross-tie line back to the -- that path.

12 MR. CURRY: Right. Here is the automatic
13 extension on --

14 CHAIRMAN STETKAR: Yes.

15 MR. CURRY: Okay. Right. And I think
16 that was your question --

17 CHAIRMAN STETKAR: That's right.

18 MR. CURRY: -- from yesterday.

19 CHAIRMAN STETKAR: Yeah, yeah.

20 MR. CURRY: So as I mentioned, we
21 researched that there is no automatic isolation. We
22 would expect operator action, you know, to isolate
23 that path. You asked how often it would be used. It
24 would be rarely used.

25 CHAIRMAN STETKAR: And that is based on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 experience from similar --

2 MR. CURRY: Right. And the purpose.

3 CHAIRMAN STETKAR: That makes sense. I
4 was just curious from -- some plants that have stand-
5 alone refueling water storage tanks have a little
6 continuously operating cleanup loop on them. I mean,
7 I have seen many designs. This one is -- you know,
8 because of your pit, you use this. I was just
9 curious, based on the operating experience, how
10 frequently people need to do cleanup on that. It's
11 just a little different than a tank.

12 MR. CURRY: Okay.

13 CHAIRMAN STETKAR: And those valves that
14 show on this drawing around the demineralizers are all
15 located in the demineralizer rooms, is that correct?

16 MR. CURRY: These valves?

17 CHAIRMAN STETKAR: Yes. I mean, that
18 doesn't help the RWSP in particular here.

19 MR. CURRY: No, no.

20 CHAIRMAN STETKAR: But that was for other
21 concerns about potential draining of the spent fuel
22 pit.

23 MR. CURRY: Well, actually, we can talk
24 about that one.

25 CHAIRMAN STETKAR: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. CURRY: Let's talk about that question
2 next. We have that on our list. I think that
3 question had to do with manual -- well, the question
4 that we had on the list was the floor drain question
5 from that area, and you had asked a question --

6 CHAIRMAN STETKAR: Oh, yes.

7 MR. CURRY: -- about closing the floor
8 drains, why were the floor drains --

9 CHAIRMAN STETKAR: Not from this area.
10 That was from the -- that was from the safety-related
11 rooms.

12 MR. CURRY: Okay.

13 CHAIRMAN STETKAR: That was a different
14 question regarding the --

15 MR. CURRY: Okay.

16 CHAIRMAN STETKAR: -- equipment and floor
17 drain system --

18 MR. CURRY: Right.

19 CHAIRMAN STETKAR: -- in particular, that
20 -- I don't recall having a question about floor drains
21 from this --

22 MR. CURRY: Okay.

23 CHAIRMAN STETKAR: -- this room.

24 MR. CURRY: I think you're correct.

25 CHAIRMAN STETKAR: I was just curious

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 about if someone -- if the operators had to go in and
2 locally isolate this part of the system, either
3 because of leakage --

4 MR. CURRY: These valves, okay.

5 CHAIRMAN STETKAR: -- those valves, you
6 know, now the -- and even the other -- the valves that
7 you have made automatic, the return valves to the
8 spent fuel pool, are those valves physically located
9 in the room with the demineralizers, or are they
10 outside of that room? In other words, are they
11 accessible, and could they be affected by flow?

12 MR. CURRY: One moment.

13 (Pause.)

14 Maybe, Mr. Chairman, we can check on that.

15 I don't think we know the answer right now.

16 CHAIRMAN STETKAR: Okay.

17 MR. CURRY: Maybe we can put that to bed
18 before we leave today.

19 CHAIRMAN STETKAR: Thanks.

20 MR. CURRY: All right. I think there was
21 a question -- I think this kind of takes care of our
22 questions on 9.1. that we had from the Committee.
23 There was a question on -- or I should say 9.1.3 to be
24 more exact. I think there was a question in 9.1.4
25 about the polar crane, seismic restraints on the polar

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 crane.

2 CHAIRMAN STETKAR: Not the polar crane,
3 the cask --

4 MR. CURRY: Well, the cask crane --

5 CHAIRMAN STETKAR: -- the cask crane. It
6 does?

7 MR. CURRY: -- restraint. It does. Are
8 you answering or --

9 CHAIRMAN STETKAR: No. You said polar
10 crane. The question is: does the cask --

11 MR. CURRY: Have the same restraints.

12 CHAIRMAN STETKAR: -- have the same
13 restraints for, you know, tipping or preventing
14 derailment basically.

15 MR. CURRY: Right. And the answer is yes.

16 CHAIRMAN STETKAR: It does. Good. Thank
17 you.

18 MR. CURRY: All right. We had a question
19 in 9.2.2, and that -- that really came up with regard
20 to the 10 minutes for restoring cooling to the RCP
21 pumps.

22 CHAIRMAN STETKAR: Yes.

23 MR. CURRY: And you questioned, well, what
24 is the basis for the 10 minutes?

25 CHAIRMAN STETKAR: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. CURRY: And whether we would get into
2 any trouble with vibration before that time. So the
3 limiting reason for that cooling is bearing cooling.

4 CHAIRMAN STETKAR: That is bearing
5 cooling.

6 MR. CURRY: Right. But heatup of the
7 bearing versus the motor or things like that. So it's
8 the bearing and it's a manufacturer's recommendation
9 and the manufacturer tells us, you know, if you can
10 get cooling back to the bearings within 10 minutes
11 there is no significant vibration of the pump.

12 CHAIRMAN STETKAR: And just let me make
13 sure, Jim, so that I understand it, because everything
14 that I had read seemed to have -- seems to say motor
15 cooling. But you're saying it is indeed bearing
16 cooling. Because, you know, there are three coolers.
17 There is the upper bearing lube oil cooler, the lower
18 bearing lube oil cooler, and, you know, what is called
19 the motor cooler, which I'm assuming is the motor
20 winding cooler.

21 MR. CURRY: Right. And I think the
22 question was, which one of these guys is limiting.

23 CHAIRMAN STETKAR: Yes.

24 MR. CURRY: And based on our research, the
25 driver for the 10 minutes is the bearing.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: Is the bearing, and
2 that is -- actually, from my experience that is
3 normal. That's why I was asking the question about
4 why the motor was limiting. So it is the bearings,
5 and it just --

6 MR. CURRY: Manufacturer's recommendation.

7 CHAIRMAN STETKAR: Manufacturer's
8 recommendation. So you can -- you have assurance that
9 if you can get it back in 10 minutes you are okay.
10 You just don't necessarily know what the margin is to
11 -- you know, at 10 minutes and 30 seconds, do things
12 get really bad, or is that just a manufacturer being
13 very --

14 MR. CURRY: At this point, that was --

15 CHAIRMAN STETKAR: -- conservative.

16 MR. CURRY: -- that was what we used to
17 set the 10 minutes.

18 CHAIRMAN STETKAR: Thanks. That at least
19 helps, and to know that it's the bearing helps. I
20 don't know what to do with it, but it helps. And I
21 think you mentioned there is still an open RAI out
22 through Chapter 8 or something like that about the
23 basis for survivability of the pumps under loss of
24 cooling. Is that right, Paul? Right, yeah.

25 MR. CURRY: All right. I think there was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 a question also in 9.2.2 about component cooling
2 water, and do we have a problem. And, actually, I
3 think this was a question to staff, so just very
4 briefly, you know, we do not have a problem with pump
5 runout if we open one train versus another train. You
6 know, one pump of a CCW train provides cooling to both
7 trains.

8 CHAIRMAN STETKAR: Right, right.

9 MR. CURRY: 9.2.6, there was a question
10 about the dyke around the demineralized water storage
11 tank. Answer is no.

12 CHAIRMAN STETKAR: Okay.

13 MR. CURRY: No dyke.

14 9.2.7, there was a question --

15 CHAIRMAN STETKAR: If you -- hold on just
16 a second. I'm a slow writer, and I'm still back
17 jotting down notes on the reactor coolant pumps.

18 (Pause.)

19 We eventually get the transcripts, but I
20 hate going through those.

21 Let's see, no dyke.

22 Okay. I'm caught up, thanks.

23 MR. CURRY: Okay. The dyke question,
24 9.2.6, no dyke around the demineralized water storage
25 tank.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIRMAN STETKAR: Okay.

2 MR. CURRY: 9.2.7, Question G, the
3 Committee was surprised that the electric pump, EFW
4 pump heat load was higher than the turbine-driven pump
5 heat load. The answer to that is the calculation for
6 the electric pump was simply based on an efficiency-
7 type calculation. So if the pump was 80 percent
8 efficient, we assumed 20 percent went into the room
9 and was a heat load to the room.

10 For the turbine-driven EFW pump, that is
11 not the way the analysis took credit for installation
12 of the pump and supporting exhaust piping. So that is
13 why that heat load was not so significant.

14 CHAIRMAN STETKAR: Okay. So it is
15 basically a different -- difference in the analysis.

16 MR. CURRY: Just in the analysis. All of
17 the energy, all of the waste heat from the electric
18 pump, was assumed to heat up the room.

19 CHAIRMAN STETKAR: Yes.

20 MR. CURRY: Not the case for the turbine-
21 driven pump. You know, it is contained, goes back
22 into the water, for example.

23 CHAIRMAN STETKAR: Okay. At least that is
24 an explanation for the different -- I mean, you know,
25 you are using it to size the ECWS capacity, and it is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 pretty conservative, you know, for the motor-driven.
2 It explains the difference. Thanks.

3 MR. CURRY: 9.2.7 --

4 CHAIRMAN STETKAR: Hold on a second. As I
5 said, I'm a really slow writer.

6 (Pause.)

7 MR. CURRY: And apparently, you know, the
8 staff also asked the same question during an audit,
9 so --

10 CHAIRMAN STETKAR: Oh, okay. We don't get
11 the RAIs. We don't even hear about the audits.

12 MR. CURRY: Okay.

13 CHAIRMAN STETKAR: Okay. Thanks, Jim.
14 I'm caught up.

15 MR. CURRY: Related to that, there was a
16 question about turbine-driven EFW pump and whether
17 steam leakage was considered. And, you know, based on
18 Japanese experience -- and also the question was
19 Japanese experience, whether steam leaks were common,
20 the answer to that is no. And steam leakage wasn't
21 considered in the turbine-driven EFW pump room
22 calculation, heatup calculation. The view is that
23 such leakage would be minor and is encompassed by the
24 margin.

25 CHAIRMAN STETKAR: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. CURRY: Also, in 9.2.7, there was a
2 question about double-lock closed isolation valves on
3 the line from the CCW to the fan coolers.

4 CHAIRMAN STETKAR: Yes.

5 MR. CURRY: And the short answer to that
6 is there is only one locked closed valve on each line.

7 It is not a double-lock closed valve, so it meets the
8 requirement.

9 CHAIRMAN STETKAR: Yes. I was going to
10 say those two single -- they are called lock closed,
11 you know, motor-operated valves, which I'm assuming
12 means that the motor is deenergized. Those are the
13 two valves, one on the inlet and one on --

14 MR. CURRY: That's correct.

15 CHAIRMAN STETKAR: -- on the return.

16 MR. CURRY: Correct.

17 CHAIRMAN STETKAR: Okay. Okay. Thank
18 you.

19 MR. CURRY: And then there is a question
20 in 9.3.3, this is the one I misspoke on earlier about
21 the floor drains in the ESF room. And you kind of
22 questioned, well, why did we close -- why did we have
23 normally closed valves versus open? And Mr. Nishio
24 gave you the answer that --

25 CHAIRMAN STETKAR: I understand the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 concern about not coupling -- I think you characterize
2 them as the east and the west sides, you know, through
3 the common drain system. I understand that concern.

4 MR. CURRY: And I think you asked a
5 question about balance. Well, gee, how did you -- did
6 you overweight one issue or --

7 CHAIRMAN STETKAR: Right.

8 MR. CURRY: -- another? And we reviewed
9 that. You questioned, well, could check valves have
10 done the job? Again, it is a safety-related function.

11 The desire was to have valves that you could monitor.

12 There is a sump in those rooms that has level
13 indication. So if you had a leak -- that level
14 indication that's in the control room, so if you had a
15 leak, the operator could take action to open the drain
16 valves if necessary.

17 So with the balance of the safety concern
18 about keeping those -- the east and west sides
19 separated, and the monitoring of potential leakage,
20 which would allow for operator action to open the
21 drain valves, the decision was to keep those valves
22 normally closed.

23 CHAIRMAN STETKAR: And you said each room
24 does have a sump with a level --

25 MR. CURRY: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: -- level indication or
2 a level alarm.

3 MR. CURRY: Yes, sir.

4 (Pause.)

5 CHAIRMAN STETKAR: Okay.

6 MR. CURRY: And then that brings us up to
7 9.5.1, the fire protection. You had a question about,
8 really, the convergence of the four trains. And Mr.
9 Ron Reynolds is back. He can explain that issue.

10 MR. REYNOLDS: Okay. Well, good morning.
11 Yes. We looked at the convergence of all four trains
12 to the control room. That is the question. And the
13 question is, do we have physical separation as all
14 four trains enter into the control room?

15 And what we found is, yes, we do have
16 that. As of yesterday, I thought we may have had a
17 chance of some fire wrap being needed, which is
18 certainly not an issue. But we had to go through the
19 cable routing to determine that in fact we have the
20 separation.

21 So I would ask the ACRS Committee to look
22 at DCD Figures 9.A-3 and 9.A-5. Now, those figures
23 are layouts --

24 CHAIRMAN STETKAR: Yes.

25 MR. REYNOLDS: -- and they are SRI.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: Right.

2 MR. REYNOLDS: And so if we needed to go
3 into more detail and description of how that happens,
4 I would certainly be glad to give that. We probably
5 need to do that --

6 CHAIRMAN STETKAR: We would have to close
7 the meeting.

8 MR. REYNOLDS: That's correct, sir.

9 CHAIRMAN STETKAR: Let me ask, Ron, before
10 we decide -- let me ask the other members. Do we want
11 to look -- I see people searching on their computers,
12 so they are probably looking at the figures. I looked
13 at those figures yesterday. Are those figures -- you
14 know, they're at specific elevations.

15 MR. REYNOLDS: Correct.

16 CHAIRMAN STETKAR: Is there any
17 intermediate volume in an elevation between those two
18 horizontal slices? In other words, the one thing -- I
19 can't figure the figure number -- the one figure
20 number shows distinct compartments with walls around
21 them. The other figure shows simply the footprint of
22 the main control room. Do the walls that are shown on
23 the lower figure extend -- and tell me when I get into
24 too sensitive things here -- extend all the way up to
25 the main control room?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. REYNOLDS: Right. Simply -- I think
2 your understanding is correct. It is an extension.

3 CHAIRMAN STETKAR: It does.

4 MR. REYNOLDS: As you look -- Figure 9.A-3
5 and 9.A-5, there is a 9.A-4 that has that intermediate
6 level. And the rooms in discussion here are a
7 continuation.

8 CHAIRMAN STETKAR: Are a continuation.
9 Okay, great. Thank you. And 9.A-4 -- I probably
10 missed 9.A-4.

11 MR. REYNOLDS: Well, that's not one that I
12 was asking about. 9.A-4 is an intermediate interval.

13 CHAIRMAN STETKAR: Okay.

14 MR. REYNOLDS: But in most cases you will
15 find just the footprint with an X through it, which
16 represents that that wall would --

17 CHAIRMAN STETKAR: Oh, okay.

18 MR. REYNOLDS: -- or room would continue
19 up to the next level.

20 CHAIRMAN STETKAR: Thank you. I'm not
21 going to ask how you get -- so all of -- essentially
22 they remain separated by division until they get to
23 the main control room. And then, in the main control
24 room --

25 MR. REYNOLDS: That's correct.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: -- whether it's the
2 sub-floor area in the main control room that you do
3 all of the cross-talk there --

4 MR. REYNOLDS: That is correct.

5 CHAIRMAN STETKAR: Okay. Okay, good. I
6 mean, that's good. Good. Thank you.

7 MR. REYNOLDS: You're welcome.

8 MR. CURRY: So, Mr. Chairman, that is the
9 list of questions we have that we took yesterday. And
10 so from our understanding at this point, we -- I have
11 one action item that we talked about, which was the
12 weir wall calculation.

13 CHAIRMAN STETKAR: Yes, the weir wall
14 heatup.

15 MR. CURRY: So at this point that's where
16 we think we are with regard to the Committee.

17 CHAIRMAN STETKAR: Well, you have a much
18 better perspective than I do, because I have piles of
19 notes and things here. What we will do is, after
20 these meetings we always go back and go through the
21 transcripts and go through our notes.

22 And if there are any remaining questions
23 that we have, what we have typically done in the past
24 is we will highlight them and make sure that they get
25 to you probably through the staff. I think that is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the way we have been doing it, right, Ilka? You know,
2 in a sense of completeness.

3 I certainly appreciate you -- you
4 obviously, as you said, either late night or early
5 morning or really late night, I really appreciate all
6 of the effort that you have put in. MHI has --
7 continues to be very, very responsive to these things.

8 And we certainly -- we really appreciate this. It
9 helps us. It keeps the process moving, and I
10 certainly thank you very much.

11 Either of the other members have any
12 further questions or points?

13 (No response.)

14 Well, thank you. I appreciate it. And
15 thank you very much.

16 MR. CURRY: We thank the Committee. Thank
17 you.

18 CHAIRMAN STETKAR: Did you want to say
19 something?

20 MS. BERRIOS: If you want to take a break
21 or you wanted to go straight with --

22 CHAIRMAN STETKAR: It depends on -- Paul,
23 how long do you think you will need?

24 MR. KALLAN: Not long.

25 MR. HAMZEHEE: Ten to 15 minutes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: If it's 15 or 20
2 minutes, why don't we just go to completion. If it
3 was going to be half an hour or 45 minutes, I would
4 take a break. But let's --

5 MR. HAMZEHEE: It's about 10 to 15
6 minutes.

7 CHAIRMAN STETKAR: Fine. Let's just
8 finish up with the staff and we can all happily
9 depart.

10 (Pause.)

11 Let me just clarify things. Bill, to get
12 it on the record -- I was kind of asking you offline,
13 but you were talking loud enough that it was picked
14 up. I had a question about -- you had a question
15 yesterday about the possible anomaly of the
16 performance of Metamic material.

17 MEMBER SHACK: In BWR and PWR
18 environments.

19 CHAIRMAN STETKAR: You know, pure water
20 versus high pH borated water. And you have looked at
21 that and thought about it and it's okay.

22 MEMBER SHACK: Right. I mean, I have
23 looked at the experience with it and it's good. I
24 have looked at a number of reports telling me that it
25 is -- it really -- you know, you do want to use -- or,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 you know, you may want to consider using the anodized
2 version in the BWR. In a PWR, it's good.

3 Then, I was trying to figure out why that
4 would be the case, because normally one things of
5 aluminum oxide as being very stable at pH 7 and the
6 solubility goes up as you go either acid or base. And
7 we had the same anomaly actually in considering
8 GSI-191 stuff at Argonne when we made aluminum
9 precipitates and we suddenly found that it would
10 dissolve in high purity water at pH 7 and it was quite
11 stable in borated water at ph 5.

12 And that -- we finally concluded to
13 ourselves that the problem was that you can't just
14 look at solubility in terms of pH alone. There is an
15 important factor of ionic strength, and in BWRs there
16 isn't a floating -- there is not an ion to be found.
17 I mean, the conductivity that they maintain is so low
18 that it is incredible, and that is really what
19 explains the difference in performance when you look
20 at the nominal pHs and say, "It should be worse in
21 PWRs, and it just isn't."

22 And as I say, that is consistent with our
23 own lab experience with aluminum oxide for a
24 completely different situation, but still looking at
25 that solute stability and it just -- my chemists keep

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 telling me I have to keep thinking about ionic
2 strength, and I just sort of go first order to pH and
3 get it wrong every time.

4 CHAIRMAN STETKAR: Thank you. So at least
5 that -- I mean, that was kind of a lingering thing.
6 You said you were going to go look at those reports.
7 So that -- good. That's closed out.

8 Okay. Paul, it's yours.

9 MR. KALLAN: All right. So we have some
10 followup answers to the questions that were -- that
11 you asked yesterday. And we will start off with
12 9.2.5. I'll turn it over to Larry with regards to the
13 ultimate heat status.

14 MR. WHEELER: Good morning, Mr. Chairman.
15 I'm Larry Wheeler, Balance of Plant. And one of the
16 items left over from yesterday was the design basis
17 statement in 9.2.5.1, which talks about the reference
18 to Reg Guide 1.27 and 36-day cooling related to a
19 pond.

20 And I handed you a copy of Reg Guide 1.27.
21 There is a discussion -- a long discussion related to
22 meteorological conditions related to 30 days and 36
23 days using a pond. So I would recommend that I work
24 with MHI and we kind of clean up the DCD, not that we
25 are going to resolve it here, but maybe just refer

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that Reg Guide 1.27 applies and get rid of the cooling
2 pond.

3 CHAIRMAN STETKAR: I think for expedience
4 that might clarify any questions. Again, for the
5 design certification, it is a moot point, because this
6 is all COL.

7 MR. KALLAN: That's correct.

8 CHAIRMAN STETKAR: But for stability with
9 the COL, especially -- I think you mentioned yesterday
10 that Reg Guide 1.27 is in the process or review and
11 revision and update. And I did read the Reg Guide
12 last night. I am better educated than I was 24 hours
13 ago. And sometimes better education leads to improved
14 confusion. So we will just leave it that way.

15 At least you have answered my question. I
16 was asking, you know, primarily what was -- was there
17 regulatory, you know, guidance. And you pointed me in
18 the right direction, so --

19 MR. KALLAN: Okay.

20 CHAIRMAN STETKAR: Thank you.

21 MR. KALLAN: Okay.

22 MEMBER BROWN: For somebody like me who is
23 non-initiated into this nuance, this is an educational
24 question, since we have a few minutes, if you don't
25 mind. If I read your notes on 1.127 -- I'm trying to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 differentiate between cooling ponds and spray ponds.
2 I mean, at 30 days -- if I look at 1.27 it kind of
3 says 36 days -- 30-day supply of water.

4 MR. WHEELER: Right. That's my first --
5 30 days.

6 MEMBER BROWN: But then it says 36 days
7 for spray ponds.

8 MR. WHEELER: That's right.

9 MEMBER BROWN: I know if you're not
10 spraying, I mean, what is -- is meteorological
11 conditions, what --

12 MR. WHEELER: Well, I'll read to you from
13 what the reg guide says. Not that that is going to
14 help.

15 MEMBER BROWN: Probably going to have a
16 brain freeze here.

17 MR. WHEELER: This is an example under the
18 meteorological conditions paragraph. As an example,
19 consider cooling ponds as a heat sink where the pond
20 temperature may reach a maximum of five days following
21 a shutdown. So what they are saying is for a pond,
22 that maximum heat load to the pond is not going to get
23 there for five days. So that is kind of my thought
24 process of where the 36-day came from.

25 MEMBER BROWN: Okay. I remembered you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 talking about that yesterday, this five days. In
2 other words, so initially you start off at some
3 temperature for the pond. And if you -- and then you
4 are using it under some conditions, that it takes five
5 days to reach a maximum temperature that it is allowed
6 to operate. Is that what you mean by "maximum
7 temperature," or is that a stable equilibrium
8 temperature? Or don't know?

9 MR. WHEELER: I can't --

10 MEMBER BROWN: Okay.

11 MR. WHEELER: I can't really comment on
12 what is in the reg guide.

13 MEMBER BROWN: All right. We'll --

14 CHAIRMAN STETKAR: I think, you know --

15 MR. WHEELER: If we were designing spray
16 ponds, I would probably, you know, learn a lot more
17 information before walking in here, but --

18 CHAIRMAN STETKAR: I think the preface is
19 -- the problem is, the discussion in the reg guide, in
20 my interpretation of it -- and this is only my
21 interpretation. I think any number of us in this room
22 might have slightly different interpretations. It
23 cites a couple of examples about how one might assign
24 the most conservative meteorological conditions
25 depending on a specific design of what you call the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 sink.

2 MEMBER BROWN: That's right. And that's
3 the --

4 CHAIRMAN STETKAR: And they call it the --

5 MEMBER BROWN: -- external environment,
6 like humidity, stuff like that?

7 CHAIRMAN STETKAR: That's right.

8 MEMBER BROWN: Okay.

9 CHAIRMAN STETKAR: That's meteorological,
10 and they call it the sink. One example that they use
11 is an actual draft cooling tower where you are
12 obviously evaporating -- you know, you are designed to
13 evaporate a volume. And they give an example about,
14 you know, how one might divine the most limiting dry
15 bulb temperature to use in your calculation to give
16 you assurance that you have a 30-day cooling
17 capability.

18 The other example they use -- and Larry
19 cited it -- is a cooling pond. It doesn't say spray.

20 It doesn't say cement pond. It doesn't say -- you
21 know, it says pond, and it says, you know, in my
22 interpretation you could use a five-day heatup time,
23 plus an additional day for, you know, extreme
24 meteorological conditions, and then 30 days.

25 But ultimately, the bottom line, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 regulatory position consistently cites the fact that
2 you need to demonstrate a 30-day cooling capability --

3 MR. WHEELER: Correct.

4 CHAIRMAN STETKAR: -- under limiting
5 meteorological conditions.

6 MR. WHEELER: That's right.

7 CHAIRMAN STETKAR: And I think how you
8 develop those meteorological conditions for your site-
9 specific configuration of whatever you call the sink,
10 you know, probably a needs a bit better elaboration in
11 an update to the reg guide.

12 MEMBER BROWN: Okay. I quit.

13 CHAIRMAN STETKAR: But I know where the 36
14 came from.

15 MR. WHEELER: I am on the committee to
16 revise that reg guide, so I will take that note back
17 and --

18 CHAIRMAN STETKAR: What is your schedule
19 for it, just out of -- do you have one?

20 MR. WHEELER: It has been ongoing for two
21 years. I don't know when we are supposed to present
22 it.

23 CHAIRMAN STETKAR: Fine. We'll see it,
24 you know, once --

25 MR. HAMZEHEE: John, if you are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 interested, we have a schedule for all the reg guide
2 updates --

3 CHAIRMAN STETKAR: Yes.

4 MR. HAMZEHEE: -- SRPs. We can
5 communicate that to you when you are available.

6 CHAIRMAN STETKAR: They always come to us
7 before they are issued for comments, and then we make
8 a decision whether we want to look at them at that
9 time. They come back after public comments are
10 resolved, and more frequently we look at them, you
11 know, at that time. So we are plugged into that
12 process.

13 MR. WHEELER: If we could move on, we will
14 discuss 9.2.2. What I threw up here is just the
15 Tier 1 figure. This shows the overall configuration
16 of the Alpha and Bravo CCWS loops.

17 If you go to the next slide, I wanted to
18 blow this section up, so we can talk about the cross-
19 ties between in this case Alpha and Bravo.

20 The cross-tie discussion was an RAI 4365,
21 Question 9.2.2-58. And in that response, which was
22 related to the thermal barrier isolating and what to
23 do with that scenario, this was MHI's response to
24 allowing the Alpha/Bravo in this case to essentially
25 not be isolated, to have the MOVs, the 7s, and the 20s

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 open.

2 And in that response, they assumed on an
3 ECCS signal the CCWS pump does not start. Therefore,
4 the 145 valves do not open.

5 Now, by the way, the 145 valves, which you
6 see on the discharge of the Alpha CS RHR heat
7 exchangers, those are normally closed. And those 145s
8 ought to open on an ECCS, plus a CCWS pump start. So
9 an ECCS start by itself are not going to open.

10 CHAIRMAN STETKAR: It doesn't open those.
11 You have to have the interlock with the pump start.

12 MR. WHEELER: You have to have the
13 permissive from the pump being open, and the ECCS, and
14 then that 145 valve goes open.

15 Now, 145 MOV takes about 120 seconds to
16 open.

17 Now, a little bit more details about the
18 flow paths, that if the Alpha train doesn't start, the
19 B pump is now going to pick up the loads going to the
20 opposite train. The flow through this ECW pump for
21 this cooler is about 40 gpm. It's a small line about
22 an inch and a half.

23 For the SI pump, it's 180 gallons per
24 minute. It's about a three-inch diameter. And
25 containment spray pump, that is 80 gpm, and that's a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 two-inch diameter pipe. So we are talking relatively
2 small flows compared to the overall -- I think it's
3 12,000 gpm flow rate.

4 CHAIRMAN STETKAR: As long as the 145
5 valve is closed.

6 MR. WHEELER: That's my next --

7 CHAIRMAN STETKAR: Okay.

8 MR. WHEELER: -- my next point. The RAI
9 response was limited to only looking at that scenario.

10 It didn't really look at other events, and I kind of
11 touched upon that yesterday, that if you actually get
12 the ECCS or the station blackout, both Bravo trains
13 come up, pump starts, the 145 goes open, 120 seconds
14 later that valve is now full open, and 121 seconds
15 into the event you lost your pump, your gas turbine,
16 your electrical bus. Now you are going to get
17 yourself into concern, because now you are picking up
18 4,400 gpm to that 14-inch line.

19 CHAIRMAN STETKAR: And the associated heat
20 load, if we are talking about a LOCA.

21 MR. WHEELER: Exactly. So to back up, the
22 RAI response was limited. The analysis needs to -- we
23 need to look at that a little further to evaluate a
24 maybe more limited scenario that now looks at that 145
25 valve being open. And the 24 hours to close that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 isolation between trains would not be acceptable.

2 CHAIRMAN STETKAR: Thank you. This, by
3 the way, points out, you know, the design basis
4 analysis. You have to assume a single failure.
5 Assuming a single failure at time T-zero --

6 MR. WHEELER: That's right.

7 CHAIRMAN STETKAR: -- in this case is not
8 necessarily the most conservative single failure. And
9 that is -- thank you. This helps a lot.

10 MR. WHEELER: And I did point out
11 yesterday, thinking that that 145 valve didn't open,
12 and that is why it didn't open, because --

13 CHAIRMAN STETKAR: Because it was at T-
14 zero.

15 MR. WHEELER: Right, yeah.

16 CHAIRMAN STETKAR: I mean, it was -- you
17 know, the simultaneous, whatever, loss of offsite
18 power with the limiting single failure presumed to be
19 the GTG would get you that at T-zero.

20 MR. WHEELER: So the staff has an audit
21 coming up with MHI next month, so I am sure we will
22 have a little bit more discussion on this one.

23 CHAIRMAN STETKAR: Thank you.

24 MR. WHEELER: Moving on to the next slide,
25 your references yesterday related to where the 24-hour

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 duration for operator action, and I pulled the insert
2 from the SECY-77-439.

3 CHAIRMAN STETKAR: Okay.

4 MR. WHEELER: And I bolded the section
5 that MHI referenced in their RAI response saying that
6 there is sort of a definition of establishing long-
7 term cooling and that is the 24-hour period of time,
8 and then they use that for kind of a signal for
9 success for the operators to get them -- the valves
10 closed, so that you can get off into long-term
11 cooling.

12 And, once again, we will have to go back
13 and revisit this now that there is kind of a more
14 limited scenario that we need to evaluate.

15 CHAIRMAN STETKAR: But this is at least
16 --and thanks for dredging this up. I didn't have the
17 opportunity last night to find this one.

18 MR. WHEELER: And I have a copy of the
19 SECY I can leave with you if --

20 CHAIRMAN STETKAR: Yes, I'd appreciate
21 that, or, you know, give it to Ilka, so -- make sure
22 that we get it distributed to everybody on the
23 Subcommittee.

24 MR. WHEELER: Any other questions for ESW,
25 component cooling, ultimate heat sink? Those are the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 ones that I --

2 CHAIRMAN STETKAR: Again, if you would
3 bear with me for a couple of minutes, because I am a
4 slow writer. I just want to make sure I make a couple
5 of notes here.

6 (Pause.)

7 Okay. I apologize. I am a slow writer.
8 But as I age, my retention is about 15 minutes. So if
9 I don't make notes, I will forget it by the time I hit
10 the door over there.

11 MR. KALLAN: Okay.

12 CHAIRMAN STETKAR: Thanks, Paul.

13 MR. KALLAN: There was a question on
14 9.1.3.1 with regards to the inconsistency in the
15 temperature with regards to the DCD and the SER, and I
16 wanted to turn it over to Raul Hernandez.

17 MR. HERNANDEZ: Yes. The description in
18 that section of our FSAR is addressing the design
19 criteria for the spent fuel pool cooling system, and
20 it found, yes, there was an inconsistency.

21 The system is designed to maintain less
22 than -- to maintain the water in the spent fuel pool
23 less than 120 with both trains running. So I will
24 need to correct this statement here that with a single
25 active failure the temperature will not reach higher

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 than 140.

2 CHAIRMAN STETKAR: With a half core.

3 MR. HERNANDEZ: Yes.

4 CHAIRMAN STETKAR: I'm sorry. Any single
5 act of failure regardless -- half core, full core.

6 MR. HERNANDEZ: Well, you know, his first
7 thing when he started looking at the half core, yes,
8 the single act of failure applies to either one of
9 them.

10 CHAIRMAN STETKAR: Right, right.

11 MR. HERNANDEZ: And it would be --

12 CHAIRMAN STETKAR: And the operative is
13 140 under that. Okay. Thanks. Thanks.

14 MR. HERNANDEZ: That statement was taken
15 from the DCD.

16 CHAIRMAN STETKAR: I actually had to craft
17 myself -- looking at all of the words in the DCD and
18 the SER, I had to put together a little table with
19 half core, full core, spent fuel, pit cooling trains,
20 RHR, CS trains, and try to divine all of the things.
21 That was the inconsistency, so --

22 MR. HERNANDEZ: Yeah. The inconsistency
23 was the statement of the single act of failure.

24 CHAIRMAN STETKAR: Right.

25 MR. HERNANDEZ: The system is designed for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 120, with both trains on it.

2 CHAIRMAN STETKAR: With both trains, 140
3 with a single act of failure.

4 MR. HERNANDEZ: Yes.

5 CHAIRMAN STETKAR: Yes. As I said, it
6 wasn't -- I just wanted to make sure I understood that
7 the table I put together was right, that I wasn't
8 missing something. It is not a concern about the
9 design of the system or, you know, any safety concern
10 essentially. So thank you.

11 MR. HERNANDEZ: Yes. And in answering one
12 of the other comments from the members about the heat
13 load at that particular scenario, the DCD specifies
14 that that is with a full pool and all of the locations
15 are full. So it is a -- the limiting heat load at
16 that moment.

17 There was also a comment on -- oh, let me
18 wait until you finish.

19 (Pause.)

20 Another comment that you had on
21 Section 9.1.3 was dealing with the particular RAI that
22 I submitted about the shutdown of the spent fuel pool
23 cooling pumps and the restart of the pumps. You were
24 asking if -- why we didn't ask for a COL action for
25 that particular procedure.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 The determination when we need a COL
2 action item basically comes down to staff -- to our
3 consideration. You know, when we look at it, it is --
4 those actions are different from what we normally see,
5 normal operations.

6 In this particular case, the actions
7 required are pretty straightforward -- you know,
8 initiating a pump, checking levels. It is not asking
9 for the operator to go outside of the containment --
10 outside of the control room to physically go to a
11 specific location.

12 It is -- they are monitoring the
13 temperature of the spent fuel pool, and when the
14 temperature goes high they would have to take actions.

15 And the actions are not something that they normally
16 wouldn't do -- you know, check temperature, check
17 level, and restart pumps. That's why I did not
18 require a COL action item for this particular.

19 CHAIRMAN STETKAR: Okay. And that is --
20 looking for the thought process, and you have
21 explained that. I mean, I think it is reasonable to
22 presume that the COL applicant will look at the design
23 of the plant and write, you know, procedural guidance
24 consistent with that design. And you have pretty well
25 explained sort of the thought process that the staff

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 goes through about, you know, any need to specifically
2 highlight things or not. So I think that makes sense.

3 MR. HERNANDEZ: When we talking about, you
4 know, going outside of where the operators are
5 normally located, or having to move to a specific
6 location to take certain actions, that -- it is more
7 demanding, and it's not going to be so
8 straightforward, so simple as just when you are inside
9 a control room and typical monitoring of the
10 situations of the plant conditions.

11 CHAIRMAN STETKAR: All right.

12 MR. HERNANDEZ: Have any other questions
13 on the spent fuel pool, spent fuel pool cooling?

14 CHAIRMAN STETKAR: I don't recall any.
15 But as I said, I think that, yeah, we pulled together
16 everything at the conclusion of the meeting. If there
17 is anything that we missed in today's discussions, we
18 will summarize it and make sure we get it to you.

19 MR. HERNANDEZ: You also had a comment on
20 Section 9.1.4 where we are talking about draindown of
21 the refueling cavity.

22 CHAIRMAN STETKAR: Yes.

23 MR. HERNANDEZ: There was a statement in
24 the staff evaluation that their makeup capability is
25 higher than the draindown. That statement came out of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the responses to the staff's RAI. The staff sent two
2 different RAIs dealing with draindown path from the
3 refueling cavity. We specifically asked them to look
4 into all of the connecting systems and look for
5 possible draindown path.

6 The applicant went through in one of the
7 responses and enumerated all of the different -- well,
8 tabulated -- they put a table together with all of the
9 different possible draindown paths and what would be
10 the worst possible case. It was determined that the
11 worst possible case was the drain for the reactor
12 cavity area. And there makeup capability from the
13 refueling water storage tank was higher than the
14 maximum expected draindown path.

15 So I guess that we could rephrase the
16 statement in the FSAR to point out exactly that we are
17 referencing the expected draindown or the evaluated
18 draindown, not --

19 CHAIRMAN STETKAR: I think that would help
20 a lot, because the connotation of "any" is --

21 MR. HERNANDEZ: It was "any" from the
22 evaluation.

23 CHAIRMAN STETKAR: -- is pretty large. By
24 the way, do you have a reference for that particular
25 RAI response?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. HERNANDEZ: Yes.

2 CHAIRMAN STETKAR: So that we can --

3 MR. HERNANDEZ: I have two RAIs. The
4 original RAI was RAI 507-3393.

5 CHAIRMAN STETKAR: 507-3393.

6 MR. HERNANDEZ: Yes.

7 CHAIRMAN STETKAR: Okay.

8 MR. HERNANDEZ: Question 9.1.4-16.

9 CHAIRMAN STETKAR: 9.1.4-16. Okay.

10 MR. HERNANDEZ: And then subsequent RAI
11 was RAI 633-4857.

12 CHAIRMAN STETKAR: 4857.

13 MR. HERNANDEZ: Question 9.1.4-21.

14 CHAIRMAN STETKAR: 9.1.4-21. Okay.

15 MR. HERNANDEZ: This is the response that
16 has the table.

17 CHAIRMAN STETKAR: And the second one has
18 the table?

19 MR. HERNANDEZ: Yes, the second one.

20 CHAIRMAN STETKAR: Okay. Could you make
21 sure -- just get that to Ilka, so that we can take a
22 look at it.

23 MR. HAMZEHEE: You should have it.

24 CHAIRMAN STETKAR: Okay. Yes, I'm --

25 MR. HERNANDEZ: This is with the RAIs

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 dealing with refueling cavity seal, and we looked more
2 than just the cavity seals and the other seals in that
3 area. We also looked at other draindown paths.

4 The FSAR -- we will revise it to be --
5 specifically highlight that this is not a general
6 statement for any leakages, just the ones that we
7 evaluated.

8 CHAIRMAN STETKAR: That would help to
9 clarify I think. And it's good -- and I think it's
10 really good to have that background document. It
11 essentially does what I was asking. You know, I was
12 challenging this notion of, how can you say "any"?
13 But it does say that, as a response to an RAI, there
14 was a consistent evaluation done, which essentially is
15 what I was driving at, you know, through the
16 questions. So that's good.

17 Ryan?

18 MR. SPRENGEL: This is Ryan Sprengel.
19 Just a clarification. We are talking about the SER.

20 MR. HERNANDEZ: Yes.

21 MR. SPRENGEL: Correct? Not the FSAR.
22 Okay. Okay.

23 MR. HERNANDEZ: Well, yes.

24 MR. SPRENGEL: I just wanted to clarify.

25 CHAIRMAN STETKAR: Thanks for clarifying

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it.

2 MR. SPRENGEL: So the changes to the SER,
3 without open items in the future, and then finally the
4 FSER. That's my understanding.

5 CHAIRMAN STETKAR: Yes, thank you. Thanks
6 for the clarification. That's important for the
7 record.

8 Paul?

9 MR. KALLAN: There was a question on 9.1.5
10 with regards to heavy load crane. And it was Section
11 9.1.5.4 with regards to what are the SSC important to
12 safety, and is it equivalent to safety, important to
13 safety. And I don't think at this point -- I mean,
14 we --

15 MS. McKENNA: This is Eileen McKenna. We
16 are not prepared to respond to that at this time. I
17 do actually have a followup, though, for the question
18 about the chilled water system and why it is not in
19 the tech specs.

20 I think the SER didn't really explain why
21 it was not in the standard tech specs and just said
22 that because it's not in the standard it's not in this
23 application. But the basis is that the essential
24 chilled water system is a support system to the rooms
25 -- to the systems that are in rooms that it services.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 And the way it is handled through the tech specs is
2 through the definition of operability for those
3 systems.

4 In particular, if I may quote from the
5 definition of "operability," a system, subsystem,
6 train, component, or device shall be operable, or have
7 operability, when it is capable of performing its
8 specified safety functions and when all necessary
9 attendant instrumentation controls, normal or
10 emergency electric power, cooling and seal water,
11 lubrication, and other auxiliary equipment that are
12 required for the system, subsystem, train, component,
13 or device to perform its functions are also capable of
14 performing their required support functions.

15 So as a specific example, if the chillers
16 are out of service in the space where, say, the
17 turbine-driven emergency feedwater pump is located, it
18 would be the responsibility of the operators to
19 evaluate whether, given whatever that condition of the
20 cooling for that space, whether that pump remains
21 operable. And if they determine it is not operable,
22 they would follow the limiting condition for operation
23 and the actions associated with the pump.

24 CHAIRMAN STETKAR: Okay. I understand all
25 of that, and I will ask you why, then, do we have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 technical specifications on ac electric power, dc
2 electric power, gas turbine generators, diesel
3 generators, essential service water systems, component
4 cooling water systems? And I probably missed a few,
5 which are all support systems which would in principle
6 be covered under those statements that you just made.

7 Why do we have tech specs that are very explicit on
8 all of those other things?

9 MS. McKENNA: The basis for when we have
10 LCOs or criteria that are written into 50.36, and one
11 of them that probably captures most of the things you
12 are talking about is Criteria 3.

13 CHAIRMAN STETKAR: I mean -- I'm asking,
14 if I go to tech specs today, the standard tech specs,
15 there are LCOs for everything that I mentioned.

16 MS. McKENNA: Yes.

17 CHAIRMAN STETKAR: There is none for ECWS,
18 simply because the people who drafted the generic tech
19 specs thought about currently operating plants that
20 don't have an essential chilled water system.
21 Otherwise, they would have put one in there. That's
22 the fact of the matter.

23 And if you draw the analogy that I don't
24 need one for essential chilled water, then I don't
25 need one for essential service water. I don't need

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 one for component cooling water. I don't need one for
2 ac power. I don't need one for dc power. Because it
3 all relies on the fact that I need support for this
4 pump that pumps water.

5 And the tech specs are not organized that
6 way in the generic tech specs. They do have LCOs that
7 call out surveillance requirements and allowed outage
8 times for all of those other support systems that I
9 listed.

10 The only exception in this particular
11 design is essential chilled water, because I believe
12 that the people who crafted the tech specs weren't
13 familiar with designs that happened to have essential
14 chilled water systems, which is not a traditional U.S.
15 plant design feature. It is more traditional for
16 other plants.

17 MS. McKENNA: True. But I think the point
18 to be made is that something like a room ventilation,
19 you may or may not need it for the equipment to be
20 operable, whereas you clearly have to have electric
21 power, and you clearly -- you know, so that there are
22 situations where you could have the essential chilled
23 water system degraded, you know, less than full
24 complement, and the equipment that it services is
25 still operable.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIRMAN STETKAR: You know, I think it's
2 a stretch because in specific -- in the US-APWR
3 technical specifications, the bases for the ultimate
4 heat sink and the essential service water system
5 specifically referenced the fact that those are
6 cooling supplies for the chillers. You know, I just
7 don't --

8 MEMBER SHACK: Without offending your
9 consistency and logic, is there a safety problem
10 associated with this?

11 CHAIRMAN STETKAR: I think there might be.
12 I think there might be in an operational sense,
13 because the technical specifications are what the
14 operators use day to day to give themselves assurance
15 that they understand the plant configuration and any
16 decreased margins.

17 And although it is nice to say that they
18 should look at this pump and fully understand all of
19 the subtleties of all of the support systems for this
20 pump that might affect its operability, they have to
21 do that.

22 But without the reminder in the technical
23 specifications that, for example, train A of essential
24 chilled water goes out and affects this pump and many
25 other pumps, and room ventilation for electrical

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 things, it is really, really difficult for operators
2 to make those connections. Or it can be.

3 Having been in a plant trying to make
4 several of those subtle connections where the tech
5 specs weren't all that clear, it is not very easy to
6 do. And I think without it having, you know, its
7 specific identification in the tech specs, you are
8 asking for people to perhaps, you know, overlook
9 something.

10 So it's not just a consistency issue,
11 because, I grant you, ultimately I need to understand
12 that every support system for this particular pump is
13 available. And indeed, in principle, I should look at
14 essential chilled water as part of that support.

15 But it just -- I just don't understand
16 that inconsistency, given the fact that every other
17 support system -- I could make the same argument if
18 they didn't put the dc power system in there. Right?

19 Philosophical argument.

20 MEMBER SHACK: Well, except that Eileen
21 sort of has an exception that, you know, might -- you
22 know, really, we go through every system and find out
23 whether it does it. But I think I would agree with
24 her that it seems to cover a lot of them.

25 CHAIRMAN STETKAR: It covers

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 philosophically.

2 MEMBER SHACK: Yes.

3 CHAIRMAN STETKAR: Philosophically, it
4 covers everything.

5 MEMBER SHACK: No. The distinction
6 between support systems that are in and support
7 systems that are out.

8 CHAIRMAN STETKAR: We can talk about this
9 later. I personally feel that -- again, this is a
10 Subcommittee meeting. I don't speak for the
11 Committee. I feel pretty strongly about this one,
12 especially having been an operator. And I -- anyway,
13 we will just leave it that way. And thanks for your
14 clarification.

15 MS. McKENNA: We understand your concern.

16 CHAIRMAN STETKAR: I appreciate that.

17 MS. McKENNA: Consistent with our current
18 guidance and interpretation of 50.36, they would not
19 be required to be in the specs.

20 MR. HAMZEHEE: Directly.

21 MS. McKENNA: Directly. Correct, yes.
22 Indirectly, the LCOs.

23 MR. HAMZEHEE: I think, John, there are
24 some operating plants that do have safety chilled
25 water, but not many. So --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: Yeah. I don't actually
2 know that --

3 MR. HAMZEHEE: There are a few.

4 CHAIRMAN STETKAR: Okay. I didn't know
5 all of -- I know most of them don't. I'm much more
6 familiar with newer plant designs that tend to have it
7 because they need extra cooling.

8 Do you happen -- no, that's okay. It's
9 not relevant to the -- I wasn't going to ask you for
10 the plants. I was going to ask you whether you happen
11 to know whether their tech specs include the chilled
12 water systems.

13 MR. HAMZEHEE: That I can't recall.

14 CHAIRMAN STETKAR: And it's actually not
15 germane necessarily to the current -- you know, the
16 current issue. So it would be interesting, but not
17 directly relevant.

18 MR. WHEELER: Excuse me, John. I was an STA
19 at Perry and they had safety-related chillers. I'll
20 go back and look at their FSAR and tech specs and see
21 --

22 CHAIRMAN STETKAR: Did you have a safety-
23 related chilled -- you had a safety-related chilled
24 water system with chillers.

25 MR. WHEELER: Correct.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN STETKAR: Okay, good. Good.

2 MR. WHEELER: I will take a look at
3 Perry's tech specs.

4 CHAIRMAN STETKAR: Because I'm familiar
5 with overseas plants that I have worked on, and they
6 are -- that had chilled water systems, and there are
7 -- but they're foreign countries, so they're not
8 relevant to this discussion.

9 But I understand -- you know, I understand
10 the philosophy. I understand the rationale. And,
11 thanks, that helped clarify that issue. I didn't say
12 I agreed with it; I just understand it now.

13 (Laughter.)

14 Okay. Any other things, Paul?

15 MR. KALLAN: No. I think staff has
16 answered all of your questions. And we have one
17 takeaway -- the SSC important to safety.

18 CHAIRMAN STETKAR: Yes.

19 MR. KALLAN: That's it.

20 CHAIRMAN STETKAR: And that's something
21 that I -- just to put that in perspective kind, I
22 raised it yesterday for two reasons. One reason is
23 that just recently -- and I can't recall the context,
24 because we see so many things, but -- and when I say
25 "recently" I mean in the last two or three months or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 so, because that is about all the memory that I have.

2 There was a discussion in some interaction
3 that we had --

4 MEMBER SHACK: It was in the risk metric
5 stuff.

6 CHAIRMAN STETKAR: Was it the risk metric
7 stuff?

8 MEMBER SHACK: It was the risk metric stuff.

9 CHAIRMAN STETKAR: Well, was it? I don't
10 think it was in that. There was a discussion about
11 the sense that there is a set -- and this was raised
12 by the staff, that there is a set of equipment,
13 structures that are important to safety, and that
14 safety-related is a subset of that larger set. I
15 think it -- it fits into the 50.69, but I don't know
16 whether it came up under the 50.69. But it --

17 MEMBER SHACK: It came up because there is
18 a number of those risk-informed things that --

19 CHAIRMAN STETKAR: But, I mean, that is
20 more clear. This was in a different context.

21 MR. HAMZEHEE: John, yesterday you were
22 correct. I am almost positive the important to safety
23 is part of the reliability assurance program. And
24 they have to define all of the -- either the safety-
25 related, non-safety-related.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER SHACK: If you look in the GDCs,
2 which pre-date the reliability assurance program by
3 decades, important to safety is there. Now, what did
4 it mean -- you know, what did they have in mind at
5 that time?

6 MR. HAMZEHEE: Right.

7 MEMBER SHACK: It is certainly different
8 than the D-RAP.

9 MR. HAMZEHEE: Right, correct. And there
10 was some loose definition and very -- not very well
11 disciplined use of the terminology, because you have
12 risk significant, safety significant, important to
13 safety, has nothing to do with safety-related.
14 Safety-related is --

15 MEMBER SHACK: That's true. That's well
16 defined.

17 MR. HAMZEHEE: Yes. And I think John --
18 that's why he was trying to figure out --

19 CHAIRMAN STETKAR: A couple of things, and
20 finish the -- one reason I raised it is that I was
21 recalling -- and I don't remember the context -- an
22 issue raised by the staff about the fact that there is
23 important to safety, and that safety-related is a
24 subset of that. So understanding what important to
25 safety is has some relevance to issues raised by the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 staff.

2 Furthermore, in this particular -- the
3 quote that I cited, there was an even further
4 distinction because there was important to safety
5 versus safe shutdown, which is even a further
6 refinement of the notion of safety-related, because
7 traditionally safe shutdown, for example, in fire
8 analysis or flooding or those types of things is a --
9 or seismic is a specifically defined set of equipment
10 that you rely on to achieve and maintain safe
11 shutdown. So it is even more finely defined than even
12 safety-related.

13 So you are now comparing some definition
14 of important to safety versus protection of safe
15 shutdown. And this was in the context of the heavy
16 load drops.

17 And I agree, I think that -- I think at
18 least for the new plants, in my mind, the better
19 guidance for determining, in an active plant design --
20 if you want to call it that -- like US-APWR, the
21 complement of equipment that is in the design
22 reliability assurance program, there is at least
23 guidance and some measure of consistency about
24 determining what is in that set of equipment.

25 And I think it is reasonable to say that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 those determinations are consistent with the notion of
2 important to safety, and that for the passive plants
3 the analogy would be the RTNSS list.

4 So I think that in the new plant design we
5 are at least getting a bit of definition included, you
6 know, around that box of what is important to safety.

7 And that's good. The bad thing is that if, indeed,
8 there are -- in this -- the genesis of this question,
9 if there are indeed SSCs out in the turbine building
10 that are -- that fit within that box, should they then
11 be protected against heavy load drops? Which brings
12 into question, you know, the turbine building crane
13 and all that kind of thing.

14 MR. HAMZEHEE: I think we need to go back
15 and make sure what we meant by important to safety.
16 Are we talking about safety-related equipment or --

17 CHAIRMAN STETKAR: In the context of your
18 SER.

19 MR. HAMZEHEE: Exactly.

20 CHAIRMAN STETKAR: Right, right.

21 MR. HAMZEHEE: So that is really the
22 clarification the staff needs to do.

23 CHAIRMAN STETKAR: Right, right. Because
24 I excerpted the words from your SER, because you were
25 comparing important to safety versus safe shutdown.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Okay. So that's what we will -- to be
2 discussed.

3 Do any of the members have any more
4 questions? We usually go around the table.

5 MEMBER SHACK: It's a little short today.

6 CHAIRMAN STETKAR: It's a short table, but
7 I'll do that. Charlie?

8 MEMBER BROWN: No, I'm done.

9 CHAIRMAN STETKAR: Bill?

10 MEMBER SHACK: No.

11 CHAIRMAN STETKAR: Okay. Are there any
12 members of the public here who have any comments?

13 (No response.)

14 Didn't expect any. I don't think we have
15 a bridge line, so I don't need to ask for that.

16 Again, I appreciate everybody's
17 participation. Thank the staff for coming up with
18 answers. And I appreciate everybody coming back
19 today. I know it is a burden on some, but I think
20 that it was useful to get resolution on a large number
21 of these items.

22 Thank you, all, and with that we are
23 adjourned.

24 (Whereupon, at 10:31 a.m., the proceedings in the
25 foregoing matter were adjourned.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1

2

3

4

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com



Presentation to ACRS Subcommittee
Chapter 9: Auxiliary Systems
Section 9.1 Fuel Storage and Handling

March 22-23, 2012
Mitsubishi Heavy Industries, Ltd.

MHI Presenters



James Curry, Ph.D., P.E., – Lead Presenter
Mitsubishi Nuclear Energy Systems, Inc.

Naoki Kawata – Technical Expert
Mitsubishi Heavy Industries, Ltd.
Chapter 9 Engineer

Yoshiyuki Tanigawa – Technical Expert
Mitsubishi Heavy Industries, Ltd.
Chapter 9 Engineer

Thomas Fitzpatrick – Project Manager
Holtec International

Charles Bullard II – Principal Engineer
Holtec International

Bret Brickner – Senior Engineer
Holtec International

Acronyms



ASME	:American Society of Mechanical Engineers
CMAA	:Crane Manufacturers Association of America
CVCS	:Chemical and Volume Control System
C/V	:Containment Vessel
EFWP	:Emergency Feedwater Pit
EPS	:Emergency Power Source
ESF	:Engineered Safety Feature
Hx	:Heat Exchanger
LLHS	:Light Load Handling System
MOV	:Motor-Operated Valve
OHLHS	: Overhead Heavy Load Handling System
PCS	:Permanent Cavity Seal
RAI	:Request for Additional Information
RHRS	:Residual Heat Removal System
RV	:Reactor Vessel
RWSAT	:Refueling Water Storage Auxiliary Tank
RWSP	:Refueling Water Storage Pit
R/B	:Reactor Building
SFP	:Spent Fuel Pit
SFPCS	:Spent Fuel Pit Cooling and Purification System
SSE	:Safe-Shutdown Earthquake

DCD Section 9.1 Fuel Storage and Handling




Section		Major Contents
9.1	Fuel Storage and Handling	9.1.1 Criticality Safety of New and Spent Fuel Storage
		9.1.2 New and Spent Fuel Storage
		9.1.3 Spent Fuel Pit Cooling and Purification System
		9.1.4 Light Load Handling System (Related to Refueling)
		9.1.5 Overhead Heavy Load Handling System

9.1.1 Criticality Safety of New and Spent Fuel Storage



- New and spent fuel storage facilities are located in the fuel handling area of the reactor building (R/B) which is designed to meet the seismic category I requirements of Regulatory Guide (RG) 1.29.
- New fuel is stored in low density racks installed in a dry new fuel storage pit.
- Spent fuel is stored in moderate density racks installed in a spent fuel pit (SFP) filled with borated water.

9.1.1 Criticality Safety of New and Spent Fuel Storage



Plan View of Light Load Handling System

9.1.1 Criticality Safety of New and Spent Fuel Storage



- The robust concrete walls and ceiling surrounding the fuel storage and handling area is designed to withstand the loads and forces caused by earthquake, wind, tornadoes, floods, and internal and external missiles.
- New and spent fuel storage racks are designed to maintain the required degree of subcriticality, and are evaluated as seismic category I structures.
- Equipment potentially damaging the stored fuel is designed to be prevented from collapsing and falling down on the structures in the event of a safe-shutdown earthquake (SSE).

9.1.1 Criticality Safety of New and Spent Fuel Storage



- **Criticality is precluded by adequate design of fuel handling and storage facilities and by administrative control procedures. Criticality analyses are performed in accordance with the following acceptance criteria and relevant requirements.**
- **New Fuel Storage Rack**
 - ✓ 10 CFR 50.68 (b) item (2) and (3)
 - $K_{\text{eff}}^* \leq 0.95$ for the flooded condition with unborated water
 - $K_{\text{eff}}^* \leq 0.98$ for optimum moderation
- **Spent Fuel Storage Rack**
 - ✓ 10 CFR 50.68 (b) item (4)
 - $K_{\text{eff}}^* \leq 0.95$ for the flooded condition with partial credit for soluble boron
 - $K_{\text{eff}}^* < 1.0$ with full density unborated water

* Maximum K_{eff} value including all biases and uncertainties at a 95% probability and 95% confidence

➤ Analysis Conditions (1/2)

- ✓ Under the new fuel assumption, the fuel assembly is assumed to have a maximum enrichment of 5 wt% pursuant to 10 CFR 50.68 (b) item (7).
- ✓ Fuel assembly fabrication tolerances are considered.
- ✓ Credit is taken for the neutron absorption in the rack structural material and neutron poison, such as boron.
- ✓ The steel plate thickness and boron content are conservatively assumed to be minimum specification values.

➤ Analysis Conditions (2/2)

✓ New fuel storage rack

- The new fuel storage rack cell is constructed of stainless steel.
- A finite rack cell array and the surrounding concrete reflectors are used in the calculations.

✓ Spent fuel storage rack

- The spent fuel storage rack cell is constructed of stainless steel with boron.
- Metamic is selected as neutron absorber material.
- An infinite rack array in the lateral direction is assumed.

✓ Material composition, fabrication tolerances of the fuel and rack, and the fuel location within the rack cell uncertainties are considered.

➤ No open or confirmatory items remain on this subsection.

9.1.2 New and Spent Fuel Storage



- Structural Requirement -

- **Structural design and stress analysis of the new and spent fuel storage racks are evaluated in accordance with the seismic category I requirements of Regulatory Guide 1.29.**
- **Loads and load combinations considered in the structural design and stress analysis are based on SRP Section 3.8.4, Appendix D.**
- **Racks can withstand a maximum uplift force based on the lifting capacity of the suspension hoist and the fuel handling machine.**
- **A subcritical array can be maintained in the event of a postulated drop of a fuel assembly and associated handling tool on a rack.**

9.1.2 New and Spent Fuel Storage



➤ Major RAIs (Confirmatory Items)

RAI No.	Question 09.01.02-X	RAI Topic / NRC Concern	RAI Response / DCD Impact
387-2931	22	<p><u>Preoperational test of the SFP:</u></p> <p>Include in the DCD evaluation of the leak-tightness of the spent fuel pool liner as one of the objectives of preoperational test.</p>	<p>➤ MHI revised the DCD Chapter 14, Subsection 14.2.12.1.85 to add the test for leak-tightness of the SFP in objective, test method, and acceptance criteria of the preoperational test for the spent fuel pit cooling and purification system.</p>

9.1.2 New and Spent Fuel Storage



➤ Major RAIs (Confirmatory Items)

RAI No.	Question 09.01.02-X	RAI Topic / NRC Concern	RAI Response / DCD Impact
387-2931	23	<p><u>Blockage of the SFP leakage collection system:</u></p> <p>Justify how the SFP leakage collection system meets the requirements of 10 CFR 20.1406 if the system is not periodically inspected to identify blockages.</p> <p>Clarify in the DCD that the SFP leakage collection system is sized to allow cleaning of blockages.</p>	<p>➤ MHI revised the DCD to clearly state that:</p> <ul style="list-style-type: none"> • The inside of the SFP leakage collection pipes are inspected using a device such as fiberscope, and cleaned if necessary, approximately every refueling outage. • The SFP leakage collection pipes are sized to allow cleaning of blockages as specified in Regulatory Guide 4.21.

9.1.2 New and Spent Fuel Storage



➤ Major RAIs (Issued/Open Action Applicant)


RAI No.	Question 09.01.02-X	RAI Topic / NRC Concern	RAI Response / DCD Impact
906-6332	26	<p><u>Containment Racks:</u></p> <p>Description and evaluation of fuel racks in the refueling cavity are missing throughout the DCD.</p> <p>Applicant should address SRP 9.1.2 and interfacing SRP sections. For example;</p> <ul style="list-style-type: none">•Structural design of the racks•Compatibility and chemical stability of the materials of the racks	[Preparation under way]

9.1.3 Spent Fuel Pit Cooling and Purification System (SFPCS)



- **The SFPCS is comprised of:**
 - ✓ **Two redundant cooling and purification trains.**
 - ✓ **Each train includes one pump, one heat exchanger (plate-type), one filter, and one demineralizer.**
 - ✓ **EPS can be aligned with SFP pumps as necessary.**
- **The SFPCS cools the SFP water by removing the decay heat generated by spent fuel assemblies in the SFP.**
- **The SFPCS purifies the borated water in SFP, RWSP, and RWSAT.**
- **The system piping is arranged such that the failure of any line cannot drain the SFP to a level less than 11.1 ft above the top of a stored assembly.**
- **The SFPCS is provided with Seismic Category I makeup water from the RWSP and the EFWP.**
- **The SFPCS trains, in conjunction with two trains of RHRS, maintain SFP temperature below 120°F during full core offload.**

9.1.3 Spent Fuel Pit Cooling and Purification System (SFPCS)



9.1.3 Spent Fuel Pit Cooling and Purification System (SFPCS)



➤ Major RAI (Open Items)

RAI No.	Question 09.01.03-X	RAI Topic / NRC Concern	RAI Response / DCD Impact
735-5723	7	How presumed failures of non-safety-related portions of the SFPCS due to a seismic event or an internally generated missile event do not adversely affect the safety-related portion of the SFPCS.	<ul style="list-style-type: none">➤ The local manual isolation valve between the safety and non-safety portion (VLV-101A/B) of each train will be changed to double, automatic isolation MOVs which close on a low-low SFP water level signal.➤ Each SFP pump also will be tripped on the low-low SFP water level signal.


9.1.4 Light Load Handling System

(Related to Refueling)



- The Light Load Handling System (LLHS) consists of the equipment and structures involved in the handling of new, irradiated, and spent fuel.
- All of the LLHS is non-safety related, except
 - Fuel transfer tube and blind flange
 - ➔ serves as part of the containment
 - Permanent cavity seal
 - ➔ retains water of refueling cavity during refueling to keep fuels in transit submerged
- The LLHS is designed to meet the criteria specified in
 - ✓ ANSI/ANS57.1-1992, “Design Requirements For Light Water Reactor Fuel Handling Systems”
- Subcriticality is maintained by design with the equipment fully loaded with fuel and the pool flooded with unborated water.

9.1.4 Light Load Handling System (Related to Refueling)



Plan View of Light Load Handling System

9.1.4 Light Load Handling System (Related to Refueling)



➤ Major RAIs (Confirmatory Items)


RAI No.	Question 09.01.04-X	RAI Topic / NRC Concern	RAI Response / DCD Impact
555-4385	19	<u>Correction of wording:</u> Replace the word, "Decontamination pit", with "Cask washdown pit" in accordance with the name change stated in the Question 09.01.04-11.	➤ MHI will modify the inconsistent wordings used to stand for the cask washdown pit. (This is not technical issue.)

9.1.4 Light Load Handling System (Related to Refueling)



➤ Major RAIs (Open Items)

RAI No.	Question 09.01.04-X	RAI Topic / NRC Concern	RAI Response / DCD Impact
887-6261	23	<p><u>Permanent Cavity Seal (PCS):</u> Will fabrication and installation of the PCS adversely affect the reactor vessel (RV)?</p> <ul style="list-style-type: none"> - Provide details about; <ul style="list-style-type: none"> · Material · Connection between the PCS and the RV - Why ASME Section III, Class 3 will not be applied. 	<ul style="list-style-type: none"> ➤ The PCS is <ul style="list-style-type: none"> • made out of stainless steel (specific types of steel are provided in the response) • indirectly attached to the RV through the seal ledge with bolts and welds ➤ ASME Section III is not applicable, because the PCS is: <ul style="list-style-type: none"> • not a pressure-retaining component • outside jurisdictional boundary of the RV



9.1.5 Overhead Heavy Load Handling System



- **The Overhead Heavy Load Handling System (OHLHS) consists of devices used for critical load handling evolutions.**
- **The OHLHS cranes are designed to meet the criteria specified in**
 - ✓ **CMAA-70, 2000, “Specifications for Top Running Bridge and Gantry Type Multiple Girder Electric Overhead Traveling Cranes”**
 - ✓ **ASME B30.2, 2005, “Overhead and Gantry Cranes”**
- **The Polar Crane and the Main Hoist on the Spent Fuel Cask Handling Crane are designed as non-safety related, seismic category II, single-failure-proof cranes, in accordance with NUREG-0554.**
- **Travel range of the spent fuel cask handling machine is limited to prevent load drop on the new and spent fuel storage pit by physical stops on the travel rails of the machine and the hoist carriage. (See Figure 9.1.5-1 in DCD)**

9.1.5 Overhead Heavy Load Handling System



➤ Major RAIs (Confirmatory Items)

RAI No.	Question 09.01.05-X	RAI Topic / NRC Concern	RAI Response / DCD Impact
616-4865	19	<p><u>Auxiliary Hoist on the Polar Crane:</u></p> <p>Administrative procedure to disallow carrying critical loads is the only measure credited to prevent unacceptable load drop accident, which does not conform to SRP 9.1.5.</p>	<p>➤ MHI revised the DCD to upgrade the Auxiliary Hoist on the Polar Crane to single failure-proof and committed to design the hoist in accordance with the requirement of ASME NOG-1 and NUREG-0554.</p>

9.1.5 Overhead Heavy Load Handling System



➤ Major RAIs (Open Items)

RAI No.	Question 09.01.05-X	RAI Topic / NRC Concern	RAI Response / DCD Impact
616-4865	18	<u>Equipment Hatch Hoist:</u> Justify how the SRP 9.1.5.III.4 guidance would be met for the Equipment Hatch Hoist, which is not single failure proof crane located over safe shut down equipment (SSE).	➤ MHI will delete the description about the Equipment Hatch Hoist from Subsection 9.1.5, because the hoist is dedicated to raising and lowering the equipment hatch, and therefore does not fit into the category of OHLHS, which is used for critical load handling evolutions.



Presentation to ACRS Subcommittee
Chapter 9: Auxiliary Systems
Section 9.2 Water Systems

March 22-23, 2012

Mitsubishi Heavy Industries, Ltd.

MHI Presenters



James Curry, Ph.D., P.E. – Lead Presenter
Mitsubishi Nuclear Energy Systems, Inc.

Marc Hotchkiss, P.E. – Lead Presenter
Mitsubishi Nuclear Energy Systems, Inc.

Junya Hattori – Technical Expert
Mitsubishi Heavy Industries, Ltd.
Chapter 9 Engineer

Naoki Kawata – Technical Expert
Mitsubishi Heavy Industries, Ltd.
Chapter 9 Engineer

Motohisa Kitamori – Technical Expert
Mitsubishi Heavy Industries, Ltd.
Chapter 9 Engineer

Keita Otani – Technical Expert
Mitsubishi Heavy Industries, Ltd.
Chapter 9 Engineer

Acronyms (1/2)



A/B	:Auxiliary Building
CDI	:Conceptual Design Information
CHP	:Charging Pump
CSF	:Condensate Storage Facilities
CCWS	:Component Cooling Water System
C/V	:Containment Vessel
CWS	:Circulating Water System
ECWS	:Essential Chilled Water System
ESW	:Essential Service Water
ESWS	:Essential Service Water System
Hx	:Heat Exchanger
HVAC	:Heating, Ventilation, and Air Conditioning
ITAAC	:Inspection, Test, Analysis, and Acceptance Criteria
LOCA	:Loss of Coolant Accident
LOOP	:Loss of Offsite Power
MCR	:Main Control Room
non-ECWS	:Non-Essential Chilled Water System
non-ESW	:Non-Essential Service Water
PSWS	:Potable and Sanitary Water System
R/B	:Reactor Building
RAI	:Request for Additional Information

Acronyms (2/2)



RWSP	:Refueling Water Storage Pit
SSCs	:Structures, Systems and Components
SSE	:Safe-Shutdown Earthquake
T/B	:Turbine Building
TCS	:Turbine Component Cooling Water System
UHS	:Ultimate Heat Sink

DCD Section 9.2 Water Systems




Section	Major Contents	Safety-Related Function	
9.2	Water Systems	9.2.1 Essential Service Water System	Yes
		9.2.2 Component Cooling Water System	Yes
		9.2.4 Potable and Sanitary Water Systems	No
		9.2.5 Ultimate Heat Sink	Yes
		9.2.6 Condensate Storage Facilities (Demineralized Water, Condensate Storage, and Primary Makeup Water)	No
		9.2.7 Chilled Water System	Yes
		9.2.8 Turbine Component Cooling Water System	No
		9.2.9 Non-Essential Service Water System	No

9.2.1 Essential Service Water System (ESWS)



- The ESWS is a safety-related system, capable of transferring heat loads from safety-related SSCs to the UHS during normal operating and accident conditions.
- The ESWS, in conjunction with the plant UHS, is designed to remove heat from the plant auxiliaries required to mitigate the consequences of a design basis event and for safe shutdown, assuming a single failure and one train unavailable due to maintenance coincident with a LOOP.
- The ESWP is interlocked with CCW pump operation to support uninterrupted heat removal.
- The ESWS is consists of:
 - ✓ Four 50%-capacity ESW pumps into four independent trains.
 - ✓ Two 100%-capacity parallel strainers in each ESW pump discharge line.
 - ✓ Backup to FSS (CDI item)

9.2.1 Essential Service Water System (ESWS)



9.2.1 Essential Service Water System (ESWS)



➤ SER Open and Confirmatory Items


RAI No.	Question 09.02.01-X	RAI Topic / NRC Concern	RAI Response / DCD Impact
xxx-6344	-	Power supply to the boundary valve AOV-577 ➤ FMEA maybe needed for AOV-577 and VLV-544A/B/C/D ➤ All boundary valves should be listed in FMEA	➤ Draft RAI is currently under discussion.
-	-	Markup information in the Oct.14, 2011 letter	➤ All of the relevant RAI responses

9.2.2 Component Cooling Water System (CCWS)



- The CCWS is the closed, intermediate system between components cooled by CCW HX cooled by ESWS.
- The CCWS performs safety function of providing cooling water to components required for accident mitigation.
- Non-essential loads (non seismic/non safety) are isolated by automatic AOVs.
- The CCWS uses either offsite power supply or onsite Class 1E power supply.
- The CCWS has RCP cross-connect tie line between subsystems.
- Non-essential chilled water of fire protection water supply to CHP is available.
- The essential portion of CCWS is designed to Seismic Category I requirements to remain functional during and following an SSE.
- The CCWS is designed to withstand leakage in one train without loss of the system's safety function.
- The ESWP is interlocked with CCW pump operation to support uninterrupted heat removal.
- The CCWS is consists of:
 - ✓ Two independent 100% cooling capacity subsystems.
 - ✓ Each subsystem is served by one CCW surge tank.
 - ✓ Each subsystem consists of two 50% capacity trains.
 - ✓ Each train contains one CCW pump and one CCW HX.

9.2.2 Component Cooling Water System (CCWS)



9.2.2 Component Cooling Water System (CCWS)



➤ SER Open and Confirmatory items

RAI No.	Question 09.02.02-X	RAI Topic / NRC Concern	RAI Response / DCD Impact
878-6200	85	Design against postulated piping leakage in safety-related portion of CCWS	The safety-related portions of the CCWS meet the requirements of the BTP 3-4 B(iii)(1)(c) and therefore are exempted from postulating leakage cracks.
-	-	Markup information in the Oct.14, 2011 letter	All of the relevant RAI responses

9.2.4 Potable and Sanitary Water Systems (PSWS)



Potable and Sanitary Water Systems is designed as CDI with the following requirements

- **PSWS is Non-Safety Related**
- **PSWS is protected against radioactive contamination through distribution piping by installing a backflow prevention device**
- **PSWS has no interconnection to any systems having the potential for contaminating radioactive material**

9.2.4 Potable and Sanitary Water Systems (PSWS)



➤ SER Open and Confirmatory items

RAI No.	Question 09.02.04-X	RAI Topic / NRC Concern	RAI Response / DCD Impact
		None	


9.2.5 Ultimate Heat Sink (UHS)



Ultimate Heat Sink is designed as CDI with the following requirement

- **The UHS dissipates the maximum heat loads from the ESWS under normal and accident conditions, including that of the LOCA or safe shutdown scenario with LOOP under the worst combination of adverse environmental conditions, including freezing.**
- **The UHS cools the unit for a minimum of 30 days (or minimum of 36 days for cooling pond) without makeup water regarding RG 1.27.**
- **The UHS Related Structures are Seismic Category I structures.**
- **The UHS withstands the effect of natural phenomena such as earthquakes, tornadoes, hurricanes, floods, tsunami and seiches without loss of capability to perform its safety functions.**

9.2.5 Ultimate Heat Sink (UHS)



9.2.5 Ultimate Heat Sink (UHS)




➤ SER Open and Confirmatory items

RAI No.	Question 09.02.05-X	RAI Topic / NRC Concern	RAI Response / DCD Impact
		None	

9.2.6 Condensate Storage Facilities (CSF)



- The CSF is a non safety-related system.
- The CSF provides treated water to primary and secondary systems.
- The CSF consists primarily of three systems:
 - Demineralized water system
 - Condensate storage and transfer system
 - Primary makeup water system



9.2.6 Condensate Storage Facilities (CSF)



➤ SER Open and Confirmatory Items

RAI No.	Question 09.02.06-X	RAI Topic / NRC Concern	RAI Response / DCD Impact
863-6148	3	To explain the mitigation of the environmental effects that do not have impact on safety-related SSCs, even when CST and its dike fail.	<ul style="list-style-type: none">➤ Entrance of the buildings are located 1 foot above ground level.➤ CST, its dike and pumps are located away from the safety-related SSCs.➤ Graded slope and drainage system should be provided as site-specific plant design.➤ Therefore, failure of the tank and dike does not impact safety-related SSCs.➤ DCD will be revised accordingly.

9.2.7 Chilled Water System




- The chilled water system includes the Essential Chilled Water System (ECWS) and Non-Essential Chilled Water System (Non-ECWS).
- The ECWS is safety-related system and performs the following functions:
 - ✓ Provides, during normal and emergency operation, chilled water for the plant safety related air-cooling and ventilation systems.
 - MCR HVAC System
 - Class 1E electrical room HVAC system
 - Safeguard component area HVAC system
 - Emergency feedwater pump area HVAC system
 - Safety related component area HVAC system
- The ECWS is consists of:
 - ✓ Four independent 50%-capacity chiller units into four independent trains.
 - ✓ Four independent 50%-capacity chilled water pumps into four independent trains.
 - ✓ Four independent 50%-capacity compression tanks into four independent trains.

9.2.7 Chilled Water System



Essential Chilled Water System



9.2.7 Chilled Water System




- **The Non-ECWS is non-safety related system with the exception of piping and valves between and including containment isolation valves.**
- **The Non-ECWS performs the following function:**
 - ✓ **Provide chilled water for the HVAC systems serving the non-safety related areas during plant normal operation and LOOP.**
 - ✓ **Connect to the CCWS to provide alternate component cooling water to the charging pumps and to provide alternate cooling water to the containment fan cooler units from CCWS.**

9.2.7 Chilled Water System



Non-Essential Chilled Water System



9.2.7 Chilled Water System




➤ SER Open and Confirmatory Items

RAI No.	Question 09.02.XX-X	RAI Topic / NRC Concern	RAI Response / DCD Impact
		There are no open and confirmatory items for 9.2.7.	

9.2.8 Turbine Component Cooling Water Systems (TCS)



- The TCS is a non safety-related system.
- The TCS provides demineralized cooling water for removal of heat from various T/B heat loads and rejection of heat to the non-essential service water system.



9.2.8 Turbine Component Cooling Water Systems (TCS)




➤ SER Open and Confirmatory items

RAI No.	Question 09.02.XX-X	RAI Topic / NRC Concern	RAI Response / DCD Impact
		None	

9.2.9 Non-Essential Service Water System (non-ESW)



- The non-ESW is a non safety-related system.
- The non-ESW provides cooling water to remove heat from the TCS via the TCS heat exchanger and discharged to the heat sink via circulating water system (CWS).



9.2.9 Non-Essential Service Water System (non-ESW)



➤ SER Open and Confirmatory items

RAI No.	Question 09.02.XX-X	RAI Topic / NRC Concern	RAI Response / DCD Impact
		None	



Presentation to ACRS Subcommittee
Chapter 9: Auxiliary Systems
Section 9.3 Process Auxiliaries

March 22-23, 2012

Mitsubishi Heavy Industries, Ltd.

James Curry, Ph.D., P.E., – Lead Presenter
Mitsubishi Nuclear Energy Systems, Inc

Naoki Kawata – Technical Expert
Mitsubishi Heavy Industries, Ltd.
Chapter 9 Engineer

Motohisa Kitamori – Technical Expert
Mitsubishi Heavy Industries, Ltd.
Chapter 9 Engineer

Acronyms (1/2)



AOV	: Air Operated Valve
A/B	: Auxiliary Building
BA	: Boric Acid
CAS	: Compressed Air System
CAGS	: Compressed Air and Gas Systems
CGS	: Compressed Gas System
CVCS	: Chemical and Volume Control System
C/V	: Containment Vessel
ECCS	: Emergency Core Cooling System
EFDS	: Equipment and Floor Drain Systems
ESF	: Engineered Safety Features
GWMS	: Gaseous Waste Management System
HUT	: Holdup Tank
HVAC	: Heating, Ventilation, and Air Conditioning
HEPA	: High-Efficiency Particulate Air
IAS	: Instrument Air System

Acronyms (2/2)



LWMS	: Liquid Waste Management System
PASS	: Post-Accident Sampling System
PGSS	: Primary Gaseous Sampling System
PLSS	: Primary Liquid Sampling System
PSS	: Process and Post-Accident Sampling Systems
PS/B	: Power Source Building
RAI	: Request for Additional Information
RCPB	: Reactor Coolant Pressure Boundary
RCS	: Reactor Coolant System
RCP	: Reactor Coolant Pump
SIS	: Safety Injection System
SSAS	: Station Service Air System
SSS	: Secondary Sampling System
SGBDSS	: Steam Generator Blowdown Sampling System
T/B	: Turbine Building
WWS	: Waste Water System

DCD Section 9.3 Process Auxiliaries



Section	Major Contents	Safety-Related function	
9.3	Process Auxiliaries	9.3.1 Compressed Air and Gas Systems (CAGS)	Yes
	Process Auxiliaries	9.3.2 Process and Post-Accident Sampling System (PSS)	Yes
	Process Auxiliaries	9.3.3 Equipment and Floor Drain System (EFDS)	Yes
	Process Auxiliaries	9.3.4 Chemical and Volume Control System (CVCS)	Yes

9.3.1 Compressed Air and Gas Systems (CAGS)




- **The CAGS has no safety-related function except for containment isolation.**
- **The CAGS consist of:**
 - ✓ Instrument Air System (IAS)
 - ✓ Station Service Air System (SSAS)
 - ✓ Compressed Gas System (CGS)
- **IAS**
 - ✓ The IAS consists of two 100% trains with a compressor, an air receiver, and an air dryer in each train.
 - ✓ The safety-related AOVs fail in safe position on loss of IA and do not need IAS to perform a safety function.
- **SSAS**
 - ✓ The SSAS consists of three 50% trains with compressors.
 - ✓ Three compressor trains share two receivers and two dryers.
 - ✓ The SSAS can supply IAS if additional air is needed.
- **CGS**
 - ✓ The CGS consists of high pressure nitrogen gas, low pressure nitrogen gas, and hydrogen gas distribution subsystems and provide pressure-regulated gases for purging, diluting, and inerting.
 - ✓ High pressure nitrogen gas is supplied to SIS Accumulators.


9.3.1 Compressed Air and Gas Systems (CAGS)



INSTRUMENT AIR SYSTEM



STATION SERVICE AIR SYSTEM



9.3.1 Compressed Air and Gas Systems (CAGS)



➤ SER Open and Confirmatory Items

RAI No.	Question 09.03.01-X	RAI Topic / NRC Concern	RAI Response / DCD Impact
		None	

9.3.2 Process and Post-Accident Sampling Systems (PSS)



PSS have no safety-related function except for containment isolation. The PSS includes the following sub-systems:

- The Primary Liquid Sampling System (PLSS)
- The Primary Gaseous Sampling System (PGSS)
- The Post-Accident Sampling System (PASS)
- The Secondary Sampling System (SSS)
- The SGBD Sampling System (SGBDSS)
- Manual local grab sample provision

Each subsystem performs the following function:

- PLSS collects liquid samples from RCS and auxiliary systems for analysis.
- PGSS collects gaseous samples from containment atmosphere.
- PASS collects highly radioactive samples of the reactor coolant, refueling water storage pit water and containment atmosphere for analysis following accident.
- SSS monitors water sample from the turbine cycle so as to control water chemistry.
- SGBDSS monitors secondary water in SGs to maintain acceptable water chemistry and detect primary to secondary SG tube leakage.
- Manual local grab sample allows collection of liquid samples from various sampling point for analysis.

9.3.2 Process and Post-Accident Sampling Systems (PSS)



➤ SER Open and Confirmatory Items

RAI No.	Question 09.03.02-X	RAI Topic / NRC Concern	RAI Response / DCD Impact
		None	

9.3.3 Equipment and Floor Drain Systems (EFDS)




EFDS has no safety function except the isolation valves installed in the drainage piping from the ESF rooms. The EFDS includes the following sub-systems:

- **Radioactive liquid waste**
- **Non-radioactive liquid waste**
- **Chemical and detergent liquid waste**
- **Oily liquid waste**

EFDS performs the following functions:

- **EFDS collects liquid waste separately depending on the liquid waste property from equipment and floor drains by gravity during all modes of operation.**
- **Collected potential radioactive liquid waste in the EFDS is transferred to the LWMS for processing while collected non radioactive liquid waste is transferred to the T/B sump for processing.**

9.3.3 Equipment and Floor Drain Systems (EFDS)



Equipment and Floor Drain System Flow Diagram

9.3.3 Equipment and Floor Drain Systems (EFDS)



➤ SER Open and Confirmatory Items

RAI No.	Question 09.03.03-X	RAI Topic / NRC Concern	RAI Response / DCD Impact
		None	

9.3.4 Chemical and Volume Control System (CVCS)




CVCS performs the following functions:

- **Maintain the coolant inventory in the RCS for all modes of operation**
- **Provide seal-water flow to the RCP**
- **Provide makeup capability for small RCS leaks**
- **Regulate the boron concentration in the reactor coolant**
- **Control the reactor coolant water chemistry**
- **Purify the reactor coolant by removal of the fission and activation products**

The CVCS performs or supports the following safety-related functions:

- **Provide reactor coolant pressure boundary (RCPB)**
- **Containment isolation for the CVCS lines penetrating the containment**
- **Provide capability to isolate the charging line upon ECCS actuation signal and high pressurizer water level signal**
- **Isolation of RCS boron dilution sources to preclude inadvertent reactivity additions**

9.3.4 Chemical and Volume Control System (CVCS)



9.3.4 Chemical and Volume Control System (CVCS)



➤ SER Open and Confirmatory Items

RAI No.	Question 09.03.04-X	RAI Topic / NRC Concern	RAI Response / DCD Impact
		None	



Presentation to ACRS Subcommittee

Chapter 9: Auxiliary Systems

**Section 9.4 Air Conditioning, Heating,
Cooling, and Ventilation Systems**

March 22-23, 2012

Mitsubishi Heavy Industries, Ltd.

Marc Hotchkiss, P.E. – Lead Presenter
Mitsubishi Nuclear Energy Systems, Inc.

Junya Hattori – Technical Expert
Mitsubishi Heavy Industries, Ltd.
Chapter 9 Engineer

Keita Otani – Technical Expert
Mitsubishi Heavy Industries, Ltd.
Chapter 9 Engineer

Acronyms (1/1)



A/B	: Auxiliary Building
AC/B	: Access Building
ASME	: American Society of Mechanical Engineers
CFR	: Code of Federal Regulations
CRE	: Control Room Envelope
COL	: Combined License
CRDM	: Control Rod Drive Mechanism
ESF	: Engineered Safety Features
GDC	: General Design Criteria
HEPA	: High-efficiency Particulate Air
HVAC	: Heating, Ventilation, and Air Conditioning
ITAAC	: Inspection, Test, Analysis, and Acceptance Criteria
LOCA	: Loss-of-coolant Accident
MCR	: Main Control Room
PS/B	: Power Source Building
R/B	: Reactor Building
RG	: Regulatory Guide
RIS	: Regulatory Issue Summary
SRP	: Standard Review Plan
SSC	: Structure, System, and Component
T/B	: Turbine Building
TSC	: Technical Support Center

DCD Section 9.4 Air Conditioning, Heating, Cooling, and Ventilation Systems




Section		Major Contents	Safety-Related function
9.4	Air Conditioning, Heating, Cooling, and Ventilation Systems	9.4.1 Main Control Room Heating, Ventilation and Air Conditioning System	Yes
		9.4.2 Spent Fuel Pool Area Ventilation System	Not Applicable
		9.4.3 Auxiliary Building Ventilation System	Yes
		9.4.4 Turbine Building Area Ventilation System	No
		9.4.5 Engineered Safety Feature Ventilation System	Yes
		9.4.6 Containment Ventilation System	Yes

9.4.1 Main Control Room Heating, Ventilation and Air Conditioning System (MCR HVAC System)



- **The MCR HVAC System provides and controls the proper environment in the MCR and other areas within the control room envelope (CRE).**
- **The MCR HVAC System is a safety-related system and performs the following functions:**
 - ✓ Excludes entry of airborne radioactivity into the CRE and removes radioactive material from the CRE environment.
 - ✓ Supports and maintains CRE habitability and permits personnel occupancy and proper functioning of instrumentation during normal conditions and design basis accidents.

9.4.1 Main Control Room Heating, Ventilation and Air Conditioning System (MCR HVAC System)



9.4.1 Main Control Room Heating, Ventilation and Air Conditioning System (MCR HVAC System)



➤ Open Items and Confirmatory Items

RAI No.	Question 09.04.01-X	RAI Topic / NRC Concern	RAI Response / DCD Impact
883-6063	29	<p><u>Open Item 09.04.01-29</u></p> <ul style="list-style-type: none"> - Provide the calculated values for maximum component temperatures in the adsorber section with normal ventilation unit flow and with filtration unit shutdown (post-LOCA condition) to conclude that design limiting temperature of 300F is not exceeded. - Provide the maximum expected post-accident radioactively-induced temperature of the charcoal filter beds. 	<ul style="list-style-type: none"> ➤ MHI is discussing draft response with NRC staff: <ul style="list-style-type: none"> ✓ The charcoal adsorber is designed in accordance with RG 1.52 and the actual loading is expected to be lower such that iodine desorption temperature would not be challenged. The high temperature alarm setpoint is established to prevent exceeding the temperature at which iodine desorption can occur. ✓ The high-high temperature alarm setpoint is established to prevent exceeding the temperature at which charcoal ignition can occur.

9.4.1 Main Control Room Heating, Ventilation and Air Conditioning System (MCR HVAC System)



➤ Open Items and Confirmatory Items

RAI No.	Question 09.04.01-X	RAI Topic / NRC Concern	RAI Response / DCD Impact
883-6063	29	<p><u>Open Item 09.04.01-29 (continued)</u></p> <p>- Provide the maximum mass loading on the upstream HEPA filters of both the MCR emergency filter trains and the Annulus Emergency Exhaust System filter trains.</p>	<p>✓ The HEPA filter unit is designed in accordance with RG 1.52 and ASME AG-1. HEPA filter particulate loading is expected to be low relative to rated dust loading due to the installed upstream high efficiency pre-filter. The HEPA filters are installed to include margin over the design flowrate.</p> <p>MHI is in discussion with NRC staff regarding final resolution.</p>

9.4.1 Main Control Room Heating, Ventilation and Air Conditioning System (MCR HVAC System)



➤ Open Items and Confirmatory Items

RAI No.	Question 09.04.01-X	RAI Topic / NRC Concern	RAI Response / DCD Impact
883-6063	30	<p><u>Open Item 09.04.01-30</u></p> <p>- Provide additional information related to the deletion of ITAAC Item 12 from Tier 1 Table 2.6.5-1 related to AAC GTG reliability.</p>	<p>MHI is in discussion with NRC staff regarding further substantiating the reason for this deletion.</p>
883-6063	31	<p><u>Open Item 09.04.01-31</u></p> <p>Provide justification for non-safety related MCR HVAC humidifiers and controls.</p> <p>NRC staff requests a minimum credible humidity for the site conditions permitted in the DC with no humidity control to use for the qualification of control room electrical equipment or the change in the plant design to include safety-related humidifiers.</p>	<p>The response to this open item is under development.</p>

9.4.1 Main Control Room Heating, Ventilation and Air Conditioning System (MCR HVAC System)



➤ Open Items and Confirmatory Items

RAI No.	Question 09.04.01-X	RAI Topic / NRC Concern	RAI Response / DCD Impact
883-6063	32	<p><u>Open Item 09.04.01-32</u></p> <p>Provide additional information regarding the design of the MCR air handling unit cooling coils and provisions to prevent coil leakage from entering the MCR through the supply duct.</p>	<p>➤ MHI provided:</p> <ul style="list-style-type: none"> ✓ The safety-related, seismic category I MCR HVAC cooling coils are not subject to postulated failure consistent with the requirements of GDC 4. Therefore, special design features to protect against a cooling coil rupture or significant leak are not warranted. Normal AHU drains accommodate condensation and minor leakage. <p>MHI is in discussion with NRC staff regarding final resolution.</p>

9.4.1 Main Control Room Heating, Ventilation and Air Conditioning System (MCR HVAC System)



➤ Open Items and Confirmatory Items

RAI No.	Question 09.04.01-X	RAI Topic / NRC Concern	RAI Response / DCD Impact
825-5999	09.04.05-21	<u>Confirmatory Item 09.04.05-21</u> Provide a reference to the updated March, 2011 version of MUAP-10020 in the DCD.	➤ As described in the response to the RAI, MHI intends to revise the reference to MUAP-10020 in the next revision of the DCD to support closure of this confirmatory item.


9.4.3 Auxiliary Building Ventilation System



The Auxiliary Building Ventilation System includes the following sub-systems:

- ✓ Auxiliary building HVAC system
 - ✓ Non-Class 1E electrical room HVAC system
 - ✓ Main steam/feedwater piping area HVAC system
 - ✓ Technical support center (TSC) HVAC system
- **The auxiliary building HVAC system is a non-safety related system, with the exception of safety-related isolation dampers which isolate the penetration and the safeguard component areas, and the vent stack from the auxiliary building HVAC system.**
- **The auxiliary building HVAC system performs the following functions:**
- ✓ Provide and maintain proper operating environment within the required temperature range for areas housing mechanical and electrical equipment within the A/B, R/B, PS/B and AC/B during normal plant operation.
 - ✓ Keep dose levels due to the airborne radioactivity in normally occupied areas below the allowable values.
 - ✓ Maintain a slightly negative pressure in the controlled areas relative to the outside atmosphere to minimize exfiltration from the radiological controlled areas.
 - ✓ Maintain airflow from areas of low radioactivity to areas of potentially higher radioactivity.

9.4.3 Auxiliary Building Ventilation System



9.4.3 Auxiliary Building Ventilation System



- **The Non-Class 1E electrical room HVAC system is non-safety related system and performs the following function:**
 - ✓ Provide and maintain the room ambient conditions within the required temperature range to support the continuous operation of the electrical equipment and components.
 - ✓ Maintain the hydrogen concentration below 1% by volume of battery room.
- **The TSC HVAC system is non-safety related system and performs the following functions:**
 - ✓ Exclude entry of airborne radioactivity into the TSC envelope and remove radioactive material from the TSC envelope environment.
 - ✓ Provide and maintain proper environmental conditions within the required temperature range to assure personnel comfort and to support the operation of the control and instrumentation equipment and components.
 - ✓ Support and maintain TSC habitability and permit personnel occupancy following plant emergency conditions.
- **The Main steam/feedwater piping area HVAC system is a non-safety related system.**
 - ✓ Provide and maintain proper environmental conditions within the required temperature range suitable to support the operation and assure the reliability of the electrical and mechanical components.

9.4.3 Auxiliary Building Ventilation System



➤ Open Items and Confirmatory Items

RAI No.	Question 09.04.03-X	RAI Topic / NRC Concern	RAI Response / DCD Impact
831-6030	17	<u>Open Item 09.04.03-17</u> Provide additional justification for not including the ABVS function to provide dilution flow in support of the GWMS in Tier 1.	➤MHI provided: ✓The existing Tier 1 descriptions and ITAAC verify functional arrangement of ABVS to support the dilution flow function and are consistent with SRP 14.3 guidance and RIS 2008-05 guidance for Tier 1 content.

9.4.3 Auxiliary Building Ventilation System



➤ Open Items and Confirmatory Items

RAI No.	Question 09.04.03-X	RAI Topic / NRC Concern	RAI Response / DCD Impact
831-6030	18	<u>Open Item 09.04.03-18</u> Clarify ITAAC Table 2.7.5.4-3 line item 10 to ensure ABVS exhaust flow greater than supply flow to maintain a negative pressure within the radiologically controlled areas.	➤MHI provided: ✓Revised wording for the ITAAC to clarify that the design commitment is to maintain exhaust airflow greater than supply airflow to control the release of potentially radioactive materials from radiologically controlled areas, and the acceptance criteria is that two of three exhaust fans will be operating and that exhaust flowrate will be greater than supply flowrate.

9.4.3 Auxiliary Building Ventilation System



➤ Open Items and Confirmatory Items

RAI No.	Question 09.04.03-X	RAI Topic / NRC Concern	RAI Response / DCD Impact
831-6030	19	<p><u>Open Item 09.04.03-19</u></p> <p>Provide the description of the function of the ABVS exhaust flow damper to prevent backflow. Establish that the responsibility for ABVS flow balance testing and frequency is assigned to the COL applicant.</p>	<p>➤MHI provided:</p> <ul style="list-style-type: none"> ✓The description of the function of the ABVS exhaust flow damper to prevent backflow will be included in the DCD. ✓A COL applicant item for ABVS flow balance testing and frequency will be included in the DCD.
831-6030	20	<p><u>Open Item 09.04.03-20</u></p> <p>Provide a description of the check valve in the sump line between the TB sump and the A/B that prevents backflow to the TB.</p>	<p>➤MHI provided:</p> <ul style="list-style-type: none"> ✓The description of the check valve in the sump line between the TB sump and the A/B that prevents backflow to the TB will be included in the DCD and shown on the flow diagram.

9.4.3 Auxiliary Building Ventilation System



➤ Open Items and Confirmatory Items

RAI No.	Question 09.04.03-X	RAI Topic / NRC Concern	RAI Response / DCD Impact
831-6030	21	<p><u>Open Item 09.04.03-21</u></p> <p>Revise DCD Figure 9.4.3-1 (ABVS) to reflect the existence of backdraft dampers.</p>	<p>➤MHI provided:</p> <p>✓DCD Subsection 9.4.3.2.1 system description will be revised to describe the backdraft dampers. The description is broadly applicable and inclusive of auxiliary building HVAC system branch ducts supplying or exhausting uncontrolled areas that may not be shown on the simplified flow diagram. Therefore, it is not practical or necessary to show the backdraft dampers on DCD Figure 9.4.3-1.</p>

9.4.3 Auxiliary Building Ventilation System





➤ Open Items and Confirmatory Items

RAI No.	Question 09.04.03-X	RAI Topic / NRC Concern	RAI Response / DCD Impact
355-2942	3	<u>Confirmatory Item 09.04.03-3</u> Revise the DCD to reflect the existence of ABVS backdraft dampers.	➤MHI provided: ✓DCD Subsection 9.4.3.2.1 system description will be revised to describe the backdraft dampers to support closure of this item.

9.4.4 Turbine Building Area Ventilation System



- The Turbine Building Area Ventilation System (T/B HVAC) is a non safety related system.
- The T/B area is not expected to include airborne radioactive contamination. No safety related SSCs are in T/B.
- The T/B HVAC maintain a suitable environment for the operation of equipment in the turbine building.



9.4.4 Turbine Building Area Ventilation System



➤ Open Items and Confirmatory Items

RAI No.	Question 09.04.04-X	RAI Topic / NRC Concern	RAI Response / DCD Impact
586-4690	6	To explain how GDC2 is not applicable, the DCD states that safety-related equipment is not located in the T/B. This commitment must be expanded to "Important to Safety" equipment.	➤ Draft response currently under development.
713-5555 (follow-up)	7	According to Appendix 3D of DCD Ch. 3, there are "Important to Safety" SSCs in T/B .	
814-5943 (follow-up)	8		

9.4.5 Engineered Safety Feature (ESF) Ventilation System



- **The ESF Ventilation System is a safety related system and includes the following sub-systems:**
 - ✓ Annulus Emergency Exhaust System
 - ✓ Class 1E Electrical Room HVAC System
 - ✓ Safeguard Component Area HVAC System
 - ✓ Emergency Feedwater Pump Area HVAC System
 - ✓ Safety Related Component Area HVAC System

9.4.5 Engineered Safety Feature (ESF) Ventilation System



- **Annulus Emergency Exhaust System performs the following function:**
 - ✓ Remove and retain fission products by filtering the air that is exhausted from the penetration areas and safeguard component areas following an accident.


- **Class 1E Electrical Room HVAC System performs the following functions:**
 - ✓ Maintain proper operating environmental conditions within Class 1E electrical rooms.
 - ✓ Maintain the hydrogen concentration below 1% by volume in the Class 1E battery room.

- **Other subsystems of the ESF ventilation system provide the proper environmental conditions within plant areas that house engineered safety features equipment.**

9.4.5 Engineered Safety Feature (ESF) Ventilation System




Annulus Emergency Exhaust System



9.4.5 Engineered Safety Feature (ESF) Ventilation System



Class 1E Electrical Room HVAC System



UAP-HF-12070-24

9.4.5 Engineered Safety Feature (ESF) Ventilation System



➤ Open Items and Confirmatory Items

RAI No.	Question 09.04.05-X	RAI Topic / NRC Concern	RAI Response / DCD Impact
825-5999	20	<u>Open Item 09.04.05-20</u> Provide the revision to ITAAC Table 2.7.5.2-3 as committed in response to RAI 474-3811, Question 09.04.05-10.	➤MHI provided: ✓As part of the implementation of RIS 2008-05 guidance for Tier 1 ITAAC, MHI determined that portions of the committed changes to ITAAC Table 2.7.5.2-3 were not appropriate since those additions were not credited in accident analyses and were not key functions.

9.4.5 Engineered Safety Feature (ESF) Ventilation System



➤ Open Items and Confirmatory Items

RAI No.	Question 09.04.05-X	RAI Topic / NRC Concern	RAI Response / DCD Impact
670-4773	18	<p><u>Confirmatory Item 09.04.05-18</u></p> <p>Provide a correction to the response to RAI 64-735, Question 9.4.5-18 related to battery hydrogen generation during discharge.</p>	<p>➤MHI will provide an amended response to RAI 64-735, Question 9.4.5-18 to support closure of this item.</p>
825-5999	21	<p><u>Confirmatory Item 09.04.05-21</u></p> <p>Provide a reference to technical report MUAP-10020 (HVAC Calculations) in DCD Section 6.5.7.</p>	<p>➤As described in the response to the RAI, MHI intends to revise the reference to MUAP-10020 in the next revision of the DCD to support closure of this confirmatory item.</p>

9.4.6 Containment Ventilation System




- **The Containment Ventilation System is a non-safety related system, with the exception of piping and valves between and including containment isolation valves, and includes the following sub-systems:**
 - ✓ Containment Fan Cooler System
 - ✓ Control Rod Drive Mechanism (CRDM) Cooling System
 - ✓ Reactor Cavity Cooling System
 - ✓ Containment Purge System
- **Containment Fan Cooler System performs the following function:**
 - ✓ Maintain proper environmental conditions in containment during normal plant operation and LOOP condition.
- **CRDM Cooling System performs the following function:**
 - ✓ Remove the heat dissipated by the CRDMs.
- **Reactor Cavity Cooling System performs the following functions:**
 - ✓ Remove the heat dissipated by the reactor vessel, the reactor vessel support structure, and the gamma radiation and fast neutron bombardment on the primary shield wall.
 - ✓ Provide adequate cooling for the primary shield and the reactor vessel support base plates to prevent concrete dehydration.

9.4.6 Containment Ventilation System



- **Containment Purge System includes the following sub-systems:**
 - ✓ Containment low volume purge system
 - ✓ Containment high volume purge system
- **Containment Low Volume Purge System performs the following functions:**
 - ✓ Minimize the potential spread of radioactive contamination from the areas serviced by the auxiliary building HVAC system.
 - ✓ Provide relief from pressure build-up within containment caused by instrument air leakage and containment temperature fluctuations.
- **Containment High Volume Purge System performs the following function:**
 - ✓ Maintain low concentrations of radioactivity in the containment atmosphere to allow access during maintenance and inspection activities

9.4.6 Containment Ventilation System



9.4.6 Containment Ventilation System



➤ Open Items and Confirmatory Items

RAI No.	Question 09.04.06-X	RAI Topic / NRC Concern	RAI Response / DCD Impact
826-6014	06.05.01-22	<p><u>Open Item 06.05.01-22:</u></p> <p>Provide ITAAC to demonstrate that as-built fire dampers fully close under system design flow rates.</p>	<p>➤MHI provided:</p> <p>✓The fire dampers are designed and installed so that the air velocity in the ducts assists in closing and does not preclude proper damper closure per NFPA requirements. Therefore no testing for closure under design flow rates is required.</p>
826-6014	06.05.01-21	<p><u>Confirmatory Item 06.05.01-21:</u></p> <p>Amend DCD Subsection 14.2.12.1.66 to resolve inconsistencies as committed to in response to question 06.05.01-14.</p>	<p>➤MHI provided:</p> <p>✓DCD Subsection 14.2.12.1.66 will be revised as committed in response to 06.05.01-14 to support closure of this item.</p>



Presentation to ACRS Subcommittee
Chapter 9: Auxiliary Systems
Section 9.5 Other Auxiliary Systems

March 22-23, 2012

Mitsubishi Heavy Industries, Ltd.

James Curry, Ph.D., P.E., – Lead Presenter
Mitsubishi Nuclear Energy Systems, Inc.

Ronald Reynolds – Lead Presenter
Mitsubishi Nuclear Energy Systems, Inc.

Keita Otani – Technical Expert
Mitsubishi Heavy Industries, Ltd.
Chapter 9 Engineer

Hideki Tanaka – Technical Expert
Advanced Energy America, LLC.

Acronyms (1/1)



EOF	:Offsite Emergency Operations Facility
FHA	:Fire Hazard Analysis
FOS	:Fuel Oil Storage and Transfer System
GTG	:Gas Turbine Generator
IESNA	:Illuminating Engineering Society of North America
LOOP	:Loss of Offsite Power
MCR	:Main Control Room
PABX	:Private Automatic Branch Telephone Exchange
PS/B	:Power Source Building
RSC	:Remote Shutdown Console
RG	:Regulatory Guide
SBO	:Station Blackout
SRP	:Standard Review Plan
SSC	:Structures, Systems, and Components
TSC	:Technical Support Center
UPS	:Uninterruptible Power Supply

DCD Section 9.5 Other Auxiliary Systems



Section	Major Contents	Safety-Related function
9.5 Other Auxiliary Systems	9.5.1 Fire Protection Program	No
	9.5.2 Communication Systems	No
	9.5.3 Lighting Systems	No
	9.5.4 Gas Turbine Generator Fuel Oil Storage and Transfer System	Yes
	9.5.5 Gas Turbine Generator Cooling Water System [Not Required]	Yes
	9.5.6 Gas Turbine Generator Starting System	Yes
	9.5.7 Gas Turbine Lubrication System	Yes
	9.5.8 GTG Combustion Air Intake, Turbine Exhaust, Room Air Supply, and Air Exhaust Systems	Yes

9.5.1 Fire Protection Program

- **Primary objectives of fire protection program:**
 - ✓ Minimize the potential for fires and explosions to occur.
 - ✓ Rapidly detect, control, and extinguish any fires that do occur.
 - ✓ Assure that any fire that is not promptly extinguished by the fire suppression system will not prevent safe-shutdown of the plant and will minimize the potential for radioactive releases to the environment.

- **Fire Protection Program describes:**
 - ✓ Defense-in-depth approach
 - ✓ Overall fire protection program for facility.
 - ✓ Positions and responsibilities for the program.
 - ✓ Manual and automatic detection and suppression systems
 - ✓ Administrative controls.
 - ✓ That the COL Applicant is responsible for providing site-specific information and a schedule for implementation.

9.5.1 Fire Protection Program

- **Fire protection design features include the following functions:**
 - ✓ Prevent fire initiation by controlling, separating, and limiting the quantities of combustibles and sources of ignition.
 - ✓ Isolate combustible materials and limit the spread of fire by subdividing plant structures into fire areas separated by fire barriers and further separate fire areas into fire zones.
 - ✓ Separate redundant safe-shutdown components and associated electrical divisions by 3-hour rated fire barriers to preserve the capability to achieve and maintain safe shutdown of the plant following a fire.
 - ✓ Preserve the capability to achieve and maintain safe shutdown of the plant using controls external to the main control room (MCR), should a fire require evacuation of the MCR or damage the MCR circuitry for safe-shutdown systems.
 - ✓ Separate redundant trains of safety-related equipment used to mitigate the consequences of a design basis accident.

9.5.1 Fire Protection Program

- **Fire protection systems are designed to:**
- ✓ Detect and locate fires and provide operator indication of the location.
 - ✓ Provide the capability to extinguish fires in any plant area, to protect site personnel, limit fire damage, and enhance safe-shutdown capabilities.
 - ✓ Supply fire suppression water at a sufficient flow rate and pressure in accordance with NFPA codes.
 - ✓ Maintain 100% design capacity of fire pump, assuming failure of one fire pump or the loss of offsite power (LOOP). Design includes one electric and one diesel-driven fire pump.
 - ✓ The fire protection system is non-safety related with the exception of piping between and including containment isolation valves
 - ✓ Seismic design requirements are applied to portions of the system located in areas containing equipment required for safe-shutdown following a safe-shutdown earthquake (SSE).

9.5.1 Fire Protection Program

- **Fire Hazard Analysis (FHA) for US-APWR standard plant**
 - ✓ The purpose of the FHA is to:
 - Evaluate potential in-situ and transient fire and explosion hazards.
 - Define fire barrier locations
 - Identify detection and suppression coverage throughout the plant
 - Confirm that the effects of a fire in any location in the plant do not adversely impact the ability to safely shut down the reactor and that the release of radioactivity to the environment is controlled and minimized.
 - Select appropriate measures for fire prevention, fire detection, fire suppression, and fire containment for each fire area containing structures, systems, and components (SSCs) important to safety in accordance with NRC guidelines and regulations.
 - ✓ The FHA is performed for areas of the plant containing safety-related components and for areas containing systems important to the generation of electricity. The FHA is performed on a fire area by fire area basis with combustible loads identified by fire zone. This approach provides confidence that plant safety is achieved and the intent of fire protection program requirements are satisfied.

9.5.2 Communication Systems

- The Communication systems consist of:
 - ✓ Public address system/page
 - ✓ Telephone system
 - ✓ Sound powered telephone system
 - ✓ Plant radio system
 - ✓ Offsite communication system including emergency communication systems
- The means exists for communication between the MCR and TSC and from the MCR and TSC to Offsite Emergency Operations Facility (EOF), principal state and local emergency operations centers, and radiological field assessment teams.
- The means exist for communication from the MCR, TSC, and EOF to the NRC headquarters and regional emergency operations centers.

9.5.2 Communication Systems

➤ Major RAIs (Confirmatory Items)

RAI No.	Question 09.05.02-X	RAI Topic / NRC Concern	RAI Response / DCD Impact
859-6105	11	<p><u>Confirmatory Item 9.5.2-1:</u></p> <p>DCD Tier 2, Section 13.3 became specific on details concerning telecommunication in the Technical Support Center (TSC) by stating that, "Ample working areas for all personnel as described in section 9.5.2." However, DCD Tier 2, Section 9.5.2, does not address "ample working areas."</p>	<p>➤ MHI previously provided:</p> <ul style="list-style-type: none"> ✓ The phrase was meant to say "Plant communications systems are described in Subsection 9.5.2" and states the correction would be made in the next DCD revision.

9.5.3 Lighting Systems

➤ The lighting system consists of:

- ✓ Normal lighting: All indoor and outdoor areas
- ✓ Emergency lighting
 - Class 1E emergency lighting: Safe shutdown operation area
 - Self-contained battery pack emergency lighting: Emergency operation area, safe ingress and egress route of personnel during emergencies
 - Normal/emergency lighting: All indoor plant area except the MCR and RSC room

➤ The lighting system is supplied from:

- ✓ Normal lighting: Non-Class 1E power system
- ✓ Emergency lighting
 - Class 1E emergency lighting: Class 1E power system
 - Self-contained battery pack emergency lighting: Class 1E power system or Non-Class 1E power system, as applicable
 - Normal/emergency lighting: Non-Class 1E power system, backed up by alternate ac power source

9.5.3 Lighting Systems

➤ Major RAIs (Open and Confirmatory Items)

RAI No.	Question 09.05.03-X	RAI Topic / NRC Concern	RAI Response / DCD Impact
		None	

9.5.4 GTG Fuel Oil Storage and Transfer System



➤ Design Features


- ✓ Each GTG FOS is composed of
 - 1) One fuel oil storage tank
 - 2) Two fuel oil transfer pumps
 - 3) One fuel oil day tank
 - 4) One fuel filling port
 - 5) Vent piping from both the fuel oil storage tank and the day tank
 - 6) Piping and Valves
 - 7) Instrumentation and Control

- ✓ Capacity
 - Fuel oil storage tank : 7 days
 - Fuel oil day tank : 1.5 hours

9.5.4 GTG Fuel Oil Storage and Transfer System



➤ System Configuration



9.5.4 GTG Fuel Oil Storage and Transfer System



➤ Major RAIs (Open Items)

RAI No.	Question	RAI Topic / NRC Concern	RAI Response / DCD Impact
468-3360	9.5.4-49	To add standard for the design of gas turbines "ISO3977 part 3, 2004" [Open Item 9.5.4-1]	<ul style="list-style-type: none">➤ This standard includes requirements which are applied to continuous operating type GTG and not appropriate for emergency/back-up type GTG.➤ MHI will identify whether there are some deviations from this standard and make an exception for the emergency GTG support systems.

9.5.4 GTG Fuel Oil Storage and Transfer System



➤ Major RAIs (Confirmatory Items)

RAI No.	Question	RAI Topic / NRC Concern	RAI Response / DCD Impact
754-5617	14.3.6-20	-Section 2.6.4.1, Item 12.b Rev. 3 of Tier 1 of US-APWR DCD should similarly make it clear that each Class 1E EPS train is located in a separate room of the PS/B. [Confirmatory Item 9.5.4-1]	➤ MHI provided: Each redundant division of Class 1E EPSs is located in a separate room of the PS/B. The corresponding ITAAC Acceptance Criteria and Section 2.6.4.1 will be similarly revised.

9.5.6 GTG Starting System

➤ Design Features

- ✓ Starting time
 - Less than 100 seconds

- ✓ Starting system
 - Compressed air system


- ✓ Starting Air Capacity
 - Three consecutive GTG starts
(without compressor assistance)

- ✓ Each GTG starting system is composed of
 - 1) Six air compressors with an air cooler
 - 2) Three drain chambers
 - 3) Two air receivers
 - 4) Two air starting units

9.5.6 GTG Starting System



➤ System Configuration



9.5.6 GTG Starting System

➤ Major RAIs (Confirmatory Items)

RAI No.	Question	RAI Topic / NRC Concern	RAI Response / DCD Impact
319-2147	9.5.6-20	<p>-The air starting system air receivers should be in accordance with ASME Section III, Class 3.</p> <p>-"Qualification and Test Plan of Class 1E Gas Turbine Generator System," December 2007, states in accordance with ASME Section VIII.</p> <p>[Confirmatory Item 9.5.6-1]</p>	<p>➤ MHI provided:</p> <p>Air receivers are designed to not ASME Section VIII but ASME Section III, Class 3.</p>
754-5617	14.3.6-28	<p>-Rev. 3 of US-APWR DCD Tier1 Table 2.6.4-2, the starting air system are ASME Section III, Class3 from discharge of the air compressors through air starter at the GTG.</p> <p>- DCD Tier 2 Figure 9.5.6-1 (Rev 2) state non safety-related up to the inlet check valve of air receiver.</p> <p>[Confirmatory Item 9.5.6-2]</p>	<p>➤ MHI provided:</p> <p>Revising Tier 1, Table 2.6.4-2 to be consistent with Figure 9.5.6-1.</p>

9.5.6 GTG Starting System

➤ Major RAIs (Confirmatory Items)

RAI No.	Question	RAI Topic / NRC Concern	RAI Response / DCD Impact
319-2147	9.5.6-22	<p>-“Qualification and Test Plan of Class 1E Gas Turbine Generator System,” December 2007, indicates that pipes from air tanks to the generator set shall be zinc coated.</p> <p>-DCD Tier 2 Table 9.5.6-1 indicates that piping will be stainless steel and carbon steel. [Confirmatory Item 9.5.6-3]</p>	<p>➤ MHI provided: The zinc coated piping is not applied.</p>
754-5617	14.3.6-24	<p>-Rev. 3 of US-APWR DCD, Table 2.6.4-1, Item 19 addresses the functional arrangements of the fuel oil storage and transfer system and the ventilation/cooling air intake and exhaust system.</p> <p>-There is no similar item in Section 2.6.4.1 for the lube oil and starting air system. [Confirmatory Item 9.5.6-4]</p>	<p>➤ MHI provided: US-APWR DCD Rev. 3 Section 2.6.4.2 Design Description 19 and corresponding Table 2.6.4-1 ITAAC #19 will be revised to verify GTG compressed air starting system configuration.</p>

9.5.7 Gas Turbine Lubrication System


➤ Design Features

- ✓ The lubrication systems are composed of
 - 1) Two GT shaft drive pumps
 - 2) One reduction gear box (Oil Reservoir)
 - 3) Suction strainer at each oil pump suction line
 - 4) One full flow filter
 - 5) One lube oil cooler for each pump
 - 6) Oil cooler fan for each oil cooler
 - 7) Valves, piping and instrumentation
- ✓ All components of the system are contained in GTG enclosure.
- ✓ Keep-warm system is not installed, since lube oil performs under cold condition

9.5.7 Gas Turbine Lubrication System



➤ System Configuration



9.5.7 Gas Turbine Lubrication System

➤ Major RAIs (Confirmatory Items)

RAI No.	Question	RAI Topic / NRC Concern	RAI Response / DCD Impact
754-5617	14.3.6-23	-Rev. 3 of US-APWR DCD, Table 2.6.4-1, Item 16 – The AC for the ITAAC should require that the as-built protection system are automatically bypassed when the Class 1E EPS is started by an ECCS actuation signal. [Confirmatory Item 9.5.7-1]	➤ MHI provided: US-APWR DCD Revision 3 Section 2.6.4.1 Design Description 16 and corresponding Table 2.6.4-1 ITAAC #16 will be revised to specify the automatic bypass feature.
754-5617	14.3.6-26	-Rev. 3 of US-APWR DCD, Table 2.6.4-1, Item 30 – This ITAAC should require that the oil capacity verified is based on the maximum expected oil consumption rate, e.g., just prior to a scheduled overhaul. [Confirmatory Item 9.5.7-2]	➤ MHI provided: US-APWR DCD Revision 3 Tier 1, Section 2.6.4.3 Design Description 30 and Table 2.6.4-1 ITAAC #30 will be revised to specify the lubricating oil consumption rate for calculating lubrication oil tank capacity (e.g., maximum expected oil consumption rate immediately prior to scheduled overhaul).

9.5.8 GTG Combustion Air Intake, Turbine Exhaust Room Air Supply, and Air Exhaust System



➤ Design Features

- ✓ Capable of supplying combustion air and providing for exhaust
 - Continuous operation of the GTGs at 110% rating output

- ✓ A combustion air intake and exhaust system consists of
 - 1) Air intake screen
 - 2) Air exhaust weather louver and screen
 - 3) Silencer
 - 4) Ventilation fan (room air supply and air exhaust)
 - 5) Associated ductwork and flexible connections


9.5.8 GTG Combustion Air Intake, Turbine Exhaust Room Air Supply, and Air Exhaust System



➤ System Configuration

Air exhaust weather louver & screen

Ventilation fan



Air intake screen

Silencer

9.5.8 GTG Combustion Air Intake, Turbine Exhaust Room Air Supply, and Air Exhaust System



➤ Major RAIs (Confirmatory Items)

RAI No.	Question	RAI Topic / NRC Concern	RAI Response / DCD Impact
704-5248	9.5.8-28	-The detail how the combustion air intake will be designed to prevent the ingestion of snow and rain. [Confirmatory Item 9.5.8-1]	➤ MHI provided: The intake structure extends beyond the edge and below the roof line of the PS/B. The air intake opening intake structure is in a horizontal position facing downward.
754-5617	14.3.6-22	-Rev. 3 of US-APWR DCD, Table 2.6.4-1, Item 11 – This ITAAC should verify a design that provides adequate separation of the intake and exhaust in accordance with the design description in Tier 2 Section 9.5.8.3 A which states that the exhaust is “located appropriately away” from the intake, “thereby minimizing the chances of the turbine exhaust being drawn into the intake.” [Confirmatory Item 9.5.8-2]	➤ MHI provided: US-APWR DCD Revision 3 Tier 1, Section 2.6.4.1 Design Description 11 and corresponding Table 2.6.4-1, ITAAC #11 will be revised to specify that the Class 1E EPS engine air intake is “appropriately separated from the engine exhaust to minimize recirculation of exhaust gases to the air intake.”

9.5.8 GTG Combustion Air Intake, Turbine Exhaust Room Air Supply, and Air Exhaust System



➤ Major RAIs (Confirmatory Items)

RAI No.	Question	RAI Topic / NRC Concern	RAI Response / DCD Impact
754-5617	14.3.6-25	<p>-Rev. 3 of US-APWR DCD, Table 2.6.4-1, Item 25 – This item addresses the power supply for the fuel oil transfer pumps.</p> <p>-There are other support system components that are also powered by the respective Class 1E division power supply, such as the ventilation/cooling supply and exhaust fans.</p> <p>[Confirmatory Item 9.5.8-3]</p>	<p>➤ MHI provided: US-APWR DCD Revision 3 Tier 1, Section 2.6.4.2 Design Description 25 and Table 2.6.4-1 ITAAC #25 will be revised to verify Class 1E power for Class 1E EPS ventilatoin fans.</p>



Presentation to the ACRS Subcommittee

**Mitsubishi Heavy Industries (MHI)
US-APWR Design Certification Application Review**

Safety Evaluation with Open Items: Chapter 9

AUXILIARY SYSTEMS

MARCH 22-23, 2012

Staff Review Team

- **Technical Staff Presenters**
 - ◆ Larry Wheeler – DCD Section 9.2.1 and 9.2.2
 - ◆ Angelo Stubbs – DCD Sections 9.2.6
 - ◆ David Nold – DCD Sections 9.4.1 and 9.4.5
- **Project Managers**
 - ◆ Jeff Ciocco – Lead Project Manager
 - ◆ Paul Kallan – Chapter 9 Project Manager

Staff Review Team

- ◆ **Diego Saenz**
Reactor System, Nuclear Performance and Code Review Branch
- ◆ **Larry Wheeler**
Balance of Plant and Technical Specifications Branch
- ◆ **Gordon Curran**
Balance of Plant and Technical Specification Branch
- ◆ **Chang Li**
Balance of Plant and Technical Specifications Branch
- ◆ **Ryan Eul**
Balance of Plant and Technical Specifications Branch
- ◆ **Raul Hernandez**
Balance of Plant and Fire Protection Branch
- ◆ **Angelo Stubbs**
Balance of Plant and Fire Protection Branch
- ◆ **Thinh Dinh**
Balance of Plant and Fire Protection Branch

Staff Review Team

- ♦ **Robert Radlinski**
Balance of Plant and Fire Protection Branch
- ♦ **David Nold**
Containment and Ventilation Branch
- ♦ **Eduardo Sastre**
Component Integrity Branch
- ♦ **Eugene Eagle**
Instrumentation and Controls Branch
- ♦ **Robert Fitzpatrick**
Instrumentation and Controls Branch

Overview of Design Certification Application, Chapter 9

SRP Section/Application Section		No. of Questions	Number of OI
9.1.1	Criticality Safety of Fresh and Spent Fuel Storage and Handling	23	0
9.1.2	New and Spent Fuel Storage	25	0
9.1.3	Spent Fuel Pool Cooling and Cleanup System	9	1
9.1.4	Light Load Handling System	23	1
9.1.5	Overhead Heavy Load Handling Systems	19	1
9.2.1	Station Service Water System	59	1

Overview of Design Certification Application, Chapter 9

SRP Section/Application Section		No. of Questions	Number of OI
9.2.2	Reactor Auxiliary Cooling Water	85	1
9.2.4	Potable and Sanitary Water Systems	3	0
9.2.5	Ultimate Heat Sink	10	0
9.2.6	Condensate Storage Facilities	3	1
9.2.7	Chilled Water System (Reviewed under 9.2.2)	0	0
9.2.8	Turbine Component Cooling Water System (Reviewed under 9.2.2)	0	0

Overview of Design Certification Application, Chapter 9

SRP Section/Application Section		No. of Questions	Number of OI
9.2.9	Non-Essential Service Water System (Reviewed under 9.2.2)	0	0
9.3.1	Compressed Air System	5	0
9.3.2	Process and Post-accident Sampling Systems	16	0
9.3.3	Equipment and Floor Drainage System	19	0
9.3.4	Chemical and Volume Control System	25	0
9.4.1	Control Room Area Ventilation System	32	4

Overview of Design Certification Application, Chapter 9

SRP Section/Application Section		No. of Questions	Number of OI
9.4.2	Spent Fuel Pool Area Ventilation System	7	0
9.4.3	Auxiliary and Radwaste Area Ventilation System	21	5
9.4.4	Turbine Area Ventilation System	8	1
9.4.5	Engineered Safety Feature Ventilation System	22	2
9.4.6	Containment Ventilation System	21	1
9.5.1	Fire Protection Program	19	0

Overview of Design Certification Application, Chapter 9

SRP Section/Application Section		No. of Questions	Number of OI
9.5.2	Communications Systems	12	0
9.5.3	Lighting Systems	9	0
9.5.4	Emergency Diesel Engine Fuel Oil Storage and Transfer System (Reviewed under 9.5.4)	51	1
9.5.5	Emergency Diesel Engine Cooling Water System	0	0
9.5.6	Emergency Diesel Engine Starting System	25	0
9.5.7	Emergency Diesel Engine Lubrication System	24	0

Overview of Design Certification Application, Chapter 9

SRP Section/Application Section		No. of Questions	Number of OI
9.5.8	Emergency Diesel Engine Combustion Air Intake and Exhaust System	28	0
Totals		603	20

Technical Topics

Section 9.2.1 - Essential Service Water System (ESWS)

- ♦ ESWS blowdown (4 trains) and strainer backwash discharge (4 trains) connect to a common header which discharges to circulating water blowdown (AOV-577)
- ♦ Safety related to nonsafety related interface
- ♦ ESW- AOV-577 automatically closes on UHS basin low level, ESWS pump stop, ECCS actuation, and LOOP
- **Open Item x (RAI 6344)** – Provide detailed information on the four different power supplies, I&C logic related to ESWS pump stop, and completed the Failure Modes and Effects Analysis (FMEA)

Technical Topics

Section 9.2.2 - Component Cooling Water System (CCWS)

- 420 cubic feet CCWS surge tank is shared between two CCWS trains
- Total of two CCWS surge tanks per unit
- No automatic valve isolation is provided to separate the two CCWS trains
- CCWS surge tank has 7 days of water volume (no safety related makeup required)
- CCWS is a moderate-energy system (Table 3.6-1), operating < 200 F and < 275 psig.
- **Open Item x (RAI 878-6200, Question 09.02.02-85)** – Provide details on how the CCWS is designed against postulated piping leak paths since a leak in the common CCWS pump discharge header has a potential to drain the common CCWS surge tank, affects two CCWS trains
- Staff received MHI RAI response on March 5, 2012 – response is under staff's evaluation

Technical Topics

Section 9.2.6 - Condensate Storage Facilities

- **Key Design Features**

- ♦ The CSF supplies/receives condensate as required by the condenser hotwell.
- ♦ The CSF has no safety-related functions, EFWS draws water from EFW pits.
- ♦ The CST is a 750,000 gallon non-seismic tank which uses a non-seismic dike to mitigate the environmental effects of system leakage or storage tank failure.

- **CSF Safety Evaluation Review**

- ♦ Staff reviewed design against SRP 9.2.6, and found GDC 2 and GDC 60 to be applicable to US-APWR design. (DCD Table 1.9.2 shows SRP 9.2.6 as N/A)
- ♦ SRP 9.2.6 Section III.3.E - (1) Outdoor storage tank designed in compliance with GDC 60 and Reg Guide 1.143. (2) For a non-safety-related storage facility, the need for a seismic Category 1 dike or retention basin is reviewed.

- **Open Item 9.2.6-3 – (RAI 9.2.6.3)**

- ♦ Request that the applicant provide justification for use of a non-seismic dike. Specifically the applicant is asked to discuss how the CSF design complies with GDC 2, and 60, since failure of the tank and dike could result in the release of the condensate to the environment and potential flooding.

Technical Topics

Section 9.4.1 and 9.4.5 – Control Room Area Ventilation System and Engineered Safety Feature Ventilation System

- **Regulation:** CFR 50.63 and GDC 4
- **Concern:** Staff seeks to maintain temperatures within design limits in areas served by the MCR HVAC system (Q 09.04.01-30) and by the ESF HVAC subsystems (Q 09.04.05-22) following SBO. Assurance is provided by establishing an AAC power source to these systems within 60 minutes of SBO onset.
- **Open Items:** DCD section 9.4.1; RAI 883-6063, Question 09.04.01-30 and DCD section 9.4.5; RAI 825-5999, Question 09.04.05-22. DCD Revision 3 test criteria of DCD section 14.2.12.1.46 “Alternate AC Power Sources for Station Black Out Preoperational Test” needs further clarification to ensure it meets the intent of RG 1.155.

Technical Topics

Section 9.4.1 – Control Room Area Ventilation System


- **Regulation:** GDC 2 and GDC 4
- **Concern:** Staff could not conclude that a internal leak within the MCR AHUs, should it occur, would not present a threat to the instrumentation and controls located in the Main Control Room below via the common HVAC duct lines (i.e. supply and return). Non safety related equipment drains route normal condensate out of the AHUs.
- **Open Item:** DCD section 9.4.1, RAI 883-6063, Q 09.04.01-32. The essential chilled water system supplies cooling water to these AHUs and is a moderate energy system. The MCR AHUs are safety-related, equipment class 3, seismic category I components. Applicant in process of formulating a response.

Figure 9.4.1-1

(back-up slide)

9. AUXILIARY SYSTEMS

US-APWF



- NOTES**
1. The air sampling lines to the radiacon monitors are isolation valves.
 2. The instruments that provide the CRE boundary integrity control instrument tubing is seismic category 1 only to maintain boundary integrity.

Figure 9.4.1-1 MCR HVAC System Flow Diagram

9.1.3 Spent Fuel Pit Cooling and Purification System (SFPCS)



➤ SFP water level

		Type	Set point	Interlock
DCD Rev.3	Non-safety x 2	Continuous	High	-
			Low	-
			Low-Low (*)	Pump stop
RAI 756-5753	Non-Safety x 1	Continuous	High	-
			Low	-
	Safety x 2	Level switch	Low-Low (*)	Pump stop
Open item RAI No. 735-5723	Non-Safety x 1	Continuous	High	-
			Low	-
	Safety x 2	Level switch	Low-Low (*)	Pump stop, non-seismic isolation

() Low-Low setpoint is above pump suction piping with adequate length to prevent vortex formation*

9.1.3 Spent Fuel Pit Cooling and Purification System (SFPCS)



➤ SFP temperature

		Type	Set point	Interlock
DCD Rev.3	Non-safety x 1	Continuous	High	-
RAI 756-5753	Safety x 2	Continuous	High	-

DCD Section 9.2.5.1 Design Bases

The UHS is designed with inventory sufficient to provide cooling for at least 30 days **(or at least 36 days for cooling pond in accordance with Regulatory Guide 1.27)** following an accident, with no makeup water.

RG 1.27 - 30 days supply
36 days period of time
(meteorological conditions) for spray
ponds

DCD_09.02.
02-49
DCD_09.02.
02-51




Figure 2.7.3.3-1 Component Cooling Water System (Sheet 1 of 2)

SECY-77-439

D. Passive Failure in a Fluid System

A passive failure in a fluid system means a breach in the fluid pressure boundary or a mechanical failure which adversely affects a flow path.

Examples include the failure of a simple check valve to move to its correct position when required, the leakage of fluid from failed components, such as pipes and valves-- particularly through a failed seal at a valve or pump-- or line blockage. Motor-operated valves which have the source of power locked out are allowed to be treated as passive components.

In the study of passive failures it is current practice to assume fluid leakage owing to gross failure of a pump or valve seal during the long term cooling mode following a LOCA (24 hours or greater after the event) but not pipe breaks.