

3RD FLOOR

FNR Decommissioning

SURVEY NO.: 2010-0113

LOCATION: POOL FLOOR

DATE: 10-05-10 TIME 1030


WEEK ENDING N/A



Instrument	Serial Number	Cal. Due Date	Efficiency	Background (CPM)	MDA (DPM)
2221/44-142	21857/172216714	31 Aug 2011	10%	324 (Ave)	Lc = 38/cpm gross
Kenneles Series 5	2161	30 July 2011	7.87a/24.51B	42/1.0B	11.46a/14.64B
N					
A					
Frisker Detector HV = 1150 Vdc		Threshold Voltage = 35 mVdc		Detector cable length = 6 ft.	

SMEAR RESULTS IN dpm/100cm²

No.	Beta/Gamma	Alpha
1	<MDA	<MDA
2	↓	↓
3		
4		
5		
6		
7		
8		
9	<MDA	<MDA
10	N	A
11		
12		
13		
14		
15		
16		
17		
18		
19		
20		



Third Floor

Legend: * Contact; ## Contact / 12" Reading or General Area; #-General Area; ① = Smear location;

Print/Signature of Surveyor: Jerry Shindel

Date: 11/2/2010

Comments: Initial scan of Rm 3104. Scan of concrete wall up to 2 meters was all < Lc. Smears coated on 11-2-10. Batch Key # 1130.

Reviewed By: Mark H. D. ...

Date: 05/13/11

Sample Report

Batch ID: Smears - 201011020802
Group: B
Device:
Batch Key: 1130

Count Date: 11/2/2010 8:02:05AM
Count Minutes: 3.00
Count Mode: Simultaneous
Operating Volts: 1410

Selected Geometry Swipe/Smear

Efficiency (%)

Alpha: 7.87 ± 0.07
Beta: 24.51 ± 0.15

<u>Sample ID</u>	<u>Sample Type</u>	<u>Alpha (dpm)</u>	<u>Unc</u>	<u>Alpha MDA (dpm)</u>	<u>Beta (dpm)</u>	<u>Unc</u>	<u>Beta MDA (dpm)</u>
Unloaded Swipe	LCS	4.24	4.24	11.46	-2.72	2.72	14.64
Tc-99 Eberline Standard	LCS	21.18	9.47	11.46	10543.23	136.78	14.64
Th-230 Eberline Standard	Unknown	30092.42	448.30	11.46	2193.22	56.41	14.64
Unloaded Swipe	LCS	4.24	4.24	11.46	-1.36	3.04	14.64
20101102081706-B1	Unknown	4.24	4.24	11.46	8.16	4.71	14.64
20101102082026-B2	Unknown	8.47	5.99	11.46	1.36	3.60	14.64
20101102082336-B3	Unknown	0.00	0.00	11.46	4.08	4.08	14.64
20101102082656-B4	Unknown	4.24	4.24	11.46	1.36	3.60	14.64
20101102083016-B5	Unknown	0.00	0.00	11.46	1.36	3.60	14.64
20101102083326-B6	Unknown	0.00	0.00	11.46	0.00	3.33	14.64
20101102083646-B7	Unknown	4.24	4.24	11.46	0.00	3.33	14.64
20101102084006-B8	Unknown	0.00	0.00	11.46	5.44	4.30	14.64
20101102084316-B9	Unknown	0.00	0.00	11.46	2.72	3.85	14.64
20101102084636-B10	Unknown	0.00	0.00	11.46	0.00	3.33	14.64
20101102084956-B11	Unknown	0.00	0.00	11.46	-2.72	2.72	14.64
20101102085316-B12	Unknown	<u>12.71</u>	7.34	11.46	2.72	3.85	14.64
20101102085626-B13	Unknown	0.00	0.00	11.46	0.00	3.33	14.64
20101102085946-B104	Unknown	0.00	0.00	11.46	4.08	4.08	14.64
Unloaded Swipe	Background	Alpha (cpm): 0.00		Beta (cpm): 1.00			
Unloaded Swipe	LCS	4.24	4.24	11.46	-2.72	2.72	14.64

*Recounted
 on
 1/32
 2nd
 11-2-10
 [Signature]*

Reviewed by: _____

[Signature]

Background Report

Batch ID: Smears - 201011020802
Group: B
Device:
Batch Key: 1130

Count Date: 11/2/2010 8:02:05AM
Count Minutes: 3.00
Count Mode: Simultaneous
Operating Volts: 1410

Selected Geometry Swipe/Smear

Background (cpm)


Alpha Rate: 0.00 ± 0.00

Beta Rate: 1.00 ± 0.58

Sample ID	Alpha (cpm)	Unc	Beta (cpm)	Unc	Guard (cpm)
20101102080205-B147	0.33	0.33	0.33	0.33	198.00
20101102080716-B149	1.67	0.75	2,585.67	29.36	202.00
20101102081026-B150	2,368.33	28.10	538.67	13.40	206.33
20101102081346-B140	0.33	0.33	0.67	0.47	198.00
20101102081706-B1	0.33	0.33	3.00	1.00	209.33
20101102082026-B2	0.67	0.47	1.33	0.67	204.67
20101102082336-B3	0.00	0.00	2.00	0.82	192.67
20101102082656-B4	0.33	0.33	1.33	0.67	214.00
20101102083016-B5	0.00	0.00	1.33	0.67	204.67
20101102083326-B6	0.00	0.00	1.00	0.58	196.67
20101102083646-B7	0.33	0.33	1.00	0.58	206.00
20101102084006-B8	0.00	0.00	2.33	0.88	210.33
20101102084316-B9	0.00	0.00	1.67	0.75	204.33
20101102084636-B10	0.00	0.00	1.00	0.58	200.00
20101102084956-B11	0.00	0.00	0.33	0.33	203.67
20101102085316-B12	1.00	0.58	1.67	0.75	194.67
20101102085626-B13	0.00	0.00	1.00	0.58	196.33
20101102085946-B104	0.00	0.00	2.00	0.82	199.00
20101102090306-B15	0.00	0.00	1.00	0.58	210.33
20101102090616-B141	0.33	0.33	0.33	0.33	189.67

Guard Avg Rate: 202.03

Reviewed by: _____



Procedure: Smears

Is Active

Count Mode

Alpha Alpha then Beta

Simultaneous

Discriminator Selection
Alpha/Beta ROI:

Tc-99 3.5% 0.8%

Beta Lower: 0.25 Beta Upper: 27.80 Alpha Lower: 53.70

Presets:

Count Time: 3 minutes

Alpha: 0 counts

Beta: 0 counts

New

Preselected Report: >>

Preselected Group & Device:

None None

Sample Count Delay

0.1 minutes (0 to 9,999 minutes)

Count Repetitions

Sample: 1 (1 - 99)

Batch: 1 (1 - 10)

Weak Sample Reject

Disable Enable

Initial Test Time:

Min Count Rate:

Save As

Reporting Units: dpm

Background Subtraction

Disable Enable

Previous Stored Method Blank

Spillover Correction

Disable Enable

Sample Activity

Disable Enable

Alpha Cal. Standard: Am-241 G2-188

Beta Cal. Standard: Tc-99 G2-189 47

Geometry Selection


Geometry: Swipe/Smear

Print

Key 1130

Rm 3104

11-12-10



FNR Decommissioning

SURVEY NO.: 2010-0114 LOCATION: POOL FLOOR ②


DATE: 10-6-10 TIME 0815 WEEK ENDING NA

Instrument	Serial Number	Cal. Due Date	Efficiency	Background (CPM)	MDA (DPM)
<u>2021/44-142</u>	<u>21857/PA240714</u>	<u>31 Aug 2011</u>	<u>10%</u>	<u>346 (Ave)</u>	<u>Lc = 403 cpm gross</u>
<u>Temple Series 5</u>	<u>2161</u>	<u>30 July 2011</u>	<u>7.87%/24.513</u>	<u>8-1.013</u>	<u>11.46%/14.6413</u>

Frisker Detector HV = <u>1250 Vdc</u>		Threshold Voltage = <u>35 mVdc</u>		Detector cable length = <u>20 ft.</u>	

SMEAR RESULTS IN dpm/100cm²

No.	Beta/Gamma	Alpha
1	<mda	<mda
2	↓	↓
3	↓	↓
4	↓	↓
5	↓	↓
6	↓	↓
7	↓	↓
8	↓	↓
9	<mda	<mda
10	↓	↓
11	↓	↓
12	↓	↓
13	↓	↓
14	↓	↓
15	NA	NA
16	↓	↓
17	↓	↓
18	↓	↓
19	↓	↓
20	↓	↓



Third Floor

Legend: * Contact; ## Contact / 12" Reading or General Area; #=General Area; ① = Smear location;

Print/Signature of Surveyor: Jerry Shinek / Jerry Katz Date: 11/2/2010

Comments: Initial scan concrete wall above 2 meters. All was <Lc.
BKG taken from a (3) location average on the concrete wall. For the smears,
I had combined the upper & lower wall on one smear survey. Background @ 1130.

Reviewed By: Munir Hussain Date: 05/13/11

FNR Decommissioning


SURVEY NO.: 2010-0115 LOCATION: POOL FLOOR
 DATE: 10-6-10 TIME 1515 WEEK ENDING N/A

Instrument	Serial Number	Cal. Due Date	Efficiency	Background (CPM)	MDA (DPM)
222/44-42	218579/p1240714	31 Aug 2011	10%	See Below	See Below
Tenneco Series 5	2161	30 July 2011	7.87%/24514	0.2/1.0 B	1146/1464 B

Frisker Detector HV = 1250 Vdc		Threshold Voltage = 35 mVdc		Detector cable length = 20 ft.	

SMEAR RESULTS IN dpm/100cm²

No.	Beta/Gamma	Alpha
1		
2		
3		
4	N	A
5		
6		
7		
8		
9		
10	<MDA	<MDA
11	↓	↓
12		
13	↓	↓
14	<MDA	<MDA
15		
16		
17	N	A
18		
19		
20		



Third Floor

Legend: * Contact; ## Contact / 12" Reading or General Area; #=General Area; ⊙ = Smear location;

Print/Signature of Surveyor: Jerry Shimels/Jerry White Date: 11/2/2010

Comments: Initial scan cinder blocks in Rm 3104. Some block is unpainted, thus I calculated (2) Lc values. Cinder block areas were <Lc in respective areas. Smears counted on 11-2-10, Batchkey # 1130.

Reviewed By: Mark H. Darnell Date: 05/13/11

FNR Decommissioning


SURVEY NO.: 2011-0043 LOCATION: POOL FLOOR

DATE: 5-17-2011 TIME 0815 WEEK ENDING P/A

Instrument	Serial Number	Cal. Due Date	Efficiency	Background (CPM)	MDA (DPM)
2221/43-37	218578/177474	9-22-11/12-23-11	10%	See Below	See Below
2221/44-142	234928/192216233	10-01-2011	10%	448 (Ave)	Lc = 514 cpm gross
Tennelec Series 5	2161	30 July 2011	7.87% / 24.51%	See Batch Report	See Batch Report
Frisker Detector HV = 1700 Vdc		Threshold Voltage = 20 mVdc		Detector cable length = 6 ft. A-43-37	

SMEAR RESULTS IN dpm/100cm²

No.	Beta/Gamma	Alpha
1	<MDA	<MDA
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		
16		
17		
18		
19		
20	<MDA	<MDA



Legend: * Contact; ## Contact / 12" Reading or General Area; # = General Area; ① = Smear location;

Print/Signature of Surveyor: Terry Shinkel / Jerry Shindel Date: 5/23/2011

Comments: Survey Floor of Rm 3103, 3104, and general walk way with floor scanned. I did a separate Lc for each area using (3) random spots for BKG's in each area. All scanned floor was < Lc, except for a hatch cover which will be decontaminated latter. Smears on Batch Kw #s. 1590, 1592, 1595, 1598, 1605. Smear #45 was 21 dpm/100cm².

Reviewed By: Mark J. Dineen Date: 05/06/11

Sample Report

Batch ID: Smears - 201105191423
Group: A
Device:
Batch Key: 1598

Count Date: 5/19/2011 2:23:07PM
Count Minutes: 3.00
Count Mode: Simultaneous
Operating Volts: 1410

Selected Geometry Swipe/Smear

Efficiency (%)

Alpha: 7.87 ± 0.07
Beta: 24.51 ± 0.15

Sample ID	Sample Type	Alpha (dpm)	Unc	Alpha MDA (dpm)	Beta (dpm)	Unc	Beta MDA (dpm)
Inloaded Swipe	LCS	0.00	0.00	11.46	-4.08	3.60	17.83
Tc-99 Ebelrne Standard	LCS	4.24	4.24	11.46	10487.48	136.36	17.83
Th-230 Ebelrne Standard	LCS	30422.78	451.65	11.46	2126.59	55.56	17.83
Inloaded Swipe	LCS	0.00	0.00	11.46	-2.72	3.85	17.83
20110519143818-A1	Unknown	4.24	4.24	11.46	4.08	4.90	17.83
20110519144138-A2	Unknown	4.24	4.24	11.46	-4.08	3.60	17.83
20110519144448-A3	Unknown	4.24	4.24	11.46	-2.72	3.85	17.83
20110519144808-A4	Unknown	<u>16.94</u>	8.47	11.46	-5.44	3.33	17.83
20110519145128-A5	Unknown	8.47	5.99	11.46	5.44	5.09	17.83
20110519145448-A6	Unknown	0.00	0.00	11.46	-1.36	4.08	17.83
20110519145759-A7	Unknown	0.00	0.00	11.46	-4.08	3.60	17.83
20110519150119-A8	Unknown	<u>12.71</u>	7.34	11.46	5.44	5.09	17.83
20110519150439-A9	Unknown	4.24	4.24	11.46	2.72	4.71	17.83
20110519150749-A10	Unknown	<u>12.71</u>	7.34	11.46	0.00	4.30	17.83
20110519151109-A11	Unknown	4.24	4.24	11.46	1.36	4.51	17.83
20110519151429-A12	Unknown	4.24	4.24	11.46	2.72	4.71	17.83
20110519151749-A13	Unknown	0.00	0.00	11.46	-2.72	3.85	17.83
20110519152059-A14	Unknown	8.47	5.99	11.46	0.00	4.30	17.83
20110519152419-A15	Unknown	0.00	0.00	11.46	10.88	5.77	17.83
20110519152739-A16	Unknown	4.24	4.24	11.46	9.52	5.61	17.83
20110519153049-A17	Unknown	0.00	0.00	11.46	-1.36	4.08	17.83
20110519153410-A18	Unknown	0.00	0.00	11.46	1.36	4.51	17.83
20110519153729-A19	Unknown	4.24	4.24	11.46	5.44	5.09	17.83
20110519154049-A20	Unknown	0.00	0.00	11.46	-1.36	4.08	17.83
20110519154359-A61	Unknown	8.47	5.99	11.46	0.00	4.30	17.83
20110519154719-A22	Unknown	4.24	4.24	11.46	9.52	5.61	17.83
20110519155039-A23	Unknown	0.00	0.00	11.46	13.60	6.08	17.83
20110519155349-A24	Unknown	4.24	4.24	11.46	6.80	5.27	17.83
20110519155710-A25	Unknown	4.24	4.24	11.46	<u>20.40</u>	6.80	17.83
20110519160030-A26	Unknown	4.24	4.24	11.46	6.80	5.27	17.83
20110519160350-A27	Unknown	4.24	4.24	11.46	1.36	4.51	17.83
20110519160700-A28	Unknown	8.47	5.99	11.46	4.08	4.90	17.83
20110519161020-A29	Unknown	0.00	0.00	11.46	6.80	5.27	17.83
20110519161340-A30	Unknown	0.00	0.00	11.46	<u>20.40</u>	6.80	17.83
20110519161650-A4	Unknown	0.00	0.00	11.46	12.24	5.93	17.83
20110519162010-A8	Unknown	4.24	4.24	11.46	5.44	5.09	17.83
20110519162330-A10	Unknown	0.00	0.00	11.46	8.16	5.44	17.83
Inloaded Swipe	Background	Alpha (cpm): 0.00		Beta (cpm): 1.67			

recount sat 5-23-11
recount sat 5-23-11
recount sat 5-23-11
recount SAT 5-24-11 Key 1605
recounts 5-24-11
recount SAT 5-24-11 Key 1605

location #45
recounts #s 21-50 5-23-11

MHS 08/06/11

Batch ID: Smears - 201105191423

Count Date: 5/19/2011 2:23:07PM

Group: A

Count Minutes: 3.00

Device:

Count Mode: Simultaneous

Batch Key: 1598

Operating Volts: 1410

Selected Geometry Swipe/Smear

Efficiency (%)

Alpha: 7.87 ± 0.07

Beta: 24.51 ± 0.15

<u>Sample ID</u>	<u>Sample Type</u>	<u>Alpha</u> <u>(dpm)</u>	<u>Unc</u>	<u>Alpha MDA</u> <u>(dpm)</u>	<u>Beta</u> <u>(dpm)</u>	<u>Unc</u>	<u>Beta MDA</u> <u>(dpm)</u>
------------------	--------------------	------------------------------	------------	----------------------------------	-----------------------------	------------	---------------------------------

Reviewed by: _____

Mark H. Duvall

Background Report

Batch ID: Smears - 201105191423
Group: A
Device:
Batch Key: 1598
Selected Geometry Swipe/Smear

Count Date: 5/19/2011 2:23:07PM
Count Minutes: 3.00
Count Mode: Simultaneous
Operating Volts: 1410

Background (cpm)

Alpha Rate: 0.00 ± 0.00

Beta Rate: 1.67 ± 0.75

Sample ID	Alpha (cpm)	Unc	Beta (cpm)	Unc	Guard (cpm)
20110519142307-A146	0.00	0.00	0.67	0.47	200.33
20110519142828-A149	0.33	0.33	2,572.67	29.28	198.00
20110519143148-A150	2,394.33	28.25	523.00	13.20	206.67
20110519143458-A142	0.00	0.00	1.00	0.58	200.67
20110519143818-A1	0.33	0.33	2.67	0.94	198.67
20110519144138-A2	0.33	0.33	0.67	0.47	182.33
20110519144448-A3	0.33	0.33	1.00	0.58	203.00
20110519144808-A4	1.33	0.67	0.33	0.33	200.33
20110519145128-A5	0.67	0.47	3.00	1.00	207.00
20110519145448-A6	0.00	0.00	1.33	0.67	197.67
20110519145759-A7	0.00	0.00	0.67	0.47	201.33
20110519150119-A8	1.00	0.58	3.00	1.00	183.00
20110519150439-A9	0.33	0.33	2.33	0.88	197.33
20110519150749-A10	1.00	0.58	1.67	0.75	203.33
20110519151109-A11	0.33	0.33	2.00	0.82	190.00
20110519151429-A12	0.33	0.33	2.33	0.88	213.67
20110519151749-A13	0.00	0.00	1.00	0.58	202.67
20110519152059-A14	0.67	0.47	1.67	0.75	195.00
20110519152419-A15	0.00	0.00	4.33	1.20	208.00
20110519152739-A16	0.33	0.33	4.00	1.15	207.67
20110519153049-A17	0.00	0.00	1.33	0.67	178.00
20110519153410-A18	0.00	0.00	2.00	0.82	198.00
20110519153729-A19	0.33	0.33	3.00	1.00	209.67
20110519154049-A20	0.00	0.00	1.33	0.67	194.67
20110519154359-A61	0.67	0.47	1.67	0.75	184.33
20110519154719-A22	0.33	0.33	4.00	1.15	213.67
20110519155039-A23	0.00	0.00	5.00	1.29	202.00
20110519155349-A24	0.33	0.33	3.33	1.05	190.33
20110519155710-A25	0.33	0.33	6.67	1.49	204.00
20110519160030-A26	0.33	0.33	3.33	1.05	191.33
20110519160350-A27	0.33	0.33	2.00	0.82	200.00
20110519160700-A28	0.67	0.47	2.67	0.94	201.33
20110519161020-A29	0.00	0.00	3.33	1.05	194.33
20110519161340-A30	0.00	0.00	6.67	1.49	207.00
20110519161650-A4	0.00	0.00	4.67	1.25	210.00
20110519162010-A8	0.33	0.33	3.00	1.00	211.33
20110519162330-A10	0.00	0.00	3.67	1.11	198.67
20110519162650-A147	0.00	0.00	1.67	0.75	199.33

MZD

Guard Avg Rate: 199.60

Reviewed by: _____

Mark H. Dinicola

Sample Report

Batch ID: Smears - 201105231254
Group: A
Device:
Batch Key: 1605
Selected Geometry: Swipe/Smear

Count Date: 5/23/2011 12:54:32PM
Count Minutes: 3.00
Count Mode: Simultaneous
Operating Volts: 1410

Efficiency (%)

Alpha: 7.87 ± 0.07
Beta: 24.51 ± 0.15

Sample ID	Sample Type	Alpha (dpm)	Unc	Alpha MDA (dpm)	Beta (dpm)	Unc	Beta MDA (dpm)
Unloaded Swipe	Background	Alpha (cpm): 0.00		Beta (cpm): 1.00			
Tc-99 Eberline Standard	LCS	4.24	4.24	11.46	10328.39	135.05	14.64
Th-230 Eberline Standard	LCS	31295.27	460.50	11.46	2098.04	55.10	14.64
Unloaded Swipe	LCS	0.00	0.00	11.46	-1.36	3.04	14.64
20110523130942-A4	Unknown	0.00	0.00	11.46	4.08	4.08	14.64
20110523131302-A12	Unknown	0.00	0.00	11.46	14.96	5.61	14.64
20110523131622-A61	Unknown	0.00	0.00	11.46	0.00	3.33	14.64
20110523131932-A25	Unknown	16.94	8.47	11.46	31.27	7.32	14.64
20110523132252-A30	Unknown	8.47	5.99	11.46	12.24	5.27	14.64
Unloaded Swipe	LCS	0.00	0.00	11.46	-1.36	3.04	14.64

A25 (2)

GOOD RECORD EFFORT?

A25 was <MDA on key 1598, and less than a contaminated area limit for alpha on key 1605, so I had to decon the area anyway with the beta being >MDA.

JF-8-11

Reviewed by:

Mark L. Driscoll

Procedure: Smear

Is Active

Count Mode

Alpha Alpha then Beta

Simultaneous

Discriminator Selection
Alpha/Beta ROI:

Tc-99 3.5% 0.8%

Beta Lower: 0.25 Beta Upper: 27.80 Alpha Lower: 53.70

Presets:

Count Time: 3 minutes

Alpha: 0 counts

Beta: 0 counts

New

Preselected Report: >>

Reporting Units: dpm

Preselected Group & Device:

None None

Sample Count Delay

0.1 minutes (0 to 9,999 minutes)

Count Repetitions

Sample: 1 (1 - 99)

Batch: 1 (1 - 10)

Weak Sample Reject

Disable Enable

Initial Test Time:

Min Count Rate:

Background Subtraction

Disable Enable

Previous Stored Method Blank

Spillover Correction

Disable Enable

Sample Activity

Disable Enable

Alpha Cal. Standard: Am-241 G2-188

Beta Cal. Standard: Tc-99 G2-189 47

Geometry Selection

Geometry: Swipe/Smear

3

Save As

Print

Key 1598
3rd Floor
GA
5-18-11

Sample Report

Batch ID: Smears - 201105171328
Group: I
Device:
Batch Key: 1590
Selected Geometry Swipe/Smear

Count Date: 5/17/2011 1:28:10PM
Count Minutes: 3.00
Count Mode: Simultaneous
Operating Volts: 1410

Efficiency (%)

Alpha: 7.87 ± 0.07
Beta: 24.51 ± 0.15

Sample ID	Sample Type	Alpha (dpm)	Unc	Alpha MDA (dpm)	Beta (dpm)	Unc	Beta MDA (dpm)
Unloaded Swipe	LCS	0.00	0.00	11.46	1.36	4.08	16.33
Tc-99 Eberline Standard	LCS	29.65	11.21	11.46	10157.07	133.69	16.33
Th-230 Eberline Standard	LCS	30499.02	452.43	11.46	2104.84	55.23	16.33
Unloaded Swipe	LCS	12.71	7.34	11.46	1.36	4.08	16.33
20110517134331-I101	Unknown	<u>16.94</u>	8.47	11.46	5.44	4.71	16.33
20110517134641-I102	Unknown	4.24	4.24	11.46	2.72	4.30	16.33
20110517135001-I103	Unknown	8.47	5.99	11.46	5.44	4.71	16.33
20110517135321-I104	Unknown	8.47	5.99	11.46	10.88	5.44	16.33
20110517135631-I105	Unknown	4.24	4.24	11.46	5.44	4.71	16.33
20110517135951-I106	Unknown	4.24	4.24	11.46	5.44	4.71	16.33
20110517140311-I107	Unknown	4.24	4.24	11.46	1.36	4.08	16.33
20110517140631-I108	Unknown	0.00	0.00	11.46	0.00	3.85	16.33
20110517140941-I109	Unknown	4.24	4.24	11.46	0.00	3.85	16.33
20110517141301-I10	Unknown	0.00	0.00	11.46	6.80	4.90	16.33
Unloaded Swipe	Background	Alpha (cpm): 0.00		Beta (cpm): 1.33			

*return SAT Key 1592
B 5-18-11*

*#1
S 1-10
B 5-17-11*

Rm 3104

Reviewed by: Mark J. Dineen

Background Report

Batch ID: Smears - 201105171328

Count Date: 5/17/2011 1:28:10PM

Group: 1

Count Minutes: 3.00

Device:

Count Mode: Simultaneous

Batch Key: 1590

Operating Volts: 1410

Selected Geometry Swipe/Smear

Background (cpm)


Alpha Rate: 0.00 ± 0.00

Beta Rate: 1.33 ± 0.67

Sample ID	Alpha (cpm)	Unc	Beta (cpm)	Unc	Guard (cpm)
20110517132810-I142	0.00	0.00	1.67	0.75	201.67
20110517133331-I149	2.33	0.88	2,491.33	28.82	208.67
20110517133651-I150	2,400.33	28.29	517.33	13.13	199.00
20110517134011-I146	1.00	0.58	1.67	0.75	206.33
20110517134331-I101	1.33	0.67	2.67	0.94	197.00
20110517134641-I102	0.33	0.33	2.00	0.82	207.33
20110517135001-I103	0.67	0.47	2.67	0.94	192.67
20110517135321-I104	0.67	0.47	4.00	1.15	199.33
20110517135631-I105	0.33	0.33	2.67	0.94	196.00
20110517135951-I106	0.33	0.33	2.67	0.94	207.67
20110517140311-I107	0.33	0.33	1.67	0.75	205.00
20110517140631-I108	0.00	0.00	1.33	0.67	201.67
20110517140941-I109	0.33	0.33	1.33	0.67	199.67
20110517141301-I10	0.00	0.00	3.00	1.00	226.67
20110517141621-I143	0.00	0.00	1.33	0.67	190.00

Guard Avg Rate: 202.58

Reviewed by:



Sample Report

Batch ID: Smears - 201105171704
Group: C
Device:
Batch Key: 1592
Selected Geometry Swipe/Smear

Count Date: 5/17/2011 5:04:02PM
Count Minutes: 3.00
Count Mode: Simultaneous
Operating Volts: 1410

Efficiency (%)

Alpha: 7.87 ± 0.07
Beta: 24.51 ± 0.15

<u>Sample ID</u>	<u>Sample Type</u>	<u>Alpha</u> <u>(dpm)</u>	<u>Unc</u>	<u>Alpha MDA</u> <u>(dpm)</u>	<u>Beta</u> <u>(dpm)</u>	<u>Unc</u>	<u>Beta MDA</u> <u>(dpm)</u>
Jnloaded Swipe	LCS	4.24	4.24	11.46	2.72	4.30	16.33
Jnloaded Swipe	LCS	4.24	4.24	11.46	2.72	4.30	16.33
Tc-99 Eberline Standard	LCS	8.47	5.99	11.46	10231.85	134.29	16.33
Th-230 Eberline Standard	LCS	30837.85	455.87	11.46	2074.92	54.82	16.33
Jnloaded Swipe	LCS	4.24	4.24	11.46	-1.36	3.60	16.33
20110517172243-C1	Unknown	0.00	0.00	11.46	2.72	4.30	16.33
20110517172603-C16	Unknown	4.24	4.24	11.46	8.16	5.09	16.33
20110517172913-C101	Unknown	8.47	5.99	11.46	4.08	4.51	16.33
Unloaded Swipe	Background	Alpha (cpm): 0.00		Beta (cpm): 1.33			

*return from
 Key 1590
 5/18/11*

GOOD RECOUNT EFFORT !

*MJD
 08/06/11*

Reviewed by: Mark H. Donnell

Procedure: Smears

Is Active

Count Mode

Alpha Alpha then Beta

Simultaneous

Discriminator Selection
Alpha/Beta ROI:

Tc-99 3.5% 0.8%

Beta Lower:	Beta Upper:	Alpha Lower:
0.25	27.80	53.70

Presets:

Count Time:	3	minutes
Alpha:	0	counts
Beta:	0	counts

New

Preselected Report:

Preselected Group & Device:

None None

Sample Count Delay:

0.1 minutes (0 to 9,999 minutes)

Count Repetitions

Sample: 1 (1 - 99)

Batch: 1 (1 - 10)

Weak Sample Reject

Disable Enable

Initial Test Time:

Min Count Rate:

Save As

Reporting Units: dpm

Background Subtraction

Disable Enable

Previous Stored Method Blank

Spillover Correction

Disable Enable

Sample Activity

Disable Enable

Alpha Cal. Standard: Am-241 G2-188

Beta Cal. Standard: Tc-99 G2-189 47

Geometry Selection

Geometry: Swipe/Smear

Print

Key 1590

RM 3104

5-17-11

Sample Report

Batch ID: Smears - 201105181424
Group: C
Device:
Batch Key: 1595
Selected Geometry Swipe/Smear

Count Date: 5/18/2011 2:24:23PM
Count Minutes: 3.00
Count Mode: Simultaneous
Operating Volts: 1410

Efficiency (%)

Alpha: 7.87 ± 0.07
Beta: 24.51 ± 0.15

<u>Sample ID</u>	<u>Sample Type</u>	<u>Alpha</u> <u>(dpm)</u>	<u>Unc</u>	<u>Alpha MDA</u> <u>(dpm)</u>	<u>Beta</u> <u>(dpm)</u>	<u>Unc</u>	<u>Beta MDA</u> <u>(dpm)</u>
Jnloaded Swipe	LCS	0.00	0.00	11.46	-2.72	2.72	14.64
Tc-99 Eberline Standard	LCS	12.71	7.34	11.46	10356.95	135.28	14.64
Th-230 Eberline Standard	LCS	31295.27	460.50	11.46	2145.63	55.76	14.64
Jnloaded Swipe	LCS	0.00	0.00	11.46	-1.36	3.04	14.64
20110518143944-C1	Unknown	8.47	5.99	11.46	1.36	3.60	14.64
20110518144304-C2	Unknown	8.47	5.99	11.46	1.36	3.60	14.64
20110518144624-C3	Unknown	4.24	4.24	11.46	2.72	3.85	14.64
20110518144934-C4	Unknown	0.00	0.00	11.46	4.08	4.08	14.64
20110518145254-C5	Unknown	0.00	0.00	11.46	6.80	4.51	14.64
20110518145614-C6	Unknown	0.00	0.00	11.46	5.44	4.30	14.64
20110518145934-C7	Unknown	0.00	0.00	11.46	0.00	3.33	14.64
20110518150244-C8	Unknown	8.47	5.99	11.46	-2.72	2.72	14.64
20110518150604-C9	Unknown	4.24	4.24	11.46	1.36	3.60	14.64
20110518150924-C10	Unknown	0.00	0.00	11.46	0.00	3.33	14.64
Jnloaded Swipe	Background	Alpha (cpm): 0.00		Beta (cpm): 1.00			

#5 11-20
5-18-11

Rm 3103

Reviewed by: *Mary H. Dore*

Background Report

Batch ID: Smears - 201105181424

Count Date: 5/18/2011 2:24:23PM

Group: C

Count Minutes: 3.00

Device:

Count Mode: Simultaneous

Batch Key: 1595

Operating Volts: 1410

Selected Geometry Swipe/Smear

Background (cpm)

Alpha Rate: 0.00 ± 0.00

Beta Rate: 1.00 ± 0.58

Sample ID	Alpha (cpm)	Unc	Beta (cpm)	Unc	Guard (cpm)
20110518142423-C147	0.00	0.00	0.33	0.33	202.00
20110518142954-C149	1.00	0.58	2,540.00	29.10	198.33
20110518143314-C150	2,463.00	28.65	527.00	13.25	206.67
20110518143634-C142	0.00	0.00	0.67	0.47	202.33
20110518143944-C1	0.67	0.47	1.33	0.67	207.67
20110518144304-C2	0.67	0.47	1.33	0.67	214.67
20110518144624-C3	0.33	0.33	1.67	0.75	198.67
20110518144934-C4	0.00	0.00	2.00	0.82	195.33
20110518145254-C5	0.00	0.00	2.67	0.94	204.00
20110518145614-C6	0.00	0.00	2.33	0.88	219.67
20110518145934-C7	0.00	0.00	1.00	0.58	201.67
20110518150244-C8	0.67	0.47	0.33	0.33	190.33
20110518150604-C9	0.33	0.33	1.33	0.67	202.00
20110518150924-C10	0.00	0.00	1.00	0.58	191.67
20110518151234-C140	0.00	0.00	1.00	0.58	189.00

Guard Avg Rate: 201.60

Reviewed by:



Procedure:

Sint ars

Is Active

Count Mode

- Alpha
- Alpha then Beta
- Simultaneous

Discriminator Selection

Alpha/Beta ROI:

Tc-99 3.5% 0.8%

Beta Lower: Beta Upper: Alpha Lower:

0.25 27.80 53.70

Presets:

Count Time: 3 minutes

Alpha: 0 counts

Beta: 0 counts

New

Preselected Report:

>>

Reporting Units:

dpm

Preselected Group & Device:

None None

Sample Count Delay

0.1 minutes (0 to 9,999 minutes)

Count Repetitions

Sample: 1 (1 - 99)

Batch: 1 (1 - 10)

Weak Sample Reject

Disable Enable

Initial Test Time:

Min Count Rate:

Save As

Background Subtraction

- Disable
- Enable
- Previous Stored
- Method Blank

Spillover Correction

Disable Enable

Sample Activity

Disable Enable

Alpha Cal. Standard: Am-241 G2-188

Beta Cal. Standard: Tc-99 G2-189 47

Geometry Selection

Geometry: Swipe/Smear

Print

Key 1595
 Rm 3103
 Floor
 5-18-11
 74

Radiological Survey Report

DATE: 12-12-07 LOCATION: 3rd Floor Bridge SURVEY NO.: 2007-2478 TIME: 1715

Smear Information DRM/100 cm² Crane Survey Map

No.	Beta/Gamma	Alpha (20%)
1	78	<MDA
2	46 <MDA	
3	<MDA	
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		
16		
17		
18		
19		
20		

This is the Rx building bridge crane radiological survey results. The crane was wiped down with bathroom cleaner ("Scrubbing Bubbles"), "Scotch-Brite" pads and towels. The wipe down was performed from the decking along the west trolley rail and from a man-lift moved along the east side of the east trolley rail. All surfaces that could be reached from those two access path were wipe down. The areas not cleaned are obvious. The surfaces cleaned are free of all loose contamination. However, a uniform level of approximately 125 NCPM is trapped everywhere dried grease is located. (The grease will not come off with scrubbing bubbles.) All measurements are less than 25% DCGZ of 574 GCPM except for the main cable. It reads 580 GCPM.

Areas not wiped or surveyed:

- 1.) Bridge rail beds and rails.
- 2.) Windlass motor & cable drum.
- 3.) Under sides & between sides of trolley rail support beams.

Legend: * = Contact; # / # = Contact Reading / General Area; # = General Area. ⊙ = Smear location; Δ = Air Sample.
 Note: Readings in mrem/hr unless noted otherwise.

Instrument	Serial Number	Cal. Due Date	Efficiency	Background (CPM)	MDA (DPM)
L-2221-	234988	4/12/08	N/A		
44-142	246233	6/08	.41 (2π @ 1/4")	rd 24 254	N/A
L-2929	216263	8/23/08	β _γ = .27, α = .4	β _γ = 33, α = ∅	β _γ = 34, α = 3
N/A					
Frisker Detector HV = 1050 Vdc		Threshold Voltage = 10 mVdc		Detector cable length = 6 ft.	

Print/Signature of Surveyor: Ned Campbell Date: 12-12-07

Comments: _____

Review By: JS Smith Date: 12/14/07

FNR Decommissioning Project
Reconnaissance Level Scan Survey Form

Survey No: 2007-1946 Survey Unit: 3-3 Pkg. SP-007 Sheet 1 of 2
Date: 9-26-07 Survey Location: Rm 3103

I. Instrument Information

Inst. Set No.	Meter Model	Scaler Serial No.	Detector Model	Detector Serial No.	HV Setting (Vdc)	THR Setting (mVdc)	2π Inst. Eff.	Calibration Due Date
1	2221	187743	43-37	243924	1750	20	.346	1-12-08
2	2221	187743	43-37	243922	1750	20	.356	1-12-08
3	2221	218598	44-142	240716	1100	35		6-22-08
<i>W/A</i>	<i>n/a</i>	<i>n/a</i>	<i>n/a</i>	<i>n/a</i>	<i>n/a</i>	<i>n/a</i>	<i>n/a</i>	<i>n/a</i>

NOTE: All cables 6-ft RG-58 (LMI 44-142, 44-9, HP-210, or 44-92 probes) or 15-ft RG-58 (LMI 43-37 gas-flow hand-held) unless otherwise noted in the comments below.

Comments: *n/a*

Initial Performance Test Performed & Satisfactory: *J* 9-26-07
Initial / Date

II. Background Measurements

Inst. Set No.	Grid or Location	Count Time (min.)	Counts per Minute (cpm)
1	BKG 1	1	1280
1	BKG 2	1	1243
1	BKG 3	1	1453
2	# BKG 1	1	1142
2	# BKG 2	1	1187
2	# BKG 3	1	1183
1	AUG	<i>NA</i>	1325
2	AUG		1170
3	AUG		342
3	BKG 1	1	365
	BKG 2	1	314
3	BKG 3	1	347

III. Total Surface Activity Measurements

Inst. Set No.	Grid or Location	Count Time (min.)	Counts per Minute (cpm)

n/a

Each of the demarked grids (or locations) on the attached survey map has been scanned and do not exceed the action level of 1,750 dpm/100-cm², unless otherwise noted on the attached survey map.

Post-Survey Performance Test Performed & Satisfactory: *JKL* 9-26-07
Initial / Date

Survey Tech: *Ron McKeay* (print / sign) Date: 9-26-07


Reviewed By (Print/Sign): *Rock Neveau* (print / sign) Date: 10-3-07



Reconnaissance Level Scan Survey Map

Survey Area: Phase 1 Survey Unit: 3-3 Classification: 1
 Building: Ford Nuclear Reactor Room: 3103
 Survey Unit Description: A- Structure Interior Surface
 Surface Area: 121,9 sq. m 1 Grid = 1 meter
 FNRDP-DWG-03_flr

Survey Technician: *Robert G. G. [Signature]*
 Mark all grids and survey locations where scan surveys were performed.
 If scan survey measurement results in a count rate that exceeds the action level, number the grid and record the total surface activity on the corresponding survey form.



Map Legend

- Pipe Penetration
- Cinder Block Wall
- Concrete (formally tiled w/ mastic remanants)
- (P.C.) - Poured Concrete
- Opening
- Inaccessible Area
- 2 meter mark (from floor)

*Verified

Comments:

- denotes where Inst. set # 3 was used
- denotes where Inst. set # 2 was used
- denotes where Inst. set # ~~3~~¹ was used

100% of denoted areas scanned.

Action Levels (AL)

Inst. set # 1: 3107 g.cpm

Inst. set # 2: 2957 g.cpm

Inst. set # 3: 664 g.cpm

No scan surveys exceeded the stated Action levels.



Survey Technician: Robert C. Gley, SR

Mark all grids and survey locations where scan surveys were performed.

If scan survey measurement results in a count rate that exceeds the action level, number the grid and record the total surface activity on the corresponding survey form.

Reconnaissance Level Scan Survey Map

Survey Area: Phase 1 Survey Unit: 3-2 Classification: 2

Building: Ford Nuclear Reactor Room: 3102


Survey Unit Description: A- Structure Interior Surface

Total Room Surface Area: 178 sq. m

Grid Spacing for Survey Units: 1 m

FNRDP-DWG-04_flr

Note: Doorway locations shown on west wall.
Doors have been removed.



Map Legend

- Electrical Strip
- Pipe Penetration
- Cinder Block Wall
- Concrete (formally tiled w/ mastic remanants)
- (P.C.) - Poured Concrete
- Opening or Inaccessible Area

Comments:

Scanned Surface Area: ~ 85.5 sq. m (floor and walls < 2 m)
 * = where 44-142 used due to 43-37 geometry was too large.
 - denotes where INST set #3 was used
 - denotes where INST set #2 was used
 - denotes where INST set #1 was used.
 No scan survey results exceed Action levels.

**FNR Decommissioning Project
Reconnaissance Level Scan Survey Form**

Survey No: 2007-1961 Survey Unit: 3-1 Pkg. SP-007 Sheet 1 of 2

Date: 9-24-07 Survey Location: Room 3101

I. Instrument Information

Inst. Set No.	Meter Model	Scaler Serial No.	Detector Model	Detector Serial No.	HV Setting (Vdc)	THR Setting (mVdc)	2π Inst. Eff.	Calibration Due Date (Scaler)	Calibration Due Date (Detector)
1	2221	187743	43-37	243924	1750	2	.346	1-12-08	6-25-08
2	2221	187743	43-37	243922	1750	2	.356	1-12-08	7-17-08
3	2221	234988	44-142	246233	1050	10	.407	4-12-08	6-08
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

NOTE: All cables 6-ft RG-58 (LMI 44-142, 44-9, HP-210, or 44-92 probes) or 15-ft RG-58 (LMI 43-37 gas-flow handheld) unless otherwise noted in the comments below.

Comments: BKG FROM FLB MONITOR USED FOR HAND MONITOR, AS PER R. NEVEAU.
N/A

Initial Performance Test Performed & Satisfactory: [Signature] 9-24-07
Initial / Date

II. Background Measurements

Inst. Set No.	Grid or Location	Count Time (min.)	Counts per Minute (cpm)
1	BKG #1	1	1271
1	BKG #2	1	1295
1	BKG #3	1	1251
1 Avg	AVG	N/A	1272
2	BKG #1	1	1271
2	BKG #2	1	1295
2	BKG #3	1	1251
2 Avg	AVG	N/A	1272
3	#1 BKG corner	1	319
3	#2 BKG corner	1	348
3	#3 BKG corner	1	297
3 Avg	AVG	N/A	321

Comments: Inst set #1, 2 action set level 3057, INST set #3 action level 644.

Each of the demarked grids (or locations) on the attached survey map has been scanned and do not exceed the action level of 1,750 dpm/100-cm², unless otherwise noted on the attached survey map.

Post-Survey Performance Test Performed & Satisfactory: [Signature] 9/24/07
Initial / Date

Survey Tech (print/sign): Ken Gaynor / Kim Gaynor Date: 9/24/2007

Reviewed By (print/sign): Rock Neveau / [Signature] Date: 10-03-07

III. Total Surface Activity Measurements

Inst. Set No.	Grid or Location	Count Time (min.)	Counts per Minute (cpm)
N/A			

Reconnaissance Level Scan Survey Map


Survey Area: Phase 1 Survey Unit: 3-1 Classification: 2
 Building: Ford Nuclear Reactor Room: 3101
 Survey Unit Description: A- Structure Interior Surface
 Surface Area: 160 sq. m Grid Spacing for Survey Units: 1m
 FNRDP-DWG-02 flr
 Survey Package: SP-007



Survey Log No. 2007-1961

Survey Technician: [Signature]
 Mark all grids and survey locations where scan surveys were performed.
 If scan survey measurement results in a count rate that exceeds the action level,
 number the grid and record the total surface activity on the corresponding survey
 form.

Page 2 of 2



Map Legend

- = Doorway
- = Hole or Opening
- = 2 meter mark (extent of recon. survey area)

Comments:
 denotes where TruST Set # 3 was used.
 denotes where TruST Set # 2 was used.
 denotes where TruST Set # 1 was used.
 100 % of these locations were surveyed.

No survey results exceeded Action Levels.

FNR Decommissioning Project
Reconnaissance Level Scan Survey Form

Survey No: 2007-2016 Survey Unit: 3-5 Pkg. 6p-007 Sheet 1 of 2
Date: 10/8/2007 Survey Location: Room 3104 3rd Floor

I. Instrument Information

Inst. Set No.	Meter Model	Scaler Serial No.	Detector Model	Detector Serial No.	HV Setting (Vdc)	THR Setting (mVdc)	2π Inst. Eff.	Calibration Due Date (Scaler)	Calibration Due Date (Detector)
1	2221	187743	43-37	243922	1750	20		1-12-08	6/25/08
2	2221	187743	43-37	243924	1750	20		1-12-08	6/25/08
3	2221	218598	44-42	240716	1100	35		6/22/2008	6/22/2008
N/A									

NOTE: All cables 6-ft RG-58 (LMI 44-142, 44-9, HP-210, or 44-92 probes) or 15-ft RG-58 (LMI 43-37 gas-flow hand-held) unless otherwise noted in the comments below.

Comments: Inst #1 used on Floor, Inst #2 used on wall, Inst #3 used on Coners

Initial Performance Test Performed & Satisfactory: 10/8/2007
Initial / Date

II. Background Measurements

Inst. Set No.	Grid or Location	Count Time (min.)	Counts per Minute (cpm)
1	#17	1	1208
1	#20	1	1269
1	#23	1	1409
1	AVG	N/A	1322
2	#2	1	1044
2	#4	1	1106
2	#7	1	1107
2	AVG	N/A	1085
3	#34	1	309
3	#36	1	307
3	#31	1	322
3	AVG	N/A	312

III. Total Surface Activity Measurements

Inst. Set No.	Grid or Location	Count Time (min.)	Counts per Minute (cpm)
N/A			

Comments: Action Level for Set #1 = 3107, Action Level Set #2 = 2882, Action Level #3 = 63

Each of the demarked grids (or locations) on the attached survey map has been scanned and do not exceed the action level of 1,750 dpm/100-cm², unless otherwise noted on the attached survey map.

Post-Survey Performance Test Performed & Satisfactory: 10/8/2007
Initial / Date

Survey Tech (print/sign): Ken Gaynor / Ken Gaynor Date: 10/8/2007


Reviewed By (print/sign): Rock Neveau / [Signature] Date: 10-08-07

Survey Log No. 2007-2016

Reconnaissance Level Scan Survey Map

Survey Technician: Ken Gaynor
 Mark all grids and survey locations where scan surveys were performed.
 If scan survey measurement results in a count rate that exceeds the action level, number the grid and record the total surface activity on the corresponding survey form.

Survey Area: Phase 1 Survey Unit: 3-5 Classification: 1
 Building: Ford Nuclear Reactor Room: 3104 - Floor/L Walls
 Survey Unit Description: A- Structure Interior Surface
 Surface Area: 73.99 sq. m(Floor & Walls up to 2m)
 Remaining Walls: 38.15 sq. m.
 Grid Spacing for Survey Units: 1m
 FNRDP-DWG-01 flr
 Survey Package SP-007



Comments:
 ✓ = 100% of Floor Area done
 x = 100% of walls Area done
 /// = 100% of the corners wall to floor Area and corner to corner
 A = Area where BKG was taken for Floor
 B = Area where BKG was taken for wall
 C = Area where BKG was taken for corners
 Reviewed by: Bob Newell 10-08-07

NOTE: South wall doors have been removed.

*Verified

- Map Legend**
- - Pipe Penetration
 - [Cinder Block Pattern] - Cinder Block Wall
 - [Concrete Pattern] - Concrete (formally tiled w/ mortic remanants)
 - (P.C.) - Poured Concrete
 - [Black Box] - Opening or Inaccessible Area

FNR Decommissioning Project
Reconnaissance Level Scan Survey Form

Survey No: 2007-2034 Survey Unit: SP-010-03 Pkg. SP-010 Sheet 1 of 2
Date: 10-9-07 Survey Location: Pool Flood Westside hatches area

I. Instrument Information

Inst. Set No.	Meter Model	Scaler Serial No.	Detector Model	Detector Serial No.	HV Setting (Vdc)	THR Setting (mVdc)	2π Inst. Eff.	Calibration Due Date (Scaler)	Calibration Due Date (Detector)
1	2221	187743	43-37	243924	1750	2	0.346	1-12-08	6-25-08
2	2221	228810	44-42	243830	1200	35	0.391	4-27-08	4-27-08
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

NOTE: All cables 6-ft RG-58 (LMI 44-142, 44-9, HP-210, or 44-92 probes) or 15-ft RG-58 (LMI 43-37 gas-flow hand-held) unless otherwise noted in the comments below.

Comments: N/A

Initial Performance Test Performed & Satisfactory: NA 10-9-07
Initial / Date

II. Background Measurements

Inst. Set No.	Grid or Location	Count Time (min.)	Counts per Minute (cpm)
1	hatch #1	1	1284
1	Between hatch 2,3	1	1177
1	hatch #4	1	1152
1	AVG	NA	1204
1	Action Limit	N/A	2982
2	hatch #1	1	351
2	Between hatch 2,3	1	407
2	hatch #4	1	359
2	AVG.	NA	372
2	action Limit	NA	694
N/A	N/A	N/A	N/A

III. Total Surface Activity Measurements

Inst. Set No.	Grid or Location	Count Time (min.)	Counts per Minute (cpm)
SEE MAP			

Comments:

Attached map has BKG locations, static 1 min measurement locations for ins. set 1 and 2.

Each of the demarked grids (or locations) on the attached survey map has been scanned and do not exceed the action level of 1,750 dpm/100-cm², unless otherwise noted on the attached survey map.

Post-Survey Performance Test Performed & Satisfactory: NA 10-9-07
Initial / Date

Survey Tech (print/sign): Robert C. Grogan / [Signature] / Ken Gaylor / Ken Gaylor Date: 10-9-07

Reviewed By (print/sign): Dr. Neveu / [Signature] / [Signature] Date: 10-15-07


Radiological Survey Report

DATE: 10-9-07 LOCATION: Pool Floor west side hatches area. SURVEY NO.: 2007-2034 TIME: 1500

Smear Information N/A

Survey Map

No.	Beta/Gamma	Alpha (20%)
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		
16		
17		
18		
19		
20		



Legend: * = Contact; #/# = Contact Reading / General Area; # = General Area. ⊙ = Smear location; Δ = Air Sample.
 Note: Readings in mrem/hr unless noted otherwise.

Instrument	Serial Number	Cal. Due Date	Efficiency	Background (CPM)	MDA (DPM)
N/A	N/A	N/A	N/A	N/A	N/A
Frisker Detector HV = <u>N/A</u> Vdc		Threshold Voltage = <u>N/A</u> mVdc		Detector cable length = <u>N/A</u> ft.	<u>N/A</u>

Print/Signature of Surveyor: Robert Coley / Ken Gaynor Date: 10-9-07

Comments: *44-142 used on handles, Random 2 SPOTS/hatch and along southern most hatch (#2) Rubber seal. 43-37 used 100% scan survey of hatches & South Floor area.

Review By: Rock Neveau Date: 10-15-07

FNR Decommissioning Project
Reconnaissance Level Scan Survey Form

Survey No: 2007-2058 Survey Unit: SP-010-03 Pkg. SP-007 Sheet 1 of 2

Date: 10-15-07 Survey Location: Rx Pool Floor Reconnaissance

I. Instrument Information

Inst. Set No.	Meter Model	Scaler Serial No.	Detector Model	Detector Serial No.	HV Setting (Vdc)	THR Setting (mVdc)	2π Inst. Eff.	Calibration Due Date (Scaler)	Calibration Due Date (Detector)
1	2221	187743	43-37	243924	1750	20	0.346	12-12-08	6-25-08
2	2221	187743	43-37	243922	1750	20	0.356	12-12-08	7-17-08
N									
					A				

NOTE: All cables 6-ft RG-58 (LMI 44-142, 44-9, HP-210, or 44-92 probes) or 15-ft RG-58 (LMI 43-37 gas-flow hand-held) unless otherwise noted in the comments below.

Comments: N/A

Initial Performance Test Performed & Satisfactory: JG 10-15-07
Initial / Date

II. Background Measurements

Inst. Set No.	Grid or Location	Count Time (min.)	Counts per Minute (cpm)
1	BKG#1	1	1217
1	BKG#2	1	1273
1	BKG#3	1	1221
	AVG	N/A	1237
	Action Level	N/A	2832
2	BKG#1	1	952
2	BKG#2	1	906
2	BKG#3	1	887
	AVG	915	2745 ¹⁰⁻¹⁵⁻⁰⁷
	Action Level		2782
N			
A			

III. Total Surface Activity Measurements

Inst. Set No.	Grid or Location	Count Time (min.)	Counts per Minute (cpm)
1	F-08	1	3149
1	F-24	1	3198
1	F-61	1	4349
N			
A			

Comments: See pg 2 for Map.

Each of the demarked grids (or locations) on the attached survey map has been scanned and do not exceed the action level of 1,750 dpm/100-cm², unless otherwise noted on the attached survey map.

Post-Survey Performance Test Performed & Satisfactory: JG 10-15-07
Initial / Date

Survey Tech (print/sign): Robert Hegarty Date: 10-15-07

Reviewed By (print/sign): R. Nevean Date: 10-15-07

Radiological Survey Report


Reconnaissance

DATE: 10-15-07 LOCATION: Rx Pool Floor SURVEY NO.: 2007-208 TIME: 1300
Including East Wall

Smear Information N/A

Survey Map

No.	Beta/Gamma	Alpha (20%)
1	N/A	N/A
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		
16		
17		
18		
19		
20		



Legend: * = Contact; #/# = Contact Reading / General Area; # = General Area. ① = Smear location; Δ = Air Sample.
 Note: Readings in mrem/hr unless noted otherwise.

Instrument	Serial Number	Cal. Due Date	Efficiency	Background (CPM)	MDA (DPM)
Frisker Detector					
HV =	Vdc	Threshold Voltage =	mVdc	Detector cable length =	ft.

Print/Signature of Surveyor: Robert C. [Signature] Date: 10-15-07

Comments: Floor scanned, walls below 2 meters scanned, except south Rx cavity wall. 44-142 needed on wall joints and wall/floor joints

Review By: Rock Neveau / [Signature] Date: 10-15-07

FNR Decommissioning Project
Reconnaissance Level Scan Survey Form

Survey No: 2007-2116 Survey Unit: 3-10 Pkg. SP-D10-04 Sheet 1 of 2

Date: 10-24-07 Survey Location: POOL FLOOR South Wall

Reconnaissance Survey

I. Instrument Information

Inst. Set No.	Meter Model	Scaler Serial No.	Detector Model	Detector Serial No.	HV Setting (Vdc)	THR Setting (mVdc)	2π Inst. Eff.	Calibration Due Date (Scaler)	Calibration Due Date (Detector)
1	2221	187743	43-37	243922	1750	20	0.356	1-12-08	7-17-08
<i>N</i>									
<i>A</i>									

NOTE: All cables 6-ft RG-58 (LMI 44-142, 44-9, HP-210, or 44-92 probes) or 15-ft RG-58 (LMI 43-37 gas-flow hand-held) unless otherwise noted in the comments below.

Comments: All areas between S-01 & S-104 scanned 100%

Initial Performance Test Performed & Satisfactory: h 10-24-07
Initial / Date

II. Background Measurements

Inst. Set No.	Grid or Location	Count Time (min.)	Counts per Minute (cpm)
1	S-15	1	936
1	S-55	1	997
1	S-95	1	931
1	AUG	N/A	954
1	ACTION Limit	N/A	2736
1	S-46	1	888
1	S-72	1	903
1	S-98	1	1017
1	AUG	N/A	936
1	ACTION Limit	N/A	2718
<i>N</i>			
<i>A</i>			

Comments: N/A

III. Total Surface Activity Measurements

Inst. Set No.	Grid or Location	Count Time (min.)	Counts per Minute (cpm)
<i>N</i>			
<i>A</i>			

Each of the demarked grids (or locations) on the attached survey map has been scanned and do not exceed the action level of 1,750 dpm/100-cm², unless otherwise noted on the attached survey map.

Post-Survey Performance Test Performed & Satisfactory: h 10-24-07
Initial / Date

Survey Tech (print/sign): Robert C. Heise/Holtege Date: 10-24-07

Reviewed By (print/sign): Rock Neven Date: 10-24-07

Survey Log No. 2007-2116

Reconnaissance Level Scan Survey Map

Survey Technician: Robert C. Gray, JR.
 Mark all grids and survey locations where scan surveys were performed.
 If scan survey measurement results in a count rate that exceeds the action level, number the grid and record the total surface activity on the corresponding survey form.

Survey Area: Phase 1 Survey Unit: 3-10 Classification: 1
 Building: Ford Nuclear Reactor Room: 3101A - South Wall
 Survey Unit Description: A- Structure Interior Surface
 Surface Area: 158.5 sq. m (Floor & Walls up to 2m)
 Grid Spacing for Survey Units: 1m
 ENRDP-DWG-7R_SW
 Survey Package SP-010-4

S-131	S-132	S-133	S-134	S-135	S-136	S-137	S-138	S-139	S-140	S-141	S-142	S-143
S-118	S-119	S-120	S-121	S-122	S-123	S-124	S-125	S-126	S-127	S-128	S-129	S-130
S-105	S-106	S-107	S-108	S-109	S-110	S-111	S-112	S-113	S-114	S-115	S-116	S-117
S-92	S-93	S-94	S-95	S-96	S-97	S-98	S-99	S-100	S-101	S-102	S-103	S-104
S-79	S-80	S-81	S-82	S-83	S-84	S-85	S-86	S-87	S-88	S-89	S-90	S-91
S-66	S-67	S-68	S-69	S-70	S-71	S-72	S-73	S-74	S-75	S-76	S-77	S-78
S-53	S-54	S-55	S-56	S-57	S-58	S-59	S-60	S-61	S-62	S-63	S-64	S-65
S-40	S-41	S-42	S-43	S-44	S-45	S-46	S-47	S-48	S-49	S-50	S-51	S-52
S-27	S-28	S-29	S-30	S-31	S-32	S-33	S-34	S-35	S-36	S-37	S-38	S-39
S-14	S-15	S-16	S-17	S-18	S-19	S-20	S-21	S-22	S-23	S-24	S-25	S-26
S-01	S-02	S-03	S-04	S-05	S-06	S-07	S-08	S-09	S-10	S-11	S-12	S-13

Crane Rail Support Beam

S-144 S-145 S-146

Comments: 100% of south wall scanned
 From S-01 to S-104
 No survey results exceeded Action Levels.
 R.N.
 10/24/07

S-157 S-158 S-159 S-160

Robert C. Gray, JR. [Signature] 10-24-07
 RPT Print Name Signature Date

Indentation

Radiological Survey Report


DATE: 10-29-07 LOCATION: 3101 Recon. SURVEY NO.: 2007-2155 TIME: 1100

Smear Information N/A

Survey Map

No.	Beta/ Gamma	Alpha (20%)
1		
2		
3		
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		
16		
17		
18		
19		
20		

N/A



Legend: * = Contact; # / # = Contact Reading / General Area; # = General Area. ⊙ = Smear location; Δ = Air Sample.

Note: Readings in mrem/hr unless noted otherwise.

Instrument	Serial Number	Cal. Due Date	Efficiency	Background (CPM)	MDA (DPM)
See Page			one	N/A	N/A
Frisker Detector HV = <u>N/A</u> Vdc		Threshold Voltage = <u>N/A</u> mVdc		Detector cable length = <u>N/A</u> ft.	

Print/Signature of Surveyor: Robert C. Geyer / [Signature] Date: 10-29-07

Comments: 43-37 used to scan 2m and below, 44-142 used in corners and where Floor meets wall, and door jams.

Review By: [Signature] Date: 11/2/07

FNR Decommissioning Project
Reconnaissance Level Scan Survey Form

Survey No: 2007-2188 Survey Unit: SP-007 Pkg. N/A Sheet 1 of 2
Date: 10/29/07 Survey Location: Fuel Vault (3rd floor)

I. Instrument Information

Inst. Set No.	Meter Model	Scaler Serial No.	Detector Model	Detector Serial No.	HV Setting (Vdc)	THR Setting (mVdc)	2π Inst. Eff.	Calibration Due Date (Scaler)	Calibration Due Date (Detector)
1	2221	218598	44742	240716	1100	35		6-22-08	6-08
2	2221	187713	4337	243922	1750	20		12-12-08	7-17-08
3	2221	187713	4337	243924	1750	20		12-12-08	6-25-08
N/A									

NOTE: All cables 6-ft RG-58 (LMI 44-142, 44-9, HP-210, or 44-92 probes) or 15-ft RG-58 (LMI 43-37 gas-flow hand-held) unless otherwise noted in the comments below.

Comments: Action level for set #1: 754 gcpm, set #2: 3282 gcpm, set #3: 3557

Initial Performance Test Performed & Satisfactory: PRE 10/29/07
Initial / Date

II. Background Measurements

Inst. Set No.	Grid or Location	Count Time (min.)	Counts per Minute (cpm)
1	BKG-1	1	418
1	BKG-2	1	428
1	BKG-3	1	444
2	BKG-1	1	1482
2	BKG-2	1	1498
2	BKG-3	1	1505
3	BKG-1	1	1712
3	BKG-2	1	1829
3	BKG-3	1	1730
1	AVG	1	430
2	AVG	1	1495
3	AVG	1	1757

III. Total Surface Activity Measurements

Inst. Set No.	Grid or Location	Count Time (min.)	Counts per Minute (cpm)
N/A			

Comments: all surfaces 100% scanned.

Each of the demarked grids (or locations) on the attached survey map has been scanned and do not exceed the action level of 1,750 dpm/100-cm², unless otherwise noted on the attached survey map.

Post-Survey Performance Test Performed & Satisfactory: PRE 10-29-07
Initial / Date

Survey Tech (print/sign): Paul R Emer + [Signature] Date: 10/29/07

Reviewed By (print/sign): [Signature] Date: 11/2/07


Radiological Survey Report

DATE: 10-29-07 LOCATION: Fuel Vault (3rd floor) SURVEY NO.: 2007-2188 TIME: 1700

Smear Information n/A

Survey Map

No.	Beta/ Gamma	Alpha (20%)
1		
2		
3		
4		
5		
6		
7		
8		
9	N	A
10		
11		
12		
13		
14		
15		
16		
17		
18		
19		
20		



Legend: * = Contact; # / # = Contact Reading / General Area; # = General Area. ⊙ = Smear location; Δ = Air Sample.
 Note: Readings in mrem/hr unless noted otherwise.

Instrument	Serial Number	Cal. Due Date	Efficiency	Background (CPM)	MDA (DPM)
n/A					
A					
A					
A					

Frisker Detector HV = Vdc Threshold Voltage = mVdc Detector cable length = ft.

Print/Signature of Surveyor: Paul R. Ernest / Paul R. Ernest Date: 10-30-07

Comments: _____

Review By: [Signature] Date: 11/2/07

Radiological Survey Report

DATE: 12-12-07 LOCATION: 3rd Floor Bridge SURVEY NO.: 2007-2478 TIME: 1715

Smear Information DRM/100 cm² Crane Survey Map

No.	Beta/Gamma	Alpha (20%)
1	78	<MDA
2	46 <MDA	
3	<MDA	
4		
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		
16		
17		
18		
19		
20		

This is the Rx building bridge crane radiological survey results. The crane was wiped down with bathroom cleaner ("Scrubbing Bubbles"), "Scotch-Brite" pads and towels. The wipe down was performed from the decking along the west trolley rail and from a man-lift moved along the east side of the east trolley rail. All surfaces that could be reached from those two access paths were wipe down. The areas not cleaned are obvious. The surfaces cleaned are free of all loose contamination. However, a uniform level of approximately 125 NCPM is trapped everywhere dried grease is located. (The grease will not come off with scrubbing bubbles.) All measurements are less than 25% DCGZ of 574 GCPM except for the main cable. It reads 580 GCPM.

Areas not wiped or surveyed:

- 1.) Bridge rail beds and rails.
- 2.) Winches motor & cable drum.
- 3.) Under sides & between sides of trolley rail support beams.

Legend: * = Contact; # / # = Contact Reading / General Area; # = General Area. ① = Smear location; Δ = Air Sample.
 Note: Readings in mrem/hr unless noted otherwise.

Instrument	Serial Number	Cal. Due Date	Efficiency	Background (CPM)	MDA (DPM)
L-2221-	234988	4/12/08	N/A		
44-142	246233	6/08	.41 (2π @ 1/4")	24 254	N/A
L-2929	216263	8/23/08	β _X = .27, α = .4	β _X = 33, α = ∅	β _X = 34, α = 3
N/A					
Frisker Detector HV = 1050 Vdc		Threshold Voltage = 10 mVdc		Detector cable length = 6 ft.	

Print/Signature of Surveyor: Ned Campbell Date: 12-12-07

Comments: _____

Review By: JR Smith Date: 12/14/07