



REGIS T. REPKO
Vice President
McGuire Nuclear Station

Duke Energy
MG01VP / 12700 Hagers Ferry Rd.
Huntersville, NC 28078

980-875-4111
980-875-4809 fax
regis.repko@duke-energy.com

March 29, 2012

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Subject: Duke Energy Carolinas, LLC
McGuire Nuclear Station, Units 1 and 2
Docket Nos. 50-369 and 50-370
Annual Commitment Change Report

Attached is a summary report of commitment changes for McGuire Nuclear Station completed during the 2011 calendar year. These changes were made per the guidance defined in NEI 99-04, "Guidelines for Managing NRC Commitments" and have no adverse effect on compliance with NRC rules and regulations.

Questions regarding this submittal should be directed to P. T. Vu, McGuire Regulatory Compliance at (980) 875-4302.

Sincerely,

Regis T. Repko

Attachment

A001
MRR

U. S. Nuclear Regulatory commission
March 29, 2012
Page 2

xc:

V. M. McCree, Region II Administrator
U. S. Nuclear Regulatory Commission
Marquis One Tower
245 Peachtree Center Ave., NE Suite 1200
Atlanta, GA 30303-1257

J. H. Thompson, Project Manager
U. S. Nuclear Regulatory Commission
11555 Rockville Pike
Mail Stop O-8G9A
Rockville, MD 20852-2738

J. Zeiler
NRC Senior Resident Inspector
McGuire Nuclear Station

McGuire Nuclear Station
 Commitment Change Summary Report
 Docket Nos. 50-369 and 50-370

NUMBER	SOURCE DOCUMENT	ORIGINAL COMMITMENT	MODIFIED COMMITMENT
2011-M-001	Duke Energy letter to NRC dated January 31, 1979, McGuire Nuclear Station Fire Protection Review.	<p>Portable emergency lights with a minimum of 8-hour battery supply are provided for the following areas:</p> <ol style="list-style-type: none"> 1) 695' Elev. Residual Heat Removal Pump Room use. 2) 716' Elev. Auxiliary Shutdown Panel (ASP) use. 3) 716' Elev. Nuclear Service Water Pumps. 4) 733' Elev. Component Cooling Pump area. 5) 750' Elev. Component Cooling Pumps. 	<p>- For Areas 1, 3, 4, and 5: There are no designated portable lights committed for these areas and there are no required manual operator actions needed.</p> <p>- For Area 2: There are fixed 8-hour battery backed lights in this location but no portable lights. There are no 10 CFR 50, Appendix R Hot Standby operator actions at the ASP. There are operator actions at the Motor Driven Auxiliary Feedwater Panels and at the Turbine Driven Auxiliary Feedwater Panels and these have respective fixed 8-hour battery backed lights.</p>