



Westinghouse Electric Company
Nuclear Power Plants
1000 Westinghouse Drive
Cranberry Township, Pennsylvania 16066
USA

Kerri Kavanagh
U S Nuclear Regulatory Commission
Two White Flint North
11555 Rockville Pike
Rockville, MD 20852-2738

Direct tel: 412-374-3382
Direct fax: 724-940-8505
e-mail: russpa@westinghouse.com

Ref: NON 99901409
Our ref: DCP_NRC_003209

April 5, 2012

Subject: 2011-201-03 Auxiliary Building Wall 7.3 Reinforcement Design

Ref: NON 99901409/2011-201-03 Auxiliary Building Wall 7.3 Reinforcement Design

The Obayashi APP-1200-CCC-102 calculation for the Auxiliary Building Wall 7.3 reinforcement design was discussed with the NRC during the 2011 Obayashi inspection. The focus for the discussion was the wall designed as a corbel as provided in the latest revision of these calculation.

As confirmed with NRC in a phone call on March 6, 2012, Westinghouse will issue a calculation note for the Auxiliary Building Wall 7.3 reinforcement design to include the design evaluation approach used in an earlier version of the APP-1200-CCC-102 calculation. Specifically, the wall will not be designed as a corbel. Westinghouse will complete and have its calculation note available for review by July 15, 2012.

Very truly yours,

A handwritten signature in black ink, appearing to read 'Paul A. Russ'.

T.J. Ray for /

Paul A. Russ
Director, AP1000 Licensing

/Enclosures

cc:	Marie Blanc	WEC
	Mike Corletti	WEC
	Lee Tunon-Sanjur	WEC
	Thomas Ray	WEC

NRO