


NRR-PMDAPEm Resource

From: Wiebe, Joel
Sent: Thursday, April 12, 2012 3:41 PM
To: David Gullott; Joseph Bauer; Mitchel Mathews
Subject: Followup RAI Questions Related to Exelon Response to RAI Question #7
Attachments: image001.jpg

1. What is the temporary tooling (after which the response states Code Case N-638-4 requires another surface examination)? N-638-4 requires another surface examination after weld-attached thermocouples are removed in paragraph 4a(3).
2. Code Case N-638-4 Paragraph 4(a)(4) states that "Acceptance criteria for surface and volumetric examination shall be in accordance with Construction Code or Section III." For some of the examinations, the response to RAI 7 references [ASME] Section III, 1992 Edition, while for other examinations, [ASME Code] Section III, 1965 Edition, Summer 1965 Addenda is referenced. Code Case N-416-3 references the ASME Code, Section III, 1992 Edition for NDE methods and acceptance criteria. Explain the logic for referencing the original construction code of record (Section III, 1965 Edition, Summer 1965 Addenda) for some examinations and Section III, 1992 Edition for other examinations
3. Confirm that Code Cases N-405-1 and N-416-3 are incorporated in the QCNPS ISI Program.



Hearing Identifier: NRR_PMDA
Email Number: 335

Mail Envelope Properties (1A97AE0578A58B46BC77AA0B5DBD72023BF3D445E1)

Subject: Followup RAI Questions Related to Exelon Response to RAI Question #7
Sent Date: 4/12/2012 3:40:52 PM
Received Date: 4/12/2012 3:40:00 PM
From: Wiebe, Joel

Created By: Joel.Wiebe@nrc.gov

Recipients:

"David Gullott" <David.Gullott@ExelonCorp.com>
Tracking Status: None
"Joseph Bauer" <Joseph.Bauer@exeloncorp.com>
Tracking Status: None
"Mitchel Mathews" <Mitchel.Mathews@exeloncorp.com>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	1065	4/12/2012 3:40:00 PM
image001.jpg	11907	

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: