

PMSTPCOL PEmails

From: Wunder, George
Sent: Tuesday, April 03, 2012 4:54 PM
To: STPCOL
Subject: FW: Draft Appendix 1E
Attachments: Appendix_1E_Draft_NRC.pdf

-----Original Message-----

From: Wunder, George
Sent: Tuesday, April 03, 2012 4:53 PM
To: Beardsley, James; Burton, William; Caverly, Jill; Colaccino, Joseph; Cook, Christopher; Cabbage, Amy; Dixon-Herrity, Jennifer; Donoghue, Joseph; Frye, Timothy; Hamzehee, Hossein; Hsia, Anthony; Jackson, Terry; Jenkins, Ronaldo; Jung, Ian; Karas, Rebecca; Kavanagh, Kerri; Kowal, Mark; Lee, Samuel; Magruder, Stewart; Masnik, Michael; McCoppin, Michael; McKenna, Eileen; McKirgan, John; Mrowca, Lynn; Norato, Michael; Peralta, Juan; Raione, Richard; Rasmussen, Richard; Roach, Edward; Schaaf, Robert; Segala, John; Shams, Mohamed; Terao, David; Thomas, Brian; Tonacci, Mark; Whited, Ryan
Subject: FW: Draft Appendix 1E

Ladies and Gentlemen,

I am happy to have seen so many of you and your staff at last week's meeting with South Texas Project on their response to the Fukushima recommendations. Attached please find the draft Appendix 1E for their COLA. This appendix addresses their responses to the recommendations. This is not being sent for formal review, but if you have any comments or questions I would enjoy hearing them.

Thanks,

George

-----Original Message-----

From: Elton, Loree [<mailto:leelton@STPEGS.COM>]
Sent: Wednesday, March 28, 2012 2:49 PM
To: Misenhimer, David; Wunder, George; Eudy, Michael; Foster, Rocky; Joseph, Stacy; Tai, Tom; Jenkins, Ronaldo
Subject: Draft Appendix 1E

Per the request George Wunder, please find attached a draft version of Appendix 1E of the FSAR, which addresses post-Fukushima recommendations.

Loree Elton
Licensing, STP 3 & 4
leelton@stpegs.com
361-972-4644

Hearing Identifier: SouthTexas34Public_EX
Email Number: 3351

Mail Envelope Properties (DAC719623E968245BD52D03696111100A86746019A)

Subject: FW: Draft Appendix 1E
Sent Date: 4/3/2012 4:53:32 PM
Received Date: 4/3/2012 4:51:19 PM
From: Wunder, George

Created By: George.Wunder@nrc.gov

Recipients:
"STPCOL" <STP.COL@nrc.gov>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	1651	4/3/2012 4:51:19 PM
Appendix_1E_Draft_NRC.pdf	102150	

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

1E Response to NRC Post-Fukushima Recommendations

1E.1 Introduction

In response to the accident at the Fukushima Daiichi Nuclear Power Plant caused by the March 2011, Magnitude 9 Tohoku earthquake and subsequent tsunami, the Nuclear Regulatory Commission established a Near-Term Task Force (NTTF) to review NRC processes and regulations to determine if improvements to its regulatory system were needed. The NTTF developed a set of recommendations intended to clarify and strengthen the regulatory framework for protection against natural phenomena. These recommendations were issued in SECY-11-0093 (Reference 1E-9).

SECY-11-0124 and SECY-11-0137 provided the NRC Commissioners with the Staff's recommendations, including prioritization for implementation. Subsequently, SECY-12-0025 was issued describing proposed orders to be issued to licensees and draft requests for information pursuant to 10 CFR 50.54(f). SECY-12-0025 stated that combined license plants under review would address the three orders and the request for information through the review process. On March 9, 2012, the Commission issued a Staff Requirements Memorandum (SRM) for SECY-12-0025 (Reference 1E-4) approving issuance of the orders and request for information with some modifications.

This appendix addresses the Tier 1 recommendations and Orders contained in SECY-12-0025, the Tier 2 recommendations contained in SECY-11-0137, and the modifications documented in the SRM consistent with the as issued orders (EA-12-049, 050 and 51) and request for information dated March 12, 2012. The NRC Recommendation in each of the following subsections is a summary of the recommendation from the NRC documents. The response to each recommendation discusses how STP 3 & 4 addresses the recommendation. The numbers in parentheses of subsection headings correspond to the NTTF recommendation number.

1E.2 Tier 1 NRC Recommendation/Responses

1E.2.1 Seismic and Flooding Reevaluations (2.1)

1E.2.1.1 Seismic

NRC Recommendation

Perform a reevaluation of the seismic hazards using present-day NRC requirements and guidance to develop a Ground Motion Response Spectrum (GMRS). The new consensus seismic source models from the Central and Eastern United States Seismic Source Characterization (CEUS), NUREG-2115, may be used to characterize the hazards.

Response

Present-day regulatory guidance and methodologies, including the approach described in Regulatory Guide (RG) 1.208, “A Performance Based Approach to Define the Site-Specific Earthquake Ground Motion,” were used to evaluate seismic hazards for the STP 3 & 4 site as discussed in Chapters 2 and 3. The evaluation conducted in conformance with RG 1.208 is discussed in Subsection 2.5S.2.6.

STP 3 & 4 reviewed the updated information provided in the CEUS and confirmed that it does not identify any new hazards that are not adequately considered in Chapters 2 and 3, and is not materially different than the GMRS discussed in 2.5S.2.6.

1E.2.1.2 Flooding

NRC Recommendation

Perform a reevaluation of all appropriate external flooding sources, including the effects from local intense precipitation on the site, probable maximum flood (PMF) on streams and rivers, storm surges, seiches, tsunamis, and dam failures. It is requested that the reevaluation apply present-day regulatory guidance and methodologies being used for ESP and COL reviews including current techniques, software, and methods used in present-day standard engineering practice to develop the flood hazard.

The recommendation also noted that flooding risks are of concern because the safety consequences of a flooding event may increase sharply with a small increase in flooding level.

Response

Present-day regulatory guidance and methodologies were used to evaluate flooding hazards relative to the STP 3 & 4 site as discussed in Section 2.4S.

Scenarios evaluated include:

- Dam Break Analysis (2.4S.4)
- Main Cooling Reservoir (MCR) Embankment Breach Analysis (2.4S.4.2.2)
- Probable Maximum Flood on Streams and Rivers (2.4S.3)
- Local Probable Maximum Precipitation (2.4S.2.3)
- Probable Maximum Surge and Seiche (2.4S.5)
- Probable Maximum Tsunami (2.4S.6)
- Ice Induced Flooding (2.4S.7)
- Channel Diversions (2.4S.9)
- Low Water Considerations (2.4S.11)

Conservatism in the STP 3 & 4 design minimize the likelihood of a small increase in flooding level leading to safety consequences. The limiting flood for STP 3 & 4 is postulated to be an MCR embankment breach; however, an embankment breach is not credible as discussed in Subsection 2.4S.4.1.2.

1E.2.2 Seismic and Flooding Walkdowns (2.3)

NRC Recommendations

Perform seismic walkdowns in order to identify and address plant specific degraded, non-conforming, or unanalyzed conditions and verify the adequacy of strategies, monitoring, and maintenance programs such that the nuclear power plant can respond to external events. The walkdown will verify current plant configuration with the current licensing basis, verify the adequacy of current strategies, maintenance plans, and identify degraded, non-conforming, or unanalyzed conditions. The walkdown procedure should be developed and submitted to the NRC. The procedure may incorporate current plant procedures, if appropriate. Prior to the walkdown, licensees should develop acceptance criteria, collect appropriate data, and assemble a team with relevant technical skills

The NRC also requests that each addressee confirm that they will use the industry developed, NRC endorsed, flood walkdown procedures or provide a description of plant-specific walkdown procedures.

Response

This recommendation is not applicable since the STP 3 & 4 units have not yet been built. However, seismic and flooding plant walkdowns will be conducted after construction as documented in COL Information Item 19.9.5.

1E.2.3 Station Blackout (SBO) Rulemaking (4.1)

NRC Recommendation

Strengthen the station blackout (SBO) mitigation capability at all operating and new reactors for design-basis and beyond-design-basis events. This includes (1) a minimum coping time of 8 hours for loss of all AC, (2) establishing the equipment, procedures, and training necessary to implement an extended coping time of 72 hours for core and spent fuel cooling and for reactor coolant system and primary containment integrity, and (3) pre-planning and pre-staging offsite resources to support uninterrupted core and spent fuel cooling, and RCS and primary containment integrity under conditions involving significant degradation of offsite transportation infrastructure associated with a significant natural disaster. This recommendation will be implemented by rule-making.

SECY-12-0025 adds the requirement that the loss of the Ultimate Heat Sink (UHS) should be evaluated as part of the SBO evaluation.

Response

(1) The STP 3 & 4 design can withstand an SBO for an indefinite period of time using an alternate AC power source, the Combustion Turbine Generator (CTG), as described in Appendix 1C (Table 1C-2). Additionally, the STP 3 & 4 design can withstand a sustained loss of all AC power, including the loss of both CTGs, for 72 hours while maintaining core cooling, as described in 19E2.1.2.2.2.

The STP 3 & 4 design has a number of features that mitigate an SBO and extended loss of all AC power:

- The primary mitigation for an extended SBO is provided by a CTG, which is independent from the Emergency Diesel Generators (EDGs) and can be connected to the 4.16 KV Class 1E buses. This CTG has black start capability and can be available for use within 10 minutes. There is one CTG per unit, they can be cross-tied, and one CTG can supply the safety loads for both units. (Tier 1 Section 2.12.11 and Tier 2 Appendix 1C).
- The batteries have a capacity of 8 hours. This capacity can be extended well beyond 8 hours if load shedding is performed (Section 8.3.2.1.3.1).
- The Reactor Core Isolation Cooling system can provide core cooling for at least 8 hours during SBO conditions without reliance on AC power (Appendix 19E.2).
- The Alternating Current-Independent Water Addition (ACIWA) system is a seismically qualified system with an external permanent diesel-driven pump and water supply capable of providing water to the Residual Heat Removal (RHR) system for core and containment cooling without reliance on AC power (Tier 1 Figure 2.15.6).
- Seismically-qualified external connections on opposite sides of the Reactor Building can be used to provide makeup water and sprays to the Spent Fuel Pool (SFP) with the use of staged portable diesel driven water supply pumps as described in Part 11 (Mitigative Strategies Report) Sections 6.1 and 6.2.

(2) STP 3 & 4 has the installed equipment to implement an extended coping time in excess of 72 hours without reliance on AC power for core and spent fuel cooling and for reactor coolant system and primary containment integrity as documented in Subsection 19E.2.2.3. The 72 hours of core cooling can be provided without reliance on the UHS. Relevant procedures and training will be developed per the Operational Program Development Plan described in Sections 13.4S and 13.5.

(3) Pre-planning and pre-staging resources to support uninterrupted core and spent fuel pool cooling, and RCS and primary containment integrity under conditions involving significant degradation of the onsite facilities associated with large fires and explosions

are documented in Part 11. Additionally, as discussed in the next section, STP will arrange for sufficient offsite resources to sustain core, containment, and spent fuel pool cooling indefinitely. These plans and resources will provide this capability under circumstances involving significant degradation of offsite transportation infrastructure associated with a significant natural disaster.

1.E.2.4 Mitigating Strategies for Beyond Design Basis Events (4.2)

NRC Recommendation

NRC issued an Order to power reactor licensees and holders of construction permits requiring a three-phase approach for mitigating beyond-design-basis external events. The initial phase requires the use of installed equipment and resources to maintain or restore core cooling, containment and spent fuel pool (SFP) cooling capabilities. The transition phase requires providing sufficient, portable, onsite equipment and consumables to maintain or restore these functions until they can be accomplished with resources brought from off site. The final phase requires obtaining sufficient offsite resources to sustain those functions indefinitely.

Response

STP 3 & 4 incorporates three staged AC independent portable pumping systems:

- Two pumps (a fire truck and trailer mounted portable pump) shared between STP 3 & 4 provide core, SFP, and containment cooling water to the RHR system via the ACIWA system (Subsection 5.4.7.1.1.10).
 - The fire truck is located in the Turbine Building Truck Bay and is protected from site hazards
 - The trailer mounted portable diesel-driven pump is located in a Seismic Category I structure as required for severe weather events (Subsection 19.4.6)
- One trailer mounted pump shared between STP 1, 2, 3, and 4 provides water in the event of the loss of large areas of the plant (Part 11, Subsection 5.1.2).
 - This trailer mounted pump is protected primarily by distance from the site

STP 3 & 4 is monitoring the development of the industry FLEX program (Reference 1E-3) and will implement the program. This industry program is developing diverse and flexible mitigation strategies to address extended loss of power and loss of ultimate heat sink that will increase the defense-in-depth for beyond design basis scenarios.

STP 3 & 4 will develop, implement, and maintain guidance and strategies to restore core cooling, containment, and SFP cooling following a beyond Design Basis Event (DBE). The strategies will be capable of mitigating a simultaneous loss of all alternating current (ac) power (including both CTGs) and loss of normal access to the ultimate heat sink, and will be implementable in all operating modes. The equipment required to mitigate the beyond DBE will be adequately protected from external events.

The guidance will utilize a three-phase approach. Phase I will use installed equipment and resources to maintain or restore core, containment and spent fuel pool (SFP) cooling capabilities. The second or transition phase will provide sufficient, portable, onsite equipment and consumables to maintain or restore these functions until they can be accomplished with resources brought from off site. The final phase III will obtain sufficient offsite resources to sustain those functions indefinitely.

The detailed procedures and training developed during implementation of operational programs as described in Section 13.4S will be developed in cooperation with Units 1 and 2 as a 4-unit site and will address all of the NRC requirements discussed above.

1E.2.5 Reliable Hardened Vents (5.1)

NRC Recommendation

NRC issued an Order to operating Boiling-Water Reactor (BWR) licensees with Mark I and Mark II containments requiring them to have a reliable hardened vent to remove decay heat and maintain control of containment pressure within acceptable limits following events that result in the loss of active containment heat removal capability or prolonged Station Blackout (SBO). The hardened vent system is required to be accessible and operable under a range of plant conditions, including a prolonged SBO and inadequate containment cooling.

Response

This recommendation does not apply since STP 3 & 4 does not have a Mark I or Mark II containment.

However, each STP 3 & 4 unit does have a passive, reliable hardened vent as part of the Containment Overpressure Protection System (COPS). COPS is Seismic Category I and is qualified for accident pressures. The vent paths for the units are not shared. This design is described in Subsection 6.2.5.2.6 and its use in conjunction with long term cooling without AC power to prevent fuel damage is demonstrated in Appendix 19E.2.2.

1E.2.6 Spent Fuel Pool (SFP) Instrumentation (7.1)

NRC Recommendation

NRC issued an order to power reactor licensees and holders of construction permits requiring them to have a reliable indication of the water level in associated spent fuel storage pools capable of supporting identification of the following pool water level conditions by trained personnel: (1) level that is adequate to support operation of the normal fuel pool cooling system, (2) level that is adequate to provide substantial radiation shielding for a person standing on the spent fuel pool operating deck, and (3) level where

fuel remains covered and actions to implement make-up water addition should no longer be deferred.

Response

STP 3 & 4 currently has reliable level and temperature monitors in the SFP that provide indication via the process computer and annunciate in the Main Control Room (MCR). The instruments are powered by battery-backed non-Class 1E vital 120 VAC, normally powered by the Plant Investment Protection (PIP) buses, which are backed-up by the Combustion Turbine Generator (CTG) as described in Subsection 7.7.1.10.

STP 3 & 4 will enhance the spent fuel pool instrumentation to ensure that it provides a reliable indication of the water level in the spent fuel storage pools capable of supporting identification of the following pool water level conditions by trained personnel: (1) level that is adequate to support operation of the normal fuel pool cooling system, (2) level that is adequate to provide substantial radiation shielding for a person standing on the spent fuel pool operating deck, and (3) level where fuel remains covered and actions to implement make-up water addition should no longer be deferred.

1. The spent fuel pool level instrumentation will include the following design features:
 - 1.1 Instruments: The instrumentation will consist of two permanent, fixed primary instrument channels with level indication from the top of the fuel racks to the top of the spent fuel pool. Level instrumentation will include high and low water level alarms that annunciate in the Control Room.
 - 1.2 Arrangement: The spent fuel pool level instrument channels will be arranged in a manner that provides reasonable protection of the level indication function against missiles that may result from damage to the structure over the spent fuel pool. This protection will be provided by maintaining instrument channel separation within the spent fuel pool area, and will utilize inherent shielding from missiles provided by existing corners in the spent fuel pool structure.
 - 1.3 Mounting: Installed instrument channel equipment within the spent fuel pool will be mounted to retain its design configuration during and following the maximum seismic ground motion considered in the design of the spent fuel pool structure.
 - 1.4 Qualification: The instrument channels will be reliable at temperature, humidity, and radiation levels consistent with the spent fuel pool water at saturation conditions for an extended period. This reliability will be established through use of an augmented quality assurance process (e.g., a process similar to that applied to the site fire protection program).
 - 1.5 Independence: The instrument channels will be physically and electrically independent of each other.

1.6 Power supplies: The permanently installed instrumentation channels will be powered by separate Non-Class 1E Vital power supplies. The instrumentation channels will also provide for power connections from sources independent of the plant ac and dc power distribution systems. The independent sources used for instrument channel power will have sufficient capacity to maintain the level indication function for at least 72 hours.

1.7 Accuracy: The instrument channels will maintain their designed accuracy following a power interruption or change in power source without recalibration.

1.8 Testing: The instrument channel design will provide for routine testing and calibration.

1.9 Display: Trained personnel will be able to monitor the spent fuel pool water level from the control room, alternate shutdown panel, or other appropriate and accessible location. The display will provide on-demand or continuous indication of spent fuel pool water level.

2. The spent fuel pool instrumentation will be maintained available and reliable through appropriate development and implementation of the following programs:

2.1 Training: Personnel will be trained in the use and the provision of alternate power to the instrument channels.

2.2 Procedures: Procedures shall be established and maintained for the testing, calibration, and use of the spent fuel pool level instrument channels.

2.3 Testing and Calibration: Processes will be established and maintained for scheduling and implementing necessary testing and calibration of spent fuel pool level instrument channels to maintain the instrument channels at the design accuracy.

1E.2.7 Emergency Procedures Rulemaking (8.0)

NRC Recommendation

Strengthen and integrate onsite emergency response capabilities such as emergency operating procedures (EOPs), severe accident management guidelines (SAMGs), and extensive damage mitigation guidelines (EDMGs). This includes modification of Technical Specifications to reference the approved EOP technical guidelines and providing more realistic, hands-on training on SAMGs and EDMGs.

Response

STP 3 & 4 procedure development will integrate the EOPs, SAMGs, and EDMGs by using the following guidance:

- Industry (BWROG) guidance as endorsed by applicable NRC regulatory guides consistent with the Task Force recommendation (SECY-11-0124).
- Plant Specific Technical Guidelines (PSTGs), EOPs and SAMGs development activities using as inputs the standard ABWR guidelines (Sections 13.5 and 1A.2) and generic industry guidance per NEI 91-04, Revision 1, Severe Accident Issue Closure Guidelines, which includes the industry commitment to incorporate severe accident strategies into the overall accident management program.
- EDMGs development as described in NEI 06-12 (Mitigative Strategies Report).

Chapter 13 describes the procedure development plan.

The STP 3 & 4 Technical Specifications meet the requirement to reference the approved EOP Guidelines. (Technical Specifications 5.5.1.1.b)

Training development requirements in Section 13.2 and 13.4S will meet the applicable requirements for realistic hands-on training.

1E.2.8 Enhanced Emergency Plan Staffing and Communication (9.3)

NRC Recommendation

Assess current communications systems and equipment used during an emergency event assuming the potential onsite and offsite damage as a result of a large scale natural event resulting in a loss of all alternating current (AC) power. It is also requested that consideration be given to any enhancements that may be appropriate for the emergency plan with respect to communications requirements of 10 CFR 50.47, Appendix E to 10 CFR Part 50, and the guidance in NUREG-0696 in light of the assumptions stated above. Also consider the means necessary to power the new and existing communications equipment during a multi-unit event, with a loss of all AC power.

Assess current staffing levels and determine the appropriate staff to fill all necessary positions for responding to a multi-unit event during a beyond design basis natural event and determine if any enhancements are appropriate given the considerations of NTTTF Recommendation 9.3.

Response

The Emergency Plan for STP 3 and 4 will be part of a site-wide emergency plan for Units 1 through 4. The NRC recommendations will be addressed in the detailed Emergency Plan procedures developed during implementation of operational programs as described in Section 13.4S and in concert with STP Units 1 and 2. COLA Part 9 Table 4.0-1, Item 10 lists the ITAAC applicable to the Emergency Plan implementing procedures.

1E.3 Tier 2 NRC Recommendations/Responses

1E.3.1 Other Natural External Hazards (2.1)

NRC Recommendation

Reevaluate and upgrade as necessary the design basis of structures, systems, and components important to safety for protection against natural external hazards other than seismic and flooding.

Response

The hazards and natural phenomena potentially affecting the STP 3 & 4 site have been identified, screened and evaluated in accordance with the latest revisions of the Standard Review Plan. The review and conclusions are documented in Chapters 2 and 3 along with the appropriate design features necessary to mitigate the events. The natural events of particular interest at the STP site are hurricane wind and missiles. STP 3 & 4 meets the latest regulatory guidance document (RG 1.221) for hurricane winds and missiles, which is based on an extreme hurricane (Subsection 2.3S.1.3.3.2 and 3H.11).

1E.3.2 Safety-related AC electrical power for the SFP makeup system (7.2)

NRC Recommendation

NRC to issue an order requiring safety related AC power for the SFP makeup system.

In accordance with SECY-11-0137, Recommendation 7.2 will be implemented by rulemaking to provide reliable SFP instrumentation and makeup capabilities

Response

The STP 3 & 4 design provides emergency makeup to the SFP using any of the three trains of the RHR system, which is powered by safety-related AC power (Tier 1, Subsection 2.4.1).

1E.3.3 Technical Specifications requirement for onsite emergency power (7.3)

NRC Recommendation

NRC to issue an order to revise technical specifications to require that one train of onsite emergency power be operable for SFP makeup and instrumentation whenever spent fuel is in the SFP, regardless of the operational mode of the reactor.

In accordance with SECY 11-0137, Recommendation 7.3 will be implemented by rulemaking to provide reliable SFP instrumentation and makeup capabilities

Response

The STP 3 & 4 Technical Specifications require at least one Emergency Diesel Generator and one Residual Heat Removal (RHR) pump to be operable in all modes. The safety related RHR system is backed by the emergency diesel generators and can also be powered by the Combustion Turbine Generator. The RHR system is capable of providing makeup to the SFP.

1E.3.4 Spent Fuel Pool Spray (7.4)

NRC Recommendation

NRC to issue order requiring seismically qualified means to spray water into the spent fuel pools, including an easily accessible connection to supply the water (e.g., using a portable pump or pumper truck) at grade outside the building

In accordance with SECY 11-0137, Recommendation 7.4 will be implemented by rulemaking to provide reliable SFP instrumentation and makeup capabilities

Response

STP 3 & 4 has committed to install a diverse spent fuel pool makeup and spray system as described in Part 11 (Mitigative Strategies Report), Section 6.0 that meets the criteria specified in this recommendation

1E.4 References

- 1E-1 SECY-11-0137, "Prioritization of Recommended Actions to be taken in response to Fukushima Lessons Learned" October 3, 2011.
- 1E-2 SECY-12-0025, "Proposed Orders and Requests for Information in Response to Lessons Learned From Japan's March 11, 2011, Great Tohoku Earthquake and Tsunami"
- 1E-3 NEI 12-XX, "FLEX Implementation Guide, Rev. A2" February 2012 (DRAFT)
- 1E-4 SRM for SECY 12-0025, "Staff Requirements-SECY-12-0025 Proposed Orders and Requests for Information in Response to Lessons Learned from Japan's March 11, 2011, Tohoku Earthquake and Tsunami" March 9, 2012
- 1E-5 EA-12-049, "Issuance of Order to Modify Licenses with Regard to Requirements for Mitigation Strategies for Beyond Design-Basis External Events," March 12, 2012

- 1E-6 EA-12-050, "Issuance of Order to Modify Licenses with Regard to Reliable Hardened Containment Vents" March 12, 2012
- 1E-7 EA-12-051, "Issuance of Order to Modify Licenses with Regard to Reliable Spent Fuel Pool Instrumentation," March 12, 2012
- 1E-8 NUREG-2115, "Central and Eastern United States Seismic Source Characterization"
- 1E-9 SECY-11-0093, "The Near-Term Report and Recommendations for Agency Actions Following the Events in Japan," July 12, 2011

DRAFT