

**Official Transcript of Proceedings**  
**NUCLEAR REGULATORY COMMISSION**

Title: Advisory Committee on Reactor Safeguards  
593rd Meeting

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Friday, April 13, 2012

Work Order No.: NRC-1546

Pages 1-97

**NEAL R. GROSS AND CO., INC.**  
**Court Reporters and Transcribers**  
**1323 Rhode Island Avenue, N.W.**  
**Washington, D.C. 20005**  
**(202) 234-4433**

## DISCLAIMER

### UNITED STATES NUCLEAR REGULATORY COMMISSION'S ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

+ + + + +

593RD MEETING

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

FRIDAY

APRIL 13, 2012

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Advisory Committee met at the Nuclear  
Regulatory Commission, Two White Flint North, Room  
T2B3, 11545 Rockville Pike, at 8:30 a.m., J. Sam  
Armijo, Chairman, presiding.

COMMITTEE MEMBERS:

- J. SAM ARMIJO, Chairman
- JOHN We. STETKAR, Vice Chairman
- HAROLD B. RAY, Member-at-Large
- SAID ABDEL-KHALIK, Member
- SANJOY BANERJEE, Member
- CHARLES H. BROWN, JR. Member
- MICHAEL L. CORRADINI, Member
- DANA A. POWERS, Member

1 JOY REMPE, Member  
2 MICHAEL T. RYAN, Member  
3 STEPHEN P. SCHULTZ, Member  
4 WILLIAM J. SHACK, Member  
5 JOHN D. SIEBER, Member  
6 GORDON R. SKILLMAN, Member

7

8 NRC STAFF PRESENT:

9 JOHN LAI, Designated Federal Official

10 ERIC E. BOWMAN, NRR/DPR

11 SUSAN E. COOPER, RES/DRA

12 RICHARD CORREIA, RESPONSIBILITY

13 KIM MORGAN BUTLER, NRR/DPR

14 SEAN PETERS, RES

15 MARK HENRY SALLEY, RES/DRA

16

17 ALSO PRESENT:

18 ERIN COLLINS, SAIC\*

19 JEFF JULIUS, Scientech

20 KAYDEE KOHLHEPP, Scientech\*

21 STUART LEWIS, EPRI

22

23 \*Present via telephone

24

25

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

A-G-E-N-D-A

Opening Remarks by the ACRS Chairman . . . . . 4

Draft Final NUREG-1921, "Fire Human  
Reliability Analysis (HRA) Guidelines" . . . . . 6

Staff Assessment of Responses to  
NRC Bulletin 2011-01,  
"Mitigating Strategies" . . . . . 74



**EPRI**

ELECTRIC POWER  
RESEARCH INSTITUTE



**SAIC**

# **EPRI/NRC-RES FIRE HRA GUIDELINES, NUREG-1921/EPRI 1023001**

Mark Henry Salley and Susan E. Cooper (NRC/RES/DRA)  
Stuart Lewis (EPRI)

ACRS Full Committee Meeting  
April 13, 2012  
Rockville, MD


*A Collaboration of U.S. NRC Office of Nuclear Regulatory Research (RES) & Electric Power Research Institute (EPRI)*

# Today's Presentation

- Short history and background of the project
- Project objectives
- Examples of challenges
- Industry perspective
- Review, Testing and Trial Applications
- Uses for other HRA projects

**Project Team requests letter from ACRS**

# Evolution of the Fire HRA Guidelines





# Background on Fire HRA

## Status of fire PRA at project initiation

- About half of US NPPs transitioning to NFPA-805
- NUREG/CR-6850 [EPRI 1011989] provided detailed guidance for fire PRA to support transition to NFPA-805

## HRA for fire PRA

- Guidance in NUREG/CR-6850
  - Conservative screening human error probabilities (HEPs)
  - Performance shaping factors (PSFs)
- Needs beyond NUREG/CR-6850
  - Approach for detailed/best-estimate HRA
  - Guidance to satisfy requirements in PRA Standard

# Objectives of Fire HRA Guidelines

- Address HRA needs beyond NUREG/CR-6850
  - Detailed quantification method for fire PRA context
  - Treatment of relevant PSFs
  - Steps to satisfy PRA Standard requirements
- Satisfy NRR User Need 2008-003, Rev. 1, Task 13
  - “...expand existing HRA methods ... to incorporate the effect of fires in full-power PRA models.”

**Pursued via joint EPRI/NRC MOU analogous to NUREG/CR-6850  
(third major joint fire-related project)**

# Examples of challenges addressed

- Need for advances in state-of-the-art for fire HRA
  - Full delineation of HRA process for fire context
  - Feasibility of human actions
  - Guidance for:
    - Response to spurious signals/actuators from cable failures
    - Potential errors of commission (EOCs)
    - Distractions in control room
    - Uncertainties (e.g., for timing information)
  - Appropriate quantification methods
    - New scoping approach
    - Adaptation of (two) existing methods for detailed analysis
  - Implications for ex-control room actions

# Examples of challenges addressed (continued)

- Piloting of methods and guidance
- Guidance to meet evolving requirements in PRA Standard
- Evolving approaches to implementing fire PRA tasks
- Continuing improvements to fire procedures in plants
- Need to develop training material in parallel with report

# Industry Perspective

- Focus has been on
  - Assuring guidance meets technical needs of users
  - Ensuring adequate review, testing and trial application
  
- Important attributes of technical approach
  - Addresses range of fire response strategies in place at plants
  - Coordinates with development of actual fire PRA models
  - Capable of producing useful insights
  - Consistent with HRA for internal events

# Review, Testing and Trial Application

- Peer review (June 2008)
- Pilot applications
  - Scoping tested by project team at two NPPs (2008)
  - Pilot by PWR Owners Group (2009)
- Public review of full draft (early 2010)
- Applications
  - Use of draft guidance to complete fire PRAs (eight sites, all with peer reviews)
  - Feedback from students in training courses (2010 and 2011)
- Review by ACRS Subcommittee on Reliability and PRA

**All elements tested via variety of applications**

# Review, Testing and Trial Application (cont'd)

## Examples of changes to report from feedback

- Increased guidance on qualitative analysis (especially feasibility assessments)
- Simplified scoping approach to quantification
- Modified timing considerations for scoping approach
- Enhanced guidance for walkthroughs/talkthroughs
- Expanded treatment of spurious actuations/operations
- Simplifications in recovery analysis, dependency analysis, and uncertainty

**Review and experience substantially improved Guidelines**

# Advances Beneficial to Other Projects

- Fire HRA guidelines directly benefit other NRC HRA projects
  - New HRA development per SRM M061020
  - Site-wide Level 3 PRA Project
- Commonality of team members among projects facilitates coordination



# Advances from Fire HRA Guidelines: Examples

- Comprehensive guidance for all steps in HRA process
- Examples on how to address PRA Standard requirements
- Integration of HRA with larger PRA study
- Example of a quantification approach that addresses traceability concerns (i.e., scoping fire HRA approach)
- Detailed guidance on feasibility assessments
- Guidance on HRA tasks for ex-control room actions and challenging environmental conditions
- Framework for HRA for other challenges, e.g.,
  - Seismic PRA

# Examples of Advances (continued)

- Situations involving problems with cues and distractions
- Development of timing estimates (including treatment of uncertainties)
- Use of procedures other than EOPs
- Training materials for all HRA process steps

# Conclusions

- Project objectives have been satisfied
  - Comprehensive, useful guidance for fire HRA
  - Approach refined through testing and application in production PRAs
- Elements of Guidelines of significant value to other HRA research and development

**Project Team requests letter from ACRS**





# U.S. NRC

UNITED STATES NUCLEAR REGULATORY COMMISSION

*Protecting People and the Environment*

## **RISK-INFORMED REGULATORY FRAMEWORK FOR NEW REACTORS**

### **Advisory Committee on Reactor Safeguards**

Contacts: Don Dube, NRO/DSRA, 301-415-1483  
Ron Frahm, NRR/DIRS, 301-415-2986

**April 12, 2012**



# Meeting Purpose

**Discuss staff's response to the SRM  
on SECY-10-0121 and request a letter**

# Agenda

- **Brief background**
- **Tabletop exercise results**
  - **RITS 4b, completion times**
  - **Reactor oversight process**
- **Conclusions, options and recommendations in draft paper**

# **Options Provided in SECY-10-0121**

- 1) No changes to existing risk-informed guidance (status quo)**
- 2) Implement enhancements to existing guidance to prevent significant decrease in enhanced safety (NRC staff recommendation)**
- 3) Develop lower numeric thresholds for new reactors**



# **Commission SRM**

## **Dated March 2, 2011**

- **Commission approved a hybrid of Options 1 and 2**
  - Continue existing risk-informed framework pending a series of tabletop exercises that test existing guidance
- **Commission “reaffirms” existing**
  - safety goals
  - safety performance expectations
  - subsidiary risk goals and associated risk guidance
  - key principles (e.g., RG 1.174)
  - quantitative metrics
- **New reactors with enhanced margins and safety features should have greater operational flexibility than current reactors**

# Tabletop Exercises

- December 2, 2010: 50.59-like change process for ex-vessel severe accident (EVSA) design features under Section VIII.B.5.c of each design certification rule
- May 4, 2011: Risk-informed inservice inspection of piping
- May 26, 2011 and June 1, 2011: Risk-Informed Technical Specifications (RITS) Initiative 4b on completion times and the Maintenance Rule (a)(4)
- June 29, 2011: RITS Initiative 5b (surveillance frequency control program)
- August 9, 2011: 50.69 and guidance in NEI 96-07 Appendix C on the change processes for Part 52 specific to EVSA design features
- October 5, 2011: RG 1.174; transition options from large release frequency (LRF) as a risk metric to large early release frequency (LERF); and ROP risk-informed case studies including SDP, reactive inspections under Management Directive 8.3, and MSPI
- October 26, 2011: Follow-up discussions with stakeholders on the ROP

## Major Conclusions

- During the tabletop exercises for licensing applications, the staff did not identify any potentially significant decreases in the enhanced safety margins for new reactors
- Identified potential gap in the Tier 2 change process regarding severe accident features that are not related to ex-vessel severe accident prevention and mitigation
- Current risk thresholds are appropriate for ROP; however, a few changes to the ROP may be warranted consistent with the integrated risk-informed principles in RG 1.174

# Key Tabletop Exercise Results

- **RITS 4b (completion times): Two key programmatic controls**
  - The risk-informed completion time is limited to a deterministic maximum of 30 days (referred to as the backstop completion time) from the time the TS action was first entered
  - Voluntary use of the risk-managed TS for a configuration which represents a loss of TS specified safety function, or inoperability of all required safety trains, is not permitted

# AP1000: RITS 4b Case Study

<b>Class 1E DC System (IDS)</b>			
<b>Division A</b>	<b>Division B</b>	<b>Division C</b>	<b>Division D</b>
1 - 24hr Battery	1 - 24hr Battery	1 - 24hr Battery	1 - 24hr Battery
	1 - 72hr Battery	1 - 72hr Battery	

<b>Passive Core Cooling (PXS)</b>	
<b>DVI Line A</b>	<b>DVI Line B</b>
Accum.-A (CKV)	Accum.-B (CKV)
CMT-A (CKV)	CMT-B (CKV)
IRWST-A (MOV)	IRWST-B (MOV)
IRWST-A (CKV1)	IRWST-B (CKV1)
IRWST-A (CKV2)	IRWST-B (CKV2)

# AP1000 SPAR Model Results


RITS 4b Case	Equip. Not Functional	CDF (/yr)	$\Delta$ CDF (/yr)	Calc Completion Time (days)	Tech. Spec. Limit (hrs)	Allowed Completion Time (days)	ICDP	Other Available Equip
Base	None (no T&M)	2.1E-07	--	--	--	--	--	All
1	1 - 1E-DCP-A (DC/AC)	5.9E-07	3.8E-07	9623	6	30	3.1E-08	1 - 24hr division and 2 - 24/72hr divisions
7*	1 IRWST Injection Line-B	1.1E-04	1.1E-04	33	1	[1hr]	[1.3E-08]	2 Accum., 1 IRWST ILs (2 flow paths), 2 PHRHs flow paths, and 2 CMTs
9-A*	1 CMT-A and 1 Accum.-A	1.6E-04	1.5E-04	24	CMT - 1 Accum. - 1	[1hr]	[1.8E-08]	1 Accum., 2 IRWST ILs (4 flow paths), 2 PHRHs flow paths, and 1 CMT

## Key Tabletop Results (cont.)

- **RITS 4b staff exercises**
  - Staff identified some configurations of equipment outages that would represent 10 years' worth of core damage probability
  - Repeated entry into such condition over time could increase CDF by one or more orders of magnitude, which could approach the baseline CDF of currently operating plants
  - Staff believes these configurations are unlikely or unrealistic, and that there were additional regulatory and programmatic controls that would limit the aggregated risk increase (e.g., performance monitoring, periodic PRA maintenance and upgrade under 50.71(h))
- **Staff concludes no substantive changes to methodology is necessary**



# Tier 2 Change Process: Gap identified for ex-vessel severe accident features






## Recommendation 1

Address the potential gap, by a) ensuring that there are sufficient details on all key severe accident features in Tier 1, and b) including a change process in future design certification rulemakings in Section VIII for *non-ex-vessel severe accident features* similar to Section VIII.B.5.c for *ex-vessel severe accident features*

# LRF-to-LERF Transition

- **LRF vs. LERF**
  - Commission goals for new reactors are based on a conditional containment failure probability (CCFP) of less than 0.1, and a LRF of less than  $10^{-6}/\text{yr}$ , as well as  $10^{-4}/\text{yr}$  for core damage frequency (CDF)
  - Operating reactors use CDF and LERF as risk metrics
- **LRF issues**
  - LRF (and CCFP) have not been defined by the staff
  - Each design center has chosen different definitions
  - LERF is used in the ASME/ANS level 1 PRA standard, in risk-informed staff guidance (e.g., RG 1.174), and ROP
  - No existing or proposed level 2 PRA standard provides a universal definition of LRF

# Recommendation 2: Option 2C



- LERF calculated at or prior to initial fuel load. CDF & LERF used for RG 1.174 acceptance guidelines going forward.
- Last regulatory use of LRF & CCFP
- Continue to meet containment performance objective following core damage per SECY-90-016 and SECY-93-087

# Tabletop Results on Other Licensing and Operational Programs

- **50.65(a)(4) – no gaps**
  - Defense in depth and plant transient assessment often more limiting in terms of risk management action level
- **RITS 5b (surveillance frequency) – no gaps**
  - Much more deterministically oriented, with risk impact only a secondary consideration in the criteria for changing surveillance test interval
- **50.69 (SSC categorization) – no gaps**
  - Rule has built-in measures to monitor RISC-3 components and take corrective actions (e.g., periodic program review every 2 refuel cycles)
- **RG 1.174 – no gaps**
  - Considerations such as defense in depth and margin of safety often more limiting than risk impact

# ROP Tabletop Approach

- Tested various realistic scenarios to confirm the adequacy of the current ROP risk-informed processes for regulatory decision-making or identify areas for improvement
- Used a broad cross-section of well-vetted cases, developed from actual greater-than-green examples from the current fleet of reactors:
  - Significance Determination Process (SDP) findings
  - Mitigating Systems Performance Index (MSPI) data
  - Management Directive (MD) 8.3 applications
- Applied similar situations to the new reactor designs, filling in gaps with realistic hypothetical situations and reasonable assumptions, and then compared the risk values and resultant regulatory response

## RESULTS

- Existing risk thresholds for determining significance of inspection findings are generally acceptable
- Greater-than-green inspection findings would likely involve common cause failures and/or long exposures of risk-significant components
- Existing process does not always ensure an appropriate regulatory response for degradation of passive components and barriers

## CONCLUSION

- SDP analyses could be augmented with additional qualitative considerations (deterministic backstop) to appropriately address performance issues

### RESULTS

- Existing risk thresholds for invoking reactive inspections are adequate for new reactors
- Deterministic criteria used initially for event screening and then within a range of response determined by risk values
- Risk values heavily influence whether or not a reactive inspection is warranted and, if so, at what level
- Variations in or minor revisions to risk models used can potentially result in an inadequate response

### CONCLUSION

- Contribution of existing deterministic criteria could be modified or new deterministic criteria developed for initiating reactive inspections for new reactors

## RESULTS

- Existing MSPI is not adequate and would be largely ineffective in determining an appropriate regulatory response for active new reactor designs
- Meaningful MSPI may not even be possible for passive systems using the current formulation of the indicator
- Existing performance limit (backstop) could be further leveraged for active new reactor designs

## CONCLUSION

- Alternate PIs in the mitigating systems cornerstone could be developed and/or additional inspection could be used to supplement insights currently gained through MSPI



## **OBJECTIVES FOR ROP OPTIONS**

- Maintain current risk thresholds for new reactor designs
- Consistent with integrated risk-informed decision-making concepts in RG 1.174
- Afford greater operational flexibility based on enhanced safety margins

### **A. USE AS IS**

- Use the existing risk-informed ROP tools for new reactor applications without making any changes
- No additional action or resources needed, but existing tools may not always provide for an appropriate regulatory response

### **B. AUGMENT EXISTING PROCESSES**

- SDP: Use existing risk-informed SDP, but augment with deterministic backstops to ensure an appropriate regulatory response to address performance issues
- MD 8.3: Modify the contribution of existing deterministic criteria or develop new criteria for determining the appropriate regulatory response to plant events
- MSPI: Develop alternative to MSPI or augment existing guidance to emphasize performance limit for active new reactor designs, and increase inspection of passive mitigating systems for passive new reactor designs
- Proposed enhancements could be developed using existing resources and working with stakeholders

### **C. DEVELOP DETERMINISTIC TOOLS**

- Do not use the existing risk-informed ROP tools
- Capture risk insights to a lesser extent than the current fleet using deterministic guidance consistent with new reactor design certification and licensing basis
- Additional resources may be necessary to research and develop the new guidance documents

### **Staff Recommendation: Option B**


- Staff would obtain Commission approval for proposed changes to ROP at least one year prior to implementation
- Process enhancements could be further refined based on experience and lessons learned

## **Next steps**

- **Finalize Commission paper based on ACRS and stakeholder feedback**
- **SECY due to be issued early June, 2012**

# SFP Zirc-Fire Research Overview

## Phase 1 Testing



This Phase 1 bundle is a detailed PWR assembly (17 by 17). This testing includes the complex thermal hydraulic conditions that strongly impact the reaction kinetics of Spent Fuel Pool LOCAs. It is unfortunate that NRC has not applied similar resources in responding to PRM-76. Instead, NRC repeatedly extols its programs that sidestep the role of the reaction kinetics during LOCAs.

**In promoting the denial of PRM-50-76 on June 29, 2005, ML050250359, the NRC Staff asserted:**

*According to him (Robert H. Leyse), it is fundamentally important that the determinations of LOCA transient chemical kinetics include the geometry of the stationary Zircaloy reactant in combination with the thermal-hydraulic conditions of the flowing-water/steam reactant.*



# **Presentation to the ACRS Full Committee – 593<sup>rd</sup> Meeting**

**Briefing on Calvert Cliffs Unit 3 COL Application Safety Evaluation  
Reports with Open Items for FSAR Chapters 6, 7, 15, and 18**

**Surinder Arora  
Project Manager**

**April 12, 2012**

# Major Milestones - Chronology

DATE	MAJOR MILESTONE
07/13/2007	Part 1 of the COL Application (Partial) submitted
12/14/2007	Part 1, Rev. 1, submitted
03/14/2008	Part 1, Rev. 2, & Part 2 of the Application submitted
08/01/2008	Revision 3 submitted
03/09/2009	Revision 4 submitted
06/30/2009	Revision 5 submitted
07/14/2009	Review schedule published
09/30/2009	Revision 6 submitted
04/12/2010	Phase 1 review completed
12/20/2010	Revision 7 submitted
11/15/2011	ACRS reviews complete for Chapters 2 (Group I), 4, 5, <b>6, 7</b> , 8, 10, 11, 12, <b>15</b> , 16, 17, <b>18</b> & 19
03/27/2012	Revision 8 submitted

# Review Schedule

<b>Phase - Activity</b>	<b>Target Date</b>
<b>Phase 1</b> - Preliminary Safety Evaluation Report (SER) and Request for Additional Information (RAI)	April 2010 (Actual)
<b>Phase 2</b> - SER with Open Items	Schedule under Review
<b>Phase 3</b> – Advisory Committee on Reactor Safeguards (ACRS) Review of SER with Open Items	Schedule under Review
<b>Phase 4</b> - Advanced SER with No Open Items	Schedule under Review
<b>Phase 5</b> - ACRS Review of Advanced SER with No Open Items	Schedule under Review
<b>Phase 6</b> – Final SER with No Open Items	Schedule under Review

NOTE: The target dates for Phase 2 to 6 are currently being evaluated based on the RAI response dates provided by UniStar in their February 21, 2012 letter.



# Review Strategy

- Pre-application activities
- Acceptance Review of the application
- COLA has chapters and sections incorporated by Reference
- Review of COLA site specific information in conjunction with the DC review. Same technical reviewers in most cases.
- Generic Open Item that ties DC and COLA Reviews
- Frequent interaction with the applicant via
  - ♦ Teleconferences
  - ♦ Audits
  - ♦ Public meetings
- Use of Electronic RAI (eRAI) System
- Phase discipline

# Summary of SER with OI: Chapter 6 Engineered Safety Features



SRP Section/Application Section		Number of RAI Questions	Number of SE Open Items
6.1.1	Metallic Materials	1	0
6.1.2	Organic Materials	3	0
6.2.1 6.2.2 6.3	Containment Functional Design Containment Heat Removal Emergency Core Cooling System	These Sections were not delivered in the Phase 2 SE	N/A
6.2.3 6.2.4 6.2.5 6.2.7 6.5	Secondary Containment Functional Design Containment Isolation System Combustible Gas Control in CTMT Fracture Prevention of CTMT Pressure Vessel Fission Product Removal & Control Systems	IBR	0
6.2.6	Containment Leakage Testing	0	0
6.4	Habitability Systems	6	2
6.6	Inservice Inspection of ASME Class 2 & 3 Components	0	0
Totals		10	2

# Summary of SER with OI: Chapter 7 Instrumentation and Controls

<b>SRP Section/Application Section</b>		<b>Number of RAI Questions</b>	<b>Number of SE Open Items</b>
7.1	Introduction	2	0
7.5	Information Systems Important to Safety	2	2
7.7	Control Systems	1	1
7.9	Data Communication Systems	1	0
Totals		6	3

# Summary of SER with OI: Chapter 15 Transient and Accident Analyses

SRP Section/Application Section		Number of RAI Questions	Number of SE Open Items
15.0	Transient and Accident analysis (except Section 15.0.3)	0	0
15.0.3	Radiological Consequences of Design Basis Accidents	1	0
Totals		1	0

# Summary of SER with OI: Chapter 18 Human Factors Engineering

SRP Section/Application Section		Number of RAI Questions	Number of SE Open Items
18.8	Procedure Development	1	0
18.12	Human Performance Monitoring	1	0
Totals		2	0



**Advisory Committee on Reactor Safeguards (ACRS)  
License Renewal Full Committee  
Columbia Generating Station (Columbia)  
Safety Evaluation Report (SER)**

April 12, 2012

Arthur Cunanan, Project Manager  
Office of Nuclear Reactor Regulation

# Presentation Outline

- Overview
- Closure of Open Items
  - Operating Experience
  - High-Voltage Porcelain Insulators
  - Crane Load Cycle Limit
  - Upper-Shelf Energy
  - Metal Fatigue
  - Core Plate Rim Hold-Down Bolts
- Conclusion

# Overview

- Safety Evaluation Report (SER) with Open Items was issued August 30, 2011
- The Open Items for the SER are closed
- Region IV Administrator's Letter of Recommendation received February 27, 2012
- The final SER was issued February 28, 2012



# Internal Corrosion of Buried Piping

- Applicant determined that the buried pipe that leaked was out-of-scope piping and it did not fail due to internal corrosion
- Internal corrosion of buried and aboveground piping is age managed by several programs
- Based on recent operating experience at other plants, the staff is developing an ISG to provide guidance for plant-specific programs

# **SER Section 3 Closure of Open Items**

## **SER Section 3.0.5 – Operating Experience**

Activities will be implemented throughout the term of the renewed license to:

- Capture, identify, process, and evaluate plant-specific and industry operating experience related to aging
- Implement changes to the aging management activities as identified through operating experience evaluations
- Provide training on aging to those personnel that screen, evaluate, and submit operating experience
- Report plant operating experience on aging to the industry

# **SER Section 3 Closure of Open Items**

## **SER Section 3.0.3.3.7— High-Voltage Porcelain Insulators**

High-voltage post insulators at the 230 kV Ashe Substation are included in the AMP with testing every 8 years and cleaning if needed

# **SER Section 4 Closure of Open Items**

## **SER Section 4.1.2.9 – TLAA Identification (Crane Load Cycle Limit)**

- The applicant stated that the analyses for cranes are TLAA's
- The applicant dispositioned the TLAA's under 10 CFR 54.21(c)(1)(i) that the analyses remain valid during the period of extended operation

# **SER Section 4 Closure of Open Items**

## **SER Section 4.2.2 – Upper-Shelf Energy**

Applicant projected upper shelf energy (USE) for the N12 nozzle forgings to 54 EFPY, and justified:

- The initial USE of 62 ft-lbs
- The copper content of 0.27 percent

Staff verified applicant's analysis that the USE for the N12 nozzle will remain > 50 ft-lbs at the end of vessel life IAW 10 CFR Part 50 Appendix G

# **SER Section 4 Closure of Open Items**

## **SER Section 4.3 – Metal Fatigue Environmentally-Assisted Fatigue (EAF)**

- The applicant addressed EAF for components beyond those identified in NUREG/CR-6260
- Audit was able to:
  - review the applicant’s methodology for selecting additional plant-specific locations
  - confirm locations screened-out for review of EAF were appropriate
  - conclude that EAF has been assessed for the applicant’s plant configuration

# **SER Section 4 Closure of Open Items**

## **SER Section 4.7.4 – Core Plate Rim Hold-Down Bolts**

- Applicant evaluated this TLAA under 10 CFR 54.21(c)(1)(iii) and provided AMR line items for the core plate rim hold-down bolts
- Applicant also committed to install core plate wedges at least two years prior to the period of extended operation
- Staff intends to issue a license condition requiring the applicant to install wedges on or before December 20, 2021

# Conclusion

On the basis of its review, the staff determines that the requirements of 10 CFR 54.29(a) have been met for the license renewal of Columbia Generating Station





**U.S. NRC**

UNITED STATES NUCLEAR REGULATORY COMMISSION

*Protecting People and the Environment*

# **Spent Fuel Pool (SFP) Scoping Study**

Katie Wagner

General Engineer

Office of Nuclear Regulatory Research


Briefing for the Advisory Committee on Reactor Safeguards  
(ACRS)

*April 12, 2012*

# Background

- The agency has a rich regulatory basis for its current position on spent fuel storage
- A number of events (e.g., change in path forward on long-term storage; Fukushima accident) motivated re-assessment of the underlying knowledge base
- To launch this re-assessment, an expedited limited-scope consequence study was undertaken (to provide insights in 1 year)
  - Objective: to re-examine the impact of moving older spent fuel to dry cask storage in an expedited manner
- Results from this study will inform a regulatory decision-making process guided by the “Tier 3” Japan Lessons-Learned item entitled Transfer of Spent Fuel to Dry Cask Storage (referenced in SECY-12-0025)

# Timeline of Major SFP-related Activities



# Motivation for Focusing on SFP Seismic Hazards

Spent fuel storage considerations include:

- SFP Seismic Hazards
- Dry Cask Storage Risk (e.g., NUREG-1864)
- Cask Drop Hazards for SFPs (e.g., NUREG-1738)
- Repackaging For Transportation
- Fuel Storage Infrastructure (e.g., 2010 EPRI study)
- Worker Dose (e.g., 2010 EPRI study)
- Emergency Preparedness (e.g., NUREG-1738)
- Part 50, 72 & 73 Regulatory Requirements
- Multi-Unit Risk (e.g., SECY-11-0089 project)
- Design/Operation Differences Between Sites
- Boraflex Degradation & Inadvertent Criticality
- Protection Against Malevolent Acts (e.g., post-9/11 security assessments)
- Other SFP Hazards (e.g., NUREG-1353)
- Actions in Response to Japan Events (e.g., Near-Term Task Force Recommendation 7)



**SFP  
Seismic  
Hazard**

*Past studies have indicated that SFP seismic hazard is an important piece of overall spent fuel risk.*


*For this reason, SFP seismic hazard is the logical place to start in probing the continued applicability of past studies and developing insights for the current spent fuel storage situation.*

*Depending on the results gained from the study, additional work might be necessary to obtain a more holistic answer.*


# Motivation for Seismic Study

Annual frequency of SFP fuel uncoverly as reported in previous SFP risk studies

## NUREG-1353\*



## NUREG-1738\*\*



\*BWR, best estimate results

\*\*Based on Livermore hazard curves which generally more closely match the updated USGS curves for the studied plant

Past SFP risk studies indicate that seismic hazard is the most prominent contributor to SFP fuel uncoverly. While these studies have known limitations, this is sufficient motivation to focus on this class of hazards in the SFPSS.

# Overview of Spent Fuel Pool Scoping Study (SFPSS)

- Focus: re-examine the potential impacts on SFP safety in the event of a challenging, beyond-design-basis seismic event
- Emphasis is given to acquiring timely results for ongoing deliberations and external stakeholder interest. The project is using:
  - Available information / methods
  - A representative operating cycle for a BWR Mark I (Peach Bottom)
  - Past studies to narrow scope
- Plan finalized in July 2011; study results to be sent to NRR: June 2012
- The closely related Japan Lessons Learned Tier 3 item from SECY-12-0025 (Transfer of Spent Fuel to Dry Cask Storage) addresses the bigger picture, with SFPSS being a key component

# Technical Approach

- Two conditions to be considered:
  - Representative of the current situation for the selected site (i.e., high-density loading and a relatively full SFP)
  - Representative of expedited movement of older fuel to a dry cask storage facility (i.e., low-density loading)
- Elements of the study include
  - Seismic and structural assessments based on available information to define initial and boundary conditions
  - SCALE analysis of reactor building dose rates
  - MELCOR accident progression analysis (effectiveness of mitigation, fission product release, etc.)
  - Emergency planning assessment
  - MACCS2 offsite consequence analysis (land contamination and health effects)
  - Probabilistic considerations

# **Seismic and Structural Methods**

*Jose Pires*

Senior Structural Engineer  
Office of Nuclear Regulatory  
Research




# Prescribed Seismic Scenario

- Seismic event: 0.5 g to 1.0 g peak ground acceleration (PGA)
  - Challenging event, but very low frequency of occurrence (one event in 61,000 years)
    - OBE is 0.05g
    - SSE is 0.12g
    - Scenario PGA is 0.71 g -- It is about 6 times that for the SSE and beyond the seismic design basis for Eastern US plants
  - USGS hazard data and models (2008) being used as starting seismic hazard model
- Review of past studies indicates that less severe events would not challenge the SFP

# Seismic Input

- Objective: to provide initial ground motion characteristics
  - Site Ground Motion Response Spectrum (GMRS)
- Rock site
- USGS Hazard Assessments (2008) used to obtain site GMRS (Similar to GI-199 resolution)
  - Site GMRS scaled up to obtain input ground motion spectra for the 0.71 g scenario
- Site GMRS rich in high frequencies (10 to 25 Hz)

# Seismic Input





Comparison of ground motion spectra: this study, SSE, and spectrum for the NUREG-1150 PRA (scaled to the SSE PGA) (NUREG/CR-4550)


# Structural Input

- Objective: to determine starting point for subsequent accident progression analysis
- Approach:
  - Generally follows approach used for GI-82 (NUREG/CR-5176)
    - Enhanced to address specific study aspects (Finite Element Modeling)
  - Uses in-structure response spectra (accelerations) calculated for the NUREG-1150 study (NUREG/CR-4550, Vol. 4, Part 3)
    - Scaled for increased PGA (from 3xSSE to about 6xSSE)
    - Scaled to account for high frequency content in the site GMRS
  - Uses 3D nonlinear finite element analysis of the SFP structure and its supports (subjected to equivalent static loads) to calculate:
    - Displacements, concrete and reinforcement strains and stresses, structural distortion, and liner strains

# Reactor Building and SFP



## SFP Details



**Used to generate 3D finite element models of the SFP structure and its supports**

# Structural Input



- **Simpler approaches to assess damage to:**
  - Penetrations, support systems, AC and DC power, other SSCs necessary for accident mitigation (e.g., building housing a portable diesel pump), other structures
- **Approximations / assumptions**
  - Effects of ground motion incoherency on high-frequency components of floor spectra approximated (possible conservatism)
  - Floor spectra do not account for coupling of SFP components to building (possible conservatism)
    - Hydrodynamic pressures based on scaled floor response spectra
    - Dynamic time-history analyses of the whole reactor building including the SFP were not done at this stage
  - Seismic loads from spent fuel racks and assemblies approximated
    - May need adjustment based on the analysis reports submitted by the licensee at the time of the license amendment for high density loading
  - Uses the SFP damage state to envelope potential leakage from the transfer gate, reactor piping, or dryer pool
- **Starting conditions for accident progression analysis**
  - Binned into a few discrete states with relative likelihood estimates

# **Scenario Delineation, Accident Progression Methods, and Consequence Analysis Methods**

*Don Helton*

Senior Risk and Reliability Engineer  
Office of Nuclear Regulatory  
Research

# Illustration of Pool Decay Heat and Operating Cycle Phases (OCPs)





# Mitigation Assumptions

- For high-density loading, two alternatives are considered for required arranging of recently discharged fuel in to a pattern that facilitate passive cooling:
  - pre-arrangement
  - arrangement following the outage
- For scenarios not including mitigative actions:
  - No operator action is considered
- For scenarios including mitigative actions:
  - Diagnosis is assumed to take until SFP level drops 5 feet + 30 minutes for observation/decision-making (recall unavailability of AC power)
  - Capacities / timings generally follow underlying endorsed guidance in NEI-06-12, Revision 2
  - Once deployed, equipment runs indefinitely
    - Represents successful arrival of offsite support or deployment of other onsite assets
- Effectiveness is determined by MELCOR





## Other Issues Not Addressed in Defining Scenarios

- Full core offload outages for vessel inspections
    - Not the typical situation for BWRs
  - Presence of new fuel in the SFP as source of zirconium
    - Present for a short period of time
  - Multi-unit effects
    - Only addressed until reactor/SFP become hydraulically decoupled
    - A focus of a recently initiated site Level 3 PRA project
  - Inadvertent criticality events
  - Recovery and repair actions
- The intent is to address as many uncertainties as practical via sensitivity studies


# Use of MELCOR for SFP Analysis

## Analysis


## Experimental studies



# High-Density Post-Outage SFP MELCOR Model



# Low-Density Post-Outage SFP MELCOR Model




# Offsite Consequence & Emergency Preparedness Modeling

- MACCS2 code will be used
  - Input: Accident source term (from MELCOR/ORIGEN), weather, population and economic data, protective measures
  - Output: Consequences (e.g. contamination, health effects) from atmospheric release
- Modeling will leverage best practices from draft NUREG-1935 (SOARCA)
- Population and economic data updated for 2011
- Emergency preparedness considerations
  - Pennsylvania specific evacuation
  - Cohorts to represent different groups of the public
  - Road network
  - Scenario-specific



# MACCS2 Modeling: Atmospheric Release and Exposure Pathways

MACCS2 models the radioactive release to the atmosphere (e.g. plume rise, dispersion, dry and wet deposition)



MACCS2 estimates the health effects from: inhalation, cloudshine, groundshine, skin deposition, and ingestion (e.g. water, milk, meat, crops)

# Consequence Modeling & Reporting

- Consequence Modeling (continued):
  - Stochastic health effects (e.g. latent cancer fatalities)
  - Three dose response models
    - Linear, no threshold (LNT) hypothesis
    - Linear, low-dose truncation - 620 mrem/yr (U.S. average dose)
    - Linear, low-dose truncation - 5 rem/yr or 10 rem lifetime (HPS position)
  - Deterministic health effects (e.g. early fatalities)
  - Federal Guidance Report 13
    - Most current federal guidance published by EPA
- Consequence Reporting:
  - Health Effects - conditional risk of early fatalities and latent cancer fatalities as related to distance from the site. (Ideal for informing individual members of the public)
  - Land Contamination - total land contamination for the site region above a specified dose level (e.g., the habitability criterion for the selected site of 500 mrem/year)



# **Concluding Remarks and Questions**

*Katie Wagner*

# Coordination and Communication

- SECY paper to be submitted in July 2012 will include a plan for the resolution of the broader item on expedited transfer of spent fuel to dry cask storage
  - Commitment was made in SECY-12-0025
- Input from program offices
- Briefings for Senior Management and Commissioners
- Interactions with licensee
- Consider feedback provided by the ACRS
- A communication plan has been drafted
- Study results to be sent to NRR by: June 2012

# SFPSS Project Team and Other-Office Working Group Representatives

- Katie Wagner – Overall project lead
- Hossein Esmaili – Accident progression lead
- Don Helton – Boundary conditions and probabilistic aspects lead
- Andy Murphy – Seismic analysis lead
- AJ Nosek – Offsite consequence lead
- Jose Pires – Structural analysis lead

## Working Group Members

- NMSS – Drew Barto
- NRO – Eric Powell, Bret Tegeler
- NRR – Steve Jones, Jeff Mitman, Eric Bowman, Kent Wood, Rick Ennis
- NSIR – Randy Sullivan, Eric Schrader

# Acronym List

- 3D = Three-Dimensional
- AC = Alternating Current
- BWR = Boiling Water Reactor
- COBRA-SFS = COBRA Spent Fuel Storage
- DC = Direct Current
- GI = Generic Issue
- GMRS = Ground Motion Response Spectra
- HPS = Health Physics Society
- LNT = Linear No Threshold
- MACCS2 = MELCOR Accident Consequence Code System
- MELCOR – Not an acronym
- NMSS = Office of Nuclear Material Safety and Safeguards
- NRO = Office of New Reactors
- NRR = Office of Nuclear Reactor Regulation
- NSIR = Office of Nuclear Security and Incident Response
- OBE = Operating Basis Earthquake
- OCP = Operating Cycle Phase
- ORIGIN = Oak Ridge Isotope Generator
- PGA = Peak Ground Acceleration
- PRA = Probabilistic Risk Assessment
- SCALE – Not an acronym
- SECY = Office of the Secretary
- SFP = Spent Fuel Pool
- SOARCA = State-Of-The-Art Reactor Consequence Analysis
- SSC = Structure, System and Component
- SSE = Safe Shutdown Earthquake
- USGS = United States Geological Survey

# **Columbia Generating Station**

## **ACRS License Renewal Committee Meeting**

April 12, 2012



---

# Columbia Generating Station

**Dale Atkinson - Vice President, Emp Dev/Corp Services**

**Don Gregoire - Manager, Regulatory Affairs**

**John Twomey - Project Manager, License Renewal**

# Agenda

- Station Overview
- Aging Management Programs and Commitments
- Closure of Open Items
- Subcommittee Topics Requiring Additional Information
- Implementation Overview
- Closing Remarks







# Station Overview - Description

- General Electric Boiling Water Reactor
  - BWR-5 / Mark II Containment
  - Plant circulating water & ultimate heat sink makeup supplied from the Columbia River
- 3486 MWt/1230 MWe

# Station Overview - History

- Construction Permit – March 19, 1973
- Operating License – December 20, 1983
- 5% Power Up-Rate - May 1995
- License Renewal application submitted-Jan. 2010
- License Expires – December 20, 2023

---

# **Aging Management Programs and Commitments**

**Don Gregoire**  
**Manager, Regulatory Affairs**

# Aging Management Programs & Commitments

- Aging Management Programs (AMP)
  - 55 Programs Credited for License Renewal
    - 35 Existing
      - 13 Enhancements
    - 20 New
- License Renewal Commitments – 71 total

# Closure of Open Items

- High-Voltage Porcelain Insulators
- Operating Experience
- Upper-Shelf Energy
- Metal Fatigue
- Core Plate Rim Hold-Down Bolts
- Fatigue Analysis of Polar Crane

# Closure of Open Items

- OI 3.0.3.3.7

## High-Voltage Porcelain Insulators

230 kV Station Blackout recovery source insulators at Ashe substation were not included in the Insulator Aging Management Program

### Resolution

- Insulators are now in program
- Tests performed in July 2011 conclude minimal accumulation and within industry limits
- Testing on 8 year frequency consistent with operating experience

# Closure of Open Items

- OI B.1.4-1

## **Operating Experience (OE)**

Future operating experience evaluations for aging effects were not specifically included in the License Renewal Application (LRA)

### Resolution

- LRA amended to clearly call out intent to review internal and external OE on an on-going basis
- Operating Experience program revised to specifically address evaluation of OE for aging effects
- Initial/recurring training for plant staff

# Closure of Open Items

- OI 4.2-1

## Upper-Shelf Energy (USE)

Technical basis not provided for initial transverse USE and copper content for instrument nozzle forgings

### Resolution

- Technical basis was provided
- Supports acceptability through end of period of extended operation



# Closure of Open Items

- OI 4.3-1

## **Metal Fatigue**

Columbia's metal fatigue Time Limited Aging Analysis (TLAA) performed for sample of critical locations listed in NUREG/CR-6260 may not be limiting

### Resolution

- The other limiting locations were identified and evaluated for Columbia
- All locations have an environmental cumulative usage factor below 1.0

# Closure of Open Items

- OI 4.7.4-1

## Lower Core Plate Rim Hold-Down Bolts

Neither an Aging Management Review (AMR) line item nor a TLAA for the reactor pressure vessel lower core plate hold-down bolts were provided

### Resolution

- LRA was amended to include:
  - AMR line item for TLAA
  - TLAA disposition for 10 CFR 54.21(c)(1)(iii)

# Closure of Open Items

- OI 4.7.5-1

## Fatigue Analysis of Polar Crane

Columbia's LRA did not include TLAA for polar crane

### Resolution

- Columbia has an overhead crane but not a polar crane
- TLAA performed for all fifteen (15) in-scope cranes and hoists
- TLAA remains valid for the period of extended operation as per 10 CFR 54.21(c)(1)(i)

# Subcommittee Topics Requiring Additional Information

Following are topics for which additional information was provided to subcommittee in December 2011:

- Microbiologically Influenced Corrosion (MIC) in systems
- Metal-Enclosed Bus (MEB) catastrophic failure
- Makeup water line from river
- Scope of Plant Service Water (TSW) piping to Reactor Closed Cooling (RCC) system
- Internal inspection of raw water buried piping
- Additional long-term plans for copper reduction

# Implementation Overview

- Implementation Activities incorporated into Columbia's Long Range Plan
  - Implementation coordinator on staff
  - Implementation procedure in place
  - Development of remaining AMPs scheduled
  - Active participation in License Renewal Implementation Working Group
  - Benchmarking of other sites with renewed licenses

# Closing Remarks



# **Advisory Committee on Reactor Safeguards**

## **Bulletin 2011-01, “Mitigating Strategies”**

**Eric E. Bowman, Sr. Project Manager, NRR/DPR**

April 13, 2012

# Purpose

1. To achieve comprehensive verification of compliance with 10 CFR 50.54(hh)(2)
2. To gather information on licensee programs in order to determine if:
  - a. Additional assessment is needed
  - b. The current inspection program should be enhanced, or
  - c. Further regulatory action is warranted.



## **30-Day Request**

1. Is the equipment necessary to execute the mitigating strategies, as described in your submittals to the NRC, available and capable of performing its intended function?
2. Are the guidance and strategies implemented capable of being executed considering the current configuration of your facility and current staffing and skill levels of the staff?

# Responses

- All licensees verified compliance.

# 60-Day Request, Questions 1 - 3

1. Describe in detail the maintenance of equipment procured to support the strategies and guidance required by 10 CFR 50.54(hh)(2) in order to ensure that it is functional when needed.
2. Describe in detail the testing of equipment procured to support the strategies and guidance required by 10 CFR 50.54(hh)(2) in order to ensure that it will function when needed.
3. Describe in detail the controls for assuring that the equipment is available when needed.

# 60-Day Request, Questions 4 and 5

4. Describe in detail how configuration and guidance management is assured so that strategies remain feasible.
5. Describe in detail how you assure availability of off-site support.

# Requests for Additional Information

- 53 RAIs out of 65 Sites
- Completeness based on comparison of information in responses and information on equipment, etc., in earlier submittals

# Discussion

- B.5.b guidance contains limited detail on maintenance, training and control of equipment, training requirements, and validation of feasibility of strategies
  - Phase 1 Guidance Document of 2/25/2005
  - NEI 06-12, Revision 2, as endorsed

# **Maintenance, Testing and Control of Equipment**

“Equipment associated with these strategies will meet standard industry practices for procuring and maintaining commercial equipment.”

# Off-site Support

- B.5.b Phase 1 effort included verification and evaluation of memoranda of understanding, etc.



## **Responses (Questions 1-3)**

- Evaluation of responses resulted in synthesis of “Standard Industry Practices” for maintenance, inventory control and testing
- Maintenance items and periodicity
- Engineering judgment based on vendor or manufacturer recommendations, informed by site characteristics, different utilization of equipment and industry standards (e.g., NFPA)

# Responses (Question 4)

- Configuration change evaluations
- Procedure validation
- Design change process
- Systematic approach to training

# Responses (Question 5)

- Off site support arrangements

# **Bulletin 2011-01 Effectiveness**


- Compliance re-verified comprehensively
- This dialogue with Industry resulted in identification of areas where improvements were possible and directly attributable to the Bulletin and Requests for Additional Information

# Questions?



# UNISTAR NUCLEAR ENERGY

**Presentation to ACRS Full Committee  
U.S. EPR™  
Calvert Cliffs Nuclear Power Plant Unit 3  
FSAR Chapters 6, 7, 15 & 18  
SER with Open Items  
April 12, 2012**



# Introduction



- Mark Finley, Senior Vice President, Regulatory Affairs & Engineering, will lead the Calvert Cliffs Unit 3 presentation.
- Presentation was prepared by UniStar and is supported by:
  - Vincent Sorel (UniStar – Director Regulatory Affairs PRA & EPR Design)
  - Sebastien Thomas (UniStar – Manager of Nuclear Engineering)

# Calvert Cliffs Unit 3 Overview



<u>Calvert Cliffs Unit 3 Summary</u>				
<u>Chapter</u>	<u># Departures</u>	<u>#Exemptions</u>	<u># SER Open Items</u>	<u># SER Open Items Responses Submitted</u>
6	1	1	2	2
7	0	0	3	2
15	1	1	0	N/A
18	1	0	0	N/A
<b>Totals</b>	3	2	5	4




# Calvert Cliffs Unit 3 ACRS Full Committee Meeting Introduction



- UNE is responsible for the design of Calvert Cliffs Unit 3 and develops the design primarily through contracts with Bechtel and AREVA who have joined in a Consortium to develop the detailed design of the US EPR.
- RCOLA authored using 'Incorporate by Reference' (IBR) methodology.
- The focus of today's presentation will be a summary of the second set (four) of FSAR Chapters that have been presented to the U.S. EPR ACRS Subcommittee.
- The initial Calvert Cliffs Unit 3 ACRS Full Committee meeting, addressing the first set (9½) of FSAR Chapters, was conducted on April 7, 2011.
- For today's presentation only supplemental information, or site-specific information, departures or exemptions from the U.S. EPR FSAR are discussed.







# List of Chapters



- Chapter 6, Engineered Safety features
- Chapter 7, Instrumentation and Controls (I&C)
- Chapter 15, Transient & Accident Analysis
- Chapter 18, Human Factors Engineering (HFE)

# ACRS Full Committee Meeting Agenda

- Chapter 6
  - Departure/Exemption
  - Summary
- Chapter 7
  - Site-specific Post Accident Monitoring Variables
  - Summary
- Chapter 15
  - Departure/Exemption
  - Summary
- Chapter 18
  - Departure
  - Summary
- Conclusions

# Chapter 6

## Engineered Safety Features

### Departure and Exemption



- Habitability Systems – Main Control Room, Toxic Chemicals
  - For Calvert Cliffs Unit 3, the detection of toxic gases and subsequent automatic isolation of the Control Room Envelope (CRE) is not required and is not a part of the site-specific design.
    - The evaluation of the Calvert Cliffs Unit 3 toxic chemicals in Calvert Cliffs Unit 3 FSAR Section 2.2.3 did not identify any credible toxic chemical accidents that exceeded the limits established in Regulatory Guide 1.78.
    - No specific provisions are required to protect the operators from an event involving a release of a toxic gas.
    - Therefore, Seismic Category 1/Class 1E toxic gas detectors and automatic isolation are not required and will not be provided at Calvert Cliffs Unit 3.

# Chapter 6

## Engineered Safety Features Summary



- COL Information Items, as specified by U.S.EPR FSAR, are addressed in Calvert Cliffs Unit 3 FSAR Chapter 6
- One Departure/Exemption from U.S. EPR FSAR
- No ASLB Contentions
- There are two (2) SER Open Items and responses have been submitted (March 25, 2011).
- There are three (3) Confirmatory Items and they have been incorporated into the COLA (Revision 05).

# ACRS Full Committee Meeting Agenda

- Chapter 6
  - Departure/Exemption
  - Summary
- Chapter 7
  - Site-specific Post Accident Monitoring Variables
  - Summary
- Chapter 15
  - Departure/Exemption
  - Summary
- Chapter 18
  - Departure
  - Summary
- Conclusions



# Chapter 7

## Instrumentation and Controls

### PAM Variables



- Site-specific Post Accident Monitoring (PAM) Variables
  - ✓ PAM variables supplemented with site specific variables
    - Ultimate Heat Sink (UHS) Tower Basin water level
    - Meteorological data
  - ✓ PAM variables list confirmed prior to fuel load after completion of the Emergency Operating procedures (EOPs) and Abnormal Operating Procedures (AOPs)

# Chapter 7

## Instrumentation and Controls

### Summary



- All COL Information Items, as specified by U. S. EPR FSAR, are addressed in Calvert Cliffs Unit 3 FSAR Chapter 7, Instrumentation and Controls.
- No Departures/Exemptions from the U.S. EPR FSAR for Chapter 7 of the Calvert Cliffs Unit 3 FSAR
- No ASLB Contentions
- There are three SER Open Items and No Confirmatory Items
- The responses to two SER Open Items (RAI 326 and RAI 325 Question 07.05-2) have been submitted and the response to the remaining Open Item is in progress. (RAI 325 Question 07.05-1)

# ACRS Full Committee Meeting Agenda

- Chapter 6
  - Departure/Exemption
  - Summary
- Chapter 7
  - Site-specific Post Accident Monitoring Variables
  - Summary
- Chapter 15
  - Departure/Exemption
  - Summary
- Chapter 18
  - Departure
  - Summary
- Conclusions



# Chapter 15

## Transient and Accident Analysis

### Departure/Exemption



#### ➤ Site Specific $\chi/Q$ Values

- Conservative estimates of atmospheric Accident values for the Exclusion Area Boundary (EAB), Low Population Zone (LPZ) and Main Control Room are presented in the U.S. EPR FSAR and bound the Calvert Cliffs Unit 3 values except the 0-2 hour value for the LPZ.
- The U.S.EPR FSAR provides the Accident  $\chi/Q$  of  $1.75E-04 \text{ sec/m}^3$  at the LPZ - 1.5 miles during the 0-2 hr period. The corresponding calculated site-specific short-term atmospheric dispersion factor for Calvert Cliffs Unit 3 is  $2.15E-04 \text{ sec/m}^3$  which exceeds/departs from the U.S. EPR value.
- The site-specific Accident Dispersion factors were used in calculating doses from accident scenarios specified in the U.S. EPR FSAR Chapter 15. Calvert Cliffs Unit 3 doses are conservatively within the limitations of 10 CFR 50.34 and GDC 19.

# Chapter 15

## Transient and Accident Analysis Departure/Exemption



**Table 15.0-2— {CCNPP Unit 3 LPZ Radiological Consequences of U.S. EPR Design Basis Accidents}**

<b>Design Basis Accident</b>		<b>Offsite Dose CCNPP Unit 3 LPZ rem (TEDE)</b>	<b>Acceptance Criterion rem (TEDE)</b>
LOCA		9.1	25
Small line break outside of Reactor Building		0.4	2.5
SGTR	Pre-incident spike	0.3	25
	Coincident spike	0.3	2.5
MSLB	Pre-incident spike	0.1	25
	Coincident spike	0.2	2.5
	Fuel rod clad failure	2.6	25
	Fuel overheating	2.8	25
RCP locked rotor/broken shaft		0.9	2.5
Rod ejection		3.4	6.3
Fuel handling accident		1.2	6.3

# Chapter 15

## Transient and Accident Analysis Summary



- One COL Information Item, as specified by U. S. EPR FSAR, is addressed in Calvert Cliffs Unit 3 FSAR Chapter 15, Transient and Accident Analysis.
- One Departure/ One Exemption in Chapter 15 from the U.S. EPR FSAR for Chapter 15 of the Calvert Cliffs Unit 3 FSAR
- There are no NRC SER Open Items or Confirmatory Items
- No ASLB Contentions
- Responses to all RAIs have been submitted.

# ACRS Full Committee Meeting Agenda

- Chapter 6
  - Departure/Exemption
  - Summary
- Chapter 7
  - Site-specific Post Accident Monitoring Variables
  - Summary
- Chapter 15
  - Departure/Exemption
  - Summary
- **Chapter 18**
  - **Departure**
  - **Summary**
- Conclusions

# Chapter 18

## Human Factors Engineering Departure



- Human Performance Monitoring (HPM) Program - Departure
  - The U.S. EPR HPM is replaced by the UniStar HPM Program entirely
  - The key differences are summarized below:
    - An Operational Focus Aggregate Index is used to trend performance of key variables that can impact Operations Human Performance
      - ✓ Aligns with INPO 09-011, Achieving Excellence in Performance Improvement
    - UniStar Corrective Action Program is utilized:
      - ✓ To track HFE issues in lieu of a separate program (HFE issue tracking system)
  - The UniStar Nuclear Energy Human Performance Monitoring Program meets the requirements of NUREG - 0711



# Chapter 18

## Human Factors Engineering

### Summary



- Five COL Information Items, as specified by U.S. EPR FSAR, are addressed in Calvert Cliffs Unit 3 FSAR Chapter 18
- No ASLB Contentions
- The Departure from the U.S. EPR Human Performance Monitoring Program implements the requirements of NUREG - 0711
- No SER Open Items
- All RAI responses have been submitted
- There are two SER Confirmatory Items and they have been incorporated into the COLA (Revision 08)

# ACRS Full Committee Meeting Agenda

- Chapter 6
  - Departure/Exemption
  - Summary
- Chapter 7
  - Site-specific Post Accident Monitoring Variables
  - Summary
- Chapter 15
  - Departure/Exemption
  - Summary
- Chapter 18
  - Departure
  - Summary
- **Conclusions**

## Chapters 6, 7, 15 and 18 Conclusions



- No ASLB Contentions
- There are three (3) departures and two (2) exemptions
- All Confirmatory Items have been incorporated in the COLA (Revision 08)
- Responses have been submitted to four (4) of the five (5) SER Open Items. The response to the remaining SER Open Item is in progress
- As of April 12, 2012, thirteen and one-half (13½) of the nineteen (19) Chapters of the Calvert Cliffs Unit 3 FSAR have completed Phase 3

# Acronyms

- **ACRS – Advisory Committee on Reactor Safeguards**
- **AOP – Abnormal Operating Procedure**
- **ASLB – Atomic Safety & Licensing Board**
- **CFR – Code of Federal Regulations**
- **COL – Combined License**
- **COLA – Combined License Application**
- **CRE – Control Room Envelope**
- **DC – Design Certification**
- **EAB – Exclusion Area Boundary**
- **EOP – Emergency Operating Procedure**
- **FSAR – Final Safety Analysis Report**
- **GDC – General Design Criteria**
- **HFE – Human Factors Engineering**
- **HPM – Human Performance Monitoring**
- **I&C – Instrumentation and Controls**
- **LPZ – Low Population Zone**
- **MSLB – Main Steam Line Break**
- **PAM – Post Accident Monitoring**
- **PRA – Probability Risk Assessment**
- **RAI – Request for Additional Information**
- **RCP – Reactor Coolant Pump**
- **SER – Safety Evaluation Report**
- **SGTR – Steam Generator Tube Rupture**
- **TEDE – Total Effective Dose Equivalent**
- **UHS – Ultimate Heat Sink**

P-R-O-C-E-E-D-I-N-G-S

8:30 a.m.

CHAIR ARMIJO: Good morning. The meeting will now come to order. This is the second day of the 593rd meeting of the Advisory Committee on Reactor Safeguards. During today's meeting the committee will consider the following. First, Draft Final NUREG-1921, "Fire Human Reliability Analysis (HRA) Guidelines;" two, future ACRS activities and report on the Planning and Procedures Subcommittee; three, reconciliation of ACRS comments and recommendations; four, staff assessment of responses to NRC Bulletin 2011-01 Mitigating Strategies; and five, preparation of ACRS reports.

This meeting is being conducted in accordance with the provisions of the Federal Advisory Committee Act. Mr. John Lai is the Designated Federal Official for this portion of the meeting. We have received no written comments or requests for time to make oral statements from members of the public regarding today's sessions. There will be a phone bridge line. To preclude interruption of the meeting the phone will be placed in a listen-in mode during the presentations and committee discussion.

A transcript of portions of the meeting is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 being kept and it is requested that the speakers use  
2 one of the microphones, identify themselves and speak  
3 with sufficient clarity and volume so that they can be  
4 readily heard.

5 At this point I'll turn it over to Mr.  
6 John Stetkar which will lead us through the first  
7 briefing.

8 MEMBER STETKAR: Thank you, Mr. Chairman.  
9 What we're going to hear about this morning is the  
10 NUREG that we've had a long history with. We've been  
11 speaking to the staff and EPRI about this effort for  
12 almost 3 years. We had our first meeting I think in  
13 June of 2009. We've had a couple of subcommittee  
14 meetings since then. It's a report that's developed,  
15 a joint report by EPRI and the staff, and it's another  
16 good example of the cooperation that the staff has  
17 developed with EPRI in terms of a lot of these really  
18 difficult issues in the area of human reliability  
19 analysis and fire modeling. There are a number of  
20 initiatives and I personally think it's working very,  
21 very well. And this is another evidence of the  
22 success of that cooperation.

23 The specific topic here are guidelines for  
24 human reliability analysis with a particular focus on  
25 fire modeling or fire analysis applications because

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 those types of scenarios impose a few unique  
2 constraints compared to some of your more traditional  
3 internal event type human reliability analyses. So,  
4 these guidelines were developed for that and I'm sure  
5 the staff will -- and EPRI will walk us through that.

6 And without taking too much more time, I  
7 don't know, Rich or Mark, do you want to say something  
8 as introduction?

9 MR. CORREIA: Yes, thank you, just  
10 briefly. Rich Correia, director of the Division of  
11 Risk Analysis and Research. Thank you, Committee, for  
12 your time today to listen to the presentation that we  
13 will give you on fire HRA. It's been a 5-year effort  
14 and we believe we've developed a comprehensible,  
15 useful set of guidelines. And if we're successful  
16 today we will be asking you for a letter.

17 MEMBER STETKAR: Thank you.

18 MR. SALLEY: Yes, and I'm Mark Salley,  
19 branch chief for Fire Research in Rich's division.  
20 Our speakers for today will be Susan Cooper from NRC  
21 and Stuart Lewis from EPRI. They were the PMS and the  
22 technical leads for this project so you should get a  
23 good story on this. Can I have the first slide?

24 One administrative thing for the folks who  
25 are on the phone line. The slides are in ADAMS and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 let me give you an ML number here real quick if you'd  
2 like to have slides in front of you. It's  
3 ML121010574. Again, that's ML121010574. Those are  
4 the slides we'll be using.

5 Again, today's presentation, we're going  
6 to give you a short history of This project. We're  
7 going to talk about its objectives, some of the  
8 challenges we faced. Having EPRI here as a partner we  
9 get to see the industry perspective so we'll have some  
10 good insights to the industry perspectives.

11 Also, with a program like this there was  
12 a number of reviews and different tests that it went  
13 through and trial applications. You'll hear in detail  
14 some of that. And finally you'll hear some uses for  
15 other HRA projects and the interface between them.  
16 Again, as Rich said, the key here to This meeting is  
17 we're going to ask for a letter.

18 And one last thing on that. It's kind of  
19 interesting how the ACRS goes. Sometimes we'll be  
20 here a lot and sometimes we won't see you for awhile.  
21 We've got two big projects. This one is this Fire HRA  
22 which you're going to see today. We've also got  
23 another one we've just been through subcommittee, the  
24 Fire Model Applications Guide, and we're currently  
25 looking at June to come with that one which is also

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 another big one we've worked with John Stetkar on. So  
2 we need -- it's feast or famine. We either see you a  
3 lot or we don't. Next slide, please.

4 This slide's a little busy but it really  
5 kind of puts things in perspective. As Rich said,  
6 this has been a 5-year voyage or journey, adventure,  
7 I mean pick your word. When you look at research  
8 programs like this they're quite interesting having  
9 done a few of them when they get this involved. You  
10 can look at this and say, you know, we've sang Auld  
11 Lang Syne five times since the start of this project,  
12 and wow, that's a long time to do this. But on the  
13 other side when you hear some of the details of some  
14 of the things this project had to do you want to look  
15 at it and say it's pretty amazing you got it done that  
16 fast. So, it all depends on how you're looking. You  
17 know, it's the old adage, it's one thing to buy  
18 sausage, it's another thing to see it being made and  
19 this kind of puts that in perspective.

20 So, without too much ado I'd like to turn  
21 this over to the technical folks, Susan and Stuart on  
22 the next slide. And again, just keep your eye on a  
23 few of these points. They'll explain in detail some  
24 of this. This gives you a nice graphic of the history  
25 of this project. Susan?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MS. COOPER: Thanks, Mark. Okay, I also  
2 would like to acknowledge Jeff Julius of Scientech who  
3 is here today with us also helping Stuart Lewis here  
4 to represent the industry side of this collaborative  
5 effort. And I'm fairly certain that a couple of the  
6 rest of our team are on the phone as well, probably  
7 Erin Collins of SAIC and Kaydee Kohlhepp of Scientech.  
8 And there are others that couldn't make it.

9 In any case, I want to just give you a  
10 little bit more on the background of this particular  
11 project. When we first started this project back in  
12 March of 2007 the status of fire PRA was that about  
13 half of the U.S. nuclear power plants were  
14 transitioning to using NFPA-805 for fire protection.  
15 And in order to make that transition they were using  
16 another document that was a result of a joint effort,  
17 and that's NUREG/CR-6850 or EPRI 1011989. And that  
18 document provided detailed guidance on how to do fire  
19 PRA to support the transition to NFPA-805.

20 With respect to HRA specifically NUREG/CR-  
21 6850 provided basically two things, and that is they  
22 provided some conservative or high, let's say high  
23 value, the high values to assign to the human events  
24 in the PRA that you identified to model. It also had  
25 some discussion and identified some performance

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 shaping factors that were considered relevant to the  
2 fire context. And there were some new, quote unquote,  
3 "new" performance shaping factors that we hadn't had  
4 to address for internal events PRA. Things like,  
5 things that you'd expect with fire like environmental  
6 hazards, smoke, toxic gases, that sort of thing. So  
7 that was principally what was in 6850 but the authors  
8 of 6850 recognized when they published that document  
9 that there still were needs in the HRA area.

10 And particular -- or to be very focused,  
11 those were an approach to develop better, best  
12 estimate HRA values, you know, things that were not  
13 quite as conservative. And at the same time we had  
14 the ASME ANS PRA standard being developed and that was  
15 going to be something that industry needed to consider  
16 when they were developing their PRAS. And so we  
17 needed guidance that also met that standard.

18 So, the objectives of the joint effort  
19 between EPRI and NRC to develop HRA guidance went hand  
20 in hand with those recognized needs. So our principal  
21 objectives in this effort had been to provide guidance  
22 on how to do quantification, detailed HRA  
23 quantification that can give you those error  
24 probabilities that are not so high and not so  
25 conservative.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           And while 6850 identified some of the  
2 performance shaping factors that are important in the  
3 fire context, it didn't really tell you how to address  
4 those in HRA. How do you match up "I understand  
5 there's smoke here" and "How do I reflect that in a  
6 number?" So we needed to make certain that when we  
7 provided our guidance we had that kind of match.

8           And we were also very cognizant of the PRA  
9 standard requirements. And as Stuart's going to talk  
10 in a little bit that was one of our challenges because  
11 the standard was kind of evolving at the same time  
12 that we were developing our guidance.

13           MEMBER BANERJEE: So let me ask you about  
14 performance shaping factors, just to make this  
15 concrete. If there's smoke here it affects your  
16 performance and you have to take that into account?  
17 Is that it?

18           MS. COOPER: It can. We have some  
19 criteria about, you know, the proximity of the smoke  
20 and so forth as to whether or not it affects you. It  
21 also can then require or instigate people to want to  
22 put on some kind of protective gear or breathing  
23 apparatus. That can have an effect on their  
24 performance. So there are a number of different ways  
25 that those kinds of performance shaping factors can

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 affect performance.

2 MEMBER BANERJEE: These are based on  
3 empirical studies? You can get these factors?

4 MS. COOPER: The evaluation --

5 MEMBER BANERJEE: How do you get them?

6 MS. COOPER: -- of say, let's just stick  
7 with smoke, how it affects human performance is  
8 principally a qualitative assessment, especially with  
9 respect to, for example, do you need to wear breathing  
10 apparatus, except for when we talk about the  
11 possibility of abandoning the control room. And then  
12 we do actually even go back to 6850 and use some  
13 numerical values about the density and so forth so far  
14 as when we might consider that the operators would  
15 leave the control room.

16 MEMBER BANERJEE: But there's a lot of  
17 experience, right? I mean, when you get a Scott out  
18 back, put it on, go out.

19 MS. COOPER: There is experience,  
20 absolutely.

21 MEMBER BANERJEE: Yes, so don't you  
22 correlate that?

23 MS. COOPER: Yes, mostly qualitatively,  
24 but there still can be impacts. It can -- one that  
25 can be most important is communication. So unless you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 have a built-in device in your breathing apparatus,  
2 communication through the device can be garbled or  
3 difficult. And so if it's important -- I mean, this  
4 is another feature of the fire context is you have  
5 many more actions that will be taking place outside  
6 the control room.

7 And so as a result there's some need  
8 usually for people, you know, in the control room,  
9 operators in the control room to communicate with  
10 people outside the control room. People outside  
11 control room are wearing a breathing apparatus and  
12 they need to communicate, you know, "I just did this,"  
13 or "You do that." It's important. That can be more  
14 difficult if they're wearing breathing apparatus.

15 MEMBER POWERS: I think the question he's  
16 trying to ask is is there someplace I can go to that  
17 says I have these data points and I have taken the  
18 average, the mode, the 95th percentile of those data  
19 points and come up with this number. Is there  
20 someplace we can do that?

21 MR. LEWIS: No, I don't think we have that  
22 kind of data.

23 MEMBER POWERS: Why not?

24 MR. LEWIS: It really is qualitative from  
25 the perspective of --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   MEMBER POWERS: I mean, that's the  
2 inherent difficulty. I mean, it's qualitative.  
3 Somebody dreamed it up. I don't have his rationale  
4 for dreaming it up, he just said well, it's difficult,  
5 so I'll put this number in. I have no idea where the  
6 number comes from.

7                   MR. LEWIS: It tends to be less a matter  
8 of putting in a different number than it is making a  
9 judgment about whether or not the action is feasible  
10 in the first place.

11                   MEMBER POWERS: Well, I mean the question  
12 is why is that acceptable? Why is that even vaguely  
13 acceptable?

14                   MS. COOPER: I think the place that we're  
15 in with HRA is that the variety of contexts and fire's  
16 a really good example. The variety of different  
17 things that can be happening and what operators would  
18 need to do and the conditions under which they need to  
19 do them just doesn't lend itself to a statistical  
20 mapping between, you know, experiments or anything  
21 like that and a number.

22                   MEMBER POWERS: How do you know that? Has  
23 anybody ever tried?

24                   MS. COOPER: Yes. We have. Actually, we  
25 even have efforts right now in data collection. Sean

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Peters, my branch chief, is here if you need him to  
2 speak to it. We have efforts right now that are  
3 principally focused in the control room where you use  
4 simulators. But when you talk about the ex control  
5 room stuff it's a little bit different. Sean, do you  
6 want to add something here?

7 MR. PETERS: Yes, we do have a variety of  
8 data programs that we're implementing right now. But  
9 as Susan indicated, the data programs in a control  
10 room simulator are a little bit different than what  
11 you can do, or what would be required in a fire  
12 scenario. A fire scenario requires operator actions  
13 outside of the control room and also indicates  
14 spurious actuations and whatnot.

15 Getting, you know, getting a statistically  
16 significant data sample for all the various human  
17 actions that are required in a fire scenario would  
18 incorporate, you know, millions and millions of  
19 dollars. We're talking on the order of a Manhattan  
20 type project to be able to encompass all the various  
21 scenarios that could come out of a fire scenario and  
22 getting a statistically significant number of data  
23 points.

24 So what you have to do with an HRA is you  
25 have to collect, you know, you collect data based on

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 human factors research, human factors literature  
2 that's out there and you try to encapsulate and  
3 qualify that data into what you would do with a  
4 qualitative analysis in HRA.

5 MEMBER POWERS: What you're saying is that  
6 we should never try to build accident analysis models  
7 because we could never melt down enough cores to  
8 possibly get a meaningful database. That's not the  
9 way we do it. We get data, we create a model and then  
10 we look at all the interactions and presumably put in  
11 correction factors when we find them. But you guys  
12 are throwing up your hands and saying "I can't get all  
13 the data, therefore I'll get none of the data."

14 MR. PETERS: We're not saying about  
15 getting none of the data. We actually have programs  
16 right now to get some of the data and we're trying to  
17 at least put certain human scenarios in and collect  
18 that data. Then we can bound all the other items, or  
19 at least interpolate all the items based upon the  
20 expert assessed difficulty of the various scenarios.

21 MEMBER SKILLMAN: I'm Dick Skillman. I'd  
22 be curious in the effort that you've expended in the  
23 last number of years how much time you've taken to  
24 talk with real firefighting people who have donned the  
25 turnout gear, faced the smoke, faced the lack of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 communication, the fear of confinement, the fear of  
2 losing their gear and battling both a physical enemy  
3 which is the fire and the emotional turmoil that these  
4 men and women face.

5 It seems to me that there is a body of  
6 evidence. Ships at sea have battled these fires, the  
7 Navy's battled these in compartments. Municipalities  
8 all over the country have fought deadly fires, not  
9 just electrical fires or paper/wood fires, but  
10 chemical fires. It seems that there's some real  
11 information that may be very beneficial and not so far  
12 away that provides the kind of information that Dr.  
13 Powers is talking about.

14 MS. COOPER: So, first of all, let me make  
15 one clarification. Within the context of fire PRA and  
16 then HRA anything related to the fire brigade and  
17 directly related to the suppression of the fire is not  
18 modeled by HRA. That -- those efforts and their  
19 success or failure are captured through data. And the  
20 HRA analyst does not have a responsibility to that.  
21 The only aspects of suppression that the nuclear power  
22 plant operator does that we model has to do with  
23 things done in the control room for, you know, maybe  
24 backing up an automatic suppression system or  
25 something like that. But anything related to the fire

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 brigade's job of putting out the fire we do not model.

2 We do model the potential effect on the  
3 control room crew because they may have just lost  
4 someone to the fire brigade. We also model or  
5 consider the fact that they'll probably be talking  
6 with the fire brigade, there will be interaction  
7 between the control room crew and the fire brigade.  
8 But so far as the actual fire suppression and those  
9 activities, we don't model that.

10 Now, I'm going to let Jeff and Stuart  
11 speak to some of the rest of your questions, but I  
12 will say that efforts that are still not yet  
13 documented that were performed here at the NRC with  
14 respect to fire events and human performance actually  
15 contributed to this performance shaping factors in  
16 6850. There was a group of researchers that included  
17 NRC, Sandia National Laboratories and actually I was  
18 part of that when I was not part of NRC. I was still  
19 a contractor. And we looked at a lot of different  
20 fire events.

21 And we had Dennis Bley who's one of your  
22 members was on the team and he brought some of his  
23 experience in from the Navy. We tried to get some  
24 cooperation with the Navy. They were not willing to  
25 share. We went out and talked to other firefighters.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Dennis went to a conference in Boston of firefighters.  
2 I mean, we did a lot of work to do some of that. That  
3 was some time ago, but that was the basis in 6850 on  
4 which we built. And although it's not done I'm still  
5 working with Sandia to try to get some of that  
6 background work that we did probably about 10 years  
7 ago now published.

8 So there was a basis where we did some of  
9 that but now I'm going to let Stuart and Jeff talk  
10 because they're working with utilities right now.

11 MEMBER CORRADINI: Just, before you do,  
12 can I just add to the -- just to address? Because I'm  
13 kind of sympathetic to what Sanjoy and Dana are  
14 asking. But you started off by saying -- maybe you  
15 didn't say it exactly this way, but what I thought I  
16 heard you say was something like it's pretty clear  
17 what we're using now are conservative.

18 So at the very least what I'd be curious  
19 about is what data or empirical evidence is clear that  
20 what you're using now is conservative, and what you're  
21 now going to evolve to at least gets closer to what  
22 has been empirically observed. Because I think at  
23 least that would give me some confidence you're going  
24 in an appropriate direction.

25 But I think you said that to begin with

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 and that one is the thing I remembered was -- so the  
2 data must show you're already conservative on how  
3 you're approaching this model.

4 MS. COOPER: So, if I could address that.  
5 The conservative screening values that were provided  
6 in 6850 are conservative as compared to the internal  
7 events PRA values for human failure events because  
8 many of those screening values are tied to those  
9 numbers in some way. In some cases it's a multiplier  
10 of the internal events number or something that's  
11 higher than the internal events number. So that's the  
12 area of conservatism and the criteria that are built  
13 into 6850 -- realize we're not talking about our  
14 document right now, though we borrowed some of this  
15 just for the beginning. But the detailed  
16 quantification is different.

17 But those conservative -- the criteria for  
18 doing that, you know, if you're going to use a very  
19 minor multiplier on your internal events number is  
20 that there are no spurious effects going on in the  
21 instruments. The fire damage to the cables is not  
22 causing your safety-related equipment to have any  
23 problems. For the most part the actions are just the  
24 same as if it was internal events and there's a small  
25 multiplier to add, you know, from the context of the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 fire. That's one set. That's the most -- that's the  
2 best you can do there.

3 Everything else from there is much higher  
4 and many of the -- at least two of the categories  
5 which are new events that are coming from like using  
6 the fire response procedures and things like  
7 abandoning the control room, those get values of 1.0.  
8 It doesn't get any more conservative than that. So,  
9 that's where I'm coming from.

10 Now, what we've done is that we've tried  
11 to back off from that very obvious conservatism by  
12 providing some tools to look at the context in a  
13 little bit more detail. So, you know, that's where  
14 we're coming from.

15 All right, now back to the firefighting  
16 experience. Take it away.

17 MR. JULIUS: I'm Jeff Julius of Scientech.  
18 So when we started the project on the industry side we  
19 went out and talked to utilities, both PWRs and BWRs  
20 and both the in control room action, the fire  
21 protection staff, as well as the operators that are  
22 performing the local manual actions to talk about what  
23 is your experience, what is your training. And a lot  
24 of these guys have background in being ex-Navy  
25 personnel and staff. So we did have an effort to go

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 out and to get the insights that we could from those  
2 people.

3 MS. COOPER: I guess one last thing that  
4 I will add is that we -- early in the project Mark  
5 Salley had arranged for some folks at NIST to look at,  
6 again, what the, you know, look at the data. They did  
7 their thing. I didn't quite understand it. But the  
8 bottom line was to see if there was anything new or  
9 different in how we should understand the effects of  
10 fire on human performance. And the results were  
11 pretty much the same as what was in 6850 so we decided  
12 not to include that effort into what we're doing. It  
13 didn't seem like it was an added effect. I sense that  
14 Mark wants to add something.

15 MR. SALLEY: Yes. A final comment just to  
16 try to address your concern, Dr. Powers' concern on  
17 smoke. When you do these types of analysis it's which  
18 tool do you go for in the toolbox. For example, the  
19 next document that we're going to talk to you about in  
20 a couple of months, the fire modeling, you know, smoke  
21 is dynamic, okay? It's going to start small, we know  
22 it's going to get bigger, the smoke's going to get  
23 more optical challenging. It's going to get denser.  
24 Questions if you're going to use the control room  
25 purge system or not. These are the kind of things

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 that the fire models give you, not the HRA piece.

2 So what I'm saying is if you want to use  
3 these tools in concert that's how you'll do a full  
4 analysis. And as a matter of fact, if you look at the  
5 Fire Model Applications Guide there's a specific  
6 example for control room abandonment where the fire  
7 modelers go through it and they go through the smoke.

8 And again, the two criteria they'd use  
9 there is the smoke density, can the operator see what  
10 they're doing, in when do they need to go to breathing  
11 apparatus, as well as any of the effects from the  
12 heat, if the operators physically have to leave from  
13 the heat. So that's something that happens in fire  
14 modeling that would be an input if you will to a  
15 complete HRA to make that decision.

16 MS. COOPER: Yes, that's a very good  
17 point. Fire PRA is -- adds a layer of complexity to  
18 all the other tasks including the HRA in the sense  
19 that there are a number of inputs that are required  
20 for the analysis that are done by other experts. And  
21 the fire modeling is a good example. So we cannot  
22 make our evaluations without input on, you know, where  
23 there is smoke and what its intensity is until we get  
24 that from someone else.

25 The same thing with the circuit analysis



1 and the fire progression. We don't know anything  
2 specifically about what instruments and what equipment  
3 has failed until somebody else has done their job to  
4 a certain point and given that information to us. And  
5 then in turn now we know what the job is for the  
6 operators and then we have to evaluate all these  
7 factors and see, you know, make an evaluation as to  
8 the reliability or failure probability.

9 MEMBER STETKAR: Let me interject  
10 something. I think this discussion has been really,  
11 really good and I just want to kind of give a little  
12 bit of my perspective.

13 This NUREG, this guidance is what I  
14 consider, it's a snapshot in time of the evolving  
15 understanding of how to model human response in  
16 general. It's developed primarily to focus on fire  
17 scenarios because quite honestly existing guidance at  
18 the time that this effort was started 5-6 years ago or  
19 more in its infancy didn't treat human response in the  
20 context of severely challenging events like fires  
21 because the PRA technology up till that time had  
22 focused primarily on internal events. Internal events  
23 don't generate smoke. They don't generate large  
24 numbers of very strange indications. They don't  
25 generate the challenges for people having to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 communicate with outside firefighters, with inside  
2 firefighters, with people doing local actions in the  
3 plant. The technology just had not faced those types  
4 of challenges.

5 Now, as we're trying to model fires,  
6 they've introduced those challenges and therefore  
7 there was a need to kind of expand the state of  
8 knowledge, the state of the practice, to address those  
9 concerns. Is it perfect? No, it's a snapshot in  
10 time.

11 There is -- I was going to give you a  
12 chance to do some self-promotion, but there is in  
13 progress a larger project to address human reliability  
14 in what I'll call the more global sense in response to  
15 a staff requirements memorandum. That project in  
16 particular is very carefully looking at both what is  
17 an appropriate set of performance shaping factors, how  
18 can those performance shaping factors, both the  
19 definition of the performance shaping factors and how  
20 they're used, be tied back to fundamental  
21 psychological principles. And how can they be tied in  
22 terms of the scale of goodness or badness if you will  
23 of particular performance shaping factors be tied back  
24 to actuarial data which is part of the data collection  
25 effort that was mentioned and other sorts of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 benchmarks.

2           So in my perspective this particular  
3 effort is not trying to solve all of those problems.  
4 It can't. That's part of the larger effort. This is  
5 a very needed effort to address many of the very  
6 challenging situations that power plant operators face  
7 in the context of a fire that had never been addressed  
8 before in the sense of overall human reliability  
9 analysis.

10           It's not the endpoint in terms of, you  
11 know, the global approach to human reliability  
12 analysis which -- and I would hope that that global  
13 approach. We have ongoing meetings on that project.  
14 The goal of that global approach I believe will more  
15 completely address some of the concerns that Sanjoy  
16 and Dana and Mike have raised regarding sort of  
17 benchmarking and definition of these performance  
18 shaping factors, and using whatever data you have av  
19 to try to pin down what those scales might be. And  
20 with that I'll be quiet.

21           MEMBER POWERS: Well, you know, for the  
22 life of me I don't know how you assess a human  
23 reliability analysis on this. If I come in and say my  
24 performance shaping factor is 0.1 and you guys say 0.3  
25 how in the world does that get resolved? It sounds to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 me it gets resolved simply by saying oh, you're not in  
2 the in crowd, therefore your number is wrong.

3 MR. LEWIS: We may have given you a  
4 misperception of what we're doing here. We didn't  
5 create a correlation between the influence of this  
6 factor and, for example, smoke density. It's more a  
7 matter of making a determination as to whether the  
8 conditions in the area where the action has to be  
9 taken support taking the action or are prevented. So  
10 that for example, as Mark alluded to, it doesn't take  
11 a tremendous amount of smoke to get to the point where  
12 you can't see what you're doing.

13 And we wouldn't give any credit to a human  
14 action in an area where that condition existed. It's  
15 not like we'd say well, you know, if you have this  
16 much smoke you increase the probability by a factor of  
17 2 and if you have more it's increased by a factor of  
18 3.

19 We do make -- there are some situations  
20 where we might make some adjustments to a basic  
21 failure. If you're in a situation where the fire has  
22 been extinguished but there's still some smoke in the  
23 area it may be somewhat less reliable than other  
24 cases.

25 And you're right, we could get into those

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 kinds of discussions but what we're really trying to  
2 do is get an understanding of whether or not that  
3 action plays an important role in the core damage  
4 frequency or other risk parameter, and then look at  
5 whether or not something else needs to be done to  
6 either reduce the uncertainty or to eliminate that  
7 contribution. We're not really very often in a  
8 situation where we would have to hang our hats on  
9 small differences in human failure probabilities,  
10 that's not the regime we typically work in. And we're  
11 not in that kind of a correlation here.

12 MEMBER POWERS: You haven't -- I'm going  
13 to change my question. Suppose that you say the  
14 smoke is too dense here, you cannot see what you're  
15 doing, ergo you cannot suppress this fire. And I come  
16 in and say oh yes, I can do that, this smoke is just  
17 fine. My guys can get in there, they're all operators  
18 from Susquehanna, they're perfect supermen and you  
19 would have absolutely no basis for criticizing me for  
20 saying that.

21 MS. COOPER: Well, again, so it's not so  
22 much -- well, as much as PRA tries to be realistic  
23 there are still rules to the game shall we say, and  
24 one of those is that we can't take credit for things  
25 that some group of guys might be able to do but not

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 everybody can do. So, when Stuart says if the smoke's  
2 at a certain level where we don't think they can see  
3 and we don't take credit for that, that's pretty much  
4 the end of the game unless they want to talk about a  
5 different path, a different location, some time later  
6 in the event, that kind of thing.

7 Now, the other thing as Stuart said, and  
8 I appreciate you correcting my mis-speaking.  
9 Sometimes the fact that there may be enough smoke in  
10 the area that they have to put on equipment, that  
11 factors into the amount of time that they need to take  
12 in order to do things, and time is something that  
13 we're always keeping track of in HRA because you need  
14 to be able to know what you're going to do, get the  
15 equipment that you need to have, get to where you're  
16 going, do it, report back. All of that has to be done  
17 in some time to be useful to preventing some system  
18 failure or plant function failure. So, the time it  
19 takes to put on the equipment, the extra time it may  
20 take you to just walk around wearing it or doing  
21 things, all those things are what we take into  
22 account.

23 And different people react differently.  
24 We try to keep that into account too. So there's  
25 never -- that's the other reason why it's difficult to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 say there's a number is because --

2 MEMBER BANERJEE: I thought that was the  
3 way you were going to answer my question originally.

4 MS. COOPER: Okay.

5 MEMBER BANERJEE: I think -- so going back  
6 to when I was a kid in a plant working we'd have to  
7 put these Scott air packs on and find our way out and  
8 take certain actions and they would time us.

9 MS. COOPER: Right.

10 MEMBER BANERJEE: How long it took us to  
11 shut something down, do something else and get out of  
12 the plant. So you have these numbers. They vary.

13 MS. COOPER: We do. As a matter of fact,  
14 yes. We indicate that job performance measures and  
15 other data that the plant may take can be an input  
16 what our analysis. However, their starting point and  
17 where we may start may be different. In other words,  
18 they may start from, you know, right here, right now,  
19 I've got my equipment on, I'm going.

20 We start earlier. We start back in the  
21 control room when they decide they need to do this  
22 action. They call somebody up on the phone. They go  
23 and get their equipment. They go and put their gear  
24 on and then they go. So we have a different starting  
25 point. But you're right, there is information, data

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 collection, timing information that can be used and we  
2 discuss that in our report.

3 And then we try to factor in the gear.  
4 There are other things we can't factor in, you know,  
5 to that data collection like the actual presence of a  
6 fire and how that affects things. Jeff, you wanted to  
7 add something?

8 MR. JULIUS: That's right. That was one  
9 of the major public comments in fact was that we had  
10 not recognized the body of timing data that was out  
11 there for the developing the time line. And so we've  
12 addressed that in our revision here.

13 And the idea is that it's not these  
14 individual performance shaping factors individually  
15 influence, it's the collective set. So it's the  
16 procedures, and the cues, and the training, and the  
17 timing. And we look at those and be able to rank  
18 those important, you know, whatever number we pick as  
19 a ranked set. And then we can go back and have the  
20 plants work on improving their procedures or training  
21 for these important actions. So whether it's a 0.1 or  
22 0.3 through this method we see the collective set of  
23 these shaping factors and then -- so that the plants  
24 have something to go back and to work on improvements,  
25 or to reducing the uncertainty of those actions.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1                   MEMBER BANERJEE: Okay. So you're on the  
2 path. All right.

3                   MS. COOPER: We don't have -- separate  
4 from the slide set that you have. We had some backup  
5 slides but there isn't one there. But Jeff has the  
6 actual report on his computer if you wanted to see one  
7 of the --

8                   MEMBER STETKAR: That's all right. In the  
9 interest of time let's -- we've had quite a bit of  
10 discussion in the subcommittee meetings regarding the  
11 concept of time lines, and addressing uncertainties in  
12 time lines. And there's uncertainty. Those time  
13 lines account for cognitive responses, they account  
14 for the actual implementation, whatever the action is  
15 and how one assesses the uncertainties in those times.

16                   In some cases the times are developed to  
17 assess feasibility of the action. In other words, if  
18 the time available is 15 minutes before something  
19 undesired occurs and you do a reasonable analysis and  
20 you say there's only 5 percent probability that you  
21 can actually achieve what you desire within that 15  
22 minutes you tend to basically fail the action. On the  
23 other hand, if there's a large margin then you have to  
24 still quantify the likelihood with uncertainty. So  
25 timing, many of the concerns that have been raised in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the context of this discussion do translate to timing.  
2 Not all of them, but many of them do. That's what I  
3 was kind of asking whether you had the -- if you don't  
4 have the time line that's fine because it's important  
5 to get through the rest of the presentation.

6 MS. COOPER: Yes, we do.

7 MEMBER BANERJEE: There is another time  
8 line here.

9 MEMBER STETKAR: There is another time  
10 line. We're still okay on that one.

11 (Laughter)

12 MS. COOPER: All right. I just want to  
13 make two points before I move off of this slide. And  
14 that is that, so what then eventually really kicked  
15 off this effort then was that NRR came to the Office  
16 of Research and asked to add a task to the user need  
17 with the Fire Research Branch to say let's develop  
18 these guidelines using existing methods. And  
19 therefore it became a joint effort with industry and  
20 the NRC and I'd like -- I think Mark already mentioned  
21 but this is the third major joint effort on fire-  
22 related research projects.

23 So, the next several slides I'm going to  
24 pass over to Stuart to address. In particular he's  
25 going to talk about challenges that the team addressed

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 in our development, the industry perspective and some  
2 things about review testing and trial applications.

3 MR. LEWIS: The first point here, in terms  
4 of the kinds of things we had to tackle in developing  
5 something advancing the state of the art in HRA for  
6 fire I think is something John already alluded to, and  
7 that is what had been done in human reliability  
8 analysis up to this point primarily focused on  
9 internal events, kind of nominal conditions in the  
10 plant, without the sorts of stressors or influence  
11 factors that a fire might produce. So trying to  
12 really understand the context for a human action when  
13 there's a fire in progress or when it's been  
14 extinguished but perhaps has had some unique effects  
15 on the plant was a major I think challenge that was  
16 faced by this project early on.

17 I have to say, I wasn't part of this  
18 project at the beginning until I joined in EPRI in  
19 2009 so I've gotten to be part of the update effort,  
20 but I didn't get to --

21 MEMBER STETKAR: This is your plausible  
22 deniability.

23 MR. LEWIS: No, no --

24 (Laughter)

25 MR. LEWIS: My first, my introduction to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the project was that I served as, I think the time  
2 line that Mark went through pretty quickly. I served  
3 on a peer review panel back in 2008 when the first  
4 draft was put together. So I did have some  
5 familiarity. And I'm not trying to deny or avoid  
6 blame for anything that's in there. If we're talking  
7 about specific things that's necessary.

8 (Laughter)

9 MR. LEWIS: But the fact is that we did  
10 have a broad range of possible influences and many of  
11 these were identified in NUREG/CR-6850 that hadn't  
12 really been tackled in any depth when it came to human  
13 reliability analysis. So that really was a big  
14 challenge here.

15 Part of that challenge was to look at the  
16 context to understand when human actions could be  
17 feasible given that you had a fire in progress. So  
18 for example, typically we would include that if you  
19 had to take an action. I'm not talking about fighting  
20 fire. As Susan said, we treat the firefighting aspect  
21 empirically based on data collected from actual  
22 nuclear power operating experience.

23 But if you have to go into an area where  
24 there's been a fire and manipulate a valve, or a  
25 circuit breaker, or take some other action we have to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 look at whether or not it's feasible actually to take  
2 that action. If you have to don protective gear does  
3 that make the time such that it's too late to take  
4 that action for example, or are the conditions still  
5 so adverse that you wouldn't expect that a human could  
6 reliably perform the action in the first place. So we  
7 would judge the action to be infeasible.

8 So we spent quite a bit of time developing  
9 criteria for how to judge the feasibility of human  
10 actions. The time line plays a big role in that  
11 process. Because again, if you have insufficient time  
12 to do what needs to be done by definition the action  
13 is infeasible.

14 We also spent quite a bit of time  
15 developing criteria or guidance on how to evaluate  
16 whether the action was feasible in terms of walking  
17 through the action in an actual plant context, or when  
18 that's not possible at least doing a detailed talk-  
19 through of the scenario with operators and other  
20 relevant personnel to understand what would need to be  
21 done, where the operators would have to go in terms of  
22 how their transit paths might be affected, what  
23 protective gear they might have to don, and that sort  
24 of thing as part of assessing the feasibility.

25 For some actions plants have gone out and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 come as close as they can to simulating the realistic  
2 conditions. That's difficult to do. Obviously they  
3 don't start a fire in a room to see what level of  
4 smoke is generated, but to the extent that it's  
5 possible to simulate those conditions that has been  
6 done for some of the more important human actions that  
7 are considered in fire PRAS.

8 We've also developed guidance for how you  
9 reflect the potential that a fire can cause spurious  
10 signals or spurious actuations in the plant and how  
11 that might affect the operators in the control room.  
12 That can come into play in several ways. Among those  
13 are the fact that the operators may be directed to  
14 take an action that's contrary to what they should  
15 actually be doing because you get a spurious signal  
16 that says to, for example, block out a diesel  
17 generator to prevent damage to the diesel when in fact  
18 there may not be any actual problem, and by doing that  
19 they've defeated the function of the diesel.

20 More generally, we expected in some fires  
21 at least that could affect a lot of control cables you  
22 may have a number of actuations occurring more or less  
23 simultaneously. They may not have anything to do with  
24 each other because they're not tied to anything that's  
25 actually going on in the processes they monitor, but

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 they could be distractions. The operators have to  
2 filter through the alarms and indicators and figure  
3 out what is really going on. So they have that  
4 potential for distraction that we tried to address.  
5 So that was another thing that we had to provide  
6 guidance for in the context of the HRA.

7           The potential errors of commission, I'm  
8 not sure how familiar you are with this concept. This  
9 refers to taking intentional acts based on the  
10 understanding the operators have in situations where  
11 those acts are actually the wrong things to do. So,  
12 it's not -- most of the things we look at in human  
13 reliability analysis for a nuclear power plant are  
14 failure to do something when it needs to be done.  
15 This is a specific case, when the operators do  
16 something they're not doing it by accident, they're  
17 doing it intentionally but they have a  
18 misunderstanding of the situation they're in. So  
19 again, this ties back to the bullet before and that is  
20 they might take these actions if they have spurious  
21 signals telling them to take the action.

22           So in that context it's a little bit hard  
23 to call them errors. They have a signal. They're  
24 responding according to what their procedure tells  
25 them to do, but in fact in the context of the accident

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 sequence they're treated as errors of commission.

2 We typically don't look at those in detail  
3 or we haven't in PRAS up to this point. I think this  
4 is an area that the project that John mentioned to  
5 respond to the other staff requirements memorandum  
6 will be looking at in detail as we go forward. It's  
7 certainly a hole in HRA today I believe, but it is  
8 something we do tackle in a specific context in fire  
9 HRA.

10 Distractions, again, you know, not only  
11 the spurious signals, but if you have to -- if the  
12 operators have to deal with what's being done to fight  
13 the fire that can add time and distraction to what it  
14 is they need to be doing to respond to the plant  
15 conditions. And then we have the whole --

16 MEMBER ABDEL-KHALIK: I can understand  
17 distractions and spurious signals that are caused by  
18 the fires. How do you address distractions or  
19 spurious signals that the operators are constantly  
20 subjected to as a result of deficiencies in the fire  
21 protection, fire detection system in a flame?

22 MS. COOPER: Deficiencies, not failures.

23 MEMBER ABDEL-KHALIK: Correct.

24 MS. COOPER: I'm not sure I know what you  
25 mean by that. Could you --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1                   MEMBER ABDEL-KHALIK: I mean, have you  
2 looked at the health of the fire protection system in  
3 an older plant? Have you looked at the health of the  
4 fire protection program in an older plant and seen how  
5 many deficiencies there are and how many spurious  
6 indications that come into the control room so that  
7 they have to have fire watches, either hourly or  
8 shiftly fire watches all the time?

9                   MS. COOPER: I think Mark wants to say  
10 something and I believe our industry folks want to say  
11 something.

12                  MR. SALLEY: Do you want to go first?

13                  MS. COOPER: Why don't you guys go ahead.

14                  MR. LEWIS: Jeff was pointing out that  
15 with respect to the firefighting systems themselves,  
16 again, that's treated within -- separate from the  
17 context of the HRA in evaluating the reliability of  
18 those systems.

19                  Now, if there are failures within those  
20 systems that could create additional demands for the  
21 control room --

22                  MEMBER ABDEL-KHALIK: That is -- that's my  
23 --

24                  MR. LEWIS: -- we haven't explicitly  
25 addressed that. I don't think that is --

1                   MEMBER ABDEL-KHALIK:  If the operators are  
2                   constantly getting alarms which they know are spurious  
3                   because they're caused by deficiencies in the system,  
4                   are they conditioned in such a way that when a real  
5                   alarm comes in they just ignore it?

6                   MS. COOPER:  That is part of some of our  
7                   discussion about distractions.  That, some of that  
8                   discussion is a result of interactions with the  
9                   subcommittee in the last few meetings.  And that is  
10                  that we recognize whether it's fire protection systems  
11                  or other things on balance of plan, that even though  
12                  the operators are trained for a fire to focus on their  
13                  safe shutdown equipment and what would be needed for  
14                  safe shutdown, there could be things going on that  
15                  because of their prior operating experience, you know,  
16                  like I've been having trouble with that rad waste  
17                  system.  It shouldn't matter to me right now but it's  
18                  been a bug in my, you know, a bug for me for the last  
19                  week and so I'm just going to take care of that  
20                  instead of what I should be.

21                  And we talk about -- this is a little bit  
22                  beyond what we can do right now, but we have some  
23                  discussion about how you can handle it in uncertainty  
24                  space.

25                  MEMBER ABDEL-KHALIK:  But that is totally

1 different. You know, having, you know, history of  
2 problems with a waste-handling system versus having a  
3 history of problems with the fire detection system.

4 MR. SALLEY: And that's an age-old  
5 question. And you know, it becomes the difference  
6 between nuisance alarms and false alarms. I believe  
7 the codes have dealt with it and the inspectors check  
8 that. Back in my NRR days I can sympathize because I  
9 know exactly what you're talking about.

10 But it's also interesting to see that  
11 there's a similar but different change going today  
12 with the technology. Something that I know NRR has  
13 been dealing with and we have a separate research  
14 program going on and that's the advent of the very  
15 early warning detection systems, if you're familiar  
16 with this. It's a new technology that samples the  
17 air. Like I said, we have a research program going on  
18 right now and what we're seeing with the PRAS and with  
19 the 805 applications is the licensees are finding out  
20 what really is sensitive in the plant. You know, what  
21 are the real pinch points and where do I really need  
22 to be sensitive for cabinet fires especially.

23 Harris, this is in part of the Harris SER  
24 if you've looked at it, but they even install brand  
25 new, state-of-the-art detection systems that work off

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 air aspiration where they pick up the smallest points  
2 of combustion. In essence, it's really fire  
3 prevention because when the electronics start to break  
4 down before they turn into a combustible type fire,  
5 the operators are able to pick it up and go in there.

6 We have a program right now in Research  
7 that's looking at this. And it's interesting because  
8 a lot of the other technologies, the other sciences  
9 have gone beyond us. For example, one of the people  
10 I'm talking with a lot is NASA and NASA is using this,  
11 Department of Energy is using it, some of their  
12 facilities and we're out trying to get their  
13 experience. Also in Canada, I understand the CANDU  
14 reactors have used this in years past. So, there is  
15 newer technology for that problem.

16 As to the nuisance alarms, wow, your  
17 question really dances on safety culture. I mean, how  
18 serious do the operators take the alarms? And that  
19 can go for any alarm on the annunciator, not just the  
20 fire alarm.

21 MR. LEWIS: Clearly we needed to develop  
22 guidance related to uncertainties that can affect the  
23 human reliability analysis. If you've been exposed to  
24 other elements in PRA you know that uncertainty plays  
25 an important role in everything that we do in PRA.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           We had some unique considerations, maybe  
2 not so unique, but sometimes we forget that when we  
3 draw a time line we have uncertainties in the  
4 estimates of each of the elements of that time line,  
5 and some of those are magnified a bit. Or at least  
6 the consequences are magnified in terms of the fire  
7 scenario where we may have less time margin because of  
8 other things that are going on are distractions.

9           MEMBER STETKAR: And in some sense -- I  
10 mean I have the time line in front of me. In some  
11 sense it -- from Said's question it doesn't address it  
12 completely, but in the context of this time line there  
13 is a starting point when the real fire really starts.  
14 And there is a delay time until the operators receive  
15 -- essentially perceive the cues to start their  
16 action. Now, their action might be to turn on a pump  
17 or to go, you know, open a valve.

18           In some sense, some of the confusion or  
19 distractions of inadequate or confusing fire alarms,  
20 fire detection could factor into uncertainties in that  
21 delay time. In other words, people being distracted  
22 by saying where the heck is the fire before they  
23 actually respond to the cues to maybe start the pump.  
24 It's not a complete, you know, deterministic  
25 evaluation of those actions, but I would argue it

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 could be factored into that initial delay until they  
2 get started doing the things they ought to get  
3 started.

4 If it's enough of a distraction  
5 unfortunately it pervades the entire time line which  
6 is something that Susan mentioned. We've had some  
7 fairly extensive discussions about this notion of  
8 distractions and focusing on other things. And that's  
9 about all I can say.

10 MEMBER SKILLMAN: John, what I heard, or  
11 at least what I assumed originally was that this is an  
12 extremely wide focus on human reliability analysis  
13 relative to fire. And what I then heard based on  
14 Susan's explanation is this is really focused on how  
15 the control room behaves given a set of inputs. And  
16 so from that perspective what we're talking about this  
17 morning is that more limited discussion item. Am I  
18 accurate in that or am I missing the point here  
19 please?

20 MEMBER STETKAR: I wouldn't characterize  
21 it personally, and I'll speak for the staff here. I  
22 wouldn't characterize it as more limited because in  
23 terms of nuclear power plant safety the response of  
24 the control room operators and the operating crew to  
25 mitigate the effects of a fire is what we're

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 interested in. So it's not limited at all in that  
2 sense. Plants get into trouble primarily because of  
3 the combined effects from the fire damage and perhaps  
4 personnel making errors. And those personnel are not  
5 the firefighters, they're the people responsible for  
6 operating the power plant. This is focused on the  
7 operators of the power plant.

8 As Susan mentioned, the extinguishment of  
9 the fire itself is factored into the global fire  
10 analysis through empirical correlations of times for  
11 fire suppression that are derived from actual data.  
12 So it is a time factor, it's a probability of  
13 suppression as a function of time, based on whether or  
14 not you have to -- you know, local firefighting,  
15 automatic, you know, those types of things. Those are  
16 treated empirically. Those aren't treated in terms of  
17 uncertainty, in terms of does the fire brigade  
18 captain, you know, forget to put his hat on.

19 So yes, if you -- your understanding is  
20 correct. This effort is focused on the operators of  
21 the nuclear power plant response in the context of a  
22 fire which eventually will be extinguished at some  
23 time even if it has to burn itself out.

24 MEMBER SKILLMAN: That's helpful. Thank  
25 you. Thank you.

1 MS. COOPER: But it can be and often is  
2 outside the control room that the operators are  
3 performing their actions. And that is an element that  
4 there's not much of in an internal event. So that's  
5 something that we've had. And that's actually  
6 Stuart's last bullet. But there's a bullet in  
7 between.

8 MR. LEWIS: So, what we've been talking  
9 about up to this point is primarily the qualitative  
10 aspects of what needs to be done to deal with the  
11 human reliability for the fire scenarios.

12 We also had to look very carefully at what  
13 was available to support quantifying the probabilities  
14 of failure to take appropriate action. And in the  
15 context of doing that, again, as Susan mentioned  
16 earlier we had a screening approach from the -- from  
17 NUREG/CR-6850 that was very general in context. And  
18 we had existing detailed approaches to performing  
19 human reliability analysis that we looked at adapting.

20 We concluded -- our team concluded  
21 somewhere along the line that an approach in between  
22 those two extremes, a fairly simplistic screening  
23 approach and a more detailed analysis would be helpful  
24 in terms of further screening actions that didn't  
25 contribute significantly to the risk results so that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 it didn't -- they didn't necessarily warrant really  
2 extensive resources being applied to evaluate them.

3 And a scoping approach was developed  
4 that's unique to this effort. The scoping approach is  
5 intended to be somewhat less bounding than the  
6 screening approach but still be something that can be  
7 applied in a fairly simple or straightforward manner  
8 without -- again, you still have to do a fair amount  
9 of work to understand the context for the action to  
10 make sure that the action is feasible in the first  
11 place and to understand some basic aspects of what  
12 needs to be done, but it doesn't require the full  
13 analysis that a detailed analysis would. So, this new  
14 scoping approach was developed along the way.

15 And then we looked at two detailed  
16 approaches for performing the analyses. One is  
17 comprised of methods developed by EPRI over the years  
18 and the other is the ATHENA approach that was  
19 developed by the NRC. And essentially we give  
20 analysts the choice. If they conclude they need to do  
21 a more detailed analysis they can choose either of  
22 those two paths. And there's some guidance on when  
23 one path might be more appropriate.

24 For example, if you get into certain  
25 cognitive actions that are particularly challenging

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 ATHENA may be able to handle those, some aspects in  
2 ways that the EPRI approaches can't do. But for the  
3 most part it's up to the analyst to decide which  
4 approach to follow. And then the rest of the work in  
5 the quantification arena had to do with how do you  
6 adapt those approaches to take into account the fire  
7 context along the way.

8           And then as Susan said, the last bullet  
9 has to do with the fact that actions would have to be  
10 taken outside the control room for the fire scenario  
11 may have some unique implications. The operators may  
12 not be able to take the path to a local area they  
13 would under normal circumstances because the fire is  
14 in an area that's in the way, or they may not be able  
15 to have access to an important area to take the  
16 action, or other aspects of taking action outside the  
17 control room. Communication becomes a greater issue,  
18 for example, so we had to address those implications  
19 for actions outside the control room.

20           A few more of the things that we had to  
21 face in this process, including the fact that we felt  
22 a strong need to pilot the methods in the guidance.  
23 This is something that has come up repeatedly in the  
24 context of NUREG/CR-6850 which is a very broad  
25 approach to performing fire risk assessment.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           And both on the industry side and the NRC  
2 side I think it's been recognized that it would have  
3 been very helpful to have actually gone all the way  
4 through a PRA applying the guidance in NUREG/CR-6850  
5 before people launched into production PRAS as part of  
6 the NFPA-805 transition. A lot of the more subtle  
7 gaps or challenges in 6850 weren't really recognized  
8 until a lot of people were well under way in  
9 performing their fire PRAS.

10           And so for the last few years we've all  
11 been scrambling to try to fill those gaps and  
12 compensate for some of the things that look fine going  
13 into the process and you don't recognize the  
14 importance of until you're actually trying to use the  
15 guidance. So we felt it was important to do an  
16 effective job of piloting this process to force out  
17 any challenges or gaps that we didn't recognize when  
18 we put the guidance together. And we'll talk a little  
19 bit more in a minute about how that was done.

20           Another of the challenges, and I think  
21 this was more of a challenge early on, but the fact  
22 was that the requirements in the PRA standard, the  
23 ASME ANS standard, were evolving along with the  
24 guidance that this project put together. So it was a  
25 little bit of a moving target, trying to put together

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 guidance that would tell people how to do the things  
2 that a standard tells you you need to do when the  
3 things in the standard are changing is clearly a  
4 challenge. But I think we have -- to getting pretty  
5 close on that aspect.

6 Another thing I think that wasn't fully  
7 recognized at the outset was the fact that in the fire  
8 PRA itself there are a large number of different  
9 tasks, some of which iterated different points. It's  
10 by no means a linear process where you can define a  
11 point at which you need to perform certain elements of  
12 the HRA and then another point where you need to do  
13 additional things. It's very much a process of trying  
14 to screen continuously areas in the plant that could  
15 contain important fires, focusing in more and more on  
16 the areas that are important and developing more and  
17 more detailed information about the fire scenarios.

18 And all that information is needed to  
19 support the HRA so that you can't just define a simple  
20 point when you perform the HRA. And trying to  
21 characterize the ties between the HRA process and the  
22 broader fire PRA process was a big challenge in this  
23 whole process.

24 Another thing that has come up as the fire  
25 PRAS get closer to completion is the fact that the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 procedures in place at the plant have been improved as  
2 part of the transition process. And in many cases  
3 it's necessary to evaluate the risk as the plant will  
4 exist after these procedures are changed. And so you  
5 have a situation where you're expected to evaluate  
6 human reliability for a procedure that may not have  
7 actually been implemented in the plant yet, so you  
8 have to make some judgment about what that's going to  
9 look like. The fire procedures I think are one of the  
10 significant areas of improvement that plants going  
11 through this transition process have realized, but  
12 that's certainly not made the HRA process any easier  
13 along the way.

14 And finally, a challenge that we did face  
15 in terms of the schedule. Not so much a technical  
16 challenge, but the -- as many of you are aware there  
17 is a fairly extensive fire PRA course that's offered  
18 jointly by EPRI and NRC twice a year. And starting in  
19 2010 there was a new track added to cover the fire  
20 HRA. And trying to develop a week's worth of training  
21 materials and to conduct that training and improve the  
22 materials has been a big focus of what's gone on the  
23 last 2 years. So that's been one cause for how it  
24 took us this long to get to where we are. It's just  
25 a fact of life, but that's something that the team who

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 was putting the report together had to deal with in  
2 parallel.

3 MEMBER SKILLMAN: Has that training course  
4 been well attended?

5 MR. LEWIS: Very well attended. I think  
6 it's been on the order of 20 to 30 students, the HRA  
7 part of the course, 20 to 30 students each of the four  
8 times it's been offered. It was offered twice in 2010  
9 and twice more in 2011. So there must be somewhere in  
10 the neighborhood of 100 people who have gone through  
11 that class.

12 MEMBER SKILLMAN: Are these primarily PRA  
13 practitioners from the fleet?

14 MR. LEWIS: It's a mixture of PRA  
15 practitioners, a fair number of NRC inspectors and  
16 others who are going to be reviewing NFPA-805  
17 submittals have attended. Other interested parties  
18 have come. So it's -- one aspect of the way this  
19 material has evolved is that many of the plants that  
20 are performing their fire PRAS have already had to  
21 deal with much of the HRA before they had the chance  
22 to attend the training. So that's -- it's been  
23 somewhat less beneficial from that standpoint  
24 unfortunately. The timing wasn't ideal anywhere along  
25 the line. But it has helped quite a bit with some

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 plants' HRA or fire PRA efforts.

2 MR. SALLEY: The training is split pretty  
3 much. It's interesting, we had a very good attendance  
4 as far as not just the industry and the consultants  
5 that we open it up to, because we treat it as a free  
6 public meeting. But we also get our inspectors.

7 Our inspectors are actually starting to  
8 use this for some of their qualification. Remember,  
9 the fire PRA is bigger than 805 and the things that we  
10 learn in here and the original roots of 6850 were for  
11 the fire re-quantification which was for the SDP  
12 process. So you know, that's a big part of it. The  
13 training does continue to expand.

14 Another interesting fact is when you look  
15 out there, where can you get this kind of training?  
16 And every year that we do this we tend to get  
17 somewhere between 10 and 13 different countries that  
18 are sending their people, both their consultants and  
19 their regulators, here. So this is kind of a cutting  
20 edge program, this training.

21 We've also, like Stuart said, we expanded  
22 it. It originally had three modules: fire PRA,  
23 circuit analysis and basic fire dynamics. The fourth  
24 track is this HRA that matches up with this NUREG.  
25 We've also added a fifth track that we started last

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 year which is the fire modeling and advanced fire  
2 modeling. So the training is thriving.

3 We take turns with it. This year is the  
4 NRC's turn. There will be two sessions of it up here  
5 in the greater D.C. area and next year EPRI will have  
6 it again.

7 MEMBER SKILLMAN: Thank you.

8 MEMBER SCHULTZ: Stuart, I understand the  
9 importance of the fifth bullet with regard to the PRA  
10 practitioners and the inspectors, and so forth. The  
11 fourth bullet there, continuing improvements in fire  
12 procedures in plants. Is this not the key focus of  
13 why we're doing this in the first place is to develop  
14 an understanding of where improvements can be made to  
15 the fire procedures? Perhaps more importantly, where  
16 it's not feasible to develop improvements to the  
17 procedures.

18 MR. LEWIS: Absolutely. It is an  
19 important focus, probably the most important focus of  
20 this work. The reason it's here, listed here as a  
21 challenge, it's just that when this process started we  
22 had a set of existing procedures. We tried to write  
23 guidance to address how you evaluate human reliability  
24 in the context of those procedures. Many of those  
25 procedures have been very fundamentally changed

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 through the last few years and so our guidance has had  
2 to adapt and accommodate those changes in the  
3 procedures. So that's where the iteration comes back.

4 MEMBER SCHULTZ: I didn't mean you didn't  
5 understand it as a good thing, but in terms of the  
6 practice, the focus of the overall effort should be to  
7 assure that the improvements aren't being made to the  
8 procedures in those areas where they can have the most  
9 impact, the most effect.

10 MS. COOPER: I would agree. Some of the  
11 discussions we've had in the training sessions, we've  
12 had some very interesting comparing of notes of  
13 different procedure formats, what works best here.  
14 Even we had some folks from the Spanish regulator show  
15 us some procedures from some of their plants and how  
16 they differently attack the problem.

17 So yes, it's good that this is coming up  
18 and the HRA is playing a role here, it's just that,  
19 you know, this is again sort of the delta against  
20 internal events. For decades now we've been looking  
21 at EOPs and only EOPs, and now we're looking at an  
22 entirely different beast. And it's evolving and we're  
23 providing the input. So, anyway. John's giving me  
24 high signs that we need to --

25 MEMBER STETKAR: Yes, to have some hope of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 meeting this time line we do need to try to get  
2 through the remainder of the presentation.

3 MR. LEWIS: I'll try to quickly give you  
4 a little bit of perspective on what it was we were  
5 trying to do.

6 MEMBER STETKAR: By the way, I told you  
7 there would be interest.

8 MR. LEWIS: Yes -- in terms of our  
9 participation in this project. Certainly the most  
10 important thing that we had to deal with was that we  
11 have -- we needed to provide clear and consistent  
12 guidance on how to perform an HRA for fire PRAS so  
13 that our users could do a good job of implementing  
14 this aspect of the analysis, and that this wouldn't be  
15 a tremendous obstacle to completing the fire PRA. We  
16 also wanted to make sure that along the way we  
17 provided adequate review and iteration on the guidance  
18 as it evolved.

19 But I do want to make a couple of points  
20 about what we view as important attributes of the  
21 approach that exists now in NUREG-1921 or EPRI  
22 1023001. First of all, it does -- as it's constituted  
23 now it does have the capability to address a broad  
24 range of fire response strategies because not every  
25 plant uses exactly the same approach to responding to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 a fire, and provides detailed guidance for how to  
2 evaluate and address those strategies. This guidance  
3 coordinates I think much better than it did in the  
4 early days with the way actual fire PRAS are  
5 conducted. So it provides the right level of  
6 information, when inputs are available and when the  
7 outputs are needed for the fire PRAS. Although I  
8 think we couldn't claim that the results have an  
9 extremely high degree of accuracy, just as we can't  
10 claim in any human reliability analysis. We do think  
11 that the studies can produce useful insights into  
12 where actions are important and what might be done to  
13 improve procedures or other aspects of the scenarios  
14 to reduce risk.

15 And we think that the guidance is  
16 producing results that are consistent with the way  
17 human reliability analysis is performed for internal  
18 events, but taking into account the fire HRA -- fire  
19 context.

20 I mentioned one of our challenges early on  
21 was to ensure that we did a sufficient amount of  
22 testing and piloting of this process. And the fact is  
23 we didn't have a full set of guidance that then went  
24 all the way through a PRA and then we made some tweaks  
25 and published the report. We did have to do the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 piloting and testing along the way, but we did enough  
2 of that that I'm confident that we've tested all the  
3 aspects from this guidance sufficiently.

4 Starting with, you mentioned the peer  
5 review that I participated in back in 2008 before I  
6 was at EPRI. In 2008 there were also pilot  
7 applications that focused primarily on this new  
8 scoping method conducted at a PWR, Diablo Canyon and  
9 a BWR, Nine Mile Point, to provide some feedback. And  
10 the scoping approach was modified as a result of that  
11 experience.

12 It was also piloted in 2009 by the PWR  
13 Owners Group and they provided quite a bit of feedback  
14 to help improve the guidance.

15 MEMBER SHACK: All the guidance or focused  
16 on the scoping stuff?

17 MR. LEWIS: That was all the guidance at  
18 that point. In December of 2009 a draft version of  
19 NUREG-1921 was published for public comment and we  
20 received comment from primarily four entities, both of  
21 the owners groups, the PWR and BWR Owners Groups.  
22 Exelon -- on a set of guidance, and then the EPRI --  
23 we have a human reliability analysis users group that  
24 supports our software development and other  
25 activities. And they provided quite a few comments as

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 well. And so much of the time, aside from developing  
2 training materials, much of the time in the last 2  
3 years or so has been spent making sure that we  
4 properly account for those comments and make revisions  
5 to the report that reflect what we learned from that.

6 We've also, perhaps at least as  
7 importantly as any of these aspects, the guidance has  
8 been in use over the last few years. Some of our team  
9 members, including Jeff from Scientech and SAIC, are  
10 actively involved in performing fire PRAS as part of  
11 this transition to NFPA-805 and they've used this  
12 guidance to support those PRAS. So even though it  
13 wasn't published in final form they had a little bit  
14 of an inside track on the guidance and were able to  
15 provide feedback to allow us to further improve the  
16 guidance.

17 And finally, Susan mentioned that we did  
18 get quite a bit of comment and feedback from the  
19 students who came to our training classes in order to  
20 the experience. Those who had actually participated  
21 in HUMAN RELIABILITY ANALYSES for fire PRA up to that  
22 point had feedback that was helpful to the process.  
23 And that, it continued through the two courses last  
24 year. I was only at the ones in 2010 so I can't speak  
25 directly to what happened last year, but I believe

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 that was very useful.

2 And of course as John said at the outset,  
3 we've had a number of interactions with the ACRS  
4 subcommittee through the years and quite a bit of  
5 useful feedback from John and others on that  
6 subcommittee.

7 So again, we're pretty confident that  
8 we've tested everything maybe not in the ideal format  
9 but in at least as thoroughly as we need to to have  
10 confidence in what we've got.

11 I'll quickly go through some of the things  
12 that have changed. I may not hit all of these bullets  
13 in the interest of time, but a lot of the work that we  
14 did in response to the testing and the reviews that  
15 were conducted affected the qualitative analysis. The  
16 qualitative analysis captures all the important  
17 aspects of the context for the action we're assessing,  
18 the timing procedures and all the other things we look  
19 at. And it's a really crucial first step in getting  
20 -- setting the stage for all the rest of the work we  
21 do in the human reliability analysis. And we did make  
22 quite a bit of modification to that process as it was  
23 originally formulated as a result of the feedback we  
24 got.

25 Made some changes to the scoping approach.

1 I won't get into any details there. We did refine the  
2 way we would reflect the timing considerations,  
3 especially as it's applied in the scoping approach.  
4 And some of the other guidance for things like walk-  
5 throughs of the scenarios and how to perform an  
6 adequate talk-through.

7 An important aspect of what we've  
8 addressed in our revision was looking at the potential  
9 for spurious actuations or spurious equipment  
10 operations along the way. And then we made some  
11 changes to the way we characterized some of the  
12 pieces, the specific pieces, including treatment of  
13 recovery, the dependency among human actions and the  
14 uncertainty analysis. So all of this, all this review  
15 and testing that we did really did make substantive  
16 improvements to the guidelines as we went along. With  
17 that I think we can turn it back over to Susan.

18 MS. COOPER: Thank you, Stuart. That  
19 leads into the next and last topic, and that is to say  
20 that we believe that the guidance that we provided for  
21 fire HRA also provides a useful guidance that can be  
22 used for other projects moving forward. In  
23 particular, at the NRC we mentioned the new HRA  
24 development from the SRM M061020. And then also the  
25 Office of Research is beginning on a project to do

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 site-wide level 3 PRA. So both of those projects in  
2 particular we believe will be benefitted by this work.

3 In addition to some of the examples that  
4 I'm going to give you, there has -- one of the other  
5 benefits is that team members for the fire HRA  
6 guidelines overlap many of the other projects at the  
7 NRC, both the two that I mentioned here and then ones  
8 in the past like some of the international and U.S.  
9 benchmarking efforts where we've been looking at the  
10 strengths and weaknesses of HRA methods.

11 You know, a lot of the focus that we have  
12 in the NUREG-1921 on qualitative analysis is a direct  
13 result from some of the insights from those early  
14 international benchmarking efforts that was then  
15 reinforced in the U.S. benchmarking efforts.

16 So, I'm just going to give you some  
17 examples of some of the things that we think that will  
18 be very important to other HRA efforts, development  
19 efforts or application efforts. The first thing is  
20 that we have in 1921 comprehensive guidance for all  
21 steps in the HRA process. That doesn't sound like  
22 much, but for the most part when someone's come up  
23 with something new they're focusing on the  
24 quantification aspect of it only. And so we've talked  
25 a lot about the qualitative analysis, but another

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 aspect that's very important is the identification and  
2 definition of human failure events to put in the model  
3 to begin with. And for internal events we can get  
4 pretty lazy in a sense because there have been so many  
5 of them done you can more or less say well, it's going  
6 to look something like this. I don't have to dream up  
7 something new.

8 For fire, in the fire context we couldn't  
9 do that. We had to look at a different set of  
10 procedures that had different actions that hadn't been  
11 modeled before. We had to look at actions that were  
12 outside the control room. So there was a significant  
13 effort that has to be made on identifying and defining  
14 human failure events to put in the PRA model. And  
15 we've got guidance on that written down.

16 We mentioned several times that we've  
17 written these guidelines to match the standard. Of  
18 course, this -- you know, we're looking specifically  
19 at the fire PRA standard, but in order to satisfy the  
20 fire PRA standard you have to also satisfy the  
21 internal events standard. So, you know, we find that  
22 to be a useful thing to be able to know how to write  
23 some guidance that would meet those kinds of  
24 requirements.

25 Stuart has mentioned a few different times

1 that in the context of a fire PRA there are lots of  
2 different tasks going on with different experts who  
3 are feeding information, providing inputs, generating  
4 input at different times in the project. And we've  
5 tried to address some of this information flow and  
6 some of the problems associated with it in our  
7 document.

8 Now, we had to write the HRA process as a  
9 serial set of steps, but we discuss how those steps  
10 can be iterated and how you might have to wait to do  
11 certain things and so forth. So, we've tried to  
12 address that, that aspect of how you really do a PRA  
13 in our documentation.

14 Stuart mentioned something about this new  
15 scoping approach that we've developed. This provides  
16 an example of how you can develop a simple HRA  
17 approach that is very traceable, and where the number  
18 comes from, and what kinds of judgments you made in  
19 order to get at that number.

20 Another aspect that we've talked about  
21 some is the notion of feasibility. And we have an  
22 extensive discussion in our qualitative analysis  
23 section on feasibility assessments. What are the  
24 criteria, how do you assess feasibility and how do you  
25 transition then from feasibility into making

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 reliability assessments.

2           Again, this is very important when you're  
3 talking about new actions, but for the most part when  
4 you're talking about internal events, PRA, things  
5 happening in the control room, using the  
6 OPPORTUNITIES, we have decades of experience that show  
7 that those things ought to be -- you ought to be able  
8 to do them unless something really strange is going  
9 on. We now have a brand new set of actions for which  
10 we have no -- we may not have any prior experience or  
11 limited experience in showing that they can actually  
12 be performed. So we've -- we've got specific guidance  
13 on how to make those kinds of assessments.

14           MEMBER STETKAR: And I think that's  
15 important. We're, again, short on time, but to  
16 address some of the concerns that were raised earlier.  
17 If you ask Hero Ralph, "Can you do this?" Hero Ralph  
18 always says, "Well, yes, I can and it'll only take me  
19 10 minutes to do it." Guidance for an evaluator of  
20 Ralph that specifically enforces a discipline to ask  
21 questions about timing, about stress, about  
22 distractions is really important because in many cases  
23 Hero Ralph if you ask him can always do something  
24 perfectly in the amount of time that's required. So  
25 that I think is very important, as Susan mentioned,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 this guidance for an objective evaluation of just the  
2 feasibility, can it be done within the available time,  
3 is important.

4 MEMBER SKILLMAN: Let me pile on because  
5 in that particular instance is to me the -- a very  
6 critical piece of this. So, Hero Ralph will say I can  
7 do it and a normal fire is out in, what, 22 minutes?  
8 They're fairly short. But you send Hero Ralph out.  
9 The fire's extinguished. He comes back and he said,  
10 "Boy, that's the best 20 minutes effort I ever put  
11 in," and they say "You've been out there for 3 hours  
12 and 26 minutes."

13 MEMBER STETKAR: Yes, that's right.

14 MEMBER SKILLMAN: Because I know in these  
15 circumstances one's mind loses track of the time line  
16 and you're so committed to task that the world can  
17 change around you.

18 MS. COOPER: Right.

19 MEMBER SKILLMAN: That is an awkward issue  
20 but it gets back to this performance shaping that Dr.  
21 Banerjee asked about and Dr. Powers asked about. But  
22 this to me is the heart of this whole thing, how we  
23 can somehow capture those types of issues and  
24 communicate them in a quantifiable way so that the  
25 industry and the agency really win this one. Because

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 this to me is one of the most important things we're  
2 talking about. Thank you.

3 MS. COOPER: Yes, thank you. Yes, it is  
4 important. And as John said, having that discipline,  
5 having it written down, you know, having some  
6 discussion about the pitfalls is very important.

7 I'm remembering something I think that  
8 Jeff and others at Sciencetech ran into. There was some  
9 kind of valve that you had to access by climbing a  
10 ladder and it was a big thing and so-and-so said, you  
11 know, Charlie said he could do it and it turns out  
12 that even Charlie couldn't do it. But you know, who  
13 knew until you actually went and walked it down and  
14 checked it for real. I'm sorry.

15 (Laughter)

16 MEMBER STETKAR: We know Charlie well  
17 enough. He could have done it.

18 MS. COOPER: All right. So, and that  
19 feeds into the notion, you know, the ex control room  
20 actions, not everything's going to be in the control  
21 room when we're looking at something outside of the  
22 internal events PRA context. And then there can be  
23 some environmental effects, you know, outside the  
24 control room that you wouldn't have to worry about.

25 And we think that this is a useful

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 framework for looking forward to things like seismic  
2 PRA where again we might be sending people out to do  
3 things outside the control room. Accessibility may be  
4 an issue, so on and so forth. So we think we,  
5 especially with the notion of feasibility and looking  
6 at things outside the control room, that we have, you  
7 know, we have a stepping-off point for going into the  
8 future.

9 We mentioned some about the notion of  
10 spurious cues and distractions. Typically in the  
11 internal events PRA process we make assumptions that  
12 the instrumentation is good and reliable and it's  
13 there. There have been a few studies where we've  
14 looked a little bit beyond that, but that's been the  
15 predominant thing and certainly that's what the PRA  
16 standard says.

17 So, here in the fire context we've had a  
18 chance to move out of that comfortable place and start  
19 looking at things, situations where the instruments  
20 can be giving you wrong information and can be  
21 distracting or leading you onto a bad path.

22 With respect to timing we've had a lot of  
23 discussion about that. We also have a lot of  
24 discussion in the report about certain aspects of time  
25 that you need to be concerned about, how to develop

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 timing information. Worrying about uncertainties in  
2 timing. You know, some of the more recent  
3 interactions we've had with the subcommittee suggested  
4 that we provide guidance on don't just develop or look  
5 for point estimates. Try to get an idea about the  
6 range of times, those sorts of things. So we have  
7 quite a bit of different developed that can help any  
8 HRA I believe in that area.

9 We've talked some about the notion that  
10 this is -- we've developed guidance on how to do HRA  
11 for procedures other than EOPs and that's been our  
12 comfortable space for decades and decades. There are  
13 differences in the procedures, fire response  
14 procedures, throughout the industry but we've tried to  
15 capture some of the aspects and some of the things  
16 that people need to be cognizant of when they're  
17 making their evaluation.

18 And we -- it's, as Mark mentioned we're  
19 going to be doing the training again this year, hosted  
20 here in the D.C. area. We have training materials now  
21 for all of the HRA process steps. We do have some  
22 focus on fire of course, but there are other aspects,  
23 again, with identification, definition, qualitative  
24 analysis that we've developed materials on.

25 MEMBER STETKAR: Susan, you mentioned

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 something in passing that I think is important, just  
2 worth noting. And that is consistency with the ASME  
3 PRA -- ASME ANS PRA standards. And this guidance if  
4 I'm not mistaken has been developed with a focus of  
5 trying to meet capability category 2, sort of those  
6 standards. Is that correct? That's sort of the  
7 general focus.

8 We don't have time -- for those of you,  
9 the committee members who aren't familiar with these,  
10 there are different capability categories in terms of,  
11 if you will, scope and level of detail of the  
12 analyses. It's important to understand, capability  
13 category 2 is kind of -- it's more than a middle  
14 level. It's a really good level of detail, but it's  
15 not full scope if you will PRA.

16 It's important because in many cases, in  
17 particular the treatment of spurious actuations within  
18 the context of that capability category are  
19 assumptions built in. And this, this guidance in  
20 particular, the way it's formulated right now are  
21 consistent with those assumptions. Capability  
22 category 3 which is beyond the scope essentially of  
23 this effort expands those assumptions in terms of  
24 things that need to be considered. I think that's  
25 worthwhile just mentioning.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 I wanted to get it on the record for this  
2 meeting. It's stated pretty well in the document  
3 itself, but it's important for the committee's  
4 understanding to know that this isn't trying to solve  
5 all of the problems or a capability category 3 or even  
6 beyond type analysis.

7 MS. COOPER: That's absolutely correct and  
8 we actually even identify some areas up front where we  
9 think, you know, if there was interest or concerns  
10 that we could go further. That's actually one area  
11 where the standard changed while we were making our --  
12 developing our guidance. We did at one point in time  
13 have the beginnings of some guidance on how to treat  
14 lots of spurious indications that might, you know,  
15 combine to cause a wrong decision. But we shifted  
16 when the standard did.

17 Okay, we made it. So, in conclusion we  
18 believe that the project objectives have been  
19 satisfied. We have comprehensive and useful guidance  
20 for fire HRA and we have, some of the authors at least  
21 have used it and find it to be so. And we have  
22 feedback from others.

23 We've refined our approach as a result of  
24 testing, public comments, applications, even feedback  
25 from training. And we think that elements of these

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 guidelines are also valuable to future and current HRA  
2 research and development.

3 And to reiterate from what Mark said, the  
4 team would like a letter, requests a letter. And that  
5 concludes our presentation unless Mark or Rich or any  
6 of my colleagues here want to say anything.

7 MR. SALLEY: We're ready to publish this  
8 and the last step of course is to check with you.  
9 This is a new, innovative way of doing it which is the  
10 whole purpose of coming here. And we're ready to  
11 publish this and move on with the next project.

12 MEMBER STETKAR: Any other comments,  
13 questions from the members? If not, thank you very  
14 much. You've covered an awful lot of material. You  
15 made it. I wasn't worried. I had 4 minutes in the  
16 bank from yesterday.

17 (Laughter)

18 MEMBER STETKAR: And with that, Mr.  
19 Chairman, back to you 36 seconds late.

20 CHAIR ARMIJO: Okay. Thank you, John.  
21 Let's take a break for 15 minutes and reconvene at  
22 10:15.

23 (Whereupon, the foregoing matter went off  
24 the record at 10:00 a.m. and went back on the record  
25 at 12:59 p.m.)

1 CHAIR ARMIJO: Okay, we're reconvening and  
2 we're now on the subject of mitigating strategies and  
3 Said will lead us through that presentation.

4 MEMBER ABDEL-KHALIK: Thank you, Mr.  
5 Chairman. Bulletin 2011-01 requiring licensees to  
6 verify compliance with 10 CFR 50.54(hh)(2) was issued  
7 by the NRC on May 11th, 2011.

8 The ACRS was briefed on the subject during  
9 our 584th meeting in June of last year. We did not  
10 write a letter on the subject. However, we requested  
11 that the staff brief us after the responses provided  
12 by the licensees are collected and analyzed. And the  
13 staff is now ready to provide that briefing and I call  
14 on Ms. Kim Morgan Butler of the NRC staff to begin the  
15 presentation.

16 MS. MORGAN BUTLER: Thank you. Good  
17 afternoon, my name is Kim Morgan Butler. I am the  
18 acting branch chief of the Generic Communications  
19 Branch within the Division of Policy and Rulemaking in  
20 the Office of Nuclear Reactor Regulation.

21 I'm here on behalf of DPR management to  
22 introduce Mr. Eric Bowman. He's going to give us the  
23 details and the updates on Bulletin 2011-01. He's  
24 going to first start with the purpose and explain some  
25 of the requests that we've made, the responses to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 those requests and then give us an overall view of the  
2 effectiveness of this bulletin.

3 And without further ado I'll pass it on to  
4 Eric.

5 MR. BOWMAN: Thanks, Kim. Good afternoon.  
6 As Kim said I'm Eric Bowman. I'm the staff lead in  
7 the Office of Nuclear Reactor Regulations for the  
8 mitigating strategies required first under B.5.b of  
9 the ICM order of 2002 and then codified as 10 CFR  
10 50.54(hh)(2). I'm also the staff lead for the  
11 mitigating strategies order that was issued on March  
12 12th, the order A 12-049. That is not going to be the  
13 subject of this presentation, however.

14 Bulletin 2011-01 was issued, as Said said,  
15 in May of 2011. The reason we issued it was to once  
16 again achieve a comprehensive verification of  
17 compliance by all licensees with the mitigating  
18 strategies requirements that were then in force. We  
19 did that through asking a certain -- two questions  
20 that were due within 30 days. We had further  
21 information that we were gathering to determine if we  
22 needed to make any changes to the requirements.

23 The 30-day request that I mentioned were  
24 these two questions essentially. Is the equipment  
25 there and available and capable of performing its

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 functions. And are the strategies as proceduralized  
2 and as the staff were trained capable of being  
3 accomplished.

4 MEMBER SKILLMAN: Eric, a brief question.  
5 Each of those questions is answerable with a yes or a  
6 no. Was that purposeful in the development of those  
7 questions?

8 MR. BOWMAN: Yes.

9 MEMBER SKILLMAN: Thank you.

10 MR. BOWMAN: And in fact, in general all  
11 the responses we got were a little bit wordier than  
12 yes or no, but ultimately they just verified that they  
13 were indeed in compliance. We got all yes answers to  
14 those set of questions.

15 CHAIR ARMIJO: Sorry, could you go back to  
16 that last slide? I didn't finish reading it and I  
17 wanted to check something. Did you ask specifically  
18 whether there were any deficiencies that they found?

19 MR. BOWMAN: We did not in this question,  
20 in this set of questions. The follow-on questions we  
21 did ask for reporting of any deficiencies they found.

22 CHAIR ARMIJO: Okay.

23 MR. BOWMAN: We did have one or two  
24 licensees that reported that they had a deficiency  
25 that was corrected at the time that they made the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 report that compliance was verified.

2 CHAIR ARMIJO: Okay. Thank you.

3 MR. BOWMAN: Onto the 60-day request which  
4 was the gathering of information for -- to assess  
5 whether or not we needed to make any further changes  
6 to the requirements. There were five questions that  
7 we asked in this section of the bulletin. These are  
8 the first three that concentrate on the equipment  
9 itself, the maintenance, inventory control and testing  
10 of the equipment. I'll give you a minute to read  
11 these questions. In the bulletin itself there are  
12 examples that were provided to further beef up or  
13 specify the information we were looking for.

14 MEMBER SKILLMAN: Curiosity question.  
15 Your slide 4 indicates all licensees verified  
16 compliance. May we interpret that to mean even those  
17 plants that are 95003 or in Manual 0350?

18 MR. BOWMAN: They all verified compliance  
19 With that regulation, yes.

20 MEMBER SKILLMAN: One hundred and four  
21 plants?

22 MR. BOWMAN: Yes.

23 MEMBER SKILLMAN: Thank you.

24 MEMBER ABDEL-KHALIK: So, how do you  
25 reconcile that with the results of the inspections

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 that were done immediately after Fukushima and found  
2 nearly 2,000 violations?

3 MR. BOWMAN: I don't believe they were  
4 characterized as being violations per se.

5 MEMBER ABDEL-KHALIK: Non-compliances.

6 MR. BOWMAN: There were different levels  
7 of compliance. This was -- as, any time is a -- it's  
8 a snapshot in time of the level of compliance. On the  
9 date that they signed it and sent in that letter they  
10 were in compliance.

11 And there are admittedly some areas, and  
12 that's why we asked these questions, to see how the  
13 maintenance of the compliance with the regulation is  
14 being accomplished on a going-forward basis.

15 The other two questions we asked dealt  
16 with configuration control for the plant, ensuring  
17 that the mitigating strategies themselves get updated  
18 if there are changes in the configuration of the  
19 plant. And also that the training and so forth are  
20 carried forward for the staff to ensure that everybody  
21 is capable of performing the strategies. And finally,  
22 the last question we asked dealt with the offsite  
23 support that was necessary for compliance. The  
24 question on the offset support was prompted in part by  
25 anecdotal reporting of lapsed memoranda of agreement,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 and so forth.

2 MEMBER STETKAR: Eric, that number 4. You  
3 said something that I didn't interpret when I read the  
4 words. You said training. Is that the intent?  
5 Because until now this has been very hardware-centric  
6 and if the operators don't know how to use the  
7 hardware.

8 MR. BOWMAN: Exactly. The first three  
9 were intentionally hardware-centric. It also included  
10 in the first three the maintenance of the hardware, so  
11 that's a little bit of --

12 MEMBER STETKAR: But that's still --

13 MR. BOWMAN: Number 4 dealt with the  
14 capability of performing the -- and it got into  
15 training, as I mentioned, by the examples that we  
16 provided to the types of information we were looking  
17 for.

18 MEMBER STETKAR: This is the source of my  
19 question. And this does not have anything to do with  
20 a U.S. plant but I'll give you an example.

21 An unnamed plant in a foreign country  
22 several years ago that I was working with had in place  
23 a fire truck and connections to hook up that fire  
24 truck for an alternate water supply. None of the  
25 operators at the nuclear power plant knew how to run

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 the pump on the -- they knew how to drive a fire truck  
2 obviously, but none of them had been trained on  
3 actually how to operate the pump. And if, I guess a  
4 fire truck, you know, it sounds like it might be easy  
5 to operate but apparently it's not. When we asked  
6 them they said no, we have to call the local fire  
7 department to get somebody to come and operate our  
8 truck for us.

9 And that's the sense of what I mean by  
10 real training. The truck was there, it had gasoline  
11 in it, it had the connections, it's just nobody knew  
12 how to use it. And they actually hadn't thought about  
13 it.

14 So that's the sense of what I was asking.  
15 Was the purpose of that number 4 to follow up at that  
16 level of implementation? In other words, do the  
17 people really know how to use the equipment, despite  
18 the fact that it's there?

19 MR. BOWMAN: The purpose of question  
20 number 4 was indeed to address that need. The  
21 training for the programs that were set up were done  
22 using the systematic approach to training. And  
23 outside of the scope of this briefing of course but  
24 the recent emergency preparedness rulemaking also  
25 makes the 50.54(hh)(2) guidance and strategies part of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the evaluated drills and exercises that are conducted  
2 periodically. So that we actually see them go and try  
3 and start the fire pump for those plants that use fire  
4 pumps. Other plants have different types of pumps.

5 MEMBER STETKAR: But I mean, that's the  
6 whole notion of --

7 MR. BOWMAN: That is.

8 MEMBER ABDEL-KHALIK: Question 4 is really  
9 a configuration management.

10 MEMBER STETKAR: Well, that's why I asked.  
11 But Eric, when he described it mentioned the word  
12 "training" which is what triggered my question to him.

13 MR. BOWMAN: The bulletin itself, I'll  
14 read you the examples that we included in there. It's  
15 guidance management is more where we see the training  
16 as being included. And we included as a subpart of  
17 that examples of the types of information to include  
18 when providing the responses to question 4 were (a)  
19 measures taken to evaluate any plant configuration  
20 changes for their effect on the feasibility of the  
21 mitigating strategies, (b) measures taken to validate  
22 the procedures or guidelines developed to support the  
23 strategies can be executed. These measures could  
24 include drills, exercises or walk-throughs of the  
25 procedures by personnel that would be expected to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 accomplish the strategies, (c) measures taken to  
2 ensure the procedures remain up-to-date and consistent  
3 with the current configuration of the plant, and (d)  
4 a description of the training program implemented in  
5 support of the mitigating strategies and of the manner  
6 in which you evaluated --

7 MEMBER STETKAR: Okay, so that's -- that  
8 captures it.

9 MR. BOWMAN: So, that's what we were going  
10 for. And when we do onsite inspections of the  
11 mitigating strategies requirements for this particular  
12 set of requirements they're accomplished on a  
13 triennial basis under the fire protection inspection  
14 program. And we do walk-throughs of the various  
15 procedures with the plant personnel. And they do  
16 demonstrate that they can, for the strategies that are  
17 selected since that's just a sampling type of  
18 inspection, they can indeed accomplish the strategies.

19 MEMBER STETKAR: But thanks. Those  
20 examples clearly, clearly show that that covers the  
21 area that I was questioning. Thanks.

22 MEMBER SCHULTZ: Eric, is there a similar  
23 broadening of definition with regard to item number 5?  
24 You mentioned letters of agreement, a memo of  
25 understanding.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. BOWMAN: There is.

2 MEMBER SCHULTZ: -- want to see those but  
3 presumably from what you've said here for item 4, item  
4 5, there may be opportunity for, or there should be  
5 opportunity for the demonstration of the availability  
6 and the communications and drills and exercises or  
7 something like that.

8 MR. BOWMAN: For item 5 what we asked is  
9 clarifying information for what would be the  
10 information we were looking for in that brief  
11 description. A listing of the offsite organizations  
12 they rely on, measures taken to ensure continuity of  
13 the memoranda of agreement or understanding, or other  
14 applicable contractual arrangements, including a  
15 listing of periods of lapsed contractual arrangements.  
16 And finally, there was also a listing of any training  
17 or site familiarization provided to the offsite  
18 responders.

19 I've got a copy of the bulletin with me.  
20 I didn't bring multiple copies. I can leave it With  
21 you there.

22 MEMBER SCHULTZ: That's fine. I  
23 appreciate the additional information.

24 MEMBER BROWN: I had a question on  
25 question 4. The -- somehow something arrived in my

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       inbox in preparation for this which was called a  
2       Summary Report. And under question 4 it listed  
3       summary of training and other types of information  
4       like these standard industry practices for stuff. But  
5       a bunch of asterisks were noted that for maintenance  
6       43 of the 65 sites did not address training. In other  
7       words, there was no response.

8               So I'm just following up on your thought  
9       about what's done relative to training. Forty-seven  
10      of the sites out of sixty-five don't provide anything  
11      at all to general employees. And there was I guess,  
12      I don't know who made the assessment, I guess it was  
13      Mega-Tech, the services company provided the basis.  
14      Well gee, they don't do that because most of these  
15      people would be under direction of somebody else.  
16      Therefore, they don't know, they don't have to know  
17      anything else. It's kind of a broad conclusion.

18             I was kind of surprised that after all of  
19      these there was almost -- I couldn't find any  
20      deficiencies anywhere.

21             MR. BOWMAN: In large part the guidance  
22      that we have and the regulatory requirement itself,  
23      the guidance is not that specific as to who needs to  
24      get trained, how often they need to get trained, and  
25      so forth. So it's very difficult to come up with a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 specific deficiency in the training area because the  
2 B.5.b effort that led to this regulation was a  
3 performance-based effort. The sole requirement that  
4 we really have is that they develop and implement the  
5 guidance and strategies to maintain or restore core  
6 coolant containment and spent fuel pooling.

7 MEMBER BROWN: Doesn't that call into  
8 question somewhat the whole strategy of using a  
9 performance-based requirement which it doesn't set any  
10 requirements and just leaves it up to anybody to do  
11 what they want to do?

12 MR. BOWMAN: It makes the inspection of it  
13 less of a "go and be sure they check the box  
14 everywhere." And it makes it more helpful for us that  
15 the EQUIPMENT rulemaking included that in the drills  
16 and exercises that are evaluated. And that's also why  
17 on the reactor oversight process inspections of the  
18 programs we go out in the field and we randomly select  
19 on a risk-informed basis strategy and have the  
20 operators actually walk through the strategy to  
21 demonstrate that they can do it.

22 MEMBER BROWN: Normally I would expect for  
23 a performance-based requirement that you have a ladder  
24 or some type of acceptance criteria that would,  
25 regardless of the methods they used, they have an

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 endpoint, end result that would -- and there was no  
2 mention of that in any of this. That's -- I was just  
3 trying to get a handle on the comments and the way the  
4 thing read.

5 I mean, I kind of drew a conclusion from  
6 all this, maybe I'm wrong, is that they went out and  
7 they answered your bulletin and they came back and  
8 said Everything's okay.

9 MR. BOWMAN: I'll get into a little bit  
10 more specifically about what we were looking at there.  
11 And just give me a couple of slides.

12 MEMBER BROWN: No, that's fine. I was  
13 just trying to give you -- after reading the summary  
14 report of what Mega-Tech reported back it seemed to be  
15 -- go inspect, make sure everything's okay and they  
16 come back and said it is. And Mega-Tech said yes,  
17 they told us it was okay and therefore it's okay. And  
18 it just seemed like the bulletin didn't have a whole  
19 lot of -- they're good questions, but there were no  
20 metrics associated with them. I've really ever seen  
21 when you can't go to a place and inspect things and  
22 find out that they don't --

23 MR. BOWMAN: I don't want to get too far  
24 ahead.

25 MEMBER BROWN: I'll wait.

1 MR. BOWMAN: The wording that was chosen,  
2 the guidance that was issued and endorsed is  
3 susceptible to interpretation in varying degrees.  
4 What we accomplished here was we got the licensees to  
5 document what they are doing.

6 MEMBER BROWN: Okay, thank you.

7 MR. BOWMAN: In the process of reviewing  
8 the responses we got to the bulletin we bounced the  
9 listings of the equipment and the offsite responders  
10 and so forth against the information that the  
11 licensees had supplied during the submittal process  
12 for the B.5.b licensing effort to ensure that they  
13 covered all the equipment that was reportedly relied  
14 on to meet the requirements originally.

15 We did notice some deltas between the  
16 earlier submittals and what was reported in the  
17 bulletin responses, and we wound up with 53 RAIs out  
18 of 65 sites for various small things. Some of them as  
19 minor as an offsite responder organization that was  
20 cited with a different name because they changed their  
21 name. But we went back and verified that they  
22 continued to use those offsite responders or they've  
23 updated it. And that all the equipment that they  
24 cited they would rely on was actually covered under  
25 the maintenance program, et cetera.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1                   MEMBER REMPE:  Would you, I mean, you  
2                   indicated something is a minor RAI.  What was the  
3                   major grouping of something that's maybe perhaps more  
4                   important?

5                   MR.  BOWMAN:  If we could have  
6                   characterized something as being a deficiency that  
7                   would have made one or more of the mitigating  
8                   strategies unavailable then that would have been  
9                   something that would have been more than minor.

10                  MEMBER REMPE:  And did you find -- is that  
11                  any of the --

12                  MR.  BOWMAN:  No.

13                  MEMBER REMPE:  What's more significant in  
14                  the 53 RAIs that you identified?

15                  MR.  BOWMAN:  As I mentioned there were  
16                  differences between the listing of the offsite  
17                  responders and the offsite responders that they had  
18                  told us before.  Omissions of certain pieces of  
19                  equipment that had been listed before.  Some of the  
20                  pieces of equipment that were listed did not list  
21                  maintenance things that were accomplished for them.  
22                  Things of that nature.

23                  And we -- part of the effectiveness of the  
24                  bulletin is that where they had not documented a  
25                  formal maintenance program for things like inspections

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 of spray nozzles, that if they were fire hose spray  
2 nozzles under the fire protection program would have  
3 specified maintenance requirements under the National  
4 Fire Protection Agency standards. Some sites didn't  
5 have those for these particular fire hose nozzles  
6 because they weren't under that program and they have  
7 since entered them in their correction action programs  
8 and are implementing maintenance of the same nature.

9 MEMBER REMPE: Thank you.

10 MR. BOWMAN: You're welcome. Okay. As I  
11 mentioned, a lot of the motivating factors for the  
12 group of questions that we asked in the 60-day  
13 responses were due to the limited amount of detail in  
14 the guidance that's out there for compliance with  
15 B.5.b and 50.54(hh)(2). That guidance takes the form  
16 of a Safeguards document that was issued in February  
17 of 2005 as well as the endorsed industry guidance of  
18 NEI 06-12 Revision 2.

19 The requirements, or what we endorsed as  
20 being an acceptable means of meeting the requirements  
21 for maintenance, testing and control of the equipment  
22 referred to the use of standard industry practices for  
23 acquisition and maintenance of the equipment, and gave  
24 no better definition of just what standard industry  
25 practice is.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 I had forwarded the document that you got  
2 on your desk. The summary report was the analysis  
3 that we had done by our contractor, Mega-Tech  
4 Services, to try and discern just what "standard  
5 industry practices" could be interpreted to mean. It  
6 also goes into the questions 4 and 5.

7 For the offsite support, on a one-time  
8 basis during the phase 1 effort for the B.5.b  
9 development process we verified and evaluated the  
10 adequacy of the memoranda of understanding and  
11 agreement with the offsite responders and so forth.  
12 This was a look at how the licensees are maintaining  
13 that type of support on a going-forward basis.

14 MEMBER SKILLMAN: Eric, typically how many  
15 offsite responders are there per site?

16 MR. BOWMAN: It varied. Some of the  
17 licensees rely on things like statutory requirements  
18 for their state or local area as opposed to listing  
19 individual memoranda of agreement. Typically we saw  
20 local law enforcement agencies, firefighting  
21 organizations, hospitals, things of that nature.

22 MEMBER SKILLMAN: EMTs, hospital, that  
23 kind of stuff?

24 MR. BOWMAN: Yes, exactly. But the  
25 numbers of them of course vary from site to site

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 because some sites are a lot further away from other  
2 offsite responding organizations.

3 MEMBER SKILLMAN: Are there any -- let me  
4 ask the question differently. What is the strangest  
5 memorandum of understanding that you came across from  
6 the licensees?

7 MR. BOWMAN: Strange in what way?

8 MEMBER SKILLMAN: I can understand  
9 firefighting, law enforcement, EMTs, ambulance  
10 service. Did you find any that required a helicopter?  
11 Any that required a tank or an armed vehicle?

12 MR. BOWMAN: No tanks or armored vehicles.  
13 There were listings of agreements with local airports  
14 for things like firefighting foam. I don't really  
15 consider those to be strange based on the context that  
16 we're in here.

17 There wasn't anything that was really all  
18 that strange in the context of a response to a  
19 bulletin. There is of course a hesitancy to list  
20 things that you don't want to be held to maintaining  
21 in the future. So, essentially the responses we got  
22 were restricted to things that were requirements and  
23 things that made sense.

24 MEMBER SKILLMAN: Thank you.

25 MR. BOWMAN: The evaluation of the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 responses to the first three questions on the  
2 maintenance and control of the equipment resulted in  
3 the synthesis of a listing of what might be considered  
4 to be standard industry practices. The contractor  
5 looked at frequencies of performance of the various  
6 maintenance items and so forth, taking into account  
7 things like if hypothetically the industry were indeed  
8 developing standards what would the resulting standard  
9 look like.

10 The more solid thing that we can look to  
11 as a result is what were the various licensees and  
12 sites taking into consideration in developing their  
13 maintenance programs and that was essentially the  
14 manufacturer's or vendor's recommendations for the  
15 equipment, differences in the uses of the equipment  
16 from their intended purpose to the purpose they would  
17 be put into use for in the mitigating strategies and  
18 also industry standards such as the National  
19 Firefighting Protection Association standards for fire  
20 protection.

21 Because it's a sister art to the  
22 mitigating strategies many of the pieces of equipment  
23 that were procured, like fire hoses and nozzles, fire  
24 engines and fire pumper trucks were purchased by the  
25 licensees in order to meet the requirement for a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 portable pumping source. So there's a set of  
2 standards that are out there that are not directly  
3 applicable but are useful in reference to understand  
4 the types of things that are done for This kind of  
5 equipment.

6 Those are the sorts of things that  
7 licensees looked at in developing their maintenance  
8 programs and that is more what we see as being the  
9 standard industry practice in that regard.

10 The responses for question 4 pretty much  
11 followed along the same boilerplate language as to  
12 what was looked at for maintaining configuration  
13 control. That is the evaluation of configuration  
14 changes in the plant's procedure validation, the  
15 design change process and use of the systematic  
16 approach to training.

17 And the question 5 results, we did have a  
18 number of sites that cited prior lapses in memoranda  
19 of agreement. They had all been corrected of course  
20 by the time we got the response as well as documenting  
21 the methodology they're using on a going-forward basis  
22 to ensure that their memoranda or whatever contractual  
23 arrangements they have going forward remain current.

24 And to a certain extent our desire is --  
25 with the bulletin was to document and ensure that on

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 a recurring basis the licensees are capable of  
2 implementing the mitigating strategies and calling on  
3 the offsite support. We weren't looking with this  
4 bulletin to identify deficiencies per se as non-  
5 compliances and enforce those.

6 Finally, the effectiveness of putting the  
7 bulletin out. As I said, we had no instances of non-  
8 compliance that would warrant enforcement. We were --  
9 we have a lot of lessons learned on the value of using  
10 phrases that are undefined such as "standard industry  
11 practices" or "maintenance."

12 We are in the process right now of  
13 developing the Interim Staff Guidance and the industry  
14 guidance for the mitigating strategies order. And  
15 we're taking this into account in what's going to be  
16 documented as the programs going forward for the  
17 strategies under that order.

18 One of the purposes of the bulletin had  
19 been to assess whether or not the inspection program  
20 needs to be modified or enhanced. After looking at  
21 the results of the bulletin and the temporary  
22 instruction inspection that preceded it we feel that  
23 the ROP realignment process is adequate to handle any  
24 changes to the inspection program.

25 MEMBER ABDEL-KHALIK: You're referring to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the triennial fire inspection?

2 MR. BOWMAN: That's where it resides now.  
3 And as I mentioned, further regulatory actions are  
4 ongoing. Rather than taking the NTTF recommendation  
5 to order reasonable protection of the equipment for  
6 other beyond design basis external events, we've got  
7 an entirely different set of mitigating strategies  
8 being developed that we're developing guidance for.

9 And that ends my presentation subject to  
10 your questions.

11 MEMBER ABDEL-KHALIK: Thank you. Are  
12 there any questions for Eric?

13 MEMBER BROWN: Can I ask just one?

14 MEMBER ABDEL-KHALIK: Please.

15 MEMBER BROWN: I don't want -- I'm just  
16 segueing a little bit from the other question. The  
17 comment was made that the compliance -- I understand  
18 you weren't looking for deficiencies or to issue non-  
19 compliance stuff like that, but who did the -- the way  
20 I read this, and the way I read the summary that you  
21 gave me was that the vendors -- excuse me, the  
22 licensees did the inspection. They wrote the  
23 response. It wasn't like you had region people  
24 sitting down with them and going through these various  
25 areas to ensure that they were in compliance. Is that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 correct?

2 MR. BOWMAN: The sequence of events as it  
3 happened, after Fukushima all of the licensees went  
4 out on a voluntary initiative to re-verify their  
5 compliance. There was an INPO Level 1 IER that asked  
6 for certain information. There was our bulletin that  
7 asked for certain information. And there were -- say  
8 again?

9 MEMBER BROWN: Who looked over their  
10 shoulder to say that they were -- were there  
11 inspectors that made sure they were --

12 MR. BOWMAN: Resident inspectors were  
13 going along and in parallel with this effort they were  
14 -- there were two temporary instruction inspections,  
15 TI 2515/183 and 184 that dealt with this action,  
16 management guidelines. The TI 183 had the resident  
17 inspectors going over the subject matter that was  
18 covered by this bulletin.

19 MEMBER BROWN: Okay, thank you.

20 MEMBER ABDEL-KHALIK: Are there any other  
21 questions for Eric? Well, thank you very much. We  
22 appreciate it.

23 MR. BOWMAN: Thank you.

24 MEMBER ABDEL-KHALIK: Thanks. Back to  
25 you, Mr. Chairman.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIR ARMIJO: Okay. Thank you, Said.  
2 Let's take 15 minutes, come back at quarter of 2 and  
3 we'll start on letter-writing. We've got an awful lot  
4 of stuff to do. We're adjourned.

5 (Whereupon, the foregoing matter went off  
6 the record at 1:31 p.m.)

7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25