

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 2, Final Safety Analysis Report**

CHAPTER 15
ACCIDENT ANALYSES

TABLE OF CONTENTS

<u>Section</u>	<u>Title</u>	<u>Page</u>
15.0	ACCIDENT ANALYSES	15.0-1
15.0.3.2	Initial Conditions	15.0-1
15.0.15	COMBINED LICENSE INFORMATION	15.0-1
15.0.16	REFERENCES	15.0-2
15.1	INCREASE IN HEAT REMOVAL FROM THE PRIMARY SYSTEM	15.1-1
15.2	DECREASE IN HEAT REMOVAL BY THE SECONDARY SYSTEM	15.2-1
15.3	DECREASE IN REACTOR COOLANT SYSTEM FLOW RATE ...	15.3-1
15.4	REACTIVITY AND POWER DISTRIBUTION ANOMALIES	15.4-1
15.5	INCREASE IN REACTOR COOLANT INVENTORY	15.5-1
15.6	DECREASE IN REACTOR COOLANT INVENTORY	15.6-1
15.6.5.3.7.3	Atmospheric Dispersion Factors	15.6-1
15.7	RADIOACTIVE RELEASE FROM A SUBSYSTEM OR COMPONENT	15.7-1
15.7.3	RELEASE OF RADIOACTIVITY TO THE ENVIRONMENT DUE TO A LIQUID TANK FAILURE	15.7-1
15.7.6	COMBINED LICENSE INFORMATION	15.7-2
15.8	ANTICIPATED TRANSIENTS WITHOUT SCRAM	15.8-1
APPENDIX 15A	EVALUATION MODELS AND PARAMETERS FOR ANALYSIS OF RADIOLOGICAL CONSEQUENCES OF ACCIDENTS	15A-1
15A.3.3	ATMOSPHERIC DISPERSION FACTORS	15A-1
APPENDIX 15B	REMOVAL OF AIRBORNE ACTIVITY FROM THE CONTAINMENT ATMOSPHERE FOLLOWING A LOCA.	15B-1

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 2, Final Safety Analysis Report**

LIST OF TABLES

<u>Number</u>	<u>Title</u>
15.7-201	AP1000 Tanks Containing Radioactive Liquid

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 2, Final Safety Analysis Report**

LIST OF FIGURES

Number

Title

None

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 2, Final Safety Analysis Report**

**CHAPTER 15
ACCIDENT ANALYSIS**

15.0 ACCIDENT ANALYSES

This **section** of the referenced DCD is incorporated by reference with the following departures and/or supplements.

15.0.3.2 Initial Conditions

Add the following paragraph at the end of DCD **Subsection 15.0.3.2**.

STD COL 15.0-1

The plant operating instrumentation selected for feedwater flow measurement is a Caldon [Cameron] LEFM CheckPlus System (**Reference 201**), which will be calibrated (in a certified laboratory using a piping configuration representative of the plant piping design) prior to installation and will be tested after installation in the plant in accordance with the LEFM CheckPlus commissioning procedure. This selected plant operating instrumentation has documented instrumentation uncertainties to calculate a power calorimetric uncertainty that confirms the 1% uncertainty assumed for the initial reactor power in the safety analysis bounds the calculated calorimetric power uncertainty values. The calculated calorimetric is done in accordance with a previously accepted Westinghouse methodology (**Reference 202**). Administrative controls implement maintenance and contingency activities related to the power calorimetric instrumentation.

15.0.15 COMBINED LICENSE INFORMATION

Add the following text to the end of DCD **Subsection 15.0.15.1**.

STD COL 15.0-1

This COL Item is addressed in FSAR **Subsection 15.0.3.2**.

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 2, Final Safety Analysis Report**

15.0.16 REFERENCES

Add the following text to the end of DCD **Subsection 15.0.16**.

201. Final Safety Evaluation for Cameron Measurement Systems Engineering Report ER-157P, Revision 8, "Caldon Ultrasonics Engineering Report ER-157P, 'Supplement to Topical Report ER-80P: Basis for a Power Uprate with the LEFM Check or Checkplus™ System'," (TAC No. ME1321). August 16, 2010. ADAMS Accession No. ML102160694.
 202. Final Safety Evaluation for Beaver Valley Power Station, Unit Nos. 1 and 2 (BVPS-1 and 2) – Issuance of Amendment re: 1.4-Percent Power Uprate and Revised BVPS-2 Heatup and Cooldown Curves. September 24, 2001, ADAMS Accession No. ML012490569.
-

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 2, Final Safety Analysis Report**

15.1 INCREASE IN HEAT REMOVAL FROM THE PRIMARY SYSTEM

This **section** of the referenced DCD is incorporated by reference with no departures or supplements.

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 2, Final Safety Analysis Report**

15.2 DECREASE IN HEAT REMOVAL BY THE SECONDARY SYSTEM

This **section** of the referenced DCD is incorporated by reference with no departures or supplements.

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 2, Final Safety Analysis Report**

15.3 DECREASE IN REACTOR COOLANT SYSTEM FLOW RATE

This **section** of the referenced DCD is incorporated by reference with no departures or supplements.

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 2, Final Safety Analysis Report**

15.4 REACTIVITY AND POWER DISTRIBUTION ANOMALIES

This **section** of the referenced DCD is incorporated by reference with no departures or supplements.

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 2, Final Safety Analysis Report**

15.5 INCREASE IN REACTOR COOLANT INVENTORY

This **section** of the referenced DCD is incorporated by reference with no departures or supplements.

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 2, Final Safety Analysis Report**

15.6 DECREASE IN REACTOR COOLANT INVENTORY

This **section** of the referenced DCD is incorporated by reference with the following departures and/or supplements.

15.6.5.3.7.3 Atmospheric Dispersion Factors

Add the following paragraph at the end of DCD **Subsection 15.6.5.3.7.3**.

HAR COL 2.3-4 Site-specific χ/Q values provided in **Subsection 2.3.4** are bounded by the values given in DCD **Tables 15A-5** and **15A-6**.

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 2, Final Safety Analysis Report**

15.7 RADIOACTIVE RELEASE FROM A SUBSYSTEM OR COMPONENT

This **section** of the referenced DCD is incorporated by reference with the following departures and/or supplements.

15.7.3 RELEASE OF RADIOACTIVITY TO THE ENVIRONMENT DUE TO A LIQUID TANK FAILURE

HAR COL 15.7-1 Add the following text at the end of DCD **Subsection 15.7.3**.

This event is defined as an unexpected and uncontrolled release of radioactive water produced by plant operations from a tank rupture. The AP1000 tanks that normally contain radioactive liquid are listed in DCD **Table 15.7-201**.

It is noted that no outdoor tanks contain radioactivity. In particular, the AP1000 does not require boron changes for load follow, and so does not recycle boric acid or water; therefore, the boric acid tank is not radioactive.

The spent resin tanks are excluded from consideration because most of their activity is bound to the spent resins, and they have minimal free water that would be subject to migration from the tank in the event of a tank failure. Tanks inside the containment building were not considered because the containment building, a seismic Category I structure, is a freestanding cylindrical steel containment vessel (DCD **Subsection 1.2.4.1**). Credit is taken for the steel liner to mitigate the effect of a postulated tank failure.

The Liquid Radwaste System (WLS) waste monitor tanks located in the radwaste building extension are considered because of their location in a non-seismic building. These three tanks have a maximum capacity of 15,000 gallons each, and contain processed fluid ready for discharge. The radwaste building has a well sealed, contiguous basemat with integral curbing that can hold the maximum liquid inventory of any tank. Floor drains in the area lead to the liquid radwaste system. The foundation for the entire building is a reinforced concrete mat on grade. Failure of any one of these tanks would be contained within the building and would involve low activity processed liquids being held for pending discharge. Any release to the environment would be leakage through cracks in the concrete. The radiological consequences of such leakage are bounded by the effluent holdup tanks. Therefore, these tanks are excluded as a limiting fault.

The remaining four tank applications were considered - the effluent holdup tanks, waste holdup tanks, monitor tanks (located in the auxiliary building), and chemical waste tanks. Of these tanks, the effluent holdup tanks have both the highest potential radioactive isotope inventory and the largest volume. The other tanks need not be considered further because they have lower isotopic activity and because rooms in which they are located are not on the lowest level of the auxiliary building (and thus intervening interior floors would mitigate the uncontrolled release of a ruptured tank). Therefore, the AP1000 effluent holdup

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 2, Final Safety Analysis Report**

tank is limiting for the purpose of calculating the effects of the failure of a radioactive liquid-containing tank. This failure is classified as a limiting fault.

The consequences of the postulated failure of an effluent holdup tank are presented in detail in [Subsection 2.4.13](#).

15.7.6 COMBINED LICENSE INFORMATION

HAR COL 15.7-1 This COL Item is addressed in [Section 15.7.3](#).

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 2, Final Safety Analysis Report**

HAR COL 15.7-1

**Table 15.7-201 (Sheet 1 of 2)
AP1000 Tanks Containing Radioactive Liquid**

Tank	Location^(a)	Nominal Tank Volume	Radioisotope Contents	Considerations/Features to Mitigate Release
PXS Tanks (IRWST and CMT's)	Inside Containment	NA	NA	Inside containment; release need not be considered.
Spent Fuel Pool	Auxiliary Building	NA	NA	Not a tank, per se. Fully lined and safety related. Located entirely inside aux. building; does not have any potential for foundation cracks to allow leakage directly to environment. Leakage would be to another room of auxiliary building.
WLS Reactor coolant drain tank	Inside containment	NA	NA	Inside containment; release need not be considered.
WLS Containment sump	Inside containment	NA	NA	Inside containment; release need not be considered.
WLS Effluent Holdup Tanks	Auxiliary Building EI 66'-6"	28,000 gal	Essentially reactor coolant	Located in unlined room at lowest portion of the auxiliary building.
WLS Waste Holdup Tanks	Auxiliary Building EI 66'-6"	15,000 gal	Less than reactor coolant	Located in unlined room at lowest portion of auxiliary building.

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 2, Final Safety Analysis Report**

HAR COL 15.7-1

**Table 15.7-201 (Sheet 2 of 2)
AP1000 Tanks Containing Radioactive Liquid**

Tank	Location^(a)	Nominal Tank Volume	Radioisotope Contents	Considerations/Features to Mitigate Release
WLS Monitor Tanks A, B, C	Auxiliary building EI 66'-6" and 117'-6"	15,000 gal	Effluent prepared for environmental discharge – much less than reactor coolant	Located in unlined room at lowest portion of auxiliary building.
WLS Monitor Tanks D, E, F	Radwaste Building	15,000 gal	Effluent prepared for environmental discharge – much less than reactor coolant	Located in unlined room at grade level in curbed, non-seismic building.
WLS Chemical Waste Tank	Auxiliary building EI 66'-6"	8,900 gal	Less than reactor coolant	Located in unlined room at lowest portion of auxiliary building.
WSS Spent Resin Storage Tanks	Auxiliary Building EI 100'	300 ft ³ (liquid volume will be much less)	Approx. reactor coolant	Located entirely inside auxiliary building; does not have any potential for foundation cracks to allow leakage directly to environment. Leakage would be to another room of auxiliary building.

^a Floor elevations are based on design plant grade of 100 ft as provided in the DCD.

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 2, Final Safety Analysis Report**

15.8 ANTICIPATED TRANSIENTS WITHOUT SCRAM

This **section** of the referenced DCD is incorporated by reference with no departures or supplements.

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 2, Final Safety Analysis Report**

APPENDIX 15A EVALUATION MODELS AND PARAMETERS FOR
ANALYSIS OF RADIOLOGICAL CONSEQUENCES OF
ACCIDENTS

This **section** of the referenced DCD is incorporated by reference with the following departures and/or supplements.

15A.3.3 Atmospheric Dispersion Factors

Replace the third paragraph in DCD **Subsection 15A.3.3** with the following:

HAR COL 2.3-4 Site-specific χ/Q values provided in **Subsection 2.3.4** are bounded by the values given in DCD **Tables 15A-5** and **15A-6**.

**Shearon Harris Nuclear Power Plant Units 2 and 3
COL Application
Part 2, Final Safety Analysis Report**

APPENDIX 15B REMOVAL OF AIRBORNE ACTIVITY FROM THE
CONTAINMENT ATMOSPHERE FOLLOWING A LOCA

This **section** of the referenced DCD is incorporated by reference with no departures or supplements.