


Plant West (N25W)

Plant East (S25E)



LEGEND

- \* HAR 2 Marker Bed A
- \*\* HAR 2 Marker Bed B
- Ground Water Level
- Interpreted Lithology Correlation
- Possible Lithology Correlation
- Top of Sound Rock  
(See Table 2.5.4-201 for definition)
- Conglomerate
- Sandstone
- Shale
- Shaley Siltstone and Sandstone
- Siltstone
- Soil (N<50/3")

Vertical Scale: 1" = 40.0'  
Horizontal Scale: 1" = 80.0'

DETAIL:

- Borehole I.D. → BPA-XX
- Ground Surface → GSE = XXX.X ft
- Elevation (Ft.)
- Extent of Soil  
(SPT "N" < 50/3")
- Lithogic Symbol
- RQD
- Observed Clay  
Seam Thickness in  
Rock Core (Ft.)
- Fractures Per Foot

NOTES:

- Clay seams or fracture zones with total clay thickness >0.1 ft. thick are shown at their approximate observed elevation. Values in parenthesis ( ) indicate total clay thickness within fraction intervals.
- See Table 2.5.4-201 for depths and descriptions of soil and top of sound rock.
- See Figure 2.5.4-202 for Cross Section locations.

Progress Energy Carolinas  
Shearon Harris Nuclear Power Plant  
Units 2 and 3  
Part 2, Final Safety Analysis Report  
New Hill, North Carolina

Stratigraphic Cross Section at HAR 2 -  
Plant West to East

FIGURE 2.5.4-204B

Rev. 1