
From: Hoc, PMT12
Sent: Wednesday, March 23, 2011 5:34 PM
To: PMT03 Hoc
Subject: FW: Hi-

From: Milligan, Patricia
Sent: Wednesday, March 23, 2011 5:32 PM
To: Hoc, PMT12
Subject: FW: Hi-

From: Gorman, Susan (CDC/OPHPR/DSNS) [mailto:spg4@cdc.gov]
Sent: Tuesday, February 01, 2011 5:38 PM
To: Milligan, Patricia; Manning, Ronald (HHS/ASPR/BARDA)
Cc: Young, Wayne (HHS/ASPR/BARDA)
Subject: RE: Hi-

Trish, I double checked, and all of our liquid KI expires by May 2012. **After that, we will not carry liquid KI any longer.** I will ask our leadership if they would approve a shipment to them, although it won't buy them much time as far as dating...once I get the answer to that, we can find out if they are still interested.

Sue

Susan E. Gorman, Pharm.D., M.S., DABAT, FAAC
Associate Director for Science
Division of Strategic National Stockpile
Centers for Disease Control and Prevention

From: Milligan, Patricia [mailto:Patricia.Milligan@nrc.gov]
Sent: Tuesday, February 01, 2011 3:33 PM
To: Gorman, Susan (CDC/OPHPR/DSNS); Manning, Ronald (HHS/ASPR/BARDA)
Cc: Young, Wayne (HHS/ASPR/BARDA)
Subject: RE: Hi-

Hi Sue

They need 200 bottles and their supply expires in 2011. I am not so sure they'd be happy with a short extension. See her attached email. Give me a call if you want to talk about this..

Trish

From: Gorman, Susan (CDC/OPHPR/DSNS) [mailto:spg4@cdc.gov]
Sent: Tuesday, February 01, 2011 3:16 PM
To: Manning, Ronald (HHS/ASPR/BARDA); Milligan, Patricia
Cc: Young, Wayne (HHS/ASPR/BARDA)
Subject: RE: Hi-

BOBB / 151

We still have some of the liquid KI and may be able to process a request for it however it does not have long dating on it – do you have any details – i.e. how many bottles/where etc? I can find out if leadership is willing to make a shipment before you let the requestor know. Also, as you know, once the product in SNS expires, it will not be replaced.

Sue

Susan E. Gorman, Pharm.D., M.S., DABAT, FAACT
Associate Director for Science
Division of Strategic National Stockpile
Centers for Disease Control and Prevention

From: Manning, Ronald (HHS/ASPR/BARDA)
Sent: Tuesday, February 01, 2011 3:10 PM
To: Milligan, Patricia
Cc: Gorman, Susan (CDC/OPHPR/DSNS); Young, Wayne (HHS/ASPR/BARDA); Manning, Ronald (HHS/ASPR/BARDA)
Subject: RE: Hi-

Hi Trish –

I am copying Sue Gorman at CDC/SNS on this email. Sue can give you the most accurate answer. I am also copying Wayne Young, who is the BARDA project officer on this contract.

Regards,
Ron

From: Milligan, Patricia [mailto:Patricia.Milligan@nrc.gov]
Sent: Tuesday, February 01, 2011 12:44 PM
To: Manning, Ronald (HHS/ASPR/BARDA)
Subject: Hi-

Hi Ron

Happy new year!!! I hope all is well with you and that you are enjoying this lovely DC weather! I had a question regarding liquid KI replenishment from a community that rec'd liquid KI when it was offered by HHS. Will HHS be resupplying the liquid KI to the communities or was it a one time distribution? Can I have her contact you for information? NRC is only distributing tablets and not liquid.

Thanks

Trish

Patricia A. Milligan, CHP, RPh
Sr. Technical Advisor - Preparedness & Response
Office of Nuclear Security and Incident Response
U.S. Nuclear Regulatory Commission
MS T3 B46M
Washington DC 20555
301-415-2223
patricia.milligan@nrc.gov

From: Hayden, Elizabeth
To: Burnell, Scott
Subject: RE: new hires
Date: Wednesday, March 23, 2011 9:13:00 AM

Oh brother. Are you pursuing this answer?

Beth Hayden
Senior Advisor
Office of Public Affairs
U.S. Nuclear Regulatory Commission
--- Protecting People and the Environment
301-415-8202
elizabeth.hayden@nrc.gov

-----Original Message-----

From: Burnell, Scott
Sent: Wednesday, March 23, 2011 9:10 AM
To: JIM EFSTATHIOU JR., BLOOMBERG/ NEWSROOM:
Cc: Hayden, Elizabeth
Subject: RE: new hires

Hello Jim;

I don't believe we slice our HR data that thinly in terms of "where are they from/where did they go," but I'll see what sorts of statistics we can provide. What's your deadline? Thanks.

Scott Burnell
Public Affairs Officer
Nuclear Regulatory Commission

-----Original Message-----

From: JIM EFSTATHIOU JR., BLOOMBERG/ NEWSROOM: [mailto:jefstathiou@bloomberg.net]
Sent: Wednesday, March 23, 2011 8:58 AM
To: Burnell, Scott
Subject: new hires

Scott,
I'm trying to get some information on the background of employees at the NRC. Can you tell me how many came from industry, academia or elsewhere? Also, can you tell me how many people the agency has hired in the past few years to process new license applications, and their backgrounds? And finally, is there any way to say how many former NRC employees moved to industry jobs?

Thanks in advance for your help.

Jim

Jim Efstathiou Jr.
Bloomberg News
731 Lexington Ave.
New York, N.Y. 10022

Tel: 212 617 1647
Cell: 202 413 8189
E-mail: jefstathiou@bloomberg.net

BBB / 152

From: [LIA07 Hoc](#)
Subject: 1800 EDT (March 23, 2011) USNRC Earthquake/Tsunami Status Update
Date: Wednesday, March 23, 2011 6:01:56 PM
Attachments: [USNRC Earthquake-Tsunami Update.032311.1800EDT.pdf](#)

Hoc
Attached, please find an 1800 EDT (March 23, 2011) status update from the US Nuclear Regulatory Commission's Emergency Operations Center regarding the impacts of the earthquake/tsunami.

Please note that this information is "Official Use Only" and is only being shared within the federal family.

Please call the Headquarters Operations Officer at 301-816-5100 with questions.

-Sara

Sara K. Mroz
Communications and Outreach
Office of Nuclear Security and Incident Response
US Nuclear Regulatory Commission
Sara.Mroz@nrc.gov
LIA07.HOC@nrc.gov (Operations Center)

BBBB / 153

From: LIA07 Hoc
Subject: 0700 EDT (March 23, 2011) USNRC Earthquake/Tsunami Status Update Corrected Document
Date: Wednesday, March 23, 2011 7:02:17 AM
Attachments: NRC Status Update 3.23.11--0700 EDT.pdf

HOC
Please find attached a 0700 EDT (March 23, 2011) status update from the US Nuclear Regulatory Commission's Emergency Operations Center regarding the impacts of the earthquake/tsunami.

This update corrects some information sources, the PMT update, and the International Response

Please note that this information is "Official Use Only" and is only being shared within the federal family.

Please call the Headquarters Operations Officer at 301-816-5100 with questions.

-Jim

Jim Anderson
Office of Nuclear Security and Incident Response
US Nuclear Regulatory Commission
James.anderson@nrc.gov
LIA07.HOC@nrc.gov (Operations Center)

BBBB/ 154

From: Hoc, PMT12
Sent: Thursday, March 24, 2011 6:50 PM
To: ET07 Hoc
Subject: RE: FYI - Customs and Border Patrol protocols for screening people coming from Japan

Is this for information or is this to supplement the review we are doing for the White House to supplement CBP protocol?

From: ET07 Hoc
Sent: Thursday, March 24, 2011 6:42 PM
To: Hoc, PMT12
Subject: FW: FYI - Customs and Border Patrol protocols for screening people coming from Japan

From: LIA06 Hoc
Sent: Thursday, March 24, 2011 6:15 PM
To: ET01 Hoc; ET05 Hoc; ET07 Hoc; ET02 Hoc; ET06 Hoc
Subject: FW: FYI - Customs and Border Patrol protocols for screening people coming from Japan

FYI

Liaison Team Director
U.S. Nuclear Regulatory Commission
Operations Center

From: Virgilio, Rosetta
Sent: Thursday, March 24, 2011 6:13 PM
To: LIA04 Hoc; OST05 Hoc; LIA06 Hoc; LIA08 Hoc; Barker, Allan; Maier, Bill; Tifft, Doug; Woodruff, Gena; Logaras, Harral; McNamara, Nancy; Trojanowski, Robert; /o=USNRC/ou=First Administrative Group/cn=Recipients/cn=6bd3eb76-62865841-d1d223b9-1e5f5439; Browder, Rachel; Erickson, Randy; Janda, Donna; Lynch, James; Orendi, Monica
Cc: Turtill, Richard; Piccone, Josephine; Jackson, Deborah
Subject: FW: FYI - Customs and Border Patrol protocols for screening people coming from Japan

THE INFO BELOW AND ATTACHED ARE FYI ONLY - NOT FOR DISSEMINATION, PER CRCPD

Note the documents were transmitted to State health officials, public health preparedness directors, and environmental health directors to verify contact info. A CRCPD working group is also working on associated talking points.

From: Cuadrado, Leira
Sent: Thursday, March 24, 2011 4:33 PM
To: Virgilio, Rosetta
Subject: FW: FYI - Customs and Border Patrol protocols for screening people coming from Japan

From: Ruth McBurney [mailto:rmcburney@crcpd.org]
Sent: Thursday, March 24, 2011 4:08 PM
To: Cuadrado, Leira; Lewis, Robert
Subject: FW: FYI - Customs and Border Patrol protocols for screening people coming from Japan

BBBBB/ 155

Here is the information that went out earlier today to the radiation control programs. We have a work group working on follow-up talking points on how contaminated persons, clothing and luggage are to be handled by radiation control programs.

We will also copy you with these when they are developed.

Ruth

From: Ruth McBurney
Sent: Thursday, March 24, 2011 12:33 PM
Cc: 'Adela Salame-Alfie'
Subject: FYI - Customs and Border Patrol protocols for screening people coming from Japan

Dear Director and Associate Members,

Attached you will find the suite of documents that make up the Traveler Plan Protocol and Procedures for screening travelers leaving Japan for possible radioactive contamination. These documents were prepared by an interagency workgroup to make sure it was appropriate and addresses many concerns.

We realize that some of you may need additional guidance on how to handle people arriving with contamination greater than 20 x background. At the same time, we are aware that each state may handle things differently. Please reach out to Adela or me if you need further assistance.

Please verify the contact information for your state and notify CRCPD as soon as possible of any changes. These documents will be made available on the secure side of the website for Director and Associate Members.

Included with this email is a document that lists the airports receiving direct flights from Japan. While every jurisdiction should be prepared to manage these cases, clearly the 14 states/territories that receive direct flights from Japan would be more directly impacted.

Please be aware that these documents have been transmitted to state health officials, public health preparedness directors, and environmental health directors.

Please share with those within your agency/public health system who have a need to know but, for now, this probably should not be widely or publicly distributed/posted.

Ruth E. McBurney
Executive Director
CRCPD
502-227-4543, ext. 0

*WFA
HOC*

From: LIA07 Hoc
To: Borchardt, Bill; Bradford, Anna; Cohen, Shari; Cooper, LaToya; Dyer, Jim; Flory, Shirley; Gibbs, Catina; Haney, Catherine; Hudson, Sharon; Jaczko, Gregory; Johnson, Michael; Leeds, Eric; Loyd, Susan; Pace, Patti; Schwarz, Sherry; Sheron, Brian; Speiser, Herald; Sprogeris, Patricia; Taylor, Renee; Virgilio, Martin; Walls, Lorena; Weber, Michael
Subject: Update for Go Books - 1800 EDT, March 24, 2011
Date: Thursday, March 24, 2011 6:21:25 PM
Attachments: [Talking Points 13.pdf](#)
[QA Price-Anderson Act 3-24-2011.pdf](#)
[TEPCO Press Release 145.pdf](#)
[TEPCO Press Release 133.pdf](#)
[TEPCO Press Release 134.pdf](#)
[TEPCO Press Release 135.pdf](#)
[TEPCO Press Release 136.pdf](#)
[TEPCO Press Release 137.pdf](#)
[TEPCO Press Release 138.pdf](#)
[TEPCO Press Release 139.pdf](#)
[TEPCO Press Release 140.pdf](#)
[TEPCO Press Release 141.pdf](#)
[TEPCO Press Release 142.pdf](#)
[TEPCO Press Release 143.pdf](#)
[TEPCO Press Release 144.pdf](#)
[ET Chronology 3-24-11 1800.pdf](#)
[USNRC Earthquake-Tsunami Update.032411.1800EDT.pdf](#)
[March 24 1515EDT one pager \(3\).docx](#)

Please find attached updated information for the "Go Books".

The updates include:

- The 1800 EDT, 03/24/11 Status Update
- The latest ET Chronology
- The latest TEPCO Press Releases (Numbers 133-145)
- NRC Talking Points (Talking Points 13 and Q&A Price-Anderson Act)
- "One Pager" (1515 EDT, 03/24/11)

Please let me know if you have any questions or concerns.

-Sara

Sara Mroz
Communications and Outreach
Office of Nuclear Security and Incident Response
US Nuclear Regulatory Commission
Sara.Mroz@nrc.gov
LIA07.HOC@nrc.gov (Operations Center)

From: OST04 Hoc
Sent: Thursday, March 24, 2011 6:11 PM
To: LIA07 Hoc
Subject: Status Update Attachments 18:00 EDT 3-23-2011

Information for the following Tabs

Talking Points (Talking points 13 & QA Price-Anderson Act)

GGBB/156

ET Chronology

NRC Press Release – No new Updates (Last update 3/23)

TEPCO Press Release (Numbers 133-145)

OPA

TALKING POINTS

JAPAN NUCLEAR SITUATION

As of 3/24/2011 3:30 PM

Updates in Red

CONTENTS

- 1. The Safety of U.S. Nuclear Power Plants**
- 2. Monitoring Radiation in the United States**
- 3. The Situation in Japan**

PART 1: THE SAFETY OF U.S. NUCLEAR POWER PLANTS

- The NRC is always looking to learn information that can be applied to U.S. reactors and we will analyze the information that comes from this incident. President Obama has asked the agency to conduct a comprehensive review of the safety of U.S. nuclear plants; the agency will do so.
- The NRC issued an Information Notice on March 18 to all of its operating nuclear power plants describing the effects of the March 11 earthquake and tsunami on Japanese nuclear power plants. The purpose of the Information Notice is to inform the plants of the most recent information available to the NRC. The NRC expects U.S. nuclear power plants will review the entire notice to determine how it applies to their facilities and consider actions, as appropriate.
- U.S. nuclear power plants are built to withstand environmental hazards, including earthquakes. Even those plants that are located outside of areas with extensive seismic activity are designed for safety in the event of such a natural disaster.
- The NRC requires that safety-significant structures, systems, and components be designed to take into account the most severe natural phenomena historically reported for the site and surrounding area. The NRC then adds a margin for error to account for the limitations on historical data. In other words, U.S. nuclear power plants are designed to be safe based on historical data to predict the area's maximum credible earthquake.
- In response to MSNBC.com report ranking US NPPs according to vulnerability to earthquakes: The NRC does not rank nuclear power plants according to their vulnerability to earthquakes. This "ranking" was developed by an MSNBC reporter using partial information and an even more partial understanding of how we evaluate plants for seismic risk. Each plant is evaluated individually according to the geology

of its site, not by a "one-size-fits-all" model - therefore such rankings or comparisons are highly misleading.

- In the 1980s and 1990s, the NRC required several changes to the BWR Mark I containments at U.S. plants to ensure they could continue to deal with severe events. The first issue involved the design's large circular tube, or "torus," which holds enough water to safely condense the large volumes of steam that could be released during a severe event. The NRC became aware in the mid-late 1970s that designers might have underestimated the forces the torus would have to withstand during an event. The NRC laid out an appropriate generic approach to resolving the issue in August 1982, and individual reactors carried out their plant-specific torus reinforcement efforts.
- The second issue involved the potential for containment failure following an extended loss of decay heat removal capability. Under the Mark I Containment Performance Improvement program that ran from the late 1980s into the early 1990s, all Mark I BWRs operating at that time installed hardened vent systems to provide an additional decay heat removal capability to protect against containment overpressure failure. The containment vent system could also be used to control hydrogen concentrations in containment. Two units, Browns Ferry 1 and 3, were in extended shutdown at that time, and hardened vents were installed before those reactors restarted. In addition most plants provided an alternate water injection capability that is independent of normal and emergency power supplies and enhanced the reliability of the automatic depressurization system to reduce the likelihood of a challenge to containment. Furthermore, in 2003, the Commission issued the "Hydrogen Rule" (10CFR50.44) that required all BWR Mark I plants to operate in an inert atmosphere to preclude the possibility of a hydrogen explosions in containment.
- The NRC recommendation related to a 50-mile evacuation zone for Americans near the affected nuclear power plants in Japan is consistent with the same kind of approach that

would be used in the United States should a comparable, although extremely unlikely, event take place here.

- In November 1976, a federal task force was formed to look at salient emergency planning issues for U.S. nuclear power plants. Out of that comprehensive evaluation came a recommendation that a 10-mile-radius EPZ would assure that “prompt and effective actions can be taken to protect the public in the event of an accident” at a plant. This was based on research showing the most significant impacts of an accident would be expected in the immediate vicinity of a plant and therefore any initial protective actions, such as evacuations or sheltering in place, should be focused there. That does not mean the protective actions could not expand beyond the 10-mile radius. Rather, emergency planners have always known such actions could be necessary if the situation warranted it. (See NUREG 0654/FEMA-REP-1.)
- Following the events of Sept. 11, 2001, NRC required all nuclear plant licensees to take additional steps to protect public health and safety in the event of a large fire or explosion. In accordance with NRC regulations, all nuclear power plants are required to maintain or restore cooling for the reactor core, containment building, and spent fuel pool under the circumstances associated with a large fire or explosion. These requirements include using existing or readily available equipment and personnel, having strategies for firefighting, operations to minimize fuel damage, and actions to minimize radiological release to the environment. In general, mitigative strategies are plans, procedures, and pre-staged equipment whose intent is to minimize the effects of adverse events. If needed, these mitigative strategies could also be used during natural phenomena such as earthquakes, tornadoes, floods, and tsunamis.

PART 2: MONITORING RADIATION IN THE UNITED STATES

- The NRC is working closely with our federal partners to monitor radiation releases from the Japanese nuclear power plants. Given the results of the monitoring and distance between Japan and Hawaii, Alaska, U.S. Pacific Territories and the U.S. West Coast, the NRC expects the U.S. to avoid any harmful levels of radioactivity. Reports of radiation being detected in the United States are all far below levels that would present a health risk. Additional questions regarding monitoring of the radioactive release should be referred to DOE at 202 586 4940.
- We are aware that minute amounts of radioactive elements have been detected at the very sensitive monitoring equipment at a number of privately owned nuclear plants. The US Government is looking at the best vehicle for reporting to the public this and any other data gathered by government. Nothing detected so far comes anywhere near a level that might concern us. We remain convinced there will be no health impact on the United States.
- The Department of Energy has been designated the lead agency for communicating information to the states regarding monitoring of radiation heading toward or over the United States. The DOE's Lawrence Livermore National Laboratory (National Atmospheric Release Assessment Center) is monitoring weather patterns over the Pacific Ocean. The Environmental Protection Agency maintains air monitoring stations throughout the country and has reinforced its monitoring effort. DOE will provide aerial monitoring. Questions about this effort should be directed to DOE at 202 586 4940.
- The Environmental Protection Agency has increased its radiation monitoring in the western U.S. Data from the EPA's RadNet is available on the EPA's website.

- [Only if specifically asked] The NRC is aware that Diablo Canyon nuclear power plant in California, among others, have detected a very low level of radiation. The site believes that the source of the radiation is likely the Fukushima Daiichi nuclear power plant in Japan. The amounts detected are barely detectable on the instruments and pose no danger to public health and safety. The NRC continues to believe, based on all available information, that no harmful levels of radiation will reach U.S. territory. This information has been shared with the U.S. Department of Energy and the U.S. Environmental Protection Agency. Additional questions regarding monitoring of the radioactive release should be referred to DOE at 202 586 4940.
- In accordance with established protocols, U.S. Customs and Border Protection (CBP) employs several types of radiation detection equipment in its operations at both air and sea ports, and uses this equipment, along with specific operational protocols, to resolve any security or safety risks that are identified with inbound travelers and cargo. Out of an abundance of caution, CBP has issued field guidance reiterating its operational protocols and directing field personnel to specifically monitor maritime and air traffic from Japan. CBP will continue to evaluate the potential risks posed by radiation contamination on inbound travelers and cargo and will adjust its detection and response protocols, in coordination with its interagency partners, as developments warrant.

PART 3: THE SITUATION IN JAPAN

- As of Sunday, March 20, 2011, the NRC continues to monitor the nuclear crisis in Japan stemming from the March 11 earthquake and tsunami. NRC's top priorities are the continued assessment of radiological conditions, dose predictions, and protective action recommendations. This effort focuses primarily on conditions in Japan around the vicinity of the Fukushima Daiichi nuclear power plant. The NRC is also working with DOE to model the flow of radiation across the Pacific Ocean toward the United States.
- A team of 10 NRC experts continues to assist Japanese efforts in Tokyo as part of a USAID-sponsored assistance effort. [If asked: One team member fell ill and returned to the US. Numbers in the team and names change; please check if asked.]
- The Commission was briefed by the NRC staff on the situation in Japan at a public meeting on Monday, March 21, 2011. A transcript for the public commission meeting held yesterday has been posted. The meeting included an overview of NRC actions related to the Japanese emergency and the possible short- and long-term activities for the NRC. The transcript can be found here: <http://www.nrc.gov/reading-rm/doc-collections/commission/recent/2011/>. And the slides from the meeting are located at: <http://www.nrc.gov/reading-rm/doc-collections/commission/slides/2011/20110321/staff-slides-03212011-meeting-rev1.pdf>.
- Chairman Jaczko gave opening remarks at the meeting. He said, in part, "We have a responsibility to the American people to undertake a systematic and methodical review of the safety of our own domestic nuclear facilities, in light of the natural disaster and the resulting nuclear emergency in Japan. Beginning to examine all available information is an essential part of our effort to analyze the event and understand its impact on Japan and implications for the United States. Our focus is always on keeping plants and radioactive materials in this country safe and secure."

A copy of his full opening remarks can be found here: <http://www.nrc.gov/reading-rm/doc-collections/news/2011/11-054.pdf>

- Based on calculations performed by NRC experts, we continue to believe that it is appropriate for U.S. residents within 50 miles of the Fukushima reactors to evacuate. Our recommendation is based on NRC guidelines for public safety that would be used in the United States under similar circumstances.
- The 10-mile EPZ reflects the area where projected doses from design basis accidents at nuclear power plants would not exceed the EPA's protective action guidelines, and we are confident that it would be adequate even for severe accidents. However, the 10-mile zone was always considered a base for emergency response that could be expanded if the situation warranted. The situation in Japan, with four reactors experiencing exceptional difficulties simultaneously, creates the need to expand the EPZ beyond the normal 10-mile radius, based on our limited data and conservative assumptions.
- The NRC is closely monitoring information about the spent fuel pools as well as radiation levels at the Japanese nuclear power plants. Given the totality of the situation, the NRC's recommendation for U.S. residents within 50 miles of the Fukushima reactors to evacuate remains unchanged. That recommendation was based on actual radiation levels in the nuclear complex.
- The Japanese government has formally asked for U.S. assistance in responding to nuclear power plant cooling issues triggered by an earthquake and tsunami on March 11.
- The NRC is coordinating its actions with other federal agencies as part of the U.S. government response. The NRC's headquarters Operations Center was activated at the beginning of the event and has been monitoring the situation on a 24-hour basis ever since.

Frequently Asked Questions

1. What is the Price-Anderson Act?

In 1957, a federal law called the Price-Anderson Act was established to ensure that adequate money would be available to pay insurance claims following an accident at a commercial nuclear power plant. That law is still in place to protect those that live around nuclear power plants.

2. My insurance agent said that my homeowner's insurance does not cover nuclear accidents. Does Price-Anderson protect me?

Your homeowner's insurance policy does not cover nuclear accidents because Price-Anderson covers claims related to nuclear accidents. By law, owners of nuclear power plants are required to purchase \$375 million of offsite liability insurance for each reactor at the plant. If a nuclear accident causes damages of more than \$375 million, the insurance is supplemented by additional coverage that is shared by every nuclear power plant in the country. There are currently 104 reactors licensed to operate in the United States, so this secondary pool of money contains about \$12.6 billion. If all of this secondary money is used, Congress would determine whether to provide additional disaster relief.

3. The Price-Anderson Act is a federal law? Why does the government spend my tax dollars on providing nuclear insurance to big energy companies?

The Price-Anderson Act is a federal law, but your tax dollars do not pay for the insurance it requires owners of nuclear power plants to purchase. The extra insurance protection required for large commercial nuclear power companies is purchased at no cost to the public or the federal government.

4. My insurance company is a nationally known, reputable business that I trust. What insurance company does the nuclear plant use – a good one or the cheapest one they can find?

All U.S. nuclear power plant owners purchase their Price-Anderson insurance from American Nuclear Insurers (ANI), which is made of several large and reputable insurance companies. About half of the ANI companies are foreign insurance businesses. On average, a nuclear power plant owner pays about \$400,000 per year for Price-Anderson insurance at a single-unit reactor site. For power plants with more than one reactor, the total annual insurance cost is typically discounted, similar to automobile insurance for households with more than one car.

5. More than a million people live within 50 miles of Plant X. How is a \$375 million insurance policy supposed to cover all of us?

The Price-Anderson Act is a federal law that requires owners of nuclear power plants to purchase \$375 million of offsite liability insurance for each reactor at the plant. If a nuclear accident causes damages of more than \$375 million, the insurance is supplemented by additional coverage that is shared by every nuclear power plant in the country. There are currently 104 reactors licensed to operate in the United States, so this secondary pool of money

contains about \$12.6 billion. If all of this secondary money is used, Congress would determine whether to provide additional disaster relief.

6. Why does the NRC let a private insurance company determine the amount of insurance coverage? Why does this private company control public protection?

The intent of the Price-Anderson Act was to allow the government to regulate the safety of nuclear power while allowing the private insurance industry to provide financial protection. The NRC is the government agency that is responsible for ensuring that nuclear power plants are designed and operated in a way that protects public health and safety. The NRC is confident that the amount of insurance coverage determined by the private insurance company is adequate to provide financial compensation in the event of a nuclear accident.

7. The accidents in Japan affected the reactors and the spent fuel pools. Does the Price-Anderson Act cover all nuclear plant accidents or just some of them?

The Price-Anderson Act covers all property and liability claims resulting from nuclear accidents at commercial nuclear power plants. This includes any incident related to the reactor or the spent fuel pool. Price-Anderson also covers claims related to transporting nuclear fuel and nuclear waste in and out of the plant.

8. I'll have to find another place to stay if I have to evacuate my home during a nuclear accident. I can't afford to pay for a hotel or apartment for several months while the government tries to clean things up. How am I supposed to pay for that?

Insurance under the Price-Anderson Act covers bodily injury, sickness, disease or resulting death, property damage and loss, and reasonable living expenses for people who are evacuated from a nuclear accident. The Stafford Act is another federal law that provides disaster relief to state and local governments. If a nuclear accident is declared an emergency or major disaster by the President, the Stafford Act will also be available to provide assistance to accident victims. The Stafford Act allows the federal and state governments to share costs of temporary housing for up to 18 months. It also provides additional money for home repair and temporary mortgage or rental payments. Distribution of Stafford Act funding is done through the Federal Emergency Management Agency. Together, the Price-Anderson and Stafford Acts provide money for a variety of expenses following a nuclear accident.

9. Has Price-Anderson ever been used?

Only once. During the 1979 accident at the Three Mile Island Nuclear Power Plant, the Price-Anderson Act provided liability insurance to the public. The day after the accident, insurance company representatives established a local claims office in Pennsylvania. Advertisements were placed in local newspapers to inform residents of claims procedures. The insurance paid for the living expenses of families who decided to evacuate, although evacuation was not immediately ordered. When Pennsylvania's governor recommended the evacuation of pregnant women and families with young children who lived near the plant, the insurance paid for those evacuation expenses, too. In 1979, more than 3000 people received nearly \$1.2 million in evacuation claims. More than 600 people were also reimbursed for lost wages as a result of the accident. In the months after the accident, numerous lawsuits were filed alleging various

injuries and property damages. To date, the Price-Anderson insurance has paid about \$71 million in claims and litigation costs associated with the Three Mile Island accident. All payments were made from the primary insurance coverage. Money from the secondary layer of insurance was not needed.

10. When does the Price-Anderson Act expire?

In 2005, the Price-Anderson Act was extended through December 31, 2025.



Press Releases

Press Release (Mar 24, 2011)

Detection of trace amounts of radioactive iodine around an exhaust stack and others of Kashiwazaki-Kariwa Nuclear Power Station

TEPCO has measured exhaust air from an exhaust stack and vent of each building of Kashiwazaki-Kariwa nuclear power station with a filter for a week, and detected iodine 131 up to 2.4×10^{-4} (becquerel/cm³) at the exhaust stacks of all buildings, the exhaust vents of service buildings and auxiliary buildings (Arahama-side) of Unit 3, 5 and 6.

It slightly exceeded the upper limit (please refer to the attachment for more information).

Therefore, TEPCO checked operation conditions and works of all units, readings of high sensitivity off gas monitor¹, a periodical analysis result of iodine 131 contained in reactor water of Unit 1, 5, 6 and 7 in operation. However, any abnormality was detected.

It is presumed that iodine 131 released into the atmosphere from Fukushima Daiichi Nuclear Power Station was collected and detected in Kashiwazaki-Kariwa Nuclear Power Station, since iodine 131 was detected in radioactivity measurement of the exhaust air of some units and no abnormality of iodine 131 in nuclear water was detected.

Readings of monitoring posts and dust radiation monitors are within the normal range and have little environmental impact. The monitoring posts are located at boundary of the station and measure an ambient dose rate. The dust radiation monitors² are located beside the monitoring posts.

Attachment: measurement result of iodine 131 in
Kashiwazaki-Kariwa Nuclear Power Station


¹: High sensitivity off gas monitor
Measurement equipment installed in an off-gas treatment system to detect minimal leakage of radioactive materials from fuel rods to the nuclear water early

²: Dust radiation monitor
Measurement equipment to monitor radioactivity contained in dust which is collected around boundary of the nuclear power station. Three dust radiation monitors are installed beside the monitoring posts.

attachment1: measurement result of iodine 131 in
Kashiwazaki-Kariwa Nuclear Power Station

attachment2: Detection of trace amounts of radioactive iodine around an exhaust stack and others of Kashiwazaki-Kariwa Nuclear Power

[Back to page top](#)



Press Releases

Press Release (Mar 24, 2011) Plant Status of Fukushima Daini Nuclear Power Station (as of 9:00 am March 24th)

[No update from the last release issued at 9:00 pm, March 23rd]

Unit Status

- 1 · Reactor cold shutdown, stable water level, offsite power is available.
 · No cooling water is leaked to the reactor containment vessel.
 · Maintain average water temperature at 100°C in the pressure restraint.
- 2 · Reactor cold shutdown, stable water level, offsite power is available.
 · No cooling water is leaked to the reactor containment vessel.
 · Maintain average water temperature at 100°C in the pressure restraint.
- 3 · Reactor cold shutdown, stable water level, offsite power is available.
 · No cooling water is leaked to the reactor containment vessel.
 · Maintain average water temperature at 100°C in the pressure restraint.
- 4 · Reactor cold shutdown, stable water level, offsite power is available.
 · No cooling water is leaked to the reactor containment vessel.
 · Maintain average water temperature at 100°C in the pressure restraint.

Other N.A.

[back to page top](#)



Press Releases

Press Release (Mar 24, 2011)
Status of TEPCO's Facilities and its services after Tohoku-Taiheiyoku-Oki Earthquake (as of 9:00AM)

Due to the Tohoku-Taiheiyoku-Oki Earthquake which occurred on March 11th 2011, TEPCO's facilities including our nuclear power stations have been severely damaged. We deeply apologize for the anxiety and inconvenience caused.

Below is the status of TEPCO's major facilities.

*new items are underlined

[Nuclear Power Station]

Fukushima Daiichi Nuclear Power Station:

Units 1 to 3: shutdown due to earthquake
(Units 4 to 6: outage due to regular inspection)

* The national government has instructed to evacuate for those local residents within 20km radius of the site periphery and to remain indoors for those local residents between 20km and 30km radius of the site periphery.

* Off-site power was connected to Unit 1 to 6.

* Unit 1

The explosive sound and white smoke was confirmed near Unit 1 when the big quake occurred at 3:36pm, March 12th. We have started injection of sea water at 8:20 pm, March 12th, and then boric acid which absorbs neutron into the reactor afterwards.

At approximately 2:30 am, March 23rd, we have started the injection of sea water into the reactor from feed water system.

* Unit 2

At 1:25 pm, March 14th, since the Reactor Core Isolation Cooling System has failed, it was determined that a specific incident stipulated in Clause 1, Article 15 of Act on Special Measures Concerning Nuclear Emergency Preparedness occurred (failure of reactor cooling function). At 5:17 pm, March 14th, while the water level in the reactor reached the top of the fuel rod, we have restarted the water injection with the valve operation.

At approximately 6:14 am, March 15th, the abnormal sound was confirmed near the suppression chamber and the pressure inside the chamber decreased afterwards. It was determined that there is a possibility that something happened in the suppression chamber. While sea water injection to the reactor continued, TEPCO employees and workers from other companies not in charge of injection work started tentative evacuation to a safe location. Sea water injection to the reactor continued.

On March 18th, power was delivered up to substation for backup power through offsite transmission line. We completed laying cable further to unit receiving facility in the building, and at 3:46 pm, March 20th the load-side power panel of the receiving facility started to be energized.

From 3: 05 pm to 5: 20 pm on March 20th, 40 tons of seawater was injected into Unit 2 by TEPCO employees.

At 6:20 on March 21st, white smoke was confirmed arising from the top of the reactor building. As of 7:11 am on March 22nd, smoke decreased to the level where we can hardly confirm.

From around 4 pm to 5 pm on March 22nd, approximately 18 tons of sea water was injected into the spent fuel pool by TEPCO employees.

* Unit 3

At 6:50 am, March 14th, while water injection to the reactor was under operation, the pressure in the reactor containment vessel increased to 530 kPa. As a result, at 7:44 am, it was determined that a specific incident stipulated in article 15, clause 1 occurred (abnormal increase of the pressure of reactor containment vessel). Afterwards, the pressure has gradually decreased (as of 9:05 am, 490 kPa).

At approximately 11:01 am, March 14th, an explosion followed by white smoke occurred near Unit 3. 4 TEPCO employees and 3 workers from other companies (all of them are conscious) have sustained injuries and they were already taken to the hospital by ambulances.

As the temperature of water in the spent fuel pool rose, spraying water by helicopters with the support of the Self Defense Force was considered, however the operation on March 16th was cancelled.

At 6:15 am, March 17th, the pressure of the Suppression Chamber temporarily increased, but currently it is stable in a certain range. On March 20th, we were preparing to implement a measurement to reduce the pressure of the reactor containment vessel (partial discharge of air containing radioactive material to outside) in order to fully secure safety. However, at present, it is not a situation to take a measure immediately to discharge air containing radioactive material to outside. We will continue to monitor the status of the pressure of the reactor containment vessel. Monitoring will be continued.

In order to cool spent fuel pool, water was sprayed by helicopters on March 17th with the cooperation of Self-Defense Forces.

At approximately past 7:00 pm, March 17th, Self-Defense Forces and the police had started spraying water by water cannon trucks upon our request for the cooperation. At 8:09 pm, March 17th, they had finished the operation.

At 2:00 pm, March 18th, spraying water by fire engines was started with the cooperation of Self-Defense Forces and the United States Armed Forces. At 2:45 pm, March 18th, they had finished the operation.

At approximately 0:30 am, March 19th, spraying water was started with the cooperation of Fire Rescue Task Forces of Tokyo Fire Department started spraying water. At approximately 1:10 am, March 19th, they finished the operation. They resumed spraying water at 2:10 pm. At approximately 3:40 am, March 20th, they finished the operation.

At approximately 9:30 pm, March 20th, spraying water was started with the cooperation of Fire Rescue Task Forces of Tokyo Fire Department. At approximately 3:58 am, March 21st, they finished the operation.

At approximately 3:55 pm, March 21st, light gray smoke was confirmed arising from the southeast side of the 5th floor roof of the Unit 3 building, and the situation was reported to the fire department at approximately 4:21 pm. The parameters of reactor pressure vessel, reactor containment vessel, and monitored environmental data remained at the same level. However, employees working around Unit 3 evacuated to a safe location. It is observed the smoke has been decreasing. On March 22nd, the color of smoke changed to somewhat white and it is slowly dissipating.

At approximately 3:10 pm on March 22nd, water discharge into Unit 3 by Tokyo Fire Department's Hyper Rescue and Osaka City Fire Department was conducted and completed at approximately 4:00 PM on the same day.

At approximately 10:45 pm on March 22nd, lights in the main operation room were restored.

At 11:00 am on March 23rd, the injection of sea water to spent fuel pool was conducted, and finished approximately at 1:20 pm on the same day.

At 4:20 pm on March 23rd, light gray smoke was observed belching from Unit 3 building. The situation was reported to the fire department at 4:25 pm on March 23rd.

The parameters of the reactor, the reactor containment vessel of Unit 3, and monitored figures around the site's immediate surroundings remained stable without significant change. To be safe, workers in the main control room of Unit 3 and around Unit 3 evacuated to a safe location.

At approximately 11:30 pm on March 23rd and 4:50 am on March 24th, TEPCO employees confirmed the smoke has disappeared. Accordingly, workers evacuation was lifted.

At approximately 5:35 am on March 24th, sea water injection through Fuel Pool Cooling and Filtering System was initiated.

* Unit 4

At approximately 6:00 am, March 15th, an explosive sound was heard and the damage in the 5th floor roof of Unit 4 reactor building was confirmed. At 9:38 am, the fire near the north-west part of 4th floor of Unit 4 reactor building was confirmed. At approximately 11:00 am, TEPCO employees confirmed that the fire was off.

At approximately 5:45 am on March 16th, a TEPCO employee discovered a fire at the northwest corner of the Nuclear Reactor Building. TEPCO immediately reported this incident to the fire department and the local government and proceeded with the extinction of fire.

At approximately 6:15 am, TEPCO staff confirmed at the site that there are no signs of fire.

At approximately 8:21 am on March 20th, spraying water by fire engines was started with the cooperation of Self-Defense Forces and they finished the operation at approximately 9:40 am. At approximately 6:45 pm spraying water was started by Self-Defenses' water cannon trucks and finished at approximately 7:45 pm.

At approximately 6:30 am, March 21st, spraying water by fire engines was started with the cooperation of Self-Defense Forces and the United States Armed Forces. At approximately 8:40 am, March 21, they had finished the operation.

On March 21st, cabling has been completed from temporary substation to the main power center.

From approximately 5:20 pm on March 22nd, water discharge from the concrete pumping vehicle was conducted and ended at approximately 8:30 pm on the same day.

From approximately 10:00 am on March 23rd, water discharge from the concrete pumping vehicle was conducted and ended at approximately 1:00 pm on the same day.

* Unit 5 and 6

At 5 am on March 19th, we started the Residual Heat Removal System Pump (C) of Unit 5 in order to cool the spent fuel pool. At 10:14 pm, we started the Residual Heat Removal System Pump (B) of Unit 6 in order to cool the spent fuel pool.

Unit 5 has been in reactor cold shutdown since 2:30 pm on March 20th. Unit 6 has been in reactor cold shutdown since 7:27 pm on March 20th.

At Units 5 and 6, in order to prevent hydrogen gas from accumulating within the buildings, we have made three holes on the roof of the reactor building for each unit.

At approximately 5:24 pm on March 23rd, the temporary Residual Heat Removal System Seawater Pump automatically stopped when its power source was switched. We plan to repair the pump while maintaining the appropriate the water level and the temperature in the reactor.

* On March 18th, regarding the spent fuel in the common spent fuel pool, we have confirmed that the water level of the pool is secured. A detailed inspection is under preparation.

* common spent fuel pool: a spent fuel pool for common use set in a separate building in a plant site in order to preserve spent fuel which are transferred from the spent fuel pool in each Unit building.

* On March 17th, we patrolled buildings for dry casks and found no signs of abnormal situation for the casks by visual observation. A detailed inspection is under preparation.

* dry cask: a measure to store spent fuel in a dry storage casks in storages. Fukushima Daiichi Nuclear Power Station started to utilize the measure from August 1995.

* In total 12 fire engines are lent for spraying water to the spent fuel pools and water injection to the nuclear reactors by various regional fire departments* as well as Tokyo Fire Department.

* On March 21st and 23rd, we detected cobalt, iodine and cesium from the seawater around discharge canal of Unit 1, 2, 3 and 4.

* On March 20th and 22nd, we detected iodine, cesium and tellurium in the air collected at the site of Fukushima Daiichi Nuclear Power Station.

* We will continuously endeavor to securing safety, and monitoring of the surrounding environment.

Fukushima Daiichi Nuclear Power Station:

Units 1 to 4: shutdown due to earthquake

* The national government has instructed evacuation for those local residents within 10km radius of the periphery.

* In order to achieve cold shutdown, reactor cooling function was restored and cooling of reactors was conducted. As a result, all reactors achieved cold shutdown: Unit 1 at 5:00 pm, March 14th, Unit 2 at 6:00 pm, March 14th, Unit 3 at 0:15 pm, March 12th, Unit 4 at 7:15 am, March 16th.

* Since March 12th, we had been preparing measures for reducing the pressure of reactor containment vessels (partial discharge of air containing radioactive materials to outside), but on March 17th, we released such preparation in all Units.

*** (Unit 1)**

As it is confirmed that the temperature of the Emergency Equipment Cooling Water System*1 has increased, at 3:20 pm, March 15th, we stopped the Residual Heat Removal System (B) for the inspection. Subsequently, failure was detected in the power supply facility associated with the pumps of the Emergency Equipment Cooling Water System. At 4:25 pm, March 15th, after replacing the power facility, the pumps and the Residual Heat Removal System (B) have been reactivated.

*** (Unit 4)**

As it is confirmed that the pressure at the outlet of the pumps of the Emergency Equipment Cooling Water System*1 has been decreased, at 8:05 pm, March 15th, we stopped the Residual Heat Removal System (B) for the inspection. Subsequently, failure was detected in the power supply facility associated with the pumps of the Emergency Equipment Cooling Water System. At 9:25 pm, March 15th, after replacing the relevant facility, the pumps and the Residual Heat Removal System (B) have been reactivated.

*1: emergency water system in which cooling water (pure water) circulates which exchanged the heat with sea water in order to cool down bearing pumps and/or heat exchangers etc.

Kashiwazaki Kariwa Nuclear Power Station:

Units 1, 5, 6, 7: normal operation

(Units 2 to 4: outage due to regular inspection)

[Thermal Power Station]

Hirono Thermal Power Station Units 2 and 4: shutdown due to earthquake
Hitachinaka Thermal Power Station Unit 1: shutdown due to earthquake
Kashima Thermal Power Station Units 2, 3, 5, 6: shutdown due to earthquake
Higashi-Ogishima Thermal Power Station Unit 1: currently being restarted

[Hydro Power Station]

* All the stations have been restored.
(Facilities damaged by the earthquake are now properly under consideration)

[Transmission System, etc.]

All substation failed due to the earthquake have been restored.

[Blackout in TEPCO's Service Area]

All the blackouts are resolved.

[Supply and Demand Status within TEPCO's Service Area to Secure Stable Power Supply]

Backup supply from Shinshinano Conversion Station: 600MW
Backup supply from Sakuma Conversion Station: 300MW
Backup supply from Higashi Shimizu Conversion Station: 100MW
Backup supply from Hokkaido-Honshu Interconnection Facilities: 600MW

Considering the critical balance of our power supply capacity and expected power demand forward, in order to avoid unexpected blackout, TEPCO has been implementing rolling blackout (planned blackout alternates from one area to another) since Mar 14th. We will make our utmost to secure the stable power supply as early as possible.

For customers who will be subject to rolling blackout, please be prepared for the announced blackout periods. Also for customers who are not subject to blackout, TEPCO appreciates your continuous cooperation in reducing electricity usage by avoiding using unnecessary lighting and electrical equipment.

[Others]

Please do NOT touch cut-off electric wires.
In order to prevent fire, please make sure to switch off the electric appliances such as hair drier and to shut down the breaker of distribution board when you leave your house.
For the customer who has in-house power generation, please secure fuel for generator.

 [back to page top](#)

Press Releases

Press Release (Mar 24, 2011)

Plant Status of Fukushima Daiichi Nuclear Power Station (as of 11:30 AM Mar 24th)

*new items are underlined

All 6 units of Fukushima Daiichi Nuclear Power Station have been shut down.

Unit 1 (Shut down)

- Reactor has been shut down. However, the explosive sound and white smoke were confirmed after the big quake occurred at 3:36 pm Mar 12th. It was assumed to be hydrogen explosion.
- At approximately 2:30 am on March 23rd, seawater was started to be injected to the nuclear reactor through the feed water system.
- At approximately 10:50 am on March 24th, white fog-like steam arising from the roof part of the reactor building was observed.
- At approximately 11:30 am on March 24th, lights in the main control room was restored.
- We have been injecting sea water into the reactor pressure vessel.

Unit 2 (Shut down)

- Reactor has been shut down and the level of reactor coolant had dropped and the reactor pressure had increased because the Reactor Core Isolation Cooling System stopped. Measures were taken to lower the pressure within the Reactor Containment Vessel and to inject sea water into the Reactor while carefully confirming safety. The level of reactor coolant and the pressure of the Reactor resumed.
- At approximately 6:00 am on March 15th, an abnormal noise began emanating from nearby Pressure Suppression Chamber and the pressure within this chamber decreased.
- At 6:20 pm on March 21st, white smoke was confirmed arising from the top of the reactor building. As of 7:11 am on March 22nd, smoke decreased to the level where we can hardly confirm
- We have been injecting sea water into the reactor pressure vessel.

Unit 3 (Shut down)

- Reactor has been shut down. However, the explosive sound and white smoke were confirmed at 11:01am Mar 14th. It was assumed to be hydrogen explosion.
- At 8:30am on March 16th, fog like steam was confirmed arising from the reactor building.
- At approximately 6:15 am on March 17th the pressure of the Suppression Chamber has temporarily increased. We were preparing to implement a measurement to reduce the pressure of the reactor containment vessel (partial discharge of air containing radioactive material to outside) in order to fully secure safety. However, at present, it is not a situation to take a measure immediately to discharge air containing radioactive material to outside now. We will continue to monitor the status of the pressure of the reactor containment vessel.
- At approximately 4:00 pm, March 21st, light gray smoke was confirmed arising from the floor roof of the Unit 3 building. On March 22nd, the color of smoke changed to somewhat white and it is slowly dissipating.
- At approximately 10:45 pm on March 22nd, the light in the main control room was turned on.
- At around 4:20 pm on March 23rd, our staff confirmed light black smoke belching from the Unit 3 building. At approximately 11:30 pm on March 23rd and 4:50 am on March 24th, our employee found no signs of smoke.
- We have been injecting sea water into the reactor pressure vessel.

Unit 4 (outage due to regular inspection)

- Reactor has been shut down. However, at approximately 6 am on March 15th. We have confirmed the explosive sound and the sustained damage around the 5th floor rooftop area of the Nuclear Reactor Building.
- On March 15th and 16th, we respectively confirmed the outbreak of fire at



Press Releases

Press Release (Mar 24, 2011) Status of TEPCO's Facilities and its services after Tohoku-Taiheiyou-Oki Earthquake (as of 14:30PM)

Due to the Tohoku-Taiheiyou-Oki Earthquake which occurred on March 11th 2011, TEPCO's facilities including our nuclear power stations have been severely damaged. We deeply apologize for the anxiety and inconvenience caused.

Below is the status of TEPCO's major facilities.

*new items are underlined

[Nuclear Power Station]

Fukushima Daiichi Nuclear Power Station:

Units 1 to 3: shutdown due to earthquake

(Units 4 to 6: outage due to regular inspection)

* The national government has instructed to evacuate for those local residents within 20km radius of the site periphery and to remain indoors for those local residents between 20km and 30km radius of the site periphery.

* Off-site power was connected to Unit 1 to 6.

* Unit 1

The explosive sound and white smoke was confirmed near Unit 1 when the big quake occurred at 3:36pm, March 12th. We have started injection of sea water at 8:20 pm, March 12th, and then boric acid which absorbs neutron into the reactor afterwards.

At approximately 2:30 am, March 23rd, we have started the injection of sea water into the reactor from feed water system.

At approximately 11:30 am, March 24th, lights in the main control room were restored.

* Unit 2

At 1:25 pm, March 14th, since the Reactor Core Isolation Cooling System has failed, it was determined that a specific incident stipulated in Clause 1, Article 15 of Act on Special Measures Concerning Nuclear Emergency Preparedness occurred (failure of reactor cooling function). At 5:17 pm, March 14th, while the water level in the reactor reached the top of the fuel rod, we have restarted the water injection with the valve operation.

At approximately 6:14 am, March 15th, the abnormal sound was confirmed near the suppression chamber and the pressure inside the chamber decreased afterwards. It was determined that there is a possibility that something happened in the suppression chamber. While sea water injection to the reactor continued, TEPCO employees and workers from other companies not in charge of injection work started tentative evacuation to a safe location. Sea water injection to the reactor continued.

On March 18th, power was delivered up to substation for backup power through offsite transmission line. We completed laying cable further to unit receiving facility in the building, and at 3:46 pm, March 20th the load-side power panel of the receiving facility started to be energized.

From 3:05 pm to 5:20 pm on March 20th, 40 tons of seawater was injected into Unit 2 by TEPCO employees.

At 6:20 on March 21st, white smoke was confirmed arising from the top of the reactor building. As of 7:11 am on March 22nd, smoke decreased to the level where we can hardly confirm.

From around 4 pm to 5 pm on March 22nd, approximately 18 tons of sea water was injected into the spent fuel pool by TEPCO employees.

* Unit 3

At 6:50 am, March 14th, while water injection to the reactor was under operation, the pressure in the reactor containment vessel increased to 530 kPa. As a result, at 7:44 am, it was determined that a specific incident stipulated in article 15, clause 1 occurred (abnormal increase of the pressure of reactor containment vessel). Afterwards, the pressure has gradually decreased (as of 9:05 am, 490 kPa).

At approximately 11:01 am, March 14th, an explosion followed by white smoke occurred near Unit 3. 4 TEPCO employees and 3 workers from other companies (all of them are conscious) have sustained injuries and they were already taken to the hospital by ambulances. As the temperature of water in the spent fuel pool rose, spraying water by helicopters with the support of the Self Defense Force was considered, however the operation on March 16th was cancelled.

At 6:15 am, March 17th, the pressure of the Suppression Chamber temporarily increased, but currently it is stable in a certain range. On March 20th, we were preparing to implement a measurement to reduce the pressure of the reactor containment vessel (partial discharge of air containing radioactive material to outside) in order to fully secure safety. However, at present, it is not a situation to take a measure immediately to discharge air containing radioactive material to outside. We will continue to monitor the status of the pressure of the reactor

containment vessel. Monitoring will be continued.

In order to cool spent fuel pool, water was sprayed by helicopters on March 17th with the cooperation of Self-Defense Forces.

At approximately past 7:00 pm, March 17th, Self-Defense Forces and the police had started spraying water by water cannon trucks upon our request for the cooperation. At 8:09 pm, March 17th, they had finished the operation.

At 2:00 pm, March 18th, spraying water by fire engines was started with the cooperation of Self-Defense Forces and the United States Armed Forces. At 2:45 pm, March 18th, they had finished the operation.

At approximately 0:30 am, March 19th, spraying water was started with the cooperation of Fire Rescue Task Forces of Tokyo Fire Department started spraying water. At approximately 1:10 am, March 19th, they finished the operation. They resumed spraying water at 2:10 pm. At approximately 3:40 am, March 20th, they finished the operation.

At approximately 9:30 pm, March 20th, spraying water was started with the cooperation of Fire Rescue Task Forces of Tokyo Fire Department. At approximately 3:58 am, March 21st, they finished the operation.

At approximately 3:55 pm, March 21st, light gray smoke was confirmed arising from the southeast side of the 5th floor roof of the Unit 3 building, and the situation was reported to the fire department at approximately 4:21 pm. The parameters of reactor pressure vessel, reactor containment vessel, and monitored environmental data remained at the same level. However, employees working around Unit 3 evacuated to a safe location. It is observed the smoke has been decreasing. On March 22nd, the color of smoke changed to somewhat white and it is slowly dissipating.

At approximately 3:10 pm on March 22nd, water discharge into Unit 3 by Tokyo Fire Department's Hyper Rescue and Osaka City Fire Department was conducted and completed at approximately 4:00 PM on the same day. At approximately 10:45 pm on March 22nd, lights in the main operation room were restored.

At 11:00 am on March 23rd, the injection of sea water to spent fuel pool was conducted, and finished approximately at 1:20 pm on the same day.

At 4:20 pm on March 23rd, light gray smoke was observed belching from Unit 3 building. The situation was reported to the fire department at 4:25 pm on March 23rd.

The parameters of the reactor, the reactor containment vessel of Unit 3, and monitored figures around the site's immediate surroundings remained stable without significant change. To be safe, workers in the main control room of Unit 3 and around Unit 3 evacuated to a safe location.

At approximately 11:30 pm on March 23rd and 4:50 am on March 24th, TEPCO employees confirmed the smoke has disappeared. Accordingly, workers evacuation was lifted.

At approximately 5:35 am on March 24th, sea water injection through Fuel Pool Cooling and Filtering System was initiated.

On March 24th, it was confirmed that 3 workers from other companies who was in charge of cable laying work in the 1st floor and the underground floor of turbine building were exposed to the radiation dose of more than 170 mSv. 2 out of 3 are being transferred to the hospital as it was confirmed that their leg skin were contaminated.

* Unit 4

At approximately 6:00 am, March 15th, an explosive sound was heard and the damage in the 5th floor roof of Unit 4 reactor building was confirmed. At 9:38 am, the fire near the north-west part of 4th floor of Unit 4 reactor building was confirmed. At approximately 11:00 am, TEPCO employees confirmed that the fire was off.

At approximately 5:45 am on March 16th, a TEPCO employee discovered a fire at the northwest corner of the Nuclear Reactor Building. TEPCO immediately reported this incident to the fire department and the local government and proceeded with the extinction of fire.

At approximately 6:15 am, TEPCO staff confirmed at the site that there are no signs of fire.

At approximately 8:21 am on March 20th, spraying water by fire engines was started with the cooperation of Self-Defense Forces and they finished the operation at approximately 9:40 am. At approximately 6:45 pm spraying water was started by Self-Defenses' water cannon trucks and finished at approximately 7:45 pm.

At approximately 6:30 am, March 21st, spraying water by fire engines was started with the cooperation of Self-Defense Forces and the United States Armed Forces. At approximately 8:40 am, March 21, they had finished the operation.

On March 21st, cabling has been completed from temporary substation to the main power center.

From approximately 5:20 pm on March 22nd, water discharge from the concrete pumping vehicle was conducted and ended at approximately 8:30 pm on the same day.

From approximately 10:00 am on March 23rd, water discharge from the concrete pumping vehicle was conducted and ended at approximately 1:00 pm on the same day.

* Unit 5 and 6

At 5 am on March 19th, we started the Residual Heat Removal System Pump (C) of Unit 5 in order to cool the spent fuel pool. At 10:14 pm, we started the Residual Heat Removal System Pump (B) of Unit 6 in order to cool the spent fuel pool.

Unit 5 has been in reactor cold shutdown since 2:30 pm on March 20th. Unit 6 has been in reactor cold shutdown since 7:27 pm on March 20th.

At Units 5 and 6, in order to prevent hydrogen gas from accumulating within the buildings, we have made three holes on the roof of the reactor building for each unit.

At approximately 5:24 pm on March 23rd, the temporary Residual Heat Removal System Seawater Pump automatically stopped when its power source was switched. We plan to repair the pump while maintaining the appropriate the water level and the temperature in the reactor. Repair work is being conducted.

* On March 18th, regarding the spent fuel in the common spent fuel pool, we have confirmed that the water level of the pool is secured. A detailed inspection is under preparation.

* common spent fuel pool: a spent fuel pool for common use set in a

separate building in a plant site in order to preserve spent fuel which are transferred from the spent fuel pool in each Unit building.

- * On March 17th, we patrolled buildings for dry casks and found no signs of abnormal situation for the casks by visual observation. A detailed inspection is under preparation.
- * dry cask: a measure to store spent fuel in a dry storage casks in storages. Fukushima Daiichi Nuclear Power Station started to utilize the measure from August 1995.
- * In total 12 fire engines are lent for spraying water to the spent fuel pools and water injection to the nuclear reactors by various regional fire departments* as well as Tokyo Fire Department.
- * On March 21st and 23rd, we detected cobalt, iodine and cesium from the seawater around discharge canal of Unit 1, 2, 3 and 4.
- * On March 20th, 21st and 23rd, we detected iodine, cesium and tellurium in the air collected at the site of Fukushima Daiichi Nuclear Power Station.
- * We will continuously endeavor to securing safety, and monitoring of the surrounding environment.

Fukushima Daiichi Nuclear Power Station:

Units 1 to 4: shutdown due to earthquake

- * The national government has instructed evacuation for those local residents within 10km radius of the periphery.
- * In order to achieve cold shutdown, reactor cooling function was restored and cooling of reactors was conducted. As a result, all reactors achieved cold shutdown: Unit 1 at 5:00 pm, March 14th, Unit 2 at 6:00 pm, March 14th, Unit 3 at 0:15 pm, March 12th, Unit 4 at 7:15 am, March 16th.
- * Since March 12th, we had been preparing measures for reducing the pressure of reactor containment vessels (partial discharge of air containing radioactive materials to outside), but on March 17th, we released such preparation in all Units.

***(Unit 1)**

As it is confirmed that the temperature of the Emergency Equipment Cooling Water System *1 has increased, at 3:20 pm, March 15th, we stopped the Residual Heat Removal System (B) for the inspection. Subsequently, failure was detected in the power supply facility associated with the pumps of the Emergency Equipment Cooling Water System. At 4:25 pm, March 15th, after replacing the power facility, the pumps and the Residual Heat Removal System (B) have been reactivated.

***(Unit 4)**

As it is confirmed that the pressure at the outlet of the pumps of the Emergency Equipment Cooling Water System*1 has been decreased, at 8:05 pm, March 15th, we stopped the Residual Heat Removal System (B) for the inspection. Subsequently, failure was detected in the power supply facility associated with the pumps of the Emergency Equipment Cooling Water System. At 9:25 pm, March 15th, after replacing the relevant facility, the pumps and the Residual Heat Removal System (B) have been reactivated.

*1: emergency water system in which cooling water (pure water) circulates which exchanged the heat with sea water in order to cool down bearing pumps and/or heat exchangers etc.

Kashiwazaki Kariwa Nuclear Power Station:

Units 1, 5, 6, 7: normal operation

(Units 2 to 4: outage due to regular inspection)

[Thermal Power Station]

Hirono Thermal Power Station Units 2 and 4: shutdown due to earthquake
Hitachinaka Thermal Power Station Unit 1: shutdown due to earthquake
Kashima Thermal Power Station Units 2, 3, 5, 6: shutdown due to earthquake
Higashi-Ongishima Thermal Power Station Unit 1: restarted generation at 13:42 PM on March 24th

[Hydro Power Station]

* All the stations have been restored.
(Facilities damaged by the earthquake are now properly under consideration)

[Transmission System, etc.]

All substation failed due to the earthquake have been restored.

[Blackout in TEPCO's Service Area]

All the blackouts are resolved.

[Supply and Demand Status within TEPCO's Service Area to Secure Stable Power Supply]

Backup supply from Shinshinano Conversion Station: 600MW
Backup supply from Sakuma Conversion Station: 300MW
Backup supply from Higashi Shimizu Conversion Station: 100MW
Backup supply from Hokkaido-Honshu Interconnection Facilities: 600MW

Considering the critical balance of our power supply capacity and expected power demand forward, in order to avoid unexpected blackout, TEPCO has been implementing rolling blackout (planned blackout alternates from one area to another) since Mar 14th. We will make our utmost to secure the stable power supply as early as possible.

For customers who will be subject to rolling blackout, please be prepared for the announced blackout periods. Also for customers who are not subject to blackouts, TEPCO appreciates your continuous cooperation in reducing electricity usage by avoiding using unnecessary lighting and electrical equipment.

[Others]

Please do NOT touch cut-off electric wires.
In order to prevent fire, please make sure to switch off the electric appliances such as hair drier and to shut down the breaker of distribution board when you leave your house.
For the customer who has in-house power generation, please secure fuel for generator.

 <http://www.tepco.co.jp>



Press Releases

Press Release (Mar 24, 2011) Plant Status of Fukushima Daiichi Nuclear Power Station (as of 15:00 pm March 24th)

[No update from the last release issued at 9:00 am, March 24th]

Unit	Status
1	<ul style="list-style-type: none">Reactor cold shutdown, stable water level, offsite power is available.No cooling water is leaked to the reactor containment vessel.Maintain average water temperature at 100°C in the pressure restraint.
2	<ul style="list-style-type: none">Reactor cold shutdown, stable water level, offsite power is available.No cooling water is leaked to the reactor containment vessel.Maintain average water temperature at 100°C in the pressure restraint.
3	<ul style="list-style-type: none">Reactor cold shutdown, stable water level, offsite power is available.No cooling water is leaked to the reactor containment vessel.Maintain average water temperature at 100°C in the pressure restraint.
4	<ul style="list-style-type: none">Reactor cold shutdown, stable water level, offsite power is available.No cooling water is leaked to the reactor containment vessel.Maintain average water temperature at 100°C in the pressure restraint.

Other N.A.

[Back to Page Top](#)



Press Releases

Press Release (Mar 24, 2011)

The results of nuclide analyses of radioactive materials in the air at the site of Fukushima Daiichi Nuclear Power Station (3rd release)

On March 22nd 2011, as part of monitoring activity of the surrounding environment, we conducted nuclide analysis of radioactive materials contained in the air which were collected on March 20th and 21st 2011 at the site of Fukushima Daiichi Nuclear Power Station, which was damaged by Tohoku-Chihou-Taiheiyu-Oki Earthquake. As a result, radioactive materials were detected as shown in the attachment. Therefore, we summarized the results and reported them to Nuclear and Industry Safety Agency as well as to the government of Fukushima Prefecture today. (previously announced)

On March 23rd, 2011, we conducted nuclide analysis of radioactive materials contained in the air which were collected on March 23rd, 2011 at the site of Fukushima Daiichi Nuclear Power Station. As a result, radioactive materials were detected as shown in the attachment. Therefore, we summarized the results and reported them to Nuclear and Industry Safety Agency as well as to the government of Fukushima Prefecture today.

We will continue the sampling survey same as this one.

attachment1: The result of the nuclide analysis of radioactive materials in the air at the site of Fukushima Daiichi Nuclear Power Station (PDF 12.1KB)

attachment2: The result of the nuclide analysis of radioactive materials in the air at the site of Fukushima Daiichi Nuclear Power Station (PDF 13.1KB)

attachment3: Nuclide analysis of radioactive materials in the air Fukushima Daiichi Nuclear Power Station (Main Gate) (PDF 33.1KB)

attachment4: Nuclide analysis of radioactive materials in the air Fukushima Daiichi Nuclear Power Station (MF-1) (PDF 33.7KB)

[Back to Page Top](#)



Press Releases

Press Release (Mar 24, 2011)
Plant Status of Fukushima Daiichi Nuclear Power Station (as of 14:00 PM Mar 24th)

*new items are underlined

All 6 units of Fukushima Daiichi Nuclear Power Station have been shut down.

Unit 1 (Shut down)

- Reactor has been shut down. However, the explosive sound and white smoke were confirmed after the big quake occurred at 3:36 pm Mar 12th. It was assumed to be hydrogen explosion.
- At approximately 2:30 am on March 23rd, seawater was started to be injected to the nuclear reactor through the feed water system.
- At approximately 10:50 am on March 24th, white fog-like steam arising from the roof part of the reactor building was observed.
- At approximately 11:30 am on March 24th, lights in the main control room was restored.
- We have been injecting sea water into the reactor pressure vessel.

Unit 2 (Shut down)

- Reactor has been shut down and the level of reactor coolant had dropped and the reactor pressure had increased because the Reactor Core Isolation Cooling System stopped. Measures were taken to lower the pressure within the Reactor Containment Vessel and to inject sea water into the Reactor while carefully confirming safety. The level of reactor coolant and the pressure of the Reactor resumed.
- At approximately 6:00 am on March 15th, an abnormal noise began emanating from nearby Pressure Suppression Chamber and the pressure within this chamber decreased.
- At 6:20 pm on March 21st, white smoke was confirmed arising from the top of the reactor building. As of 7:11 am on March 22nd, smoke decreased to the level where we can hardly confirm.
- We have been injecting sea water into the reactor pressure vessel.

Unit 3 (Shut down)

- Reactor has been shut down. However, the explosive sound and white smoke were confirmed at 11:01am Mar 14th. It was assumed to be hydrogen explosion.
- At 8:30am on March 16th, fog like steam was confirmed arising from the reactor building.
- At approximately 6:15 am on March 17th the pressure of the Suppression Chamber has temporarily increased. We were preparing to implement a measurement to reduce the pressure of the reactor containment vessel (partial discharge of air containing radioactive material to outside) in order to fully secure safety. However, at present, it is not a situation to take a measure immediately to discharge air containing radioactive material to outside now. We will continue to monitor the status of the pressure of the reactor containment vessel.
- At approximately 4:00 pm, March 21st, light gray smoke was confirmed arising from the floor roof of the Unit 3 building. On March 22nd, the color of smoke changed to somewhat white and it is slowly dissipating.
- At approximately 10:45 pm on March 22nd, the light in the main control room was turned on.
- At around 4:20 pm on March 23rd, our staff confirmed light black smoke belching from the Unit 3 building. At approximately 11:30 pm on March 23rd and 4:50 am on March 24th, our employee found no signs of smoke.
- We have been injecting sea water into the reactor pressure vessel.

Unit 4 (outage due to regular inspection)

- Reactor has been shut down. However, at approximately 6 am on March 15th. We have confirmed the explosive sound and the sustained damage around the 5th floor rooftop area of the Nuclear Reactor Building.
- On March 15th and 16th, we respectively confirmed the outbreak of fire at the 4th floor of the northwestern part of the Nuclear Reactor Building. We immediately reported this matter to the fire department and the related authorities. TEPCO employees confirmed that each fire had already died down by itself.
- At this moment, we do not consider any reactor coolant leakage inside the reactor containment vessel happened.

Unit 5 (outage due to regular inspection)

- Reactor has been shut down and the sufficient level of reactor coolant to ensure safety is maintained.
- At 5 am, March 19th, we started the Residual Heat Removal System Pump (C) in order to cool the spent fuel pool.
- At this moment, we do not consider any reactor coolant leakage inside the reactor containment vessel happened.
- At 2:30 pm, March 20th, the reactor achieved reactor cold shutdown.
- At around 5:24 pm on March 23rd, when we switched the temporary Residual Heat Removal System Seawater Pump, it automatically stopped. We will repair the pump and maintain the reactor water level and the temperature in the reactor properly. Repair work is being conducted.

Unit 6 (outage due to regular inspection)

- Reactor has been shut down and the sufficient level of reactor coolant to ensure safety is maintained.

- We are working on receiving external power supply to Units 5 and 6.
- We completed the repair work on the emergency diesel generator (A).
- At 10:14 pm, March 19th, we started the Residual Heat Removal System Pump (B) of Unit 6 in order to cool the spent fuel pool.
- At this moment, we do not consider any reactor coolant leakage inside the reactor containment vessel happened.
- At 7:27 pm, March 20th, the reactor achieved reactor cold shutdown.

Today's work for cooling the spent fuel pools

- At approximately 5:35 am, we started injecting seawater into the fuel spent pool of Unit 3, using Fuel Pool Cooling and Filtering(clean up) system (FPC).
- We are considering further spraying at other units and others subject to the conditions of spent fuel pools.

Casualty

- 2 workers of cooperative firm were injured at the occurrence of the earthquake, and were transported to the hospital on March 11th.
- 4 workers were injured and transported to the hospital after explosive sound and white smoke were confirmed around the Unit 1 on March 11th.
- Presence of 2 TEPCO employees at the site is not confirmed on March 11th.
- 1 TEPCO employee who was not able to stand by his own holding left chest with his hand, was transported to the hospital by an ambulance on March 12th.
- 1 subcontract worker at the key earthquake-proof building was unconscious and transported to the hospital by an ambulance on March 12th.
- The radiation exposure of 1 TEPCO employee, who was working inside the reactor building, exceeded 100mSv and he was transported to the hospital on March 12th.
- 2 TEPCO employees felt bad during their operation in the central control rooms of Unit 1 and 2 while wearing full masks, and were transferred to Fukushima Daiichi Nuclear Power Station for consultation with a medical advisor on March 13th.
- 11 workers were injured and transported to Fukushima Daiichi Nuclear Power Station etc. after explosive sound and white smoke were confirmed around the Unit 3. One of the workers was transported to the FUKUSHIMA Medical University Hospital on March 14th.
- At approximately 10 pm on March 22nd, 1 worker who had been working on setting up a temporary power panel in the common pool was injured and transported to Fukushima Daiichi Nuclear Power Station where the industrial doctor is.
- At approximately 1 am on March 23rd, 1 worker who had been working on transporting a temporary power panel in the common pool was injured and transported to Fukushima Daiichi Nuclear Power Station where the industrial doctor is.
- On March 24th, it was confirmed that 3 workers from other companies who were in charge of cable laying work in the 1st floor and the underground floor of turbine building were exposed to the radiation dose of more than 170 mSv. 2 out of 3 are being transferred to the hospital as it was confirmed that their leg skin were contaminated.

Others


- We measured radioactive materials (iodine etc.) inside of the nuclear power station area (outdoor) by monitoring car and confirmed that radioactive materials level is getting higher than ordinary level. As listed below, we have determined that specific incidents stipulated in article 15, clause 1 of Act on Special Measures Concerning Nuclear Emergency Preparedness (Abnormal increase in radiation dose measured at site boundary) have occurred.


- Determined at 4:17 pm Mar 12th (Around Monitoring Post 4)
- Determined at 8:56 am Mar 13th (Around Monitoring Post 4)
- Determined at 2:15 pm Mar 13th (Around Monitoring Post 4)
- Determined at 3:50 am Mar 14th (Around Monitoring Post 6)
- Determined at 4:15 am Mar 14th (Around Monitoring Post 2)
- Determined at 9:37 am Mar 14th (Around Monitoring Post 3)
- Determined at 9:37 pm Mar 14th (Around main entrance)
- Determined at 6:51 am Mar 15th (Around main entrance)
- Determined at 8:11 am Mar 15th (Around main entrance)
- Determined at 4:17 pm Mar 15th (Around main entrance)
- Determined at 11:05 pm Mar 15th (Around main entrance)
- Determined at 8:58 am Mar 19th (Around MP5)

From now on, if the measured figure fluctuates and goes above and below 500 micro Sv/h, we deem that as the continuous same event and will not regard that as a new specific incidents stipulated in article 15, clause 1 of the Act on Special Measures Concerning Nuclear Emergency Preparedness (Abnormal increase in radiation dose measured at site boundary) has occurred. In the interim, if we measure a manifestly abnormal figure and it is evident that the event is not the continuous same event, we will determine and notify.

- The national government has instructed evacuation for those local residents within 20km radius of the periphery and evacuation to inside for those residents from 20km to 30km radius of the periphery, because it's possible that radioactive materials are discharged.
- At approximately 10am on March 15th, we observed 400mSv/h at the inland side of the Unit 3 reactor building and 100mSv/h at the inland side of the Unit 4 reactor building.
- We checked the status of spent fuel in the common pool, and confirmed that the water level secured. We are planning to conduct a detailed inspection.
- We found no signs of abnormal situation for the casks by visual observation during the patrol activity. A detailed inspection is under preparation.
- At Units 5 and 6, in order to prevent hydrogen gas from accumulating within the buildings, we have made three holes on the roof of the reactor building for each unit.
- In total 12 fire engines are lent for the water spraying to the spent fuel pools and water injection to the nuclear reactors by various regional fire departments' as well as Tokyo Fire Department. Also, instruction regarding the setting and operation of large scale decontamination system was provided by Niigata City Fire Headquarters and Hamamatsu City Fire Headquarters.
- Koriyama Fire Department, Iwaki Fire Brigade Headquarters, Fire Headquarters of Sukagawa District Wide Area Fire-fighting Association, Yonezawa City Fire Headquarters, Utsunomiya City Fire Headquarters, Fire Headquarters of Aizu-Wakamatsu wide area municipal association, Saitama City Fire Bureau, and Niigata City Fire Bureau.
- On March 21st and 22nd, we detected cobalt, iodine and cesium from the seawater around discharge canal of Units 1, 2, 3 and 4.
- We detected iodine, cesium and tellurium in the air collected at the site of Fukushima Daiichi Nuclear Power Station on March 20th, 21st and 22nd.
- Until March 22nd, Units 1 through 6 were started to be energized from

the external power source.
- We will continue to take all measures to ensure the safety and to continue monitoring the surrounding environment around the Power Station.

 [Back to Page Top](#)



Press Releases

Press Release (Mar 24, 2011) Implementation Plan of Rolling Blackouts on and after March 25, 2011

Due to the power supply-demand balance, TEPCO has been implementing rolling blackout since Monday, March 14. We sincerely regret causing anxiety and inconvenience to our customers and the society. We appreciate your cooperation in conserving electricity consumption. For customers who will be subject to rolling blackouts, please be prepared for the announced blackout periods. Also, for the customers who are not subject to blackouts, we would appreciate your continuous cooperation in reducing electricity usage by turning off unnecessary lightings and electrical appliances. We would like to inform the implementation plan of rolling blackouts on and after March 25, 2011 as follows.

Implementation plan of rolling blackout on March 25 (Fri.)
Considering today's electricity supply-demand and tomorrow's weather, regional group and time periods for the planned blackout are as follows.

Group 3 6:20-10:00
Group 4 9:20-13:00
Group 5 12:20-16:00
Group 3 13:50-17:30
Group 1 15:20-19:00
Group 4 16:50-20:30

Group 2 18:20-22:00 ...Rolling blackout will not be implemented.

...The necessity of the rolling blackouts will be judged depending on the supply-demand balance, and will be informed by 2 hours before the start of blackouts.

- The actual blackout period for each group is planned to be maximum of 3 hours during the relevant scheduled time period.
- Starting and ending time of blackout periods may slightly differ.
- Depending on the supply-demand balance of the day, planned blackouts may not be carried out. In case the electricity supply-demand balance becomes tighter than expected, we will reconsider the rolling blackout plan and inform you accordingly before we implement the revised plan.
- A blackout may occur in the adjacent areas where the planned blackouts are carried out.

Implementation plan of rolling blackouts from Saturday, March 26 to Thursday, March 31

Please refer to the "exhibit" for detailed plan.

- The actual blackout period for each group is planned to be maximum of about 3 hours during the relevant scheduled time period.
- Starting and ending time of blackout periods will slightly differ day by day.
- Depending on the supply-demand balance hereafter, planned blackouts may not be carried out. Moreover, in case the electricity supply-demand balance becomes tighter than expected, we will reconsider the rolling blackout plan and inform you accordingly before we implement the revised plan.
- A blackout may occur in the adjacent areas where the planned blackouts are carried out.

[Others]

- In order to prevent fires, please make sure to switch off electric appliances such as hair driers when you leaving home.
- Please carefully pay attention to the traffic at the crossings in case the traffic lights are suddenly turned off.
- As for the building and apartment, please be aware that equipment and facility such as elevator, automatic door, automatic lock, and multilevel parking lot will not function. In particular, please avoid using elevators not to be trapped during the blackout.

<Reference>

•Prediction of demand and supply on March 24
Estimated Demand 38,500 MW (18:00-19:00)
Supply Capacity 38,500 MW

•Prediction of demand and supply on March 25
Estimated Demand 38,500 MW (18:00-19:00)
Supply Capacity 38,500 MW

- Prediction of demand
According to the weather forecast, the temperature will be higher than that of today. However, estimated temperature in the evening will be lower due to rain, so we assume estimated peak demand on March 25 will be 38,500MW, which is same as today.
- Estimated demand and supply capacity may change depending on the situation of the day.

[Back to page top](#)



Press Releases

Press Release (Mar 24, 2011) Status of the Inspection and Restoration Works Performed after the Niigata-Chuetsu-Oki Earthquake (as of March 24)

We are announcing the status of major inspections and restoration works and nonconformances at TEPCO's Kashiwazaki-Kariwa Nuclear Power Station after the Niigata-Chuetsu-Oki Earthquake. Please be advised that we have been temporarily suspending a part of the restoration works since March 11, 2011, as we have been fully dedicated to the support and cooperation to Fukushima Daiichi Nuclear Power Station and Fukushima Daini Nuclear Power Station which were damaged by the Tohoku-Chihou-Taiheiyu-Oki Earthquake. We resume restoration works of Kashiwazaki-Kariwa Nuclear Power Station from March 22, 2011 accordingly.

Inspection/ Restoration Status

- ◇ Inspection and restoration completed between March 18 to March 24, 2011
(Completed on the following date)
 - No notable activity during this week.
- ◇ Inspection and restoration to be commenced between March 25 to March 31, 2011
(To be commenced on the following date)
 - No notable activity during this week.
- ◇ Work Schedule of Major Inspection and Restoration from March 30 to April 16, 2011
 - Work Schedule of the Main Inspection/ Restoration of the Kashiwazaki-Kariwa Nuclear Power Station in Response to the Niigata-Chuetsu-Oki Earthquake (during 4 Weeks) ...Appendix

(Reference)

Nonconformances Found in the Inspection and Restoration Works Performed after the Niigata-Chuetsu-Oki Earthquake

Based on the "Public Announcement Regarding Nonconformance Found in the Inspection and Restoration Works Performed after the Niigata-Chuetsu-Oki Earthquake," the Tokyo Electric Power Company, Incorporated (TEPCO) provides this announcement containing incidents information reported from March 17 to March 23, 2011.

- ◇ Incidents Information (relating to the Chuetsu-Oki Earthquake)

From March 17 to March 23, 2011 (Total figure from August 10, 2007)		Number of Incidents by Announcement Category (Total figure from August 10, 2007)	
No. of Reported Events	0 (10)	I	0 (0)
		II	0 (0)
		III	0 (10)

<Reports from March 17 to March 23, 2011>

Announcement Category	Date of Detection	Title of Report	Status
I	-	-	-
II	-	-	-
III	-	-	-

- ◇ Other Findings

- No notable activity during this week.

Appendix: Work Schedule of the Main Inspection/ Restoration of the Kashiwazaki-Kariwa Nuclear Power Station in Response to the Niigata-Chuetsu-Oki Earthquake (during 4 Weeks) (PDF 15.9KB)

[Back to page top](#)



Press Releases

Press Release (Mar 24, 2011)
Plant Status of Fukushima Daiichi Nuclear Power Station (as of 6:00 PM Mar 24th)

*new items are underlined

All 6 units of Fukushima Daiichi Nuclear Power Station have been shut down.

Unit 1 (Shut down)

-Reactor has been shut down. However, the explosive sound and white smoke were confirmed after the big quake occurred at 3:36 pm Mar 12th. It was assumed to be hydrogen explosion.
-At approximately 2:30 am on March 23rd, seawater was started to be injected to the nuclear reactor through the feed water system.
-At approximately 10:50 am on March 24th, white fog-like steam arising from the roof part of the reactor building was observed.
-At approximately 11:30 am on March 24th, lights in the main control room was restored.
-We have been injecting sea water into the reactor pressure vessel.

Unit 2 (Shut down)

-At approximately 6:00 am on March 15th, an abnormal noise began emanating from nearby Pressure Suppression Chamber and the pressure within this chamber decreased.
-At 6:20 pm on March 21st, white smoke was confirmed arising from the top of the reactor building. As of 7:11 am on March 22nd, smoke decreased to the level where we can hardly confirm.
-We have been injecting sea water into the reactor pressure vessel.

Unit 3 (Shut down)

-Reactor has been shut down. However, the explosive sound and white smoke were confirmed at 11:01am Mar 14th. It was assumed to be hydrogen explosion.
-At 8:30am on March 16th, fog like steam was confirmed arising from the reactor building.
-At approximately 6:15 am on March 17th the pressure of the Suppression Chamber has temporarily increased. We were preparing to implement a measurement to reduce the pressure of the reactor containment vessel (partial discharge of air containing radioactive material to outside) in order to fully secure safety. However, at present, it is not a situation to take a measure immediately to discharge air containing radioactive material to outside now. We will continue to monitor the status of the pressure of the reactor containment vessel.
-At approximately 4:00 pm, March 21st, light gray smoke was confirmed arising from the floor roof of the Unit 3 building. On March 22nd, the color of smoke changed to somewhat white and it is slowly dissipating.
-At approximately 10:45 pm on March 22nd, the light in the main control room was turned on.
-At around 4:20 pm on March 23rd, our staff confirmed light black smoke belching from the Unit 3 building. At approximately 11:30 pm on March 23rd and 4:50 am on March 24th, our employee found no signs of smoke.
-We have been injecting sea water into the reactor pressure vessel.

Unit 4 (outage due to regular inspection)

-Reactor has been shut down. However, at approximately 6 am on March 15th. We have confirmed the explosive sound and the sustained damage around the 5th floor rooftop area of the Nuclear Reactor Building.
-On March 15th and 16th, we respectively confirmed the outbreak of fire at the 4th floor of the northwestern part of the Nuclear Reactor Building. We immediately reported this matter to the fire department and the related authorities. TEPCO employees confirmed that each fire had already died down by itself.
-At this moment, we do not consider any reactor coolant leakage inside the reactor containment vessel happened.

Unit 5 (outage due to regular inspection)

-Reactor has been shut down and the sufficient level of reactor coolant to ensure safety is maintained.
-At 5 am, March 19th, we started the Residual Heat Removal System Pump (C) in order to cool the spent fuel pool.
-At this moment, we do not consider any reactor coolant leakage inside the reactor containment vessel happened.
-At 2:30 pm, March 20th, the reactor achieved reactor cold shutdown. At around 5:24 pm on March 23rd, when we switched the temporary Residual Heat Removal System Seawater Pump, it has stopped automatically. At around 4:14 pm, March 14th, we started replaced pump and at around 4:35 pm, cooling of reactor has restarted.

Unit 6 (outage due to regular inspection)

-Reactor has been shut down and the sufficient level of reactor coolant to ensure safety is maintained.
-We are working on receiving external power supply to Units 5 and 6. We completed the repair work on the emergency diesel generator (A).
-At 10:14 pm, March 19th, we started the Residual Heat Removal System Pump (B) of Unit 6 in order to cool the spent fuel pool.
-At this moment, we do not consider any reactor coolant leakage inside the reactor containment vessel happened.
-At 7:27 pm, March 20th, the reactor achieved reactor cold shutdown.

Today's work for cooling the spent fuel pools

-At approximately 5:35 am, we started injecting seawater into the fuel

spent pool of Unit 3, using Fuel Pool Cooling and Filtering(clean up) system (FPC) and finished at 4:05 pm.
 -At around 2:35 pm, spraying to unit 4 by concrete pump track and finished at around 5:30 pm.
 -We are considering further spraying at other units and others subject to the conditions of spent fuel pools.

Casualty

-2 workers of cooperative firm were injured at the occurrence of the earthquake, and were transported to the hospital on March 11th.
 -4 workers were injured and transported to the hospital after explosive sound and white smoke were confirmed around the Unit 1 on March 11th.
 -Presence of 2 TEPCO employees at the site is not confirmed on March 11th.
 -1 TEPCO employee who was not able to stand by his own holding left chest with his hand, was transported to the hospital by an ambulance on March 12th.
 -1 subcontract worker at the key earthquake-proof building was unconscious and transported to the hospital by an ambulance on March 12th.
 -The radiation exposure of 1 TEPCO employee, who was working inside the reactor building, exceeded 100mSv and he was transported to the hospital on March 12th.
 -2 TEPCO employees felt bad during their operation in the central control rooms of Unit 1 and 2 while wearing full masks, and were transferred to Fukushima Daiichi Nuclear Power Station for consultation with a medical advisor on March 13th.
 -11 workers were injured and transported to Fukushima Daiichi Nuclear Power Station etc. after explosive sound and white smoke were confirmed around the Unit 3. One of the workers was transported to the FUKUSHIMA Medical University Hospital on March 14th.
 -At approximately 10 pm on March 22nd, 1 worker who had been working on setting up a temporary power panel in the common pool was injured and transported to Fukushima Daiichi Nuclear Power Station where the industrial doctor is.
 -At approximately 1 am on March 23rd, 1 worker who had been working on transporting a temporary power panel in the common pool was injured and transported to Fukushima Daiichi Nuclear Power Station where the industrial doctor is.
 -On March 24th, it was confirmed that 3 workers from other companies who were in charge of cable laying work in the 1st floor and the underground floor of turbine building were exposed to the radiation dose of more than 170 mSv. 2 out of 3 are being transferred to the hospital as it was confirmed that their leg skin were contaminated. They were transferred to FUKUSHIMA Medical University Hospital.

Others

-We measured radioactive materials (iodine etc.) inside of the nuclear power station area (outdoor) by monitoring car and confirmed that radioactive materials level is getting higher than ordinary level. As listed below, we have determined that specific incidents stipulated in article 15, clause 1 of Act on Special Measures Concerning Nuclear Emergency Preparedness (Abnormal increase in radiation dose measured at site boundary) have occurred.
 -Determined at 4:17 pm Mar 12th (Around Monitoring Post 4)
 -Determined at 8:56 am Mar 13th (Around Monitoring Post 4)
 -Determined at 2:15 pm Mar 13th (Around Monitoring Post 4)
 -Determined at 3:50 am Mar 14th (Around Monitoring Post 6)
 -Determined at 4:15 am Mar 14th (Around Monitoring Post 2)
 -Determined at 9:27 am Mar 14th (Around Monitoring Post 3)
 -Determined at 9:37 pm Mar 14th (Around main entrance)
 -Determined at 6:51 am Mar 15th (Around main entrance)
 -Determined at 8:11 am Mar 15th (Around main entrance)
 -Determined at 4:17 pm Mar 15th (Around main entrance)
 -Determined at 11:05 pm Mar 15th (Around main entrance)
 -Determined at 8:58 am Mar 19th (Around MP5)
 From now on, if the measured figure fluctuates and goes above and below 500 micro Sv/h, we deem that as the continuous same event and will not regard that as a new specific incidents stipulated in article 15, clause 1 of the Act on Special Measures Concerning Nuclear Emergency Preparedness (Abnormal increase in radiation dose measured at site boundary) has occurred. In the interim, if we measure a manifestly abnormal figure and it is evident that the event is not the continuous same event, we will determine and notify.

-The national government has instructed evacuation for those local residents within 20km radius of the periphery and evacuation to inside for those residents from 20km to 30km radius of the periphery, because it's possible that radioactive materials are discharged.
 -At approximately 10am on March 15th, we observed 400mSv/h at the inland side of the Unit 3 reactor building and 100mSv/h at the inland side of the Unit 4 reactor building.
 -At around 10:37 am March 21st, water spraying to common spent fuel pool and finished at 3:30 pm (conducted by TEPCO).
 -At 3:37 pm, March 24th, electricity supply to common spent fuel pool has started from external power.
 -We found no signs of abnormal situation for the casks by visual observation during the patrol activity. A detailed inspection is under preparation.
 -At Units 5 and 6, in order to prevent hydrogen gas from accumulating within the buildings, we have made three holes on the roof of the reactor building for each unit.
 -In total 12 fire engines are lent for the water spraying to the spent fuel pools and water injection to the nuclear reactors by various regional fire departments* as well as Tokyo Fire Department. Also, instruction regarding the setting and operation of large scale decontamination system was provided by Niigata City Fire Headquarter and Hamamatsu City Fire Headquarter.
 *: Koriyama Fire Department, Iwaki Fire Brigade Headquarters, Fire Headquarters of Sukagawa District Wide Area Fire-fighting Association, Yonezawa City Fire Headquarters, Utsunomiya City Fire Headquarters, Fire Headquarters of Aizu-Wakamatsu wide area municipal association, Saitama City Fire Bureau, and Niigata City Fire Bureau.
 -Until March 22nd, Units 1 through 6 were started to be energized from the external power source.
 -We will continue to take all measures to ensure the safety and to continue monitoring the surrounding environment around the Power Station.

⏮ Back to Page Top

 Search

Press Releases

Press Release (Mar 24, 2011) Plant Status of Fukushima Daini Nuclear Power Station (as of 9:00 pm March 24th)


[No update from the last release issued at 3:00 pm, March 24th]

Unit Status

- 1 · Reactor cold shutdown, stable water level, offsite power is available.
 - No cooling water is leaked to the reactor containment vessel.
 - Maintain average water temperature at 100°C in the pressure restraint.
- 2 · Reactor cold shutdown, stable water level, offsite power is available.
 - No cooling water is leaked to the reactor containment vessel.
 - Maintain average water temperature at 100°C in the pressure restraint.
- 3 · Reactor cold shutdown, stable water level, offsite power is available.
 - No cooling water is leaked to the reactor containment vessel.
 - Maintain average water temperature at 100°C in the pressure restraint.
- 4 · Reactor cold shutdown, stable water level, offsite power is available.
 - No cooling water is leaked to the reactor containment vessel.
 - Maintain average water temperature at 100°C in the pressure restraint.

Other N.A.

 [Back to page top](#)

 Search

Press Releases


Press Release (Mar 24, 2011)
Plant Status of Fukushima Daiichi Nuclear Power Station (as of 9:00 pm March 24th)

[No update from the last release issued at 3:00 pm, March 24th]

Unit Status

- 1 · Reactor cold shutdown, stable water level, offsite power is available.
· No cooling water is leaked to the reactor containment vessel.
· Maintain average water temperature at 100°C in the pressure restraint.
- 2 · Reactor cold shutdown, stable water level, offsite power is available.
· No cooling water is leaked to the reactor containment vessel.
· Maintain average water temperature at 100°C in the pressure restraint.
- 3 · Reactor cold shutdown, stable water level, offsite power is available.
· No cooling water is leaked to the reactor containment vessel.
· Maintain average water temperature at 100°C in the pressure restraint.
- 4 · Reactor cold shutdown, stable water level, offsite power is available.
· No cooling water is leaked to the reactor containment vessel.
· Maintain average water temperature at 100°C in the pressure restraint.

Other N.A.

 [Back to page top](#)



Press Releases

Press Release (Mar 24, 2011)
Plant Status of Fukushima Daini Nuclear Power Station (as of 9:00 pm March 24th)

[No update from the last release issued at 3:00 pm, March 24th]

Unit Status

- 1 · Reactor cold shutdown, stable water level, offsite power is available.
 - No cooling water is leaked to the reactor containment vessel.
 - Maintain average water temperature at 100°C in the pressure restraint.
- 2 · Reactor cold shutdown, stable water level, offsite power is available.
 - No cooling water is leaked to the reactor containment vessel.
 - Maintain average water temperature at 100°C in the pressure restraint.
- 3 · Reactor cold shutdown, stable water level, offsite power is available.
 - No cooling water is leaked to the reactor containment vessel.
 - Maintain average water temperature at 100°C in the pressure restraint.
- 4 · Reactor cold shutdown, stable water level, offsite power is available.
 - No cooling water is leaked to the reactor containment vessel.
 - Maintain average water temperature at 100°C in the pressure restraint.

Other N.A.

[back to page top](#)



Press Releases

Press Release (Mar 24, 2011)
Plant Status of Fukushima Daiichi Nuclear Power Station (as of 9:00 pm March 24th)


[No update from the last release issued at 3:00 pm, March 24th]

Unit Status

- 1 · Reactor cold shutdown, stable water level, offsite power is available.
 · No cooling water is leaked to the reactor containment vessel.
 · Maintain average water temperature at 100°C in the pressure restraint.
- 2 · Reactor cold shutdown, stable water level, offsite power is available.
 · No cooling water is leaked to the reactor containment vessel.
 · Maintain average water temperature at 100°C in the pressure restraint.
- 3 · Reactor cold shutdown, stable water level, offsite power is available.
 · No cooling water is leaked to the reactor containment vessel.
 · Maintain average water temperature at 100°C in the pressure restraint.
- 4 · Reactor cold shutdown, stable water level, offsite power is available.
 · No cooling water is leaked to the reactor containment vessel.
 · Maintain average water temperature at 100°C in the pressure restraint.

Other N.A.

[back to page top](#)



Press Releases

Press Release (Mar 24, 2011) Plant Status of Fukushima Daiichi Nuclear Power Station (as of 9:00 pm March 24th)


[No update from the last release issued at 3:00 pm, March 24th]

Unit Status

- 1 · Reactor cold shutdown, stable water level, offsite power is available.
 - No cooling water is leaked to the reactor containment vessel.
 - Maintain average water temperature at 100°C in the pressure restraint.
- 2 · Reactor cold shutdown, stable water level, offsite power is available.
 - No cooling water is leaked to the reactor containment vessel.
 - Maintain average water temperature at 100°C in the pressure restraint.
- 3 · Reactor cold shutdown, stable water level, offsite power is available.
 - No cooling water is leaked to the reactor containment vessel.
 - Maintain average water temperature at 100°C in the pressure restraint.
- 4 · Reactor cold shutdown, stable water level, offsite power is available.
 - No cooling water is leaked to the reactor containment vessel.
 - Maintain average water temperature at 100°C in the pressure restraint.

Other N.A.

[back to page top](#)



Press Releases

Press Release (Mar 24, 2011)
Plant Status of Fukushima Daiichi Nuclear Power Station (as of 9:00 pm March 24th)


[No update from the last release issued at 3:00 pm, March 24th]

Unit Status

- 1 · Reactor cold shutdown, stable water level, offsite power is available.
 - No cooling water is leaked to the reactor containment vessel.
 - Maintain average water temperature at 100°C in the pressure restraint.
- 2 · Reactor cold shutdown, stable water level, offsite power is available.
 - No cooling water is leaked to the reactor containment vessel.
 - Maintain average water temperature at 100°C in the pressure restraint.
- 3 · Reactor cold shutdown, stable water level, offsite power is available.
 - No cooling water is leaked to the reactor containment vessel.
 - Maintain average water temperature at 100°C in the pressure restraint.
- 4 · Reactor cold shutdown, stable water level, offsite power is available.
 - No cooling water is leaked to the reactor containment vessel.
 - Maintain average water temperature at 100°C in the pressure restraint.

Other N.A.

[Back to page top](#)



Press Releases

Press Release (Mar 24, 2011) Plant Status of Fukushima Daini Nuclear Power Station (as of 9:00 pm March 24th)

[No update from the last release issued at 3:00 pm, March 24th]

Unit Status

- 1 · Reactor cold shutdown, stable water level, offsite power is available.
· No cooling water is leaked to the reactor containment vessel.
· Maintain average water temperature at 100°C in the pressure restraint.
- 2 · Reactor cold shutdown, stable water level, offsite power is available.
· No cooling water is leaked to the reactor containment vessel.
· Maintain average water temperature at 100°C in the pressure restraint.
- 3 · Reactor cold shutdown, stable water level, offsite power is available.
· No cooling water is leaked to the reactor containment vessel.
· Maintain average water temperature at 100°C in the pressure restraint.
- 4 · Reactor cold shutdown, stable water level, offsite power is available.
· No cooling water is leaked to the reactor containment vessel.
· Maintain average water temperature at 100°C in the pressure restraint.

Other N.A.

[back to page top](#)



Press Releases

Press Release (Mar 24, 2011) Plant Status of Fukushima Daiichi Nuclear Power Station (as of 9:00 pm March 24th)


[No update from the last release issued at 3:00 pm, March 24th]

Unit Status

- 1 · Reactor cold shutdown, stable water level, offsite power is available.
 · No cooling water is leaked to the reactor containment vessel.
 · Maintain average water temperature at 100°C in the pressure restraint.
- 2 · Reactor cold shutdown, stable water level, offsite power is available.
 · No cooling water is leaked to the reactor containment vessel.
 · Maintain average water temperature at 100°C in the pressure restraint.
- 3 · Reactor cold shutdown, stable water level, offsite power is available.
 · No cooling water is leaked to the reactor containment vessel.
 · Maintain average water temperature at 100°C in the pressure restraint.
- 4 · Reactor cold shutdown, stable water level, offsite power is available.
 · No cooling water is leaked to the reactor containment vessel.
 · Maintain average water temperature at 100°C in the pressure restraint.

Other N.A.

[back to page top](#)



Press Releases

Press Release (Mar 24, 2011) Plant Status of Fukushima Daiichi Nuclear Power Station (as of 9:00 pm March 24th)


[No update from the last release issued at 3:00 pm, March 24th]

Unit Status

- 1 · Reactor cold shutdown, stable water level, offsite power is available.
· No cooling water is leaked to the reactor containment vessel.
· Maintain average water temperature at 100°C in the pressure restraint.
- 2 · Reactor cold shutdown, stable water level, offsite power is available.
· No cooling water is leaked to the reactor containment vessel.
· Maintain average water temperature at 100°C in the pressure restraint.
- 3 · Reactor cold shutdown, stable water level, offsite power is available.
· No cooling water is leaked to the reactor containment vessel.
· Maintain average water temperature at 100°C in the pressure restraint.
- 4 · Reactor cold shutdown, stable water level, offsite power is available.
· No cooling water is leaked to the reactor containment vessel.
· Maintain average water temperature at 100°C in the pressure restraint.

Other N.A.

[Back to page top](#)



Press Releases

Press Release (Mar 24, 2011) Plant Status of Fukushima Daini Nuclear Power Station (as of 9:00 pm March 24th)

[No update from the last release issued at 3:00 pm, March 24th]

Unit Status

- 1
 - Reactor cold shutdown, stable water level, offsite power is available.
 - No cooling water is leaked to the reactor containment vessel.
 - Maintain average water temperature at 100°C in the pressure restraint.
- 2
 - Reactor cold shutdown, stable water level, offsite power is available.
 - No cooling water is leaked to the reactor containment vessel.
 - Maintain average water temperature at 100°C in the pressure restraint.
- 3
 - Reactor cold shutdown, stable water level, offsite power is available.
 - No cooling water is leaked to the reactor containment vessel.
 - Maintain average water temperature at 100°C in the pressure restraint.
- 4
 - Reactor cold shutdown, stable water level, offsite power is available.
 - No cooling water is leaked to the reactor containment vessel.
 - Maintain average water temperature at 100°C in the pressure restraint.

Other N.A.

[back to page top](#)

From: OST05 Hoc
Sent: Thursday, March 24, 2011 1:51 PM
To: LIA04 Hoc
Subject: FW: Response to EPA drinking water limits question

FYI

From: Hoc, PMT12
Sent: Thursday, March 24, 2011 1:49 PM
To: OST05 Hoc
Subject: RE: Response to EPA drinking water limits question

This has been completed.

From: OST05 Hoc
Sent: Thursday, March 24, 2011 12:53 PM
To: PMT03 Hoc; Hoc, PMT12
Cc: OST05 Hoc; LIA04 Hoc
Subject: FW: Response to EPA drinking water limits question

PMT- forwarding this to PMT for response.

Thank you,
-Maria Arribas-Colon

From: Henderson, Pamela
Sent: Thursday, March 24, 2011 10:19 AM
To: OST05 Hoc
Cc: McNamara, Nancy; LIA04 Hoc; LIA03 Hoc; PMT03 Hoc; Hoc, PMT12; Tifft, Doug
Subject: RE: Response to EPA drinking water limits question

Maria,

I believe that RASCAL would utilize NRC limits?

From the EPA website.... EPA bases drinking water limits on a dose of 4 mrem/year to total body or any critical organ. For I-131 the limit is 3 pCi/liter. For Cs-137 the limit is 200 pCi/liter.

From: OST05 Hoc
Sent: Thursday, March 24, 2011 10:12 AM
To: Tifft, Doug; Henderson, Pamela
Cc: McNamara, Nancy; OST05 Hoc; LIA04 Hoc; LIA03 Hoc
Subject: RE: Response to EPA drinking water limits question

Good morning Doug,

I just verified the numbers and the units with RASCAL folks in PMT, and it was confirmed that they are correct.

If you have any additional question on this, please contact PMT at (301) 816-5499.

BBBB / 157

Thank you,
-Maria Arribas-Colon

From: Tifft, Doug
Sent: Thursday, March 24, 2011 7:59 AM
To: OST05 Hoc; LIA04 Hoc
Cc: Henderson, Pamela; McNamara, Nancy
Subject: RE: Response to EPA drinking water limits question

This doesn't sound right. I expected the units to be in pCi/L. And I'd also expect that the limits for one year olds would be lower than the limits for adults.

Would you mind double checking with your EPA contact what the EPA drinking water limit is for I-131 and Cs-137?

I've also got the question in to one of my Regional EPA contacts.

Thanks,
-Doug

From: OST05 Hoc
Sent: Wednesday, March 23, 2011 7:45 PM
To: Henderson, Pamela; Barker, Allan; Browder, Rachel; Erickson, Randy; Logaras, Haral; Maier, Bill; McNamara, Nancy; Tifft, Doug; Trojanowski, Robert; Woodruff, Gena
Cc: OST05 Hoc; LIA04 Hoc; Easson, Stuart; Flannery, Cindy; Lukes, Kim; Maupin, Cardelia; Noonan, Amanda; Rautzen, William; Rivera, Alison; Ryan, Michelle; Turtill, Richard; Virgilio, Rosetta
Subject: Response to EPA drinking water limits question

Doug/ Pam,

This email is in response to your question on the EPA drinking water standards limits for Iodine-131 and Cesium-137. See below.

Iodine-131

One year old: 167 Bq/Kg

Adult: 2420 Bq/Kg

Cesium-137

One year old: 2990 Bq/Kg


Adult: 1360 Bq/Kg

Thank you,
-Maria Arribas-Colon

福島第二(2F) (事業者のモニタリングポスト)

3月19日																						
モニタリングポスト	18:20	18:30	18:40	18:50	19:00	19:10	19:20	19:30	19:40	19:50	20:00	20:10	20:20	20:30	20:40	20:50	21:00	21:10	21:20	21:30	21:40	21:50
MP1($\mu\text{Sv/h}$)	16.723	16.720	16.743	16.803	16.773	16.747	16.740	16.730	16.707	16.710	16.657	16.710	16.623	16.613	16.610	16.690	16.583	16.550	16.547	16.583	16.510	16.557
MP2($\mu\text{Sv/h}$)	10.193	10.157	10.187	10.163	10.167	10.153	10.143	10.133	10.107	10.090	10.083	10.103	10.083	10.097	10.077	10.077	10.080	10.037	10.000	10.730	9.990	10.027
MP3($\mu\text{Sv/h}$)	16.963	16.890	16.860	16.890	16.980	16.853	16.887	16.797	16.797	16.807	16.820	16.800	16.817	16.763	16.760	16.727	16.737	16.703	16.707	16.710	16.713	16.650
MP4($\mu\text{Sv/h}$)	11.643	11.650	11.637	11.593	11.617	11.620	11.607	11.590	11.547	11.557	11.550	11.560	11.503	11.523	11.513	11.497	11.480	11.497	11.477	11.440	11.493	11.507
MP5($\mu\text{Sv/h}$)	11.527	11.557	11.580	11.507	11.553	11.513	11.507	11.467	11.467	11.467	11.467	11.457	11.373	11.457	11.387	11.467	11.467	11.367	11.380	11.367	11.367	11.367
MP6($\mu\text{Sv/h}$)	12.960	12.967	12.937	12.930	12.887	12.917	12.863	12.933	12.883	12.920	12.887	12.867	12.867	12.810	12.837	12.827	12.787	12.807	12.800	12.770	12.793	12.787
MP7($\mu\text{Sv/h}$)	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測
風向	西	西北西	北西	西北西	西	西北西	西北西	西北西	西北西	西北西	西北西	西北西	西北西	北北西	北北西	北	南	南	南南西	西南西	西南西	西南西
風速(m/s)	2.6	3.5	1.8	2.5	3.7	2.7	5.3	6.5	5.5	4.7	2.6	1.4	1.6	1.8	0.9	3.2	1.9	1.8	3.4	5.1	8.8	10.8

3月19日				
モニタリングポスト	22:00	22:10	22:20	22:30
MP1($\mu\text{Sv/h}$)	16.517	16.483	16.470	16.470
MP2($\mu\text{Sv/h}$)	10.017	10.003	9.997	9.973
MP3($\mu\text{Sv/h}$)	16.657	16.657	16.603	16.663
MP4($\mu\text{Sv/h}$)	11.457	11.457	11.447	11.443
MP5($\mu\text{Sv/h}$)	11.367	11.373	11.367	11.313
MP6($\mu\text{Sv/h}$)	12.747	12.730	12.743	12.730
MP7($\mu\text{Sv/h}$)	欠測	欠測	欠測	欠測
風向	西北西	西	西南西	西
風速(m/s)	11.9	10.8	5.7	4.8



9/エフ二→車2F

共有 ← EKC 放射線班

福島第二(2F) (事業者のモニタリングポスト)

3月19日	7:20	7:30	7:40	7:50	8:00	8:10	8:20	8:30	8:40	8:50	9:00	9:10	9:20	9:30	9:40	9:50	10:00	10:10	10:20	10:30	10:40	10:50
モニタリングポスト																						
MP1($\mu\text{Sv/h}$)	17.4	17.4	17.3	17.3	17.3	17.3	17.3	17.3	17.2	17.2	17.2	17.1	17.0	17.1	17.1	17.1	17.0	16.9	17.0	16.9	16.9	16.9
MP2($\mu\text{Sv/h}$)	10.6	10.5	10.5	10.5	10.5	10.5	10.5	10.4	10.4	10.4	10.3	10.3	10.3	10.2	10.3	10.2	10.2	10.2	10.2	10.2	10.1	18.1
MP3($\mu\text{Sv/h}$)	17.7	17.7	17.7	17.7	17.7	17.6	17.7	17.6	17.7	17.6	17.6	17.5	17.4	17.4	17.5	17.4	17.4	17.4	17.4	17.3	17.3	17.3
MP4($\mu\text{Sv/h}$)	12.4	12.4	12.3	12.3	12.3	12.3	12.3	12.3	12.2	12.2	12.2	12.2	12.2	12.1	12.1	12.1	12.1	12.1	12.0	12.0	12.0	12.0
MP5($\mu\text{Sv/h}$)	11.0	11.0	10.9	10.9	10.9	10.9	10.9	10.9	10.9	10.8	10.8	10.8	10.8	10.8	10.8	10.8	10.8	10.8	10.8	10.8	10.8	10.8
MP6($\mu\text{Sv/h}$)	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測
MP7($\mu\text{Sv/h}$)	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測
風向	南南西	南	南南西	南南西	南	南西	西	南西	南	南	南南東	南	南	南	南	南	南	南	南	南南東	南東	南東
風速(m/s)	4.2	4.0	3.9	4.4	5.5	5.8	1.7	2.9	2.5	1.7	3.5	4.1	4.3	6.3	6.4	7.7	6.8	7.1	7.8	8.1	4.6	5.0

3月19日	11:00	11:10	11:20	11:30	11:40	11:50	12:00	12:10	12:20	12:30	12:40	12:50	13:00	13:10	13:20	13:30	13:40	13:50	14:00	14:10	14:20	14:30
モニタリングポスト																						
MP1($\mu\text{Sv/h}$)	16.9	16.9	16.9	16.9	16.8	16.9	16.8	16.8	16.8	16.8	16.8	16.8	16.8	16.8	16.8	16.8	16.8	16.8	16.7	16.8	16.7	16.7
MP2($\mu\text{Sv/h}$)	10.6	10.6	10.6	10.6	10.6	10.6	10.6	10.6	10.5	10.5	10.5	10.4	10.5	10.5	10.4	10.4	10.4	10.4	10.4	10.2	10.3	10.3
MP3($\mu\text{Sv/h}$)	17.3	17.2	17.2	17.1	17.1	17.1	17.1	17.0	17.0	17.1	17.0	17.0	17.0	17.0	17.0	17.0	16.9	16.9	17.0	17.0	16.9	16.9
MP4($\mu\text{Sv/h}$)	12.0	12.0	12.0	11.9	11.9	11.9	11.8	11.8	11.8	11.8	11.8	11.8	11.8	11.8	11.8	11.7	11.8	11.7	11.7	11.7	11.7	11.7
MP5($\mu\text{Sv/h}$)	10.8	10.8	10.8	10.8	10.8	10.8	10.8	10.8	10.8	10.8	10.8	10.8	10.8	10.8	10.8	10.7	10.7	10.8	10.7	10.7	10.7	10.6
MP6($\mu\text{Sv/h}$)	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測
MP7($\mu\text{Sv/h}$)	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測
風向	南南東	南南東	南南東	南東	南南東	南南東	南南東	南南東	南南東	南南東	南南東	南南西	西	西	西	西	西北西	西北西	西	西	西	西
風速(m/s)	7.5	8.0	8.3	6.3	7.4	8.3	8.2	9.4	6.3	5.6	5.0	8.9	11.2	10.2	11.9	11.0	7.2	6.0	7.1	5.8	8.6	5.4

3月19日	14:40	14:50	15:00	15:10	15:20	15:30	15:40	15:50	16:00	16:10	16:20	16:30	16:40	16:50	17:00	17:10	17:20	17:30	17:40	17:50	18:00	18:10
モニタリングポスト																						
MP1($\mu\text{Sv/h}$)	16.7	16.7	16.7	16.7	16.7	16.7	16.7	16.6	16.6	16.5	16.5	16.5	16.5	16.5	16.4	16.913	16.867	16.840	16.890	16.820	16.800	16.827
MP2($\mu\text{Sv/h}$)	10.3	10.2	10.3	10.3	10.3	10.2	10.2	10.2	10.2	10.2	10.2	10.2	10.2	10.2	10.2	10.220	10.190	10.220	10.180	10.210	10.207	10.160
MP3($\mu\text{Sv/h}$)	16.9	16.9	16.9	16.9	16.9	16.9	16.9	16.9	16.9	16.9	16.8	16.8	16.9	16.8	16.8	17.027	17.067	17.003	17.040	17.027	17.007	16.997
MP4($\mu\text{Sv/h}$)	11.7	11.7	11.7	11.7	11.6	11.6	11.6	11.8	11.5	11.6	11.6	11.5	11.6	11.5	11.5	11.639	11.640	11.683	11.680	11.647	11.650	11.663
MP5($\mu\text{Sv/h}$)	10.6	10.6	10.6	10.6	10.6	10.6	10.5	10.4	10.4	10.4	10.4	10.4	10.4	10.4	10.3	11.567	11.560	11.567	11.567	11.567	11.567	11.567
MP6($\mu\text{Sv/h}$)	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	13.020	12.997	13.003	12.970	12.960	12.980	12.967
MP7($\mu\text{Sv/h}$)	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測
風向	西	西	西北西	西	西北西	西	西	西	西	西	西	西	西	西	西	西	西	西	西	西	西	西北西
風速(m/s)	8.6	10.6	8.3	8.1	4.1	6.9	5.0	2.8	3.3	6.2	7.7	9.7	10.7	7.7	7.9	8.0	5.5	6.8	2.7	5.4	6.1	3.0

3月19日 15:45

3月20日 05:28

福島第二(2F) (事業者のモニタリングポスト)

3月18日												
モニタリングポスト	22:00	22:10	22:20	22:30	22:40	22:50	23:00	23:10	23:20	23:30	23:40	23:50
MP1($\mu\text{Sv/h}$)	18.5	18.5	18.5	18.4	18.4	18.4	18.3	18.3	18.3	18.3	18.2	18.2
MP2($\mu\text{Sv/h}$)	11.2	11.2	11.1	11.2	11.1	11.1	11.2	11.1	11.1	11.1	11.1	11.1
MP3($\mu\text{Sv/h}$)	18.8	18.8	18.8	18.8	18.7	18.7	18.7	18.7	18.7	18.7	18.7	18.8
MP4($\mu\text{Sv/h}$)	13.0	13.0	13.0	13.0	13.0	13.0	13.0	13.0	12.9	13.0	12.9	12.9
MP5($\mu\text{Sv/h}$)	11.8	11.9	11.8	11.6	11.8	11.9	11.9	11.7	11.7	11.7	11.7	11.7
MP6($\mu\text{Sv/h}$)	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測
MP7($\mu\text{Sv/h}$)	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測
風向	西	西	西	西	西南西	南西	西南西	南西	南西	南西	南西	南
風速(m/s)	5.0	5.0	3.9	4.5	3.9	2.5	2.6	2.3	2.0	2.6	1.7	1.4

3月19日																						
モニタリングポスト	0:00	0:10	0:20	0:30	0:40	0:50	1:00	1:10	1:20	1:30	1:40	1:50	2:00	2:10	2:20	2:30	2:40	2:50	3:00	3:10	3:20	3:30
MP1($\mu\text{Sv/h}$)	18.2	18.2	18.2	18.2	18.1	18.1	18.1	18.1	18.1	18.1	18.0	18.0	17.9	18.0	18.0	17.9	17.8	17.8	17.8	17.8	17.9	17.8
MP2($\mu\text{Sv/h}$)	11.1	10.9	11.0	11.0	11.0	10.8	10.9	10.9	10.9	10.8	10.9	10.8	10.8	10.8	10.8	10.8	10.8	10.8	10.8	10.8	10.8	10.8
MP3($\mu\text{Sv/h}$)	18.7	18.7	18.6	18.8	18.5	18.5	18.5	18.5	18.5	18.4	18.4	18.4	18.4	18.4	18.3	18.4	18.3	18.3	18.3	18.2	18.3	18.2
MP4($\mu\text{Sv/h}$)	12.9	12.9	12.9	12.9	12.8	12.8	12.8	12.8	12.8	12.8	12.8	12.8	12.8	12.7	12.8	12.7	12.7	12.7	12.7	12.7	12.7	12.7
MP5($\mu\text{Sv/h}$)	11.7	11.7	11.7	11.6	11.7	11.7	11.7	11.7	11.6	11.6	11.6	11.6	11.6	11.6	11.6	11.5	11.6	11.6	11.5	11.5	11.5	11.5
MP6($\mu\text{Sv/h}$)	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測
MP7($\mu\text{Sv/h}$)	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測
風向	南西	南西	南西	南	南	南	南	南	南南西	南	南南西	南南西	南	南	南	南	南	南	南	南	南	南
風速(m/s)	0.3	1.6	1.4	0.6	0.6	1.2	1.5	3.5	3.6	3.8	6.4	6.1	5.8	6.5	6.6	5.8	5.6	4.9	4.4	3.6	4.1	5.8

3月19日																						
モニタリングポスト	3:40	3:50	4:00	4:10	4:20	4:30	4:40	4:50	5:00	5:10	5:20	5:30	5:40	5:50	6:00	6:10	6:20	6:30	6:40	6:50	7:00	7:10
MP1($\mu\text{Sv/h}$)	17.8	17.7	17.7	17.7	17.6	17.0	17.7	17.6	17.8	17.6	17.6	17.6	17.6	17.6	17.5	17.5	17.5	17.5	17.5	17.5	17.4	17.4
MP2($\mu\text{Sv/h}$)	10.7	10.7	10.7	10.7	10.7	10.7	10.7	10.7	10.7	10.7	10.7	10.7	10.7	10.7	10.7	10.6	10.7	10.6	10.6	10.7	10.6	10.6
MP3($\mu\text{Sv/h}$)	18.2	18.2	18.2	18.1	18.0	18.0	18.0	17.9	18.0	17.9	17.9	17.9	17.8	17.9	17.9	17.8	17.8	17.8	17.8	17.7	17.7	17.8
MP4($\mu\text{Sv/h}$)	12.7	12.6	12.8	12.6	12.6	12.6	12.6	12.6	12.5	12.6	12.6	12.5	12.5	12.5	12.5	12.5	12.4	12.4	12.4	12.4	12.4	12.4
MP5($\mu\text{Sv/h}$)	11.4	11.5	11.4	11.4	11.5	11.4	11.4	11.4	11.4	11.3	11.3	11.3	11.2	11.2	11.2	11.1	11.1	11.1	11.2	11.1	11.0	11.0
MP6($\mu\text{Sv/h}$)	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測
MP7($\mu\text{Sv/h}$)	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測
風向	南南西	南	南	南	南南西	南	南	南	南	南南西	南南西	南西	南西	南南西	南	南南西	南	南	南	南	南南西	南南西
風速(m/s)	4.9	3.3	3.8	4.0	5.9	5.6	3.6	6.1	5.2	5.9	5.0	7.2	8.3	8.6	6.1	6.1	6.2	7.7	6.4	6.5	6.0	5.7

福島第二(2F) (事業者のモニタリングポスト)

3月18日																						
モニタリングポスト	11:00	11:10	11:20	11:30	11:40	11:50	12:00	12:10	12:20	12:30	12:40	12:50	13:00	13:10	13:20	13:30	13:40	13:50	14:00	14:10	14:20	14:30
MP1($\mu\text{Sv/h}$)	19.4	19.4	19.4	19.3	19.3	19.3	19.3	19.2	19.2	19.2	19.2	19.2	19.4	19.3	19.4	19.6	19.6	19.8	19.3	19.3	19.2	19.2
MP2($\mu\text{Sv/h}$)	11.7	11.7	11.7	11.7	11.7	11.7	11.6	11.6	11.6	11.6	11.6	11.6	11.7	11.7	11.9	11.8	12.0	12.2	11.7	11.7	11.6	11.6
MP3($\mu\text{Sv/h}$)	19.8	19.8	19.8	19.8	19.6	19.7	19.7	19.5	19.6	19.5	19.6	19.5	19.6	19.5	19.8	19.8	20.0	19.9	19.7	19.6	19.6	19.5
MP4($\mu\text{Sv/h}$)	13.8	13.8	13.7	13.8	13.8	13.7	13.7	13.7	13.7	13.7	13.6	13.6	13.7	13.7	13.8	13.8	14.1	14.1	13.8	13.8	13.8	13.7
MP5($\mu\text{Sv/h}$)	12.4	12.4	12.3	12.4	12.3	12.3	12.2	12.2	12.2	12.2	12.2	12.2	12.3	12.2	12.5	12.5	12.5	12.5	12.5	12.3	12.3	12.3
MP6($\mu\text{Sv/h}$)	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測
MP7($\mu\text{Sv/h}$)	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測
風向	北西	西	南西	南南東	南南東	南	南南東	南東	南東	南東	南南東	南東	南東	南東	南東	南東	南東	南東	東南東	東南東	東	東
風速(m/s)	2.7	1.9	2.1	5.4	5.6	5.7	5.8	5.4	5.1	5.7	4.9	3.8	3.6	4.4	3.0	4.1	3.5	1.9	3.7	4.2	4.3	4.5

3月18日																						
モニタリングポスト	14:40	14:50	15:00	15:10	15:20	15:30	15:40	15:50	16:00	16:10	16:20	16:30	16:40	16:50	17:00	17:10	17:20	17:30	17:40	17:50	18:00	18:10
MP1($\mu\text{Sv/h}$)	19.1	19.1	19.1	19.1	19.1	19.1	19.1	19.1	19.0	19.0	18.9	18.9	18.9	18.8	18.8	18.7	18.7	18.7	18.7	18.7	18.7	18.7
MP2($\mu\text{Sv/h}$)	11.6	11.6	11.6	11.6	11.6	11.6	11.5	11.5	11.4	11.4	11.4	11.4	11.4	11.4	11.4	11.3	11.3	11.3	11.3	11.3	11.3	11.3
MP3($\mu\text{Sv/h}$)	19.5	19.5	19.5	19.5	19.4	19.4	19.4	19.3	19.3	19.3	19.3	19.2	19.3	19.2	19.2	19.2	19.2	19.1	19.1	19.0	19.1	19.1
MP4($\mu\text{Sv/h}$)	13.7	13.7	13.7	13.7	13.7	13.6	13.6	13.5	13.5	13.4	13.4	13.4	13.4	13.4	13.4	13.4	13.3	13.4	13.3	13.3	13.4	13.3
MP5($\mu\text{Sv/h}$)	12.2	12.2	12.3	12.2	12.2	12.0	12.0	12.0	12.0	12.0	12.0	11.9	11.9	11.9	11.9	11.9	11.9	11.9	11.9	11.9	11.9	11.8
MP6($\mu\text{Sv/h}$)	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測
MP7($\mu\text{Sv/h}$)	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測
風向	東南東	南東	東南東	東南東	南東	南東	南南東	南	南東	東南東	南	南南東	南南東	南	南南東	南南東	南南東	南	南	南	南	南
風速(m/s)	3.3	3.1	2.9	2.8	3.3	2.5	3.0	1.7	2.2	0.6	2.2	2.4	1.4	2.3	3.9	2.4	2.0	2.0	1.7	3.3	2.5	2.2

3月18日																						
モニタリングポスト	18:20	18:30	18:40	18:50	19:00	19:10	19:20	19:30	19:40	19:50	20:00	20:10	20:20	20:30	20:40	20:50	21:00	21:10	21:20	21:30	21:40	21:50
MP1($\mu\text{Sv/h}$)	18.7	18.7	18.7	18.7	18.7	18.7	18.6	18.5	18.5	18.7	18.6	18.6	18.6	18.6	18.6	18.6	18.6	18.6	18.5	18.5	18.5	18.5
MP2($\mu\text{Sv/h}$)	11.3	11.3	11.3	11.3	11.3	11.3	11.3	11.3	11.3	11.3	11.3	11.3	11.3	11.2	11.3	11.2	11.2	11.2	11.2	11.2	11.2	11.2
MP3($\mu\text{Sv/h}$)	19.0	18.9	19.0	18.9	19.0	19.0	18.9	18.9	18.8	18.9	18.9	18.9	18.8	18.9	18.8	18.9	18.8	18.8	18.8	18.8	18.8	18.9
MP4($\mu\text{Sv/h}$)	13.3	13.3	13.3	13.3	13.3	13.3	13.3	13.3	13.2	13.3	13.2	13.2	13.2	13.2	13.2	13.2	13.2	13.1	13.1	13.1	13.1	13.1
MP5($\mu\text{Sv/h}$)	11.9	11.8	11.9	11.9	11.9	11.8	11.8	11.8	11.8	11.8	11.8	11.8	11.8	11.8	11.8	11.8	11.8	11.8	11.8	11.8	11.7	11.8
MP6($\mu\text{Sv/h}$)	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測
MP7($\mu\text{Sv/h}$)	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測
風向	南	南	南	南	南	南	南西	南	南	南南西	南南西	南西	南西	西南西	南西	南西	西南西	西南西	西南西	西南西	西南西	西
風速(m/s)	2.2	2.2	1.6	4.2	4.5	3.6	4.3	3.1	2.2	3.8	3.7	5.0	5.8	1.7	3.2	2.5	5.1	5.6	5.8	6.1	5.9	5.6

福島第二(2F) (事業者のモニタリングポスト)

3月18日																						
モニタリングポスト	0:00	0:10	0:20	0:30	0:40	0:50	1:00	1:10	1:20	1:30	1:40	1:50	2:00	2:10	2:20	2:30	2:40	2:50	3:00	3:10	3:20	3:30
MP1($\mu\text{Sv/h}$)	20.8	20.8	20.7	20.7	20.7	20.7	20.7	20.7	20.6	20.8	20.6	20.6	20.6	20.7	20.5	20.5	20.5	20.5	20.4	20.5	20.4	20.4
MP2($\mu\text{Sv/h}$)	点検中	点検中	点検中	点検中	点検中	点検中	点検中	点検中	点検中	点検中	点検中	点検中	点検中	点検中	点検中	点検中	点検中	点検中	点検中	点検中	点検中	点検中
MP3($\mu\text{Sv/h}$)	21.3	21.3	21.3	21.3	21.2	21.1	21.0	21.1	21.1	21.1	21.0	21.0	20.9	21.0	20.9	20.9	20.9	20.9	20.9	20.9	20.9	20.9
MP4($\mu\text{Sv/h}$)	14.8	14.8	14.8	14.8	14.7	14.7	14.7	14.6	14.6	14.7	14.6	14.6	14.6	14.6	14.6	14.6	14.6	14.6	14.6	14.5	14.6	14.6
MP5($\mu\text{Sv/h}$)	13.4	13.4	13.4	13.4	13.4	13.4	13.4	13.4	13.4	13.4	13.4	13.4	13.4	13.4	13.4	13.4	13.4	13.4	13.4	13.4	13.4	13.4
MP6($\mu\text{Sv/h}$)	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測
MP7($\mu\text{Sv/h}$)	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測
風向	西北西	西北西	西	西	西	西北西	北西	北西	北西	北西	北西	北西	北西	北西	北西	北西	北北西	北北西	北	北	北	北西
風速(m/s)	5.2	8.1	8.0	7.7	6.8	7.0	7.3	6.1	5.6	6.4	6.5	6.7	7.7	7.2	6.0	5.2	5.1	2.3	3.4	3.9	3.9	3.1

3月18日																						
モニタリングポスト	3:40	3:50	4:00	4:10	4:20	4:30	4:40	4:50	5:00	5:10	5:20	5:30	5:40	5:50	6:00	6:10	6:20	6:30	6:40	6:50	7:00	7:10
MP1($\mu\text{Sv/h}$)	20.3	20.3	20.4	20.3	20.3	20.3	20.3	20.2	20.3	20.2	20.2	20.2	20.2	20.2	20.2	20.2	20.1	20.1	20.1	20.1	20.0	20.1
MP2($\mu\text{Sv/h}$)	点検中	点検中	点検中	点検中	点検中	点検中	点検中	点検中	点検中	点検中	点検中	点検中	点検中	点検中	点検中	点検中	点検中	点検中	点検中	点検中	点検中	点検中
MP3($\mu\text{Sv/h}$)	20.9	20.9	20.8	20.8	20.8	20.8	20.8	20.7	20.7	20.7	20.5	20.5	20.6	20.5	20.5	20.5	20.5	20.5	20.4	20.4	20.4	20.4
MP4($\mu\text{Sv/h}$)	14.6	14.6	14.5	14.5	14.5	14.5	14.5	14.4	14.5	14.5	14.4	14.5	14.4	14.3	14.3	14.3	14.3	14.3	14.3	14.2	14.2	14.2
MP5($\mu\text{Sv/h}$)	13.4	13.4	13.4	13.4	13.4	13.4	13.4	13.4	13.4	13.4	13.4	13.4	13.3	13.3	13.0	13.0	12.9	12.8	12.6	12.7	12.5	12.5
MP6($\mu\text{Sv/h}$)	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測
MP7($\mu\text{Sv/h}$)	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測
風向	北北西	北西	北西	北西	北北西	北	北	北	北	北	北	北	北	北西	西	北北西	北北西	西北西	北西	北西	北西	北北西
風速(m/s)	3.0	3.1	2.8	2.6	4.2	5.4	5.0	4.5	2.9	3.0	3.4	2.0	1.8	1.1	1.4	2.8	3.6	2.8	5.9	6.6	5.0	2.8

3月18日																						
モニタリングポスト	7:20	7:30	7:40	7:50	8:00	8:10	8:20	8:30	8:40	8:50	9:00	9:10	9:20	9:30	9:40	9:50	10:00	10:10	10:20	10:30	10:40	10:50
MP1($\mu\text{Sv/h}$)	20.1	20.0	20.0	20.0	20.0	19.8	19.8	19.8	19.7	19.8	19.8	19.7	19.7	19.7	19.7	19.7	19.7	19.6	19.5	19.5	19.5	19.4
MP2($\mu\text{Sv/h}$)	点検中	点検中	点検中	点検中	点検中	点検中	点検中	点検中	点検中	点検中	点検中	点検中	11.9	11.9	11.9	11.8	11.8	11.8	11.7	11.7	11.8	11.7
MP3($\mu\text{Sv/h}$)	20.3	20.4	20.4	20.3	20.3	20.3	20.2	20.3	20.1	20.2	20.1	20.1	20.1	20.0	20.0	20.0	19.9	19.9	19.9	19.9	19.9	19.8
MP4($\mu\text{Sv/h}$)	14.2	14.2	14.2	14.2	14.1	14.1	14.2	14.1	14.1	14.1	14.0	14.0	14.0	13.9	13.9	13.9	13.9	13.9	13.8	13.8	13.8	13.8
MP5($\mu\text{Sv/h}$)	12.6	12.5	12.5	12.5	12.6	12.5	12.5	12.5	12.5	12.5	12.5	12.5	12.5	12.5	12.5	12.5	12.5	12.5	12.5	12.5	12.5	12.4
MP6($\mu\text{Sv/h}$)	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測
MP7($\mu\text{Sv/h}$)	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測	欠測
風向	北西	北西	北	西北西	北北西	北西	北西	北	北西	北北西	北北西	北北西	北北西	北北西	北北西	西北西	西北西	北西	北西	北西	北西	北西
風速(m/s)	1.3	1.4	1.7	2.8	6.5	5.8	4.4	3.2	3.9	7.2	5.6	4.9	7.6	5.0	5.8	6.1	5.7	4.1	4.0	3.4	3.2	3.9

各発電所の環境モニタリング結果

単位: $\mu\text{Sv/h}$

通常の平常値の範囲	会社名	発電所名	3月18日											
			12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00
0.023~0.027	北海道電力	泊原発	0.022	0.022	0.022	0.021	0.022	0.022	0.022	0.022	0.022	0.022	0.022	0.022
0.024~0.060	東北電力	女川原子力発電所	2.60	2.60	2.60	2.60	2.50	2.50	2.50	2.50	2.50	2.40	2.40	2.40
0.012~0.060	東北電力	東通原子力発電所	0.018	0.017	0.017	0.017	0.018	0.017	0.016	0.018	0.017	0.017	0.016	0.016
0.033~0.050	東京電力	福島第一原子力発電所	263.5	262	3414	3345	4485	5055	4984	3788	3611	419.1	393.9	373.6
0.036~0.052	東京電力	福島第二原子力発電所	19.7	19.6	19.7	19.5	19.3	19.2	19.1	19.0	18.9	18.8	18.8	18.7
0.011~0.159	東京電力	柏崎刈羽原子力発電所	0.052	0.069	0.068	0.063	0.063	0.063	0.062	0.062	0.064	0.064	0.064	0.063
0.036~0.052	日本原子力発電	東海第二発電所	0.685	0.605	0.669	0.658	0.654	0.660	0.653	0.649	0.651	0.646	0.645	0.640
0.039~0.110	日本原子力発電	関西発電所	0.072	0.073	0.072	0.073	0.072	0.072	0.073	0.073	0.074	0.072	0.073	0.073
0.064~0.108	中部電力	浜岡原子力発電所	0.068	0.068	0.068	0.068	0.068	0.068	0.068	0.068	0.068	0.068	0.068	0.068
0.0207~0.132	北陸電力	志賀原子力発電所	0.031	0.031	0.031	0.031	0.031	0.032	0.032	0.032	0.031	0.032	0.032	0.032
0.028~0.130	中国電力	島根原子力発電所	0.031	0.030	0.030	0.030	0.030	0.030	0.030	0.030	0.031	0.030	0.031	0.030
0.070~0.077	中国電力	美浜発電所	0.071	0.071	0.070	0.071	0.072	0.071	0.071	0.072	0.072	0.072	0.070	0.073
0.045~0.047	関西電力	高浜発電所	0.042	0.042	0.042	0.042	0.043	0.043	0.043	0.043	0.042	0.042	0.043	0.043
0.036~0.040	関西電力	大飯発電所	0.034	0.034	0.034	0.034	0.033	0.034	0.034	0.034	0.034	0.036	0.036	0.036
0.011~0.080	四国電力	伊方発電所	0.014	0.013	0.014	0.014	0.014	0.014	0.014	0.014	0.014	0.014	0.014	0.014
0.023~0.087	九州電力	玄海原子力発電所	0.028	0.027	0.028	0.027	0.026	0.025	0.027	0.027	0.025	0.023	0.027	0.028
0.034~0.120	九州電力	川内原子力発電所	0.036	0.037	0.033	0.033	0.036	0.037	0.037	0.037	0.039	0.039	0.039	0.038
0.009~0.069	日本原燃(株)	六ヶ所 再処理工場	0.014	0.014	0.014	0.014	0.014	0.014	0.014	0.014	0.014	0.014	0.013	0.013
0.009~0.071	日本原燃(株)	六ヶ所 再処理工場	0.015	0.015	0.016	0.016	0.016	0.015	0.015	0.015	0.015	0.015	0.015	0.015

※福島第一原子力発電所については、作業状況により若干測定時間のずれ及び測定位置の変更が生じることもございます。

通常の平常値の範囲	会社名	発電所名	3月19日											
			0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00
0.023~0.027	北海道電力	泊原発	0.022	0.022	0.022	0.022	0.022	0.022	0.021	0.022	0.022	0.022	0.022	
0.024~0.060	東北電力	女川原子力発電所	2.40	2.30	2.30	2.30	2.30	2.30	2.20	2.20	2.20	2.30		
0.012~0.060	東北電力	東通原子力発電所	0.017	0.018	0.017	0.017	0.017	0.017	0.016	0.017	0.016	0.017		
0.033~0.050	東京電力	福島第一原子力発電所	3229	3248	318.7	306.9	301.7	297.5	293.8	290.6	339	364.5		
0.036~0.052	東京電力	福島第二原子力発電所	18.7	18.5	18.4	18.3	18.2	18	17.9	17.7	17.7	17.6		
0.011~0.159	東京電力	柏崎刈羽原子力発電所	0.064	0.065	0.063	0.065	0.065	0.064	0.065	0.064	0.064	0.064		
0.036~0.052	日本原子力発電	東海第二発電所	0.641	0.642	0.637	0.632	0.630	0.628	0.628	0.625	0.621	0.617		
0.039~0.110	日本原子力発電	関西発電所	0.073	0.073	0.074	0.074	0.073	0.072	0.074	0.073	0.073	0.073		
0.064~0.108	中部電力	浜岡原子力発電所	0.068	0.068	0.068	0.068	0.068	0.068	0.068	0.068	0.068	0.068		
0.0207~0.132	北陸電力	志賀原子力発電所	0.032	0.032	0.033	0.033	0.033	0.033	0.033	0.032	0.033	0.032		
0.028~0.130	中国電力	島根原子力発電所	0.030	0.031	0.031	0.031	0.028	0.030	0.030	0.028	0.031	0.030		
0.070~0.077	中国電力	美浜発電所	0.072	0.072	0.072	0.072	0.073	0.071	0.073	0.071	0.074			
0.045~0.047	関西電力	高浜発電所	0.043	0.043	0.042	0.043	0.043	0.042	0.043	0.042	0.043			
0.036~0.040	関西電力	大飯発電所	0.036	0.036	0.035	0.036	0.035	0.035	0.035	0.036	0.035			
0.011~0.080	四国電力	伊方発電所	0.014	0.013	0.014	0.013	0.014	0.014	0.014	0.014	0.014	0.014		
0.023~0.087	九州電力	玄海原子力発電所	0.027	0.025	0.027	0.027	0.029	0.027	0.026	0.029	0.027	0.026		
0.034~0.120	九州電力	川内原子力発電所	0.039	0.038	0.038	0.038	0.043	0.038	0.036	0.038	0.036	0.036		
0.009~0.069	日本原燃(株)	六ヶ所 再処理工場	0.014	0.013	0.013	0.013	0.014	0.013	0.014	0.014	0.014	0.013		
0.009~0.071	日本原燃(株)	六ヶ所 再処理工場	0.015	0.015	0.015	0.016	0.016	0.015	0.015	0.015	0.016	0.016		

※福島第一原子力発電所については、作業状況により若干測定時間のずれ及び測定位置の変更が生じることもございます。

3/19(土) 9時時点

平成28年 3月20日 1時48分

平成28年 3月20日 1時52分

3月19日

福島第一(1F) 測定場所

①事務本館北(2号機より北西約0.5キロ) ②体育館付近(MP-5東側)(2号機より西北西約0.9キロ)
 ③西門付近(MP-5付近)(2号機より西約1.1キロ) ④正門付近前(MP-8付近)(2号機より西南西約1.0キロ)

測定場所	①																							
モニタリングカー	18:50	19:00	19:10	19:20	19:30	19:40	19:50	20:00	20:10	20:20	20:30	20:40	20:50	21:00	21:10	21:20	21:30	21:40	21:50	22:00	22:10	22:20	22:30	
測定値(μSv/h)	2978.0	2972.0	2965.0	2981.0	2967.0	2946.0	2941.0	2937.0	2931.0	2924.0	2917.0	2912.0	2909.0	2906.0	2906.0	2895.0	2891.0	2883.0	2880.0	2880.0	2876.0	2855.0	2854.0	
中性子	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
風向	西	西南西	西南西	西南西	西	西	西	西	西	西	西	西	西	西	西	西	西	西	西	西	西北西	東北東	西南西	西
風速(m/s)	4.4	4.1	3.2	2.7	2.8	2.7	2.2	2.6	3.1	2.6	2.5	2.6	3.1	3.4	3.4	2.3	1.8	2.0	2.2	1.2	0.8	1.0	2.0	

系記録 3月20日 0時45分

系記録 3月20日 0時52分

3月19日

福島第一(1F) 測定場所

①事務本館北(2号機より北西約0.5キロ)

②体育館付近(MP-5東側)(2号機より北西約0.9キロ)

③西門付近(MP-5付近)(2号機より西約1.1キロ)

④正門付近前(MP-6付近)(2号機より西南西約1.0キロ)

測定場所	③																							
モニタリングカー	3:40	3:50	4:00	4:10	4:20	4:30	4:40	4:50	5:00	5:10	5:20	5:30	5:40	5:50	6:00	6:10	6:20	6:30	6:40	6:50	7:00	7:10	7:20	
測定値($\mu\text{Sv/h}$)	303.6	303.1	301.7	301.3	300.5	299.2	299.2	298.5	297.5	296.4	295.8	295.1	295.4	294.3	293.8	293.6	292.6	292.3	291.5	290.9	290.6	289.8	289.1	
中性子	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
風向	南南東	西北西	東	西	西北西	南東	西	南	南	南	東	北西	東	南東	西	南東	東北東	東南東	南南東	東	北西	西	西	
風速(m/s)	0.9	0.6	0.6	0.5	0.4	0.6	0.6	0.4	0.5	0.5	0.9	0.9	0.9	0.6	0.9	0.7	0.5	0.4	0.3	0.4	0.7	0.3	0.1	

測定場所	③																							
モニタリングカー	7:20	7:40	7:50	8:00	8:10	8:20	8:30	8:40	8:50	9:00	9:10	9:20	9:30	9:40	9:50	10:00	10:10	10:20	10:30	10:40	10:50	11:00	11:10	
測定値($\mu\text{Sv/h}$)	288.9	288.6	287.2	399.0	830.8	670.6	431.9	390.5	522.5	364.5	338.5	323.8	425.2	657.3	358.3	346.1	341.2	338.4	334.3	130.2	327.1	322.6	319.1	
中性子	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
風向	西南西	南西	南東	北北東	西北西	西北西	東	東北東	東北東	北東	東	東	東	東	南東	南東	南	南東	東	南南東	南南東	南西	西	
風速(m/s)	0.8	0.6	0.6	0.3	0.5	0.3	0.4	0.6	0.6	0.9	1.6	2.1	2.0	1.5	1.8	1.8	1.9	1.9	1.7	1.5	1.5	1.6	2	

測定場所	③		測定 位置 変更 ※13	①																					
モニタリングカー	11:20	11:30		11:40	11:50	12:00	12:10	12:20	12:30	12:40	12:50	13:00	13:10	13:20	13:30	13:40	13:50	14:00	14:10	14:20	14:30	14:40	14:50		
測定値($\mu\text{Sv/h}$)	316.1	313.1		3954.0	3901.0	3682.0	3828.0	3802.0	3749.0	3704.0	3655.0	3629.0	3694.0	3686.0	3529.0	3491.0	3473.0	3443.0	3417.0	3396.0	3375.0	3348.0	3340.0	3340.0	
中性子	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
風向	西北西	南西		西北西	西	西	西	西北西	西	西南西	西南西	北西	西	北西	西	西	南南西	西	北東	西	北	南南西	南東	南東	
風速(m/s)	2.9	3.4		4.0	4.7	6.8	5.7	5.6	5.7	5.9	6.1	4.2	3.7	5.3	4.3	5.1	4.9	5.8	3.4	4.6	4.9	3.1	2		

測定場所	①																							
モニタリングカー	15:00	15:10	15:20	15:30	15:40	15:50	16:00	16:10	16:20	16:30	16:40	16:50	17:00	17:10	17:20	17:30	17:40	17:50	18:00	18:10	18:20	18:30	18:40	
測定値(μSv/h)	3279.0	3281.0	3229.0	3194.0	3474.0	3167.0	3165.0	3137.0	3135.0	3120.0	3111.0	3089.0	3078.0	3071.0	3058.0	3051.0	3033.0	3024.0	3020.0	3007.0	3002.0	2998.0	2992.0	
中性子	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
風向	西	西	西	南西	南西	南	北西	西	西	西南西	西南西	西	西	西	北西	西	西	西	西	西	西	西	西	
風速(m/s)	4.9	4.6	3.4	3.8	4.6	3.9	2.4	4.8	9.0	4.5	6.1	5.1	5.7	4.5	4.1	3.3	3.8	3.6	3.6	2.7	2.8	4.1	1	

※13 事務本館北(2号機より北西約0.5キロ) ※放水活動による効果を測定するためにより近傍へ移動

3月18日

福島第一(1F) 測定場所

①事務本館北(2号機より北西約0.5キロ) ②体育館付近(MP-5東側)(2号機より北西約0.9キロ)
 ③西門付近(MP-5付近)(2号機より西約1.1キロ) ④正門付近前(MP-6付近)(2号機より西南西約1.0キロ)

測定場所	①																							
モニタリングカー	14:45	14:50	14:55	15:00	15:10	15:20	15:30	15:40	15:50	16:00	16:10	16:20	16:30	16:40	16:50	17:00	17:10	17:20	17:30	17:40	17:50	18:00	18:10	
測定値($\mu\text{Sv/h}$)	3357.0	3339.0	3346.0	3345.0	3368.0	3582.0	4076.0	3823.0	4396.0	4485.0	4352.0	4535.0	4419.0	4277.0	4735.0	5055.0	5033.0	4952.0	4251.0	4182.0	4098.0	4084.0	4069.0	
中性子	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
風向	南南東	東南東	南	南東	南	南南東	南南東	南南東	南南東	南南東	東南東	南	南南東	東	南南東	南	南南東	南南東	南	南	南南西	南南西	南	
風速(m/s)	1.6	1.5	1.5	1.4	1.7	1.9	2.3	2.1	2.2	2.4	2.0	2.1	1.8	2.1	2.1	2.0	2.1	3.1	2.3	1.8	1.8	1.2	1.1	

測定場所	①												測定 位置 変更 ※10	③											
モニタリングカー	18:20	18:30	18:40	18:50	19:00	19:10	19:20	19:30	19:40	19:50	20:00	20:10		20:20	20:30	20:40	20:50	21:00	21:10	21:20	21:30	21:40	21:50		
測定値(μSv/h)	4069.0	3922.0	3885.0	3832.0	3788.0	3745.0	3728.0	3699.0	3669.0	3634.0	3611.0	447.6		441.2	434.5	429.2	429.9	419.1	414.2	409.4	405.2	401.6	397.1		
中性子	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
風向	南	南南西	南南西	南南西	西	南西	南西	南南西	南	西南西	西南西	南		西	西北西	南西	西南西	南南西	西	西	西	北北西	西		
風速(m/s)	1.2	1.5	1.5	1.4	1.5	1.3	1.4	1.4	1.3	1.5	1.3	3.0	0.5	0.7	0.8	0.6	0.5	0.6	0.3	0.3	0.4	0.1			

測定場所	③										①		
モニタリングカー	22:00	22:10	22:20	22:30	22:40	22:50	23:00	23:10	23:20	測定位置	23:30	23:40	23:50
測定値($\mu\text{Sv/h}$)	393.9	389.2	385.9	382.9	379.6	375.9	373.0	371.2	368.9	※11	3254.0	3256.0	3244.0
中性子	ND	ND	ND	ND	ND	ND	ND	ND	ND	※11	ND	ND	ND
風向	南西	南西	西	西	南西	西	北	北西	西南西	※11	西南西	南西	西南西
風速(m/s)	0.5	0.7	0.5	0.5	0.4	0.4	0.3	0.4	0.3	※11	2.8	1.2	1.2

3月19日

測定場所	①												測定 位置 変更 ※12	③											
モニタリングカー	0:00	0:10	0:20	0:30	0:40	0:50	1:00	1:10	1:20	1:30	1:40	1:50		2:00	2:10	2:20	2:30	2:40	2:50	3:00	3:10	3:20	3:30		
測定値(μSv/h)	3229.0	3224.0	3219.0	3231.0	3242.0	3284.0	3248.0	3279.0	3247.0	3195.0	3188.0	3181.0		313.7	312.2	311.1	310.0	308.1	308.6	306.9	306.0	305.1	304.1		
中性子	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
風向	西南西	西南西	南西	南西	西南西	西	西南西	西南西	西南西	西南西	南西	西南西		北	北	南	西南西	西南西	北北東	西北西	南西	南南東	東		
風速(m/s)	1.4	1.4	1.2	1.1	0.9	1.4	1.3	1.3	1.3	1.4	1.6	1.3	3.0	0.3	0.3	0.6	0.3	0.4	0.6	0.7	0.7	0.1			

※10 西門付近(MP-5付近)(2号機より西約1.1キロ) ※定点で測定するため移動

※11 事務本館北(2号機より北西約0.5キロ) ※放水活動による効果を測定するためにより近傍へ移動

※12 西門付近(MP-5付近)(2号機より西約1.1キロ) ※定点で測定するため移動

3月18日

福島第一(1F) 測定場所

 ①事務本館北(2号機より北西約0.5キロ) ②体育館付近(MP-5東側)(2号機より北西約0.9キロ)
 ③西門付近(MP-5付近)(2号機より西約1.1キロ) ④正門付近前(MP-6付近)(2号機より西南西約1.0キロ)

測定場所	③																							
モニタリングカー	0:00	0:10	0:20	0:30	0:40	0:50	1:00	1:10	1:20	1:30	1:40	1:50	2:00	2:10	2:20	2:30	2:40	2:50	3:00	3:10	3:20	3:30	3:40	
測定値(μSv/h)	287.0	287.3	286.6	286.4	286.3	286.0	285.6	285.5	285.2	284.9	284.6	284.4	284.0	283.7	283.7	283.5	283.0	282.9	282.6	282.2	282.1	281.6	281.0	
中性子	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
風向	西	西	西	西	北西	西北西	北西	北西	北西	北西	北	北西	北西	北東	北東	北東	北北東	北西	西	西北西	西北西	西	北西	
風速(m/s)	1.4	1.0	1.0	0.8	0.9	1.0	1.6	1.5	1.7	1.4	0.9	0.6	1.0	0.5	0.2	0.2	0.2	0.2	0.2	0.3	0.4	0.7	0	


測定場所	③																							
モニタリングカー	3:50	4:00	4:10	4:20	4:30	4:40	4:50	5:00	5:10	5:20	5:30	5:40	5:50	6:00	6:10	6:20	6:30	6:40	6:50	7:00	7:10	7:20	7:30	
測定値(μSv/h)	281.1	281.1	280.9	280.7	280.2	280.0	279.8	279.4	279.3	279.0	278.9	278.9	277.1	274.0	274.0	273.8	274.1	272.7	273.4	272.4	271.7	271.6	271.5	
中性子	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
風向	東	西	西	北	北西	北	北東	北北東	北北西	北	北西	北西	北	北東	西	北	西	北西	西	西	北	北	西	
風速(m/s)	0.4	0.5	0.5	0.4	0.2	0.6	0.5	0.5	0.5	0.6	0.7	1.0	1.0	1.3	1.6	1.4	1.2	1.5	1.6	2.3	2.1	1.9	2	

測定場所	③																							
モニタリングカー	7:40	7:50	8:00	8:10	8:20	8:30	8:40	8:50	9:00	9:10	9:20	9:30	9:40	9:50	10:00	10:10	10:20	10:30	10:40	10:50	11:00	11:10	11:20	
測定値(μSv/h)	271.1	271.2	270.5	270.3	269.9	269.9	269.8	269.2	268.7	267.6	268.9	267.5	267.0	266.9	266.7	266.4	266.1	265.7	265.4	264.8	265.0	264.4	264.0	
中性子	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
風向	北西	北	北西	北西	西	西	西	北西	西北西	西北西	西	西	西	西北西	北北西	西	北西	北西	北	南西	西	北	北西	
風速(m/s)	2.9	3.0	2.7	2.9	3.4	3.7	3.3	2.5	2.6	2.8	2.3	3.3	2.9	3.1	2.0	1.8	2.2	2.5	2.3	1.8	1.9	1.5	1.0	

測定場所	③													測定 位置 変更 ※9	①									
モニタリングカー	11:30	11:40	11:50	12:00	12:10	12:20	12:30	12:40	12:50	13:00	13:10	13:20	13:30		13:50	14:00	14:10	14:15	14:20	14:25	14:30	14:35	14:40	
測定値(μSv/h)	264.1	264.4	263.4	263.5	263.1	262.9	263.3	264.3	261.3	262.0	261.9	262.7	264.1		3484.0	3414.0	3382.0	3371.0	3362.0	3357.0	3352.0	3342.0	3348	
中性子	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
風向	南西	南西	西北西	北	西	南東	東	南	南東	南	東南東	南東	東		東南東	南南東	南東	東南東	南	東南東	南東	南南東	南南	
風速(m/s)	1.5	1.7	1.6	1.7	1.3	1.2	1.1	1.8	2.7	3.0	2.6	2.5	2.0	1.8	2.0	1.7	1.6	1.7	1.9	1.9	1.7			

※9 事務本館北(2号機より北西約0.5キロ) ※放水活動による効果を測定するためにより近傍へ移動

福島第一原子力発電所



insir

From: [LIA07 Hoc](#)
Subject: 0600 EDT (March 24, 2011) USNRC Earthquake/Tsunami Status Update
Date: Thursday, March 24, 2011 6:23:44 AM
Attachments: [NRC Status Update 3.24.11--0600 EDT.pdf](#)

Please find attached a 0600 EDT (March 24, 2011) status update from the US Nuclear Regulatory Commission's Emergency Operations Center regarding the impacts of the earthquake/tsunami.

HOC Please note that this information is "Official Use Only" and is only being shared within the federal family.

Please call the Headquarters Operations Officer at 301-816-5100 with questions.

-Jim

Jim Anderson
Office of Nuclear Security and Incident Response
US Nuclear Regulatory Commission
James.anderson@nrc.gov
LIA07.HOC@nrc.gov (Operations Center)

BBBB/158

From: LIA07 Hoc
To: LIA07 Hoc; Borchardt, Bill; Bradford, Anna; Cohen, Shari; Cooper, LaToya; Dyer, Jim; Flory, Shirley; Gibbs, Catina; Haney, Catherine; Hudson, Sharon; Jaczko, Gregory; Johnson, Michael; Leeds, Eric; Loyd, Susan; Pace, Patti; Schwarz, Sherry; Sheron, Brian; Speiser, Herald; Taylor, Renee; Virgilio, Martin; Walls, Lorena; Weber, Michael
Subject: Correction to Update for "Go Books," 0600 3/24/11
Date: Thursday, March 24, 2011 6:42:14 AM
Attachments: NRC Status Update 3.24.11--0600 EDT.pdf

HOC
Please find attached a corrected 032411 0600 EDT Status Update. The previous version was incorrectly labeled as a "Draft."

Thank you,

-Jim

Jim Anderson
Office of Nuclear Security and Incident Response
US Nuclear Regulatory Commission
LIA07.HOC@nrc.gov
James.anderson@nrc.gov

BBBB / 159

HOC

From: [LIA07 Hoc](#)
Cc: [LIA07 Hoc](#)
Subject: Corrected 0600 EDT (March 24, 2011) USNRC Earthquake/Tsunami Status Update
Date: Thursday, March 24, 2011 6:40:12 AM
Attachments: [NRC Status Update 3.24.11--0600 EDT.pdf](#)

Please find attached a 0600 EDT (March 24, 2011) status update from the US Nuclear Regulatory Commission's Emergency Operations Center regarding the impacts of the earthquake/tsunami. **This corrects the previous version that was incorrectly marked draft.**

Please note that this information is "Official Use Only" and is only being shared within the federal family.

Please call the Headquarters Operations Officer at 301-816-5100 with questions.

-Jim

Jim Anderson
Office of Nuclear Security and Incident Response
US Nuclear Regulatory Commission
James.anderson@nrc.gov
LIA07.HOC@nrc.gov (Operations Center)

BBBB / 160

From: LIA07 Hoc
Subject: 1800 EDT (March 24, 2011) USNRC Earthquake/Tsunami Status Update
Date: Thursday, March 24, 2011 6:00:04 PM
Attachments: USNRC Earthquake-Tsunami Update.032411.1800EDT.pdf

HOC
Attached, please find an 1800 EDT (March 24, 2011) status update from the US Nuclear Regulatory Commission's Emergency Operations Center regarding the impacts of the earthquake/tsunami.

Please note that this information is "Official Use Only" and is only being shared within the federal family.

Please call the Headquarters Operations Officer at 301-816-5100 with questions.

-Sara

Sara K. Mroz
Communications and Outreach
Office of Nuclear Security and Incident Response
US Nuclear Regulatory Commission
Sara.Mroz@nrc.gov
LIA07.HOC@nrc.gov (Operations Center)

BBB/ 161

To: PMT03 Hoc
Cc: OST05 Hoc; LIA04 Hoc
Subject: FW: Response to EPA drinking water limits question

PMT- Could you please get back to RI on this?
Contacts: Doug Tift and Pamela Henderson

Thank you,
-Maria

From: Henderson, Pamela
Sent: Thursday, March 24, 2011 10:19 AM
To: OST05 Hoc
Cc: McNamara, Nancy; LIA04 Hoc; LIA03 Hoc; PMT03 Hoc; Hoc, PMT12; Tift, Doug
Subject: RE: Response to EPA drinking water limits question

Maria,

I believe that RASCAL would utilize NRC limits?

From the EPA website.... EPA bases drinking water limits on a dose of 4 mrem/year to total body or any critical organ. For I-131 the limit is 3 pCi/liter. For Cs-137 the limit is 200 pCi/liter.

From: OST05 Hoc
Sent: Thursday, March 24, 2011 10:12 AM
To: Tift, Doug; Henderson, Pamela
Cc: McNamara, Nancy; OST05 Hoc; LIA04 Hoc; LIA03 Hoc
Subject: RE: Response to EPA drinking water limits question

Good morning Doug,

I just verified the numbers and the units with RASCAL folks in PMT, and it was confirmed that they are correct.

If you have any additional question on this, please contact PMT at (301) 816-5499.

Thank you,
-Maria Arribas-Colon

From: Tift, Doug
Sent: Thursday, March 24, 2011 7:59 AM
To: OST05 Hoc; LIA04 Hoc
Cc: Henderson, Pamela; McNamara, Nancy
Subject: RE: Response to EPA drinking water limits question

This doesn't sound right. I expected the units to be in pCi/L. And I'd also expect that the limits for one year olds would be lower than the limits for adults.

Would you mind double checking with your EPA contact what the EPA drinking water limit is for I-131 and Cs-137?

BBBB / 162

I've also got the question in to one of my Regional EPA contacts.

Thanks,
-Doug

From: OST05 Hoc

Sent: Wednesday, March 23, 2011 7:45 PM

To: Henderson, Pamela; Barker, Allan; Browder, Rachel; Erickson, Randy; Logaras, Haral; Maier, Bill; McNamara, Nancy; Tifft, Doug; Trojanowski, Robert; Woodruff, Gena

Cc: OST05 Hoc; LIA04 Hoc; Easson, Stuart; Flannery, Cindy; Lukes, Kim; Maupin, Cardelia; Noonan, Amanda; Rautzen, William; Rivera, Alison; Ryan, Michelle; Turtill, Richard; Virgilio, Rosetta

Subject: Response to EPA drinking water limits question

Doug/ Pam,

This email is in response to your question on the EPA drinking water standards limits for Iodine-131 and Cesium-137. See below.

Iodine-131

One year old: 167 Bq/Kg

Adult: 2420 Bq/Kg

Cesium-137

One year old: 2990 Bq/Kg

Adult: 1360 Bq/Kg

Thank you,
-Maria Arribas-Colon

From: PMT03 Hoc
Sent: Friday, March 25, 2011 8:14 PM
To: eoc_environmental_unit@epa.gov
Subject: FW: US Nuclear Plant Reported Measurements
Attachments: US Nuclear Plant Reported Measurements 03252011.xlsx

The message to 'eoc_environmentalunit@epa.gov' was returned undeliverable...

From: PMT03 Hoc
Sent: Friday, March 25, 2011 8:11 PM
To: 'eoc_environmentalunit@epa.gov'; 'eoc_manager@epa.gov'
Subject: US Nuclear Plant Reported Measurements

Ryan Craffey
Protective Measures Team, USNRC

OFFICIAL USE ONLY

Date	Plant	Isotope	Concentration
3/18/2011	San Onofre	I-131	1.4E-13 uCi/cc
3/18/2011	Diablo Canyon	I-131	3.8 to 6E-13 uCi/cc
3/19/2011	San Onofre	I-131	6.5E-13 to 7.0E-13 uCi/cc
3/19/2011	Palo Verde	Cs-134	2.22E-13 uCi/cc
3/19/2011	Palo Verde	Cs-137	3.58E-13 uCi/cc
3/19/2011	Palo Verde	I-131	1.54E-12 uCi/cc
3/20/2011	San Onofre	I-131	2.0E-12 uCi/cc
3/20/2011	Palo Verde	Cs-134	3.87E-13 uCi/cc
3/20/2011	Palo Verde	I-131	2.50E-12 uCi/cc
3/21/2011	Nine Mile Point	I-131	19.1 pCi/L (rainwater)
3/21/2011	Palo Verde	I-131	6.70E-13 uCi/cc
3/21/2011	Palo Verde	Cs-134	2.06E-13 uCi/cc
3/21/2011	Palo Verde	Cs-137	2.71E-13 uCi/cc
3/22/2011	San Onofre	I-131	7.0 to 8.0E-13 uCi/cc
3/22/2011	San Onofre	Cs-137	1.25E-13 uCi/cc
3/22/2011	Columbia	I-131	6.74E-13 uCi/cc
3/22/2011	Nine Mile Point	I-131	18 pCi/L (rainwater)
3/22/2011	Ginna	I-131	26.8 pCi/L (rainwater)
3/22/2011	Palo Verde	I-131	2.01E-12 uCi/cc
3/22/2011	Palo Verde	Cs-137	2.93E-13 uCi/cc
3/22/2011	Palo Verde	Cs-134	2.76E-13 uCi/cc
3/23/2011	Millstone	I-131	25.6 pCi/L (rainwater)
3/23/2011	San Onofre	I-131	5E-13 to 6E-13 uCi/cc
3/23/2011	San Onofre	Cs-137	7E-14 uCi/cc
3/23/2011	Palo Verde	I-131	7.42E-13 uCi/cc
3/23/2011	TMI	I-131	95 pCi/L (rainwater)
3/24/2011	Palo Verde	I-131	6.30E-13 uCi/cc
3/24/2011	Oyster Creek	I-131	127 pCi/L (rainwater)
3/24/2011	San Onofre	I-131	3.0E-13 to 6.0E-13 uCi/cc
3/24/2011	Limerick	I-131	47 pCi/L (rainwater)
3/25/2011	South Texas	I-131	2.6E-13 uCi/cc

I-131 Reporting Levels
NUREG-1201 and NUREG-1302

	I-131	Units	I-131
Drinking Water	2	pCi/L	2.00E-09
Non-Drinking Water	20	pCi/L	2.00E-08
Air	0.9	pCi/m3	9.00E-13

3/25/2011	San Onofre	I-131	9.0E-13 to 1E-12 uCi/cc
3/25/2011	San Onofre	Cs-137	1E-13 to 3E-13 uCi/cc

OFFICIAL USE ONLY

Units

uCi/ml

uCi/ml

uCi/cc

From: OST05 Hoc
Sent: Thursday, March 24, 2011 12:53 PM
To: PMT03 Hoc; Hoc, PMT12
Cc: OST05 Hoc; LIA04 Hoc
Subject: FW: Response to EPA drinking water limits question

PMT- forwarding this to PMT for response.

Thank you,
-Maria Arribas-Colon

From: Henderson, Pamela
Sent: Thursday, March 24, 2011 10:19 AM
To: OST05 Hoc
Cc: McNamara, Nancy; LIA04 Hoc; LIA03 Hoc; PMT03 Hoc; Hoc, PMT12; Tifft, Doug
Subject: RE: Response to EPA drinking water limits question

Maria,

I believe that RASCAL would utilize NRC limits?

From the EPA website.... EPA bases drinking water limits on a dose of 4 mrem/year to total body or any critical organ. For I-131 the limit is 3 pCi/liter. For Cs-137 the limit is 200 pCi/liter.

From: OST05 Hoc
Sent: Thursday, March 24, 2011 10:12 AM
To: Tifft, Doug; Henderson, Pamela
Cc: McNamara, Nancy; OST05 Hoc; LIA04 Hoc; LIA03 Hoc
Subject: RE: Response to EPA drinking water limits question

Good morning Doug,

I just verified the numbers and the units with RASCAL folks in PMT, and it was confirmed that they are correct.

If you have any additional question on this, please contact PMT at (301) 816-5499.

Thank you,
-Maria Arribas-Colon

From: Tifft, Doug
Sent: Thursday, March 24, 2011 7:59 AM
To: OST05 Hoc; LIA04 Hoc
Cc: Henderson, Pamela; McNamara, Nancy
Subject: RE: Response to EPA drinking water limits question

This doesn't sound right. I expected the units to be in pCi/L. And I'd also expect that the limits for one year olds would be lower than the limits for adults.

Would you mind double checking with your EPA contact what the EPA drinking water limit is for I-131 and Cs-137?

BBBB / 164

I've also got the question in to one of my Regional EPA contacts.

Thanks,
-Doug

From: OST05 Hoc

Sent: Wednesday, March 23, 2011 7:45 PM

To: Henderson, Pamela; Barker, Allan; Browder, Rachel; Erickson, Randy; Logaras, Haral; Maier, Bill; McNamara, Nancy; Tift, Doug; Trojanowski, Robert; Woodruff, Gena

Cc: OST05 Hoc; LIA04 Hoc; Easson, Stuart; Flannery, Cindy; Lukes, Kim; Maupin, Cardelia; Noonan, Amanda; Rautzen, William; Rivera, Alison; Ryan, Michelle; Turtill, Richard; Virgilio, Rosetta

Subject: Response to EPA drinking water limits question

Doug/ Pam,

This email is in response to your question on the EPA drinking water standards limits for Iodine-131 and Cesium-137. See below.

Iodine-131

One year old: 167 Bq/Kg

Adult: 2420 Bq/Kg

Cesium-137

One year old: 2990 Bq/Kg

Adult: 1360 Bq/Kg

Thank you,
-Maria Arribas-Colon

From: LIA07 Hoc *MSR*
Cc: LIA07 Hoc
Subject: 0430 EDT (March 25, 2011) USNRC Earthquake/Tsunami Status Update
Date: Friday, March 25, 2011 5:00:12 AM
Attachments: NRC Status Update 3.25.11--0430.pdf

HOC
Attached, please find a 0430 EDT (March 25, 2011) status update from the US Nuclear Regulatory Commission's Emergency Operations Center regarding the impacts of the earthquake/tsunami. **Please note that the NRC has moved the publication time of this document from 0600 to 0430 to better serve the needs of its team in Japan.**

Please note that this information is "Official Use Only" and is only being shared within the federal family.

Please call the Headquarters Operations Officer at 301-816-5100 with questions.

-Jim

Jim Anderson
Office of Nuclear Security and Incident Response
US Nuclear Regulatory Commission
James.anderson@nrc.gov
LIA07.HOC@nrc.gov (Operations Center)

BBBB / 165

From: LIA07 Hoc
Sent: Friday, March 25, 2011 5:00 AM
Cc: LIA07 Hoc
Subject: 0430 EDT (March 25, 2011) USNRC Earthquake/Tsunami Status Update
Attachments: NRC Status Update 3.25.11--0430.pdf

Attached, please find a 0430 EDT (March 25, 2011) status update from the US Nuclear Regulatory Commission's Emergency Operations Center regarding the impacts of the earthquake/tsunami. **Please note that the NRC has moved the publication time of this document from 0600 to 0430 to better serve the needs of its team in Japan.**

Please note that this information is "~~Official Use Only~~" and is only being shared within the federal family.

Please call the Headquarters Operations Officer at 301-816-5100 with questions.

-Jim

Jim Anderson
Office of Nuclear Security and Incident Response
US Nuclear Regulatory Commission
James.anderson@nrc.gov
LIA07.HOC@nrc.gov (Operations Center)

BBB / 166

WITH
HOC

From: LIA07 Hoc
To: Borchardt, Bill; Bradford, Anna; Cohen, Shari; Cooper, LaToya; Dyer, Jim; Flory, Shirley; Gibbs, Catina; Haney, Catherine; Hudson, Sharon; Jaczko, Gregory; Johnson, Michael; Leeds, Eric; Loyd, Susan; Pace, Patti; Schwarz, Sherry; Sheron, Brian; Speiser, Herald; Sprogeris, Patricia; Taylor, Renee; Virgilio, Martin; Walls, Lorena; Weber, Michael
Subject: Update for Go Books - 1800 EDT, March 25, 2011
Date: Friday, March 25, 2011 6:55:45 PM
Attachments: [TEPCO Press Release 152.pdf](#)
[TEPCO Press Release 162.pdf](#)
[TEPCO Press Release 161.pdf](#)
[TEPCO Press Release 160.pdf](#)
[TEPCO Press Release 159.pdf](#)
[TEPCO Press Release 158.pdf](#)
[TEPCO Press Release 157.pdf](#)
[TEPCO Press Release 156.pdf](#)
[TEPCO Press Release 155.pdf](#)
[TEPCO Press Release 154.pdf](#)
[TEPCO Press Release 153.pdf](#)
[GI-199 TP & QA 3-25-11.pdf](#)
[ET Chronology 3-25-11 1800.pdf](#)
[March 25 1500 EDT one pager \(3\).doc](#)
[USNRC Earthquake-Tsunami Update 032511 1800EDT.PDF](#)

Please find attached updated information for the "Go Books".

The updates include:


- The 1800 EDT, 03/25/11 Status Update
- The latest ET Chronology
- The latest TEPCO Press Releases (Numbers 152-162)
- NRC Talking Points (GI-199)
- "One Pager" (1500 EDT, 03/25/11)

Please let me know if you have any questions or concerns.

-Sara

Sara Mroz
Communications and Outreach
Office of Nuclear Security and Incident Response
US Nuclear Regulatory Commission
Sara.Mroz@nrc.gov
LIA07.HOC@nrc.gov (Operations Center)

BBBB / 167



Press Releases

Press Release (Mar 25, 2011)
Plant Status of Fukushima Daiichi Nuclear Power Station (as of 9:00 am March 25th)

[No update from the last release issued at 9:00 pm, March 24th]

Unit Status

- 1 · Reactor cold shutdown, stable water level, offsite power is available.
· No reactor coolant is leaked to the reactor containment vessel.
· Maintain average water temperature at 100°C in the Pressure Suppression Chamber.
- 2 · Reactor cold shutdown, stable water level, offsite power is available.
· No reactor coolant is leaked to the reactor containment vessel.
· Maintain average water temperature at 100°C in the Pressure Suppression Chamber.
- 3 · Reactor cold shutdown, stable water level, offsite power is available.
· No reactor coolant is leaked to the reactor containment vessel.
· Maintain average water temperature at 100°C in the Pressure Suppression Chamber.
- 4 · Reactor cold shutdown, stable water level, offsite power is available.
· No reactor coolant is leaked to the reactor containment vessel.
· Maintain average water temperature at 100°C in the Pressure Suppression Chamber.

Other N.A.

[Back to page top](#)



Press Releases

Press Release (Mar 25,2011) Implementation Plan of Rolling Blackouts on and after March 26, 2011

Due to the tight power supply-demand balance, TEPCO has been implementing rolling blackout since Monday, March 14. We sincerely regret causing anxiety and inconvenience to our customers and the society. We appreciate your cooperation in conserving electricity consumption.

For customers who will be subject to rolling blackouts, please be prepared for the announced blackout periods. Also, for the customers who are not subject to blackouts, we would appreciate your continuous cooperation in reducing electricity usage by turning off unnecessary lightings and electrical appliances.

We would like to inform the implementation plan of rolling blackouts on and after March 26, 2011 as follows. Since today, we will, in principle, inform each 5 sub-group divided from each existing 5 group (Group 1 to 5) on the rolling blackout plan on the following day.

Implementation plan of rolling blackout on March 26 (Sat.) and March 27 (Sun.)

On March 26, Saturday, no rolling-blackout will be implemented in any time periods based on the today's power demand, the weather forecast on March 26 and the trend of the power supply.

On March 27, Sunday, no rolling-blackout will be implemented in any time periods based on the trend of the current power supply and demand.

Implementation plan of rolling blackout on March 28 (Mon.) and April 1 (Fri.)

Please refer to the appendix for details.

- The actual blackout period for each Group is planned to be maximum about 3 hours during the relevant scheduled time period.
- Each blackout period for each Group differs every day and starting and ending time of blackout periods may slightly differ.
- Depending on the supply-demand balance of the day, planned blackouts may not be carried out. In case the electricity supply-demand balance becomes tighter than expected, we will reconsider the rolling blackout plan and inform you accordingly before we implement the revised plan.
- A blackout may occur in the adjacent areas where the planned blackouts are carried out

[Others]

- In order to prevent fires, please make sure to switch off electric appliances such as hair driers when you leaving home.
- Please carefully pay attention to the traffic at the crossings in case the traffic lights are suddenly turned off.
- As for the buildings and apartments, please be aware that equipments and facilities such as elevators, automatic doors, automatic locks, and multilevel parking lots will not function. In particular, please avoid using elevators during the scheduled blackouts.

<Reference>

- oPrediction of demand and supply on March 25

Estimated Demand	35,000 MW (18:00-19:00)
Supply Capacity	37,500 MW
- oPrediction of demand and supply on March 26

Estimated Demand	35,000 MW (18:00-19:00)
Supply Capacity	37,500 MW

- *Prediction of demand
According to the weather forecast, the temperature tomorrow on March 26 will be lower than that of today. However, tomorrow is Saturday and we assume the estimated peak demand on March 26 will be 35,000MW, lower than that on weekdays.
- *Estimated demand and supply capacity may change depending on the situation of the day.

attachment:Weekly Rolling Blackout Plan from Mar 26th (Sat) to Apr 1st (Fri)(PDF 63KB)

[Back to page top](#)

Press Releases

Press Release (Mar 25, 2011) Plant Status of Fukushima Daiichi Nuclear Power Station (as of 10:30 PM Mar 25th)

*new items are underlined

All 6 units of Fukushima Daiichi Nuclear Power Station have been shut down.

Unit 1(Shut down)

- Reactor has been shut down. However, the explosive sound and white smoke were confirmed after the big quake occurred at 3:36 pm Mar 12th. It was assumed to be hydrogen explosion.
- At approximately 2:30 am on March 23rd, seawater was started to be injected to the nuclear reactor through the feed water system.
- At approximately 10:50 am on March 24th, white fog-like steam arising from the roof part of the reactor building was observed.
- At approximately 11:30 am on March 24th, lights in the main control room was restored.
- We had been injecting sea water into the reactor, but from 3:37 pm on March 25th, we started injecting fresh water into it.

Unit 2(Shut down)

- At approximately 6:00 am on March 15th, an abnormal noise began emanating from nearby Pressure Suppression Chamber and the pressure within this chamber decreased.
- At 6:20 pm on March 21st, white smoke was confirmed arising from the top of the reactor building. As of 7:11 am on March 22nd, smoke decreased to the level to nearly non-existent.
- We have been injecting sea water into the reactor.

Unit 3(Shut down)

- Reactor has been shut down. However, the explosive sound and white smoke were confirmed at 11:01am Mar 14th. It was assumed to be hydrogen explosion.
- At 8:30am on March 16th, fog like steam was confirmed arising from the reactor building.
- At approximately 6:15 am on March 17th the pressure of the Suppression Chamber has temporarily increased. We were preparing to implement a measurement to reduce the pressure of the reactor containment vessel (partial discharge of air containing radioactive material to outside) in order to fully secure safety. However, at present, it is not a situation to take a measure immediately to discharge air containing radioactive material to outside now. We will continue to monitor the status of the pressure of the reactor containment vessel.
- At approximately 4:00 pm, March 21st, light gray smoke was confirmed arising from the floor roof of the Unit 3 building. On March 22nd, the color of smoke changed to somewhat white and it is slowly dissipating.
- At approximately 10:45 pm on March 22nd, the light in the main control room was turned on.
- At around 4:20 pm on March 23rd, our staff confirmed light black smoke belching from the Unit 3 building. At approximately 11:30 pm on March 23rd and 4:50 am on March 24th, our employee found no signs of smoke.
- We had been injecting sea water into the reactor pressure vessel, but from 6:02 pm on March 25th, we started injecting fresh water into it.

Unit 4 (outage due to regular inspection)

- Reactor has been shut down. However, at approximately 6 am on March 15th. We have confirmed the explosive sound and the sustained damage around the 5th floor rooftop area of the Nuclear Reactor Building.
- On March 15th and 16th, we respectively confirmed the outbreak of fire at the 4th floor of the northwestern part of the Nuclear Reactor Building. We immediately reported this matter to the fire department and the related authorities. TEPCO employees confirmed that each fire had already died down by itself.
- At this moment, we do not consider any reactor coolant leakage inside the reactor happened.

Unit 5 (outage due to regular inspection)

- Reactor has been shut down and the sufficient level of reactor coolant to ensure safety is maintained.
- At 5 am, March 19th, we started the Residual Heat Removal System Pump (C) in order to cool the spent fuel pool.
- At this moment, we do not consider any reactor coolant leakage inside the reactor containment vessel happened.
- At 2:30 pm, March 20th, the reactor achieved reactor cold shutdown. At around 5:24 pm on March 23rd, when we switched the temporary Residual Heat Removal System Seawater Pump, it has stopped automatically. At around 4:14 pm, March 24th, we started replaced pump and at around 4:35 pm, cooling of reactor has restarted.

Unit 6 (outage due to regular inspection)

- Reactor has been shut down and the sufficient level of reactor coolant to ensure safety is maintained.
- We are working on receiving external power supply to Units 5 and 6. We completed the repair work on the emergency diesel generator (A).
- At 10:14 pm, March 19th, we started the Residual Heat Removal System Pump (B) of Unit 6 in order to cool the spent fuel pool.
- At this moment, we do not consider any reactor coolant leakage inside the reactor containment vessel happened.
- At 7:27 pm, March 20th, the reactor achieved reactor cold shutdown.
- In relation to the two seawater side pumps of the Residual Heat Removal System, we changed the power source from temporary to permanent at 3:38 PM and 3:42PM, Mar 25 respectively. They are operating normally.

Today's work for cooling the spent fuel pools

- At :05 am, March 25th, we started injecting seawater into the spent fuel pool of Unit 4, using Fuel Pool Cooling and Filtering(clean up) system (FPC) and finished at 10:20 am. At 10:30 am, March 25th, we started injecting seawater into the spent fuel pool of Unit 2, using Fuel Pool Cooling and Filtering (clean up) system (FPC) and finished it at 0:19 pm of the same day.
- Spraying at the spent fuel pool of Unit 3 by Kawasaki City Fire Department was carried out from 1:28 pm to 4:00 pm on March 25th.
- From 7:05 PM to 10:07 PM, Mar 25, water discharge by concrete pumping vehicle to the spent fuel pool of Unit 4 was conducted.
- We are considering further spraying at other units and others subject to the conditions of spent fuel pools.

Casualty

- 2 workers of cooperative firm were injured at the occurrence of the earthquake, and were transported to the hospital on March 11th.
- Presence of 2 TEPCO employees at the site is not confirmed on March 11th.
- 1 TEPCO employee who was not able to stand by his own holding left chest with his hand, was transported to the hospital by an ambulance on March 12th.
- 4 workers were injured and transported to the hospital after explosive sound and white smoke were confirmed around the Unit 1 on March 12th.
- 1 subcontract worker at the key earthquake-proof building was unconscious and transported to the hospital by an ambulance on March 12th.
- The radiation exposure of 1 TEPCO employee, who was working inside the reactor building, exceeded 100mSv and he was transported to the hospital on March 12th.
- 2 TEPCO employees felt bad during their operation in the central control rooms of Unit 1 and 2 while wearing full masks, and were transferred to Fukushima Daini Nuclear Power Station for consultation with a medical advisor on March 13th.
- 11 workers were injured and transported to Fukushima Daini Nuclear Power Station etc. after explosive sound and white smoke were confirmed around the Unit 3. One of the workers was transported to the FUKUSHIMA Medical University Hospital on March 14th.
- At approximately 10 pm on March 22nd, 1 worker who had been working on setting up a temporary power panel in the common pool was injured and transported to Fukushima Daini Nuclear Power Station where the industrial doctor is.
- At approximately 1:30 am on March 23rd, 1 worker who had been working on transporting a temporary power panel in the common pool was injured and transported to Fukushima Daini Nuclear Power Station where the industrial doctor is.
- On March 24th, it was confirmed that 3 workers from cooperative companies who were in charge of cable laying work in the 1st floor and the underground floor of turbine building were exposed to the radiation dose of more than 170 mSv. 2 of them were confirmed that their leg skin were contaminated. Although they were decontaminated, since it there were possibility of beta ray burn injury, they were transferred to Fukushima Medical University Hospital. The third worker was also transferred to Fukushima Medical University Hospital today (March 25). The 3 workers are now been transferred to National Institute of Radiological Sciences in Chiba Prefecture.

Regarding this event, TEPCO has reported to related government ministries and agencies on measures to be taken to assure appropriate radiation dose control and radiation exposure related operations.

Before today's restoration work, we will make notification to the concerned parties and continue to take all possible measures to future management.

Others

- We measured radioactive materials (iodine etc.) inside of the nuclear power station area (outdoor) by monitoring car and confirmed that radioactive materials level is getting higher than ordinary level. As listed below, we have determined that specific incidents stipulated in article 15, clause 1 of Act on Special Measures Concerning Nuclear Emergency Preparedness (Abnormal increase in radiation dose measured at site boundary) have occurred.
- Determined at 4:17 pm Mar 12th (Around Monitoring Post 4)
- Determined at 8:56 am Mar 13th (Around Monitoring Post 4)
- Determined at 2:15 pm Mar 13th (Around Monitoring Post 4)
- Determined at 3:50 am Mar 14th (Around Monitoring Post 6)
- Determined at 4:15 am Mar 14th (Around Monitoring Post 2)
- Determined at 9:27 am Mar 14th (Around Monitoring Post 3)
- Determined at 9:37 pm Mar 14th (Around main entrance)
- Determined at 6:51 am Mar 15th (Around main entrance)
- Determined at 8:11 am Mar 15th (Around main entrance)
- Determined at 4:17 pm Mar 15th (Around main entrance)
- Determined at 11:05 pm Mar 15th (Around main entrance)
- Determined at 8:58 am Mar 19th (Around MP5)

From now on, if the measured figure fluctuates and goes above and below 500 micro Sv/h, we deem that as the continuous same event and will not regard that as a new specific incidents stipulated in article 15, clause 1 of the Act on Special Measures Concerning Nuclear Emergency Preparedness (Abnormal increase in radiation dose measured at site boundary) has occurred. In the interim, if we measure a manifestly abnormal figure and it is evident that the event is not the continuous same event, we will determine and notify.

- The national government has instructed evacuation for those local

- residents within 20km radius of the periphery and evacuation to inside for those residents from 20km to 30km radius of the periphery, because it's possible that radioactive materials are discharged.
- At approximately 10am on March 15th, we observed 400mSv/h at the inland side of the Unit 3 reactor building and 100mSv/h at the inland side of the Unit 4 reactor building.
 - At around 10:37 am March 21st, water spraying to common spent fuel pool and finished at 3:30 pm (conducted by TEPCO).
 - At around 3:37 pm, March 24th, electricity supply to common spent fuel pool has started from external power source. At around 6:05 pm, fuel pool cooling pump was started to cool the pool.
 - We found no signs of abnormal situation for the casks by visual observation during the patrol activity. A detailed inspection is under preparation.
 - At Units 5 and 6, in order to prevent hydrogen gas from accumulating within the buildings, we have made three holes on the roof of the reactor building for each unit.
 - In total 12 fire engines are lent for the water spraying to the spent fuel pools and water injection to the nuclear reactors by various regional fire departments* as well as Tokyo Fire Department. Also, instruction regarding the setting and operation of large scale decontamination system was provided by Niigata City Fire Headquarter and Hamamatsu City Fire Headquarter.
 - *: Koriyama Fire Department, Iwaki Fire Brigade Headquarters, Fire Headquarters of Sukagawa District Wide Area Fire-fighting Association, Yonezawa City Fire Headquarters, Utsunomiya City Fire Headquarters, Fire Headquarters of Alzu-Wakamatsu wide area municipal association, Saitama City Fire Bureau, and Niigata City Fire Bureau.
 - By March 22nd, Units 1 through 6 were started to be energized from the external power source.
 - We will continue to take all measures to ensure the safety and to continue monitoring the surrounding environment around the Power Station.

[Back to page top](#)



Press Releases

Press Release (Mar 25, 2011)
Plant Status of Fukushima Daiichi Nuclear Power Station (as of 4:30 PM Mar 25th)

*new items are underlined

All 6 units of Fukushima Daiichi Nuclear Power Station have been shut down.

Unit 1(Shut down)

- Reactor has been shut down. However, the explosive sound and white smoke were confirmed after the big quake occurred at 3:36 pm Mar 12th. It was assumed to be hydrogen explosion.
- At approximately 2:30 am on March 23rd, seawater was started to be injected to the nuclear reactor through the feed water system.
- At approximately 10:50 am on March 24th, white fog-like steam arising from the roof part of the reactor building was observed.
- At approximately 11:30 am on March 24th, lights in the main control room was restored.
- We had injected sea water into the reactor pressure vessel, but at 3:37 pm on March 25th, we have started to inject fresh water into it.

Unit 2(Shut down)

- At approximately 6:00 am on March 15th, an abnormal noise began emanating from nearby Pressure Suppression Chamber and the pressure within this chamber decreased.
- At 6:20 pm on March 21st, white smoke was confirmed arising from the top of the reactor building. As of 7:11 am on March 22nd, smoke decreased to the level where we can hardly confirm.
- We have been injecting sea water into the reactor pressure vessel.

Unit 3(Shut down)

- Reactor has been shut down. However, the explosive sound and white smoke were confirmed at 11:01am Mar 14th. It was assumed to be hydrogen explosion.
- At 8:30am on March 16th, fog like steam was confirmed arising from the reactor building.
- At approximately 6:15 am on March 17th the pressure of the Suppression Chamber has temporarily increased. We were preparing to implement a measurement to reduce the pressure of the reactor containment vessel (partial discharge of air containing radioactive material to outside) in order to fully secure safety. However, at present, it is not a situation to take a measure immediately to discharge air containing radioactive material to outside now. We will continue to monitor the status of the pressure of the reactor containment vessel.
- At approximately 4:00 pm, March 21st, light gray smoke was confirmed arising from the floor roof of the Unit 3 building. On March 22nd, the color of smoke changed to somewhat white and it is slowly dissipating.
- At approximately 10:45 pm on March 22nd, the light in the main control room was turned on.
- At around 4:20 pm on March 23rd, our staff confirmed light black smoke belching from the Unit 3 building. At approximately 11:30 pm on March 23rd and 4:50 am on March 24th, our employee found no signs of smoke.
- We have been injecting sea water into the reactor pressure vessel.

Unit 4 (outage due to regular inspection)

- Reactor has been shut down. However, at approximately 6 am on March 15th. We have confirmed the explosive sound and the sustained damage around the 5th floor rooftop area of the Nuclear Reactor Building.
- On March 15th and 16th, we respectively confirmed the outbreak of fire at the 4th floor of the northwestern part of the Nuclear Reactor Building. We immediately reported this matter to the fire department and the related authorities. TEPCO employees confirmed that each fire had already died down by itself.
- At this moment, we do not consider any reactor coolant leakage inside the reactor containment vessel happened.

Unit 5 (outage due to regular inspection)

- Reactor has been shut down and the sufficient level of reactor coolant to ensure safety is maintained.
- At 5 am, March 19th, we started the Residual Heat Removal System Pump (C) in order to cool the spent fuel pool.
- At this moment, we do not consider any reactor coolant leakage inside the reactor containment vessel happened.
- At 2:30 pm, March 20th, the reactor achieved reactor cold shutdown. At around 5:24 pm on March 23rd, when we switched the temporary Residual Heat Removal System Seawater Pump, it has stopped automatically. At around 4:14 pm, March 24th, we started replaced pump and at around 4:35 pm, cooling of reactor has restarted.

Unit 6 (outage due to regular inspection)

- Reactor has been shut down and the sufficient level of reactor coolant to ensure safety is maintained.

- We are working on receiving external power supply to Units 5 and 6. We completed the repair work on the emergency diesel generator (A).
- At 10:14 pm, March 19th, we started the Residual Heat Removal System Pump (B) of Unit 6 in order to cool the spent fuel pool.
- At this moment, we do not consider any reactor coolant leakage inside the reactor containment vessel happened.
- At 7:27 pm, March 20th, the reactor achieved reactor cold shutdown.

Today's work for cooling the spent fuel pools

- At 05 am, March 25th, we started injecting seawater into the fuel spent pool of Unit 4, using Fuel Pool Cooling and Filtering(clean up) system (FPC) and finished at 10:20 am. At 10:30 am, March 25th, we started injecting seawater into the spent fuel pool of Unit 2, using Fuel Pool Cooling and Filtering (clean up) system (FPC) and finished it at 0:19 pm of the same day.
- Spraying at the spent fuel pool of Unit 3 by Kawasaki City Fire Department was carried out from 1:28 pm to 4:00 pm on March 25th.
- We are considering further spraying at other units and others subject to the conditions of spent fuel pools.

Casualty

- 2 workers of cooperative firm were injured at the occurrence of the earthquake, and were transported to the hospital on March 11th.
- 4 workers were injured and transported to the hospital after explosive sound and white smoke were confirmed around the Unit 1 on March 11th.
- Presence of 2 TEPCO employees at the site is not confirmed on March 11th.
- 1 TEPCO employee who was not able to stand by his own holding left chest with his hand, was transported to the hospital by an ambulance on March 12th.
- 1 subcontract worker at the key earthquake-proof building was unconscious and transported to the hospital by an ambulance on March 12th.
- The radiation exposure of 1 TEPCO employee, who was working inside the reactor building, exceeded 100mSv and he was transported to the hospital on March 12th.
- 2 TEPCO employees felt bad during their operation in the central control rooms of Unit 1 and 2 while wearing full masks, and were transferred to Fukushima Daiichi Nuclear Power Station for consultation with a medical advisor on March 13th.
- 11 workers were injured and transported to Fukushima Daiichi Nuclear Power Station etc. after explosive sound and white smoke were confirmed around the Unit 3. One of the workers was transported to the FUKUSHIMA Medical University Hospital on March 14th.
- At approximately 10 pm on March 22nd, 1 worker who had been working on setting up a temporary power panel in the common pool was injured and transported to Fukushima Daiichi Nuclear Power Station where the industrial doctor is.
- At approximately 1 am on March 23rd, 1 worker who had been working on transporting a temporary power panel in the common pool was injured and transported to Fukushima Daiichi Nuclear Power Station where the industrial doctor is.
- On March 24th, it was confirmed that 3 workers from cooperative companies who were in charge of cable laying work in the 1st floor and the underground floor of turbine building were exposed to the radiation dose of more than 170 mSv. 2 of them were confirmed that their leg skin were contaminated. Although they were decontaminated, since it there were possibility of beta ray burn injury, they were transferred to Fukushima Medical University Hospital. The third worker was also transferred to Fukushima Medical University Hospital today (March 25). The 3 workers are now been transferred to National Institute of Radiological Sciences in Chiba Prefecture.

Regarding this event, TEPCO has reported to related government ministries and agencies on measures to be taken to assure appropriate radiation dose control and radiation exposure related operations.

Before today's restoration work, we will make notification to the concerned parties and continue to take all possible measures to future management.

Others

- We measured radioactive materials (iodine etc.) inside of the nuclear power station area (outdoor) by monitoring car and confirmed that radioactive materials level is getting higher than ordinary level. As listed below, we have determined that specific incidents stipulated in article 15, clause 1 of Act on Special Measures Concerning Nuclear Emergency Preparedness (Abnormal increase in radiation dose measured at site boundary) have occurred.
 - Determined at 4:17 pm Mar 12th (Around Monitoring Post 4)
 - Determined at 8:56 am Mar 13th (Around Monitoring Post 4)
 - Determined at 2:15 pm Mar 13th (Around Monitoring Post 4)
 - Determined at 3:50 am Mar 14th (Around Monitoring Post 6)
 - Determined at 4:15 am Mar 14th (Around Monitoring Post 2)
 - Determined at 9:27 am Mar 14th (Around Monitoring Post 3)
 - Determined at 9:37 pm Mar 14th (Around main entrance)
 - Determined at 6:51 am Mar 15th (Around main entrance)
 - Determined at 8:11 am Mar 15th (Around main entrance)
 - Determined at 4:17 pm Mar 15th (Around main entrance)
 - Determined at 11:05 pm Mar 15th (Around main entrance)
 - Determined at 8:58 am Mar 19th (Around MF5)
- From now on, if the measured figure fluctuates and goes above and below 500 micro Sv/h, we deem that as the continuous same event and will not regard that as a new specific incidents stipulated in article 15, clause 1 of the Act on Special Measures Concerning Nuclear Emergency Preparedness (Abnormal increase in radiation dose measured at site boundary) has occurred. In the interim, if we measure a manifestly abnormal figure and it is evident that the event is not the continuous same event, we will determine and notify.

- The national government has instructed evacuation for those local residents within 20km radius of the periphery and evacuation to inside for those residents from 20km to 30km radius of the periphery, because it's possible that radioactive materials are discharged.
- At approximately 10am on March 15th, we observed 400mSv/h at the inland side of the Unit 3 reactor building and 100mSv/h at the inland side of the Unit 4 reactor building.
- At around 10:37 am March 21st, water spraying to common spent fuel pool and finished at 3:30 pm (conducted by TEPCO).

- At around 3:37 pm, March 24th, electricity supply to common spent fuel pool has started from external power source. At around 6:05 pm, fuel pool cooling pump was started to cool the pool.
- We found no signs of abnormal situation for the casks by visual observation during the patrol activity. A detailed inspection is under preparation.
- At Units 5 and 6, in order to prevent hydrogen gas from accumulating within the buildings, we have made three holes on the roof of the reactor building for each unit.
- In total 12 fire engines are lent for the water spraying to the spent fuel pools and water injection to the nuclear reactors by various regional fire departments* as well as Tokyo Fire Department. Also, instruction regarding the setting and operation of large scale decontamination system was provided by Niigata City Fire Headquarter and Hamamatsu City Fire Headquarter.
- *: Koriyama Fire Department, Iwaki Fire Brigade Headquarters, Fire Headquarters of Sukagawa District Wide Area Fire-fighting Association, Yonezawa City Fire Headquarters, Utsunomiya City Fire Headquarters, Fire Headquarters of Aizu-Wakamatsu wide area municipal association, Saitama City Fire Bureau, and Niigata City Fire Bureau.
- Until March 22nd, Units 1 through 6 were started to be energized from the external power source.
- We will continue to take all measures to ensure the safety and to continue monitoring the surrounding environment around the Power Station.

[Back to page top](#)



Press Releases

Press Release (Mar 25, 2011) Plant Status of Fukushima Daini Nuclear Power Station (as of 3:00 pm March 25th)

[No update from the last release issued at 9:00 am, March 25th]

Unit Status

- 1
 - Reactor cold shutdown, stable water level, offsite power is available.
 - No reactor coolant is leaked to the reactor containment vessel.
 - Maintain average water temperature at 100°C in the Pressure Suppression Chamber.
- 2
 - Reactor cold shutdown, stable water level, offsite power is available.
 - No reactor coolant is leaked to the reactor containment vessel.
 - Maintain average water temperature at 100°C in the Pressure Suppression Chamber.
- 3
 - Reactor cold shutdown, stable water level, offsite power is available.
 - No reactor coolant is leaked to the reactor containment vessel.
 - Maintain average water temperature at 100°C in the Pressure Suppression Chamber.
- 4
 - Reactor cold shutdown, stable water level, offsite power is available.
 - No reactor coolant is leaked to the reactor containment vessel.
 - Maintain average water temperature at 100°C in the Pressure Suppression Chamber.

Other N.A.

[back to page top](#)



Press Releases

Press Release (Mar 25, 2011)

Special Measures for the electricity bills for the customers who have suffered from the Tohoku-Chihou-Taiheiyu-Oki Earthquake (2011)

We sincerely express our best wish for all the customers who have suffered from the Tohoku-Chihou-Taiheiyu-Oki Earthquake ("Earthquake").

If requested from customers who suffered from the Earthquake in the areas where the Disaster Relief Act was applied, we will offer special measures for the electricity bills for such customers (previously announce on March 15th, 16th and 18th).

Further to the additional application of Disaster Relief Act to 4 municipalities in Chiba Prefecture, we have decided to expand areas to those we apply exceptional conditions of electricity supply (Special Measures for the customers who have seriously suffered from Tohoku-Chihou-Taiheiyu-Oki Earthquake) to General Supply Provisions, based on a proviso of Section I of Article 21 of Electricity Business Act., have applied to Ministry of Economy, Trade and Industry for and have acquired an additional approval. The contents are as follows.


<Eligible Customers>

All the customers who have suffered from the Earthquake since March 11th in the areas shown below to which the Disaster Relief Act is applied in relation to the Earthquake and who applied for the special measures:
 Ibaraki Prefecture: Mito city, Hitachi city, Tsuchiura city, Ishioka city, Ryugasaki city, Shimotsuna city, Joso city, Hitachiota city, Takahagi city, Kitaibaraki city, Kasama city, Toride city, Ushiku city, Tsukuba city, Hitachinaka city, Kashima city, Itako city, Hitachiomiya city, Kasumigaura city, Sakuragawa city, Kamisu city, Namegata city, Hokota city, Tsukubamirai city, Omitama city, Ibaraki town, Oarai town, Shirosato town, Tokai village, Daigo town, Ami town, Naka city, Miho village, Kawachi village, Chikusei city, Inashiki city, Tone town
 Tochigi Prefecture: Utsunomiya city, Oyama city, Moka city, Otawara city, Yaita city, Nasukarasuyama city, Sakura city, Nasushiobara city, Mashiko town, Motegi town, Ichikai town, Haga town, Takanezawa town, Nasu town, Nakagawa town
 Chiba Prefecture: Asahi city, Katori city, Yamatake city, Tsukumo town, Chiba city (Mihama ward), Narashino city, Abiko city and Urayasu city, and other neighboring areas below.
 Ibaraki Prefecture: Bando city, Moriya city, Yachiyo town, Yuuki city, Koga city
 Tochigi Prefecture: Nikko city, Kanuma city, Shimotsuke city, Shioya town, Mibu town, Kaminokawa town, Tochigi city, Nogi town
 Chiba Prefecture: Noda city, Kashiwa city, Choshi city, Tohnosyo town, Narita city, Yachimata city, Togane city, Tomisato city, Sosa city, Sakae town, Oamishirasato town, Shibayama town, Yokoshibahikari town, Kanzaki town, Tako town, Inzai city, Chiba city (Chuo ward, Hanamigawa ward, Inage ward), Ichikawa city, Funabashi city, Yachiyo city
 Tokyo: Edogawa ward

<Special Measures>

1. Deferring the due date for 1 month
 As to the electricity bill for February 2011 (whose due date is March 11 or afterward), March 2011, and April 2011, the due date* is deferred for 1 month.
 *The due date is 30 days after the next day of meter-reading.
2. Exemption from payment for the months of no electricity use
 If you have been used no electricity since the occurrence of damage from the Earthquake, we do not charge any amount for the 6 month after the month when the damage of the Earthquake has risen.
3. Exemption from the payment for the construction
 If you have been used no electricity, terminate the contract of electricity since the occurrence of damage from the Earthquake, and applied for a new electricity contract by the end of September, 2011, basically we do not charge any amount for the construction.
4. Exemption from the payment for temporary construction
 If you applied for an contract of temporary electricity for the purpose of restore the damaged areas by the end of September, 2011, we do not charge any amount for the temporarily construction.
5. Exemption from payment of the basic fee for the broken facilities due to the Earthquake
 If customers' electricity facilities partly broke down due to the Earthquake, we do not charge basic fees for the broken facilities unless the facilities become in service, by the end of September 2011.
6. Exemption from the construction to install electricity meters etcetera

If you apply for changing the position of an electricity meter or a service wire by the end of September 2011, basically we do not charge any amount for the first part of the construction.

 [back to page top](#)

Press Releases

Press Release (Mar 25, 2011)

The improvement of implementation of rolling blackout (introduction of subdivision of each group)

TEPCO has been implementing the rolling blackout since March 14 due to the tightening power supply-demand balance caused by the Tohoku-Taiheiyou-Oki Earthquake. We sincerely regret causing anxiety and inconvenience to our customers and the society. We appreciate your cooperation in conserving electricity consumption.

As previously informed on March 22nd, we have recently divided the area subject to the rolling blackout into 5 groups and announced the schedule of blackout based on such groups. Hereafter from March 26th, we will ramify each existing group further into 5 sub groups based on prefecture.


This is to enable our customers to predict the blackout more accurately as the blackout is currently implemented within the group entirely and partially depending on the actual demand-supply balance.

This improvement is to enable our customers to figure out the areas of rolling blackout more easily, therefore the concept of the rolling blackout, the existing groups and the period of blackout will remain unchanged.

Sub groups take turn for the blackout so that the unequal treatment among customers will be avoided.

Please refer to the attachment on our website for the detailed region of the groups.

[Ramification of groups]




TEPCO plans to introduce additional measures to improve our operation such as the following example for the better announcement of blackout forecast. (actual introduction will be determined after successfully installing the group ramification.)

[forecast mark: example]

• blackout is scheduled.	• there is a possibility of blackout.	• NO blackout is scheduled

TEPCO will continue to do its utmost to secure the stable supply of electricity. We apology for the inconvenience caused and appreciate your continuous cooperation in conservation of electricity and your understanding for the rolling blackout.

attachment1:Detail of rolling blackout area for each group(PDF 46.6KB)
attachment2:Rolling blackout which segmentalizes areas(image) (PDF 69.7KB)

 [back to page top](#)



Press Releases

Press Release (Mar 25, 2011) Power Supply and Demand Outlook in This Summer and Measures

1. Supply and Demand Situation and its Outlook

Because many of our nuclear power stations and thermal power stations are severely damaged and forced to shut down due to the Tohoku-Chihou-Taiheiyō-Oki Earthquake, TEPCO has made every endeavor to ensure a stable power supply now. The power supply capacity for this summer in TEPCO is estimated at around 46.50 million kW as of this moment.

In the meantime, given the prospect for influence of the earthquake and energy-saving effect, the peak demand for this summer in TEPCO is expected to be around 55.00 million kW (daily peak at generation end), which is 5.00 million kW less than that in the same season of last year. (The estimation of the average peak demand in weekday is estimated at around 48.00 million kW.)

For this reason, since it is expected that the power supply capacity will be much less than the peak demand in this summer, TEPCO will concentrate our efforts in strengthening the capacity for power supply, and will also vigorously pursue demand-side measures for further energy saving.

<Power Supply and Demand Outlook in this summer> (Unit: million kW)

	March 24, 2011 (past record)	End of July, 2011
Demand (Daily peak at generation end)	37.29	55.00
Supply Capacity	36.50 (38.50)	46.50 (※)
Reserve Capacity	▲ 0.50 (1.50)	▲ 8.50 (※)

Figure in parenthesis includes pumped hydropower generation.

※ Power supply capacity of pumped hydropower generation varies with trend in power supply and demand, thus, TEPCO will continuously monitor and examine it.

2. Additional Power Supply Capacity (included in the supply capacity as of end of July, 2011 in the above)

- (1) Recovery from shutdown caused by the earthquake disaster [7.60 million kW]
Unit No.1 to No. 6 at Kashima Thermal Power Station, Unit No.1 at Hitachinaka Thermal Power Station, etc.
- (2) Restart of operation of thermal power generation units under long-term scheduled shutdown [0.90 million kW]
Unit No.1 to No. 4 at Yokosuka Thermal Power Station
- (3) Recovery from periodical inspection [3.70 million kW]
Unit No.1-1 at Shinagawa Thermal Power Station, Unit No.7-2 of Yokohama Thermal Power Station, etc.
- (4) Installation of gas turbine, etc. [0.40 million kW]
- (5) Others [▲2.60 million kW]
Decrease of output from existing thermal power stations in summer (due to increase of ambient temperature), etc.

TEPCO will continuously consider additional measure for further strengthening the power supply capacity.

3. Demand-Side Measures

While asking all of our customers to cooperate in energy saving, TEPCO will continue to improve power supply and demand situation, utilizing supply and demand adjustment contract.

We sincerely regret causing anxiety and inconvenience to our customers, and appreciate your continuous cooperation in conserving electricity consumption.

[Back to page top](#)



Press Releases

Press Release (Mar 25, 2011) Status of TEPCO's Facilities and its services after Tohoku-Taiheiyu-Oki Earthquake (as of 3:00PM)

Due to the Tohoku-Taiheiyu-Oki Earthquake which occurred on March 11th 2011, TEPCO's facilities including our nuclear power stations have been severely damaged. We deeply apologize for the anxiety and inconvenience caused.

Below is the status of TEPCO's major facilities.

*new items are underlined

[Nuclear Power Station]

Fukushima Daiichi Nuclear Power Station:

Units 1 to 3: shutdown due to earthquake

(Units 4 to 6: outage due to regular inspection)

* The national government has instructed to evacuate for those local residents within 20km radius of the site periphery and to remain indoors for those local residents between 20km and 30km radius of the site periphery.

*Off-site power was connected to Unit 1 to 6.

*Unit 1

The explosive sound and white smoke was confirmed near Unit 1 when the big quake occurred at 3:36pm, March 12th. We have started injection of sea water at 8:20 pm, March 12th, and then boric acid which absorbs neutron into the reactor afterwards.

At approximately 2:30 am, March 23rd, we have started the injection of sea water into the reactor from feed water system.

At approximately 10:50 on March 24th, white smoke was confirmed arising from the top of the reactor building.

At approximately 11:30 am, March 24th, lights in the main control room were restored.

*Unit 2

At 1:25 pm, March 14th, since the Reactor Core Isolation Cooling System has failed, it was determined that a specific incident stipulated in Clause 1, Article 15 of Act on Special Measures Concerning Nuclear Emergency Preparedness occurred (failure of reactor cooling function).

At 5:17 pm, March 14th, while the water level in the reactor reached the top of the fuel rod, we have restarted the water injection with the valve operation.

At approximately 6:14 am, March 15th, the abnormal sound was confirmed near the suppression chamber and the pressure inside the chamber decreased afterwards. It was determined that there is a possibility that something happened in the suppression chamber. While sea water injection to the reactor continued, TEPCO employees and workers from other companies not in charge of injection work started tentative evacuation to a safe location. Sea water injection to the reactor continued.

On March 18th, power was delivered up to substation for backup power through offsite transmission line. We completed laying cable further to unit receiving facility in the building, and at 3:46 pm, March 20th the load-side power panel of the receiving facility started to be energized.

From 3: 05 pm to 5: 20 pm on March 20th, 40 tons of seawater was injected into Unit 2 by TEPCO employees.

At 6:20 on March 21st, white smoke was confirmed arising from the top of the reactor building. As of 7:11 am on March 22nd, smoke decreased to the level where we can hardly confirm.

From around 4 pm to 5 pm on March 22nd, approximately 18 tons of sea water was injected into the spent fuel pool by TEPCO employees.

From 10:30 am on March 25th, sea water injection through Fuel Pool Cooling and Filtering System was initiated.

*Unit 3

At 6:50 am, March 14th, while water injection to the reactor was under operation, the pressure in the reactor containment vessel increased to 530 kPa. As a result, at 7:44 am, it was determined that a specific incident stipulated in article 15, clause 1 occurred (abnormal increase of the pressure of reactor containment vessel). Afterwards, the pressure

has gradually decreased (as of 9:05 am, 490 kPa).

At approximately 11:01 am, March 14th, an explosion followed by white smoke occurred near Unit 3. 4 TEPCO employees and 3 workers from other companies (all of them are conscious) have sustained injuries and they were already taken to the hospital by ambulances. As the temperature of water in the spent fuel pool rose, spraying water by helicopters with the support of the Self Defense Force was considered, however the operation on March 16th was cancelled.

At 6:15 am, March 17th, the pressure of the Suppression Chamber temporarily increased, but currently it is stable in a certain range. On March 20th, we were preparing to implement a measurement to reduce the pressure of the reactor containment vessel (partial discharge of air containing radioactive material to outside) in order to fully secure safety. However, at present, it is not a situation to take a measure immediately to discharge air containing radioactive material to outside. We will continue to monitor the status of the pressure of the reactor containment vessel. Monitoring will be continued.

In order to cool spent fuel pool, water was sprayed by helicopters on March 17th with the cooperation of Self-Defense Forces.

At approximately past 7:00 pm, March 17th, Self-Defense Forces and the police had started spraying water by water cannon trucks upon our request for the cooperation. At 8:09 pm, March 17th, they had finished the operation.

At 2:00 pm, March 18th, spraying water by fire engines was started with the cooperation of Self-Defense Forces and the United States Armed Forces. At 2:45 pm, March 18th, they had finished the operation.

At approximately 0:30 am, March 19th, spraying water was started with the cooperation of Fire Rescue Task Forces of Tokyo Fire Department started spraying water. At approximately 1:10 am, March 19th, they finished the operation. They resumed spraying water at 2:10 pm. At approximately 3:40 am, March 20th, they finished the operation.

At approximately 9:30 pm, March 20th, spraying water was started with the cooperation of Fire Rescue Task Forces of Tokyo Fire Department. At approximately 3:58 am, March 21st, they finished the operation.

At approximately 3:55 pm, March 21st, light gray smoke was confirmed arising from the southeast side of the 5th floor roof of the Unit 3 building, and the situation was reported to the fire department at approximately 4:21 pm. The parameters of reactor pressure vessel, reactor containment vessel, and monitored environmental data remained at the same level. However, employees working around Unit 3 evacuated to a safe location. It is observed the smoke has been decreasing. On March 22nd, the color of smoke changed to somewhat white and it is slowly dissipating.

At approximately 3:10 pm on March 22nd, water discharge into Unit 3 by Tokyo Fire Department's Hyper Rescue and Osaka City Fire Department was conducted and completed at approximately 4:00 PM on the same day.

At approximately 10:45 pm on March 22nd, lights in the main operation room were restored.

At 11:00 am on March 23rd, the injection of sea water to spent fuel pool was conducted, and finished approximately at 1:20 pm on the same day.

At 4:20 pm on March 23rd, light gray smoke was observed belching from Unit 3 building. The situation was reported to the fire department at 4:25 pm on March 23rd. The parameters of the reactor, the reactor containment vessel of Unit 3, and monitored figures around the site's immediate surroundings remained stable without significant change. To be safe, workers in the main control room of Unit 3 and around Unit 3 evacuated to a safe location.

At approximately 11:30 pm on March 23rd and 4:50 am on March 24th, TEPCO employees confirmed the smoke has disappeared. Accordingly, workers evacuation was lifted.

From approximately 5:35 am on March 24th, sea water injection through Fuel Pool Cooling and Filtering System was initiated and finished at approximately 4:05 pm on the same day.

*Unit 4

At approximately 6:00 am, March 15th, an explosive sound was heard and the damage in the 5th floor roof of Unit 4 reactor building was confirmed. At 9:38 am, the fire near the north-west part of 4th floor of Unit 4 reactor building was confirmed. At approximately 11:00 am, TEPCO employees confirmed that the fire was off.

At approximately 5:45 am on March 16th, a TEPCO employee discovered a fire at the northwest corner of the Nuclear Reactor Building. TEPCO immediately reported this incident to the fire department and the local government and proceeded with the extinction of fire. At approximately 6:15 am, TEPCO staff confirmed at the site that there are no signs of fire.

At approximately 8:21 am on March 20th, spraying water by fire engines was started with the cooperation of Self-Defense Forces and they finished the operation at approximately 9:40 am. At approximately 6:45 pm spraying water was started by Self-Defenses' water cannon trucks and finished at approximately 7:45 pm.

At approximately 6:30 am, March 21st, spraying water by fire engines was started with the cooperation of Self-Defense Forces and the United States Armed Forces. At approximately 8:40 am, March 21, they had finished the operation. On March 21st, cabling has been completed from temporary substation to the main power center.

From approximately 5:20 pm on March 22nd, spraying water from the concrete pumping vehicle was conducted and ended at approximately 8:30 pm on the same day.

From approximately 10:00 am on March 23rd, spraying water from the concrete pumping vehicle was conducted and ended at approximately 1:00 pm on the same day.

From approximately 2:35 pm on March 24th, spraying water by the concrete pumping vehicle was conducted and ended at approximately 5:30 pm on the same day.

From 6:05 am on March 25th, seawater injection through Fuel Pool Cooling and Filtering System was initiated and finished at approximately 10:20 am on the same day.

***Unit 5 and 6**

At 5 am on March 19th, we started the Residual Heat Removal System Pump (C) of Unit 5 in order to cool the spent fuel pool. At 10:14 pm, we started the Residual Heat Removal System Pump (B) of Unit 6 in order to cool the spent fuel pool.

Unit 5 has been in reactor cold shutdown since 2:30 pm on March 20th.
Unit 6 has been in reactor cold shutdown since 7:27 pm on March 20th.

At Units 5 and 6, in order to prevent hydrogen gas from accumulating within the buildings, we have made three holes on the roof of the reactor building for each unit.

At approximately 5:24 pm on March 23rd, the temporary Residual Heat Removal System Seawater Pump automatically stopped when its power source was switched. We plan to repair the pump while maintaining the appropriate water level and the temperature in the reactor. At around 4:14 pm, March 24th, we started replaced pump and at around 4:35 pm, cooling of reactor has restarted.

*On March 18th, regarding the spent fuel in the common spent fuel pool, we have confirmed that the water level of the pool is secured. At around 10:37 am March 21st, water spraying to common spent fuel pool and finished at 3:30 pm. At around 6:05 pm, fuel pool cooling pump was started to cool the pool.

*common spent fuel pool: a spent fuel pool for common use set in a separate building in a plant site in order to preserve spent fuel which are transferred from the spent fuel pool in each Unit building.

*On March 17th, we patrolled buildings for dry casks and found no signs of abnormal situation for the casks by visual observation. A detailed inspection is under preparation.

*dry cask: a measure to store spent fuel in a dry storage casks in storages. Fukushima Daiichi Nuclear Power Station started to utilize the measure from August 1995.

* In total 13 fire engines are lent for spraying water to the spent fuel pools and water injection to the nuclear reactors by various regional fire departments* as well as Tokyo Fire Department. Also, instruction regarding the setting and operation of large scale decontamination system was provided.

* On March 24, 2011, it was confirmed that 3 workers from cooperative companies who were in charge of cable laying work in the 1st floor and the underground floor of turbine building were exposed to the radiation dose of more than 170mSv. 2 of them were confirmed that their leg skins were contaminated. Although they were decontaminated by laundering, they were transferred to Fukushima Medical University hospital because there is possibility that they get a burn injury by beta ray. On March 25th, remaining worker was also transferred to Fukushima Medical University hospital. All 3 workers are now being transferred to National Institute of Radiological Sciences in Chiba Prefecture. We will assess radiation dose of 2 worker's leg skin by beta ray. We thoroughly instruct our employees and workers of cooperative companies to recognize APD alarm and evacuate when the alarm rings. We will explain this event, together with appropriate measures to be taken, to the government and to people concerned in order to fully secure the safety in relation to radiation dose management and operations associated with radiation exposure.

* On March 21st, 23rd and 24th, we detected cobalt, iodine, cesium and tellurium from the seawater around discharge canal of Unit 1, 2, 3 and 4.

* On March 21st, 23rd and 24th, we detected iodine, cesium and tellurium in the air collected at the site of Fukushima Daiichi Nuclear Power Station.

*We will continuously endeavor to securing safety, and monitoring of the surrounding environment.

**Fukushima Daiichi Nuclear Power Station:
Units 1 to 4: shutdown due to earthquake**

* The national government has instructed evacuation for those local residents within 10km radius of the periphery.

* In order to achieve cold shutdown, reactor cooling function was restored and cooling of reactors was conducted. As a result, all reactors achieved cold shutdown: Unit 1 at 5:00 pm, March 14th, Unit 2 at 6:00 pm, March 14th, Unit 3 at 0:15 pm, March 12th, Unit 4 at 7:15 am, March 16th.

*Since March 12th, we had been preparing measures for reducing the pressure of reactor containment vessels (partial discharge of air containing radioactive materials to outside), but on March 17th, we released such preparation in all Units.

***(Unit 1)**

As it is confirmed that the temperature of the Emergency Equipment Cooling Water System *1 has increased, at 3:20 pm, March 15th, we

stopped the Residual Heat Removal System (B) for the inspection. Subsequently, failure was detected in the power supply facility associated with the pumps of the Emergency Equipment Cooling Water System. At 4:25 pm, March 15th, after replacing the power facility, the pumps and the Residual Heat Removal System (B) have been reactivated.

*(Unit 4)

As it is confirmed that the pressure at the outlet of the pumps of the Emergency Equipment Cooling Water System*¹ has been decreased, at 8:05 pm, March 15th, we stopped the Residual Heat Removal System (B) for the inspection. Subsequently, failure was detected in the power supply facility associated with the pumps of the Emergency Equipment Cooling Water System. At 9:25 pm, March 15th, after replacing the relevant facility, the pumps and the Residual Heat Removal System (B) have been reactivated.

*1: emergency water system in which cooling water (pure water) circulates which exchanged the heat with sea water in order to cool down bearing pumps and/or heat exchangers etc.

Kashiwazaki Kariwa Nuclear Power Station:

Units 1, 5, 6, 7: normal operation
(Units 2 to 4: outage due to regular inspection)

[Thermal Power Station]

Hirono Thermal Power Station Units 2 and 4: shutdown due to earthquake
Hitachinaka Thermal Power Station Unit 1: shutdown due to earthquake
Kashima Thermal Power Station Units 2, 3, 5, 6: shutdown due to earthquake

[Hydro Power Station]

* All the stations have been restored.
(Facilities damaged by the earthquake are now properly under consideration)

[Transmission System, etc.]

All substation failed due to the earthquake have been restored.

[Blackout in TEPCO's Service Area]

All the blackouts are resolved.

[Supply and Demand Status within TEPCO's Service Area to Secure Stable Power Supply]

Backup supply from Shinshinano Conversion Station: 600MW
Backup supply from Sakuma Conversion Station: 300MW
Backup supply from Higashi Shimizu Conversion Station: 100MW
Backup supply from Hokkaido-Honshu Interconnection Facilities: 600MW

Considering the critical balance of our power supply capacity and expected power demand forward, in order to avoid unexpected blackout, TEPCO has been implementing rolling blackout (planned blackout alternates from one area to another) since Mar 14th. We will make our utmost to secure the stable power supply as early as possible. For customers who will be subject to rolling blackout, please be prepared for the announced blackout periods. Also for customers who are not subject to blackouts, TEPCO appreciates your continuous cooperation in reducing electricity usage by avoiding using unnecessary lighting and electrical equipment.

[Others]

Please do NOT touch cut-off electric wires.
In order to prevent fire, please make sure to switch off the electric appliances such as hair driers when you leave your house.
For the customer who has in-house power generation, please secure fuel for generator.

[Back to top](#)



Press Releases

Press Release (Mar 25,2011)

Detection of radioactive materials from the seawater around the discharge canal of Fukushima Daiichi Nuclear Power Station(5th release)

On March 21st 2011, radioactive materials were detected from the seawater around the discharge canal (south) of Fukushima Daiichi Nuclear Power Station which was damaged by the 2011 Tohoku-Taiheiyou-Oki Earthquake. This is the result of the sampling survey of radioactive materials in the seawater which was implemented as a part of monitoring activity of surrounding environment. We had informed the result to Nuclear and Industrial Safety Agency (NISA) and Fukushima prefecture. (previously announced)

On March 24th 2011, we had conducted re-sampling survey to examine the effect of radioactive materials in the seawater. We had informed the result to Nuclear and Industrial Safety Agency (NISA) and the government of Fukushima Prefecture, because radioactive materials were detected as shown in the attachment.

We will continue to conduct same kind of sampling survey.

attachment1:The result of the nuclide analysis of the seawater
(Around the discharge canal (south) of Fukushima Daiichi Nuclear Power Station) (PDF 34.1KB)

attachment2:The result of the nuclide analysis of the seawater
(Around the discharge canal (north) of Units 5 and 6 Fukushima Daiichi Nuclear Power Station) (PDF 34.0KB)

attachment3:The result of the nuclide analysis of the seawater
(Around the discharge canal (north) of Units 3 and 4 of Fukushima Daiichi Nuclear Power Station) (PDF 34.0KB)

attachment4:The result of the nuclide analysis of the seawater
(Around Iwasawa Coast) (PDF 33.9KB)

attachment5:Radioactivity Density of Seawater(PDF 72.6KB)

[Back to page top](#)



Press Releases

Press Release (Mar 25, 2011) Plant Status of Fukushima Daiichi Nuclear Power Station (as of 0:30 PM Mar 25th)

*new items are underlined

All 6 units of Fukushima Daiichi Nuclear Power Station have been shut down.

Unit 1 (Shut down)

- Reactor has been shut down. However, the explosive sound and white smoke were confirmed after the big quake occurred at 3:36 pm Mar 12th. It was assumed to be hydrogen explosion.
- At approximately 2:30 am on March 23rd, seawater was started to be injected to the nuclear reactor through the feed water system.
- At approximately 10:50 am on March 24th, white fog-like steam arising from the roof part of the reactor building was observed.
- At approximately 11:30 am on March 24th, lights in the main control room was restored.
- We have been injecting sea water into the reactor pressure vessel.

Unit 2 (Shut down)

- At approximately 6:00 am on March 15th, an abnormal noise began emanating from nearby Pressure Suppression Chamber and the pressure within this chamber decreased.
- At 6:20 pm on March 21st, white smoke was confirmed arising from the top of the reactor building. As of 7:11 am on March 22nd, smoke decreased to the level where we can hardly confirm.
- We have been injecting sea water into the reactor pressure vessel.

Unit 3 (Shut down)

- Reactor has been shut down. However, the explosive sound and white smoke were confirmed at 11:01am Mar 14th. It was assumed to be hydrogen explosion.
- At 8:30am on March 16th, fog like steam was confirmed arising from the reactor building.
- At approximately 6:15 am on March 17th the pressure of the Suppression Chamber has temporarily increased. We were preparing to implement a measurement to reduce the pressure of the reactor containment vessel (partial discharge of air containing radioactive material to outside) in order to fully secure safety. However, at present, it is not a situation to take a measure immediately to discharge air containing radioactive material to outside now. We will continue to monitor the status of the pressure of the reactor containment vessel.
- At approximately 4:00 pm, March 21st, light gray smoke was confirmed arising from the floor roof of the Unit 3 building. On March 22nd, the color of smoke changed to somewhat white and it is slowly dissipating.
- At approximately 10:45 pm on March 22nd, the light in the main control room was turned on.
- At around 4:20 pm on March 23rd, our staff confirmed light black smoke belching from the Unit 3 building. At approximately 11:30 pm on March 23rd and 4:50 am on March 24th, our employee found no signs of smoke.
- We have been injecting sea water into the reactor pressure vessel.

Unit 4 (outage due to regular inspection)

- Reactor has been shut down. However, at approximately 6 am on March 15th. We have confirmed the explosive sound and the sustained damage around the 5th floor rooftop area of the Nuclear Reactor Building.
- On March 15th and 16th, we respectively confirmed the outbreak of fire at the 4th floor of the northwestern part of the Nuclear Reactor Building. We immediately reported this matter to the fire department and the related authorities. TEPCO employees confirmed that each fire had already died down by itself.
- At this moment, we do not consider any reactor coolant leakage inside the reactor containment vessel happened.

Unit 5 (outage due to regular inspection)

- Reactor has been shut down and the sufficient level of reactor coolant to ensure safety is maintained.
- At 5 am, March 19th, we started the Residual Heat Removal System Pump (C) in order to cool the spent fuel pool.
- At this moment, we do not consider any reactor coolant leakage inside the reactor containment vessel happened.
- At 2:30 pm, March 20th, the reactor achieved reactor cold shutdown. At around 5:24 pm on March 23rd, when we switched the temporary Residual Heat Removal System Seawater Pump, it has stopped automatically. At around 4:14 pm, March 24th, we started replaced pump and at around 4:35 pm, cooling of reactor has restarted.

Unit 6 (outage due to regular inspection)

- Reactor has been shut down and the sufficient level of reactor coolant

- to ensure safety is maintained.
- We are working on receiving external power supply to Units 5 and 6. We completed the repair work on the emergency diesel generator (A).
- At 10:14 pm, March 19th, we started the Residual Heat Removal System Pump (B) of Unit 6 in order to cool the spent fuel pool.
- At this moment, we do not consider any reactor coolant leakage inside the reactor containment vessel happened.
- At 7:27 pm, March 20th, the reactor achieved reactor cold shutdown.

Today's work for cooling the spent fuel pools

- At approximately 6:05 am, March 25th, we started injecting seawater into the fuel spent pool of Unit 4, using Fuel Pool Cooling and Filtering (clean up) system (FPC) and finished at 10:20 am. At approximately 10:30 am, March 25th, we started injecting seawater into the fuel spent pool of Unit 2, using Fuel Pool Cooling and Filtering (clean up) system (FPC).
- We are considering further spraying at other units and others subject to the conditions of spent fuel pools.

Casualty

- 2 workers of cooperative firm were injured at the occurrence of the earthquake, and were transported to the hospital on March 11th.
- 4 workers were injured and transported to the hospital after explosive sound and white smoke were confirmed around the Unit 1 on March 11th.
- Presence of 2 TEPCO employees at the site is not confirmed on March 11th.
- 1 TEPCO employee who was not able to stand by his own holding left chest with his hand, was transported to the hospital by an ambulance on March 12th.
- 1 subcontract worker at the key earthquake-proof building was unconscious and transported to the hospital by an ambulance on March 12th.
- The radiation exposure of 1 TEPCO employee, who was working inside the reactor building, exceeded 100mSv and he was transported to the hospital on March 12th.
- 2 TEPCO employees felt bad during their operation in the central control rooms of Unit 1 and 2 while wearing full masks, and were transferred to Fukushima Daiichi Nuclear Power Station for consultation with a medical advisor on March 13th.
- 11 workers were injured and transported to Fukushima Daiichi Nuclear Power Station etc. after explosive sound and white smoke were confirmed around the Unit 3. One of the workers was transported to the FUKUSHIMA Medical University Hospital on March 14th.
- At approximately 10 pm on March 22nd, 1 worker who had been working on setting up a temporary power panel in the common pool was injured and transported to Fukushima Daiichi Nuclear Power Station where the industrial doctor is.
- At approximately 1 am on March 23rd, 1 worker who had been working on transporting a temporary power panel in the common pool was injured and transported to Fukushima Daiichi Nuclear Power Station where the industrial doctor is.
- On March 24th, it was confirmed that 3 workers from cooperative companies who were in charge of cable laying work in the 1st floor and the underground floor of turbine building were exposed to the radiation dose of more than 170 mSv. 2 of them were confirmed that their leg skin were contaminated. Although they were decontaminated, since it is judged that there is possibility of beta ray burn injury, they were transferred to Fukushima Medical University Hospital. The third person also transferred to National Institute of Radiological Sciences in Chiba Prefecture today (March 25). After medical examination at Fukushima Medical University Hospital, they will be transferred to National Institute of Radiological Sciences in Chiba Prefecture today (March 25).
- Regarding this event, Fukushima Labour Bureau gave TEPCO verbal instructions. After writing up lessons and future measures, taking comments of Fukushima Labour Bureau to heart, TEPCO will report related government ministries and agencies to make assurance doubly sure thoroughness of radiation control and exposure to radiation. Before today's restoration work, we will make notification to the concerned parties and continue to take all possible measures to future management.

Others

- We measured radioactive materials (iodine etc.) inside of the nuclear power station area (outdoor) by monitoring car and confirmed that radioactive materials level is getting higher than ordinary level. As listed below, we have determined that specific incidents stipulated in article 15, clause 1 of Act on Special Measures Concerning Nuclear Emergency Preparedness (Abnormal increase in radiation dose measured at site boundary) have occurred.
 - Determined at 4:17 pm Mar 12th (Around Monitoring Post 4)
 - Determined at 8:56 am Mar 13th (Around Monitoring Post 4)
 - Determined at 2:15 pm Mar 13th (Around Monitoring Post 4)
 - Determined at 3:50 am Mar 14th (Around Monitoring Post 6)
 - Determined at 4:15 am Mar 14th (Around Monitoring Post 2)
 - Determined at 9:27 am Mar 14th (Around Monitoring Post 3)
 - Determined at 9:37 pm Mar 14th (Around main entrance)
 - Determined at 6:51 am Mar 15th (Around main entrance)
 - Determined at 8:11 am Mar 15th (Around main entrance)
 - Determined at 4:17 pm Mar 15th (Around main entrance)
 - Determined at 11:05 pm Mar 15th (Around main entrance)
 - Determined at 8:58 am Mar 19th (Around MP5)
- From now on, if the measured figure fluctuates and goes above and below 500 micro Sv/h, we deem that as the continuous same event and will not regard that as a new specific incidents stipulated in article 15, clause 1 of the Act on Special Measures Concerning Nuclear Emergency Preparedness (Abnormal increase in radiation dose measured at site boundary) has occurred. In the interim, if we measure a manifestly abnormal figure and it is evident that the event is not the continuous same event, we will determine and notify.

- The national government has instructed evacuation for those local residents within 20km radius of the periphery and evacuation to inside for those residents from 20km to 30km radius of the periphery, because it's possible that radioactive materials are discharged.
- At approximately 10am on March 15th, we observed 400mSv/h at the inland side of the Unit 3 reactor building and 100mSv/h at the inland side of

- the Unit 4 reactor building.
- At around 10:37 am March 21st, water spraying to common spent fuel pool and finished at 3:30 pm (conducted by TEPCO).
- At around 3:37 pm, March 24th, electricity supply to common spent fuel pool has started from external power source. At around 6:05 pm, fuel pool cooling pump was started to cool the pool.
- We found no signs of abnormal situation for the casks by visual observation during the patrol activity. A detailed inspection is under preparation.
- At Units 5 and 6, in order to prevent hydrogen gas from accumulating within the buildings, we have made three holes on the roof of the reactor building for each unit.
- In total 12 fire engines are lent for the water spraying to the spent fuel pools and water injection to the nuclear reactors by various regional fire departments* as well as Tokyo Fire Department. Also, instruction regarding the setting and operation of large scale decontamination system was provided by Niigata City Fire Headquarter and Hamamatsu City Fire Headquarter.
- *: Koriyama Fire Department, Iwaki Fire Brigade Headquarters, Fire Headquarters of Sukagawa District Wide Area Fire-fighting Association, Yonezawa City Fire Headquarters, Utsunomiya City Fire Headquarters, Fire Headquarters of Aizu-Wakamatsu wide area municipal association, Saitama City Fire Bureau, and Niigata City Fire Bureau.
- Until March 22nd, Units 1 through 6 were started to be energized from the external power source.
- We will continue to take all measures to ensure the safety and to continue monitoring the surrounding environment around the Power Station.

[Back to page top](#)

GI-199 Safety Risk Assessment Background Information

Talking Points

- The NRC's GI-199 safety risk assessment was completed in August 2010. It is publically available. <http://pbadupws.nrc.gov/docs/ML1002/ML100270582.html>
- The purpose of the GI-199 safety risk assessment was to perform a conservative, screening-level assessment to determine whether additional seismic safety review was needed for nuclear plants in the Central and Eastern United States (CEUS).
- Updates to seismic data and models indicate increased seismic hazard estimates for some operating nuclear power plant sites in CEUS.
- The results of this assessment are not final estimates of plant-specific seismic risk.
- The NRC does not rank plants by seismic risk.
- The NRC continues to conclude that all plants have adequate seismic safety margin and continue to operate safely.

Q&A

1. What is GI-199?

Generic Issue 199 investigates the safety implications of updated earthquake-related data and models. These updated data and models suggest that the probability for earthquake ground shaking above the seismic design basis for some nuclear power plants in the Central and Eastern United States (CEUS) is still low, but larger than previous estimates.

2. Are the NRC reviews/analyses based on 2004 seismic data from USGS? Is there other updated earthquake information and modeling?

In 2004, preliminary results from United States Geological Survey (USGS) work indicated an increase in the probability of exceeding the Safe Shutdown Earthquake (SSE) for 29 nuclear power sites in the CEUS. The probability increases identified by USGS were primarily due to recent developments in the modeling of earthquake ground motion in the CEUS. USGS published updated data in 2008, which is what was used in the NRC's GI-199 safety risk assessment.

3. The NRC report talks about "screening reviews." What does that mean?

In December 2007, NRC completed a limited scope screening analysis, which is used by the NRC staff to decide whether an issue requires additional review. The screening compared the new seismic data with earlier seismic evaluations conducted by the NRC staff. The limited scope screening analysis concluded that seismic designs of plants in the CEUS continue to provide adequate safety margins. However, because the NRC recognized that this new seismic data could reduce available safety margins, the NRC staff conducted further analysis by performing NRC's GI-199 safety risk assessment.

4. Does the GI-199 study examine all nuclear power plants?

The GI-199 safety risk assessment is limited to all plants in the CEUS. Although plants at the Columbia, Diablo Canyon, Palo Verde, and San Onofre sites are not included in the GI-199 safety risk assessment, the NRC Information Notice on GI-199 is addressed to all operating power plants in the U.S. (as well as all independent spent fuel storage installation licensees). The NRC will also consider inclusion of operating reactors in the Western U.S. in its future generic communication information requests.

5. Does the GI-199 study consider spent fuel pools?

Spent fuel pools (SFPs) were not specifically evaluated as part of GI-199 safety risk assessment. However, based on their design characteristics, the NRC concludes that SFPs remain safe. SFPs are constructed of reinforced concrete, several feet thick, with a stainless steel liner to prevent leakage and maintain water quality. SFPs are inherently structurally-rugged and are designed to the same seismic requirements as the nuclear plant.

6. Is the NRC performing any inspections for GI-199?

The NRC is not currently performing inspections that are directly related to GI-199. However, on March 23, 2011, the NRC directed its inspectors to assess the actions taken by nuclear plant licensees in response to events at the Fukushima Daiichi nuclear station in Japan. NRC inspectors were given direction in the form of a Temporary Instruction (TI), which is one of the processes that NRC inspectors use to perform inspections following specific events. Using TI 2515/183, NRC inspectors will verify that important equipment and materials are adequate and properly staged, tested, and maintained in order to respond to a severe earthquake, flooding event, or loss of all electrical power. This inspection is an additional NRC activity. It does not replace any of the routine reviews that NRC inspectors perform daily at every nuclear power plant. Inspection activities for TI 2515/183 are expected to be completed by April 29, 2011. The results will be issued in a publically available inspection report by May 13, 2011.

7. What happens next with GI-199?

The NRC is developing a Generic Letter (GL) to request information from all nuclear plants in the CEUS, which is a total of 96 operating reactors. The GL is scheduled to be issued for public comment in the late spring 2011. In addition its internal review processes, the NRC will also present the GL to the Advisory Committee on Reactor Safeguards (ACRS) both before and after the public comment period. The GL should be issued by end of 2011, near the time when new seismic models become available. These new seismic models are being developed by NRC, DOE, and EPRI. In addition the USGS will review the model. Information requested in the GL will likely require 3 to 6 months for nuclear plant licensees to prepare. NRC's review will be on-going as information is collected. Based on NRC's review of that information, a determination will be made regarding required changes at nuclear plants.

8. What if the GI-199 is wrong and an unexpected earthquake happens?

Following the events of September 11, 2001, NRC required all nuclear plant licensees to take additional steps to protect public health and safety in the event of a large fire or explosion. If needed, these additional steps could also be used during natural phenomena such as earthquakes, tornadoes, floods, and tsunamis. In general, these additional steps are plans, procedures, and pre-staged equipment whose intent is to minimize the effects of adverse events. In accordance with NRC regulations, all nuclear power plants are required to maintain or restore cooling for the reactor core, containment building, and spent fuel pool under the circumstances associated with a large fire or explosion. These requirements include using existing or readily available equipment and personnel, having strategies for firefighting, operations to minimize fuel damage, and actions to minimize radiological release to the environment.

Date: March 25, 2011

Lee, Richard

From: Basu, Sudhamay
Sent: Friday, March 25, 2011 5:14 PM
To: Lee, Richard
Subject: Fukushima Unit 1

Richard,

Here is a tally of information from different sources.

GRS is quoting the Japanese TV station saying "presumably" 70% fuel assemblies damaged.
Japan government spokesman Edano acknowledged there may have been a core meltdown.
Japan Atomic Industrial Forum (JAIF) is saying there is core damage, but is not quoting any number.
TEPCO is silent on core damage

Sud

BBB/ 168

Lee, Richard

From: Lee, Richard
Sent: Friday, March 25, 2011 7:55 AM
To: Scott, Michael; Gibson, Kathy; Voglewede, John; Santiago, Patricia
Subject: RE: QUESTION FROM JAPAN

Mike:

Charlie Tinkler is our hydrogen expert. So is Allen Notafrensesco. I do not know who did the slide show.

Richard

From: Scott, Michael
Sent: Friday, March 25, 2011 5:44 AM
To: Gibson, Kathy; Lee, Richard; Voglewede, John; Santiago, Patricia
Subject: QUESTION FROM JAPAN

I seem to remember someone sending out a slide show on hydrogen since I've been in RES. I can't remember who our expert was, but I need to get a copy of the slide show he or she had developed on the subject. Can any of you recall?

Thanks

Mike

BBB/ 169

From: PMT09 Hoc
Sent: Friday, March 25, 2011 9:48 AM
To: PMT03 Hoc
Attachments: RE: Q about shelf-life for KI Tablets - Can you find your document summarizing shelf-life extension for KI; RE: Emailing: boardfile.htm

From: LIA05 Hoc
Sent: Friday, March 25, 2011 7:01 PM
To: Dan Feighert; Andrew Seward; Harry Sherwood; John Simpson; Michelle Ralston;
Steve Horwitz; Tim Greten; Vanessa E. Quinn
Subject: NRC Status Update 1800 25 march 2011
Attachments: NRC Status Update-3.25.11--1800.pdf

Please find the attached.

Ken Wierman Nightshift 1500-2300
FEMA REP Liaison
NRC Operations Center
(301) 816-5187

~~*****FOR OFFICIAL USE ONLY*****~~

DO NOT RELEASE OUTSIDE OF THE FEDERAL FAMILY

BBB/171

Bensi, Michelle

From: Bensi, Michelle
Sent: Friday, March 25, 2011 5:49 PM
To: Kammerer, Annie
Subject: SONGS Q&A attached
Attachments: SONGS QAs_3-25-11_MBedit.docx

See attached file.

BBBB/ 172

clm 66
Pind... l

6.5

What does the Japanese Earthquake Mean to San Onofre?

1) Could an earthquake and tsunami the size of the one in Japan happen at San Onofre?

The March 2011 Tohoku earthquake occurred on a subduction zone, which is the type of tectonic region that produces earthquakes of the largest magnitude. A subduction zone is a tectonic plate boundary where one tectonic plate is pushed under another plate. Severe tsunamis like the one experienced in Japan are only produced by earthquakes occurring at this type of plate boundary. The only subduction zone affecting the continental US is the Cascadia subduction zone, which lies off the coasts of Oregon, Washington, and the northernmost portion of California. Consequently, an earthquake and tsunami as large as the one experienced in Japan could only happen in that coastal region of the continental US.

No. This earthquake occurred on a "subduction zone", which is the type of tectonic region that produces the largest magnitudes earthquake. A subduction zone is a tectonic plate boundary where one tectonic plate is pushed under another plate. Subduction zone earthquakes are also required to produce the kind of massive tsunami seen in Japan. In the continental US, the only subduction zone is the Cascadia subduction zone which lies off the coast of far northern California, Oregon and Washington. So, a continental earthquake and tsunami as large as in Japan could only happen there.

Earthquakes occurring outside of the Cascadia subduction zone are not expected to exceed a magnitude of approximately 8.25. Earthquakes of this magnitude would only occur on the largest fault lines, such as the San Andreas fault, which is 50 miles away from San Onofre. Outside of the Cascadia subduction zone, earthquakes are not expected to exceed a magnitude of approximately 8.25; and that would only occur on the largest fault lines, such as the San Andreas fault, which is 50 miles away onshore. Furthermore, the San Andreas is an onshore fault and thus not capable of producing a tsunami.

Comment [MB1]: Edited to match DCNPP document.

2) What magnitude earthquake are currently operating US nuclear plants such as SONGS San Onofre designed to?

Structures, systems and components respond to the specific ground motion experienced during an earthquake. Ground motion intensity is a function of the magnitude of an earthquake, the distance from the fault to the site, and other geologic characteristics. Nuclear plants, and in fact all engineered structures, are designed based on ground motions, not earthquake magnitudes. Each nuclear power plant in the United States is designed for a ground motion intensity that is determined on a site-specific basis.

Each reactor is designed for a different ground motion that is determined on a site specific basis. Ground motion is a function of both the magnitude of an earthquake and the distance from the fault to the site; and it is ground motion that causes damage. So, Nuclear plants, and in fact all engineered structures, are actually designed based on ground motion levels, not earthquake magnitudes. The existing nuclear plants were designed using a "deterministic" or "scenario earthquake" approach that accounted for the largest earthquakes expected in the area around the plant. The existing nuclear plants were designed based on a "deterministic" or "scenario earthquake" basis that accounted for the largest earthquakes expected in the area around the plant. The scenario earthquake at SONGS San Onofre is a magnitude 7 approximately 5 miles from the main plant. This The scenario earthquake results in a ground motion that has a peak ground acceleration of 0.67g, that is 67% of the acceleration of gravity.

3) Could San Onofre withstand an earthquake of the magnitude of the Japanese earthquake?

~~It~~ San Onofre ~~could~~ is designed to withstand the ground shaking experienced by the Japanese nuclear plants. As discussed above, it is the ground motions, not the magnitude, that structures, systems, and components "feel" (note: the strength of ground motion is a function of the earthquake magnitude and other factors). ~~As discussed above, it is actually ground motions that structures, systems, and components "feel".~~ At this time, ~~We~~ we do not have direct recordings of ground motion at the Japanese reactors. However, we do have estimates of shaking ~~that come from~~ a ShakeMap produced by the K-NET system. The ground motion at the Japanese nuclear reactors is believed to be somewhat on the order of the 0.67g, or possibly slightly higher. Thus the ground shaking is similar to or slightly higher than that the peak ground acceleration to which San Onofre peak ground acceleration has been analyzed to. However, US nuclear plants have additional seismic margin beyond the design basis ground motion, as demonstrated by the results of the Individual Plant Examination of External Events program carried out by the NRC in the mid-90s.

It should be noted that, the Fukushima plant itself withstood the ground shaking resulting from the Tohoku earthquake. Preliminary information suggests that important safety systems performed their required function in the period between the occurrence of the earthquake and the impact of the tsunami. It appears that the emergency diesel generators successfully started once offsite power was lost following the earthquake. Therefore, the tsunami appears to have played a key role in the loss of power sources at the site (including the diesel generators), ultimately resulting in a condition known as station blackout. The station blackout has been a critical factor in the ongoing problems. ~~the Fukushima plant also withstood the earthquake. In the hour or so after the earthquake the Fukushima plant's safety systems, including the diesel generators, performed as expected and effectively shut down the reactor. The cause of the problems at the plant stemmed from the loss of emergency power that appears to be the direct result of the subsequent tsunami, which far exceeded the design-basis tsunami for the Fukushima plant.~~

Comment [MB2]: This wording was taken from the wording used in the public FAQ (that Annie has already approved, at least preliminarily). I have copied it here for consistency.

4) Is possible to have a tsunami at San Onofre that is capable of damaging the plant?

The plant grade of San Onofre Units 2 and 3 ~~plant grade~~ is elevation +30.0 feet MLLW. San Onofre has a reinforced concrete cantilevered retaining seawall and screen well perimeter wall designed to withstand the design basis earthquake, followed by the maximum predicted tsunami with coincident storm wave action. The controlling tsunami for San Onofre, occurring during simultaneous high tide and storm surge, produces a maximum runup to elevation +15.6 feet MLLW at the Unit 2 and 3 seawall. When storm waves are superimposed, the predicted maximum runup is to elevation +27 MLLW. Tsunami protection for the ~~SONGS~~ San Onofre site is provided by a reinforced concrete seawall constructed to elevation +30.0 MLLW. A tsunami larger than this is extremely unlikely.

5) Has the earthquake hazard at San Onofre been reviewed like Diablo Canyon nuclear power plant is doing? Are they planning on doing an update before relicensing?

Relicensing does not evaluate seismic hazard or other siting issues. Seismic safety is part of NRC's ongoing licensing activities. If an immediate safety concern ~~immersed~~ emerges, the issue ~~would be~~ is addressed ~~as part of NRC's response by the NRC,~~ regardless of relicensing status.

-The closest active fault to the plant is approximately five miles offshore from San Onofre, where a system of folds and faults exists called the offshore zone of deformation (OZD). The OZD includes the Newport-Inglewood-Rose Canyon fault system. The Cristianitos fault is ½ mile southeast of San Onofre, but is an inactive fault. Other faults such as the San Andreas and San Jacinto, which can generate a

larger magnitude earthquakes, are sufficiently far enough away that they would produce ground motions at San Onofre that are much less severe than earthquakes in the OZD for San Onofre.

Comment [MB3]: Larger than what?

Notwithstanding the above, the NRC is considering extending the Generic Issue 199 program to all operating reactors. (Generic Issue 199 currently focuses on plants in the central and eastern United States.) This extension would require a reassessment of hazard for San Onofre using the latest probabilistic seismic hazard assessment approaches. Based on a preliminary assessment using the source model developed by the USGS for the national seismic hazard maps, the annual probability of occurrence of a 0.67g ground motion at the San Onofre site is only slightly higher than is than the annual probability of occurrence that is recommended for new nuclear plants.

Comment [MB4]: Recommended or required?

6) How do we know that the emergency diesel generators in San Onofre will not fail to operate like in Japan?

Emergency Diesel Generators (EDGs) are installed in a seismically qualified structure and are seismic Category I equipment. Even if these EDGs did fail, plants can safely shutdown using station blackout power source law 10 CFR 50.63. In addition, in the 1980s, the NRC instituted a rule that requires nuclear power plants to further assure that a loss of both offsite and onsite emergency AC power systems (a condition known as a station blackout) would not adversely affect public health and safety. As a result of this rule all plants have (1) established station blackout coping and recovery procedures; (2) completed training for these procedures; (3) implemented modifications as necessary to cope with a station blackout; and (4) ensured a 4-16 hour coping capability. Subsequently, studies conducted by the NRC have shown that the hardware and procedures that have been implemented to meet the station blackout requirements have resulted in a significant risk reduction and have further enhanced defense in depth. In 1988 the NRC concluded that additional regulatory requirements were justified in order to provide further assurance that a loss of both offsite and onsite emergency ac power systems would not adversely affect public health and safety and the station blackout rule was enacted. Studies conducted by the NRC since this rule has been in effect confirms that the hardware and procedures that have been implemented to meet the station blackout requirements have resulted in significant risk reduction and have further enhanced defense in depth. However, we NRC plans to carefully evaluate the lessons learned from the events in Japan to determine if enhancements to the station blackout rule are warranted.

Comment [MB5]: Changed to have consistent wording with the public FAQ

7) Was there any damage to San Onofre from either the earthquake or the resulting tsunami?

There was no damage at the San Onofre nuclear plant from either the earthquake or tsunami.


8) What about emergency planning for San Onofre. Does it consider tsunami?

FEMA reviews off-site evacuation plans every 2 years during a biennial emergency preparedness exercise. During the same exercise, NRC evaluates on-site evacuation plans. Population studies are done every 10 years, and evacuation time estimates are re-evaluated at that time. FEMA reviews these evacuation plans, and will only accept the plans if there is "reasonable assurance" that the off-site facilities and infrastructure are capable of protecting public health and safety in the event of an emergency at FEMA reviews off-site evacuation plans formally every 2 years during a biennial emergency preparedness exercise. NRC evaluates on-site evacuation plans during the same exercise. Population studies are formally done every 10 years, and evacuation time estimates are re-evaluated at that time. FEMA reviews these evacuation plans, and will conclude their acceptability through a finding of "reasonable assurance" that the off-site facilities and infrastructure is capable of protecting public

Comment [MB6]: Wording revised to match DCNPP document

health and safety in the event of an emergency at San Onofre. The next such exercise is planned for April 12, 2011.

-The San Onofre emergency plan initiates the emergency response organization and results in declaration of emergency conditions via their Emergency Action Levels. The facility would then make protective action recommendations to the Governor, who would then decide on what protective actions would be ordered for the residents around San Onofre. The consideration of tsunami would be contained in the State-state and local (Citycity, Countycounty) emergency plans, which are reviewed by FEMA.



Walt
draft de m...
Bensi, Michelle

From: Bensi, Michelle
Sent: Friday, March 25, 2011 5:14 PM
To: Kammerer, Annie
Subject: Public FAQ
Attachments: Frequently asked questions related to the March 11 2011 Earthquake and Tsunami
3-24-2011.docx

For your review: Attached are the edits, comments, and additions for the public FAQ.
-Shelby

Draft - ~~OUO~~

NRC frequently asked questions related to the March 11, 2011 Japanese Earthquake and Tsunami

3-1925-11 (DRAFT) Version

Compiled by Annie Kammerer, Jon Ake, and Cliff Munson for submission to OPA and NRR. We would appreciate getting an edited word file back to assure that the public comments and the internal document are consistent.

Printed 4/26/2011 9:16 AM 3/24/2011 7:01 PM Draft - ~~OUO~~

Draft - ODO

List of Questions

1) Can an earthquake and tsunami as large as happened in Japan also happen here?	1
2) Did the Japanese underestimate the size of the maximum credible earthquake and tsunami that could affect the plants?	1
3) How high was the tsunami at the Fukushima nuclear plants?.....	11
4) Was the damage to the Japanese nuclear plants mostly from the earthquake or the tsunami?	21
5) Have any lessons for US nuclear plants been identified?	21
6) Was there any damage to US reactors from either the earthquake or the resulting tsunami?...	2
7) How many US reactors are located in active earthquake zones?.....	2
8) What level of earthquake hazard are the US reactors designed for?	2
9) What magnitude earthquake are currently operating US nuclear plants designed to?	32
10) Have events in Japan changed our perception of earthquake risk to the nuclear plants in the US?	32
11) Can significant damage to a nuclear plant like we see in Japan happen in the US due to an earthquake? Are the Japanese nuclear plants similar to US nuclear plants?	32
12) What is the likelihood of the design basis or "SSE" ground motions being exceeded over the life of a nuclear plant?.....	3
13) Which reactors are along coastal areas that could be affected by a tsunami?	43
14) What is magnitude anyway? What is the Richter Scale? What is intensity?	43
15) How do magnitude and ground motion relate to each other?.....	54
16) What is Generic Issue 199 about?	54
17) Does GI-199 provide rankings of US nuclear plants in terms of safety?	54
18) What are the current findings of GI-199?	54
19) What do you mean by "increased estimates of seismic hazards" at nuclear plant sites?.....	55
20) Does the Seismic Core Damage represent a measurement of the risk of radiation release or only the risk of core damage (not accounting for additional containment)?	65
21) Where can I get current information about Generic Issue 199?	65
22) Could an accident sequence like the one at Japan's Fukushima Daiichi nuclear plants happen in the US?	65

1) Can an earthquake and tsunami as large as happened in Japan also happen here?

This Tohoku earthquake occurred on a "subduction zone", which is the type of tectonic region that produces earthquakes of the largest magnitude. A subduction zone is a tectonic plate boundary where one tectonic plate is pushed under another plate. Severe tsunamis like the one experienced in Japan are only produced by earthquakes occurring at this type of plate boundary. Subduction zone earthquakes are also required to produce the kind of massive tsunami seen in Japan. The only subduction zone affecting the continental US is the Cascadia subduction zone, which lies off the coasts of Oregon, Washington, and the northernmost portion of California. Consequently, a continental earthquake and tsunami as large as the one experienced in Japan could only happen in that coastal region. In the continental US, the only subduction zone is the Cascadia subduction zone which lies off the coast of northern California, Oregon and Washington. So, a continental earthquake and tsunami as large as in Japan could only happen there. The only nuclear plant near the Cascadia subduction zone is the Columbia Generating Station. This plant is located a large distance from both the coast (approximately 225 miles) and the subduction zone (approximately 300 miles). Because of the distance between the plant and the Cascadia subduction zone, the strength of ground motion expected at the plant is far lower than the ground motion experienced at the Fukushima plants. The large distance between the Columbia Generating Station and the coast also precludes the possibility of a tsunami affecting the plant.), so the ground motions estimated at the plant are far lower than those seen at the Fukushima plants. This distance also precludes the possibility of a tsunami affecting the plant. Outside of the Cascadia subduction zone, earthquakes are not expected to exceed a magnitude of approximately 8, which is significantly smaller than the magnitude of the Tohoku earthquake. Magnitude is measured on a log scale and so a magnitude 9 earthquake produces about ten times stronger shaking and releases about 31 times more energy than a magnitude 8 earthquake.

2) Did the Japanese underestimate the size of the maximum credible earthquake and tsunami that could affect the plants?

The magnitude of the earthquake was somewhat greater than was expected for that the part of the subduction zone on which the [NAME] Tohoku earthquake occurred. However, the Japanese nuclear plants were recently reassessed using ground motion levels similar to those that are believed to have occurred at the sites during the [NAME] Tohoku earthquake. The ground motions against which the Japanese nuclear plants were reviewed-reassessed were expected to result from earthquakes that were of smaller magnitude, but that were much closer to the sites. The NRC does not currently have information on the maximum tsunami height that was expected at the sites.

3) How high was the tsunami at the Fukushima nuclear plants? Was it higher than was expected?

The tsunami modeling team at the National Oceanic and Atmospheric Administration's Pacific Marine Environmental Lab have estimated the wave height just offshore (at the 5 meter bathymetric line) to be approximately 8 meters in height at Fukushima Daiichi and approximately 7 meters in Fukushima Daini. This estimate is based on recordings from NOAA's Deep-ocean Assessment and Reporting of Tsunamis (DART) buoys and a high resolution numerical model developed for the tsunami warning system. # plant recordings exist they were not yet provided to the NRC. A recent estimate released by TEPCO indicates that the tsunami water at the Fukushima Daiichi site reached a height of 14 meters. The report also indicates that the design basis tsunami height was 5.7 meters and that the emergency diesel generators were located 10-13 meters above sea levels. This data was provided by TEPCO and has not been confirmed by the NRC.

Formatted: Highlight

Formatted: Highlight

Comment [MB1]: Added earthquake name and took out references to tsunami (moved those to the next question)

Comment [MB2]: Added more recent information (info verified by Annie)

Draft - ODO

4) Was the damage to the Japanese nuclear plants mostly from the earthquake or the tsunami?

Because this event happened ~~occurred~~ in Japan, it ~~is~~ will be hard for NRC staff to make the assessment necessary to understand exactly what happened at this time until comprehensive assessments can be performed. Preliminary information suggests that important safety systems performed their required function in the period between the occurrence of the earthquake and the impact of the tsunami. It appears that the emergency diesel generators successfully started once offsite power was lost. In the nuclear plants there may have been some damage from the shaking, and the earthquake caused the loss of offsite power. However, ~~Therefore~~, the tsunami appears to have played a key role in the loss of other power sources at the site (including the diesel generators), producing ultimately resulting in a condition known as station blackout, which ~~The station blackout has been~~ is a critical factor in the ongoing problems.

Comment [MB3]: Updated to reflect more recent information.

5) Have any lessons for US nuclear plants been identified?

The NRC is in the process of following and reviewing the events in real time. This will undoubtedly lead to the identification of issues that warrant further study. However, a complete understanding of lessons learned will require more information than is currently available to NRC staff.

6) Was there any damage to US reactors from either the earthquake or the resulting tsunami?

No.

7) How many US reactors are located in active earthquake zones?

Although we often think of the US as having "active" and "non-active" earthquake zones, earthquakes can actually happen almost anywhere. Seismologists typically separate the US into low, moderate, and high seismicity zones. The NRC requires that every nuclear plant be designed for site-specific ground motions that are appropriate for their ~~its~~ locations. In addition, the NRC has specified a minimum ground motion level to which nuclear plants must be designed.

8) What level of earthquake hazard are the US reactors designed for?

Each reactor is designed for a different ground motion level that is determined on a site-specific basis. The existing nuclear plants were designed ~~on~~ using a "deterministic" or "scenario earthquake" basis approach that accounted for the largest earthquakes expected in the area around the plant, without consideration of the likelihood of the earthquakes ~~considered~~ occurring. New reactors are designed using probabilistic techniques that characterize both the ground motion levels and associated uncertainty in the definition of the seismic hazard at the proposed site. These probabilistic techniques account for the ground motions that may result from all potential seismic sources in the region around the site. Technically speaking, ~~this is new nuclear plants~~ are designed for the ground motion with an annual frequency of occurrence of 1×10^{-4} /year, ~~but~~ This can be thought of as the ground motion that occurs every 10,000 years, on average. One important aspect ~~is that~~ associated with the use of probabilistic seismic hazard and other ~~and~~ risk-assessment techniques is that they account for beyond-design basis events. NRC's Generic Issue 199 (GI-199) project is using the latest state-of-the-art probabilistic techniques ~~used for new nuclear plants~~ to review the seismic safety of the existing plants. [see questions 16 to 21 for more information about GI-199]

Comment [MB4]: It seems strange to me to say "uncertainty at the proposed site." It made me ask "uncertainty in what?" I tried to add some words, that while vague, add a little more info.

9) What magnitude earthquake are currently operating US nuclear plants designed to?

Ground motion is a function of both the magnitude of an earthquake, ~~and~~ the distance from the fault to the site, and other geologic characteristics. Nuclear plants, and in fact all engineered structures, are actually designed based on ground motion levels, not earthquake magnitudes. The existing nuclear plants were designed ~~based on using~~ a "deterministic" or "scenario earthquake" ~~basis approach~~ that accounted for the largest earthquakes expected in the area around the plant. A margin is further added to the predicted ground motions to provide added robustness.

10) Have events in Japan changed our perception of earthquake risk to the nuclear plants in the US?

The NRC continues to determine that US nuclear plants are safe. ~~This~~ The events transpiring in Japan following the Tohoku earthquake does not change the NRC's perception of earthquake hazard (i.e., ground motion levels) at US nuclear plants. It is too early to tell what the lessons will be learned from this earthquake ~~are~~. The NRC will look closely at all aspects of the response of the Fukushima plants to the earthquake and tsunami to determine if any actions need to be taken in US nuclear plants and if any changes are necessary to NRC regulations.

11) Can significant damage to a nuclear plant like we see in Japan happen in the US due to an earthquake? Are the Japanese nuclear plants similar to US nuclear plants?

All US nuclear plants are built to withstand environmental hazards, including earthquakes and tsunamis. ~~Even these~~ nuclear plants that are located within areas with low and moderate seismic activity are designed for safety in the event of such a natural disasters. The NRC requires that safety significant structures, systems, and components be designed to take into account even rare and extreme seismic and tsunami events. In addition to the design of the plants, significant effort ~~goes into~~ is devoted to emergency response planning and severe accident management. This approach is called defense-in-depth.

The Japanese facilities at Fukushima are similar in design to some US facilities. However, the NRC has required modifications to ~~the US plants since they were designed and built~~. Examples of these ~~modifications, including~~ include design changes to control hydrogen and pressure in the containment. The NRC ~~has also required~~ requires plants to have additional equipment and measures in place to mitigate damage stemming from large fires and explosions resulting from a beyond-design-basis event. The measures include providing core and spent fuel pool cooling and an additional means to power other equipment on site.

In addition, in the 1980s, the NRC instituted a rule that required nuclear ~~power~~ plants to further assure that a loss of both offsite and onsite emergency AC power systems (a condition known as a station blackout) would not adversely affect public health and safety. As a result of this rule, all plants have (1) established station blackout coping and recovery procedures; (2) completed training for these procedures; (3) implemented modifications as necessary to cope with a station blackout; and (4) ensured a 4-16 hour coping capability. Subsequently, studies conducted by the NRC have shown that the hardware and procedures that have been implemented to meet the station blackout requirements have resulted in a significant risk reduction and have further enhanced defense-in-depth.

12) What is the likelihood of the design basis or "SSE" ground motions being exceeded over the life of a nuclear plant?

The ground motions that are used as seismic design bases at US nuclear plants are called the Safe Shutdown Earthquake (SSE) ground motions ~~(SSE)~~. It is important to remember that structures, systems

Comment [MB5]: Seems redundant to first sentence.

Comment [MB6]: Not past tense if the requirement is still in place.

Comment [MB7]: Added station blackout reference (at recommendation of NEI). This text is from the commission briefing document.

Comment [MB8]: Is there more than one GM design basis? The original sentence is written half plural, half singular.

and components are required to have "adequate margin," meaning that they must continue be able withstand shaking levels that are above the plant's design basis.

In the mid to late 1990s, the NRC staff reviewed the potential for ground motions beyond the design basis as part of the Individual Plant Examination of External Events (IPEEE). From this review, the staff determined that seismic designs of operating nuclear plants in the US have adequate safety margins for withstanding earthquakes. Currently, the NRC is in the process of conducting GI-199 to again assess the resistance of US nuclear plants to earthquakes. Based on NRC's preliminary analyses to date, the mean probability of ground motions exceeding the SSE over the life of the plant, for the plants in the Central and Eastern United States, is less than about 1%. Based on NRC's analyses to date, the probability of ground motions exceeding the SSE for the plants in the Central and Eastern United States is less than 2%, with values ranging from a low of 0.1% to a high of 6%.

~~It is important to remember that structures, systems and components are required to have "adequate margin," meaning that they must continue be able withstand shaking levels that are above the plant's design basis.~~

Comment [MB9]: Modified based on edits made during the construction of the commission briefing document.

13) Which reactors are along coastal areas that could be affected by a tsunami?

Many nuclear plants are located in coastal areas that could potentially be affected by a tsunami. Two nuclear plants, Diablo Canyon and San Onofre, are on the Pacific Coast, which is known to have a tsunami hazard. Two nuclear plants on the Gulf Coast, South Texas and Crystal River, could also be affected by tsunami. There are many nuclear plants on the Atlantic Coast or on rivers that may be affected by a tidal bore resulting from a tsunami. These include St. Lucie, Turkey Point, Brunswick, Oyster Creek, Millstone, Pilgrim, Seabrook, Calvert Cliffs, Salem/Hope Creek, and Surry. Tsunami on the Gulf and Atlantic Coasts occur, but are very rare. Generally the flooding anticipated from hurricane storm surge exceeds the flooding expected from a tsunami for nuclear plants on the Atlantic and Gulf Coast. Regardless, all nuclear plants are designed to withstand a tsunami.

Comment [MB10]: Do you want to say something about plants being designed to resist the hurricane? It isn't said here explicitly.

14) What is magnitude anyway? What is the Richter Scale? What is intensity?

An earthquake's magnitude is a measure of the strength of the earthquake as determined from seismographic observations. Magnitude is essentially an objective, quantitative measure of the size of an earthquake. The magnitude can be expressed in various ways based on seismographic records (e.g., Richter Local Magnitude, Surface Wave Magnitude, Body Wave Magnitude, and Moment Magnitude). Currently, the most commonly used magnitude measurement is the Moment Magnitude, Mw, which is based on the strength of the rock that ruptured, the area of the fault that ruptured, and the average amount of slip. Moment magnitude is, therefore, a direct measure of the energy released during an earthquake. Because of the logarithmic basis of the scale, each whole number increase in magnitude represents a tenfold increase in measured amplitude. ~~As an estimate of energy, each whole number step in the magnitude scale corresponds to the release of about 31 times more energy than the amount associated with the preceding whole number value.~~

Comment [MB11]: I don't know how confident I feel in this statement. I believe some plants says in their FSARs that "the plant isn't affected by tsunami" and then don't say much more. I don't know if I would classify this as "designed for tsunami" - maybe you want to clarify by saying that all plants affected by tsunami are designed to withstand them.

The Richter magnitude scale was developed in 1935 by Charles F. Richter of the California Institute of Technology and was based on the behavior of a specific seismograph that was manufactured at that time. The instruments are no longer in use and the magnitude scale is, therefore, no longer used in the technical community. However, the Richter Scale is a term that is so commonly used by the public that scientists generally just answer questions about "Richter" magnitude by substituting moment magnitude without correcting the misunderstanding. Like moment magnitude, the Richter Scale is a logarithmic scale. Each whole number increase corresponds to a tenfold increase in measured amplitude and about 31 times more energy.

Draft - ODO

The intensity of an earthquake is a qualitative assessment of the effects of the earthquake at a particular location. The intensity assigned is based on observed effects on humans, on human-built structures, and on the earth's surface at a particular location. The most commonly used scale in the US is the Modified Mercalli Intensity (MMI) scale, which has values ranging from I to XII in the order of severity. MMI of I indicates an earthquake that was not felt except by a very few, whereas MMI of XII indicates total damage of all works of construction, either partially or completely. While an earthquake has only one magnitude, intensity depends on the effects at each particular location.

15) How do magnitude and ground motion relate to each other?

The ground motion experienced at a particular location is a function of the magnitude of the earthquake, the distance from the fault to the location of interest, and other elements such as the geologic materials through which the waves pass.

16) What is Generic Issue 199 about?

GI-199 investigates the safety and risk implications of updated earthquake-related data and models on existing nuclear plants. For some nuclear plants in the Central and Eastern United States, these these updated data and models suggest that the probability for that earthquake ground motion above will exceed the seismic design basis for some nuclear plants in the Central and Eastern United States, although is while still low, is larger than previously estimates estimated.

17) Does GI-199 provide rankings of US nuclear plants in terms of safety?

The NRC does not rank nuclear plants by seismic risk. The objective of the GI-199 Safety/Risk Assessment was to perform a conservative, screening level assessment to evaluate if whether further investigations of seismic safety for operating reactors in the central and eastern US (CEUS) are warranted, consistent with NRC directives. The results of the GI-199 safety risk assessment should not be interpreted as definitive estimates of plant-specific seismic risk because some analyses were very conservative making the calculated risk higher than in reality. The nature of the information used in the analyses, (both seismic hazard data and plant level fragility information) make these estimates useful only as a screening tool.

18) What are the current findings of GI-199?

Currently operating nuclear plants in the US remain safe, with no need for immediate action. This determination is based on NRC staff reviews of updated seismic hazard information and the conclusions of the first stage of GI-199. Existing nuclear plants were designed, with considerable margin, to be able to withstand the ground motions from the "deterministic" or "scenario earthquake" that accounted for the largest earthquakes expected in the area around the plant. The results of the GI-199 assessment demonstrate that the probability of exceeding the design basis ground motion may have increased at some sites, but only by a relatively small amount. In addition, the probabilities of seismic core damage are lower than the guidelines for taking immediate action. Although there is not an immediate safety concern, the NRC is focused on assuring safety during even very rare and extreme events. Therefore, the NRC has determined that assessment of updated seismic hazards and plant performance should continue.

19) What do you mean by "increased estimates of seismic hazards" at nuclear plant sites?

Seismic hazard (earthquake hazard) represents the chance (or probability) that a specific level of ground motion could be observed or exceeded at a given location. Our estimates of seismic hazard at some Central and Eastern United States locations, have changed based on results from recent research,

Draft - ODO

indicating that earthquakes occurred more often in some locations than previously estimated. Our estimates of seismic hazard have also changed because the models used to predict the level of ground motion, ~~as caused by a specific magnitude earthquake at a certain distance from a site, changed~~ have improved. The increased estimates of seismic hazard at some locations in the Central and Eastern United States were discussed in a memorandum to the Commission, dated July 26, 2006. (The memorandum is available in the NRC Agencywide Documents Access and Management System [ADAMS] under Accession No. ML052360044).

20) Does the Seismic Core Damage Frequency represent a measurement of the risk of radiation release or only the risk of core damage (not accounting for additional containment)?

Formatted: No underline

Seismic core damage frequency is the probability of damage to the core resulting from a seismic initiating event. It does not imply either a meltdown or the loss of containment, which ~~would be~~ required ~~necessary~~ for radiological release to occur. The likelihood of radiation release is far lower than the core damage frequency.

21) Where can I get current information about Generic Issue 199?

The public NRC Generic Issues Program (GIP) website (<http://www.nrc.gov/about-nrc/regulatory/generic-issues.html>) contains program information and documents, background and historical information, generic issue status information, and links to related programs. The latest Generic Issue Management Control System quarterly report, which has regularly updated GI-199 information, is publicly available at <http://www.nrc.gov/reading-rm/doc-collections/generic-issues/quarterly/index.html>. Additionally, the US Geological Survey provides data and results that are publicly available at <http://earthquake.usgs.gov/hazards/products/conterminous/2008/>.

22) Could an accident sequence like the one at Japan's Fukushima Daiichi nuclear plants happen in the US?

It is difficult to answer this question until we have a better understanding of the precise problems and conditions that faced the operators at Fukushima Daiichi. We do know, however, that Fukushima Daiichi Units 1-3 lost all offsite power and emergency diesel generators. This situation is called "station blackout." ~~US nuclear power plants are designed to cope with a station blackout event that involves a loss of offsite power and onsite emergency power.~~ The Nuclear Regulatory Commission's detailed regulations address this scenario. US nuclear power plants are designed to cope with a station blackout event that involves a loss of offsite power and onsite emergency power. In addition to design features, US nuclear plants are required to conduct a "coping" assessment, perform modifications if necessary, and develop a strategy to demonstrate to the NRC that they ~~could~~ can maintain the plant in a safe condition during a station blackout scenario. These assessments, proposed modifications to the plant, and operating procedures were reviewed and approved by the NRC. Several plants added additional AC power sources to comply with this regulation. Additional information about the NRC's station blackout rule is contained in question #11.

Comment [MB12]: Better to say can??? I don't know.

In addition, ~~US nuclear plant designs and operating practices since~~ in response to the terrorist events of September 11, 2001, the NRC issued an Interim Compensatory Measures (ICM) Order ~~are designed requiring licensees to take certain actions to mitigate severe accident scenarios such as aircraft impact, which~~ These scenarios include the complete loss of offsite power and all on-site emergency power sources.

US nuclear plant designs include consideration of seismic events and tsunamis'. It is important not to extrapolate earthquake and tsunami data from one location of the world to another when evaluating these natural hazards. These catastrophic natural events are very region- and location-specific, based on tectonic and geological fault line locations.

THE FOLLOWING QUESTIONS ARE TENTATIVE!

23) Are the spent fuel pools designed to resist earthquake shaking?


Spent fuel pools are constructed of reinforced concrete, several feet thick, with a stainless steel liner to prevent leakage and maintain water quality. Due to their configuration, spent fuel pools are inherently structurally-rugged and are designed to the same seismic requirements and ground motion levels as the nuclear plant.

24) Does the NRC have a research program that is designed to look at seismic and tsunami issues?

Insert answer here.

25) What prevents radiation from being released into the environment?

There are three barriers to prevent the release of radiation into the environment. The first barrier is a tube around the reactor fuel rod known as cladding. The second next barrier to release is the reactor vessel and associated pumps and piping. This is a closed loop system that prevents radioactive material from being released from the core. The third barrier is the containment structure. This is a steel-lined concrete structure. The containment structure prevents the release of radioactive material into the environment in the event of an accident.



Comment [MB13]: How does this info apply to the question?

Formatted: Highlight

Formatted: Heading 3

Formatted: Heading 3

Comment [MB14]: Annie to answer this question.

Comment [MB15]: Someone will need to decide if this answer should really be included in this document (or if the document should stick to seismic questions). If it is to be included, someone will need to review this answer.

Formatted: Heading 3

Formatted: Centered

From: LIA07 Hoc
Subject: 1800 EDT (March 25, 2011) USNRC Earthquake/Tsunami Status Update
Date: Friday, March 25, 2011 6:50:39 PM
Attachments: USNRC Earthquake-Tsunami Update 032511 1800EDT.pdf

HOC
Attached, please find an 1800 EDT (March 25, 2011) status update from the US Nuclear Regulatory Commission's Emergency Operations Center regarding the impacts of the earthquake/tsunami.

Please note that this information is "Official Use Only" and is only being shared within the federal family.

Please call the Headquarters Operations Officer at 301-816-5100 with questions.

-Sara

Sara K. Mroz
Communications and Outreach
Office of Nuclear Security and Incident Response
US Nuclear Regulatory Commission
Sara.Mroz@nrc.gov
LIA07.HOC@nrc.gov (Operations Center)

BBBB/ 174

From: PMT03 Hoc
Sent: Saturday, March 26, 2011 12:58 AM
To: Hinson, Charles
Subject: PMT Dose Assessor

Charlie,

We have you scheduled to work with Tony Huffert, Saturday, 3/26, from 7am-3pm. There is a slot still unfilled on Sunday, 3/27, where Tony is still scheduled by himself. I'll speak with you when you arrive this morning to see if you could work that shift also.

Thanks.

Lou

From: PMT03 Hoc
Sent: Saturday, March 26, 2011 1:23 AM
To: Costa, Arlon; Chowdhury, Prosanta
Cc: OST02 HOC; OST01 HOC
Subject: PMT Coordinator

Arlon, Prosanta,

We're almost complete on the PMT Coordinator roster for next week, but there are two slots needing filled next Saturday, April 2nd, if you're available. The slots are 7am-3pm and 3pm-11pm (and actually 11pm-7am Sunday which I will take if it remains unfilled). If each of you can fill one of these slots, that would be great. Please respond by copying OST01 and OST02, to be placed on the roster.

Hope to see you then.

Thanks.

Lou

Lee, Richard

From: Lee, Richard
Sent: Friday, March 25, 2011 3:48 PM
To: 'powess@crossnet.org'
Subject: FW: Garwin comments of Science Group call of 03/24. To Binkley list of 03/24.
Attachments: ATT00001..gif

Another one.

From: Sheron, Brian
Sent: Friday, March 25, 2011 12:44 PM
To: Lee, Richard
Subject: FW: Garwin comments of Science Group call of 03/24. To Binkley list of 03/24.

From: Richard L Garwin [mailto:rlg2@us.ibm.com]
Sent: Friday, March 25, 2011 11:32 AM
To: Binkley, Steve
Cc: Brinkman, Bill; Hurlbut, Brandon; Sheron, Brian; Poneman, Daniel; 'harold.mcfarlane@inl.gov'; Adams, Ian; 'jholdren@ostp.eop.gov'; Kelly, John E (NE); 'john.grossenbacher@inl.gov'; Owens, Missy; 'peterson@nuc.berkeley.edu'; Lyons, Peter; 'phillip.finck@inl.gov'; 'rgarwin@ostp.eop.gov'; 'RJBudnitz@lbl.gov'; 'ronaldo.szilard@inl.gov'; SCHU; Aoki, Steven; Koonin, Steven; 'Steven_A_Fetter@ostp.eop.gov'; DAgostino, Thomas
Subject: Garwin comments of Science Group call of 03/24. To Binkley list of 03/24.

Some observations by Dick Garwin:

1. GET DATA ON VENTING AS IT HAPPENS. I believe it was John Kelly who said that if one watched Japanese TV one could hear a statement from TEPCO that they were about to vent, and there would be a TV image of the accompanying "white smoke" (steam). It would be very valuable to us all to have this information in the next report rather than "3 days later." There must be millions of Japanese people at home, glued to their TV, a few of whom could be asked/paid to send an email or IM or twitter recounting the venting statement. That way we would have redundant, timely reporting that could be provided in a section of the 12-hr SITREP or elsewhere.

2. DETAILS OF HARDENED VENT PIPE. We have heard of the "hardened vent pipe" to the plant stack. Could we have details of that, please, as well as of any filters in the stack? Bob Budnitz and I were two of the authors of the 1975 Report to the American Physical Society of the study group on light-water-reactor safety, "[http://rmp.aps.org/pdf/RMP/v47/iS1/pS1_1] as was Frank von Hippel, who just published an OpEd in the New York Times [<http://www.nytimes.com/2011/03/24/opinion/24Von-Hippel.html>]. On page S110 of the Report we find,

Similarly, in PWR accidents where the containment might fail due to melt-through by the core, rather than by overpressure, the total fission product release is assumed to be reduced greatly as a result of the filtering action of the soil (Draft WASH-1400, Appendix V).

These possible effects suggest that emphasis be placed on containment designs which ensure that, in case of containment failure, fission products would be scrubbed and/or filtered before their release. Thus, for example, a BWR containment might be designed to fail in a controlled way via pressure release valves which vented from the pressure-suppression pool or through large stabilized-bed filters. The remaining gases could then be filtered through the standby gas treatment system.

The von Hippel OpEd states, "Even before Three Mile Island, a group of nuclear engineers had proposed that filtered vents be attached to buildings around reactors, which are intended to contain the gases released from overheated fuel. If the pressure inside these containment buildings increased dangerously — as has happened repeatedly at Fukushima — the vents would release these gases after the filters greatly reduced their radioactivity. France and Germany installed such filters in their plants, but the Nuclear Regulatory Commission declined to require them. Given the influence of America's example, had the commission demanded the addition of filtered vents, they would likely have been required worldwide, including in Japan." Perhaps TEPCO has installed such filters. Does any of the Science Group know? Can we provide some expedient filters that will handle the temperature and heat load?

3. MOVING FLUIDS BY PUMPING OR VALVING AIR. We mentioned moving fluids by periodically pressurizing containments or other vessels. This requires pipe access to the fluid to be moved. A generic pump of this kind would be a tank with an inlet valve and an outlet valve, with air space above the fluid. Closing the outlet valve, opening the inlet valve and venting the air (through a filter) would allow the pump volume to be largely filled with fluid. Closing the inlet, opening the outlet and pumping air into the head space would expel the fluid. If the fluid evolves hydrogen, then nitrogen should be used for pressurizing.

4. PREPARING FOR MASSIVE REPLUMBING. In the control of the Macondo well at 5000-ft water depth, remotely operated vehicles (ROV) were essential. But so were the ingenious and powerful hydraulically powered wrenches, not much bigger than the massive bolts and nuts they were to unscrew or reinsert. Our labs, industry, and counterparts on the Japanese side should amass and test this capability, together with waterjet cutters and other tools suitable for remote operation. It might even be desirable to bore holes through concrete containment under modest internal pressure, without leaking much of the contents.

I believe that that sort of operation is routine in the oil industry-- with structures under much higher pressure. Perhaps a US-Japanese technical working group could be created for this task.

5. MITIGATING CORROSION FROM SALT. In addition to the super-important impact of massive salt accumulation on the ability to cool the reactor, there was early recognition of the corrosive effects of salt. A note from a retired Canadian engineer experienced in both nuclear power and desalination is attached. Most of this we know and are acting on, but I was ignorant of the zirconium corrosion hazard. I pass this to those in contact with our experts, for whatever new it may add.

Withhold A
()
Bensi, Michelle

From: Bensi, Michelle
Sent: Friday, March 25, 2011 2:22 PM
To: Kammerer, Annie
Subject: Diablo Q&As
Attachments: Diablo Canyon QAs_MBedit_3-25.docx

Annie,

I have attached the Diablo Canyon Q&As with edits. You will see that I have replaced big chunks of words in the Diablo doc with the exact text used in the public FAQs (based on the revisions we made yesterday). I thought it would be good to have the wording be consistent between the documents.

With regard to the SONGS doc: Some of the questions are common between the SONGS and Diablo documents. I will not edit the common questions until I get back your revisions on the Diablo questions (so that the answers will use the same wording).

I am working on the public FAQs now.

Shelby

Excerpt -

What does the Japanese Earthquake Mean to Diablo Canyon?

1) Could an earthquake and tsunami the size of the one in Japan happen at Diablo Canyon?

No. This earthquake occurred on a "subduction zone", which is the type of tectonic region that produces the largest magnitude earthquake. A subduction zone is a tectonic plate boundary where one tectonic plate is pushed under another plate. Subduction zone earthquakes are also required to produce the kind of massive tsunami seen in Japan. In the continental US, the only subduction zone is the Cascadia subduction zone which lies off the coast of far northern California, Oregon and Washington. So, a continental earthquake and tsunami as large as in Japan could only happen there.

The Tohoku earthquake occurred on a subduction zone, which is the type of tectonic region that produces earthquakes of the largest magnitude. A subduction zone is a tectonic plate boundary where one tectonic plate is pushed under another plate. Severe tsunamis like the one experienced in Japan are only produced by earthquakes occurring at this type of plate boundary. The only subduction zone affecting the continental US is the Cascadia subduction zone, which lies off the coasts of Oregon, Washington, and the northernmost portion of California. Consequently, a continental earthquake and tsunami as large as the one experienced in Japan could only happen in that coastal region!

Diablo Canyon Nuclear Power Plant is located outside of the Cascadia subduction zone. Outside of the Cascadia subduction zone, earthquakes occurring outside of the Cascadia subduction zone are not expected to exceed a magnitude of approximately 8.25, and that would only earthquakes of this magnitude would only occur on the largest fault lines, such as the San Andreas fault, which is 50 miles away from Diablo Canyon Nuclear Power Plant. Furthermore, the San Andreas is an onshore fault and thus not capable of producing a tsunami.

2) What magnitude earthquake are currently operating US nuclear plants such as Diablo Canyon designed to?

Structural damage is caused by the intensity/strength of ground motion experienced during an earthquake. Ground motion intensity is a function of the magnitude of an earthquake, the distance from the fault to the site, and other geologic characteristics. Nuclear plants, and in fact all engineered structures, are designed based on ground motion intensity levels, not earthquake magnitudes. Each reactor nuclear power plant in the United States is designed for a different ground motion intensity that is determined on a site-specific basis. Ground motion is a function of both the magnitude of an earthquake and the distance from the fault to the site; and it is ground motion that causes damage. So, Nuclear plants, and in fact all engineered structures, are actually designed based on ground motion levels, not earthquake magnitudes.

The existing nuclear plants were designed based using on a "deterministic" or "scenario earthquake" basis approach that accounted for the largest earthquakes expected in the area around the plant. The scenario earthquake at Diablo Canyon is a magnitude 7.5 on the Hosgri Fault, which is located 3 miles from the main plant. This earthquake is expected to result in a ground motion that has a peak ground acceleration of 0.75g, that is (-75% of the acceleration of gravity).

3) Could the newly discovered Shoreline Fault produce a larger "Scenario scenario Earthquake earthquake"?

Diablo Canyon Nuclear Power Plant was designed for a "scenario earthquake" occurring on the Hosgri Fault. The Shoreline Fault is smaller than the Hosgri Fault, and the maximum magnitude expected on the Shoreline Fault is smaller than the maximum magnitude expected on the Hosgri Fault. The NRC's

Comment [MB1]: Changed wording to be consistent with the public FAQ document.

Comment [MB2]: Can you make this statement a little "stronger" by saying the only fault that is capable of producing such large EQs and that is located near DCNPP is the San Andreas? If not, then this answer is incomplete and you would really need to list other large faults.

Formatted: Font: Italic

Comment [m3]: This isn't "perfectly" accurate because the actual numerical numbers may be the same for some plants (e.g. PGA=0.1g).

preliminary analyses indicate that the ground motions from the largest earthquakes expected on the ~~smaller~~ Shoreline Fault ~~do will~~ not exceed the ground motions expected from an earthquake from on the Hosgri Fault, Diablo Canyon for which the plant has already been analyzed for a large earthquake on the Hosgri Fault and been found to be safe.

NRC is currently reviewing the Final Report on the Shoreline Fault, ~~that which~~ was submitted to the NRC earlier this year. As part of the review, the NRC is performing an independent analysis of potential ground motions based the data contained in the report and other information. Much of the data on the Shoreline Fault comes from the USGS in Menlo Park.

4) Could Diablo Canyon withstand an earthquake of the magnitude of the Japanese earthquake?

~~It~~ Diablo Canyon Nuclear Power Plant could is designed to withstand the level of ground shaking experienced by the Japanese nuclear plants during the Tohoku earthquake. As discussed above, it is ~~actually the~~ ground motions, not the magnitude, that structures, systems, and components "feel" (note: the strength of ground shaking is a function of the earthquake magnitude and other factors). At this time, ~~We~~ do not have direct recordings of the ground motion at the Japanese reactors. However, we do have estimates of shaking that come from a ShakeMap produced by the the K-NET system. Based on the available information, ~~the~~ ground motion at the Japanese nuclear reactors is believed to be somewhat smaller than the 0.75g peak ground acceleration that Diablo Canyon has been analyzed ~~to~~ designed to withstand. ~~Do~~, Consequently, the NRC believes that Diablo Canyon could withstand the ground shaking experienced by the Fukushima plant.

~~In fact~~ Furthermore, the Fukushima plant also withstood the ground shaking resulting from the Tohoku earthquake. Preliminary information suggests that important safety systems performed their required function in the period between the occurrence of the earthquake and the impact of the tsunami. It appears that the emergency diesel generators successfully started once offsite power was lost. Therefore, the tsunami appears to have played a key role in the loss of power sources at the site (including the diesel generators), ultimately resulting in a condition known as station blackout. The station blackout has been a critical factor in the ongoing problems. In the hour or so after the earthquake the Fukushima plant's safety systems, including the diesel generators, performed as expected and effectively shut down the reactor. The cause of the problems at the plant stemmed from the loss of emergency power that appears to be the direct result of the subsequent tsunami, which far exceeded the design basis tsunami for the Fukushima plant.

5) Is Diablo Canyon's equipment vulnerable to tsunami?

Nuclear plants are designed to withstand provide protection against natural phenomena such as tsunami and earthquakes. Diablo Canyon's main plant is located above the flood level associated with the maximum expected tsunami. The intake structures and Auxiliary Sea Water System at Diablo canyon are designed for combination of tsunami and storm wave activity.

6) How do we know that the emergency diesel generators in Diablo Canyon and SONGS will not fail to operate like in Japan?

Emergency Diesel Generators (EDGs) are installed in a seismically qualified structure(s). In addition, in the 1980s, the NRC instituted a rule that required nuclear power plants to further assure that a loss of both offsite and onsite emergency AC power systems (a condition known as a station blackout) would not adversely affect public health and safety. As a result of this rule all plants have (1) established station blackout coping and recovery procedures; (2) completed training for these procedures; (3)

Comment [MB4]: Is this true? Was it designed for this or was it reviewed for this level? I don't like saying "could withstand" in such a certain way. There is always uncertainty when working with earthquakes b/c no single GM IM is a full descriptor of ground shaking (which of course you know! ☺).

Comment [MB5]: We have received other information about the GM intensity at the plants, however the information is in gal, and I am not familiar with that system. Please see the further table in the "useful tables" section of the seismic Q&A document.

Comment [MB6]: This wording was taken from the wording used in the public FAQ (that Annie has already approved, at least preliminarily). I have copied it here for consistency.

Comment [MB7]: What do you mean by "main plant"? This is used throughout the document. Do you mean the reactor and aux bldg?

Comment [MB8]: Do you mean to say it is above any tsunami that could affect the plant ever? That's a pretty certain statement.

implemented modifications as necessary to cope with a station blackout; and (4) ensured a 4-16 hour coping capability. Subsequently, studies conducted by the NRC have shown that the hardware and procedures that have been implemented to meet the station blackout requirements have resulted in a significant risk reduction and have further enhanced defense-in-depth.

Even if these EDGs did fail, plants can safely shutdown using station blackout power source law 10 CFR 50.63. In 1988 the NRC concluded that additional regulatory requirements were justified in order to provide further assurance that a loss of both offsite and onsite emergency ac power systems would not adversely affect public health and safety and the station blackout rule was enacted. Studies conducted by the NRC since this rule has been in effect confirms that the hardware and procedures that have been implemented to meet the station blackout requirements have resulted in significant risk reduction and have further enhanced defense in depth. However, we plan to carefully evaluate the lessons learned from the events in Japan to determine if enhancements to the station blackout rule are warranted.

7) Was there any damage to Diablo Canyon from either the earthquake or the resulting tsunami?

A small tsunami did hit the region around Diablo Canyon. There was no damage at the nuclear plant.

8) How do we know the evacuation routes in the region around Diablo Canyon are realistic?

FEMA reviews off-site evacuation plans formally every 2 years during a biennial emergency preparedness exercise. During the same exercise, NRC evaluates on-site evacuation plans during the same exercise. Population studies are formally done every 10 years, and evacuation time estimates are re-evaluated at that time. FEMA reviews these evacuation plans, and will conclude their acceptability through a finding of only accept the plans if there is "reasonable assurance" that the off-site facilities and infrastructure is are capable of protecting public health and safety in the event of an emergency at DCNPP.

Comment [MB9]: Changes to have consistent wording with the public FAQ

Lee, Richard

From: Lee, Richard
Sent: Saturday, March 26, 2011 3:28 PM
To: Aissa, Mourad; Algama, Don
Subject: FW: ANS Technical Brief: MOX Fuel & Fukushima
Attachments: ANS-Technical-Brief-MOX-Fukushima.pdf

Fyi. I think we concur with ANS position.

-----Original Message-----

From: Gibson, Kathy
Sent: Saturday, March 26, 2011 1:45 PM
To: Lee, Richard; Tinkler, Charles
Subject: Fw: ANS Technical Brief: MOX Fuel & Fukushima

I'm using you guys as the clearinghouses for all the stuff I get so you can draw whatever conclusions are appropriate based on all the relevant information coming in.

----- Original Message -----

From: Hoxie, Chris
To: Gibson, Kathy
Sent: Sat Mar 26 13:26:25 2011
Subject: FW: ANS Technical Brief: MOX Fuel & Fukushima

Do you get these? Anyway, briefly it says the fact that its MOX at Japan is not a big deal....

-----Original Message-----

From: ANS Broadcasts [<mailto:broadcasts@ans.org>]
Sent: Saturday, March 26, 2011 5:02 AM
To: Hoxie, Chris
Subject: ANS Technical Brief: MOX Fuel & Fukushima

The ANS Special Committee on Nuclear Non-Proliferation has prepared the attached Technical Brief on The Impact of Mixed Oxide Fuel Use on Accident Consequences at Fukushima Daiichi.

For additional Fukushima resources, visit the "Featured Content" box on the front page of the American Nuclear Society's website:

<http://www.ans.org/>

BBB/179

From: ET02 Hoc
Sent: Saturday, March 26, 2011 10:13 PM
To: RST01 Hoc; RST12 Hoc; RST09 Hoc
Subject: FW: <http://www.youtube.com/watch?v=5teJikIzIJU> All 4 units are steaming now

From: ET02 Hoc
Sent: Saturday, March 26, 2011 9:56 PM
To: ET02 Hoc
Subject: <http://www.youtube.com/watch?v=5teJikIzIJU>

BBB/180

Bano, Mahmooda

Released

From: Scott, Michael
Sent: Saturday, March 26, 2011 2:15 AM
To: LIA02 Hoc
Cc: LIA03 Hoc; Casto, Chuck; Monninger, John; Dorman, Dan
Subject: RE: ACTION - Decommissioning Type Information for Ops Center

I think this is more what they were looking for, rather than the licensing discussion previously sent. Please advise me when this is fully vetted and can be released to the Japanese. Thanks.

From: LIA02 Hoc
Sent: Friday, March 25, 2011 12:25 PM
To: Scott, Michael
Cc: LIA03 Hoc
Subject: FW: ACTION - Decommissioning Type Information for Ops Center

Some more information.

Steve

-----Original Message-----

From: Richards, Stuart
Sent: Wednesday, March 23, 2011 6:51 PM
To: Camper, Larry; Bowman, Gregory; Rini, Brett
Subject: FW: ACTION - Decommissioning Type Information for Ops Center

fyi - Stu

From: Rahimi, Meraj
Sent: Wednesday, March 23, 2011 5:50 PM
To: Ordaz, Vonna; Benner, Eric; ET05 Hoc; RST01 Hoc; Richards, Stuart
Cc: White, Bernard; Mohseni, Aby; Davis, Jack; Weaver, Doug; Doolittle, Elizabeth; Waters, Michael; Kinneman, John; Bailey, Marissa; Tschiltz, Michael
Subject: RE: ACTION - Decommissioning Type Information for Ops Center

Here is the proposed SFST/FCCS/HLW coordinated response:

We would not recommend early entombment considerations due to the high thermal loads and associated negative effects on entombment material properties. In fact, we believe it might not be prudent to entomb at all. We believe that Japan should consider waiting until the core or spent fuel debris can be cooled sufficiently and then removed similar to TMI. We would initially recommend pumping continuously borated water into the molten core or spent fuel pool. Longer term, if entombment is considered by Japan, it is our opinion that entombment would be less problematic (with respect to criticality issues) if the entombment is around the molten core or pool, rather than directly onto the fuel and in the primary containment vessel. We believe that heat transfer will be a significant challenge and thus it would be best if the entombment was built with low and high vents that would enable the transfer of heat through air convection. If the entombment is considered by pouring some type of material on the molten core or spent fuel pool the system reactivity and heat transfer capability is highly dependent on the material of use. We believe, the temperature in the reactor core or the dried spent fuel pool is too high for the concrete to cure. Both concrete (especially wet) and sand would be a neutron moderator and could raise criticality

BBBB / 191

concerns. Whatever is used should be carefully evaluated. Due to the unknown configuration in the core, any medium should conservatively be heavily borated. Another option maybe the use of sand with boron frits which would turn into glass when contacted with the molten core. This would immobilize the radionuclides. However, the temperature at which the sand is added must be at the point that the glass can solidified. This may require longer cooling time.

In the interim while options are considered, it might be advisable to confine the core or the pool with filtered flexible enclosure.

Meraj Rahimi

Chief of Criticality, Shielding, and Dose Assessment Branch Division of Spent Fuel Storage and Transportation Office of Nuclear Materials Safety and Safeguard U.S. Nuclear Regulatory Commission

6003 Executive Blvd., Suite 301

Rockville, MD 20852

Phone: 301-492-3338

Fax: 301-492-3348

e-mail: meraj.rahimi@nrc.gov

From: Ordaz, Vonna

Sent: Wednesday, March 23, 2011 3:21 PM

To: Benner, Eric

Cc: White, Bernard; Mohseni, Aby; Davis, Jack; Weaver, Doug; Rahimi, Meraj; Doolittle, Elizabeth; Waters, Michael; Kinneman, John; Bailey, Marissa; Tschiltz, Michael

Subject: ACTION - Decommissioning Type Information for Ops Center

Importance: High

Eric,

SFST has the lead to coordinate a response with HLW and FCSS, and respond to the Reactor Safety Team, the ET Response Coordinator, and Stu Richards in the Operations Center with a CC to Dan Dorman by 6pm.

Thanks,
Vonna

From: Ordaz, Vonna

Sent: Wednesday, March 23, 2011 3:13 PM

To: Richards, Stuart; Weaver, Doug; Mohseni, Aby; Davis, Jack

Cc: RST01 Hoc; Bowman, Gregory; Hickman, John; Lee, Richard; Rini, Brett; Case, Michael; McConnell, Keith; Watson, Bruce; Camper, Larry; Deegan, George; Waters, Michael

Subject: RE: Decommissioning Type Information

Thanks, Stu. We'll get back to you.

Vonna

From: Richards, Stuart

Sent: Wednesday, March 23, 2011 2:32 PM

To: Weaver, Doug; Mohseni, Aby; Davis, Jack

Cc: RST01 Hoc; Bowman, Gregory; Hickman, John; Lee, Richard; Rini, Brett; Case, Michael;

McConnell, Keith; Watson, Bruce; Camper, Larry; Deegan, George; Ordaz, Vonna; Waters, Michael

Subject: RE: Decommissioning Type Information

Importance: High

Dan Dorman has asked the Ops Center to respond to a number of questions related to the Japanese event.

Can NMSS respond to the following?

8. What should they be considering with respect to criticality prevention and decay heat removal during the entombment period?

The goal is to provide the response to the Ops Center by 6 pm tonight.

I will forward you the original request, which may help.

Thanks
Stu

From: Deegan, George
Sent: Wednesday, March 23, 2011 2:05 PM
To: Richards, Stuart; Camper, Larry
Cc: RST01 Hoc; Bowman, Gregory; Hickman, John; Lee, Richard; Rini, Brett; Case, Michael; McConnell, Keith; Watson, Bruce
Subject: RE: Decommissioning Type Information

Stu- As your email came in, Brett Rini and I were speaking with one another. I indicated that FSME will be working on #7 (licensing requirements) and #9 (whatever relevant info we can pull together from the TMI event), but that the best shop for criticality type issues (Question #8) is probably NMSS.

From: Richards, Stuart
Sent: Wednesday, March 23, 2011 1:51 PM
To: Camper, Larry
Cc: Deegan, George; RST01 Hoc; Bowman, Gregory; Hickman, John; Lee, Richard; Rini, Brett; Case, Michael
Subject: RE: Decommissioning Type Information

Larry

RES might be able to help you with Question #8. Richard Lee in DSA is our POC on this one.

We can provide you some thoughts on enclosures, but I agree that a good answer will take a lot of time and a lot more information on the status of the units.

Stu

From: Camper, Larry
Sent: Wednesday, March 23, 2011 12:49 PM
To: Dorman, Dan
Cc: Deegan, George; RST01 Hoc; Bowman, Gregory; Hickman, John
Subject: Decommissioning Type Information

Dan,
Greetings! Trust you are holding up well over there! Regarding your message of earlier today, we will be able to provide feedback on Question number 6 today by the 18:00 timeframe. Questions 6,8 and 9 will require a bit of review and interface with RES but we will start that process today. Standby for a better timeline on those. The staff did some work on the entombment issue via a couple of SECY's but the approach died out because it became clear that industry was not going to utilize it in the US. Of course, the situation in Japan is quite different etc. Regardless, our earlier work should be of some benefit but we just have

to resurrect it and review etc. In thinking ahead just a bit, I suspect that we will need to put together some sort of Task Force or think tank type group to analyze possible paths forward for the overall decommissioning of the site and for the related waste management etc. Of course, we have some time to think about this issue but not too long etc.

From: OST01 HOC
Sent: Saturday, March 26, 2011 12:32 PM
To: PMT02 Hoc; PMT11 Hoc; Hoc, PMT12; PMT01 Hoc
Subject: FW: Skin Dose Coefficients per Tony Huffert's Request
Attachments: SkinDose_WaterImmersion.xls; DecayChains.TXT

Importance: High

From: HOO Hoc
Sent: Saturday, March 26, 2011 12:29 PM
To: LIA07 Hoc; OST01 HOC; OST02 HOC; OST03 HOC
Subject: FW: Skin Dose Coefficients per Tony Huffert's Request
Importance: High

From: Eckerman, Keith F. [mailto:eckermankf@ornl.gov]
Sent: Saturday, March 26, 2011 12:26 PM
To: HOO Hoc
Subject: Re: Skin Dose Coefficients per Tony Huffert's Request
Importance: High

Attached are the skin and effective (ICRP 60 wTs) dose rate coefficients for water immersion; i.e., swimming. See the Excel file SkinDose_WaterImmersion.XLS. Please note:

1. The values reflect no consideration of protective clothing.
2. The values are for the individual radioisotope with no consideration of their decay chain. That is the Sr-90 value does not include Y-90, Cs-137 values does not include Ba-137m, etc.

Also attached is a file (DecayChains.TXT) listing of the decay chains. That file can be opened via MS Notebook or any ASCII editor.

The values are based on the nuclear decay data of ICRP 107 and the computational methods of Federal Guidance Report 12 & 13.

Keith F. Eckerman, Ph.D.
Dosimetry Research Team
P.O. Box 2008 MS6495
Oak Ridge National Laboratory
Oak Ridge, TN 37871-6495

Phone: (865) 574-6251
FAX: (865) 574-3266
E-mail: eckermankf@ornl.gov
Web site: <http://ordose.ornl.gov/>

BBBB / 182

Decay Chains of the ICRP-07 Collection

Ne-24

----- Daughter					
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4		Nuclide			
1 Ne-24	3.38m	1.000E+00	Na-24		
2 Na-24	14.9590h	1.000E+00	Mg-24\$		

Mg-28

----- Daughter					
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4		Nuclide			
1 Mg-28	20.915h	1.000E+00	Al-28		
2 Al-28	2.2414m	1.000E+00	Si-28\$		

Si-32

----- Daughter					
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4		Nuclide			
1 Si-32	132y	1.000E+00	P-32		
2 P-32	14.263d	1.000E+00	S-32\$		

S-38

----- Daughter					
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4		Nuclide			
1 S-38	170.3m	1.000E+00	Cl-38		
2 Cl-38	37.24m	1.000E+00	Ar-38\$		

Cl-34m

----- Daughter					
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4		Nuclide			
1 Cl-34m	32.00m	4.460E-01	Cl-34	5.540E-01	S-34\$
2 Cl-34	1.5264s	1.000E+00	S-34\$		

Cl-39

----- Daughter					
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4		Nuclide			
1 Cl-39	55.6m	1.000E+00	Ar-39		
2 Ar-39	269y	1.000E+00	K-39\$		

Ar-42

----- Daughter					
----------------	--	--	--	--	--

Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Ar-42 32.9y 1.000E+00 K-42
 2 K-42 12.360h 1.000E+00 Ca-42\$

Ar-43

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Ar-43 5.37m 1.000E+00 K-43
 2 K-43 22.3h 1.000E+00 Ca-43\$

Ar-44

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Ar-44 11.87m 1.000E+00 K-44
 2 K-44 22.13m 1.000E+00 Ca-44\$

K-45

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 K-45 17.3m 1.000E+00 Ca-45
 2 Ca-45 162.67d 1.000E+00 Sc-45\$

Ca-47

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Ca-47 4.536d 1.000E+00 Sc-47
 2 Sc-47 3.3492d 1.000E+00 Ti-47\$

Ca-49

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Ca-49 8.718m 1.000E+00 Sc-49
 2 Sc-49 57.2m 1.000E+00 Ti-49\$

Sc-44m

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Sc-44m 58.61h 9.880E-01 Sc-44 1.200E-02 Ca-44\$

2. Sc-44	3.97h	1.000E+00	Ca-44\$			
Ti-44				----- Daughter		
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Ti-44	60.0y	1.000E+00	Sc-44			
2 Sc-44	3.97h	1.000E+00	Ca-44\$			
Ti-52				----- Daughter		
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Ti-52	1.7m	1.000E+00	V-52			
2 V-52	3.743m	1.000E+00	Cr-52\$			
Cr-48				----- Daughter		
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Cr-48	21.56h	1.000E+00	V-48			
2 V-48	15.9735d	1.000E+00	Ti-48\$			
Cr-49				----- Daughter		
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Cr-49	42.3m	1.000E+00	V-49			
2 V-49	330d	1.000E+00	Ti-49\$			
Cr-56				----- Daughter		
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Cr-56	5.94m	1.000E+00	Mn-56			
2 Mn-56	2.5789h	1.000E+00	Fe-56\$			
Mn-51				----- Daughter		
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Mn-51	46.2m	1.000E+00	Cr-51			
2 Cr-51	27.7025d	1.000E+00	V-51\$			
Mn-52m				----- Daughter		

Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Mn-52m 21.1m 1.750E-02 Mn-52 9.825E-01 Cr-52\$
 2 Mn-52 5.591d 1.000E+00 Cr-52\$

Fe-52

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Fe-52 8.275h 1.000E+00 Mn-52m
 2 Mn-52m 21.1m 1.750E-02 Mn-52 9.825E-01 Cr-52\$
 3 Mn-52 5.591d 1.000E+00 Cr-52\$

Fe-53

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Fe-53 8.51m 1.000E+00 Mn-53
 2 Mn-53 3.7E+6y 1.000E+00 Cr-53\$

Fe-53m

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Fe-53m 2.526m 1.000E+00 Fe-53
 2 Fe-53 8.51m 1.000E+00 Mn-53
 3 Mn-53 3.7E+6y 1.000E+00 Cr-53\$

Fe-60

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Fe-60 1.5E+6y 1.000E+00 Co-60m
 2 Co-60m 10.467m 9.976E-01 Co-60 2.400E-03 Ni-60\$
 3 Co-60 5.2713y 1.000E+00 Ni-60\$

Fe-61

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Fe-61 5.98m 1.000E+00 Co-61
 2 Co-61 1.650h 1.000E+00 Ni-61\$

Fe-62

----- Daughter
 Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Fe-62	68s	1.000E+00	Co-62			
2 Co-62	1.50m	1.000E+00	Ni-62\$			

Co-55

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Co-55	17.53h	1.000E+00	Fe-55			
2 Fe-55	2.737y	1.000E+00	Mn-55\$			

Co-58m

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Co-58m	9.04h	1.000E+00	Co-58			
2 Co-58	70.86d	1.000E+00	Fe-58\$			

Co-60m

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Co-60m	10.467m	9.976E-01	Co-60	2.400E-03	Ni-60\$	
2 Co-60	5.2713y	1.000E+00	Ni-60\$			

Ni-56

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ni-56	6.075d	1.000E+00	Co-56			
2 Co-56	77.23d	1.000E+00	Fe-56\$			

Ni-57

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ni-57	35.60h	1.000E+00	Co-57			
2 Co-57	271.74d	1.000E+00	Fe-57\$			

Ni-66

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ni-66	54.6h	1.000E+00	Cu-66			
2 Cu-66	5.120m	1.000E+00	Zn-66\$			

Cu-57

```
----- Daughter
Products -----
  Nuclide Halflife f1 Nuclide f2 Nuclide f3
Nuclide f4 Nuclide
  1 Cu-57 0.1963s 1.000E+00 Ni-57
  2 Ni-57 35.60h 1.000E+00 Co-57
  3 Co-57 271.74d 1.000E+00 Fe-57$
```

Cu-59

```
----- Daughter
Products -----
  Nuclide Halflife f1 Nuclide f2 Nuclide f3
Nuclide f4 Nuclide
  1 Cu-59 81.5s 1.000E+00 Ni-59
  2 Ni-59 1.01E+5y 1.000E+00 Co-59$
```

Cu-69

```
----- Daughter
Products -----
  Nuclide Halflife f1 Nuclide f2 Nuclide f3
Nuclide f4 Nuclide
  1 Cu-69 2.85m 1.000E+00 Zn-69
  2 Zn-69 56.4m 1.000E+00 Ga-69$
```

Zn-60

```
----- Daughter
Products -----
  Nuclide Halflife f1 Nuclide f2 Nuclide f3
Nuclide f4 Nuclide
  1 Zn-60 2.38m 1.000E+00 Cu-60
  2 Cu-60 23.7m 1.000E+00 Ni-60$
```

Zn-61

```
----- Daughter
Products -----
  Nuclide Halflife f1 Nuclide f2 Nuclide f3
Nuclide f4 Nuclide
  1 Zn-61 89.1s 1.000E+00 Cu-61
  2 Cu-61 3.333h 1.000E+00 Ni-61$
```

Zn-62

```
----- Daughter
Products -----
  Nuclide Halflife f1 Nuclide f2 Nuclide f3
Nuclide f4 Nuclide
  1 Zn-62 9.186h 1.000E+00 Cu-62
  2 Cu-62 9.673m 1.000E+00 Ni-62$
```

Zn-69m

```
----- Daughter
```

Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Zn-69m	13.76h	9.997E-01	Zn-69	3.300E-04	Ga-69\$	
2 Zn-69	56.4m	1.000E+00	Ga-69\$			

Zn-72

----- Daughter						
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Zn-72	46.5h	1.000E+00	Ga-72			
2 Ga-72	14.10h	1.000E+00	Ge-72\$			

Ga-65

----- Daughter						
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Ga-65	15.2m	1.000E+00	Zn-65			
2 Zn-65	244.06d	1.000E+00	Cu-65\$			

Ge-66

----- Daughter						
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Ge-66	2.26h	1.000E+00	Ga-66			
2 Ga-66	9.49h	1.000E+00	Zn-66\$			

Ge-67

----- Daughter						
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Ge-67	18.9m	1.000E+00	Ga-67			
2 Ga-67	3.2612d	1.000E+00	Zn-67\$			

Ge-68

----- Daughter						
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Ge-68	270.95d	1.000E+00	Ga-68			
2 Ga-68	67.71m	1.000E+00	Zn-68\$			

Ge-77

----- Daughter						
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Ge-77	11.30h	1.000E+00	As-77			

2 As-77 38.83h 1.000E+00 Se-77\$

Ge-78

----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4			Nuclide			
1 Ge-78	88m	1.000E+00	As-78			
2 As-78	90.7m	1.000E+00	Se-78\$			

As-68

----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4			Nuclide			
1 As-68	151.6s	1.000E+00	Ge-68			
2 Ge-68	270.95d	1.000E+00	Ga-68			
3 Ga-68	67.71m	1.000E+00	Zn-68\$			

As-69

----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4			Nuclide			
1 As-69	15.23m	1.000E+00	Ge-69			
2 Ge-69	39.05h	1.000E+00	Ga-69\$			

As-71

----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4			Nuclide			
1 As-71	65.28h	1.000E+00	Ge-71			
2 Ge-71	11.43d	1.000E+00	Ga-71\$			

As-79

----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4			Nuclide			
1 As-79	9.01m	9.719E-01	Se-79m	2.812E-02	Se-79	
2 Se-79m	3.92m	9.994E-01	Se-79	5.600E-04	Br-79\$	
3 Se-79	2.95E+5y	1.000E+00	Br-79\$			

Se-70

----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4			Nuclide			
1 Se-70	41.1m	1.000E+00	As-70			
2 As-70	52.6m	1.000E+00	Ge-70\$			

Se-71

----- Daughter					
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Se-71	4.74m	1.000E+00	As-71		
2 As-71	65.28h	1.000E+00	Ge-71		
3 Ge-71	11.43d	1.000E+00	Ga-71\$		

Se-72

----- Daughter					
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Se-72	8.40d	1.000E+00	As-72		
2 As-72	26.0h	1.000E+00	Ge-72\$		

Se-73

----- Daughter					
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Se-73	7.15h	1.000E+00	As-73		
2 As-73	80.30d	1.000E+00	Ge-73\$		

Se-73m

----- Daughter					
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Se-73m	39.8m	7.260E-01	Se-73	2.740E-01	As-73
2 Se-73	7.15h	1.000E+00	As-73		
3 As-73	80.30d	1.000E+00	Ge-73\$		

Se-79m

----- Daughter					
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Se-79m	3.92m	9.994E-01	Se-79	5.600E-04	Br-79\$
2 Se-79	2.95E+5y	1.000E+00	Br-79\$		

Se-81m

----- Daughter					
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Se-81m	57.28m	9.995E-01	Se-81	5.200E-04	Br-81\$
2 Se-81	18.45m	1.000E+00	Br-81\$		

Se-83

----- Daughter

Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Se-83 22.3m 1.000E+00 Br-83
 2 Br-83 2.40h 9.984E-01 Kr-83m 1.552E-03 Kr-83\$
 3 Kr-83m 1.83h 1.000E+00 Kr-83\$

Se-83m

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Se-83m 70.1s 1.000E+00 Br-83
 2 Br-83 2.40h 9.984E-01 Kr-83m 1.552E-03 Kr-83\$
 3 Kr-83m 1.83h 1.000E+00 Kr-83\$

Se-84

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Se-84 3.1m 1.000E+00 Br-84
 2 Br-84 31.80m 1.000E+00 Kr-84\$

Br-72

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Br-72 78.6s 1.000E+00 Se-72
 2 Se-72 8.40d 1.000E+00 As-72
 3 As-72 26.0h 1.000E+00 Ge-72\$

Br-73

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Br-73 3.4m 9.988E-01 Se-73m 1.192E-03 Se-73
 2 Se-73m 39.8m 7.260E-01 Se-73 2.740E-01 As-73
 3 Se-73 7.15h 1.000E+00 As-73
 4 As-73 80.30d 1.000E+00 Ge-73\$

Br-75

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Br-75 96.7m 1.000E+00 Se-75
 2 Se-75 119.779d 1.000E+00 As-75\$

Br-76m

----- Daughter

Products	Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
	Nuclide f4						
	1 Br-76m	1.31s	9.970E-01	Br-76	3.000E-03	Se-76\$	
	2 Br-76	16.2h	1.000E+00	Se-76\$			

Br-77m

----- Daughter

Products	Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
	Nuclide f4						
	1 Br-77m	4.28m	1.000E+00	Br-77			
	2 Br-77	57.036h	1.000E+00	Se-77\$			

Br-80m

----- Daughter

Products	Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
	Nuclide f4						
	1 Br-80m	4.4205h	1.000E+00	Br-80			
	2 Br-80	17.68m	9.170E-01	Kr-80\$	8.300E-02	Se-80\$	

Br-82m

----- Daughter

Products	Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
	Nuclide f4						
	1 Br-82m	6.13m	9.760E-01	Br-82	2.400E-02	Kr-82\$	
	2 Br-82	35.30h	1.000E+00	Kr-82\$			

Br-83

----- Daughter

Products	Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
	Nuclide f4						
	1 Br-83	2.40h	9.984E-01	Kr-83m	1.552E-03	Kr-83\$	
	2 Kr-83m	1.83h	1.000E+00	Kr-83\$			

Br-85

----- Daughter

Products	Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
	Nuclide f4						
	1 Br-85	2.90m	9.978E-01	Kr-85m	2.211E-03	Kr-85	
	2 Kr-85m	4.480h	2.140E-01	Kr-85	7.860E-01	Rb-85\$	
	3 Kr-85	10.756y	1.000E+00	Rb-85\$			

Kr-74

----- Daughter

Products	Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
	Nuclide						

Nuclide	f4	Nuclide	
1 Kr-74		11.50m	1.000E+00 Br-74
2 Br-74		25.4m	1.000E+00 Se-74\$

Kr-75

-----				Daughter
Products	-----			
Nuclide	Halflife	f1	Nuclide	f2
Nuclide	f4	Nuclide		f3
1 Kr-75	4.29m	1.000E+00	Br-75	
2 Br-75	96.7m	1.000E+00	Se-75	
3 Se-75	119.779d	1.000E+00	As-75\$	

Kr-76

-----				Daughter
Products	-----			
Nuclide	Halflife	f1	Nuclide	f2
Nuclide	f4	Nuclide		f3
1 Kr-76	14.8h	8.114E-03	Br-76m	9.919E-01 Br-76
2 Br-76m	1.31s	9.970E-01	Br-76	3.000E-03 Se-76\$
3 Br-76	16.2h	1.000E+00	Se-76\$	

Kr-77

-----				Daughter
Products	-----			
Nuclide	Halflife	f1	Nuclide	f2
Nuclide	f4	Nuclide		f3
1 Kr-77	74.4m	9.613E-02	Br-77m	9.039E-01 Br-77
2 Br-77m	4.28m	1.000E+00	Br-77	
3 Br-77	57.036h	1.000E+00	Se-77\$	

Kr-81m

-----				Daughter
Products	-----			
Nuclide	Halflife	f1	Nuclide	f2
Nuclide	f4	Nuclide		f3
1 Kr-81m	13.10s	1.000E+00	Kr-81	2.500E-05 Br-81\$
2 Kr-81	2.29E+5y	1.000E+00	Br-81\$	

Kr-85m

-----				Daughter
Products	-----			
Nuclide	Halflife	f1	Nuclide	f2
Nuclide	f4	Nuclide		f3
1 Kr-85m	4.480h	2.140E-01	Kr-85	7.860E-01 Rb-85\$
2 Kr-85	10.756y	1.000E+00	Rb-85\$	

Kr-87

-----				Daughter
Products	-----			
Nuclide	Halflife	f1	Nuclide	f2
Nuclide	f4	Nuclide		f3

福島第一原子力発電所の20km以遠のモニタリング結果について

平成23年4月8日 13時00分現在
文 部 科 学 省

○文部科学省が集計した結果

- * 1 GM(ガイガーミュラー計測管)における値
- * 2 電離箱における値
- * 3 NaI(ヨウ化ナトリウム)シンチレータにおける値
- * 4 測定時間内における測定値の変動範囲

場所(福島第1発電所からの距離)	測定日時	数値(マイクロシーベルト/時) (記載のない限り屋外)	天候	実施者
測定エリア【1】 (約60km北西)	4月8日8時31分	0.8 *2	降雨なし	文部科学省
測定エリア【2】 (約55km北西)	4月8日9時10分	3.5 *2	降雨なし	日本原子力研究開発機構
測定エリア【3】 (約45km北西)	4月8日10時20分	2.8 *2	降雨なし	日本原子力研究開発機構
測定エリア【4】 (約50km北西)	4月8日9時29分	2.3 *2	降雨なし	文部科学省
測定エリア【5】 (約45km北)	4月8日11時03分	0.5 *2	降雨なし	日本原子力研究開発機構
測定エリア【6】 (約35km北)	4月8日11時25分	0.6 *2	降雨なし	日本原子力研究開発機構
測定エリア【7】 (約35km北)	4月8日11時39分	0.7 *2	降雨なし	日本原子力研究開発機構
測定エリア【10】 (約40km北西)	4月8日9時43分	1.7 *2	降雨なし	文部科学省
測定エリア【11】 (約40km北西)	4月8日9時54分	1.9 *2	降雨なし	文部科学省
測定エリア【12】 (約40km西)	4月8日10時32分	0.7 *2	降雨なし	文部科学省
測定エリア【13】 (約40km西)	4月8日10時39分	1.0 *2	降雨なし	文部科学省
測定エリア【14】 (約35km西)	4月8日10時49分	0.8 *2	降雨なし	文部科学省
測定エリア【15】 (約35km西)	4月8日10時59分	1.3 *2	降雨なし	文部科学省
測定エリア【20】 (約45km北西)	4月8日10時18分	1.3 *2	降雨なし	文部科学省
測定エリア【31】 (約30km西北西)	4月8日10時51分	9.0 *2	降雨なし	文部科学省

1 Kr-87	76.3m	1.000E+00	Rb-87
2 Rb-87	4.923E10y	1.000E+00	Sr-87\$

Kr-88

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4			Nuclide			
1 Kr-88	2.84h	1.000E+00	Rb-88			
2 Rb-88	17.78m	1.000E+00	Sr-88\$			

Kr-89

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4			Nuclide			
1 Kr-89	3.15m	1.000E+00	Rb-89			
2 Rb-89	15.15m	1.000E+00	Sr-89			
3 Sr-89	50.53d	1.000E+00	Y-89\$			

Rb-77

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4			Nuclide			
1 Rb-77	3.77m	1.000E+00	Kr-77			
2 Kr-77	74.4m	9.613E-02	Br-77m	9.039E-01	Br-77	
3 Br-77m	4.28m	1.000E+00	Br-77			
4 Br-77	57.036h	1.000E+00	Se-77\$			

Rb-78m

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4			Nuclide			
1 Rb-78m	5.74m	1.000E-01	Rb-78	9.000E-01	Kr-78\$	
2 Rb-78	17.66m	1.000E+00	Kr-78\$			

Rb-79

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4			Nuclide			
1 Rb-79	22.9m	1.000E+00	Kr-79			
2 Kr-79	35.04h	1.000E+00	Br-79\$			

Rb-81

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4			Nuclide			
1 Rb-81	4.576h	9.569E-01	Kr-81m	4.309E-02	Kr-81	

2 Kr-81m	13.10s	1.000E+00	Kr-81	2.500E-05	Br-81\$
3 Kr-81	2.29E+5y	1.000E+00	Br-81\$		

Rb-81m

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4			Nuclide			
1 Rb-81m	30.5m	9.760E-01	Rb-81	2.135E-04	Kr-81m	
2.379E-02 Kr-81						
2 Rb-81	4.576h	9.569E-01	Kr-81m	4.309E-02	Kr-81	
3 Kr-81m	13.10s	1.000E+00	Kr-81	2.500E-05	Br-81\$	
4 Kr-81	2.29E+5y	1.000E+00	Br-81\$			

Rb-83

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4			Nuclide			
1 Rb-83	86.2d	7.429E-01	Kr-83m	2.571E-01	Kr-83\$	
2 Kr-83m	1.83h	1.000E+00	Kr-83\$			

Rb-84m

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4			Nuclide			
1 Rb-84m	20.26m	1.000E+00	Rb-84			
2 Rb-84	32.77d	9.620E-01	Kr-84\$	3.800E-02	Sr-84\$	

Rb-86m

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4			Nuclide			
1 Rb-86m	1.017m	1.000E+00	Rb-86			
2 Rb-86	18.642d	1.000E+00	Sr-86\$	5.200E-05	Kr-86\$	

Rb-89

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4			Nuclide			
1 Rb-89	15.15m	1.000E+00	Sr-89			
2 Sr-89	50.53d	1.000E+00	Y-89\$			

Rb-90

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4			Nuclide			
1 Rb-90	158s	1.000E+00	Sr-90			

2	Sr-90	28.79y	1.000E+00	Y-90
3	Y-90	64.10h	1.000E+00	Zr-90\$

Rb-90m

				----- Daughter	
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Rb-90m	258s	2.600E-02	Rb-90	9.740E-01	Sr-90
2 Rb-90	158s	1.000E+00	Sr-90		
3 Sr-90	28.79y	1.000E+00	Y-90		
4 Y-90	64.10h	1.000E+00	Zr-90\$		

Sr-79

				----- Daughter	
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Sr-79	2.25m	1.000E+00	Rb-79		
2 Rb-79	22.9m	1.000E+00	Kr-79		
3 Kr-79	35.04h	1.000E+00	Br-79\$		

Sr-80

				----- Daughter	
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Sr-80	106.3m	1.000E+00	Rb-80		
2 Rb-80	33.4s	1.000E+00	Kr-80\$		

Sr-81

				----- Daughter	
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Sr-81	22.3m	1.442E-03	Rb-81m	9.986E-01	Rb-81
2 Rb-81m	30.5m	9.760E-01	Rb-81	2.135E-04	Kr-81m
2.379E-02 Kr-81					
3 Rb-81	4.576h	9.569E-01	Kr-81m	4.309E-02	Kr-81
4 Kr-81m	13.10s	1.000E+00	Kr-81	2.500E-05	Br-81\$
5 Kr-81	2.29E+5y	1.000E+00	Br-81\$		

Sr-82

				----- Daughter	
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Sr-82	25.36d	1.000E+00	Rb-82		
2 Rb-82	1.273m	1.000E+00	Kr-82\$		

Sr-83

----- Daughter

Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Sr-83 32.41h 1.000E+00 Rb-83
 2 Rb-83 86.2d 7.429E-01 Kr-83m 2.571E-01 Kr-83\$
 3 Kr-83m 1.83h 1.000E+00 Kr-83\$

Sr-85m

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Sr-85m 67.63m 8.660E-01 Sr-85 1.340E-01 Rb-85\$
 2 Sr-85 64.84d 1.000E+00 Rb-85\$

Sr-87m

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Sr-87m 2.815h 3.000E-03 Rb-87 9.970E-01 Sr-87\$
 2 Rb-87 4.923E10y 1.000E+00 Sr-87\$

Sr-90

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Sr-90 28.79y 1.000E+00 Y-90
 2 Y-90 64.10h 1.000E+00 Zr-90\$

Sr-91

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Sr-91 9.63h 5.825E-01 Y-91m 4.175E-01 Y-91
 2 Y-91m 49.71m 1.000E+00 Y-91
 3 Y-91 58.51d 1.000E+00 Zr

Sr-92

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Sr-92 2.66h 1.000E+00 Y-92
 2 Y-92 3.54h 1.000E+00 Zr-92\$

Sr-93

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3

Nuclide	f4	Nuclide			
1 Sr-93		7.423m	1.000E+00	Y-93	
2 Y-93		10.18h	1.000E+00	Zr-93	
3 Zr-93	1.53E+6y	9.750E-01	Nb-93m	2.500E-02	Nb-93\$
4 Nb-93m	16.13y	1.000E+00	Nb-93\$		

Sr-94

Products				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 Sr-94	75.3s	1.000E+00	Y-94		
2 Y-94	18.7m	1.000E+00	Zr-94\$		

Y-81

Products				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 Y-81	70.4s	1.000E+00	Sr-81		
2 Sr-81	22.3m	1.442E-03	Rb-81m	9.986E-01	Rb-81
3 Rb-81m	30.5m	9.760E-01	Rb-81	2.135E-04	Kr-81m
2.379E-02 Kr-81					
4 Rb-81	4.576h	9.569E-01	Kr-81m	4.309E-02	Kr-81
5 Kr-81m	13.10s	1.000E+00	Kr-81	2.500E-05	Br-81\$
6 Kr-81	2.29E+5y	1.000E+00	Br-81\$		

Y-83

Products				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 Y-83	7.08m	1.000E+00	Sr-83		
2 Sr-83	32.41h	1.000E+00	Rb-83		
3 Rb-83	86.2d	7.429E-01	Kr-83m	2.571E-01	Kr-83\$
4 Kr-83m	1.83h	1.000E+00	Kr-83\$		

Y-83m

Products				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 Y-83m	2.85m	4.000E-01	Y-83	6.000E-01	Sr-83
2 Y-83	7.08m	1.000E+00	Sr-83		
3 Sr-83	32.41h	1.000E+00	Rb-83		
4 Rb-83	86.2d	7.429E-01	Kr-83m	2.571E-01	Kr-83\$
5 Kr-83m	1.83h	1.000E+00	Kr-83\$		

Y-85

Products				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3

Nuclide	f4	Nuclide			
1 Y-85		2.68h	1.000E+00	Sr-85m	
2 Sr-85m		67.63m	8.660E-01	Sr-85	1.340E-01 Rb-85\$
3 Sr-85		64.84d	1.000E+00	Rb-85\$	

Y-85m

Products				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 Y-85m	4.86h	4.000E-02	Sr-85m	9.600E-01	Sr-85
2 Sr-85m	67.63m	8.660E-01	Sr-85	1.340E-01	Rb-85\$
3 Sr-85	64.84d	1.000E+00	Rb-85\$		

Y-86m

Products				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 Y-86m	48m	9.931E-01	Y-86	6.900E-03	Sr-86\$
2 Y-86	14.74h	1.000E+00	Sr-86\$		

Y-87

Products				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 Y-87	79.8h	1.000E+00	Sr-87m		
2 Sr-87m	2.815h	3.000E-03	Rb-87	9.970E-01	Sr-87\$
3 Rb-87	4.923E10y	1.000E+00	Sr-87\$		

Y-87m

Products				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 Y-87m	13.37h	9.843E-01	Y-87	1.570E-02	Sr-87\$
2 Y-87	79.8h	1.000E+00	Sr-87m		
3 Sr-87m	2.815h	3.000E-03	Rb-87	9.970E-01	Sr-87\$
4 Rb-87	4.923E10y	1.000E+00	Sr-87\$		

Y-90m

Products				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 Y-90m	3.19h	1.000E+00	Y-90	1.800E-05	Zr-90\$
2 Y-90	64.10h	1.000E+00	Zr-90\$		

Y-91m

Products				Daughter	
----------	--	--	--	----------	--

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Y-91m	49.71m	1.000E+00	Y-91			
2 Y-91	58.51d	1.000E+00	Zr-91\$			

Y-93

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Y-93	10.18h	1.000E+00	Zr-93			
2 Zr-93	1.53E+6y	9.750E-01	Nb-93m	2.500E-02	Nb-93\$	
3 Nb-93m	16.13y	1.000E+00	Nb-93\$			

Y-95

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Y-95	10.3m	1.000E+00	Zr-95			
2 Zr-95	64.032d	1.080E-02	Nb-95m	9.892E-01	Nb-95	
3 Nb-95m	3.61d	9.440E-01	Nb-95	5.600E-02	Mo-95\$	
4 Nb-95	34.991d	1.000E+00	Mo-95\$			

Zr-85

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Zr-85	7.86m	9.684E-01	Y-85m	3.159E-02	Y-85	
2 Y-85m	4.86h	4.000E-02	Sr-85m	9.600E-01	Sr-85	
3 Y-85	2.68h	1.000E+00	Sr-85m			
4 Sr-85m	67.63m	8.660E-01	Sr-85	1.340E-01	Rb-85\$	
5 Sr-85	64.84d	1.000E+00	Rb-85\$			

Zr-86

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Zr-86	16.5h	1.000E+00	Y-86			
2 Y-86	14.74h	1.000E+00	Sr-86\$			

Zr-87

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Zr-87	1.68h	9.970E-01	Y-87m	2.964E-03	Y-87	
2 Y-87m	13.37h	9.843E-01	Y-87	1.570E-02	Sr-87\$	
3 Y-87	79.8h	1.000E+00	Sr-87m			
4 Sr-87m	2.815h	3.000E-03	Rb-87	9.970E-01	Sr-87\$	

5 Rb-87 4.923E10y 1.000E+00 Sr-87\$

Zr-88 ----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Zr-88	83.4d	1.000E+00	Y-88			
2 Y-88	106.65d	1.000E+00	Sr-88\$			

Zr-89m ----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Zr-89m	4.161m	9.377E-01	Zr-89	6.230E-02	Y-89\$	
2 Zr-89	78.41h	1.000E+00	Y-89\$			

Zr-93 ----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Zr-93	1.53E+6y	9.750E-01	Nb-93m	2.500E-02	Nb-93\$	
2 Nb-93m	16.13y	1.000E+00	Nb-93\$			

Zr-95 ----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Zr-95	64.032d	1.080E-02	Nb-95m	9.892E-01	Nb-95	
2 Nb-95m	3.61d	9.440E-01	Nb-95	5.600E-02	Mo-95\$	
3 Nb-95	34.991d	1.000E+00	Mo-95\$			

Zr-97 ----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Zr-97	16.744h	1.000E+00	Nb-97			
2 Nb-97	72.1m	1.000E+00	Mo-97\$			

Nb-87 ----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Nb-87	3.75m	1.000E+00	Zr-87			
2 Zr-87	1.68h	9.970E-01	Y-87m	2.964E-03	Y-87	
3 Y-87m	13.37h	9.843E-01	Y-87	1.570E-02	Sr-87\$	
4 Y-87	79.8h	1.000E+00	Sr-87m			

5 Sr-87m	2.815h	3.000E-03	Rb-87	9.970E-01	Sr-87\$
6 Rb-87	4.923E10y	1.000E+00	Sr-87\$		

Nb-88

-----				Daughter	
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Nb-88	14.5m	1.000E+00	Zr-88		
2 Zr-88	83.4d	1.000E+00	Y-88		
3 Y-88	106.65d	1.000E+00	Sr-88\$		

Nb-88m

-----				Daughter	
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Nb-88m	7.78m	1.000E+00	Zr-88		
2 Zr-88	83.4d	1.000E+00	Y-88		
3 Y-88	106.65d	1.000E+00	Sr-88\$		

Nb-89

-----				Daughter	
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Nb-89	2.03h	1.228E-02	Zr-89m	9.877E-01	Zr-89
2 Zr-89m	4.161m	9.377E-01	Zr-89	6.230E-02	Y-89\$
3 Zr-89	78.41h	1.000E+00	Y-89\$		

Nb-89m

-----				Daughter	
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Nb-89m	66m	1.000E+00	Zr-89m		
2 Zr-89m	4.161m	9.377E-01	Zr-89	6.230E-02	Y-89\$
3 Zr-89	78.41h	1.000E+00	Y-89\$		

Nb-91m

-----				Daughter	
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Nb-91m	60.86d	9.660E-01	Nb-91	3.400E-02	Zr-91\$
2 Nb-91	680y	1.000E+00	Zr-91\$		

Nb-94m

-----				Daughter	
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				

1 Nb-94m	6.263m	9.950E-01	Nb-94	5.000E-03	Mo-94\$
2 Nb-94	2.03E+4y	1.000E+00	Mo-94\$		

Nb-95m

Products -----				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Nb-95m	3.61d	9.440E-01	Nb-95	5.600E-02	Mo-95\$
2 Nb-95	34.991d	1.000E+00	Mo-95\$		

Nb-99

Products -----				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Nb-99	15.0s	1.000E+00	Mo-99		
2 Mo-99	65.94h	8.773E-01	Tc-99m	1.227E-01	Tc-99
3 Tc-99m	6.015h	1.000E+00	Tc-99	3.700E-05	Ru-99\$
4 Tc-99	2.111E+5y	1.000E+00	Ru-99\$		

Nb-99m

Products -----				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Nb-99m	2.6m	2.000E-02	Nb-99	9.800E-01	Mo-99
2 Nb-99	15.0s	1.000E+00	Mo-99		
3 Mo-99	65.94h	8.773E-01	Tc-99m	1.227E-01	Tc-99
4 Tc-99m	6.015h	1.000E+00	Tc-99	3.700E-05	Ru-99\$
5 Tc-99	2.111E+5y	1.000E+00	Ru-99\$		

Mo-89

Products -----				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Mo-89	2.11m	1.000E+00	Nb-89		
2 Nb-89	2.03h	1.228E-02	Zr-89m	9.877E-01	Zr-89
3 Zr-89m	4.161m	9.377E-01	Zr-89	6.230E-02	Y-89\$
4 Zr-89	78.41h	1.000E+00	Y-89\$		

Mo-90

Products -----				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Mo-90	5.56h	1.000E+00	Nb-90		
2 Nb-90	14.60h	1.000E+00	Zr-90\$		

Mo-91

----- Daughter

Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Mo-91 15.49m 3.423E-04 Nb-91m 9.997E-01 Nb-91
 2 Nb-91m 60.86d 9.660E-01 Nb-91 3.400E-02 Zr-91\$
 3 Nb-91 680y 1.000E+00 Zr-91\$

Mo-91m

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Mo-91m 64.6s 5.000E-01 Mo-91 5.000E-01 Nb-91m
 2 Mo-91 15.49m 3.423E-04 Nb-91m 9.997E-01 Nb-91
 3 Nb-91m 60.86d 9.660E-01 Nb-91 3.400E-02 Zr-91\$
 4 Nb-91 680y 1.000E+00 Zr-91\$

Mo-93

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Mo-93 4.0E+3y 8.800E-01 Nb-93m 1.200E-01 Nb-93\$
 2 Nb-93m 16.13y 1.000E+00 Nb-93\$

Mo-93m

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Mo-93m 6.85h 9.988E-01 Mo-93 1.200E-03 Nb-93\$
 2 Mo-93 4.0E+3y 8.800E-01 Nb-93m 1.200E-01 Nb-93\$
 3 Nb-93m 16.13y 1.000E+00 Nb-93\$

Mo-99

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Mo-99 65.94h 8.773E-01 Tc-99m 1.227E-01 Tc-99
 2 Tc-99m 6.015h 1.000E+00 Tc-99 3.700E-05 Ru-99\$
 3 Tc-99 2.111E+5y 1.000E+00 Ru-99\$

Mo-101

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Mo-101 14.61m 1.000E+00 Tc-101
 2 Tc-101 14.2m 1.000E+00 Ru-101\$

Mo-102

-----					Daughter	
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4		Nuclide				
1 Mo-102	11.3m	1.000E+00	Tc-102			
2 Tc-102	5.28s	1.000E+00	Ru-102\$			

Tc-91

-----					Daughter	
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4		Nuclide				
1 Tc-91	3.14m	6.979E-03	Mo-91m	9.930E-01	Mo-91	
2 Mo-91m	64.6s	5.000E-01	Mo-91	5.000E-01	Nb-91m	
3 Mo-91	15.49m	3.423E-04	Nb-91m	9.997E-01	Nb-91	
4 Nb-91m	60.86d	9.660E-01	Nb-91	3.400E-02	Zr-91\$	
5 Nb-91	680y	1.000E+00	Zr-91\$			

Tc-91m

-----					Daughter	
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4		Nuclide				
1 Tc-91m	3.3m	9.798E-01	Mo-91m	2.024E-02	Mo-91	
2 Mo-91m	64.6s	5.000E-01	Mo-91	5.000E-01	Nb-91m	
3 Mo-91	15.49m	3.423E-04	Nb-91m	9.997E-01	Nb-91	
4 Nb-91m	60.86d	9.660E-01	Nb-91	3.400E-02	Zr-91\$	
5 Nb-91	680y	1.000E+00	Zr-91\$			

Tc-93

-----					Daughter	
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4		Nuclide				
1 Tc-93	2.75h	1.000E+00	Mo-93			
2 Mo-93	4.0E+3y	8.800E-01	Nb-93m	1.200E-01	Nb-93\$	
3 Nb-93m	16.13y	1.000E+00	Nb-93\$			

Tc-93m

-----					Daughter	
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4		Nuclide				
1 Tc-93m	43.5m	7.660E-01	Tc-93	2.340E-01	Mo-93	
2 Tc-93	2.75h	1.000E+00	Mo-93			
3 Mo-93	4.0E+3y	8.800E-01	Nb-93m	1.200E-01	Nb-93\$	
4 Nb-93m	16.13y	1.000E+00	Nb-93\$			

Tc-95m

-----					Daughter	
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3

Nuclide	f4	Nuclide			
1 Tc-95m		61d	3.880E-02	Tc-95	9.612E-01 Mo-95\$
2 Tc-95		20.0h	1.000E+00	Mo-95\$	

Tc-96m

				----- Daughter	
Products	-----				
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Tc-96m	51.5m	9.800E-01	Tc-96	2.000E-02	Mo
2 Tc-96	4.28d	1.000E+00	Mo-96\$		

Tc-97m

				----- Daughter	
Products	-----				
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Tc-97m	90.1d	1.000E+00	Tc-97		
2 Tc-97	2.6E+6y	1.000E+00	Mo-97\$		

Tc-99m

				----- Daughter	
Products	-----				
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Tc-99m	6.015h	1.000E+00	Tc-99	3.700E-05	Ru-99\$
2 Tc-99	2.111E+5y	1.000E+00	Ru-99\$		

Tc-102m

				----- Daughter	
Products	-----				
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Tc-102m	4.35m	2.000E-02	Tc-102	9.800E-01	Ru-102\$
2 Tc-102	5.28s	1.000E+00	Ru-102\$		

Tc-105

				----- Daughter	
Products	-----				
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Tc-105	7.6m	1.000E+00	Ru-105		
2 Ru-105	4.44h	1.000E+00	Rh-105		
3 Rh-105	35.36h	1.000E+00	Pd-105\$		

Ru-92

				----- Daughter	
Products	-----				
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Ru-92	3.65m	1.000E+00	Tc-92		
2 Tc-92	4.25m	1.000E+00	Mo-92\$		

Ru-94

```

----- Daughter
Products -----
  Nuclide  Halflife    f1    Nuclide  f2    Nuclide  f3
Nuclide  f4    Nuclide
  1 Ru-94      51.8m  1.000E+00 Tc-94m
  2 Tc-94m     52.0m  1.000E+00 Mo-94$
```

Ru-95

```

----- Daughter
Products -----
  Nuclide  Halflife    f1    Nuclide  f2    Nuclide  f3
Nuclide  f4    Nuclide
  1 Ru-95      1.643h  2.613E-02 Tc-95m  9.739E-01 Tc-95
  2 Tc-95m      61d   3.880E-02 Tc-95   9.612E-01 Mo-95$
  3 Tc-95      20.0h  1.000E+00 Mo-95$
```

Ru-97

```

----- Daughter
Products -----
  Nuclide  Halflife    f1    Nuclide  f2    Nuclide  f3
Nuclide  f4    Nuclide
  1 Ru-97      2.9d   4.218E-04 Tc-97m  9.996E-01 Tc-97
  2 Tc-97m     90.1d  1.000E+00 Tc-97
  3 Tc-97      2.6E+6y  1.000E+00 Mo-97$
```

Ru-103

```

----- Daughter
Products -----
  Nuclide  Halflife    f1    Nuclide  f2    Nuclide  f3
Nuclide  f4    Nuclide
  1 Ru-103     39.26d  9.876E-01 Rh-103m  1.245E-02 Rh-103$
  2 Rh-103m    56.114m  1.000E+00 Rh-103$
```

Ru-105

```

----- Daughter
Products -----
  Nuclide  Halflife    f1    Nuclide  f2    Nuclide  f3
Nuclide  f4    Nuclide
  1 Ru-105      4.44h  1.000E+00 Rh-105
  2 Rh-105     35.36h  1.000E+00 Pd-105$
```

Ru-106

```

----- Daughter
Products -----
  Nuclide  Halflife    f1    Nuclide  f2    Nuclide  f3
Nuclide  f4    Nuclide
  1 Ru-106     373.59d  1.000E+00 Rh-106
  2 Rh-106     29.80s  1.000E+00 Pd-106$
```

Ru-107

----- Daughter
 Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ru-107	3.75m	1.000E+00	Rh-107			
2 Rh-107	21.7m	1.000E+00	Pd-107			
3 Pd-107	6.5E+6y	1.000E+00	Ag-107\$			

Ru-108

----- Daughter
 Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ru-108	4.55m	1.000E+00	Rh-108			
2 Rh-108	16.8s	1.000E+00	Pd-108\$			

Rh-94

----- Daughter
 Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Rh-94	70.6s	1.000E+00	Ru-94			
2 Ru-94	51.8m	1.000E+00	Tc-94m			
3 Tc-94m	52.0m	1.000E+00	Mo-94\$			

Rh-95

----- Daughter
 Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Rh-95	5.02m	1.000E+00	Ru-95			
2 Ru-95	1.643h	2.613E-02	Tc-95m	9.739E-01	Tc-95	
3 Tc-95m	61d	3.880E-02	Tc-95	9.612E-01	Mo-95\$	
4 Tc-95	20.0h	1.000E+00	Mo-95\$			

Rh-95m

----- Daughter
 Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Rh-95m	1.96m	8.800E-01	Rh-95	1.200E-01	Ru-95	
2 Rh-95	5.02m	1.000E+00	Ru-95			
3 Ru-95	1.643h	2.613E-02	Tc-95m	9.739E-01	Tc-95	
4 Tc-95m	61d	3.880E-02	Tc-95	9.612E-01	Mo-95\$	
5 Tc-95	20.0h	1.000E+00	Mo-95\$			

Rh-96m

----- Daughter
 Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Rh-96m	1.51m	6.000E-01	Rh-96	4.000E-01	Ru-96\$	

2 Rh-96 9.90m 1.000E+00 Ru-96\$

Rh-97

----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Rh-97	30.7m	1.000E+00	Ru-97			
2 Ru-97	2.9d	4.218E-04	Tc-97m	9.996E-01	Tc-97	
3 Tc-97m	90.1d	1.000E+00	Tc-97			
4 Tc-97	2.6E+6y	1.000E+00	Mo-97\$			

Rh-97m

----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Rh-97m	46.2m	5.600E-02	Rh-97	9.440E-01	Ru-97	
2 Rh-97	30.7m	1.000E+00	Ru-97			
3 Ru-97	2.9d	4.218E-04	Tc-97m	9.996E-01	Tc-97	
4 Tc-97m	90.1d	1.000E+00	Tc-97			
5 Tc-97	2.6E+6y	1.000E+00	Mo-97\$			

Rh-100m

----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Rh-100m	4.6m	9.830E-01	Rh-100	1.700E-02	Ru-100\$	
2 Rh-100	20.8h	1.000E+00	Ru-100\$			

Rh-101m

----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Rh-101m	4.34d	6.400E-02	Rh-101	9.360E-01	Ru-101\$	
2 Rh-101	3.3y	1.000E+00	Ru-101\$			

Rh-102m

----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Rh-102m	3.742y	2.330E-03	Rh-102	9.977E-01	Ru-102\$	
2 Rh-102	207d	7.800E-01	Ru-102\$	2.200E-01	Pd-102\$	

Rh-104m

----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3

1 Rh-104m	4.34m	9.987E-01	Rh-104	1.300E-03	Pd-104\$
2 Rh-104	42.3s	9.955E-01	Pd-104\$	4.500E-03	Ru-104\$

Rh-107

-----				Daughter	
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Rh-107	21.7m	1.000E+00	Pd-107		
2 Pd-107	6.5E+6y	1.000E+00	Ag-107\$		

Rh-109

-----				Daughter	
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Rh-109	80s	1.000E+00	Pd-109		
2 Pd-109	13.7012h	1.000E+00	Ag-109\$		

Pd-96

-----				Daughter	
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Pd-96	122s	1.000E+00	Rh-96m		
2 Rh-96m	1.51m	6.000E-01	Rh-96	4.000E-01	Ru-96\$
3 Rh-96	9.90m	1.000E+00	Ru-96\$		

Pd-97

-----				Daughter	
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Pd-97	3.10m	1.162E-02	Rh-97m	9.884E-01	Rh-97
2 Rh-97m	46.2m	5.600E-02	Rh-97	9.440E-	
3 Rh-97	30.7m	1.000E+00	Ru-97		
4 Ru-97	2.9d	4.218E-04	Tc-97m	9.996E-01	Tc-97
5 Tc-97m	90.1d	1.000E+00	Tc-97		
6 Tc-97	2.6E+6y	1.000E+00	Mo-97\$		

Pd-98

-----				Daughter	
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Pd-98	17.7m	1.000E+00	Rh-98		
2 Rh-98	8.7m	1.000E+00	Ru-98\$		

Pd-99

-----				Daughter	
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3

Nuclide	f4	Nuclide			
1 Pd-99		21.4m	9.665E-01	Rh-99m	3.353E-02 Rh-99
2 Rh-99m		4.7h	1.000E+00	Ru-99\$	
3 Rh-99		16.1d	1.000E+00	Ru-99\$	

Pd-100

Products -----					Daughter
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4			Nuclide		
1 Pd-100	3.63d	1.000E+00	Rh-100		
2 Rh-100	20.8h	1.000E+00	Ru-100\$		

Pd-101

Products -----					Daughter
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4			Nuclide		
1 Pd-101	8.47h	9.973E-01	Rh-101m	2.700E-03	Rh-101
2 Rh-101m	4.34d	6.400E-02	Rh-101	9.360E-01	Ru-101\$
3 Rh-101	3.3y	1.000E+00	Ru-101\$		

Pd-103

Products -----					Daughter
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4			Nuclide		
1 Pd-103	16.991d	9.988E-01	Rh-103m	1.251E-03	Rh-103\$
2 Rh-103m	56.114m	1.000E+00	Rh-103\$		

Pd-109m

Products -----					Daughter
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4			Nuclide		
1 Pd-109m	4.69m	1.000E+00	Pd-109		
2 Pd-109	13.7012h	1.000E+00	Ag-109\$		

Pd-111

Products -----					Daughter
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4			Nuclide		
1 Pd-111	23.4m	9.976E-01	Ag-111m	2.437E-03	Ag-111
2 Ag-111m	64.8s	9.930E-01	Ag-111	7.000E-03	Cd-111\$
3 Ag-111	7.45d	1.000E+00	Cd-111\$		

Pd-112

Products -----					Daughter
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4			Nuclide		

1 Pd-112	21.03h	1.000E+00	Ag-112
2 Ag-112	3.130h	1.000E+00	Cd-112\$

Pd-114

-----				Daughter	
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Pd-114	2.42m	1.000E+00	Ag-114		
2 Ag-114	4.6s	1.000E+00	Cd-114\$		

Ag-99

-----				Daughter	
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Ag-99	124s	1.000E+00	Pd-99		
2 Pd-99	21.4m	9.665E-01	Rh-99m	3.353E-02	Rh-99
3 Rh-99m	4.7h	1.000E+00	Ru-99\$		
4 Rh-99	16.1d	1.000E+00	Ru-99\$		

Ag-100m

-----				Daughter	
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Ag-100m	2.24m	1.000E+00	Pd-100		
2 Pd-100	3.63d	1.000E+00	Rh-100		
3 Rh-100	20.8h	1.000E+00	Ru-100\$		

Ag-101

-----				Daughter	
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Ag-101	11.1m	1.000E+00	Pd-101		
2 Pd-101	8.47h	9.973E-01	Rh-101m	2.700E-03	Rh-101
3 Rh-101m	4.34d	6.400E-02	Rh-101	9.360E-01	Ru-101\$
4 Rh-101	3.3y	1.000E+00	Ru-101\$		

Ag-102m

-----				Daughter	
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Ag-102m	7.7m	4.900E-01	Ag-102	5.100E-01	Pd-102\$
2 Ag-102	12.9m	1.000E+00	Pd-102\$		

Ag-103

-----				Daughter	
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3

Nuclide	f4	Nuclide	
1 Ag-103	65.7m	1.000E+00	Pd-103
2 Pd-103	16.991d	9.988E-01	Rh-103m 1.251E-03 Rh-103\$
3 Rh-103m	56.114m	1.000E+00	Rh-103\$

Ag-104m

			----- Daughter	
Products	-----			
Nuclide	Halflife	f1	Nuclide	f2
Nuclide	f4	Nuclide		f3
1 Ag-104m	33.5m	7.000E-04	Ag-104	9.993E-01 Pd-104\$
2 Ag-104	69.2m	1.000E+00	Pd-104\$	

Ag-105m

			----- Daughter	
Products	-----			
Nuclide	Halflife	f1	Nuclide	f2
Nuclide	f4	Nuclide		f3
1 Ag-105m	7.23m	9.966E-01	Ag-105	3.400E-03 Pd-105\$
2 Ag-105	41.29d	1.000E+00	Pd-105\$	

Ag-108m

			----- Daughter	
Products	-----			
Nuclide	Halflife	f1	Nuclide	f2
Nuclide	f4	Nuclide		f3
1 Ag-108m	418y	8.700E-02	Ag-108	9.130E-01 Pd-108\$
2 Ag-108	2.37m	9.715E-01	Cd-108\$	2.850E-02 Pd-108\$

Ag-110m

			----- Daughter	
Products	-----			
Nuclide	Halflife	f1	Nuclide	f2
Nuclide	f4	Nuclide		f3
1 Ag-110m	249.76d	1.360E-02	Ag-110	9.864E-01 Cd-110\$
2 Ag-110	24.6s	9.970E-01	Cd-110\$	3.000E-03 Pd-110\$

Ag-111m

			----- Daughter	
Products	-----			
Nuclide	Halflife	f1	Nuclide	f2
Nuclide	f4	Nuclide		f3
1 Ag-111m	64.8s	9.930E-01	Ag-111	7.000E-03 Cd-111\$
2 Ag-111	7.45d	1.000E+00	Cd-111\$	

Ag-113

			----- Daughter	
Products	-----			
Nuclide	Halflife	f1	Nuclide	f2
Nuclide	f4	Nuclide		f3
1 Ag-113	5.37h	1.739E-02	Cd-113m	9.826E-01 Cd-113
2 Cd-113m	14.1y	1.400E-03	Cd-113	9.986E-01 In-113\$

3 Cd-113 7.7E+15y 1.000E+00 In-113\$

Ag-113m

----- Daughter					
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Ag-113m	68.7s	6.400E-01	Ag-113	3.600E-01	Cd-113
2 Ag-113	5.37h	1.739E-02	Cd-113m	9.826E-01	Cd-113
3 Cd-113m	14.1y	1.400E-03	Cd-113	9.986E-01	In-113\$
4 Cd-113	7.7E+15y	1.000E+00	In-113\$		

Ag-115

----- Daughter					
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Ag-115	20.0m	9.421E-01	Cd-115	5.787E-02	Cd-115m
2 Cd-115	53.46h	1.000E+00	In-115m		
3 Cd-115m	44.6d	1.058E-04	In-115m	9.999E-01	In-115
4 In-115m	4.486h	9.500E-01	In-115	5.000E-02	Sn-115\$
5 In-115	4.41E+14y	1.000E+00	Sn-115\$		

Ag-117

----- Daughter					
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Ag-117	73.6s	8.470E-01	Cd-117	1.530E-01	Cd-117m
2 Cd-117	2.49h	9.151E-01	In-117m	8.493E-02	In-117
3 Cd-117m	3.36h	9.983E-03	In-117m	9.900E-01	In-117
4 In-117m	116.2m	4.710E-01	In-117	5.290E-01	Sn-117\$
5 In-117	43.2m	3.532E-03	Sn-117m	9.965E-01	Sn-117\$
6 Sn-117m	13.76d	1.000E+00	Sn-117\$		

Cd-101

----- Daughter					
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Cd-101	1.36m	1.000E+00	Ag-101		
2 Ag-101	11.1m	1.000E+00	Pd-101		
3 Pd-101	8.47h	9.973E-01	Rh-101m	2.700E-03	Rh-101
4 Rh-101m	4.34d	6.400E-02	Rh-101	9.360E-01	Ru-101\$
5 Rh-101	3.3y	1.000E+00	Ru-101\$		

Cd-102

----- Daughter					
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Cd-102	5.5m	9.462E-01	Ag-102m	5.376E-02	Ag-102

2	Ag-102m	7.7m	4.900E-01	Ag-102	5.100E-01	Pd-102\$
3	Ag-102	12.9m	1.000E+00	Pd-102\$		

Cd-103

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4			Nuclide			
1 Cd-103	7.3m	1.000E+00	Ag-103			
2 Ag-103	65.7m	1.000E+00	Pd-103			
3 Pd-103	16.991d	9.988E-01	Rh-103m	1.251E-03	Rh-103\$	
4 Rh-103m	56.114m	1.000E+00	Rh-103\$			

Cd-104

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4			Nuclide			
1 Cd-104	57.7m	1.000E+00	Ag-104m			
2 Ag-104m	33.5m	7.000E-04	Ag-104	9.993E-01	Pd-104\$	
3 Ag-104	69.2m	1.000E+00	Pd-104\$			

Cd-105

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4			Nuclide			
1 Cd-105	55.5m	8.296E-01	Ag-105m	1.704E-01	Ag-105	
2 Ag-105m	7.23m	9.966E-01	Ag-105	3.400E-03	Pd-105\$	
3 Ag-105	41.29d	1.000E+00	Pd-105\$			

Cd-113m

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4			Nuclide			
1 Cd-113m	14.1y	1.400E-03	Cd-113	9.986E-01	In-113\$	
2 Cd-113	7.7E+15y	1.000E+00	In-113\$			

Cd-115

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4			Nuclide			
1 Cd-115	53.46h	1.000E+00	In-115m			
2 In-115m	4.486h	9.500E-01	In-115	5.000E-02	Sn-115\$	
3 In-115	4.41E+14y	1.000E+00	Sn-115\$			

Cd-115m

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3

Nuclide	f4	Nuclide			
1 Cd-115m		44.6d	1.058E-04	In-115m	9.999E-01 In-115
2 In-115m		4.486h	9.500E-01	In-115	5.000E-02 Sn-115\$
3 In-115	4.41E+14y		1.000E+00	Sn-115\$	

Cd-117

Products					Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Cd-117	2.49h	9.151E-01	In-117m	8.493E-02	In-117	
2 In-117m	116.2m	4.710E-01	In-117	5.290E-01	Sn-117\$	
3 In-117	43.2m	3.532E-03	Sn-117m	9.965E-01	Sn-117\$	
4 Sn-117m	13.76d	1.000E+00	Sn-117\$			

Cd-117m

Products					Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Cd-117m	3.36h	9.983E-03	In-117m	9.900E-01	In-117	
2 In-117m	116.2m	4.710E-01	In-117	5.290E-01	Sn-117\$	
3 In-117	43.2m	3.532E-03	Sn-117m	9.965E-01	Sn-117\$	
4 Sn-117m	13.76d	1.000E+00	Sn-117\$			

Cd-118

Products					Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Cd-118	50.3m	1.000E+00	In-118			
2 In-118	5.0s	1.000E+00	Sn-118\$			

Cd-119

Products					Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Cd-119	2.69m	9.009E-01	In-119m	9.909E-02	In-119	
2 In-119m	18.0m	5.600E-02	In-119	9.440E-01	Sn-119\$	
3 In-119	2.4m	9.477E-03	Sn-119m	9.905E-01	Sn-119\$	
4 Sn-119m	293.1d	1.000E+00	Sn-119\$			

Cd-119m

Products					Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Cd-119m	2.20m	2.133E-03	In-119m	9.979E-01	In-119	
2 In-119m	18.0m	5.600E-02	In-119	9.440E-01	Sn-119\$	
3 In-119	2.4m	9.477E-03	Sn-119m	9.905E-01	Sn-119\$	
4 Sn-119m	293.1d	1.000E+00	Sn-119\$			

In-103

				----- Daughter		
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 In-103	60s	1.000E+00	Cd-103			
2 Cd-103	7.3m	1.000E+00	Ag-103			
3 Ag-103	65.7m	1.000E+00	Pd-103			
4 Pd-103	16.991d	9.988E-01	Rh-103m	1.251E-03	Rh-103\$	
5 Rh-103m	56.114m	1.000E+00	Rh-103\$			

In-105

				----- Daughter		
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 In-105	5.07m	1.000E+00	Cd-105			
2 Cd-105	55.5m	8.296E-01	Ag-105m	1.704E-01	Ag-105	
3 Ag-105m	7.23m	9.966E-01	Ag-105	3.400E-03	Pd-105\$	
4 Ag-105	41.29d	1.000E+00	Pd-105\$			

In-107

				----- Daughter		
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 In-107	32.4m	1.000E+00	Cd-107			
2 Cd-107	6.50h	1.000E+00	Ag-107\$			

In-109

				----- Daughter		
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 In-109	4.2h	1.000E+00	Cd-109			
2 Cd-109	461.4d	1.000E+00	Ag-109\$			

In-109m

				----- Daughter		
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 In-109m	1.34m	1.000E+00	In-109			
2 In-109	4.2h	1.000E+00	Cd-109			
3 Cd-109	461.4d	1.000E+00	Ag-109\$			

In-111

				----- Daughter		
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					

1 In-111	2.8047d	5.000E-05	Cd-111m	1.000E+00	Cd-111\$
2 Cd-111m	48.50m	1.000E+00	Cd-111\$		

In-111m

-----			Daughter		
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4			Nuclide		
1 In-111m	7.7m	1.000E+00	In-111		
2 In-111	2.8047d	5.000E-05	Cd-111m	1.000E+00	Cd-111\$
3 Cd-111m	48.50m	1.000E+00	Cd-111\$		

In-112m

-----			Daughter		
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4			Nuclide		
1 In-112m	20.56m	1.000E+00	In-112		
2 In-112	14.97m	5.600E-01	Cd-112\$	4.400E-01	Sn-112\$

In-114m

-----			Daughter		
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4			Nuclide		
1 In-114m	49.51d	9.675E-01	In-114	3.250E-02	Cd-114\$
2 In-114	71.9s	9.950E-01	Sn-114\$	5.000E-03	Cd-114\$

In-115m

-----			Daughter		
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4			Nuclide		
1 In-115m	4.486h	9.500E-01	In-115	5.000E-02	Sn-115\$
2 In-115	4.41E+14y	1.000E+00	Sn-115\$		

In-117

-----			Daughter		
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4			Nuclide		
1 In-117	43.2m	3.532E-03	Sn-117m	9.965E-01	Sn-117\$
2 Sn-117m	13.76d	1.000E+00	Sn-117\$		

In-117m

-----			Daughter		
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4			Nuclide		
1 In-117m	116.2m	4.710E-01	In-117	5.290E-01	Sn-117\$
2 In-117	43.2m	3.532E-03	Sn-117m	9.965E-01	Sn-117\$
3 Sn-117m	13.76d	1.000E+00	Sn-117\$		

In-119

					----- Daughter	
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 In-119	2.4m	9.477E-03	Sn			
2 Sn-119m	293.1d	1.000E+00	Sn-119\$			

In-119m

					----- Daughter	
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 In-119m	18.0m	5.600E-02	In-119	9.440E-01	Sn-119\$	
2 In-119	2.4m	9.477E-03	Sn-119m	9.905E-01	Sn-119\$	
3 Sn-119m	293.1d	1.000E+00	Sn-119\$			

In-121

					----- Daughter	
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 In-121	23.1s	1.135E-01	Sn-121m	8.865E-01	Sn-121	
2 Sn-121m	43.9y	7.760E-01	Sn-121	2.240E-01	Sb-121\$	
3 Sn-121	27.03h	1.000E+00	Sb-121\$			

In-121m

					----- Daughter	
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 In-121m	3.88m	1.200E-02	In-121	9.880E-01	Sn-121	
2 In-121	23.1s	1.135E-01	Sn-121m	8.865E-01	Sn-121	
3 Sn-121m	43.9y	7.760E-01	Sn-121	2.240E-01	Sb-121\$	
4 Sn-121	27.03h	1.000E+00	Sb-121\$			

Sn-106

					----- Daughter	
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Sn-106	1.92m	1.000E+00	In-106m			
2 In-106m	5.2m	1.000E+00	Cd-106\$			

Sn-108

					----- Daughter	
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Sn-108	10.30m	1.000E+00	In-108m			
2 In-108m	39.6m	1.000E+00	Cd-108\$			

Sn-109

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Sn-109	18.0m	2.827E-01	In-109m	7.173E-01	In-109	
2 In-109m	1.34m	1.000E+00	In-109			
3 In-109	4.2h	1.000E+00	Cd-109			
4 Cd-109	461.4d	1.000E+00	Ag-109\$			

Sn-110

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Sn-110	4.11h	1.000E+00	In-110m			
2 In-110m	69.1m	1.000E+00	Cd-110\$			

Sn-111

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Sn-111	35.3m	2.074E-03	In-111m	9.979E-01	In-111	
2 In-111m	7.7m	1.000E+00	In-111			
3 In-111	2.8047d	5.000E-05	Cd-111m	1.000E+00	Cd-111\$	
4 Cd-111m	48.50m	1.000E+00	Cd-111\$			

Sn-113

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Sn-113	115.09d	1.000E+00	In-113m	2.235E-05	In-113\$	
2 In-113m	1.6579h	1.000E+00	In-113\$			

Sn-113m

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Sn-113m	21.4m	9.110E-01	Sn-113	8.900E-02	In-113\$	
2 Sn-113	115.09d	1.000E+00	In-113m	2.235E-05	In-113\$	
3 In-113m	1.6579h	1.000E+00	In-113\$			

Sn-121m

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Sn-121m	43.9y	7.760E-01	Sn-121	2.240E-01	Sb-121\$	

2 Sn-121 27.03h 1.000E+00 Sb-121\$

Sn-125

```

----- Daughter
Products -----
  Nuclide  Halflife    f1      Nuclide  f2      Nuclide  f3
Nuclide  f4      Nuclide
  1 Sn-125      9.64d  1.000E+00  Sb-125
  2 Sb-125     2.75856y  2.314E-01  Te-125m  7.686E-01  Te-125$
  3 Te-125m     57.40d  1.000E+00  Te-125$

```

Sn-125m

```

----- Daughter
Products -----
  Nuclide  Halflife    f1      Nuclide  f2      Nuclide  f3
Nuclide  f4      Nuclide
  1 Sn-125m     9.52m  1.000E+00  Sb-125
  2 Sb-125     2.75856y  2.314E-01  Te-125m  7.686E-01  Te-125$
  3 Te-125m     57.40d  1.000E+00  Te-125$

```

Sn-126

```

----- Daughter
Products -----
  Nuclide  Halflife    f1      Nuclide  f2      Nuclide  f3
Nuclide  f4      Nuclide
  1 Sn-126     2.30E+5y  1.000E+00  Sb-126m
  2 Sb-126m     19.15m  1.400E-01  Sb-126   8.600E-01  Te-126$
  3 Sb-126      12.35d  1.000E+00  Te-126$

```

Sn-127

```

----- Daughter
Products -----
  Nuclide  Halflife    f1      Nuclide  f2      Nuclide  f3
Nuclide  f4      Nuclide
  1 Sn-127      2.10h  1.000E+00  Sb-127
  2 Sb-127      3.85d  1.768E-01  Te-127m  8.232E-01  Te-127
  3 Te-127m     109d  9.760E-01  Te-127   2.400E-02  I-127$
  4 Te-127      9.35h  1.000E+00  I-127$

```

Sn-127m

```

----- Daughter
Products -----
  Nuclide  Halflife    f1      Nuclide  f2      Nuclide  f3
Nuclide  f4      Nuclide
  1 Sn-127m     4.13m  1.000E+00  Sb-127
  2 Sb-127      3.85d  1.768E-01  Te-127m  8.232E-01  Te-127
  3 Te-127m     109d  9.760E-01  Te-127   2.400E-02  I-127$
  4 Te-127      9.35h  1.000E+00  I-127$

```

Sn-128

```

----- Daughter
Products -----

```

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Sn-128	59.07m	1.000E+00	Sb-128m			
2 Sb-128m	10.4m	3.600E-02	Sb-128	9.640E-01	Te-128\$	
3 Sb-128	9.01h	1.000E+00	Te-128\$			

Sn-129

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Sn-129	2.23m	1.000E+00	Sb-129			
2 Sb-129	4.40h	2.262E-01	Te-129m	7.738E-01	Te-129	
3 Te-129m	33.6d	6.300E-01	Te-129	3.700E-01	I-129	
4 Te-129	69.6m	1.000E+00	I-129			
5 I-129	1.57E+7y	1.000E+00	Xe-129\$			

Sn-130

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Sn-130	3.72m	1.000E+00	Sb-130m			
2 Sb-130m	6.3m	1.000E+00	Te-130\$			

Sn-130m

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Sn-130m	1.7m	8.600E-01	Sb-130	1.399E-01	Sb-130m	
2 Sb-130	39.5m	1.000E+00	Te-130\$			
3 Sb-130m	6.3m	1.000E+00	Te-130\$			

Sb-111

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Sb-111	75s	1.000E+00	Sn-111			
2 Sn-111	35.3m	2.074E-03	In-111m	9.979E-01	In-111	
3 In-111m	7.7m	1.000E+00	In-111			
4 In-111	2.8047d	5.000E-05	Cd-111m	1.000E+00	Cd-111\$	
5 Cd-111m	48.50m	1.000E+00	Cd-111\$			

Sb-113

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Sb-113	6.67m	2.243E-01	Sn-113m	7.757E-01	Sn-113	
2 Sn-113m	21.4m	9.110E-01	Sn-113	8.900E-02	In-113\$	

3	Sn-113	115.09d	1.000E+00	In-113m	2.235E-05	In-113\$
4	In-113m	1.6579h	1.000E+00	In-113\$		

Sb-122m

Products				Daughter		
Nuclide	Half-life	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Sb-122m	4.191m	1.000E+00	Sb-122			
2 Sb-122	2.7238d	9.759E-01	Te-122\$	2.410E-02	Sn-122\$	

Sb-124m

Products				Daughter		
Nuclide	Half-life	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Sb-124m	93s	7.500E-01	Sb-124	2.500E-01	Te-124\$	
2 Sb-124	60.20d	1.000E+00	Te-124\$			

Sb-124n

Products				Daughter		
Nuclide	Half-life	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Sb-124n	20.2m	1.000E+00	Sb-124m			
2 Sb-124m	93s	7.500E-01	Sb-124	2.500E-01	Te-124\$	
3 Sb-124	60.20d	1.000E+00	Te-124\$			

Sb-125

Products				Daughter		
Nuclide	Half-life	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Sb-125	2.75856y	2.314E-01	Te-125m	7.686E-01	Te-125\$	
2 Te-125m	57.40d	1.000E+00	Te-125\$			

Sb-126m

Products				Daughter		
Nuclide	Half-life	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Sb-126m	19.15m	1.400E-01	Sb-126	8.600E-01	Te-126\$	
2 Sb-126	12.35d	1.000E+00	Te-126\$			

Sb-127

Products				Daughter		
Nuclide	Half-life	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Sb-127	3.85d	1.768E-01	Te-127m	8.232E-01	Te-127	
2 Te-127m	109d	9.760E-01	Te-127	2.400E-02	I-127\$	
3 Te-127	9.35h	1.000E+00	I-127\$			

Sb-128m

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Sb-128m	10.4m	3.600E-02	Sb-128	9.640E-01	Te-128\$	
2 Sb-128	9.01h	1.000E+00	Te-128\$			

Sb-129

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Sb-129	4.40h	2.262E-01	Te-129m	7.738E-01	Te-129	
2 Te-129m	33.6d	6.300E-01	Te-129	3.700E-01	I-129	
3 Te-129	69.6m	1.000E+00	I-129			
4 I-129	1.57E+7y	1.000E+00	Xe-129\$			

Sb-131

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Sb-131	23.03m	8.207E-02	Te-131m	9.179E-01	Te-131	
2 Te-131m	30h	2.220E-01	Te-131	7.780E-01	I-131	
3 Te-131	25.0m	1.000E+00	I-131			
4 I-131	8.02070d	1.176E-02	Xe-131m	9.882E-01	Xe-131\$	
5 Xe-131m	11.84d	1.000E+00	Xe-131\$			

Sb-133

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Sb-133	2.5m	1.734E-01	Te-133m	8.266E-01	Te-133	
2 Te-133m	55.4m	1.750E-01	Te-133	8.250E-01	I-133	
3 Te-133	12.5m	1.000E+00	I-133			
4 I-133	20.8h	2.885E-02	Xe-133m	9.711E-01	Xe-133	
5 Xe-133m	2.19d	1.000E+00	Xe-133			
6 Xe-133	5.243d	1.000E+00	Cs-133\$			

Te-113

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Te-113	1.7m	1.000E+00	Sb-113			
2 Sb-113	6.67m	2.243E-01	Sn-113m	7.757E-01	Sn-113	
3 Sn-113m	21.4m	9.110E-01	Sn-113	8.900E-02	In-113\$	
4 Sn-113	115.09d	1.000E+00	In-113m	2.235E-05	In-113\$	
5 In-113m	1.6579h	1.000E+00	In-113\$			

Te-114 ----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Te-114	15.2m	1.000E+00	Sb-114			
2 Sb-114	3.49m	1.000E+00	Sn-114\$			

Te-115 ----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Te-115	5.8m	1.000E+00	Sb-115			
2 Sb-115	32.1m	1.000E+00	Sn-115\$			

Te-115m ----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Te-115m	6.7m	1.000E+00	Sb-115			
2 Sb-115	32.1m	1.000E+00	Sn-115\$			

Te-116 ----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Te-116	2.49h	1.000E+00	Sb-116			
2 Sb-116	15.8m	1.000E+00	Sn-116\$			

Te-117 ----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Te-117	62m	1.000E+00	Sb-117			
2 Sb-117	2.80h	1.000E+00	Sn-117\$			

Te-118 ----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Te-118	6.00d	1.000E+00	Sb-118			
2 Sb-118	3.6m	1.000E+00	Sn-118\$			

Te-119 ----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Te-119	16.05h	1.000E+00	Sb-119			
2 Sb-119	38.19h	1.000E+00	Sn-119\$			

Te-119m

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Te-119m	4.70d	1.000E+00	Sb-119			
2 Sb-119	38.19h	1.000E+00	Sn-119\$			

Te-121m

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Te-121m	154d	8.860E-01	Te-121	1.140E-01	Sb-121\$	
2 Te-121	19.16d	1.000E+00	Sb-121\$			

Te-123m

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Te-123m	119.25d	1.000E+00	Te-123			
2 Te-123	6.00E+14y	1.000E+00	Sb-123\$			

Te-127m

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Te-127m	109d	9.760E-01	Te-127	2.400E-02	I-127\$	
2 Te-127	9.35h	1.000E+00	I-127\$			

Te-129

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Te-129	69.6m	1.000E+00	I-129			
2 I-129	1.57E+7y	1.000E+00	Xe-129\$			

Te-129m

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Te-129m	33.6d	6.300E-01	Te-129	3.700E-01	I-129	
2 Te-129	69.6m	1.000E+00	I-129			

3 I-129 1.57E+7y 1.000E+00 Xe-129\$

Te-131

----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Te-131	25.0m	1.000E+00	I-131			
2 I-131	8.02070d	1.176E-02	Xe-131m	9.882E-01	Xe-131\$	
3 Xe-131m	11.84d	1.000E+00	Xe-131\$			

Te-131m

----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Te-131m	30h	2.220E-01	Te-131	7.780E-01	I-131	
2 Te-131	25.0m	1.000E+00	I-131			
3 I-131	8.02070d	1.176E-02	Xe-131m	9.882E-01	Xe-131\$	
4 Xe-131m	11.84d	1.000E+00	Xe-131\$			

Te-132

----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Te-132	3.204d	1.000E+00	I-132			
2 I-132	2.295h	1.000E+00	Xe-132\$			

Te-133

----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Te-133	12.5m	1.000E+00	I-133			
2 I-133	20.8h	2.885E-02	Xe-133m	9.711E-01	Xe-133	
3 Xe-133m	2.19d	1.000E+00	Xe-133			
4 Xe-133	5.243d	1.000E+00	Cs-133\$			

Te-133m

----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Te						
2 Te-133	12.5m	1.000E+00	I-133			
3 I-133	20.8h	2.885E-02	Xe-133m	9.711E-01	Xe-133	
4 Xe-133m	2.19d	1.000E+00	Xe-133			
5 Xe-133	5.243d	1.000E+00	Cs-133\$			

Te-134

----- Daughter

Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Te-134 41.8m 1.000E+00 I-134
 2 I-134 52.5m 1.000E+00 Xe-134\$

I-118

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 I-118 13.7m 1.000E+00 Te-118
 2 Te-118 6.00d 1.000E+00 Sb-118
 3 Sb-118 3.6m 1.000E+00 Sn-118\$

I-118m

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 I-118m 8.5m 1.000E+00 Te-118
 2 Te-118 6.00d 1.000E+00 Sb-118
 3 Sb-118 3.6m 1.000E+00 Sn-118\$

I-119

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 I-119 19.1m 9.905E-01 Te-119 9.542E-03 Te-119m
 2 Te-119 16.05h 1.000E+00 Sb-119
 3 Te-119m 4.70d 1.000E+00 Sb-119
 4 Sb-119 38.19h 1.000E+00 Sn-119\$

I-121

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 I-121 2.12h 2.863E-03 Te-121m 9.971E-01 Te-121
 2 Te-121m 154d 8.860E-01 Te-121 1.140E-01 Sb-121\$
 3 Te-121 19.16d 1.000E+00 Sb-121\$

I-123

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 I-123 13.27h 4.442E-05 Te-123m 1.000E+00 Te-123
 2 Te-123m 119.25d 1.000E+00 Te-123
 3 Te-123 6.00E+14y 1.000E+00 Sb-123\$

I-130m

----- Daughter					
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 I-130m	8.84m	8.400E-01	I-130	1.600E-01	Xe-130\$
2 I-130	12.36h	1.000E+00	Xe-130\$		

I-131

----- Daughter					
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 I-131	8.02070d	1.176E-02	Xe-131m	9.882E-01	Xe-131\$
2 Xe-131m	11.84d	1.000E+00	Xe-131\$		

I-132m

----- Daughter					
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 I-132m	1.387h	8.600E-01	I-132	1.400E-01	Xe-132\$
2 I-132	2.295h	1.000E+00	Xe-132\$		

I-133

----- Daughter					
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 I-133	20.8h	2.885E-02	Xe-133m	9.711E-01	Xe-133
2 Xe-133m	2.19d	1.000E+00	Xe-133		
3 Xe-133	5.243d	1.000E+00	Cs-133\$		

I-134m

----- Daughter					
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 I-134m	3.60m	9.770E-01	I-134	2.300E-02	Xe-134\$
2 I-134	52.5m	1.000E+00	Xe-134\$		

I-135

----- Daughter					
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 I-135	6.57h	1.657E-01	Xe-135m	8.343E-01	Xe-135
2 Xe-135m	15.29m	9.940E-01	Xe-135	6.000E-03	Cs-135
3 Xe-135	9.14h	1.000E+00	Cs-135		
4 Cs-135	2.3E+6y	1.000E+00	Ba-135\$		

Xe-120

----- Daughter

Products						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Xe-120	40m	1.000E+00	I-120			
2 I-120	81.6m	1.000E+00	Te-120\$			

Xe-121

----- Daughter

Products						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Xe-121	40.1m	1.000E+00	I-121			
2 I-121	2.12h	2.863E-03	Te-121m	9.971E-01	Te-121	
3 Te-121m	154d	8.860E-01	Te-121	1.140E-01	Sb-121\$	
4 Te-121	19.16d	1.000E+00	Sb-121\$			

Xe-122

----- Daughter

Products						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Xe-122	20.1h	1.000E+00	I-122			
2 I-122	3.63m	1.000E+00	Te-122\$			

Xe-123

----- Daughter

Products						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Xe-123	2.08h	1.000E+00	I-123			
2 I-123	13.27h	4.442E-05	Te-123m	1.000E+00	Te-123	
3 Te-123m	119.25d	1.000E+00	Te-123			
4 Te-123	6.00E+14y	1.000E+00	Sb-123\$			

Xe-125

----- Daughter

Products						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Xe-125	16.9h	1.000E+00	I-125			
2 I-125	59.400d	1.000E+00	Te-125\$			

Xe-127m

----- Daughter

Products						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Xe-127m	69.2s	1.000E+00	Xe-127			
2 Xe-127	36.4d	1.000E+00	I-127\$			

Xe-133m

-----						Daughter
Products	-----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Xe-133m	2.19d	1.000E+00	Xe-133			
2 Xe-133	5.243d	1.000E+00	Cs-133\$			

Xe-135

-----						Daughter
Products	-----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Xe-135	9.14h	1.000E+00	Cs-135			
2 Cs-135	2.3E+6y	1.000E+00	Ba-135\$			

Xe-135m

-----						Daughter
Products	-----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Xe-135m	15.29m	9.940E-01	Xe-135	6.000E-03	Cs-135	
2 Xe-135	9.14h	1.000E+00	Cs-135			
3 Cs-135	2.3E+6y	1.000E+00	Ba-135\$			

Xe-137

-----						Daughter
Products	-----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Xe-137	3.818m	1.000E+00	Cs-137			
2 Cs-137	30.1671y	9.440E-01	Ba-137m	5.600E-02	Ba-137\$	
3 Ba-137m	2.552m	1.000E+00	Ba-137\$			

Xe-138

-----						Daughter
Products	-----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Xe-138	14.08m	1.000E+00	Cs-138			
2 Cs-138	33.41m	1.000E+00	Ba-138\$			

Cs-121

-----						Daughter
Products	-----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Cs-121	155s	1.000E+00	Xe-121			
2 Xe-121	40.1m	1.000E+00	I-121			
3 I-121	2.12h	2.863E-03	Te-121m	9.971E-01	Te-121	
4 Te-121m	154d	8.860E-01	Te-121	1.140E-01	Sb-121\$	
5 Te-121	19.16d	1.000E+00	Sb-121\$			

Cs-121m

Products				Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3	
Nuclide f4	Nuclide						
1 Cs-121m	122s	1.700E-01	Cs-121	8.300E-01	Xe-121		
2 Cs-121	155s	1.000E+00	Xe-121				
3 Xe-121	40.1m	1.000E+00	I-121				
4 I-121	2.12h	2.863E-03	Te-121m	9.971E-01	Te-121		
5 Te-121m	154d	8.860E-01	Te-121	1.140E-01	Sb-121\$		
6 Te-121	19.16d	1.000E+00	Sb-				

Cs-123

Products				Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3	
Nuclide f4	Nuclide						
1 Cs-123	5.88m	1.000E+00	Xe-123				
2 Xe-123	2.08h	1.000E+00	I-123				
3 I-123	13.27h	4.442E-05	Te-123m	1.000E+00	Te-123		
4 Te-123m	119.25d	1.000E+00	Te-123				
5 Te-123	6.00E+14y	1.000E+00	Sb-123\$				

Cs-125

Products				Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3	
Nuclide f4	Nuclide						
1 Cs-125	45m	1.000E+00	Xe-125				
2 Xe-125	16.9h	1.000E+00	I-125				
3 I-125	59.400d	1.000E+00	Te-125\$				

Cs-127

Products				Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3	
Nuclide f4	Nuclide						
1 Cs-127	6.25h	1.000E+00	Xe-127				
2 Xe-127	36.4d	1.000E+00	I-127\$				

Cs-130m

Products				Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3	
Nuclide f4	Nuclide						
1 Cs-130m	3.46m	9.984E-01	Cs-130	1.600E-03	Xe-130\$		
2 Cs-130	29.21m	9.840E-01	Xe-130\$	1.600E-02	Ba-130\$		

Cs-134m

Products				Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3	
Nuclide f4	Nuclide						

Nuclide	f4	Nuclide	
1 Cs-134m	2.903h	1.000E+00	Cs-134
2 Cs-134	2.0648y	1.000E+00	Ba-134\$ 3.000E-06 Xe-134\$

Cs-135m

-----				Daughter
Products	-----			
Nuclide	Halflife	f1	Nuclide	f2
Nuclide	f4	Nuclide		f3
1 Cs-135m	53m	1.000E+00	Cs-135	
2 Cs-135	2.3E+6y	1.000E+00	Ba-135\$	

Cs-137

-----				Daughter
Products	-----			
Nuclide	Halflife	f1	Nuclide	f2
Nuclide	f4	Nuclide		f3
1 Cs-137	30.1671y	9.440E-01	Ba-137m 5.600E-02	Ba-137\$
2 Ba-137m	2.552m	1.000E+00	Ba-137\$	

Cs-138m

-----				Daughter
Products	-----			
Nuclide	Halflife	f1	Nuclide	f2
Nuclide	f4	Nuclide		f3
1 Cs-138m	2.91m	8.100E-01	Cs-138 1.900E-01	Ba-138\$
2 Cs-138	33.41m	1.000E+00	Ba-138\$	

Cs-139

-----				Daughter
Products	-----			
Nuclide	Halflife	f1	Nuclide	f2
Nuclide	f4	Nuclide		f3
1 Cs-139	9.27m	1.000E+00	Ba-139	
2 Ba-139	83.06m	1.000E+00	La-139\$	

Cs-140

-----				Daughter
Products	-----			
Nuclide	Halflife	f1	Nuclide	f2
Nuclide	f4	Nuclide		f3
1 Cs-140	63.7s	1.000E+00	Ba-140	
2 Ba-140	12.752d	1.000E+00	La-140	
3 La-140	1.6781d	1.000E+00	Ce-140\$	

Ba-124

-----				Daughter
Products	-----			
Nuclide	Halflife	f1	Nuclide	f2
Nuclide	f4	Nuclide		f3
1 Ba-124	11.0m	1.000E+00	Cs-124	
2 Cs-124	30.8s	1.000E+00	Xe-124\$	

Ba-126 ----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ba-126	100m	1.000E+00	Cs-126			
2 Cs-126	1.64m	1.000E+00	Xe-126\$			

Ba-127 ----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ba-127	12.7m	1.000E+00	Cs-127			
2 Cs-127	6.25h	1.000E+00	Xe-127			
3 Xe-127	36.4d	1.000E+00	I-127\$			

Ba-128 ----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ba-128	2.43d	1.000E+00	Cs-128			
2 Cs-128	3.640m	1.000E+00	Xe-128\$			

Ba-129 ----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ba-129	2.23h	1.000E+00	Cs-129			
2 Cs-129	32.06h	1.000E+00	Xe-129\$			

Ba-129m ----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ba-129m	2.16h	1.000E+00	Cs-129			
2 Cs-129	32.06h	1.000E+00	Xe-129\$			

Ba-131 ----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ba-131	11.50d	1.000E+00	Cs-131			
2 Cs-131	9.689d	1.000E+00	Xe-131\$			

Ba-131m ----- Daughter

Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Ba-131m	14.6m	1.000E+00	Ba-131			
2 Ba-131	11.50d	1.000E+00	Cs-131			
3 Cs-131	9.689d	1.000E+00	Xe-131\$			

Ba-133m

----- Daughter						
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Ba-133m	38.9h	9.999E-01	Ba-133	9.600E-05	Cs-133\$	
2 Ba-133	10.52y	1.000E+00	Cs-133\$			

Ba-140

----- Daughter						
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Ba-140	12.752d	1.000E+00	La-140			
2 La-140	1.6781d	1.000E+00	Ce-140\$			

Ba-141

----- Daughter						
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Ba-141	18.27m	1.000E+00	La-141			
2 La-141	3.92h	1.000E+00	Ce-141			
3 Ce-141	32.508d	1.000E+00	Pr-141\$			

Ba-142

----- Daughter						
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Ba-142	10.6m	1.000E+00	La-142			
2 La-142	91.1m	1.000E+00	Ce-142\$			

La-128

----- Daughter						
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 La-128	5.18m	1.000E+00	Ba-128			
2 Ba-128	2.43d	1.000E+00	Cs-128			
3 Cs-128	3.640m	1.000E+00	Xe-128\$			

La-129

----- Daughter						
Products -----						

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4		Nuclide				
1 La-129	11.6m	9.238E-01	Ba-129	7.616E-02	Ba-129m	
2 Ba-129	2.23h	1.000E+00	Cs-129			
3 Ba-129m	2.16h	1.000E+00	Cs-129			
4 Cs-129	32.06h	1.000E+00	Xe-129\$			

La-131

Products			Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4		Nuclide			
1 La-131	59m	1.000E+00	Ba-131		
2 Ba-131	11.50d	1.000E+00	Cs-131		
3 Cs-131	9.689d	1.000E+00	Xe-131\$		

La-132m

Products			Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4		Nuclide			
1 La-132m	24.3m	7.600E-01	La-132	2.400E-01	Ba-132\$
2 La-132	4.8h	1.000E+00	Ba-132\$		

La-133

Products			Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4		Nuclide			
1 La-133	3.912h	1.000E+00	Ba-133		
2 Ba-133	10.52y	1.000E+00	Cs-133\$		

La-141

Products			Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4		Nuclide			
1 La-141	3.92h	1.000E+00	Ce-141		
2 Ce-141	32.508d	1.000E+00	Pr-141\$		

La-143

Products			Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4		Nuclide			
1 La-143	14.2m	1.000E+00	Ce-143		
2 Ce-143	33.039h	1.000E+00	Pr-143		
3 Pr-143	13.57d	1.000E+00	Nd-		

Ce-130

Products			Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4		Nuclide			

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ce-130	22.9m	1.000E+00	La-130			
2 La-130	8.7m	1.000E+00	Ba-130\$			

Ce-131

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ce-131	10.2m	1.000E+00	La-131			
2 La-131	59m	1.000E+00	Ba-131			
3 Ba-131	11.50d	1.000E+00	Cs-131			
4 Cs-131	9.689d	1.000E+00	Xe-131\$			

Ce-132

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ce-132	3.51h	1.000E+00	La-132			
2 La-132	4.8h	1.000E+00	Ba-132\$			

Ce-133

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ce-133	97m	1.000E+00	La-133			
2 La-133	3.912h	1.000E+00	Ba-133			
3 Ba-133	10.52y	1.000E+00	Cs-133\$			

Ce-133m

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ce-133m	4.9h	1.000E+00	La-133			
2 La-133	3.912h	1.000E+00	Ba-133			
3 Ba-133	10.52y	1.000E+00	Cs-133\$			

Ce-134

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ce-134	3.16d	1.000E+00	La-134			
2 La-134	6.45m	1.000E+00	Ba-134\$			

Ce-135

Products				Daughter		
----------	--	--	--	----------	--	--

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ce-135	17.7h	1.000E+00	La-135			
2 La-135	19.5h	1.000E+00	Ba-135\$			

Ce-137

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ce-137	9.0h	1.000E+00	La-137			
2 La-137	6.0E+4y	1.000E+00	Ba-137\$			

Ce-137m

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ce-137m	34.4h	9.922E-01	Ce-137	7.800E-03	La-137	
2 Ce-137	9.0h	1.000E+00	La-137			
3 La-137	6.0E+4y	1.000E+00	Ba-137\$			

Ce-143

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ce-143	33.039h	1.000E+00	Pr-143			
2 Pr-143	13.57d	1.000E+00	Nd-143\$			

Ce-144

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ce-144	284.91d	9.770E-03	Pr-144m	9.902E-01	Pr-144	
2 Pr-144m	7.2m	9.993E-01	Pr-144	7.000E-04	Nd-144	
3 Pr-144	17.28m	1.000E+00	Nd-144			
4 Nd-144	2.29E+15y	1.000E+00	Ce-140\$			

Ce-145

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ce-145	3.01m	1.000E+00	Pr-145			
2 Pr-145	5.984h	1.000E+00	Nd-145\$			

Pr-134

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
---------	----------	----	---------	----	---------	----

Nuclide	f4	Nuclide	
1 Pr-134		11m	1.000E+00 Ce-134
2 Ce-134		3.16d	1.000E+00 La-134
3 La-134		6.45m	1.000E+00 Ba-134\$

Pr-134m

Products				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4			Nuclide		
1 Pr-134m	17m	1.000E+00	Ce-134		
2 Ce-134	3.16d	1.000E+00	La-134		
3 La-134	6.45m	1.000E+00	Ba-134\$		

Pr-135

Products				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4			Nuclide		
1 Pr-135	24m	1.000E+00	Ce-135		
2 Ce-135	17.7h	1.000E+00	La-135		
3 La-135	19.5h	1.000E+00	Ba-135\$		

Pr-137

Products				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4			Nuclide		
1 Pr-137	1.28h	1.000E+00	Ce-137		
2 Ce-137	9.0h	1.000E+00	La-137		
3 La-137	6.0E+4y	1.000E+00	Ba-137\$		

Pr-139

Products				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4			Nuclide		
1 Pr-139	4.41h	1.000E+00	Ce-139		
2 Ce-139	137.641d	1.000E+00	La-139\$		

Pr-142m

Products				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4			Nuclide		
1 Pr-142m	14.6m	1.000E+00	Pr-142		
2 Pr-142	19.12h	9.998E-01	Nd-142\$	1.640E-04	Ce-142\$

Pr-144

Products				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3

Nuclide	f4	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Pr-144		17.28m	1.000E+00	Nd-144			
2 Nd-144		2.29E+15y	1.000E+00	Ce-140\$			

Pr-144m

Products				Daughter			
Nuclide	f4	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Pr-144m		7.2m	9.993E-01	Pr-144	7.000E-04	Nd-144	
2 Pr-144		17.28m	1.000E+00	Nd-144			
3 Nd-144		2.29E+15y	1.000E+00	Ce-140\$			

Pr-147

Products				Daughter			
Nuclide	f4	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Pr-147		13.4m	1.000E+00	Nd-147			
2 Nd-147		10.98d	1.000E+00	Pm-147			
3 Pm-147		2.6234y	1.000E+00	Sm-147			
4 Sm-147		1.060E11y	1.000E+00	Nd-143\$			

Nd-134

Products				Daughter			
Nuclide	f4	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Nd-134		8.5m	1.000E+00	Pr-134m			
2 Pr-134m		17m	1.000E+00	Ce-134			
3 Ce-134		3.16d	1.000E+00	La-134			
4 La-134		6.45m	1.000E+00	Ba-134\$			

Nd-135

Products				Daughter			
Nuclide	f4	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Nd-135		12.4m	1.000E+00	Pr-135			
2 Pr-135		24m	1.000E+00	Ce-135			
3 Ce-135		17.7h	1.000E+00	La-135			
4 La-135		19.5h	1.000E+00	Ba-135\$			

Nd-136

Products				Daughter			
Nuclide	f4	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Nd-136		50.65m	1.000E+00	Pr-136			
2 Pr-136		13.1m	1.000E+00	Ce-136\$			

Nd-137

----- Daughter

Products	Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide						
1 Nd-137	38.5m	1.000E+00	Pr-137				
2 Pr-137	1.28h	1.000E+00	Ce-137				
3 Ce-137	9.0h	1.000E+00	La-137				
4 La-137	6.0E+4y	1.000E+00	Ba-137\$				

Nd-138 ----- Daughter

Products	Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide						
1 Nd-138	5.04h	1.000E+00	Pr-138				
2 Pr-138	1.45m	1.000E+00	Ce-138\$				

Nd-139 ----- Daughter

Products	Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide						
1 Nd-139	29.7m	1.000E+00	Pr-139				
2 Pr-139	4.41h	1.000E+00	Ce-139				
3 Ce-139	137.641d	1.000E+00	La-139\$				

Nd-139m ----- Daughter

Products	Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide						
1 Nd-139m	5.50h	1.180E-01	Nd-139	8.820E-01	Pr-139		
2 Nd-139	29.7m	1.000E+00	Pr-139				
3 Pr-139	4.41h	1.000E+00	Ce-139				
4 Ce-139	137.641d	1.000E+00	La-139\$				

Nd-140 ----- Daughter

Products	Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide						
1 Nd-140	3.37d	1.000E+00	Pr-140				
2 Pr-140	3.39m	1.000E+00	Ce-140\$				

Nd-141m ----- Daughter

Products	Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide						
1 Nd-141m	62.0s	9.997E-01	Nd-141	3.200E-04	Pr-141\$		
2 Nd-141	2.49h	1.000E+00	Pr-141\$				

Nd-147

-----						Daughter
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Nd-147	10.98d	1.000E+00	Pm-147			
2 Pm-147	2.6234y	1.000E+00	Sm-147			
3 Sm-147	1.060E11y	1.000E+00	Nd-143\$			

Nd-149

-----						Daughter
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Nd-149	1.728h	1.000E+00	Pm-149			
2 Pm-149	53.08h	1.000E+00	Sm-149\$			

Nd-151

-----						Daughter
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Nd-151	12.44m	1.000E+00	Pm-151			
2 Pm-151	28.40h	1.000E+00	Sm-151			
3 Sm-151	90y	1.000E+00	Eu-151\$			

Nd-152

-----						Daughter
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Nd-152	11.4m	1.000E+00	Pm-152			
2 Pm-152	4.12m	1.000E+00	Sm-152\$			

Pm-136

-----						Daughter
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Pm-136	107s	1.000E+00	Nd-136			
2 Nd-136	50.65m	1.000E+00	Pr-136			
3 Pr-136	13.1m	1.000E+00	Ce-136\$			

Pm-137m

-----						Daughter
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Pm-137m	2.4m	1.000E+00	Nd-137			
2 Nd-137	38.5m	1.000E+00	Pr-137			
3 Pr-137	1.28h	1.000E+00	Ce-137			
4 Ce-137	9.0h	1.000E+00	La-137			

5 La-137 6.0E+4y 1.000E+00 Ba-137\$

Pm-139

-----				Daughter	
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Pm-139	4.15m	1.000E+00	Nd-139		
2 Nd-139	29.7m	1.000E+00	Pr-139		
3 Pr-139	4.41h	1.000E+00	Ce-139		
4 Ce-139	137.641d	1.000E+00	La-139\$		

Pm-140

-----				Daughter	
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Pm-140	9.2s	1.000E+00	Nd-140		
2 Nd-140	3.37d	1.000E+00	Pr-140		
3 Pr-140	3.39m	1.000E+00	Ce-140\$		

Pm-140m

-----				Daughter	
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Pm-140m	5.95m	1.000E+00	Nd-140		
2 Nd-140	3.37d	1.000E+00	Pr-140		
3 Pr-140	3.39m	1.000E+00	Ce-140\$		

Pm-141

-----				Daughter	
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Pm-141	20.90m	1.665E-03	Nd-141m	9.983E-01	Nd-141
2 Nd-141m	62.0s	9.997E-01	Nd-141	3.200E-04	Pr-141\$
3 Nd-141	2.49h	1.000E+00	Pr-141\$		

Pm-144

-----				Daughter	
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Pm-144	363d	1.000E+00	Nd-144		
2 Nd-144	2.29E+15y	1.000E+00	Ce-140\$		

Pm-146

-----				Daughter	
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				

1 Pm-146	5.53y	3.400E-01	Sm-146	6.600E-01	Nd-146\$
2 Sm-146	1.03E+8y	1.000E+00	Nd-142\$		

Pm-147

-----				Daughter	
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Pm-147	2.6234y	1.000E+00	Sm-147		
2 Sm-147	1.060E11y	1.000E+00	Nd-143\$		

Pm-148

-----				Daughter	
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Pm-148	5.368d	1.000E+00	Sm-148		
2 Sm-148	7E+15y	1.000E+00	Nd-144		
3 Nd-144	2.29E+15y	1.000E+00	Ce-140\$		

Pm-148m

-----				Daughter	
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Pm-148m	41.29d	4.200E-02	Pm-148	9.580E-01	Sm-148
2 Pm-148	5.368d	1.000E+00	Sm-148		
3 Sm-148	7E+15y	1.000E+00	Nd-144		
4 Nd-144	2.29E+15y	1.000E+00	Ce-140\$		

Pm-151

-----				Daughter	
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Pm-151	28.40h	1.000E+00	Sm-151		
2 Sm-151	90y	1.000E+00	Eu-151\$		

Pm-153

-----				Daughter	
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Pm-153	5.25m	1.000E+00	Sm-153		
2 Sm-153	46.50h	1.000E+00	Eu-153\$		

Sm-139

-----				Daughter	
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Sm-139	2.57m	1.000E+00	Pm-139		

2	Pm-139	4.15m	1.000E+00	Nd-139
3	Nd-139	29.7m	1.000E+00	Pr-139
4	Pr-139	4.41h	1.000E+00	Ce-139
5	Ce-139	137.641d	1.000E+00	La-139\$

Sm-140

Products				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 Sm-140	14.82m	1.000E+00	Pm-140		
2 Pm-140	9.2s	1.000E+00	Nd-140		
3 Nd-140	3.37d	1.000E+00	Pr-140		
4 Pr-140	3.39m	1.000E+00	Ce-140\$		

Sm-141

Products				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 Sm-141	10.2m	1.000E+00	Pm-141		
2 Pm-141	20.90m	1.665E-03	Nd-141m	9.983E-01	Nd-141
3 Nd-141m	62.0s	9.997E-01	Nd-141	3.200E-04	Pr-141\$
4 Nd-141	2.49h	1.000E+00	Pr-141\$		

Sm-141m

Products				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 Sm-141m	22.6m	3.100E-03	Sm-141	9.969E-01	Pm-141
2 Sm-141	10.2m	1.000E+00	Pm-141		
3 Pm-141	20.90m	1.665E-03	Nd-141m	9.983E-01	Nd-141
4 Nd-141m	62.0s	9.997E-01	Nd-141	3.200E-04	Pr-141\$
5 Nd-141	2.49h	1.000E+00	Pr-141\$		

Sm-142

Products				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 Sm-142	72.49m	1.000E+00	Pm-142		
2 Pm-142	40.5s	1.000E+00	Nd-142\$		

Sm-143

Products				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 Sm-143	8.75m	1.000E+00	Pm-143		
2 Pm-143	265d	1.000E+00	Nd-143\$		

Sm-143m

```
----- Daughter
Products -----
  Nuclide  Halflife    f1    Nuclide  f2    Nuclide  f3
Nuclide  f4    Nuclide
  1 Sm-143m    66s  9.976E-01 Sm-143  2.400E-03 Pm-143
  2 Sm-143     8.75m 1.000E+00 Pm-143
  3 Pm-143    265d 1.000E+00 Nd-143$
```

Sm-145

```
----- Daughter
Products -----
  Nuclide  Halflife    f1    Nuclide  f2    Nuclide  f3
Nuclide  f4    Nuclide
  1 Sm-145    340d 1.000E+00 Pm-145
  2 Pm-145   17.7y 1.000E+00 Nd-145$ 2.800E-09 Pr-141$
```

Sm-148

```
----- Daughter
Products -----
  Nuclide  Halflife    f1    Nuclide  f2    Nuclide  f3
Nuclide  f4    Nuclide
  1 Sm-148    7E+15y 1.000E+00 Nd-144
  2 Nd-144   2.29E+15y 1.000E+00 Ce-140$
```

Sm-155

```
----- Daughter
Products -----
  Nuclide  Halflife    f1    Nuclide  f2    Nuclide  f3
Nuclide  f4    Nuclide
  1 Sm-155    22.3m 1.000E+00 Eu-155
  2 Eu-155    4.7611y 1.000E+00 Gd-155$
```

Sm-156

```
----- Daughter
Products -----
  Nuclide  Halflife    f1    Nuclide  f2    Nuclide  f3
Nuclide  f4    Nuclide
  1 Sm-156     9.4h 1.000E+00 Eu-156
  2 Eu-156   15.19d 1.000E+00 Gd-156$
```

Sm-157

```
----- Daughter
Products -----
  Nuclide  Halflife    f1    Nuclide  f2    Nuclide  f3
Nuclide  f4    Nuclide
  1 Sm-157     8.03m 1.000E+00 Eu-157
  2 Eu-157   15.18h 1.000E+00 Gd-157$
```

Eu-142

```
----- Daughter
Products -----
```

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Eu-142	2.34s	1.000E+00	Sm-142			
2 Sm-142	72.49m	1.000E+00	Pm-142			
3 Pm-142	40.5s	1.000E+00	Nd-142\$			

Eu-142m

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Eu-142m	1.223m	1.000E+00	Sm-142			
2 Sm-142	72.49m	1.000E+00	Pm-142			
3 Pm-142	40.5s	1.000E+00	Nd-142\$			

Eu-143

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Eu-143	2.59m	1.207E-03	Sm-143m	9.988E-01	Sm-143	
2 Sm-143m	66s	9.976E-01	Sm-143	2.400E-03	Pm-143	
3 Sm-143	8.75m	1.000E+00	Pm-143			
4 Pm-143	265d	1.000E+00	Nd-143\$			

Eu-145

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Eu-145	5.93d	1.000E+00	Sm-145			
2 Sm-145	340d	1.000E+00	Pm-145			
3 Pm-145	17.7y	1.000E+00	Nd-145\$	2.800E-09	Pr-141\$	

Eu-146

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Eu-146	4.61d	1.000E+00	Sm-146			
2 Sm-146	1.03E+8y	1.000E+00	Nd-142\$			

Eu-147

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Eu-147	24.1d	1.000E+00	Sm-147	2.200E-05	Pm-143	
2 Sm-147	1.060E11y	1.000E+00	Nd-143\$			
3 Pm-143	265d	1.000E+00	Nd-143\$			

Eu-148

----- Daughter

Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide	f4	Nuclide				
1 Eu-148	54.5d	1.000E+00	Sm-148	9.400E-09	Pm-144	
2 Sm-148	7E+15y	1.000E+00	Nd-144			
3 Pm-144	363d	1.000E+00	Nd-144			
4 Nd-144	2.29E+15y	1.000E+00	Ce-140\$			

Eu-150m

----- Daughter

Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide	f4	Nuclide				
1 Eu-150m	12.8h	8.900E-01	Gd-150	1.100E-01	Sm-150\$	
2 Gd-150	1.79E+6y	1.000E+00	Sm-146			
3 Sm-146	1.03E+8y	1.000E+00	Nd-142\$			

Eu-152

----- Daughter

Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide	f4	Nuclide				
1 Eu-152	13.537y	2.790E-01	Gd-152	7.210E-01	Sm-152\$	
2 Gd-152	1.08E+14y	1.000E+00	Sm-148			
3 Sm-148	7E+15y	1.000E+00	Nd-144			
4 Nd-144	2.29E+15y	1.000E+00	Ce-140\$			

Eu-152m

----- Daughter

Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide	f4	Nuclide				
1 Eu-152m	9.3116h	7.200E-01	Gd-152	2.800E-01	Sm-152\$	
2 Gd-152	1.08E+14y	1.000E+00	Sm-148			
3 Sm-148	7E+15y	1.000E+00	Nd-144			
4 Nd-144	2.29E+15y	1.000E+00	Ce-140\$			

Eu-152n

----- Daughter

Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide	f4	Nuclide				
1 Eu-152n	96m	1.000E+00	Eu-152			
2 Eu-152	13.537y	2.790E-01	Gd-152	7.210E-01	Sm-152\$	
3 Gd-152	1.08E+14y	1.000E+00	Sm-148			
4 Sm-148	7E+15y	1.000E+00	Nd-144			
5 Nd-144	2.29E+15y	1.000E+00	Ce-140\$			

Eu-154m

----- Daughter

Products -----						
----------------	--	--	--	--	--	--

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Eu-154m	46.0m	1.000E+00	Eu-154			
2 Eu-154	8.593y	9.998E-01	Gd-154\$	2.000E-04	Sm-154\$	

Eu-159

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Eu-159	18.1m	1.000E+00	Gd-159			
2 Gd-159	18.479h	1.000E+00	Tb-159\$			

Gd-142

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Gd-142	70.2s	1.000E+00	Eu-142			
2 Eu-142	2.34s	1.000E+00	Sm-142			
3 Sm-142	72.49m	1.000E+00	Pm-142			
4 Pm-142	40.5s	1.000E+00	Nd-142\$			

Gd-143m

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Gd-143m	110.0s	1.000E+00	Eu-143			
2 Eu-143	2.59m	1.207E-03	Sm-143m	9.988E-01	Sm-143	
3 Sm-143m	66s	9.976E-01	Sm-143	2.400E-03	Pm-143	
4 Sm-143	8.75m	1.000E+00	Pm-143			
5 Pm-143	265d	1.000E+00	Nd-143\$			

Gd-144

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Gd-144	4.47m	1.000E+00	Eu-144			
2 Eu-144	10.2s	1.000E+00	Sm-144\$			

Gd-145

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Gd-145	23.0m	1.000E+00	Eu-145			
2 Eu-145	5.93d	1.000E+00	Sm-145			
3 Sm-145	340d	1.000E+00	Pm-145			
4 Pm-145	17.7y	1.000E+00	Nd-145\$	2.800E-09	Pr-141\$	

Gd-145m

					----- Daughter	
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Gd-145m	85s	9.430E-01	Gd-145	5.700E-02	Eu-145	
2 Gd-145	23.0m	1.000E+00	Eu-145			
3 Eu-145	5.93d	1.000E+00	Sm-145			
4 Sm-145	340d	1.000E+00	Pm-145			
5 Pm-145	17.7y	1.000E+00	Nd-145\$	2.800E-09	Pr-141\$	

Gd-146

					----- Daughter	
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide	f4	Nuclide				
1 Gd-146	48.27d	1.000E+00	Eu-146			
2 Eu-146	4.61d	1.000E+00	Sm-146			
3 Sm-146	1.03E+8y	1.000E+00	Nd-142\$			

Gd-147

-----					Daughter	
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide	f4	Nuclide				
1 Gd-147	38.1h	1.000E+00	Eu-147			
2 Eu-147	24.1d	1.000E+00	Sm-147	2.200E-05	Pm-143	
3 Sm-147	1.060E11y	1.000E+00	Nd-143\$			
4 Pm-143	265d	1.000E+00	Nd-143\$			

Gd-149

				----- Daughter		
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Gd-149	9.28d	1.000E+00	Eu-149			
2 Eu-149	93.1d	1.000E+00	Sm-149\$			

Gd-150

				----- Daughter		
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Gd-150	1.79E+6y	1.000E+00	Sm-146			
2 Sm-146	1.03E+8y	1.000E+00	Nd-142\$			

Gd-151

-----					Daughter	
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Gd-151	124d	1.000E-08	Sm-147	1.000E+00	Eu-151	\$

2 Sm-147 1.060E11y 1.000E+00 Nd-143\$

Gd-152

```

----- Daughter
Products -----
  Nuclide  Halflife    f1    Nuclide  f2    Nuclide  f3
Nuclide  f4    Nuclide
  1 Gd-152  1.08E+14y  1.000E+00 Sm-148
  2 Sm-148    7E+15y  1.000E+00 Nd-144
  3 Nd-144  2.29E+15y  1.000E+00 Ce-140$

```

Gd-162

```

----- Daughter
Products -----
  Nuclide  Halflife    f1    Nuclide  f2    Nuclide  f3
Nuclide  f4    Nuclide
  1 Gd-162    8.4m  1.000E+00 Tb-162
  2 Tb-162    7.60m  1.000E+00 Dy-162$

```

Tb-146

```

----- Daughter
Products -----
  Nuclide  Halflife    f1    Nuclide  f2    Nuclide  f3
Nuclide  f4    Nuclide
  1 Tb-146    23s  1.000E+00 Gd-146
  2 Gd-146   48.27d  1.000E+00 Eu-146
  3 Eu-146    4.61d  1.000E+00 Sm-146
  4 Sm-146   1.03E+8y  1.000E+00 Nd-142$

```

Tb-147

```

----- Daughter
Products -----
  Nuclide  Halflife    f1    Nuclide  f2    Nuclide  f3
Nuclide  f4    Nuclide
  1 Tb-147    1.64h  1.000E+00 Gd-147
  2 Gd-147    38.1h  1.000E+00 Eu-147
  3 Eu-147    24.1d  1.000E+00 Sm-147  2.200E-05 Pm-143
  4 Sm-147   1.060E11y  1.000E+00 Nd-143$
  5 Pm-143    265d  1.000E+00 Nd-143$

```

Tb-147m

```

----- Daughter
Products -----
  Nuclide  Halflife    f1    Nuclide  f2    Nuclide  f3
Nuclide  f4    Nuclide
  1 Tb-147m   1.87m  1.000E+00 Gd-147
  2 Gd-147    38.1h  1.000E+00 Eu-147
  3 Eu-147    24.1d  1.000E+00 Sm-147  2.200E-05 Pm-143
  4 Sm-147   1.060E11y  1.000E+00 Nd-143$
  5 Pm-143    265d  1.000E+00 Nd-143$

```

Tb-148

-----						Daughter
Products	-----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Tb-148	60m	1.000E+00	Gd-148			
2 Gd-148	74.6y	1.000E+00	Sm-144\$			

Tb-148m

-----						Daughter
Products	-----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Tb-148m	2.20m	1.000E+00	Gd-148			
2 Gd-148	74.6y	1.000E+00	Sm-144\$			

Tb-149

-----						Daughter
Products	-----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Tb-149	4.118h	8.330E-01	Gd-149	1.670E-01	Eu-145	
2 Gd-149	9.28d	1.000E+00	Eu-149			
3 Eu-145	5.93d	1.000E+00	Sm-145			
4 Eu-149	93.1d	1.000E+00	Sm-149\$			
5 Sm-145	340d	1.000E+00	Pm-145			
6 Pm-145	17.7y	1.000E+00	Nd-145\$	2.800E-09	Pr-141\$	

Tb-149m

-----						Daughter
Products	-----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Tb-149m	4.16m	9.998E-01	Gd-149	2.200E-04	Eu-145	
2 Gd-149	9.28d	1.000E+00	Eu-149			
3 Eu-145	5.93d	1.000E+00	Sm-145			
4 Eu-149	93.1d	1.000E+00	Sm-149\$			
5 Sm-145	340d	1.000E+00	Pm-145			
6 Pm-145	17.7y	1.000E+00	Nd-145\$	2.800E-09	Pr-141\$	

Tb-150

-----						Daughter
Products	-----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Tb-150	3.48h	1.000E+00	Gd-150	7.000E-06	Eu-146	
2 Gd-150	1.79E+6y	1.000E+00	Sm-146			
3 Eu-146	4.61d	1.000E+00	Sm-146			
4 Sm-146	1.03E+8y	1.000E+00	Nd-142\$			

Tb-150m

-----						Daughter
Products	-----					

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Tb-150m	5.8m	1.000E+00	Gd-150			
2 Gd-150	1.79E+6y	1.000E+00	Sm-146			
3 Sm-146	1.03E+8y	1.000E+00	Nd-142\$			

Tb-151

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Tb-151	17.609h	1.000E+00	Gd-151	9.500E-05	Eu-147	
2 Gd-151	124d	1.000E-08	Sm-147	1.000E+00	Eu-151\$	
3 Eu-147	24.1d	1.000E+00	Sm-147	2.200E-05	Pm-143	
4 Sm-147	1.060E11y	1.000E+00	Nd-143\$			
5 Pm-143	265d	1.000E+00	Nd-143\$			

Tb-151m

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Tb-151m	25s	9.340E-01	Tb-151	6.600E-02	Gd-151	
2 Tb-151	17.609h	1.000E+00	Gd-151	9.500E-05	Eu-147	
3 Gd-151	124d	1.000E-08	Sm-147	1.000E+00	Eu-151\$	
4 Eu-147	24.1d	1.000E+00	Sm-147	2.200E-05	Pm-143	
5 Sm-147	1.060E11y	1.000E+00	Nd-143\$			
6 Pm-143	265d	1.000E+00	Nd-143\$			

Tb-152

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Tb-152	17.5h	1.000E+00	Gd-152			
2 Gd-152	1.08E+14y	1.000E+00	Sm-148			
3 Sm-148	7E+15y	1.000E+00	Nd-144			
4 Nd-144	2.29E+15y	1.000E+00	Ce-140\$			

Tb-152m

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Tb-152m	4.2m	7.880E-01	Tb-152	2.120E-01	Gd-152	
2 Tb-152	17.5h	1.000E+00	Gd-152			
3 Gd-152	1.08E+14y	1.000E+00	Sm-148			
4 Sm-148	7E+15y	1.000E+00	Nd-144			
5 Nd-144	2.29E+15y	1.000E+00	Ce-140\$			

Tb-153

----- Daughter

Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Tb-153 2.34d 1.000E+00 Gd-153
 2 Gd-153 240.4d 1.000E+00 Eu-153\$

Tb-156m

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Tb-156m 24.4h 1.000E+00 Tb-156
 2 Tb-156 5.35d 1.000E+00 Gd-156\$

Tb-156n

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Tb-156n 5.3h 1.000E+00 Tb-156
 2 Tb-156 5.35d 1.000E+00 Gd-156\$

Tb-165

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Tb-165 2.11m 8.903E-01 Dy-165m 1.097E-01 Dy-165
 2 Dy-165m 1.257m 9.776E-01 Dy-165 2.240E-02 Ho-165\$
 3 Dy-165 2.334h 1.000E+00 Ho-165\$

Dy-148

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Dy-148 3.3m 1.000E+00 Tb-148
 2 Tb-148 60m 1.000E+00 Gd-148
 3 Gd-148 74.6y 1.000E+00 Sm-144\$

Dy-149

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Dy-149 4.20m 5.668E-01 Tb-149 4.332E-01 Tb-149m
 2 Tb-149 4.118h 8.330E-01 Gd-149 1.670E-01 Eu-145
 3 Tb-149m 4.16m 9.998E-01 Gd-149 2.200E-04 Eu-145
 4 Gd-149 9.28d 1.000E+00 Eu-149
 5 Eu-145 5.93d 1.000E+00 Sm-145
 6 Eu-149 93.1d 1.000E+00 Sm-149\$
 7 Sm-145 340d 1.000E+00 Pm-145

8 Pm-145 17.7y 1.000E+00 Nd-145\$ 2.800E-09 Pr-141\$

Dy-150

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Dy-150	7.17m	6.400E-01	Tb-150	3.600E-01	Gd-146	
2 Tb-150	3.48h	1.000E+00	Gd-150	7.000E-06	Eu-146	
3 Gd-146	48.27d	1.000E+00	Eu-146			
4 Gd-150	1.79E+6y	1.000E+00	Sm-146			
5 Eu-146	4.61d	1.000E+00	Sm-146			
6 Sm-146	1.03E+8y	1.000E+00	Nd-142\$			

Dy-151

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Dy-151	17.9m	4.102E-01	Tb-151m	5.338E-01	Tb-151	
5.600E-02 Gd-147						
2 Tb-151m	25s	9.340E-01	Tb-151	6.600E-02	Gd-151	
3 Tb-151	17.609h	1.000E+00	Gd-151	9.500E-05	Eu-147	
4 Gd-147	38.1h	1.000E+00	Eu-147			
5 Gd-151	124d	1.000E-08	Sm-147	1.000E+00	Eu-151\$	
6 Eu-147	24.1d	1.000E+00	Sm-147	2.200E-05	Pm-143	
7 Sm-147	1.060E11y	1.000E+00	Nd-143\$			
8 Pm-143	265d	1.000E+00	Nd-143\$			

Dy-152

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Dy-152	2.38h	9.990E-01	Tb-152	1.000E-03	Gd-148	
2 Tb-152	17.5h	1.000E+00	Gd-152			
3 Gd-148	74.6y	1.000E+00	Sm-144\$			
4 Gd-152	1.08E+14y	1.000E+00	Sm-148			
5 Sm-148	7E+15y	1.000E+00	Nd-144			
6 Nd-144	2.29E+15y	1.000E+00	Ce-140\$			

Dy-153

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Dy-153	6.4h	1.000E+00	Tb-153	9.400E-05	Gd-149	
2 Tb-153	2.34d	1.000E+00	Gd-153			
3 Gd-149	9.28d	1.000E+00	Eu-149			
4 Gd-153	240.4d	1.000E+00	Eu-153\$			
5 Eu-149	93.1d	1.000E+00	Sm-149\$			

Dy-154

Products -----				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4		Nuclide				
1 Dy-154	3.0E+6y	1.000E+00	Gd-150			
2 Gd-150	1.79E+6y	1.000E+00	Sm-146			
3 Sm-146	1.03E+8y	1.000E+00	Nd-142\$			

Dy-155

Products -----				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4		Nuclide				
1 Dy-155	9.9h	1.000E+00	Tb-155			
2 Tb-155	5.32d	1.000E+00	Gd-155\$			

Dy-157

Products -----				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4		Nuclide				
1 Dy-157	8.14h	1.000E+00	Tb-157			
2 Tb-157	71y	1.000E+00	Gd-157\$			

Dy-165m

Products -----				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4		Nuclide				
1 Dy-165m	1.257m	9.776E-01	Dy-165	2.240E-02	Ho-165\$	
2 Dy-165	2.334h	1.000E+00	Ho-165\$			

Dy-166

Products -----				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4		Nuclide				
1 Dy-166	81.6h	1.000E+00	Ho-166			
2 Ho-166	26.80h	1.000E+00	Er-166\$			

Dy-167

Products -----				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4		Nuclide				
1 Dy-167	6.20m	1.000E+00	Ho-167			
2 Ho-167	3.1h	1.000E+00	Er-167\$			

Dy-168

Products -----				Daughter		

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Dy-168	8.7m	1.000E+00	Ho-168			
2 Ho-168	2.99m	1.000E+00	Er-168\$			

Ho-150

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ho-150	76.8s	1.000E+00	Dy-150			
2 Dy-150	7.17m	6.400E-01	Tb-150	3.600E-01	Gd-146	
3 Tb-150	3.48h	1.000E+00	Gd-150	7.000E-06	Eu-146	
4 Gd-146	48.27d	1.000E+00	Eu-146			
5 Gd-150	1.79E+6y	1.000E+00	Sm-146			
6 Eu-146	4.61d	1.000E+00	Sm-146			
7 Sm-146	1.03E+8y	1.000E+00	Nd-142\$			

Ho-153

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ho-153	2.01m	9.995E-01	Dy-153	5.100E-04	Tb-149m	
2 Dy-153	6.4h	1.000E+00	Tb-153	9.400E-05	Gd-149	
3 Tb-149m	4.16m	9.998E-01	Gd-149	2.200E-04	Eu-145	
4 Tb-153	2.34d	1.000E+00	Gd-153			
5 Gd-149	9.28d	1.000E+00	Eu-149			
6 Gd-153	240.4d	1.000E+00	Eu-153\$			
7 Eu-149	93.1d	1.000E+00	Sm-149\$			
8 Eu-145	5.93d	1.000E+00	Sm-145			
9 Sm-145	340d	1.000E+00	Pm-145			
10 Pm-145	17.7y	1.000E+00	Nd-145\$	2.800E-09	Pr-141\$	

Ho-153m

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ho-153m	9.3m	9.982E-01	Dy-153	1.800E-03	Tb-149	
2 Dy-153	6.4h	1.000E+00	Tb-153	9.400E-05	Gd-149	
3 Tb-149	4.118h	8.330E-01	Gd-149	1.670E-01	Eu-145	
4 Tb-153	2.34d	1.000E+00	Gd-153			
5 Gd-149	9.28d	1.000E+00	Eu-149			
6 Gd-153	240.4d	1.000E+00	Eu-153\$			
7 Eu-149	93.1d	1.000E+00	Sm-149\$			
8 Eu-145	5.93d	1.000E+00	Sm-145			
9 Sm-145	340d	1.000E+00	Pm-145			
10 Pm-145	17.7y	1.000E+00	Nd-145\$	2.800E-09	Pr-141\$	

Ho-154

----- Daughter

Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Ho-154 11.76m 9.998E-01 Dy-154 1.900E-04 Tb-150
 2 Dy-154 3.0E+6y 1.000E+00 Gd-150
 3 Tb-150 3.48h 1.000E+00 Gd-150 7.000E-06 Eu-146
 4 Gd-150 1.79E+6y 1.000E+00 Sm-146
 5 Eu-146 4.61d 1.000E+00 Sm-146
 6 Sm-146 1.03E+8y 1.000E+00 Nd-142\$

Ho-154m

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Ho-154m 3.10m 1.000E+00 Dy-154 1.000E-05 Tb-150m
 2 Dy-154 3.0E+6y 1.000E+00 Gd-150
 3 Tb-150m 5.8m 1.000E+00 Gd-150
 4 Gd-150 1.79E+6y 1.000E+00 Sm-146
 5 Sm-146 1.03E+8y 1.000E+00 Nd-142\$

Ho-155

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Ho-155 48m 1.000E+00 Dy-155
 2 Dy-155 9.9h 1.000E+00 Tb-155
 3 Tb-155 5.32d 1.000E+00 Gd-155\$

Ho-157

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Ho-157 12.6m 1.000E+00 Dy-157
 2 Dy-157 8.14h 1.000E+00 Tb-157
 3 Tb-157 71y 1.000E+00 Gd-157\$

Ho-159

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Ho-159 33.05m 1.000E+00 Dy-159
 2 Dy-159 144.4d 1.000E+00 Tb-159\$

Ho-162m

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide

1 Ho-162m	67.0m	6.200E-01	Ho-162	3.800E-01	Dy-162\$
2 Ho-162	15.0m	1.000E+00	Dy-162\$		

Ho-164m

			----- Daughter		
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Ho-164m	38.0m	1.000E+00	Ho-164		
2 Ho-164	29m	6.000E-01	Dy-164\$	4.000E-01	Er-164\$

Ho-168m

			----- Daughter		
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Ho-168m	132s	1.000E+00	Ho-168		
2 Ho-168	2.99m	1.000E+00	Er-168\$		

Er-154

			----- Daughter		
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Er-154	3.73m	9.953E-01	Ho-154	4.700E-03	Dy-150
2 Ho-154	11.76m	9.998E-01	Dy-154	1.900E-04	Tb-150
3 Dy-150	7.17m	6.400E-01	Tb-150	3.600E-01	Gd-146
4 Dy-154	3.0E+6y	1.000E+00	Gd-150		
5 Tb-150	3.48h	1.000E+00	Gd-150	7.000E-06	Eu-146
6 Gd-150	1.79E+6y	1.000E+00	Sm-146		
7 Gd-146	48.27d	1.000E+00	Eu-146		
8 Eu-146	4.61d	1.000E+00	Sm-146		
9 Sm-146	1.03E+8y	1.000E+00	Nd-142\$		

Er-156

			----- Daughter		
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Er-156	19.5m	1.000E+00	Ho-156		
2 Ho-156	56m	1.000E+00	Dy-156\$		

Er-159

			----- Daughter		
Products -----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Er-159	36m	1.000E+00	Ho-159		
2 Ho-159	33.05m	1.000E+00	Dy-159		
3 Dy-159	144.4d	1.000E+00	Tb-159\$		

Er-161

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Er-161 3.21h 1.000E+00 Ho-161
 2 Ho-161 2.48h 1.000E+00 Dy-161\$

Er-163

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Er-163 75.0m 1.000E+00 Ho-163
 2 Ho-163 4570y 1.000E+00 Dy-163\$

Er-171

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Er-171 7.516h 1.000E+00 Tm-171
 2 Tm-171 1.92y 1.000E+00 Yb-171\$

Er-172

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Er-172 49.3h 1.000E+00 Tm-172
 2 Tm-172 63.6h 1.000E+00 Yb-172\$

Er-173

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Er-173 1.434m 1.000E+00 Tm-173
 2 Tm-173 8.24h 1.000E+00 Yb-173\$

Tm-161

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Tm-161 30.2m 1.000E+00 Er-161
 2 Er-161 3.21h 1.000E+00 Ho-161
 3 Ho-161 2.48h 1.000E+00 Dy-161\$

Tm-163

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3

Nuclide	f4	Nuclide	
1 Tm-163		1.810h	1.000E+00 Er-163
2 Er-163		75.0m	1.000E+00 Ho-163
3 Ho-163		4570y	1.000E+00 Dy-163\$

Tm-165

Products				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 Tm-165	30.06h	1.000E+00	Er-165		
2 Er-165	10.36h	1.000E+00	Ho-165\$		

Tm-175

Products				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 Tm-175	15.2m	1.000E+00	Yb-175		
2 Yb-175	4.185d	1.000E+00	Lu-175\$		

Yb-162

Products				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 Yb-162	18.87m	1.000E+00	Tm-162		
2 Tm-162	21.70m	1.000E+00	Er-162\$		

Yb-163

Products				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 Yb-163	11.05m	1.000E+00	Tm-163		
2 Tm-163	1.810h	1.000E+00	Er-163		
3 Er-163	75.0m	1.000E+00	Ho-163		
4 Ho-163	4570y	1.000E+00	Dy-163\$		

Yb-164

Products				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 Yb-164	75.8m	1.000E+00	Tm-164		
2 Tm-164	2.0m	1.000E+00	Er-164\$		

Yb-165

Products				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 Yb-165					
2 Tm-165					

1	Yb-165	9.9m	1.000E+00	Tm-165
2	Tm-165	30.06h	1.000E+00	Er-165
3	Er-165	10.36h	1.000E+00	Ho-165\$

Yb-166

Products -----				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Yb-166	56.7h	1.000E+00	Tm-166		
2 Tm-166	7.70h	1.000E+00	Er-166\$		

Yb-167

Products -----				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Yb-167	17.5m	1.000E+00	Tm-167		
2 Tm-167	9.25d	1.000E+00	Er-167\$		

Yb-177

Products -----				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Yb-177	1.911h	1.000E+00	Lu-177		
2 Lu-177	6.647d	1.000E+00	Hf-177\$		

Yb-178

Products -----				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Yb-178	74m	1.000E+00	Lu-178		
2 Lu-178	28.4m	1.000E+00	Hf-178\$		

Yb-179

Products -----				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Yb-179	8.0m	1.000E+00	Lu-179		
2 Lu-179	4.59h	1.000E+00	Hf-179\$		

Lu-165

Products -----				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Lu-165	10.74m	1.000E+00	Yb-165		
2 Yb-165	9.9m	1.000E+00	Tm-165		
3 Tm-165	30.06h	1.000E+00	Er-165		

4 Er-165 10.36h 1.000E+00 Ho-165\$

Lu-167

```
----- Daughter
Products -----
  Nuclide Halflife f1 Nuclide f2 Nuclide f3
Nuclide f4 Nuclide
  1 Lu-167 51.5m 1.000E+00 Yb-167
  2 Yb-167 17.5m 1.000E+00 Tm-167
  3 Tm-167 9.25d 1.000E+00 Er-167$
```

Lu-169

```
----- Daughter
Products -----
  Nuclide Halflife f1 Nuclide f2 Nuclide f3
Nuclide f4 Nuclide
  1 Lu-169 34.06h 1.000E+00 Yb-169
  2 Yb-169 32.026d 1.000E+00 Tm-169$
```

Lu-169m

```
----- Daughter
Products -----
  Nuclide Halflife f1 Nuclide f2 Nuclide f3
Nuclide f4 Nuclide
  1 Lu-169m 160s 1.000E+00 Lu-169
  2 Lu-169 34.06h 1.000E+00 Yb-169
  3 Yb-169 32.026d 1.000E+00 Tm-169$
```

Lu-171m

```
----- Daughter
Products -----
  Nuclide Halflife f1 Nuclide f2 Nuclide f3
Nuclide f4 Nuclide
  1 Lu-171m 79s 1.000E+00 Lu-171
  2 Lu-171 8.24d 1.000E+00 Yb-171$
```

Lu-172m

```
----- Daughter
Products -----
  Nuclide Halflife f1 Nuclide f2 Nuclide f3
Nuclide f4 Nuclide
  1 Lu-172m 3.7m 1.000E+00 Lu-172
  2 Lu-172 6.70d 1.000E+00 Yb-172$
```

Lu-174m

```
----- Daughter
Products -----
  Nuclide Halflife f1 Nuclide f2 Nuclide f3
Nuclide f4 Nuclide
  1 Lu-174m 142d 9.938E-01 Lu-174 6.200E-03 Yb-174$
  2 Lu-174 3.31y 1.000E+00 Yb-174$
```


Lu-177m

----- Daughter
 Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Lu-177m	160.4d	2.170E-01	Lu-177	7.830E-01	Hf-177\$	
2 Lu-177	6.647d	1.000E+00	Hf-177\$			

Lu-181

----- Daughter
 Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Lu-181	3.5m	1.000E+00	Hf-181			
2 Hf-181	42.39d	1.000E+00	Ta-181\$			

Hf-167

----- Daughter
 Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Hf-167	2.05m	1.000E+00	Lu-167			
2 Lu-167	51.5m	1.000E+00	Yb-167			
3 Yb-167	17.5m	1.000E+00	Tm-167			
4 Tm-167	9.25d	1.000E+00	Er-167\$			

Hf-169

----- Daughter
 Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Hf-169	3.24m	3.096E-02	Lu-169m	9.690E-01	Lu-169	
2 Lu-169m	160s	1.000E+00	Lu-169			
3 Lu-169	34.06h	1.000E+00	Yb-169			
4 Yb-169	32.026d	1.000E+00	Tm-169\$			

Hf-170

----- Daughter
 Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Hf-170	16.01h	1.000E+00	Lu-170			
2 Lu-170	2.012d	1.000E+00	Yb-170\$			

Hf-172

----- Daughter
 Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Hf-172	1.87y	1.000E+00	Lu-172m			
2 Lu-172m	3.7m	1.000E+00	Lu-172			
3 Lu-172	6.70d	1.000E+00	Yb-172\$			

Hf-173

```
----- Daughter
Products -----
  Nuclide  Halflife    f1    Nuclide  f2    Nuclide  f3
Nuclide  f4    Nuclide
  1 Hf-173    23.6h  1.000E+00 Lu-173
  2 Lu-173    1.37y  1.000E+00 Yb-173$
```

Hf-182

```
----- Daughter
Products -----
  Nuclide  Halflife    f1    Nuclide  f2    Nuclide  f3
Nuclide  f4    Nuclide
  1 Hf-182    9E+6y  1.000E+00 Ta-182
  2 Ta-182   114.43d  1.000E+00 W-182$
```

Hf-182m

```
----- Daughter
Products -----
  Nuclide  Halflife    f1    Nuclide  f2    Nuclide  f3
Nuclide  f4    Nuclide
  1 Hf-182m   61.5m  4.200E-01 Hf-182  8.928E-02 Ta-182m
4.907E-01 Ta-182
  2 Hf-182    9E+6y  1.000E+00 Ta-182
  3 Ta-182m   15.84m  1.000E+00 Ta-182
  4 Ta-182   114.43d  1.000E+00 W-182$
```

Hf-183

```
----- Daughter
Products -----
  Nuclide  Halflife    f1    Nuclide  f2    Nuclide  f3
Nuclide  f4    Nuclide
  1 Hf-183    1.067h  1.000E+00 Ta-183
  2 Ta-183    5.1d   1.000E+00 W-183$
```

Hf-184

```
----- Daughter
Products -----
  Nuclide  Halflife    f1    Nuclide  f2    Nuclide  f3
Nuclide  f4    Nuclide
  1 Hf-184    4.12h  1.000E+00 Ta-184
  2 Ta-184    8.7h   1.000E+00 W-184$
```

Ta-170

```
----- Daughter
Products -----
  Nuclide  Halflife    f1    Nuclide  f2    Nuclide  f3
Nuclide  f4    Nuclide
  1 Ta-170    6.76m  1.000E+00 Hf-170
  2 Hf-170   16.01h  1.000E+00 Lu-170
  3 Lu-170    2.012d  1.000E+00 Yb-170$
```

Ta-172

Products -----				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4		Nuclide				
1 Ta-172	36.8m	1.000E+00	Hf-172			
2 Hf-172	1.87y	1.000E+00	Lu-172m			
3 Lu-172m	3.7m	1.000E+00	Lu-172			
4 Lu-172	6.70d	1.000E+00	Yb-172\$			

Ta-173

Products -----				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4		Nuclide				
1 Ta-173	3.14h	1.000E+00	Hf-173			
2 Hf-173	23.6h	1.000E+00	Lu-173			
3 Lu-173	1.37y	1.000E+00	Yb-173\$			

Ta-174

Products -----				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4		Nuclide				
1 Ta-174	1.14h	1.000E+00	Hf-174			
2 Hf-174	2.0E+15y	1.000E+00	Yb-170\$			

Ta-175

Products -----				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4		Nuclide				
1 Ta-175	10.5h	1.000E+00	Hf-175			
2 Hf-175	70d	1.000E+00	Lu-175\$			

Ta-182m

Products -----				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4		Nuclide				
1 Ta-182m	15.84m	1.000E+00	Ta-182			
2 Ta-182	114.43d	1.000E+00	W-182\$			

Ta-185

Products -----				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4		Nuclide				
1 Ta-185	49.4m	1.000E+00	W-185			
2 W-185	75.1d	1.000E+00	Re-185\$			

W-177

----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 W-177	132m	1.000E+00	Ta-177			
2 Ta-177	56.56h	1.000E+00	Hf-177\$			

W-178

----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 W-178	21.6d	1.000E+00	Ta-178			
2 Ta-178	9.31m	1.000E+00	Hf-178\$			

W-179

----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 W-179	37.05m	1.000E+00	Ta-179			
2 Ta-179	1.82y	1.000E+00	Hf-179\$			

W-179m

----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 W-179m	6.40m	9.972E-01	W-179	2.800E-03	Ta-179	
2 W-179	37.05m	1.000E+00	Ta-179			
3 Ta-179	1.82y	1.000E+00	Hf-179\$			

W-185m

----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 W-185m	1.597m	1.000E+00	W-185			
2 W-185	75.1d	1.000E+00	Re-185\$			

W-187

----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 W-187	23.72h	1.000E+00	Re-187			
2 Re-187	4.12E+10y	1.000E+00	Os-187\$			

W-188

----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 W-188	69.78d	1.000E+00	Re-188			
2 Re-188	17.0040h	1.000E+00	Os-188\$			

W-190

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 W-190	30.0m	1.000E+00	Re-190			
2 Re-190	3.1m	1.000E+00	Os-190\$			

Re-178

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Re-178	13.2m	1.000E+00	W-178			
2 W-178	21.6d	1.000E+00	Ta-178			
3 Ta-178	9.31m	1.000E+00	Hf-178\$			

Re-179

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Re-179	19.5m	2.392E-01	W-179m	7.608E-01	W-179	
2 W-179m	6.40m	9.972E-01	W-179	2.800E-03	Ta-179	
3 W-179	37.05m	1.000E+00	Ta-179			
4 Ta-179	1.82y	1.000E+00	Hf-179\$			

Re-181

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Re-181	19.9h	1.000E+00	W-181			
2 W-181	121.2d	1.000E+00	Ta-181\$			

Re-184m

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Re-184m	169d	7.540E-01	Re-184	2.460E-01	W-184\$	
2 Re-184	38.0d	1.000E+00	W-184\$			

Re-186

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3

Nuclide	f4	Nuclide				
1 Re-186		3.7183d	9.253E-01	Os-186	7.470E-02	W-186\$
2 Os-186		2.0E+15y	1.000E+00	W-182\$		

Re-186m

				----- Daughter		
Products	-----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide	f4	Nuclide				
1 Re-186m	2.00E+5y	1.000E+00	Re-186			
2 Re-186	3.7183d	9.253E-01	Os-186	7.470E-02	W-186\$	
3 Os-186	2.0E+15y	1.000E+00	W-182\$			

Re-188m

				----- Daughter		
Products	-----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide	f4	Nuclide				
1 Re-188m	18.59m	1.000E+00	Re-188			
2 Re-188	17.0040h	1.000E+00	Os-188\$			

Re-189

				----- Daughter		
Products	-----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide	f4	Nuclide				
1 Re-189	24.3h	1.221E-01	Os-189m	8.779E-01	Os-189\$	
2 Os-189m	5.8h	1.000E+00	Os-189\$			

Re-190m

				----- Daughter		
Products	-----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide	f4	Nuclide				
1 Re-190m	3.2h	4.560E-01	Re-190	5.440E-01	Os-190\$	
2 Re-190	3.1m	1.000E+00	Os-190\$			

Os-180

				----- Daughter		
Products	-----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide	f4	Nuclide				
1 Os-180	21.5m	1.000E+00	Re-180			
2 Re-180	2.44m	1.000E+00	W-180\$			

Os-181

				----- Daughter		
Products	-----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide	f4	Nuclide				
1 Os-181	105m	1.000E+00	Re-181			
2 Re-181	19.9h	1.000E+00	W-181			

3 W-181 121.2d 1.000E+00 Ta-181\$

Os-182

----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Os-182	22.10h	1.000E+00	Re-182m			
2 Re-182m	12.7h	1.000E+00	W-182\$			

Os-183

----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Os-183	13.0h	1.000E+00	Re-183			
2 Re-183	70.0d	1.000E+00	W-183\$			

Os-183m

----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Os-183m	9.9h	1.500E-01	Os-183	8.500E-01	Re-183	
2 Os-183	13.0h	1.000E+00	Re-183			
3 Re-183	70.0d	1.000E+00	W-183\$			

Os-191m

----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Os-191m	13.10h	1.000E+00	Os-191			
2 Os-191	15.4d	1.000E+00	Ir-191\$			

Os-193

----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Os-193	30.11h	3.476E-03	Ir-193m	9.965E-01	Ir-193\$	
2 Ir-193m	10.53d	1.000E+00	Ir-193\$			

Os-194

----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Os-194	6.0y	1.000E+00	Ir-194			
2 Ir-194	19.28h	1.000E+00	Pt-194\$			

Os-196

Products -----					Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Os-196	34.9m	1.000E+00	Ir-196			
2 Ir-196	52s	1.000E+00	Pt-196\$			

Ir-180

Products -----					Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ir-180	1.5m	1.000E+00	Os-180			
2 Os-180	21.5m	1.000E+00	Re-180			
3 Re-180	2.44m	1.000E+00	W-180\$			

Ir-182

Products -----					Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ir-182	15m	1.000E+00	Os-182			
2 Os-182	22.10h	1.000E+00	Re-182m			
3 Re-182m	12.7h	1.000E+00	W-182\$			

Ir-183

Products -----					Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ir-183	58m	7.097E-01	Os-183m	2.903E-01	Os-183	
2 Os-183m	9.9h	1.500E-01	Os-183	8.500E-01	Re-183	
3 Os-183	13.0h	1.000E+00	Re-183			
4 Re-183	70.0d	1.000E+00	W-183\$			

Ir-185

Products -----					Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ir-185	14.4h	1.000E+00	Os-185			
2 Os-185	93.6d	1.000E+00	Re-185\$			

Ir-186

Products -----					Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ir-186	16.64h	1.000E+00	Os-186			
2 Os-186	2.0E+15y	1.000E+00	W-182\$			

Ir-186m

----- Daughter
 Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ir-186m	1.92h	2.500E-01	Ir-186	7.500E-01	Os-186	
2 Ir-186	16.64h	1.000E+00	Os-186			
3 Os-186	2.0E+15y	1.000E+00	W-182\$			

Ir-189

----- Daughter
 Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ir-189	13.2d	7.426E-02	Os-189m	9.257E-01	Os-189\$	
2 Os-189m	5.8h	1.000E+00	Os-189\$			

Ir-190m

----- Daughter
 Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ir-190m	1.120h	1.000E+00	Ir-190			
2 Ir-190	11.78d	1.000E+00	Os-190\$			

Ir-190n

----- Daughter
 Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ir-190n	3.087h	9.140E-01	Os-190m	8.600E-02	Ir-190	
2 Os-190m	9.9m	1.000E+00	Os-190\$			
3 Ir-190	11.78d	1.000E+00	Os-190\$			

Ir-192m

----- Daughter
 Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ir-192m	1.45m	9.998E-01	Ir-192	1.750E-04	Pt-192\$	
2 Ir-192	73.827d	9.513E-01	Pt-192\$	4.870E-02	Os-192\$	

Ir-192n

----- Daughter
 Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ir-192n	241y	1.000E+00	Ir-192			
2 Ir-192	73.827d	9.513E-01	Pt-192\$	4.870E-02	Os-192\$	

Ir-195m

----- Daughter
 Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ir-195m	3.8h	4.369E-01	Pt-195m	5.000E-02	Ir-195	
5.131E-01 Pt-195\$						
2 Pt-195m	4.02d	1.000E+00	Pt-195\$			
3 Ir-195	2.5h	1.000E+00	Pt-195\$			

Pt-184

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Pt-184	17.3m	1.000E+00	Ir-184	1.700E-05	Os-180	
2 Ir-184	3.09h	1.000E+00	Os-184\$			
3 Os-180	21.5m	1.000E+00	Re-180			
4 Re-180	2.44m	1.000E+00	W-180\$			

Pt-186

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Pt-186	2.08h	8.194E-01	Ir-186m	1.806E-01	Ir-186	
1.000E-06 Os-182						
2 Ir-186m	1.92h	2.500E-01	Ir-186	7.500E-01	Os-186	
3 Ir-186	16.64h	1.000E+00	Os-186			
4 Os-182	22.10h	1.000E+00	Re-182m			
5 Os-186	2.0E+15y	1.000E+00	W-182\$			
6 Re-182m	12.7h	1.000E+00	W-182\$			

Pt-187

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Pt-187	2.35h	1.000E+00	Ir-187			
2 Ir-187	10.5h	1.000E+00	Os-187\$			

Pt-188

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Pt-188	10.2d	1.000E+00	Ir-188	2.900E-07	Os-184\$	
2 Ir-188	41.5h	1.000E+00	Os-188\$			

Pt-189

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Pt-189	10.87h	1.000E+00	Ir-189			

2 Ir-189	13.2d	7.426E-02	Os-189m	9.257E-01	Os-189\$
3 Os-189m	5.8h	1.000E+00	Os-189\$		

Pt-190

-----						Daughter
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Pt-190	6.50E+11y	1.000E+00	Os-186			
2 Os-186	2.0E+15y	1.000E+00	W-182\$			

Pt-193m

-----						Daughter
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Pt-193m	4.33d	1.000E+00	Pt-193			
2 Pt-193	50y	1.000E+00	Ir-193\$			

Pt-197m

-----						Daughter
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Pt-197m	95.41m	9.670E-01	Pt-197	3.300E-02	Au-197\$	
2 Pt-197	19.8915h	1.000E+00	Au-197\$			

Pt-199

-----						Daughter
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Pt-199	30.80m	1.000E+00	Au-199			
2 Au-199	3.139d	1.000E+00	Hg-199\$			

Pt-200

-----						Daughter
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Pt-200	12.5h	1.000E+00	Au-200			
2 Au-200	48.4m	1.000E+00	Hg-200\$			

Pt-202

-----						Daughter
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Pt-202	44h	1.000E+00	Au-202			
2 Au-202	28.8s	1.000E+00	Hg-202\$			

Au-186

----- Daughter

Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4		Nuclide				
1 Au-186	10.7m	1.000E+00	Pt-186			
2 Pt-186	2.08h	8.194E-01	Ir-186m	1.806E-01	Ir-186	
1.000E-06 Os-182						
3 Ir-186m	1.92h	2.500E-01	Ir-186	7.500E-01	Os-186	
4 Ir-186	16.64h	1.000E+00	Os-186			
5 Os-182	22.10h	1.000E+00	Re-182m			
6 Os-186	2.0E+15y	1.000E+00	W-182\$			
7 Re-182m	12.7h	1.000E+00	W-182\$			

Au-187

----- Daughter

Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4		Nuclide				
1 Au-187	8.4m	1.000E+00	Pt-187	3.000E-05	Ir-183	
2 Pt-187	2.35h	1.000E+00	Ir-187			
3 Ir-183	58m	7.097E-01	Os-183m	2.903E-01	Os-183	
4 Ir-187	10.5h	1.000E+00	Os-187\$			
5 Os-183m	9.9h	1.500E-01	Os-183	8.500E-01	Re-183	
6 Os-183	13.0h	1.000E+00	Re-183			
7 Re-183	70.0d	1.000E+00	W-183\$			

Au-190

----- Daughter

Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4		Nuclide				
1 Au-190	42.8m	1.000E+00	Pt-190			
2 Pt-190	6.50E+11y	1.000E+00	Os-186			
3 Os-186	2.0E+15y	1.000E+00	W-182\$			

Au-191

----- Daughter

Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4		Nuclide				
1 Au-191	3.18h	1.000E+00	Pt-191			
2 Pt-191	2.802d	1.000E+00	Ir-191\$			

Au-193

----- Daughter

Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4		Nuclide				
1 Au-193	17.65h	1.000E+00	Pt-193			
2 Pt-193	50y	1.000E+00	Ir-193\$			

Au-193m

----- Daughter

Products	Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide						
1 Au-193m	3.9s	9.997E-01	Au-193	3.000E-04	Pt-193m		
2 Au-193	17.65h	1.000E+00	Pt-193				
3 Pt-193m	4.33d	1.000E+00	Pt-193				
4 Pt-193	50y	1.000E+00	Ir-193\$				

Au-195m

----- Daughter

Products	Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide						
1 Au-195m	30.5s	1.000E+00	Au-195				
2 Au-195	186.098d	1.000E+00	Pt-195\$				

Au-196m

----- Daughter

Products	Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide						
1 Au-196m	9.6h	1.000E+00	Au-196				
2 Au-196	6.183d	9.280E-01	Pt-196\$	7.200E-02	Hg-196\$		

Au-198m

----- Daughter

Products	Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide						
1 Au-198m	2.27d	1.000E+00	Au-198				
2 Au-198	2.69517d	1.000E+00	Hg-198\$				

Au-200m

----- Daughter

Products	Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide						
1 Au-200m	18.7h	1.800E-01	Au-200	8.200E-01	Hg-200\$		
2 Au-200	48.4m	1.000E+00	Hg-200\$				

Hg-190

----- Daughter

Products	Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide						
1 Hg-190	20.0m	1.000E+00	Au-190				
2 Au-190	42.8m	1.000E+00	Pt-190				
3 Pt-190	6.50E+11y	1.000E+00	Os-186				
4 Os-186	2.0E+15y	1.000E+00	W-182\$				

Hg-191m

Products -----				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Hg-191m	50.8m	1.000E+00	Au-191			
2 Au-191	3.18h	1.000E+00	Pt-191			
3 Pt-191	2.802d	1.000E+00	Ir-191\$			

Hg-192

Products -----				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Hg-192	4.85h	1.000E+00	Au-192			
2 Au-192	4.94h	1.000E+00	Pt-192\$			

Hg-193

Products -----				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Hg-193	3.80h	3.541E-02	Au-193m	9.646E-01	Au-193	
2 Au-193m	3.9s	9.997E-01	Au-193	3.000E-04	Pt-193m	
3 Au-193	17.65h	1.000E+00	Pt-193			
4 Pt-193m	4.33d	1.000E+00	Pt-193			
5 Pt-193	50y	1.000E+00	Ir-193\$			

Hg-193m

Products -----				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Hg-193m	11.8h	7.100E-02	Hg-193	8.920E-01	Au-193m	
3.703E-02 Au-193						
2 Hg-193	3.80h	3.541E-02	Au-193m	9.646E-01	Au-193	
3 Au-193m	3.9s	9.997E-01	Au-193	3.000E-04	Pt-193m	
4 Au-193	17.65h	1.000E+00	Pt-193			
5 Pt-193m	4.33d	1.000E+00	Pt-193			
6 Pt-193	50y	1.000E+00	Ir-193\$			

Hg-194

Products -----				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Hg-194	440y	1.000E+00	Au-194			
2 Au-194	38.02h	1.000E+00	Pt-194\$			

Hg-195

Products -----				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3

Nuclide	f4	Nuclide	
1 Hg-195	10.53h	1.000E+00	Au-195
2 Au-195	186.098d	1.000E+00	Pt-195\$

Hg-195m

Products				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Hg-195m	41.6h	5.420E-01	Hg-195	4.580E-01	Au-195
2 Hg-195	10.53h	1.000E+00	Au-195		
3 Au-195	186.098d	1.000E+00	Pt-195\$		

Hg-197m

Products				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Hg-197m	23.8h	9.140E-01	Hg-197	8.600E-02	Au-197\$
2 Hg-197	64.94h	1.000E+00	Au-197\$		

Hg-206

Products				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Hg-206	8.15m	1.000E+00	Tl-206		
2 Tl-206	4.200m	1.000E+00	Pb-206\$		

Hg-207

Products				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Hg-207	2.9m	1.000E+00	Tl-207		
2 Tl-207	4.77m	1.000E+00	Pb-207\$		

Tl-190

Products				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Tl-190	2.6m	1.000E+00	Hg-190		
2 Hg-190	20.0m	1.000E+00	Au-190		
3 Au-190	42.8m	1.000E+00	Pt-190		
4 Pt-190	6.50E+11y	1.000E+00	Os-186		
5 Os-186	2.0E+15y	1.000E+00	W-182\$		

Tl-190m

Products				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3

Nuclide	f4	Nuclide	
1 Tl-190m	3.7m	1.000E+00	Hg-190
2 Hg-190	20.0m	1.000E+00	Au-190
3 Au-190	42.8m	1.000E+00	Pt-190
4 Pt-190	6.50E+11y	1.000E+00	Os-186
5 Os-186	2.0E+15y	1.000E+00	W-182\$

Tl-194

Products -----				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 Tl-194	33.0m	1.000E+00	Hg-194		
2 Hg-194	440y	1.000E+00	Au-194		
3 Au-194	38.02h	1.000E+00	Pt-194\$		

Tl-194m

Products -----				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 Tl-194m	32.8m	1.000E+00	Hg-194		
2 Hg-194	440y	1.000E+00	Au-194		
3 Au-194	38.02h	1.000E+00	Pt-194\$		

Tl-195

Products -----				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 Tl-195	1.16h	3.436E-03	Hg-195m	9.966E-01	Hg-195
2 Hg-195m	41.6h	5.420E-01	Hg-195	4.580E-01	Au-195
3 Hg-195	10.53h	1.000E+00	Au-195		
4 Au-195	186.098d	1.000E+00	Pt-195\$		

Tl-197

Products -----				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 Tl-197	2.84h	1.000E+00	Hg-197		
2 Hg-197	64.94h	1.000E+00	Au-197\$		

Tl-198m

Products -----				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 Tl-198m	1.87h	4.600E-01	Tl-198	5.400E-01	Hg-198\$
2 Tl-198	5.3h	1.000E+00	Hg-198\$		

Tl-206m

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Tl-206m 3.74m 1.000E+00 Tl-206
 2 Tl-206 4.200m 1.000E+00 Pb-206\$

Tl-209

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Tl-209 2.161m 1.000E+00 Pb-209
 2 Pb-209 3.253h 1.000E+00 Bi-209\$

Tl-210

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Tl-210 1.30m 1.000E+00 Pb-210
 2 Pb-210 22.20y 1.000E+00 Bi-210 1.900E-08 Hg-206
 3 Bi-210 5.013d 1.000E+00 Po-210 1.320E-06 Tl-206
 4 Hg-206 8.15m 1.000E+00 Tl-206
 5 Po-210 138.376d 1.000E+00 Pb-206\$
 6 Tl-206 4.200m 1.000E+00 Pb-206\$

Pb-194

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Pb-194 12.0m 1.000E+00 Tl-194 7.300E-08 Hg-190
 2 Tl-194 33.0m 1.000E+00 Hg-194
 3 Hg-190 20.0m 1.000E+00 Au-190
 4 Hg-194 440y 1.000E+00 Au-194
 5 Au-194 38.02h 1.000E+00 Pt-194\$
 6 Au-190 42.8m 1.000E+00 Pt-190
 7 Pt-190 6.50E+11y 1.000E+00 Os-186
 8 Os-186 2.0E+15y 1.000E+00 W-182\$

Pb-195m

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 Pb-195m 15m 1.000E+00 Tl-195
 2 Tl-195 1.16h 3.436E-03 Hg-195m 9.966E-01 Hg-195
 3 Hg-195m 41.6h 5.420E-01 Hg-195 4.580E-01 Au-195
 4 Hg-195 10.53h 1.000E+00 Au-195
 5 Au-195 186.098d 1.000E+00 Pt-195\$

Pb-196

----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Pb-196	37m	1.000E+00	Tl-196			
2 Tl-196	1.84h	1.000E+00	Hg-196\$			

Pb-197

----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Pb-197	8m	1.000E+00	Tl-197			
2 Tl-197	2.84h	1.000E+00	Hg-197			
3 Hg-197	64.94h	1.000E+00	Au-197\$			

Pb-197m

----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Pb-197m	43m	1.900E-01	Pb-197	8.100E-01	Tl-197	
2 Pb-197	8m	1.000E+00	Tl-197			
3 Tl-197	2.84h	1.000E+00	Hg-197			
4 Hg-197	64.94h	1.000E+00	Au-197\$			

Pb-198

----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Pb-198	2.4h	1.000E+00	Tl-198			
2 Tl-198	5.3h	1.000E+00	Hg-198\$			

Pb-199

----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Pb-199	90m	1.000E+00	Tl-199			
2 Tl-199	7.42h	1.000E+00	Hg-199\$			

Pb-200

----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Pb-200	21.5h	1.000E+00	Tl-200			
2 Tl-200	26.1h	1.000E+00	Hg-200\$			

Pb-201

Products -----					Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Pb-201	9.33h	1.000E+00	Tl-201			
2 Tl-201	72.912h	1.000E+00	Hg-201\$			

Pb-201m

Products -----					Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Pb-201m	61s	1.000E+00	Pb-201			
2 Pb-201	9.33h	1.000E+00	Tl-201			
3 Tl-201	72.912h	1.000E+00	Hg-201\$			

Pb-202

Products -----					Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Pb-202	5.25E+4y	9.900E-01	Tl-202	1.000E-02	Hg-198\$	
2 Tl-202	12.23d	1.000E+00	Hg-202\$			

Pb-202m

Products -----					Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Pb-202m	3.53h	9.050E-01	Pb-202	9.500E-02	Tl-202	
2 Pb-202	5.25E+4y	9.900E-01	Tl-202	1.000E-02	Hg-198\$	
3 Tl-202	12.23d	1.000E+00	Hg-202\$			

Pb-210

Products -----					Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206	
2 Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206	
3 Hg-206	8.15m	1.000E+00	Tl-206			
4 Po-210	138.376d	1.000E+00	Pb-206\$			
5 Tl-206	4.200m	1.000E+00	Pb-206\$			

Pb-211

Products -----					Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Pb-211	36.1m	1.000E+00	Bi-211			
2 Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211	
3 Tl-207	4.77m	1.000E+00	Pb-207\$			

4 Po-211 0.516s 1.000E+00 Pb-207\$

Pb-212

Products				----- Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Pb-212	10.64h	1.000E+00	Bi-212			
2 Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208	
3 Po-212	2.99E-7s	1.000E+00	Pb-208\$			
4 Tl-208	3.053m	1.000E+00	Pb-208\$			

Pb-214

Products				----- Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Pb-214	26.8m	1.000E+00	Bi-214			
2 Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210	
3 Po-214	1.643E-4s	1.000E+00	Pb-210			
4 Tl-210	1.30m	1.000E+00	Pb-210			
5 Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206	
6 Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206	
7 Hg-206	8.15m	1.000E+00	Tl-206			
8 Po-210	138.376d	1.000E+00	Pb-206\$			
9 Tl-206	4.200m	1.000E+00	Pb-206\$			

Bi-197

Products				----- Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Bi-197	9.3m	4.390E-01	Pb-197m	5.610E-01	Pb-197	
2 Pb-197m	43m	1.900E-01	Pb-197	8.100E-01	Tl-197	
3 Pb-197	8m	1.000E+00	Tl-197			
4 Tl-197	2.84h	1.000E+00	Hg-197			
5 Hg-197	64.94h	1.000E+00	Au-197\$			

Bi-200

Products				----- Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Bi-200	36.4m	1.000E+00	Pb-200			
2 Pb-200	21.5h	1.000E+00	Tl-200			
3 Tl-200	26.1h	1.000E+00	Hg-200\$			

Bi-201

Products				----- Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Bi-201						

1	Bi-201	108m	4.517E-01	Pb-201m	5.483E-01	Pb-201
2	Pb-201m	61s	1.000E+00	Pb-201		
3	Pb-201	9.33h	1.000E+00	Tl-201		
4	Tl-201	72.912h	1.000E+00	Hg-201\$		

Bi-202

Products				----- Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4			Nuclide			
1 Bi-202	1.72h	1.000E+00	Pb-202			
2 Pb-202	5.25E+4y	9.900E-01	Tl-202	1.000E-02	Hg-198\$	
3 Tl-202	12.23d	1.000E+00	Hg-202\$			

Bi-203

Products				----- Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4			Nuclide			
1 Bi-203	11.76h	1.000E+00	Pb-203			
2 Pb-203	51.873h	1.000E+00	Tl-203\$			

Bi-204

Products				----- Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4			Nuclide			
1 Bi-204	11.22h	9.853E-02	Pb-204m	9.015E-01	Pb-204\$	
2 Pb-204m	67.2m	1.000E+00	Pb-204\$			

Bi-205

Products				----- Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4			Nuclide			
1 Bi-205	15.31d	1.000E+00	Pb-205			
2 Pb-205	1.53E+7y	1.000E+00	Tl-205\$			

Bi-210

Products				----- Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4			Nuclide			
1 Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206	
2 Po-210	138.376d	1.000E+00	Pb-206\$			
3 Tl-206	4.200m	1.000E+00	Pb-206\$			

Bi-210m

Products				----- Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4			Nuclide			

1 Bi-210m 3.04E+6y 1.000E+00 Tl-206
 2 Tl-206 4.200m 1.000E+00 Pb-206\$

Bi-211

----- Daughter
 Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211	
2 Tl-207	4.77m	1.000E+00	Pb-207\$			
3 Po-211	0.516s	1.000E+00	Pb-207\$			

Bi-212

----- Daughter
 Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208	
2 Po-212	2.99E-7s	1.000E+00	Pb-208\$			
3 Tl-208	3.053m	1.000E+00	Pb-208\$			

Bi-212n

----- Daughter
 Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Bi-212n	7.0m	1.000E+00	Po-212m			
2 Po-212m	45.1s	9.993E-01	Pb-208\$			

Bi-213

----- Daughter
 Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Bi-213	45.59m	9.791E-01	Po-213	2.090E-02	Tl-209	
2 Po-213	4.2E-6s	1.000E+00	Pb-209			
3 Tl-209	2.161m	1.000E+00	Pb-209			
4 Pb-209	3.253h	1.000E+00	Bi-209\$			

Bi-214

----- Daughter
 Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210	
2 Po-214	1.643E-4s	1.000E+00	Pb-210			
3 Tl-210	1.30m	1.000E+00	Pb-210			
4 Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206	
5 Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206	
6 Hg-206	8.15m	1.000E+00	Tl-206			
7 Po-210	138.376d	1.000E+00	Pb-206\$			
8 Tl-206	4.200m	1.000E+00	Pb-206\$			

Bi-215

					----- Daughter			
Products -----								
Nuclide		Halflife	f1	Nuclide		f2	Nuclide	f3
Nuclide	f4	Nuclide						
1	Bi-215	7.6m	1.000E+00	Po-215				
2	Po-215	1.781E-3s	1.000E+00	Pb-211				
3	Pb-211	36.1m	1.000E+00	Bi-211				
4	Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211		
5	Tl-207	4.77m	1.000E+00	Pb-207\$				
6	Po-211	0.516s	1.000E+00	Pb-207\$				

Bi-216

					----- Daughter		
Products -----							
Nuclide		Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide	f4	Nuclide					
1	Bi-216	2.17m	1.000E+00	Po-216			
2	Po-216	0.145s	1.000E+00	Pb-212			
3	Pb-212	10.64h	1.000E+00	Bi-212			
4	Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208	
5	Po-212	2.99E-7s	1.000E+00	Pb-208\$			
6	Tl-208	3.053m	1.000E+00	Pb-208\$			

Po-203

			----- Daughter			
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Po-203	36.7m	9.989E-01	Bi-203	1.100E-03	Pb-199	
2 Bi-203	11.76h	1.000E+00	Pb-203			
3 Pb-199	90m	1.000E+00	Tl-199			
4 Pb-203	51.873h	1.000E+00	Tl-203\$			
5 Tl-199	7.42h	1.000E+00	Hg-199\$			

Po-204

			----- Daughter			
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Po-204	3.53h	9.934E-01	Bi-204	6.600E-03	Pb-200	
2 Bi-204	11.22h	9.853E-02	Pb-204m	9.015E-01	Pb-204\$	
3 Pb-200	21.5h	1.000E+00	Tl-200			
4 Pb-204m	67.2m	1.000E+00	Pb-204\$			
5 Tl-200	26.1h	1.000E+00	Hq-200\$			

Po-205

				----- Daughter		
Products	-----					
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					

1	Po-205	1.66h	9.990E-01	Bi-205	4.000E-04	Pb-201
2	Bi-205	15.31d	1.000E+00	Pb-205		
3	Pb-201	9.33h	1.000E+00	Tl-201		
4	Pb-205	1.53E+7y	1.000E+00	Tl-205\$		
5	Tl-201	72.912h	1.000E+00	Hg-201\$		

Po-206

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Po-206	8.8d	9.455E-01	Bi-206	5.450E-02	Pb-202	
2 Bi-206	6.243d	1.000E+00	Pb-206\$			
3 Pb-202	5.25E+4y	9.900E-01	Tl-202	1.000E-02	Hg-198\$	
4 Tl-202	12.23d	1.000E+00	Hg-202\$			

Po-207

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Po-207	5.80h	9.998E-01	Bi-207	2.100E-04	Pb-203	
2 Bi-207	32.9y	1.000E+00	Pb-207\$			
3 Pb-203	51.873h	1.000E+00	Tl-203\$			

Po-208

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Po-208	2.898y	2.230E-05	Bi-208	1.000E+00	Pb-204\$	
2 Bi-208	3.68E+5y	1.000E+00	Pb-208\$			

Po-209

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Po-209	102y	9.952E-01	Pb-205	4.800E-03	Bi-209\$	
2 Pb-205	1.53E+7y	1.000E+00	Tl-205\$			

Po-213

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Po-213	4.2E-6s	1.000E+00	Pb-209			
2 Pb-209	3.253h	1.000E+00	Bi-209\$			

Po-214

Products				Daughter		
----------	--	--	--	----------	--	--

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Po-214	1.643E-4s	1.000E+00	Pb-210			
2 Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206	
3 Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206	
4 Hg-206	8.15m	1.000E+00	Tl-206			
5 Po-210	138.376d	1.000E+00	Pb-206\$			
6 Tl-206	4.200m	1.000E+00	Pb-206\$			

Po-215

----- Daughter

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Po-215	1.781E-3s	1.000E+00	Pb-211			
2 Pb-211	36.1m	1.000E+00	Bi-211			
3 Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211	
4 Tl-207	4.77m	1.000E+00	Pb-207\$			
5 Po-211	0.516s	1.000E+00	Pb-207\$			

Po-216

----- Daughter

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Po-216	0.145s	1.000E+00	Pb-212			
2 Pb-212	10.64h	1.000E+00	Bi-212			
3 Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208	
4 Po-212	2.99E-7s	1.000E+00	Pb-208\$			
5 Tl-208	3.053m	1.000E+00	Pb-208\$			

Po-218

----- Daughter

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Po-218	3.10m	9.998E-01	Pb-214	2.000E-04	At-218	
2 Pb-214	26.8m	1.000E+00	Bi-214			
3 At-218	1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218	
4 Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210	
5 Rn-218	3.5E-2s	1.000E+00	Po-214			
6 Po-214	1.643E-4s	1.000E+00	Pb-210			
7 Tl-210	1.30m	1.000E+00	Pb-210			
8 Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206	
9 Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206	
10 Hg-206	8.15m	1.000E+00	Tl-206			
11 Po-210	138.376d	1.000E+00	Pb-206\$			
12 Tl-206	4.200m	1.000E+00	Pb-206\$			

At-204

----- Daughter

Products -----

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4		Nuclide				
1 At-204	9.2m	9.620E-01	Po-204	3.800E-02	Bi-200	
2 Po-204	3.53h	9.934E-01	Bi-204	6.600E-03	Pb-200	
3 Bi-200	36.4m	1.000E+00	Pb-200			
4 Bi-204	11.22h	9.853E-02	Pb-204m	9.015E-01	Pb-204\$	
5 Pb-200	21.5h	1.000E+00	Tl-200			
6 Pb-204m	67.2m	1.000E+00	Pb-204\$			
7 Tl-200	26.1h	1.000E+00	Hg-200\$			

At-205

			----- Daughter			
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4		Nuclide				
1 At-205	26.2m	9.000E-01	Po-205	1.000E-01	Bi-201	
2 Po-205	1.66h	9.990E-01	Bi-205	4.000E-04	Pb-201	
3 Bi-201	108m	4.517E-01	Pb-201m	5.483E-01	Pb-201	
4 Bi-205	15.31d	1.000E+00	Pb-205			
5 Pb-201m	61s	1.000E+00	Pb-201			
6 Pb-201	9.33h	1.000E+00	Tl-201			
7 Pb-205	1.53E+7y	1.000E+00	Tl-205\$			
8 Tl-201	72.912h	1.000E+00	Hg-201\$			

At-206

			----- Daughter			
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4		Nuclide				
1 At-206	30.6m	9.911E-01	Po-206	8.900E-03	Bi-202	
2 Po-206	8.8d	9.455E-01	Bi-206	5.450E-02	Pb-202	
3 Bi-202	1.72h	1.000E+00	Pb-202			
4 Bi-206	6.243d	1.000E+00	Pb-206\$			
5 Pb-202	5.25E+4y	9.900E-01	Tl-202	1.000E-02	Hg-198\$	
6 Tl-202	12.23d	1.000E+00	Hg-202\$			

At-207

			----- Daughter			
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4		Nuclide				
1 At-207	1.80h	9.140E-01	Po-207	8.600E-02	Bi-203	
2 Po-207	5.80h	9.998E-01	Bi-207	2.100E-04	Pb-203	
3 Bi-203	11.76h	1.000E+00	Pb-203			
4 Bi-207	32.9y	1.000E+00	Pb-207\$			
5 Pb-203	51.873h	1.000E+00	Tl-203\$			

At-208

			----- Daughter			
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4		Nuclide				

1 At-208	1.63h	9.945E-01	Po-208	5.500E-03	Bi-204
2 Po-208	2.898y	2.230E-05	Bi-208	1.000E+00	Pb-204\$
3 Bi-204	11.22h	9.853E-02	Pb-204m	9.015E-01	Pb-204\$
4 Bi-208	3.68E+5y	1.000E+00	Pb-208\$		
5 Pb-204m	67.2m	1.000E+00	Pb-204\$		

At-209

Products			Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 At-209	5.41h	9.590E-01	Po-209	4.100E-02	Bi-205
2 Po-209	102y	9.952E-01	Pb-205	4.800E-03	Bi-209\$
3 Bi-205	15.31d	1.000E+00	Pb-205		
4 Pb-205	1.53E+7y	1.000E+00	Tl-205\$		

At-210

Products			Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 At-210	8.1h	9.982E-01	Po-210	1.750E-03	Bi-206
2 Po-210	138.376d	1.000E+00	Pb-206\$		
3 Bi-206	6.243d	1.000E+00	Pb-206\$		

At-211

Products			Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 At-211	7.214h	5.820E-01	Po-211	4.180E-01	Bi-207
2 Po-211	0.516s	1.000E+00	Pb-207\$		
3 Bi-207	32.9y	1.000E+00	Pb-207\$		

At-215

Products			Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 At-215	1.00E-4s	1.000E+00	Bi-211		
2 Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211
3 Tl-207	4.77m	1.000E+00	Pb-207\$		
4 Po-211	0.516s	1.000E+00	Pb-207\$		

At-216

Products			Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 At-216	3.00E-4s	1.000E+00	Bi-212		
2 Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208
3 Po-212	2.99E-7s	1.000E+00	Pb-208\$		

4 Tl-208 3.053m 1.000E+00 Pb-208\$

At-217

Products -----				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4		Nuclide				
1 At-217	3.23E-2s	9.999E-01	Bi-213			
2 Bi-213	45.59m	9.791E-01	Po-213	2.090E-02	Tl-209	
3 Po-213	4.2E-6s	1.000E+00	Pb-209			
4 Tl-209	2.161m	1.000E+00	Pb-209			
5 Pb-209	3.253h	1.000E+00	Bi-209\$			

At-218

Products -----				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4		Nuclide				
1 At-218	1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218	
2 Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210	
3 Rn-218	3.5E-2s	1.000E+00	Po-214			
4 Po-214	1.643E-4s	1.000E+00	Pb-210			
5 Tl-210	1.30m	1.000E+00	Pb-210			
6 Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206	
7 Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206	
8 Hg-206	8.15m	1.000E+00	Tl-206			
9 Po-210	138.376d	1.000E+00	Pb-206\$			
10 Tl-206	4.200m	1.000E+00	Pb-206\$			

At-219

Products -----				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4		Nuclide				
1 At-219	56s	9.700E-01	Bi-215			
2 Bi-215	7.6m	1.000E+00	Po-215			
3 Po-215	1.781E-3s	1.000E+00	Pb-211			
4 Pb-211	36.1m	1.000E+00	Bi-211			
5 Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211	
6 Tl-207	4.77m	1.000E+00	Pb-207\$			
7 Po-211	0.516s	1.000E+00	Pb-207\$			

At-220

Products -----				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4		Nuclide				
1 At-220	3.71m	9.200E-01	Rn-220	8.000E-02	Bi-216	
2 Rn-220	55.6s	1.000E+00	Po-216			
3 Bi-216	2.17m	1.000E+00	Po-216			
4 Po-216	0.145s	1.000E+00	Pb-212			
5 Pb-212	10.64h	1.000E+00	Bi-212			

6 Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208
7 Po-212	2.99E-7s	1.000E+00	Pb-208\$		
8 Tl-208	3.053m	1.000E+00	Pb-208\$		

Rn-207

Products			Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide
Nuclide f4					f3
1 Rn-207	9.25m	7.900E-01	At-207	2.100E-01	Po-203
2 At-207	1.80h	9.140E-01	Po-207	8.600E-02	Bi-203
3 Po-203	36.7m	9.989E-01	Bi-203	1.100E-03	Pb-199
4 Po-207	5.80h	9.998E-01	Bi-207	2.100E-04	Pb-203
5 Bi-203	11.76h	1.000E+00	Pb-203		
6 Bi-207	32.9y	1.000E+00	Pb-207\$		
7 Pb-203	51.873h	1.000E+00	Tl-203\$		
8 Pb-199	90m	1.000E+00	Tl-199		
9 Tl-199	7.42h	1.000E+00	Hg-199\$		

Rn-209

Products			Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide
Nuclide f4					f3
1 Rn-209	28.5m	8.300E-01	At-209	1.700E-01	Po-205
2 At-209	5.41h	9.590E-01	Po-209	4.100E-02	Bi-205
3 Po-205	1.66h	9.990E-01	Bi-205	4.000E-04	Pb-201
4 Po-209	102y	9.952E-01	Pb-205	4.800E-03	Bi-209\$
5 Bi-205	15.31d	1.000E+00	Pb-205		
6 Pb-205	1.53E+7y	1.000E+00	Tl-205\$		
7 Pb-201	9.33h	1.000E+00	Tl-201		
8 Tl-201	72.912h	1.000E+00	Hg-201\$		

Rn-210

Products			Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide
Nuclide f4					f3
1 Rn-210	2.4h	9.600E-01	Po-206	4.000E-02	At-210
2 Po-206	8.8d	9.455E-01	Bi-206	5.450E-02	Pb-202
3 At-210	8.1h	1.750E-03	Bi-206	9.982E-01	Po-210
4 Bi-206	6.243d	1.000E+00	Pb-206\$		
5 Pb-202	5.25E+4y	9.900E-01	Tl-202	1.000E-02	Hg-198\$
6 Tl-202	12.23d	1.000E+00	Hg-202\$		
7 Po-210	138.376d	1.000E+00	Pb-206\$		

Rn-211

Products			Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide
Nuclide f4					f3
1 Rn-211	14.6h	7.260E-01	At-211	2.740E-01	Po-207

2 At-211	7.214h	5.820E-01	Po-211	4.180E-01	Bi-207
3 Po-207	5.80h	9.998E-01	Bi-207	2.100E-04	Pb-203
4 Po-211	0.516s	1.000E+00	Pb-207\$		
5 Bi-207	32.9y	1.000E+00	Pb-207\$		
6 Pb-203	51.873h	1.000E+00	Tl-203\$		

Rn-212

Products				----- Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 Rn-212	23.9m	1.000E+00	Po-208		
2 Po-208	2.898y	2.230E-05	Bi-208	1.000E+00	Pb-204\$
3 Bi-208	3.68E+5y	1.000E+00	Pb-208\$		

Rn-215

Products				----- Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 Rn-215	2.30us	1.000E+00	Po-211		
2 Po-211	0.516s	1.000E+00	Pb-207\$		

Rn-216

Products				----- Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 Rn-216	4.5E-5s	1.000E+00	Po-212		
2 Po-212	2.99E-7s	1.000E+00	Pb-208\$		

Rn-217

Products				----- Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 Rn-217	5.40E-4s	1.000E+00	Po-213		
2 Po-213	4.2E-6s	1.000E+00	Pb-209		
3 Pb-209	3.253h	1.000E+00	Bi-209\$		

Rn-218

Products				----- Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 Rn-218	3.5E-2s	1.000E+00	Po-214		
2 Po-214	1.643E-4s	1.000E+00	Pb-210		
3 Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206
4 Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206
5 Hg-206	8.15m	1.000E+00	Tl-206		
6 Po-210	138.376d	1.000E+00	Pb-206\$		
7 Tl-206	4.200m	1.000E+00	Pb-206\$		

Rn-219

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Rn-219	3.96s	1.000E+00	Po-215			
2 Po-215	1.781E-3s	1.000E+00	Pb-211			
3 Pb-211	36.1m	1.000E+00	Bi-211			
4 Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211	
5 Tl-207	4.77m	1.000E+00	Pb-207\$			
6 Po-211	0.516s	1.000E+00	Pb-207\$			

Rn-220

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Rn-220	55.6s	1.000E+00	Po-216			
2 Po-216	0.145s	1.000E+00	Pb-212			
3 Pb-212	10.64h	1.000E+00	Bi-212			
4 Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208	
5 Po-212	2.99E-7s	1.000E+00	Pb-208\$			
6 Tl-208	3.053m	1.000E+00	Pb-208\$			

Rn-222

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Rn-222	3.8235d	1.000E+00	Po-218			
2 Po-218	3.10m	9.998E-01	Pb-214	2.000E-04	At-218	
3 Pb-214	26.8m	1.000E+00	Bi-214			
4 At-218	1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218	
5 Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210	
6 Rn-218	3.5E-2s	1.000E+00	Po-214			
7 Po-214	1.643E-4s	1.000E+00	Pb-210			
8 Tl-210	1.30m	1.000E+00	Pb-210			
9 Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206	
10 Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206	
11 Hg-206	8.15m	1.000E+00	Tl-206			
12 Po-210	138.376d	1.000E+00	Pb-206\$			
13 Tl-206	4.200m	1.000E+00	Pb-206\$			

Rn-223

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Rn-223	24.3m	1.000E+00	Fr-223			
2 Fr-223	22.00m	1.000E+00	Ra-223	6.000E-05	At-219	
3 Ra-223	11.43d	1.000E+00	Rn-219			

4	At-219	56s	9.700E-01	Bi-215	
5	Rn-219	3.96s	1.000E+00	Po-215	
6	Bi-215	7.6m	1.000E+00	Po-215	
7	Po-215	1.781E-3s	1.000E+00	Pb-211	
8	Pb-211	36.1m	1.000E+00	Bi-211	
9	Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03 Po-211
10	Tl-207	4.77m	1.000E+00	Pb-207\$	
11	Po-211	0.516s	1.000E+00	Pb-207\$	

Fr-212

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Fr-212	20.0m	5.700E-01	Rn-212	4.300E-01	At-208	
2 Rn-212	23.9m	1.000E+00	Po-208			
3 At-208	1.63h	9.945E-01	Po-208	5.500E-03	Bi-204	
4 Po-208	2.898y	2.230E-05	Bi-208	1.000E+00	Pb-204\$	
5 Bi-208	3.68E+5y	1.000E+00	Pb-208\$			
6 Bi-204	11.22h	9.853E-02	Pb-204m	9.015E-01	Pb-204\$	
7 Pb-204m	67.2m	1.000E+00	Pb-204\$			

Fr-219

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Fr-219	2.0E-2s	1.000E+00	At-215			
2 At-215	1.00E-4s	1.000E+00	Bi-211			
3 Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211	
4 Tl-207	4.77m	1.000E+00	Pb-207\$			
5 Po-211	0.516s	1.000E+00	Pb-207\$			

Fr-220

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Fr-220	27.4s	9.965E-01	At-216	3.500E-03	Ra-220	
2 At-216	3.00E-4s	1.000E+00	Bi-212			
3 Ra-220	1.79E-2s	1.000E+00	Rn-216			
4 Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208	
5 Rn-216	4.5E-5s	1.000E+00	Po-212			
6 Po-212	2.99E-7s	1.000E+00	Pb-208\$			
7 Tl-208	3.053m	1.000E+00	Pb-208\$			

Fr-221

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Fr-221	4.9m	1.000E+00	At-217			

2 At-217	3.23E-2s	9.999E-01	Bi-213	
3 Bi-213	45.59m	9.791E-01	Po-213	2.090E-02 Tl-209
4 Po-213	4.2E-6s	1.000E+00	Pb-209	
5 Tl-209	2.161m	1.000E+00	Pb-209	
6 Pb-209	3.253h	1.000E+00	Bi-209\$	

Fr-222

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Fr-222	14.2m	1.000E+00	Ra-222			
2 Ra-222	38.0s	1.000E+00	Rn-218			
3 Rn-218	3.5E-2s	1.000E+00	Po-214			
4 Po-214	1.643E-4s	1.000E+00	Pb-210			
5 Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206	
6 Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206	
7 Hg-206	8.15m	1.000E+00	Tl-206			
8 Po-210	138.376d	1.000E+00	Pb-206\$			
9 Tl-206	4.200m	1.000E+00	Pb-206\$			

Fr-223

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Fr-223	22.00m	1.000E+00	Ra-223	6.000E-05	At-219	
2 Ra-223	11.43d	1.000E+00	Rn-219			
3 At-219	56s	9.700E-01	Bi-215			
4 Rn-219	3.96s	1.000E+00	Po-215			
5 Bi-215	7.6m	1.000E+00	Po-215			
6 Po-215	1.781E-3s	1.000E+00	Pb-211			
7 Pb-211	36.1m	1.000E+00	Bi-211			
8 Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211	
9 Tl-207	4.77m	1.000E+00	Pb-207\$			
10 Po-211	0.516s	1.000E+00	Pb-207\$			

Fr-224

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Fr-224	3.33m	1.000E+00	Ra-224			
2 Ra-224	3.66d	1.000E+00	Rn-220			
3 Rn-220	55.6s	1.000E+00	Po-216			
4 Po-216	0.145s	1.000E+00	Pb-212			
5 Pb-212	10.64h	1.000E+00	Bi-212			
6 Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208	
7 Po-212	2.99E-7s	1.000E+00	Pb-208\$			
8 Tl-208	3.053m	1.000E+00	Pb-208\$			

Fr-227

Products				Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3	
1 Fr-227	2.47m	1.000E+00	Ra-227				
2 Ra-227	42.2m	1.000E+00	Ac-227				
3 Ac-227	21.772y	9.862E-01	Th-227	1.380E-02	Fr-223		
4 Th-227	18.68d	1.000E+00	Ra-223				
5 Fr-223	22.00m	1.000E+00	Ra-223	6.000E-05	At-219		
6 Ra-223	11.43d	1.000E+00	Rn-219				
7 Rn-219	3.96s	1.000E+00	Po-215				
8 At-219	56s	9.700E-01	Bi-215				
9 Bi-215	7.6m	1.000E+00	Po-215				
10 Po-215	1.781E-3s	1.000E+00	Pb-211				
11 Pb-211	36.1m	1.000E+00	Bi-211				
12 Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211		
13 Tl-207	4.77m	1.000E+00	Pb-207\$				
14 Po-211	0.516s	1.000E+00	Pb-207\$				

Ra-219

Products				Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3	
1 Ra-219	10ms	1.000E+00	Rn-215				
2 Rn-215	2.30us	1.000E+00	Po-211				
3 Po-211	0.516s	1.000E+00	Pb-207\$				

Ra-220

Products				Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3	
1 Ra-220	1.79E-2s	1.000E+00	Rn-216				
2 Rn-216	4.5E-5s	1.000E+00	Po-212				
3 Po-212	2.99E-7s	1.000E+00	Pb-208\$				

Ra-221

Products				Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3	
1 Ra-221	28s	1.000E+00	Rn-217				
2 Rn-217	5.40E-4s	1.000E+00	Po-213				
3 Po-213	4.2E-6s	1.000E+00	Pb-209				
4 Pb-209	3.253h	1.000E+00	Bi-209\$				

Ra-222

Products				Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3	
1 Ra-222	3.823d	1.000E+00	Rn-222				
2 Rn-222	3.823d	1.000E+00	Po-218				
3 Po-218	3.10m	1.000E+00	Pb-214				
4 Pb-214	26.8m	1.000E+00	Bi-214				
5 Bi-214	19.9m	1.000E+00	Th-214				
6 Th-214	24.1d	1.000E+00	Pa-214				
7 Pa-214	1.17m	1.000E+00	Ac-214				
8 Ac-214	2.13m	1.000E+00	Th-214				
9 Th-214	24.1d	1.000E+00	Pa-214				
10 Pa-214	1.17m	1.000E+00	Ac-214				
11 Ac-214	2.13m	1.000E+00	Th-214				
12 Th-214	24.1d	1.000E+00	Pa-214				
13 Pa-214	1.17m	1.000E+00	Ac-214				
14 Ac-214	2.13m	1.000E+00	Th-214				
15 Th-214	24.1d	1.000E+00	Pa-214				
16 Pa-214	1.17m	1.000E+00	Ac-214				
17 Ac-214	2.13m	1.000E+00	Th-214				
18 Th-214	24.1d	1.000E+00	Pa-214				
19 Pa-214	1.17m	1.000E+00	Ac-214				
20 Ac-214	2.13m	1.000E+00	Th-214				
21 Th-214	24.1d	1.000E+00	Pa-214				
22 Pa-214	1.17m	1.000E+00	Ac-214				
23 Ac-214	2.13m	1.000E+00	Th-214				
24 Th-214	24.1d	1.000E+00	Pa-214				
25 Pa-214	1.17m	1.000E+00	Ac-214				
26 Ac-214	2.13m	1.000E+00	Th-214				
27 Th-214	24.1d	1.000E+00	Pa-214				
28 Pa-214	1.17m	1.000E+00	Ac-214				
29 Ac-214	2.13m	1.000E+00	Th-214				
30 Th-214	24.1d	1.000E+00	Pa-214				
31 Pa-214	1.17m	1.000E+00	Ac-214				
32 Ac-214	2.13m	1.000E+00	Th-214				
33 Th-214	24.1d	1.000E+00	Pa-214				
34 Pa-214	1.17m	1.000E+00	Ac-214				
35 Ac-214	2.13m	1.000E+00	Th-214				
36 Th-214	24.1d	1.000E+00	Pa-214				
37 Pa-214	1.17m	1.000E+00	Ac-214				
38 Ac-214	2.13m	1.000E+00	Th-214				
39 Th-214	24.1d	1.000E+00	Pa-214				
40 Pa-214	1.17m	1.000E+00	Ac-214				
41 Ac-214	2.13m	1.000E+00	Th-214				
42 Th-214	24.1d	1.000E+00	Pa-214				
43 Pa-214	1.17m	1.000E+00	Ac-214				
44 Ac-214	2.13m	1.000E+00	Th-214				
45 Th-214	24.1d	1.000E+00	Pa-214				
46 Pa-214	1.17m	1.000E+00	Ac-214				
47 Ac-214	2.13m	1.000E+00	Th-214				
48 Th-214	24.1d	1.000E+00	Pa-214				
49 Pa-214	1.17m	1.000E+00	Ac-214				
50 Ac-214	2.13m	1.000E+00	Th-214				
51 Th-214	24.1d	1.000E+00	Pa-214				
52 Pa-214	1.17m	1.000E+00	Ac-214				
53 Ac-214	2.13m	1.000E+00	Th-214				
54 Th-214	24.1d	1.000E+00	Pa-214				
55 Pa-214	1.17m	1.000E+00	Ac-214				
56 Ac-214	2.13m	1.000E+00	Th-214				
57 Th-214	24.1d	1.000E+00	Pa-214				
58 Pa-214	1.17m	1.000E+00	Ac-214				
59 Ac-214	2.13m	1.000E+00	Th-214				
60 Th-214	24.1d	1.000E+00	Pa-214				
61 Pa-214	1.17m	1.000E+00	Ac-214				
62 Ac-214	2.13m	1.000E+00	Th-214				
63 Th-214	24.1d	1.000E+00	Pa-214				
64 Pa-214	1.17m	1.000E+00	Ac-214				
65 Ac-214	2.13m	1.000E+00	Th-214				
66 Th-214	24.1d	1.000E+00	Pa-214				
67 Pa-214	1.17m	1.000E+00	Ac-214				
68 Ac-214	2.13m	1.000E+00	Th-214				
69 Th-214	24.1d	1.000E+00	Pa-214				
70 Pa-214	1.17m	1.000E+00	Ac-214				
71 Ac-214	2.13m	1.000E+00	Th-214				
72 Th-214	24.1d	1.000E+00	Pa-214				
73 Pa-214	1.17m	1.000E+00	Ac-214				
74 Ac-214	2.13m	1.000E+00	Th-214				
75 Th-214	24.1d	1.000E+00	Pa-214				
76 Pa-214	1.17m	1.000E+00	Ac-214				
77 Ac-214	2.13m	1.000E+00	Th-214				
78 Th-214	24.1d	1.000E+00	Pa-214				
79 Pa-214	1.17m	1.000E+00	Ac-214				
80 Ac-214	2.13m	1.000E+00	Th-214				
81 Th-214	24.1d	1.000E+00	Pa-214				
82 Pa-214	1.17m	1.000E+00	Ac-214				
83 Ac-214	2.13m	1.000E+00	Th-214				
84 Th-214	24.1d	1.000E+00	Pa-214				
85 Pa-214	1.17m	1.000E+00	Ac-214				
86 Ac-214	2.13m	1.000E+00	Th-214				
87 Th-214	24.1d	1.000E+00	Pa-214				
88 Pa-214	1.17m	1.000E+00	Ac-214				
89 Ac-214	2.13m	1.000E+00	Th-214				
90 Th-214	24.1d	1.000E+00	Pa-214				
91 Pa-214	1.17m	1.000E+00	Ac-214				
92 Ac-214	2.13m	1.000E+00	Th-214				
93 Th-214	24.1d	1.000E+00	Pa-214				
94 Pa-214	1.17m	1.000E+00	Ac-214				
95 Ac-214	2.13m	1.000E+00	Th-214				
96 Th-214	24.1d	1.000E+00	Pa-214				
97 Pa-214	1.17m	1.000E+00	Ac-214				
98 Ac-214	2.13m	1.000E+00	Th-214				
99 Th-214	24.1d	1.000E+00	Pa-214				
100 Pa-214	1.17m	1.000E+00	Ac-214				
101 Ac-214	2.13m	1.000E+00	Th-214				
102 Th-214	24.1d	1.000E+00	Pa-214				
103 Pa-214	1.17m	1.000E+00	Ac-214				
104 Ac-214	2.13m	1.000E+00	Th-214				
105 Th-214	24.1d	1.000E+00	Pa-214				
106 Pa-214	1.17m	1.000E+00	Ac-214				
107 Ac-214	2.13m	1.000E+00	Th-214				
108 Th-214	24.1d	1.000E+00	Pa-214				
109 Pa-214	1.17m	1.000E+00	Ac-214				
110 Ac-214	2.13m	1.000E+00	Th-214				
111 Th-214	24.1d	1.000E+00	Pa-214				
112 Pa-214	1.17m	1.000E+00	Ac-214				
113 Ac-214	2.13m	1.000E+00	Th-214				
114 Th-214	24.1d	1.000E+00	Pa-214				
115 Pa-214	1.17m	1.000E+00	Ac-214				
116 Ac-214	2.13m	1.000E+00	Th-214				
117 Th-214	24.1d	1.000E+00	Pa-214				
118 Pa-214	1.17m	1.000E+00	Ac-214				
119 Ac-214	2.13m	1.000E+00	Th-214				
120 Th-214	24.1d	1.000E+00	Pa-214				
121 Pa-214	1.17m	1.000E+00	Ac-214				
122 Ac-214	2.13m	1.000E+00	Th-214				
123 Th-214	24.1d	1.000E+00	Pa-214				
124 Pa-214	1.17m	1.000E+00	Ac-214				
125 Ac-214	2.13m	1.000E+00	Th-214				
126 Th-214	24.1d	1.000E+00	Pa-214				
127 Pa-214	1.17m	1.000E+00	Ac-214				
128 Ac-214	2.13m	1.000E+00	Th-214				
129 Th-214	24.1d	1.000E+00	Pa-214				
130 Pa-214	1.17m	1.000E+00	Ac-214				
131 Ac-214	2.13m	1.000E+00	Th-214				
132 Th-214	24.1d	1.000E+00	Pa-214				
133 Pa-214	1.17m	1.000E+00	Ac-214				
134 Ac-214	2.13m	1.000E+00	Th-214				
135 Th-214	24.1d	1.000E+00	Pa-214				

1	Ra-222	38.0s	1.000E+00	Rn-218		
2	Rn-218	3.5E-2s	1.000E+00	Po-214		
3	Po-214	1.643E-4s	1.000E+00	Pb-210		
4	Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206
5	Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206
6	Hg-206	8.15m	1.000E+00	Tl-206		
7	Po-210	138.376d	1.000E+00	Pb-206\$		
8	Tl-206	4.200m	1.000E+00	Pb-206\$		

Ra-223

Products				----- Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1	Ra-223	11.43d	1.000E+00	Rn-219		
2	Rn-219	3.96s	1.000E+00	Po-215		
3	Po-215	1.781E-3s	1.000E+00	Pb-211		
4	Pb-211	36.1m	1.000E+00	Bi-211		
5	Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211
6	Tl-207	4.77m	1.000E+00	Pb-207\$		
7	Po-211	0.516s	1.000E+00	Pb-207\$		

Ra-224

Products				----- Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1	Ra-224	3.66d	1.000E+00	Rn-220		
2	Rn-220	55.6s	1.000E+00	Po-216		
3	Po-216	0.145s	1.000E+00	Pb-212		
4	Pb-212	10.64h	1.000E+00	Bi-212		
5	Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208
6	Po-212	2.99E-7s	1.000E+00	Pb-208\$		
7	Tl-208	3.053m	1.000E+00	Pb-208\$		

Ra-225

Products				----- Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1	Ra-225	14.9d	1.000E+00	Ac-225		
2	Ac-225	10.0d	1.000E+00	Fr-221		
3	Fr-221	4.9m	1.000E+00	At-217		
4	At-217	3.23E-2s	9.999E-01	Bi-213		
5	Bi-213	45.59m	9.791E-01	Po-213	2.090E-02	Tl-209
6	Po-213	4.2E-6s	1.000E+00	Pb-209		
7	Tl-209	2.161m	1.000E+00	Pb-209		
8	Pb-209	3.253h	1.000E+00	Bi-209\$		

Ra-226

Products				----- Daughter		
----------	--	--	--	----------------	--	--

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Ra-226	1600y	1.000E+00	Rn-222			
2 Rn-222	3.8235d	1.000E+00	Po-218			
3 Po-218	3.10m	9.998E-01	Pb-214	2.000E-04	At-218	
4 Pb-214	26.8m	1.000E+00	Bi-214			
5 At-218	1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218	
6 Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210	
7 Rn-218	3.5E-2s	1.000E+00	Po-214			
8 Po-214	1.643E-4s	1.000E+00	Pb-210			
9 Tl-210	1.30m	1.000E+00	Pb-210			
10 Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206	
11 Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206	
12 Hg-206	8.15m	1.000E+00	Tl-206			
13 Po-210	138.376d	1.000E+00	Pb-206\$			
14 Tl-206	4.200m	1.000E+00	Pb-206\$			

Ra-227

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Ra-227	42.2m	1.000E+00	Ac-227			
2 Ac-227	21.772y	9.862E-01	Th-227	1.380E-02	Fr-223	
3 Th-227	18.68d	1.000E+00	Ra-223			
4 Fr-223	22.00m	1.000E+00	Ra-223	6.000E-05	At-219	
5 Ra-223	11.43d	1.000E+00	Rn-219			
6 Rn-219	3.96s	1.000E+00	Po-215			
7 At-219	56s	9.700E-01	Bi-215			
8 Bi-215	7.6m	1.000E+00	Po-215			
9 Po-215	1.781E-3s	1.000E+00	Pb-211			
10 Pb-211	36.1m	1.000E+00	Bi-211			
11 Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211	
12 Tl-207	4.77m	1.000E+00	Pb-207\$			
13 Po-211	0.516s	1.000E+00	Pb-207\$			

Ra-228

Products			Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Ra-228	5.75y	1.000E+00	Ac-228			
2 Ac-228	6.15h	1.000E+00	Th-228			
3 Th-228	1.9116y	1.000E+00	Ra-224			
4 Ra-224	3.66d	1.000E+00	Rn-220			
5 Rn-220	55.6s	1.000E+00	Po-216			
6 Po-216	0.145s	1.000E+00	Pb-212			
7 Pb-212	10.64h	1.000E+00	Bi-212			
8 Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208	
9 Po-212	2.99E-7s	1.000E+00	Pb-208\$			
10 Tl-208	3.053m	1.000E+00	Pb-208\$			

Ra-230

Products				Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3	
Nuclide f4	Nuclide						
1 Ra-230	93m	1.000E+00	Ac-230				
2 Ac-230	122s	1.000E+00	Th-230				
3 Th-230	7.538E+4y	1.000E+00	Ra-226				
4 Ra-226	1600y	1.000E+00	Rn-222				
5 Rn-222	3.8235d	1.000E+00	Po-218				
6 Po-218	3.10m	9.998E-01	Pb-214	2.000E-04	At-218		
7 Pb-214	26.8m	1.000E+00	Bi-214				
8 At-218	1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218		
9 Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210		
10 Rn-218	3.5E-2s	1.000E+00	Po-214				
11 Po-214	1.643E-4s	1.000E+00	Pb-210				
12 Tl-210	1.30m	1.000E+00	Pb-210				
13 Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206		
14 Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206		
15 Hg-206	8.15m	1.000E+00	Tl-206				
16 Po-210	138.376d	1.000E+00	Pb-206\$				
17 Tl-206	4.200m	1.000E+00	Pb-206\$				

Ac-223

Products				Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3	
Nuclide f4	Nuclide						
1 Ac-223	2.10m	9.900E-01	Fr-219				
2 Fr-219	2.0E-2s	1.000E+00	At-215				
3 At-215	1.00E-4s	1.000E+00	Bi-211				
4 Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211		
5 Tl-207	4.77m	1.000E+00	Pb-207\$				
6 Po-211	0.516s	1.000E+00	Pb-207\$				

Ac-224

Products				Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3	
Nuclide f4	Nuclide						
1 Ac-224	2.78h	9.090E-01	Ra-224	9.100E-02	Fr-220		
2 Ra-224	3.66d	1.000E+00	Rn-220				
3 Fr-220	27.4s	9.965E-01	At-216	3.500E-03	Ra-220		
4 Rn-220	55.6s	1.000E+00	Po-216				
5 Po-216	0.145s	1.000E+00	Pb-212				
6 Pb-212	10.64h	1.000E+00	Bi-212				
7 At-216	3.00E-4s	1.000E+00	Bi-212				
8 Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208		
9 Ra-220	1.79E-2s	1.000E+00	Rn-216				
10 Rn-216	4.5E-5s	1.000E+00	Po-212				
11 Po-212	2.99E-7s	1.000E+00	Pb-208\$				
12 Tl-208	3.053m	1.000E+00	Pb-208\$				

Ac-225

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Ac-225	10.0d	1.000E+00	Fr-221			
2 Fr-221	4.9m	1.000E+00	At-217			
3 At-217	3.23E-2s	9.999E-01	Bi-213			
4 Bi-213	45.59m	9.791E-01	Po-213	2.090E-02	Tl-209	
5 Po-213	4.2E-6s	1.000E+00	Pb-209			
6 Tl-209	2.161m	1.000E+00	Pb-209			
7 Pb-209	3.253h	1.000E+00	Bi-209\$			

Ac-226

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Ac-226	29.37h	8.300E-01	Th-226	1.700E-01	Ra-226	
6.000E-05 Fr-222						
2 Th-226	30.57m	1.000E+00	Ra-222			
3 Ra-226	1600y	1.000E+00	Rn-222			
4 Fr-222	14.2m	1.000E+00	Ra-222			
5 Ra-222	38.0s	1.000E+00	Rn-218			
6 Rn-222	3.8235d	1.000E+00	Po-218			
7 Po-218	3.10m	2.000E-04	At-218	9.998E-01	Pb-214	
8 At-218	1.5s	1.000E-03	Rn-218	9.990E-01	Bi-214	
9 Rn-218	3.5E-2s	1.000E+00	Po-214			
10 Pb-214	26.8m	1.000E+00	Bi-214			
11 Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210	
12 Po-214	1.643E-4s	1.000E+00	Pb-210			
13 Tl-210	1.30m	1.000E+00	Pb-210			
14 Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206	
15 Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206	
16 Hg-206	8.15m	1.000E+00	Tl-206			
17 Po-210	138.376d	1.000E+00	Pb-206\$			
18 Tl-206	4.200m	1.000E+00	Pb-206\$			

Ac-227

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Ac-227	21.772y	9.862E-01	Th-227	1.380E-02	Fr-223	
2 Th-227	18.68d	1.000E+00	Ra-223			
3 Fr-223	22.00m	1.000E+00	Ra-223	6.000E-05	At-219	
4 Ra-223	11.43d	1.000E+00	Rn-219			
5 Rn-219	3.96s	1.000E+00	Po-215			
6 At-219	56s	9.700E-01	Bi-215			
7 Bi-215	7.6m	1.000E+00	Po-215			
8 Po-215	1.781E-3s	1.000E+00	Pb-211			

9	Pb-211	36.1m	1.000E+00	Bi-211		
10	Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211
11	Tl-207	4.77m	1.000E+00	Pb-207\$		
12	Po-211	0.516s	1.000E+00	Pb-207\$		

Ac-228

Products				----- Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ac-228	6.15h	1.000E+00	Th-228			
2 Th-228	1.9116y	1.000E+00	Ra-224			
3 Ra-224	3.66d	1.000E+00	Rn-220			
4 Rn-220	55.6s	1.000E+00	Po-216			
5 Po-216	0.145s	1.000E+00	Pb-212			
6 Pb-212	10.64h	1.000E+00	Bi-212			
7 Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208	
8 Po-212	2.99E-7s	1.000E+00	Pb-208\$			
9 Tl-208	3.053m	1.000E+00	Pb-208\$			

Ac-230

Products				----- Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ac-230	122s	1.000E+00	Th-230			
2 Th-230	7.538E+4y	1.000E+00	Ra-226			
3 Ra-226	1600y	1.000E+00	Rn-222			
4 Rn-222	3.8235d	1.000E+00	Po-218			
5 Po-218	3.10m	9.998E-01	Pb-214	2.000E-04	At-218	
6 Pb-214	26.8m	1.000E+00	Bi-214			
7 At-218	1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218	
8 Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210	
9 Rn-218	3.5E-2s	1.000E+00	Po-214			
10 Po-214	1.643E-4s	1.000E+00	Pb-210			
11 Tl-210	1.30m	1.000E+00	Pb-210			
12 Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206	
13 Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206	
14 Hg-206	8.15m	1.000E+00	Tl-206			
15 Po-210	138.376d	1.000E+00	Pb-206\$			
16 Tl-206	4.200m	1.000E+00	Pb-206\$			

Ac-231

Products				----- Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ac-231	7.5m	1.000E+00	Th-231			
2 Th-231	25.52h	1.000E+00	Pa-231			
3 Pa-231	3.276E+4y	1.000E+00	Ac-227			
4 Ac-227	21.772y	9.862E-01	Th-227	1.380E-02	Fr-223	
5 Th-227	18.68d	1.000E+00	Ra-223			

6	Fr-223	22.00m	1.000E+00	Ra-223	6.000E-05	At-219
7	Ra-223	11.43d	1.000E+00	Rn-219		
8	Rn-219	3.96s	1.000E+00	Po-215		
9	At-219	56s	9.700E-01	Bi-215		
10	Bi-215	7.6m	1.000E+00	Po-215		
11	Po-215	1.781E-3s	1.000E+00	Pb-211		
12	Pb-211	36.1m	1.000E+00	Bi-211		
13	Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211
14	Tl-207	4.77m	1.000E+00	Pb-207\$		
15	Po-211	0.516s	1.000E+00	Pb-207\$		

Ac-232

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ac-232	119s	1.000E+00	Th-232			
2 Th-232	1.405E10y	1.000E+00	Ra-228			
3 Ra-228	5.75y	1.000E+00	Ac-228			
4 Ac-228	6.15h	1.000E+00	Th-228			
5 Th-228	1.9116y	1.000E+00	Ra-224			
6 Ra-224	3.66d	1.000E+00	Rn-220			
7 Rn-220	55.6s	1.000E+00	Po-216			
8 Po-216	0.145s	1.000E+00	Pb-212			
9 Pb-212	10.64h	1.000E+00	Bi-212			
10 Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208	
11 Po-212	2.99E-7s	1.000E+00	Pb-208\$			
12 Tl-208	3.053m	1.000E+00	Pb-208\$			

Ac-233

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Ac-233	145s	1.000E+00	Th-233			
2 Th-233	22.3m	1.000E+00	Pa-233			
3 Pa-233	26.967d	1.000E+00	U-233			
4 U-233	1.592E+5y	1.000E+00	Th-229			
5 Th-229	7.34E+3y	1.000E+00	Ra-225			
6 Ra-225	14.9d	1.000E+00	Ac-225			
7 Ac-225	10.0d	1.000E+00	Fr-221			
8 Fr-221	4.9m	1.000E+00	At-217			
9 At-217	3.23E-2s	9.999E-01	Bi-213			
10 Bi-213	45.59m	9.791E-01	Po-213	2.090E-02	Tl-209	
11 Po-213	4.2E-6s	1.000E+00	Pb-209			
12 Tl-209	2.161m	1.000E+00	Pb-209			
13 Pb-209	3.253h	1.000E+00	Bi-209\$			

Th-223

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3

Nuclide	f4	Nuclide		
1 Th-223		0.60s	1.000E+00	Ra-219
2 Ra-219		10ms	1.000E+00	Rn-215
3 Rn-215		2.30us	1.000E+00	Po-211
4 Po-211		0.516s	1.000E+00	Pb-207\$

Th-224

----- Daughter				
Products -----				
Nuclide	Halflife	f1	Nuclide	f2
Nuclide	f4	Nuclide		f3
1 Th-224	1.05s	1.000E+00	Ra-220	
2 Ra-220	1.79E-2s	1.000E+00	Rn-216	
3 Rn-216	4.5E-5s	1.000E+00	Po-212	
4 Po-212	2.99E-7s	1.000E+00	Pb-208\$	

Th-226

----- Daughter				
Products -----				
Nuclide	Halflife	f1	Nuclide	f2
Nuclide	f4	Nuclide		f3
1 Th-226	30.57m	1.000E+00	Ra-222	
2 Ra-222	38.0s	1.000E+00	Rn-218	
3 Rn-218	3.5E-2s	1.000E+00	Po-214	
4 Po-214	1.643E-4s	1.000E+00	Pb-210	
5 Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08 Hg-206
6 Bi-210	5.013d	1.000E+00	Po-210	1.320E-06 Tl-206
7 Hg-206	8.15m	1.000E+00	Tl-206	
8 Po-210	138.376d	1.000E+00	Pb-206\$	
9 Tl-206	4.200m	1.000E+00	Pb-206\$	

Th-227

----- Daughter				
Products -----				
Nuclide	Halflife	f1	Nuclide	f2
Nuclide	f4	Nuclide		f3
1 Th-227	18.68d	1.000E+00	Ra-223	
2 Ra-223	11.43d	1.000E+00	Rn-219	
3 Rn-219	3.96s	1.000E+00	Po-215	
4 Po-215	1.781E-3s	1.000E+00	Pb-211	
5 Pb-211	36.1m	1.000E+00	Bi-211	
6 Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03 Po-211
7 Tl-207	4.77m	1.000E+00	Pb-207\$	
8 Po-211	0.516s	1.000E+00	Pb-207\$	

Th-228

----- Daughter				
Products -----				
Nuclide	Halflife	f1	Nuclide	f2
Nuclide	f4	Nuclide		f3
1 Th-228	1.9116y	1.000E+00	Ra-224	
2 Ra-224	3.66d	1.000E+00	Rn-220	

3	Rn-220	55.6s	1.000E+00	Po-216		
4	Po-216	0.145s	1.000E+00	Pb-212		
5	Pb-212	10.64h	1.000E+00	Bi-212		
6	Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208
7	Po-212	2.99E-7s	1.000E+00	Pb-208\$		
8	Tl-208	3.053m	1.000E+00	Pb-208\$		

Th-229

Products				----- Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Th-229	7.34E+3y	1.000E+00	Ra-225			
2 Ra-225	14.9d	1.000E+00	Ac-225			
3 Ac-225	10.0d	1.000E+00	Fr-221			
4 Fr-221	4.9m	1.000E+00	At-217			
5 At-217	3.23E-2s	9.999E-01	Bi-213			
6 Bi-213	45.59m	9.791E-01	Po-213	2.090E-02	Tl-209	
7 Po-213	4.2E-6s	1.000E+00	Pb-209			
8 Tl-209	2.161m	1.000E+00	Pb-209			
9 Pb-209	3.253h	1.000E+00	Bi-209\$			

Th-230

Products				----- Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Th-230	7.538E+4y	1.000E+00	Ra-226			
2 Ra-226	1600y	1.000E+00	Rn-222			
3 Rn-222	3.8235d	1.000E+00	Po-218			
4 Po-218	3.10m	9.998E-01	Pb-214	2.000E-04	At-218	
5 Pb-214	26.8m	1.000E+00	Bi-214			
6 At-218	1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218	
7 Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210	
8 Rn-218	3.5E-2s	1.000E+00	Po-214			
9 Po-214	1.643E-4s	1.000E+00	Pb-210			
10 Tl-210	1.30m	1.000E+00	Pb-210			
11 Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206	
12 Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206	
13 Hg-206	8.15m	1.000E+00	Tl-206			
14 Po-210	138.376d	1.000E+00	Pb-206\$			
15 Tl-206	4.200m	1.000E+00	Pb-206\$			

Th-231

Products				----- Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Th-231	25.52h	1.000E+00	Pa-231			
2 Pa-231	3.276E+4y	1.000E+00	Ac-227			
3 Ac-227	21.772y	9.862E-01	Th-227	1.380E-02	Fr-223	
4 Th-227	18.68d	1.000E+00	Ra-223			

5	Fr-223	22.00m	1.000E+00	Ra-223	6.000E-05	At-219
6	Ra-223	11.43d	1.000E+00	Rn-219		
7	Rn-219	3.96s	1.000E+00	Po-215		
8	At-219	56s	9.700E-01	Bi-215		
9	Bi-215	7.6m	1.000E+00	Po-215		
10	Po-215	1.781E-3s	1.000E+00	Pb-211		
11	Pb-211	36.1m	1.000E+00	Bi-211		
12	Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211
13	Tl-207	4.77m	1.000E+00	Pb-207\$		
14	Po-211	0.516s	1.000E+00	Pb-207\$		

Th-232

Products				----- Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Th-232	1.405E10y	1.000E+00	Ra-228			
2 Ra-228	5.75y	1.000E+00	Ac-228			
3 Ac-228	6.15h	1.000E+00	Th-228			
4 Th-228	1.9116y	1.000E+00	Ra-224			
5 Ra-224	3.66d	1.000E+00	Rn-220			
6 Rn-220	55.6s	1.000E+00	Po-216			
7 Po-216	0.145s	1.000E+00	Pb-212			
8 Pb-212	10.64h	1.000E+00	Bi-212			
9 Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208	
10 Po-212	2.99E-7s	1.000E+00	Pb-208\$			
11 Tl-208	3.053m	1.000E+00	Pb-208\$			

Th-233

Products				----- Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Th-233	22.3m	1.000E+00	Pa-233			
2 Pa-233	26.967d	1.000E+00	U-233			
3 U-233	1.592E+5y	1.000E+00	Th-229			
4 Th-229	7.34E+3y	1.000E+00	Ra-225			
5 Ra-225	14.9d	1.000E+00	Ac-225			
6 Ac-225	10.0d	1.000E+00	Fr-221			
7 Fr-221	4.9m	1.000E+00	At-217			
8 At-217	3.23E-2s	9.999E-01	Bi-213			
9 Bi-213	45.59m	9.791E-01	Po-213	2.090E-02	Tl-209	
10 Po-213	4.2E-6s	1.000E+00	Pb-209			
11 Tl-209	2.161m	1.000E+00	Pb-209			
12 Pb-209	3.253h	1.000E+00	Bi-209\$			

Th-234

Products				----- Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Th-234	24.10d	1.000E+00	Pa-234m			

2	Pa-234m	1.17m	1.600E-03	Pa-234	9.984E-01	U-234
3	Pa-234	6.70h	1.000E+00	U-234		
4	U-234	2.455E+5y	1.000E+00	Th-230		
5	Th-230	7.538E+4y	1.000E+00	Ra-226		
6	Ra-226	1600y	1.000E+00	Rn-222		
7	Rn-222	3.8235d	1.000E+00	Po-218		
8	Po-218	3.10m	9.998E-01	Pb-214	2.000E-04	At-218
9	Pb-214	26.8m	1.000E+00	Bi-214		
10	At-218	1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218
11	Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210
12	Rn-218	3.5E-2s	1.000E+00	Po-214		
13	Po-214	1.643E-4s	1.000E+00	Pb-210		
14	Tl-210	1.30m	1.000E+00	Pb-210		
15	Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206
16	Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206
17	Hg-206	8.15m	1.000E+00	Tl-206		
18	Po-210	138.376d	1.000E+00	Pb-206\$		
19	Tl-206	4.200m	1.000E+00	Pb-206\$		

Th-235

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Th-235	7.1m	1.000E+00	Pa-235			
2 Pa-235	24.5m	9.999E-01	U-235m	1.011E-04	U-235	
3 U-235m	26m	1.000E+00	U-235			
4 U-235	7.04E+8y	1.000E+00	Th-231			
5 Th-231	25.52h	1.000E+00	Pa-231			
6 Pa-231	3.276E+4y	1.000E+00	Ac-227			
7 Ac-227	21.772y	9.862E-01	Th-227	1.380E-02	Fr-223	
8 Th-227	18.68d	1.000E+00	Ra-223			
9 Fr-223	22.00m	1.000E+00	Ra-223	6.000E-05	At-219	
10 Ra-223	11.43d	1.000E+00	Rn-219			
11 Rn-219	3.96s	1.000E+00	Po-215			
12 At-219	56s	9.700E-01	Bi-215			
13 Bi-215	7.6m	1.000E+00	Po-215			
14 Po-215	1.781E-3s	1.000E+00	Pb-211			
15 Pb-211	36.1m	1.000E+00	Bi-211			
16 Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211	
17 Tl-207	4.77m	1.000E+00	Pb-207\$			
18 Po-211	0.516s	1.000E+00	Pb-207\$			

Th-236

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Th-236	37.5m	1.000E+00	Pa-236			
2 Pa-236	9.1m	1.000E+00	U-236			
3 U-236	2.342E+7y	1.000E+00	Th-232			
4 Th-232	1.405E10y	1.000E+00	Ra-228			

5	Ra-228	5.75y	1.000E+00	Ac-228		
6	Ac-228	6.15h	1.000E+00	Th-228		
7	Th-228	1.9116y	1.000E+00	Ra-224		
8	Ra-224	3.66d	1.000E+00	Rn-220		
9	Rn-220	55.6s	1.000E+00	Po-216		
10	Po-216	0.145s	1.000E+00	Pb-212		
11	Pb-212	10.64h	1.000E+00	Bi-212		
12	Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208
13	Po-212	2.99E-7s	1.000E+00	Pb-208\$		
14	Tl-208	3.053m	1.000E+00	Pb-208\$		

Pa-227

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Pa-227	38.3m	8.500E-01	Ac-223	1.500E-01	Th-227	
2 Ac-223	2.10m	9.900E-01	Fr-219			
3 Th-227	18.68d	1.000E+00	Ra-223			
4 Fr-219	2.0E-2s	1.000E+00	At-215			
5 At-215	1.00E-4s	1.000E+00	Bi-211			
6 Ra-223	11.43d	1.000E+00	Rn-219			
7 Rn-219	3.96s	1.000E+00	Po-215			
8 Po-215	1.781E-3s	1.000E+00	Pb-211			
9 Pb-211	36.1m	1.000E+00	Bi-211			
10 Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211	
11 Tl-207	4.77m	1.000E+00	Pb-207\$			
12 Po-211	0.516s	1.000E+00	Pb-207\$			

Pa-228

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Pa-228	22h	9.800E-01	Th-228	2.000E-02	Ac-224	
2 Th-228	1.9116y	1.000E+00	Ra-224			
3 Ac-224	2.78h	9.090E-01	Ra-224	9.100E-02	Fr-220	
4 Ra-224	3.66d	1.000E+00	Rn-220			
5 Rn-220	55.6s	1.000E+00	Po-216			
6 Po-216	0.145s	1.000E+00	Pb-212			
7 Pb-212	10.64h	1.000E+00	Bi-212			
8 Fr-220	27.4s	9.965E-01	At-216	3.500E-03	Ra-220	
9 At-216	3.00E-4s	1.000E+00	Bi-212			
10 Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208	
11 Ra-220	1.79E-2s	1.000E+00	Rn-216			
12 Rn-216	4.5E-5s	1.000E+00	Po-212			
13 Po-212	2.99E-7s	1.000E+00	Pb-208\$			
14 Tl-208	3.053m	1.000E+00	Pb-208\$			

Pa-229

Products				Daughter		
----------	--	--	--	----------	--	--

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Pa-229	1.50d	9.952E-01	Th-229	4.800E-03	Ac-225	
2 Th-229	7.34E+3y	1.000E+00	Ra-225			
3 Ra-225	14.9d	1.000E+00	Ac-225			
4 Ac-225	10.0d	1.000E+00	Fr-221			
5 Fr-221	4.9m	1.000E+00	At-217			
6 At-217	3.23E-2s	9.999E-01	Bi-213			
7 Bi-213	45.59m	9.791E-01	Po-213	2.090E-02	Tl-209	
8 Po-213	4.2E-6s	1.000E+00	Pb-209			
9 Tl-209	2.161m	1.000E+00	Pb-209			
10 Pb-209	3.253h	1.000E+00	Bi-209\$			

Pa-230

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Pa-230	17.4d	9.160E-01	Th-230	8.400E-02	U-230	
3.200E-05 Ac-226						
2 Th-230	7.538E+4y	1.000E+00	Ra-226			
3 U-230	20.8d	1.000E+00	Th-226			
4 Ac-226	29.37h	1.700E-01	Ra-226	8.300E-01	Th-226	
6.000E-05 Fr-222						
5 Ra-226	1600y	1.000E+00	Rn-222			
6 Rn-222	3.8235d	1.000E+00	Po-218			
7 Po-218	3.10m	9.998E-01	Pb-214	2.000E-04	At-218	
8 Pb-214	26.8m	1.000E+00	Bi-214			
9 At-218	1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218	
10 Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210	
11 Th-226	30.57m	1.000E+00	Ra-222			
12 Fr-222	14.2m	1.000E+00	Ra-222			
13 Ra-222	38.0s	1.000E+00	Rn-218			
14 Rn-218	3.5E-2s	1.000E+00	Po-214			
15 Po-214	1.643E-4s	1.000E+00	Pb-210			
16 Tl-210	1.30m	1.000E+00	Pb-210			
17 Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206	
18 Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206	
19 Hg-206	8.15m	1.000E+00	Tl-206			
20 Po-210	138.376d	1.000E+00	Pb-206\$			
21 Tl-206	4.200m	1.000E+00	Pb-206\$			

Pa-231

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Pa-231	3.276E+4y	1.000E+00	Ac-227			
2 Ac-227	21.772y	9.862E-01	Th-227	1.380E-02	Fr-223	
3 Th-227	18.68d	1.000E+00	Ra-223			
4 Fr-223	22.00m	1.000E+00	Ra-223	6.000E-05	At-219	
5 Ra-223	11.43d	1.000E+00	Rn-219			

6	Rn-219	3.96s	1.000E+00	Po-215	
7	At-219	56s	9.700E-01	Bi-215	
8	Bi-215	7.6m	1.000E+00	Po-215	
9	Po-215	1.781E-3s	1.000E+00	Pb-211	
10	Pb-211	36.1m	1.000E+00	Bi-211	
11	Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03 Po-211
12	Tl-207	4.77m	1.000E+00	Pb-207\$	
13	Po-211	0.516s	1.000E+00	Pb-207\$	

Pa-232

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Pa-232	1.31d	1.000E+00	U-232	3.000E-05	Th-232	
2 U-232	68.9y	1.000E+00	Th-228			
3 Th-232	1.405E10y	1.000E+00	Ra-228			
4 Ra-228	5.75y	1.000E+00	Ac-228			
5 Ac-228	6.15h	1.000E+00	Th-228			
6 Th-228	1.9116y	1.000E+00	Ra-224			
7 Ra-224	3.66d	1.000E+00	Rn-220			
8 Rn-220	55.6s	1.000E+00	Po-216			
9 Po-216	0.145s	1.000E+00	Pb-212			
10 Pb-212	10.64h	1.000E+00	Bi-212			
11 Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208	
12 Po-212	2.99E-7s	1.000E+00	Pb-208\$			
13 Tl-208	3.053m	1.000E+00	Pb-208\$			

Pa-233

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Pa-233	26.967d	1.000E+00	U-233			
2 U-233	1.592E+5y	1.000E+00	Th-229			
3 Th-229	7.34E+3y	1.000E+00	Ra-225			
4 Ra-225	14.9d	1.000E+00	Ac-225			
5 Ac-225	10.0d	1.000E+00	Fr-221			
6 Fr-221	4.9m	1.000E+00	At-217			
7 At-217	3.23E-2s	9.999E-01	Bi-213			
8 Bi-213	45.59m	9.791E-01	Po-213	2.090E-02	Tl-209	
9 Po-213	4.2E-6s	1.000E+00	Pb-209			
10 Tl-209	2.161m	1.000E+00	Pb-209			
11 Pb-209	3.253h	1.000E+00	Bi-209\$			

Pa-234

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Pa-234	6.70h	1.000E+00	U-234			
2 U-234	2.455E+5y	1.000E+00	Th-230			

3	Th-230	7.538E+4y	1.000E+00	Ra-226	
4	Ra-226	1600y	1.000E+00	Rn-222	
5	Rn-222	3.8235d	1.000E+00	Po-218	
6	Po-218	3.10m	9.998E-01	Pb-214	2.000E-04 At-218
7	Pb-214	26.8m	1.000E+00	Bi-214	
8	At-218	1.5s	9.990E-01	Bi-214	1.000E-03 Rn-218
9	Bi-214	19.9m	9.998E-01	Po-214	2.100E-04 Tl-210
10	Rn-218	3.5E-2s	1.000E+00	Po-214	
11	Po-214	1.643E-4s	1.000E+00	Pb-210	
12	Tl-210	1.30m	1.000E+00	Pb-210	
13	Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08 Hg-206
14	Bi-210	5.013d	1.000E+00	Po-210	1.320E-06 Tl-206
15	Hg-206	8.15m	1.000E+00	Tl-206	
16	Po-210	138.376d	1.000E+00	Pb-206\$	
17	Tl-206	4.200m	1.000E+00	Pb-206\$	

Pa-234m

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Pa-234m	1.17m	1.600E-03	Pa-234	9.984E-01	U-234	
2 Pa-234	6.70h	1.000E+00	U-234			
3 U-234	2.455E+5y	1.000E+00	Th-230			
4 Th-230	7.538E+4y	1.000E+00	Ra-226			
5 Ra-226	1600y	1.000E+00	Rn-222			
6 Rn-222	3.8235d	1.000E+00	Po-218			
7 Po-218	3.10m	9.998E-01	Pb-214	2.000E-04	At-218	
8 Pb-214	26.8m	1.000E+00	Bi-214			
9 At-218	1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218	
10 Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210	
11 Rn-218	3.5E-2s	1.000E+00	Po-214			
12 Po-214	1.643E-4s	1.000E+00	Pb-210			
13 Tl-210	1.30m	1.000E+00	Pb-210			
14 Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206	
15 Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206	
16 Hg-206	8.15m	1.000E+00	Tl-206			
17 Po-210	138.376d	1.000E+00	Pb-206\$			
18 Tl-206	4.200m	1.000E+00	Pb-206\$			

Pa-235

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Pa-235	24.5m	9.999E-01	U-235m	1.011E-04	U-235	
2 U-235m	26m	1.000E+00	U-235			
3 U-235	7.04E+8y	1.000E+00	Th-231			
4 Th-231	25.52h	1.000E+00	Pa-231			
5 Pa-231	3.276E+4y	1.000E+00	Ac-227			
6 Ac-227	21.772y	9.862E-01	Th-227	1.380E-02	Fr-223	
7 Th-227	18.68d	1.000E+00	Ra-223			

8	Fr-223	22.00m	1.000E+00	Ra-223	6.000E-05	At-219
9	Ra-223	11.43d	1.000E+00	Rn-219		
10	Rn-219	3.96s	1.000E+00	Po-215		
11	At-219	56s	9.700E-01	Bi-215		
12	Bi-215	7.6m	1.000E+00	Po-215		
13	Po-215	1.781E-3s	1.000E+00	Pb-211		
14	Pb-211	36.1m	1.000E+00	Bi-211		
15	Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211
16	Tl-207	4.77m	1.000E+00	Pb-207\$		
17	Po-211	0.516s	1.000E+00	Pb-207\$		

Pa-236

Products				----- Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Pa-236	9.1m	1.000E+00	U-236			
2 U-236	2.342E+7y	1.000E+00	Th-232			
3 Th-232	1.405E10y	1.000E+00	Ra-228			
4 Ra-228	5.75y	1.000E+00	Ac-228			
5 Ac-228	6.15h	1.000E+00	Th-228			
6 Th-228	1.9116y	1.000E+00	Ra-224			
7 Ra-224	3.66d	1.000E+00	Rn-220			
8 Rn-220	55.6s	1.000E+00	Po-216			
9 Po-216	0.145s	1.000E+00	Pb-212			
10 Pb-212	10.64h	1.000E+00	Bi-212			
11 Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208	
12 Po-212	2.99E-7s	1.000E+00	Pb-208\$			
13 Tl-208	3.053m	1.000E+00	Pb-208\$			

Pa-237

Products				----- Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Pa-237	8.7m	1.000E+00	U-237			
2 U-237	6.75d	1.000E+00	Np-237			
3 Np-237	2.144E+6y	1.000E+00	Pa-233			
4 Pa-233	26.967d	1.000E+00	U-233			
5 U-233	1.592E+5y	1.000E+00	Th-229			
6 Th-229	7.34E+3y	1.000E+00	Ra-225			
7 Ra-225	14.9d	1.000E+00	Ac-225			
8 Ac-225	10.0d	1.000E+00	Fr-221			
9 Fr-221	4.9m	1.000E+00	At-217			
10 At-217	3.23E-2s	9.999E-01	Bi-213			
11 Bi-213	45.59m	9.791E-01	Po-213	2.090E-02	Tl-209	
12 Po-213	4.2E-6s	1.000E+00	Pb-209			
13 Tl-209	2.161m	1.000E+00	Pb-209			
14 Pb-209	3.253h	1.000E+00	Bi-209\$			

U-227

----- Daughter

Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 U-227 1.1m 1.000E+00 Th-223
 2 Th-223 0.60s 1.000E+00 Ra-219
 3 Ra-219 10ms 1.000E+00 Rn-215
 4 Rn-215 2.30us 1.000E+00 Po-211
 5 Po-211 0.516s 1.000E+00 Pb-207\$

U-228

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 U-228 9.1m 9.750E-01 Th-224
 2 Th-224 1.05s 1.000E+00 Ra-220
 3 Ra-220 1.79E-2s 1.000E+00 Rn-216
 4 Rn-216 4.5E-5s 1.000E+00 Po-212
 5 Po-212 2.99E-7s 1.000E+00 Pb-208\$

U-230

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 U-230 20.8d 1.000E+00 Th-226
 2 Th-226 30.57m 1.000E+00 Ra-222
 3 Ra-222 38.0s 1.000E+00 Rn-218
 4 Rn-218 3.5E-2s 1.000E+00 Po-214
 5 Po-214 1.643E-4s 1.000E+00 Pb-210
 6 Pb-210 22.20y 1.000E+00 Bi-210 1.900E-08 Hg-206
 7 Bi-210 5.013d 1.000E+00 Po-210 1.320E-06 Tl-206
 8 Hg-206 8.15m 1.000E+00 Tl-206
 9 Po-210 138.376d 1.000E+00 Pb-206\$
 10 Tl-206 4.200m 1.000E+00 Pb-206\$

U-231

----- Daughter
 Products -----
 Nuclide Halflife f1 Nuclide f2 Nuclide f3
 Nuclide f4 Nuclide
 1 U-231 4.2d 1.000E+00 Pa-231 4.000E-05 Th-227
 2 Pa-231 3.276E+4y 1.000E+00 Ac-227
 3 Ac-227 21.772y 9.862E-01 Th-227 1.380E-02 Fr-223
 4 Th-227 18.68d 1.000E+00 Ra-223
 5 Fr-223 22.00m 1.000E+00 Ra-223 6.000E-05 At-219
 6 Ra-223 11.43d 1.000E+00 Rn-219
 7 Rn-219 3.96s 1.000E+00 Po-215
 8 At-219 56s 9.700E-01 Bi-215
 9 Bi-215 7.6m 1.000E+00 Po-215
 10 Po-215 1.781E-3s 1.000E+00 Pb-211
 11 Pb-211 36.1m 1.000E+00 Bi-211

12 Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211
13 Tl-207	4.77m	1.000E+00	Pb-207\$		
14 Po-211	0.516s	1.000E+00	Pb-207\$		

U-232

Products			Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 U-232	68.9y	1.000E+00	Th-228		
2 Th-228	1.9116y	1.000E+00	Ra-224		
3 Ra-224	3.66d	1.000E+00	Rn-220		
4 Rn-220	55.6s	1.000E+00	Po-216		
5 Po-216	0.145s	1.000E+00	Pb-212		
6 Pb-212	10.64h	1.000E+00	Bi-212		
7 Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208
8 Po-212	2.99E-7s	1.000E+00	Pb-208\$		
9 Tl-208	3.053m	1.000E+00	Pb-208\$		

U-233

Products			Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 U-233	1.592E+5y	1.000E+00	Th-229		
2 Th-229	7.34E+3y	1.000E+00	Ra-225		
3 Ra-225	14.9d	1.000E+00	Ac-225		
4 Ac-225	10.0d	1.000E+00	Fr-221		
5 Fr-221	4.9m	1.000E+00	At-217		
6 At-217	3.23E-2s	9.999E-01	Bi-213		
7 Bi-213	45.59m	9.791E-01	Po-213	2.090E-02	Tl-209
8 Po-213	4.2E-6s	1.000E+00	Pb-209		
9 Tl-209	2.161m	1.000E+00	Pb-209		
10 Pb-209	3.253h	1.000E+00	Bi-209\$		

U-234

Products			Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 U-234	2.455E+5y	1.000E+00	Th-230		
2 Th-230	7.538E+4y	1.000E+00	Ra-226		
3 Ra-226	1600y	1.000E+00	Rn-222		
4 Rn-222	3.8235d	1.000E+00	Po-218		
5 Po-218	3.10m	9.998E-01	Pb-214	2.000E-04	At-218
6 Pb-214	26.8m	1.000E+00	Bi-214		
7 At-218	1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218
8 Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210
9 Rn-218	3.5E-2s	1.000E+00	Po-214		
10 Po-214	1.643E-4s	1.000E+00	Pb-210		
11 Tl-210	1.30m	1.000E+00	Pb-210		
12 Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206

13 Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206
14 Hg-206	8.15m	1.000E+00	Tl-206		
15 Po-210	138.376d	1.000E+00	Pb-206\$		
16 Tl-206	4.200m	1.000E+00	Pb-206\$		

U-235

Products			Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 U-235	7.04E+8y	1.000E+00	Th-231		
2 Th-231	25.52h	1.000E+00	Pa-231		
3 Pa-231	3.276E+4y	1.000E+00	Ac-227		
4 Ac-227	21.772y	9.862E-01	Th-227	1.380E-02	Fr-223
5 Th-227	18.68d	1.000E+00	Ra-223		
6 Fr-223	22.00m	1.000E+00	Ra-223	6.000E-05	At-219
7 Ra-223	11.43d	1.000E+00	Rn-219		
8 Rn-219	3.96s	1.000E+00	Po-215		
9 At-219	56s	9.700E-01	Bi-215		
10 Bi-215	7.6m	1.000E+00	Po-215		
11 Po-215	1.781E-3s	1.000E+00	Pb-211		
12 Pb-211	36.1m	1.000E+00	Bi-211		
13 Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211
14 Tl-207	4.77m	1.000E+00	Pb-207\$		
15 Po-211	0.516s	1.000E+00	Pb-207\$		

U-235m

Products			Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 U-235m	26m	1.000E+00	U-235		
2 U-235	7.04E+8y	1.000E+00	Th-231		
3 Th-231	25.52h	1.000E+00	Pa-231		
4 Pa-231	3.276E+4y	1.000E+00	Ac-227		
5 Ac-227	21.772y	9.862E-01	Th-227	1.380E-02	Fr-223
6 Th-227	18.68d	1.000E+00	Ra-223		
7 Fr-223	22.00m	1.000E+00	Ra-223	6.000E-05	At-219
8 Ra-223	11.43d	1.000E+00	Rn-219		
9 Rn-219	3.96s	1.000E+00	Po-215		
10 At-219	56s	9.700E-01	Bi-215		
11 Bi-215	7.6m	1.000E+00	Po-215		
12 Po-215	1.781E-3s	1.000E+00	Pb-211		
13 Pb-211	36.1m	1.000E+00	Bi-211		
14 Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211
15 Tl-207	4.77m	1.000E+00	Pb-207\$		
16 Po-211	0.516s	1.000E+00	Pb-207\$		

U-236

Products			Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3

Nuclide	f4	Nuclide		
1 U-236	2.342E+7y	1.000E+00	Th-232	
2 Th-232	1.405E10y	1.000E+00	Ra-228	
3 Ra-228	5.75y	1.000E+00	Ac-228	
4 Ac-228	6.15h	1.000E+00	Th-228	
5 Th-228	1.9116y	1.000E+00	Ra-224	
6 Ra-224	3.66d	1.000E+00	Rn-220	
7 Rn-220	55.6s	1.000E+00	Po-216	
8 Po-216	0.145s	1.000E+00	Pb-212	
9 Pb-212	10.64h	1.000E+00	Bi-212	
10 Bi-212	60.55m	6.406E-01	Po-212	3.594E-01 Tl-208
11 Po-212	2.99E-7s	1.000E+00	Pb-208\$	
12 Tl-208	3.053m	1.000E+00	Pb-208\$	

U-237

Products				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 U-237	6.75d	1.000E+00	Np-237		
2 Np-237	2.144E+6y	1.000E+00	Pa-233		
3 Pa-233	26.967d	1.000E+00	U-233		
4 U-233	1.592E+5y	1.000E+00	Th-229		
5 Th-229	7.34E+3y	1.000E+00	Ra-225		
6 Ra-225	14.9d	1.000E+00	Ac-225		
7 Ac-225	10.0d	1.000E+00	Fr-221		
8 Fr-221	4.9m	1.000E+00	At-217		
9 At-217	3.23E-2s	9.999E-01	Bi-213		
10 Bi-213	45.59m	9.791E-01	Po-213	2.090E-02	Tl-209
11 Po-213	4.2E-6s	1.000E+00	Pb-209		
12 Tl-209	2.161m	1.000E+00	Pb-209		
13 Pb-209	3.253h	1.000E+00	Bi-209\$		

U-238

Products				Daughter	
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 U-238	4.468E+9y	1.000E+00	Th-234	5.450E-07	SF
2 Th-234	24.10d	1.000E+00	Pa-234m		
3 Pa-234m	1.17m	1.600E-03	Pa-234	9.984E-01	U-234
4 Pa-234	6.70h	1.000E+00	U-234		
5 U-234	2.455E+5y	1.000E+00	Th-230		
6 Th-230	7.538E+4y	1.000E+00	Ra-226		
7 Ra-226	1600y	1.000E+00	Rn-222		
8 Rn-222	3.8235d	1.000E+00	Po-218		
9 Po-218	3.10m	9.998E-01	Pb-214	2.000E-04	At-218
10 Pb-214	26.8m	1.000E+00	Bi-214		
11 At-218	1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218
12 Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210
13 Rn-218	3.5E-2s	1.000E+00	Po-214		
14 Po-214	1.643E-4s	1.000E+00	Pb-210		

15	Tl-210	1.30m	1.000E+00	Pb-210		
16	Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206
17	Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206
18	Hg-206	8.15m	1.000E+00	Tl-206		
19	Po-210	138.376d	1.000E+00	Pb-206\$		
20	Tl-206	4.200m	1.000E+00	Pb-206\$		

U-239

Products				----- Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 U-239	23.45m	1.000E+00	Np-239			
2 Np-239	2.3565d	1.000E+00	Pu-239			
3 Pu-239	2.411E+4y	9.994E-01	U-235m	6.000E-04	U-235	
4 U-235m	26m	1.000E+00	U-235			
5 U-235	7.04E+8y	1.000E+00	Th-231			
6 Th-231	25.52h	1.000E+00	Pa-231			
7 Pa-231	3.276E+4y	1.000E+00	Ac-227			
8 Ac-227	21.772y	9.862E-01	Th-227	1.380E-02	Fr-223	
9 Th-227	18.68d	1.000E+00	Ra-223			
10 Fr-223	22.00m	1.000E+00	Ra-223	6.000E-05	At-219	
11 Ra-223	11.43d	1.000E+00	Rn-219			
12 Rn-219	3.96s	1.000E+00	Po-215			
13 At-219	56s	9.700E-01	Bi-215			
14 Bi-215	7.6m	1.000E+00	Po-215			
15 Po-215	1.781E-3s	1.000E+00	Pb-211			
16 Pb-211	36.1m	1.000E+00	Bi-211			
17 Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211	
18 Tl-207	4.77m	1.000E+00	Pb-207\$			
19 Po-211	0.516s	1.000E+00	Pb-207\$			

U-240

Products				----- Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 U-240	14.1h	1.000E+00	Np-240m			
2 Np-240m	7.22m	1.100E-03	Np-240	9.989E-01	Pu-240	
3 Np-240	61.9m	1.000E+00	Pu-240			
4 Pu-240	6564y	1.000E+00	U-236	5.750E-08	SF	
5 U-236	2.342E+7y	1.000E+00	Th-232			
6 Th-232	1.405E10y	1.000E+00	Ra-228			
7 Ra-228	5.75y	1.000E+00	Ac-228			
8 Ac-228	6.15h	1.000E+00	Th-228			
9 Th-228	1.9116y	1.000E+00	Ra-224			
10 Ra-224	3.66d	1.000E+00	Rn-220			
11 Rn-220	55.6s	1.000E+00	Po-216			
12 Po-216	0.145s	1.000E+00	Pb-212			
13 Pb-212	10.64h	1.000E+00	Bi-212			
14 Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208	
15 Po-212	2.99E-7s	1.000E+00	Pb-208\$			

16 Tl-208 3.053m 1.000E+00 Pb-208\$

U-242

Products				Daughter		
Nuclide		Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide					
1 U-242	16.8m	1.000E+00	Np-242			
2 Np-242	2.2m	1.000E+00	Pu-242			
3 Pu-242	3.75E+5y	1.000E+00	U-238	5.540E-06	SF	
4 U-238	4.468E+9y	1.000E+00	Th-234	5.450E-07	SF	
5 Th-234	24.10d	1.000E+00	Pa-234m			
6 Pa-234m	1.17m	1.600E-03	Pa-234	9.984E-01	U-234	
7 Pa-234	6.70h	1.000E+00	U-234			
8 U-234	2.455E+5y	1.000E+00	Th-230			
9 Th-230	7.538E+4y	1.000E+00	Ra-226			
10 Ra-226	1600y	1.000E+00	Rn-222			
11 Rn-222	3.8235d	1.000E+00	Po-218			
12 Po-218	3.10m	9.998E-01	Pb-214	2.000E-04	At-218	
13 Pb-214	26.8m	1.000E+00	Bi-214			
14 At-218	1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218	
15 Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210	
16 Rn-218	3.5E-2s	1.000E+00	Po-214			
17 Po-214	1.643E-4s	1.000E+00	Pb-210			
18 Tl-210	1.30m	1.000E+00	Pb-210			
19 Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206	
20 Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206	
21 Hg-206	8.15m	1.000E+00	Tl-206			
22 Po-210	138.376d	1.000E+00	Pb-206\$			
23 Tl-206	4.200m	1.000E+00	Pb-206\$			

Np-232

Products				Daughter		
Nuclide		Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide					
1 Np-232	14.7m	1.000E+00	U-232			
2 U-232	68.9y	1.000E+00	Th-228			
3 Th-228	1.9116y	1.000E+00	Ra-224			
4 Ra-224	3.66d	1.000E+00	Rn-220			
5 Rn-220	55.6s	1.000E+00	Po-216			
6 Po-216	0.145s	1.000E+00	Pb-212			
7 Pb-212	10.64h	1.000E+00	Bi-212			
8 Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208	
9 Po-212	2.99E-7s	1.000E+00	Pb-208\$			
10 Tl-208	3.053m	1.000E+00	Pb-208\$			

Np-233

Products				Daughter		
Nuclide		Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide					

1	Np-233	36.2m	1.000E+00	U-233	1.000E-05	Pa-229
2	U-233	1.592E+5y	1.000E+00	Th-229		
3	Pa-229	1.50d	9.952E-01	Th-229	4.800E-03	Ac-225
4	Th-229	7.34E+3y	1.000E+00	Ra-225		
5	Ra-225	14.9d	1.000E+00	Ac-225		
6	Ac-225	10.0d	1.000E+00	Fr-221		
7	Fr-221	4.9m	1.000E+00	At-217		
8	At-217	3.23E-2s	9.999E-01	Bi-213		
9	Bi-213	45.59m	9.791E-01	Po-213	2.090E-02	Tl-209
10	Po-213	4.2E-6s	1.000E+00	Pb-209		
11	Tl-209	2.161m	1.000E+00	Pb-209		
12	Pb-209	3.253h	1.000E+00	Bi-209\$		

Np-234

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Np-234	4.4d	1.000E+00	U-234			
2 U-234	2.455E+5y	1.000E+00	Th-230			
3 Th-230	7.538E+4y	1.000E+00	Ra-226			
4 Ra-226	1600y	1.000E+00	Rn-222			
5 Rn-222	3.8235d	1.000E+00	Po-218			
6 Po-218	3.10m	9.998E-01	Pb-214	2.000E-04	At-218	
7 Pb-214	26.8m	1.000E+00	Bi-214			
8 At-218	1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218	
9 Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210	
10 Rn-218	3.5E-2s	1.000E+00	Po-214			
11 Po-214	1.643E-4s	1.000E+00	Pb-210			
12 Tl-210	1.30m	1.000E+00	Pb-210			
13 Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206	
14 Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206	
15 Hg-206	8.15m	1.000E+00	Tl-206			
16 Po-210	138.376d	1.000E+00	Pb-206\$			
17 Tl-206	4.200m	1.000E+00	Pb-206\$			

Np-235

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Np-235	396.1d	3.993E-03	U-235m	9.960E-01	U-235	
2.600E-05 Pa-231						
2 U-235m	26m	1.000E+00	U-235			
3 U-235	7.04E+8y	1.000E+00	Th-231			
4 Th-231	25.52h	1.000E+00	Pa-231			
5 Pa-231	3.276E+4y	1.000E+00	Ac-227			
6 Ac-227	21.772y	9.862E-01	Th-227	1.380E-02	Fr-223	
7 Th-227	18.68d	1.000E+00	Ra-223			
8 Fr-223	22.00m	1.000E+00	Ra-223	6.000E-05	At-219	
9 Ra-223	11.43d	1.000E+00	Rn-219			
10 Rn-219	3.96s	1.000E+00	Po-215			

11	At-219	56s	9.700E-01	Bi-215	
12	Bi-215	7.6m	1.000E+00	Po-215	
13	Po-215	1.781E-3s	1.000E+00	Pb-211	
14	Pb-211	36.1m	1.000E+00	Bi-211	
15	Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03 Po-211
16	Tl-207	4.77m	1.000E+00	Pb-207\$	
17	Po-211	0.516s	1.000E+00	Pb-207\$	

Np-236

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Np-236	1.54E+5y	8.730E-01	U-236	1.250E-01	Pu-236	
1.600E-03 Pa-232						
2 U-236	2.342E+7y	1.000E+00	Th-232			
3 Pu-236	2.858y	1.000E+00	U-232	1.370E-09	SF	
4 Pa-232	1.31d	3.000E-05	Th-232	1.000E+00	U-232	
5 Th-232	1.405E10y	1.000E+00	Ra-228			
6 Ra-228	5.75y	1.000E+00	Ac-228			
7 Ac-228	6.15h	1.000E+00	Th-228			
8 U-232	68.9y	1.000E+00	Th-228			
9 Th-228	1.9116y	1.000E+00	Ra-224			
10 Ra-224	3.66d	1.000E+00	Rn-220			
11 Rn-220	55.6s	1.000E+00	Po-216			
12 Po-216	0.145s	1.000E+00	Pb-212			
13 Pb-212	10.64h	1.000E+00	Bi-212			
14 Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208	
15 Po-212	2.99E-7s	1.000E+00	Pb-208\$			
16 Tl-208	3.053m	1.000E+00	Pb-208\$			

Np-236m

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Np-236m	22.5h	5.200E-01	U-236	4.800E-01	Pu-236	
2 U-236	2.342E+7y	1.000E+00	Th-232			
3 Pu-236	2.858y	1.000E+00	U-232	1.370E-09	SF	
4 Th-232	1.405E10y	1.000E+00	Ra-228			
5 Ra-228	5.75y	1.000E+00	Ac-228			
6 Ac-228	6.15h	1.000E+00	Th-228			
7 U-232	68.9y	1.000E+00	Th-228			
8 Th-228	1.9116y	1.000E+00	Ra-224			
9 Ra-224	3.66d	1.000E+00	Rn-220			
10 Rn-220	55.6s	1.000E+00	Po-216			
11 Po-216	0.145s	1.000E+00	Pb-212			
12 Pb-212	10.64h	1.000E+00	Bi-212			
13 Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208	
14 Po-212	2.99E-7s	1.000E+00	Pb-208\$			
15 Tl-208	3.053m	1.000E+00	Pb-208\$			

Np-237

Products				Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3	
Nuclide f4	Nuclide						
1 Np-237	2.144E+6y	1.000E+00	Pa-233				
2 Pa-233	26.967d	1.000E+00	U-233				
3 U-233	1.592E+5y	1.000E+00	Th-229				
4 Th-229	7.34E+3y	1.000E+00	Ra-225				
5 Ra-225	14.9d	1.000E+00	Ac-225				
6 Ac-225	10.0d	1.000E+00	Fr-221				
7 Fr-221	4.9m	1.000E+00	At-217				
8 At-217	3.23E-2s	9.999E-01	Bi-213				
9 Bi-213	45.59m	9.791E-01	Po-213	2.090E-02	Tl-209		
10 Po-213	4.2E-6s	1.000E+00	Pb-209				
11 Tl-209	2.161m	1.000E+00	Pb-209				
12 Pb-209	3.253h	1.000E+00	Bi-209\$				

Np-238

Products				Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3	
Nuclide f4	Nuclide						
1 Np-238	2.117d	1.000E+00	Pu-238				
2 Pu-238	87.7y	1.000E+00	U-234	1.850E-09	SF		
3 U-234	2.455E+5y	1.000E+00	Th-230				
4 Th-230	7.538E+4y	1.000E+00	Ra-226				
5 Ra-226	1600y	1.000E+00	Rn-222				
6 Rn-222	3.8235d	1.000E+00	Po-218				
7 Po-218	3.10m	9.998E-01	Pb-214	2.000E-04	At-218		
8 Pb-214	26.8m	1.000E+00	Bi-214				
9 At-218	1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218		
10 Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210		
11 Rn-218	3.5E-2s	1.000E+00	Po-214				
12 Po-214	1.643E-4s	1.000E+00	Pb-210				
13 Tl-210	1.30m	1.000E+00	Pb-210				
14 Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206		
15 Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206		
16 Hg-206	8.15m	1.000E+00	Tl-206				
17 Po-210	138.376d	1.000E+00	Pb-206\$				
18 Tl-206	4.200m	1.000E+00	Pb-206\$				

Np-239

Products				Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3	
Nuclide f4	Nuclide						
1 Np-239	2.3565d	1.000E+00	Pu-239				
2 Pu-239	2.411E+4y	9.994E-01	U-235m	6.000E-04	U-235		
3 U-235m	26m	1.000E+00	U-235				
4 U-235	7.04E+8y	1.000E+00	Th-231				
5 Th-231	25.52h	1.000E+00	Pa-231				

6	Pa-231	3.276E+4y	1.000E+00	Ac-227		
7	Ac-227	21.772y	9.862E-01	Th-227	1.380E-02	Fr-223
8	Th-227	18.68d	1.000E+00	Ra-223		
9	Fr-223	22.00m	1.000E+00	Ra-223	6.000E-05	At-219
10	Ra-223	11.43d	1.000E+00	Rn-219		
11	Rn-219	3.96s	1.000E+00	Po-215		
12	At-219	56s	9.700E-01	Bi-215		
13	Bi-215	7.6m	1.000E+00	Po-215		
14	Po-215	1.781E-3s	1.000E+00	Pb-211		
15	Pb-211	36.1m	1.000E+00	Bi-211		
16	Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211
17	Tl-207	4.77m	1.000E+00	Pb-207\$		
18	Po-211	0.516s	1.000E+00	Pb-207\$		

Np-240

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Np-240	61.9m	1.000E+00	Pu-240			
2 Pu-240	6564y	1.000E+00	U-236	5.750E-08	SF	
3 U-236	2.342E+7y	1.000E+00	Th-232			
4 Th-232	1.405E10y	1.000E+00	Ra-228			
5 Ra-228	5.75y	1.000E+00	Ac-228			
6 Ac-228	6.15h	1.000E+00	Th-228			
7 Th-228	1.9116y	1.000E+00	Ra-224			
8 Ra-224	3.66d	1.000E+00	Rn-220			
9 Rn-220	55.6s	1.000E+00	Po-216			
10 Po-216	0.145s	1.000E+00	Pb-212			
11 Pb-212	10.64h	1.000E+00	Bi-212			
12 Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208	
13 Po-212	2.99E-7s	1.000E+00	Pb-208\$			
14 Tl-208	3.053m	1.000E+00	Pb-208\$			

Np-240m

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Np-240m	7.22m	1.100E-03	Np-240	9.989E-01	Pu-240	
2 Np-240	61.9m	1.000E+00	Pu-240			
3 Pu-240	6564y	1.000E+00	U-236	5.750E-08	SF	
4 U-236	2.342E+7y	1.000E+00	Th-232			
5 Th-232	1.405E10y	1.000E+00	Ra-228			
6 Ra-228	5.75y	1.000E+00	Ac-228			
7 Ac-228	6.15h	1.000E+00	Th-228			
8 Th-228	1.9116y	1.000E+00	Ra-224			
9 Ra-224	3.66d	1.000E+00	Rn-220			
10 Rn-220	55.6s	1.000E+00	Po-216			
11 Po-216	0.145s	1.000E+00	Pb-212			
12 Pb-212	10.64h	1.000E+00	Bi-212			
13 Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208	

14	Po-212	2.99E-7s	1.000E+00	Pb-208\$
15	Tl-208	3.053m	1.000E+00	Pb-208\$

Np-241

Products				Daughter		
Nuclide		Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide					
1 Np-241	13.9m	1.000E+00	Pu-241			
2 Pu-241	14.35y	1.000E+00	Am-241	2.450E-05	U-237	
3 Am-241	432.2y	1.000E+00	Np-237			
4 U-237	6.75d	1.000E+00	Np-237			
5 Np-237	2.144E+6y	1.000E+00	Pa-233			
6 Pa-233	26.967d	1.000E+00	U-233			
7 U-233	1.592E+5y	1.000E+00	Th-229			
8 Th-229	7.34E+3y	1.000E+00	Ra-225			
9 Ra-225	14.9d	1.000E+00	Ac-225			
10 Ac-225	10.0d	1.000E+00	Fr-221			
11 Fr-221	4.9m	1.000E+00	At-217			
12 At-217	3.23E-2s	9.999E-01	Bi-213			
13 Bi-213	45.59m	9.791E-01	Po-213	2.090E-02	Tl-209	
14 Po-213	4.2E-6s	1.000E+00	Pb-209			
15 Tl-209	2.161m	1.000E+00	Pb-209			
16 Pb-209	3.253h	1.000E+00	Bi-209\$			

Np-242

Products				Daughter		
Nuclide		Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide					
1 Np-242	2.2m	1.000E+00	Pu-242			
2 Pu-242	3.75E+5y	1.000E+00	U-238	5.540E-06	SF	
3 U-238	4.468E+9y	1.000E+00	Th-234	5.450E-07	SF	
4 Th-234	24.10d	1.000E+00	Pa-234m			
5 Pa-234m	1.17m	1.600E-03	Pa-234	9.984E-01	U-234	
6 Pa-234	6.70h	1.000E+00	U-234			
7 U-234	2.455E+5y	1.000E+00	Th-230			
8 Th-230	7.538E+4y	1.000E+00	Ra-226			
9 Ra-226	1600y	1.000E+00	Rn-222			
10 Rn-222	3.8235d	1.000E+00	Po-218			
11 Po-218	3.10m	9.998E-01	Pb-214	2.000E-04	At-218	
12 Pb-214	26.8m	1.000E+00	Bi-214			
13 At-218	1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218	
14 Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210	
15 Rn-218	3.5E-2s	1.000E+00	Po-214			
16 Po-214	1.643E-4s	1.000E+00	Pb-210			
17 Tl-210	1.30m	1.000E+00	Pb-210			
18 Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206	
19 Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206	
20 Hg-206	8.15m	1.000E+00	Tl-206			
21 Po-210	138.376d	1.000E+00	Pb-206\$			
22 Tl-206	4.200m	1.000E+00	Pb-206\$			

Np-242m

Products				Daughter			
Nuclide		Halflife	f1	Nuclide		f2	Nuclide f3
Nuclide f4	Nuclide						
1 Np-242m	5.5m	1.000E+00	Pu-242				
2 Pu-242	3.75E+5y	1.000E+00	U-238	5.540E-06	SF		
3 U-238	4.468E+9y	1.000E+00	Th-234	5.450E-07	SF		
4 Th-234	24.10d	1.000E+00	Pa-234m				
5 Pa-234m	1.17m	1.600E-03	Pa-234	9.984E-01	U-234		
6 Pa-234	6.70h	1.000E+00	U-234				
7 U-234	2.455E+5y	1.000E+00	Th-230				
8 Th-230	7.538E+4y	1.000E+00	Ra-226				
9 Ra-226	1600y	1.000E+00	Rn-222				
10 Rn-222	3.8235d	1.000E+00	Po-218				
11 Po-218	3.10m	9.998E-01	Pb-214	2.000E-04	At-218		
12 Pb-214	26.8m	1.000E+00	Bi-214				
13 At-218	1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218		
14 Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210		
15 Rn-218	3.5E-2s	1.000E+00	Po-214				
16 Po-214	1.643E-4s	1.000E+00	Pb-210				
17 Tl-210	1.30m	1.000E+00	Pb-210				
18 Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206		
19 Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206		
20 Hg-206	8.15m	1.000E+00	Tl-206				
21 Po-210	138.376d	1.000E+00	Pb-206\$				
22 Tl-206	4.200m	1.000E+00	Pb-206\$				

Pu-232

Products				Daughter			
Nuclide		Halflife	f1	Nuclide		f2	Nuclide f3
Nuclide f4	Nuclide						
1 Pu-232	33.7m	7.700E-01	Np-232	2.300E-01	U-228		
2 Np-232	14.7m	1.000E+00	U-232				
3 U-228	9.1m	9.750E-01	Th-224				
4 U-232	68.9y	1.000E+00	Th-228				
5 Th-228	1.9116y	1.000E+00	Ra-224				
6 Ra-224	3.66d	1.000E+00	Rn-220				
7 Rn-220	55.6s	1.000E+00	Po-216				
8 Po-216	0.145s	1.000E+00	Pb-212				
9 Pb-212	10.64h	1.000E+00	Bi-212				
10 Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208		
11 Th-224	1.05s	1.000E+00	Ra-220				
12 Ra-220	1.79E-2s	1.000E+00	Rn-216				
13 Rn-216	4.5E-5s	1.000E+00	Po-212				
14 Po-212	2.99E-7s	1.000E+00	Pb-208\$				
15 Tl-208	3.053m	1.000E+00	Pb-208\$				

Pu-234

----- Daughter

Products -----							
Nuclide	f4	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Pu-234		8.8h	9.400E-01	Np-234	6.000E-02	U-230	
2 Np-234		4.4d	1.000E+00	U-234			
3 U-230		20.8d	1.000E+00	Th-226			
4 U-234		2.455E+5y	1.000E+00	Th-230			
5 Th-230		7.538E+4y	1.000E+00	Ra-226			
6 Ra-226		1600y	1.000E+00	Rn-222			
7 Rn-222		3.8235d	1.000E+00	Po-218			
8 Po-218		3.10m	9.998E-01	Pb-214	2.000E-04	At-218	
9 Pb-214		26.8m	1.000E+00	Bi-214			
10 At-218		1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218	
11 Bi-214		19.9m	9.998E-01	Po-214	2.100E-04	Tl-210	
12 Th-226		30.57m	1.000E+00	Ra-222			
13 Ra-222		38.0s	1.000E+00	Rn-218			
14 Rn-218		3.5E-2s	1.000E+00	Po-214			
15 Po-214		1.643E-4s	1.000E+00	Pb-210			
16 Tl-210		1.30m	1.000E+00	Pb-210			
17 Pb-210		22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206	
18 Bi-210		5.013d	1.000E+00	Po-210	1.320E-06	Tl-206	
19 Hg-206		8.15m	1.000E+00	Tl-206			
20 Po-210		138.376d	1.000E+00	Pb-206\$			
21 Tl-206		4.200m	1.000E+00	Pb-206\$			

Pu-235

Products ----- Daughter							
Nuclide	f4	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Pu-235		25.3m	1.000E+00	Np-235	2.700E-05	U-231	
2 Np-235		396.1d	3.993E-03	U-235m	9.960E-01	U-235	
2.600E-05 Pa-231							
3 U-231		4.2d	1.000E+00	Pa-231	4.000E-05	Th-227	
4 U-235m		26m	1.000E+00	U-235			
5 U-235		7.04E+8y	1.000E+00	Th-231			
6 Th-231		25.52h	1.000E+00	Pa-231			
7 Pa-231		3.276E+4y	1.000E+00	Ac-227			
8 Ac-227		21.772y	9.862E-01	Th-227	1.380E-02	Fr-223	
9 Th-227		18.68d	1.000E+00	Ra-223			
10 Fr-223		22.00m	1.000E+00	Ra-223	6.000E-05	At-219	
11 Ra-223		11.43d	1.000E+00	Rn-219			
12 Rn-219		3.96s	1.000E+00	Po-215			
13 At-219		56s	9.700E-01	Bi-215			
14 Bi-215		7.6m	1.000E+00	Po-215			
15 Po-215		1.781E-3s	1.000E+00	Pb-211			
16 Pb-211		36.1m	1.000E+00	Bi-211			
17 Bi-211		2.14m	9.972E-01	Tl-207	2.760E-03	Po-211	
18 Tl-207		4.77m	1.000E+00	Pb-207\$			
19 Po-211		0.516s	1.000E+00	Pb-207\$			

Pu-236

Products				Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3	
1 Pu-236	2.858y	1.000E+00	U-232	1.370E-09	SF		
2 U-232	68.9y	1.000E+00	Th-228				
3 Th-228	1.9116y	1.000E+00	Ra-224				
4 Ra-224	3.66d	1.000E+00	Rn-220				
5 Rn-220	55.6s	1.000E+00	Po-216				
6 Po-216	0.145s	1.000E+00	Pb-212				
7 Pb-212	10.64h	1.000E+00	Bi-212				
8 Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208		
9 Po-212	2.99E-7s	1.000E+00	Pb-208\$				
10 Tl-208	3.053m	1.000E+00	Pb-208\$				

Pu-237

Products				Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3	
1 Pu-237	45.2d	1.000E+00	Np-237	4.200E-05	U-233		
2 Np-237	2.144E+6y	1.000E+00	Pa-233				
3 Pa-233	26.967d	1.000E+00	U-233				
4 U-233	1.592E+5y	1.000E+00	Th-229				
5 Th-229	7.34E+3y	1.000E+00	Ra-225				
6 Ra-225	14.9d	1.000E+00	Ac-225				
7 Ac-225	10.0d	1.000E+00	Fr-221				
8 Fr-221	4.9m	1.000E+00	At-217				
9 At-217	3.23E-2s	9.999E-01	Bi-213				
10 Bi-213	45.59m	9.791E-01	Po-213	2.090E-02	Tl-209		
11 Po-213	4.2E-6s	1.000E+00	Pb-209				
12 Tl-209	2.161m	1.000E+00	Pb-209				
13 Pb-209	3.253h	1.000E+00	Bi-209\$				

Pu-238

Products				Daughter			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3	
1 Pu-238	87.7y	1.000E+00	U-234	1.850E-09	SF		
2 U-234	2.455E+5y	1.000E+00	Th-230				
3 Th-230	7.538E+4y	1.000E+00	Ra-226				
4 Ra-226	1600y	1.000E+00	Rn-222				
5 Rn-222	3.8235d	1.000E+00	Po-218				
6 Po-218	3.10m	9.998E-01	Pb-214	2.000E-04	At-218		
7 Pb-214	26.8m	1.000E+00	Bi-214				
8 At-218	1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218		
9 Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210		
10 Rn-218	3.5E-2s	1.000E+00	Po-214				
11 Po-214	1.643E-4s	1.000E+00	Pb-210				
12 Tl-210	1.30m	1.000E+00	Pb-210				
13 Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206		

14 Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206
15 Hg-206	8.15m	1.000E+00	Tl-206		
16 Po-210	138.376d	1.000E+00	Pb-206\$		
17 Tl-206	4.200m	1.000E+00	Pb-206\$		

Pu-239

Products			Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 Pu-239	2.411E+4y	9.994E-01	U-235m	6.000E-04	U-235
2 U-235m	26m	1.000E+00	U-235		
3 U-235	7.04E+8y	1.000E+00	Th-231		
4 Th-231	25.52h	1.000E+00	Pa-231		
5 Pa-231	3.276E+4y	1.000E+00	Ac-227		
6 Ac-227	21.772y	9.862E-01	Th-227	1.380E-02	Fr-223
7 Th-227	18.68d	1.000E+00	Ra-223		
8 Fr-223	22.00m	1.000E+00	Ra-223	6.000E-05	At-219
9 Ra-223	11.43d	1.000E+00	Rn-219		
10 Rn-219	3.96s	1.000E+00	Po-215		
11 At-219	56s	9.700E-01	Bi-215		
12 Bi-215	7.6m	1.000E+00	Po-215		
13 Po-215	1.781E-3s	1.000E+00	Pb-211		
14 Pb-211	36.1m	1.000E+00	Bi-211		
15 Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211
16 Tl-207	4.77m	1.000E+00	Pb-207\$		
17 Po-211	0.516s	1.000E+00	Pb-207\$		

Pu-240

Products			Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 Pu-240	6564y	1.000E+00	U-236	5.750E-08	SF
2 U-236	2.342E+7y	1.000E+00	Th-232		
3 Th-232	1.405E10y	1.000E+00	Ra-228		
4 Ra-228	5.75y	1.000E+00	Ac-228		
5 Ac-228	6.15h	1.000E+00	Th-228		
6 Th-228	1.9116y	1.000E+00	Ra-224		
7 Ra-224	3.66d	1.000E+00	Rn-220		
8 Rn-220	55.6s	1.000E+00	Po-216		
9 Po-216	0.145s	1.000E+00	Pb-212		
10 Pb-212	10.64h	1.000E+00	Bi-212		
11 Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208
12 Po-212	2.99E-7s	1.000E+00	Pb-208\$		
13 Tl-208	3.053m	1.000E+00	Pb-208\$		

Pu-241

Products			Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				

1	Pu-241	14.35y	1.000E+00	Am-241	2.450E-05	U-237
2	Am-241	432.2y	1.000E+00	Np-237		
3	U-237	6.75d	1.000E+00	Np-237		
4	Np-237	2.144E+6y	1.000E+00	Pa-233		
5	Pa-233	26.967d	1.000E+00	U-233		
6	U-233	1.592E+5y	1.000E+00	Th-229		
7	Th-229	7.34E+3y	1.000E+00	Ra-225		
8	Ra-225	14.9d	1.000E+00	Ac-225		
9	Ac-225	10.0d	1.000E+00	Fr-221		
10	Fr-221	4.9m	1.000E+00	At-217		
11	At-217	3.23E-2s	9.999E-01	Bi-213		
12	Bi-213	45.59m	9.791E-01	Po-213	2.090E-02	Tl-209
13	Po-213	4.2E-6s	1.000E+00	Pb-209		
14	Tl-209	2.161m	1.000E+00	Pb-209		
15	Pb-209	3.253h	1.000E+00	Bi-209\$		

Pu-242

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1	Pu-242	3.75E+5y	1.000E+00	U-238	5.540E-06	SF
2	U-238	4.468E+9y	1.000E+00	Th-234	5.450E-07	SF
3	Th-234	24.10d	1.000E+00	Pa-234m		
4	Pa-234m	1.17m	1.600E-03	Pa-234	9.984E-01	U-234
5	Pa-234	6.70h	1.000E+00	U-234		
6	U-234	2.455E+5y	1.000E+00	Th-230		
7	Th-230	7.538E+4y	1.000E+00	Ra-226		
8	Ra-226	1600y	1.000E+00	Rn-222		
9	Rn-222	3.8235d	1.000E+00	Po-218		
10	Po-218	3.10m	9.998E-01	Pb-214	2.000E-04	At-218
11	Pb-214	26.8m	1.000E+00	Bi-214		
12	At-218	1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218
13	Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210
14	Rn-218	3.5E-2s	1.000E+00	Po-214		
15	Po-214	1.643E-4s	1.000E+00	Pb-210		
16	Tl-210	1.30m	1.000E+00	Pb-210		
17	Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206
18	Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206
19	Hg-206	8.15m	1.000E+00	Tl-206		
20	Po-210	138.376d	1.000E+00	Pb-206\$		
21	Tl-206	4.200m	1.000E+00	Pb-206\$		

Pu-243

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1	Pu-243	4.956h	1.000E+00	Am-243		
2	Am-243	7.37E+3y	1.000E+00	Np-239		
3	Np-239	2.3565d	1.000E+00	Pu-239		
4	Pu-239	2.411E+4y	9.994E-01	U-235m	6.000E-04	U-235

5	U-235m	26m	1.000E+00	U-235	
6	U-235	7.04E+8y	1.000E+00	Th-231	
7	Th-231	25.52h	1.000E+00	Pa-231	
8	Pa-231	3.276E+4y	1.000E+00	Ac-227	
9	Ac-227	21.772y	9.862E-01	Th-227	1.380E-02 Fr-223
10	Th-227	18.68d	1.000E+00	Ra-223	
11	Fr-223	22.00m	1.000E+00	Ra-223	6.000E-05 At-219
12	Ra-223	11.43d	1.000E+00	Rn-219	
13	Rn-219	3.96s	1.000E+00	Po-215	
14	At-219	56s	9.700E-01	Bi-215	
15	Bi-215	7.6m	1.000E+00	Po-215	
16	Po-215	1.781E-3s	1.000E+00	Pb-211	
17	Pb-211	36.1m	1.000E+00	Bi-211	
18	Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03 Po-211
19	Tl-207	4.77m	1.000E+00	Pb-207\$	
20	Po-211	0.516s	1.000E+00	Pb-207\$	

Pu-244

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Pu-244	8.00E+7y	9.988E-01	U-240	1.210E-03	SF	
2 U-240	14.1h	1.000E+00	Np-240m			
3 Np-240m	7.22m	1.100E-03	Np-240	9.989E-01	Pu-240	
4 Np-240	61.9m	1.000E+00	Pu-240			
5 Pu-240	6564y	1.000E+00	U-236	5.750E-08	SF	
6 U-236	2.342E+7y	1.000E+00	Th-232			
7 Th-232	1.405E10y	1.000E+00	Ra-228			
8 Ra-228	5.75y	1.000E+00	Ac-228			
9 Ac-228	6.15h	1.000E+00	Th-228			
10 Th-228	1.9116y	1.000E+00	Ra-224			
11 Ra-224	3.66d	1.000E+00	Rn-220			
12 Rn-220	55.6s	1.000E+00	Po-216			
13 Po-216	0.145s	1.000E+00	Pb-212			
14 Pb-212	10.64h	1.000E+00	Bi-212			
15 Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208	
16 Po-212	2.99E-7s	1.000E+00	Pb-208\$			
17 Tl-208	3.053m	1.000E+00	Pb-208\$			

Pu-245

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Pu-245	10.5h	1.000E+00	Am-245			
2 Am-245	2.05h	1.000E+00	Cm-245			
3 Cm-245	8.5E+3y	1.000E+00	Pu-241	6.100E-09	SF	
4 Pu-241	14.35y	1.000E+00	Am-241	2.450E-05	U-237	
5 Am-241	432.2y	1.000E+00	Np-237			
6 U-237	6.75d	1.000E+00	Np-237			
7 Np-237	2.144E+6y	1.000E+00	Pa-233			

8	Pa-233	26.967d	1.000E+00	U-233		
9	U-233	1.592E+5y	1.000E+00	Th-229		
10	Th-229	7.34E+3y	1.000E+00	Ra-225		
11	Ra-225	14.9d	1.000E+00	Ac-225		
12	Ac-225	10.0d	1.000E+00	Fr-221		
13	Fr-221	4.9m	1.000E+00	At-217		
14	At-217	3.23E-2s	9.999E-01	Bi-213		
15	Bi-213	45.59m	9.791E-01	Po-213	2.090E-02	Tl-209
16	Po-213	4.2E-6s	1.000E+00	Pb-209		
17	Tl-209	2.161m	1.000E+00	Pb-209		
18	Pb-209	3.253h	1.000E+00	Bi-209\$		

Pu-246

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1	Pu-246	10.84d	1.000E+00	Am-246m		
2	Am-246m	25.0m	1.000E+00	Cm-246		
3	Cm-246	4.76E+3y	9.997E-01	Pu-242	2.630E-04	SF
4	Pu-242	3.75E+5y	1.000E+00	U-238	5.540E-06	SF
5	U-238	4.468E+9y	1.000E+00	Th-234	5.450E-07	SF
6	Th-234	24.10d	1.000E+00	Pa-234m		
7	Pa-234m	1.17m	1.600E-03	Pa-234	9.984E-01	U-234
8	Pa-234	6.70h	1.000E+00	U-234		
9	U-234	2.455E+5y	1.000E+00	Th-230		
10	Th-230	7.538E+4y	1.000E+00	Ra-226		
11	Ra-226	1600y	1.000E+00	Rn-222		
12	Rn-222	3.8235d	1.000E+00	Po-218		
13	Po-218	3.10m	9.998E-01	Pb-214	2.000E-04	At-218
14	Pb-214	26.8m	1.000E+00	Bi-214		
15	At-218	1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218
16	Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210
17	Rn-218	3.5E-2s	1.000E+00	Po-214		
18	Po-214	1.643E-4s	1.000E+00	Pb-210		
19	Tl-210	1.30m	1.000E+00	Pb-210		
20	Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206
21	Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206
22	Hg-206	8.15m	1.000E+00	Tl-206		
23	Po-210	138.376d	1.000E+00	Pb-206\$		
24	Tl-206	4.200m	1.000E+00	Pb-206\$		

Am-237

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1	Am-237	73.0m	9.998E-01	Pu-237	2.500E-04	Np-233
2	Pu-237	45.2d	1.000E+00	Np-237	4.200E-05	U-233
3	Np-233	36.2m	1.000E+00	U-233	1.000E-05	Pa-229
4	Np-237	2.144E+6y	1.000E+00	Pa-233		
5	Pa-233	26.967d	1.000E+00	U-233		

6	U-233	1.592E+5y	1.000E+00	Th-229		
7	Pa-229	1.50d	9.952E-01	Th-229	4.800E-03	Ac-225
8	Th-229	7.34E+3y	1.000E+00	Ra-225		
9	Ra-225	14.9d	1.000E+00	Ac-225		
10	Ac-225	10.0d	1.000E+00	Fr-221		
11	Fr-221	4.9m	1.000E+00	At-217		
12	At-217	3.23E-2s	9.999E-01	Bi-213		
13	Bi-213	45.59m	9.791E-01	Po-213	2.090E-02	Tl-209
14	Po-213	4.2E-6s	1.000E+00	Pb-209		
15	Tl-209	2.161m	1.000E+00	Pb-209		
16	Pb-209	3.253h	1.000E+00	Bi-209\$		

Am-238

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1	Am-238	98m	1.000E+00	Pu-238	1.000E-06	Np-234
2	Pu-238	87.7y	1.000E+00	U-234	1.850E-09	SF
3	Np-234	4.4d	1.000E+00	U-234		
4	U-234	2.455E+5y	1.000E+00	Th-230		
5	Th-230	7.538E+4y	1.000E+00	Ra-226		
6	Ra-226	1600y	1.000E+00	Rn-222		
7	Rn-222	3.8235d	1.000E+00	Po-218		
8	Po-218	3.10m	9.998E-01	Pb-214	2.000E-04	At-218
9	Pb-214	26.8m	1.000E+00	Bi-214		
10	At-218	1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218
11	Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210
12	Rn-218	3.5E-2s	1.000E+00	Po-214		
13	Po-214	1.643E-4s	1.000E+00	Pb-210		
14	Tl-210	1.30m	1.000E+00	Pb-210		
15	Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206
16	Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206
17	Hg-206	8.15m	1.000E+00	Tl-206		
18	Po-210	138.376d	1.000E+00	Pb-206\$		
19	Tl-206	4.200m	1.000E+00	Pb-206\$		

Am-239

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1	Am-239	11.9h	9.999E-01	Pu-239	1.000E-04	Np-235
2	Pu-239	2.411E+4y	9.994E-01	U-235m	6.000E-04	U-235
3	Np-235	396.1d	3.993E-03	U-235m	9.960E-01	U-235
2.600E-05	Pa-231					
4	U-235m	26m	1.000E+00	U-235		
5	U-235	7.04E+8y	1.000E+00	Th-231		
6	Th-231	25.52h	1.000E+00	Pa-231		
7	Pa-231	3.276E+4y	1.000E+00	Ac-227		
8	Ac-227	21.772y	9.862E-01	Th-227	1.380E-02	Fr-223
9	Th-227	18.68d	1.000E+00	Ra-223		

10	Fr-223	22.00m	1.000E+00	Ra-223	6.000E-05	At-219
11	Ra-223	11.43d	1.000E+00	Rn-219		
12	Rn-219	3.96s	1.000E+00	Po-215		
13	At-219	56s	9.700E-01	Bi-215		
14	Bi-215	7.6m	1.000E+00	Po-215		
15	Po-215	1.781E-3s	1.000E+00	Pb-211		
16	Pb-211	36.1m	1.000E+00	Bi-211		
17	Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211
18	Tl-207	4.77m	1.000E+00	Pb-207\$		
19	Po-211	0.516s	1.000E+00	Pb-207\$		

Am-240

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Am-240	50.8h	1.000E+00	Pu-240	1.900E-06	Np-236	
2 Pu-240	6564y	1.000E+00	U-236	5.750E-08	SF	
3 Np-236	1.54E+5y	8.730E-01	U-236	1.600E-03	Pa-232	
1.250E-01 Pu-236						
4 U-236	2.342E+7y	1.000E+00	Th-232			
5 Pa-232	1.31d	3.000E-05	Th-232	1.000E+00	U-232	
6 Th-232	1.405E10y	1.000E+00	Ra-228			
7 Ra-228	5.75y	1.000E+00	Ac-228			
8 Ac-228	6.15h	1.000E+00	Th-228			
9 Pu-236	2.858y	1.000E+00	U-232	1.370E-09	SF	
10 U-232	68.9y	1.000E+00	Th-228			
11 Th-228	1.9116y	1.000E+00	Ra-224			
12 Ra-224	3.66d	1.000E+00	Rn-220			
13 Rn-220	55.6s	1.000E+00	Po-216			
14 Po-216	0.145s	1.000E+00	Pb-212			
15 Pb-212	10.64h	1.000E+00	Bi-212			
16 Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208	
17 Po-212	2.99E-7s	1.000E+00	Pb-208\$			
18 Tl-208	3.053m	1.000E+00	Pb-208\$			

Am-241

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Am-241	432.2y	1.000E+00	Np-237			
2 Np-237	2.144E+6y	1.000E+00	Pa-233			
3 Pa-233	26.967d	1.000E+00	U-233			
4 U-233	1.592E+5y	1.000E+00	Th-229			
5 Th-229	7.34E+3y	1.000E+00	Ra-225			
6 Ra-225	14.9d	1.000E+00	Ac-225			
7 Ac-225	10.0d	1.000E+00	Fr-221			
8 Fr-221	4.9m	1.000E+00	At-217			
9 At-217	3.23E-2s	9.999E-01	Bi-213			
10 Bi-213	45.59m	9.791E-01	Po-213	2.090E-02	Tl-209	
11 Po-213	4.2E-6s	1.000E+00	Pb-209			

12	Tl-209	2.161m	1.000E+00	Pb-209
13	Pb-209	3.253h	1.000E+00	Bi-209\$

Am-242

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Am-242	16.02h	8.270E-01	Cm-242	1.730E-01	Pu-242	
2 Cm-242	162.8d	1.000E+00	Pu-238	6.370E-08	SF	
3 Pu-242	3.75E+5y	1.000E+00	U-238	5.540E-06	SF	
4 Pu-238	87.7y	1.000E+00	U-234	1.850E-09	SF	
5 U-238	4.468E+9y	1.000E+00	Th-234	5.450E-07	SF	
6 Th-234	24.10d	1.000E+00	Pa-234m			
7 Pa-234m	1.17m	1.600E-03	Pa-234	9.984E-01	U-234	
8 Pa-234	6.70h	1.000E+00	U-234			
9 U-234	2.455E+5y	1.000E+00	Th-230			
10 Th-230	7.538E+4y	1.000E+00	Ra-226			
11 Ra-226	1600y	1.000E+00	Rn-222			
12 Rn-222	3.8235d	1.000E+00	Po-218			
13 Po-218	3.10m	9.998E-01	Pb-214	2.000E-04	At-218	
14 Pb-214	26.8m	1.000E+00	Bi-214			
15 At-218	1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218	
16 Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210	
17 Rn-218	3.5E-2s	1.000E+00	Po-214			
18 Po-214	1.643E-4s	1.000E+00	Pb-210			
19 Tl-210	1.30m	1.000E+00	Pb-210			
20 Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206	
21 Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206	
22 Hg-206	8.15m	1.000E+00	Tl-206			
23 Po-210	138.376d	1.000E+00	Pb-206\$			
24 Tl-206	4.200m	1.000E+00	Pb-206\$			

Am-242m

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Am-242m	141y	9.955E-01	Am-242	4.500E-03	Np-238	
2 Am-242	16.02h	8.270E-01	Cm-242	1.730E-01	Pu-242	
3 Np-238	2.117d	1.000E+00	Pu-238			
4 Cm-242	162.8d	1.000E+00	Pu-238	6.370E-08	SF	
5 Pu-242	3.75E+5y	1.000E+00	U-238	5.540E-06	SF	
6 Pu-238	87.7y	1.000E+00	U-234	1.850E-09	SF	
7 U-238	4.468E+9y	1.000E+00	Th-234	5.450E-07	SF	
8 Th-234	24.10d	1.000E+00	Pa-234m			
9 Pa-234m	1.17m	1.600E-03	Pa-234	9.984E-01	U-234	
10 Pa-234	6.70h	1.000E+00	U-234			
11 U-234	2.455E+5y	1.000E+00	Th-230			
12 Th-230	7.538E+4y	1.000E+00	Ra-226			
13 Ra-226	1600y	1.000E+00	Rn-222			
14 Rn-222	3.8235d	1.000E+00	Po-218			

15	Po-218	3.10m	9.998E-01	Pb-214	2.000E-04	At-218
16	Pb-214	26.8m	1.000E+00	Bi-214		
17	At-218	1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218
18	Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210
19	Rn-218	3.5E-2s	1.000E+00	Po-214		
20	Po-214	1.643E-4s	1.000E+00	Pb-210		
21	Tl-210	1.30m	1.000E+00	Pb-210		
22	Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206
23	Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206
24	Hg-206	8.15m	1.000E+00	Tl-206		
25	Po-210	138.376d	1.000E+00	Pb-206\$		
26	Tl-206	4.200m	1.000E+00	Pb-206\$		

Am-243

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Am-243	7.37E+3y	1.000E+00	Np-239			
2 Np-239	2.3565d	1.000E+00	Pu-239			
3 Pu-239	2.411E+4y	9.994E-01	U-235m	6.000E-04	U-235	
4 U-235m	26m	1.000E+00	U-235			
5 U-235	7.04E+8y	1.000E+00	Th-231			
6 Th-231	25.52h	1.000E+00	Pa-231			
7 Pa-231	3.276E+4y	1.000E+00	Ac-227			
8 Ac-227	21.772y	9.862E-01	Th-227	1.380E-02	Fr-223	
9 Th-227	18.68d	1.000E+00	Ra-223			
10 Fr-223	22.00m	1.000E+00	Ra-223	6.000E-05	At-219	
11 Ra-223	11.43d	1.000E+00	Rn-219			
12 Rn-219	3.96s	1.000E+00	Po-215			
13 At-219	56s	9.700E-01	Bi-215			
14 Bi-215	7.6m	1.000E+00	Po-215			
15 Po-215	1.781E-3s	1.000E+00	Pb-211			
16 Pb-211	36.1m	1.000E+00	Bi-211			
17 Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211	
18 Tl-207	4.77m	1.000E+00	Pb-207\$			
19 Po-211	0.516s	1.000E+00	Pb-207\$			

Am-244

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Am-244	10.1h	1.000E+00	Cm-244			
2 Cm-244	18.10y	1.000E+00	Pu-240	1.371E-06	SF	
3 Pu-240	6564y	1.000E+00	U-236	5.750E-08	SF	
4 U-236	2.342E+7y	1.000E+00	Th-232			
5 Th-232	1.405E10y	1.000E+00	Ra-228			
6 Ra-228	5.75y	1.000E+00	Ac-228			
7 Ac-228	6.15h	1.000E+00	Th-228			
8 Th-228	1.9116y	1.000E+00	Ra-224			
9 Ra-224	3.66d	1.000E+00	Rn-220			

10	Rn-220	55.6s	1.000E+00	Po-216		
11	Po-216	0.145s	1.000E+00	Pb-212		
12	Pb-212	10.64h	1.000E+00	Bi-212		
13	Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208
14	Po-212	2.99E-7s	1.000E+00	Pb-208\$		
15	Tl-208	3.053m	1.000E+00	Pb-208\$		

Am-244m

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Am-244m	26m	9.996E-01	Cm-244			
2 Cm-244	18.10y	1.000E+00	Pu-240	1.371E-06	SF	
3 Pu-240	6564y	1.000E+00	U-236	5.750E-08	SF	
4 U-236	2.342E+7y	1.000E+00	Th-232			
5 Th-232	1.405E10y	1.000E+00	Ra-228			
6 Ra-228	5.75y	1.000E+00	Ac-228			
7 Ac-228	6.15h	1.000E+00	Th-228			
8 Th-228	1.9116y	1.000E+00	Ra-224			
9 Ra-224	3.66d	1.000E+00	Rn-220			
10 Rn-220	55.6s	1.000E+00	Po-216			
11 Po-216	0.145s	1.000E+00	Pb-212			
12 Pb-212	10.64h	1.000E+00	Bi-212			
13 Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208	
14 Po-212	2.99E-7s	1.000E+00	Pb-208\$			
15 Tl-208	3.053m	1.000E+00	Pb-208\$			

Am-245

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Am-245	2.05h	1.000E+00	Cm-245			
2 Cm-245	8.5E+3y	1.000E+00	Pu-241	6.100E-09	SF	
3 Pu-241	14.35y	1.000E+00	Am-241	2.450E-05	U-237	
4 Am-241	432.2y	1.000E+00	Np-237			
5 U-237	6.75d	1.000E+00	Np-237			
6 Np-237	2.144E+6y	1.000E+00	Pa-233			
7 Pa-233	26.967d	1.000E+00	U-233			
8 U-233	1.592E+5y	1.000E+00	Th-229			
9 Th-229	7.34E+3y	1.000E+00	Ra-225			
10 Ra-225	14.9d	1.000E+00	Ac-225			
11 Ac-225	10.0d	1.000E+00	Fr-221			
12 Fr-221	4.9m	1.000E+00	At-217			
13 At-217	3.23E-2s	9.999E-01	Bi-213			
14 Bi-213	45.59m	9.791E-01	Po-213	2.090E-02	Tl-209	
15 Po-213	4.2E-6s	1.000E+00	Pb-209			
16 Tl-209	2.161m	1.000E+00	Pb-209			
17 Pb-209	3.253h	1.000E+00	Bi-209\$			

Am-246

Products -----				Daughter -----			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3	
Nuclide f4	Nuclide						
1 Am-246	39m	1.000E+00	Cm-246				
2 Cm-246	4.76E+3y	9.997E-01	Pu-242	2.630E-04	SF		
3 Pu-242	3.75E+5y	1.000E+00	U-238	5.540E-06	SF		
4 U-238	4.468E+9y	1.000E+00	Th-234	5.450E-07	SF		
5 Th-234	24.10d	1.000E+00	Pa-234m				
6 Pa-234m	1.17m	1.600E-03	Pa-234	9.984E-01	U-234		
7 Pa-234	6.70h	1.000E+00	U-234				
8 U-234	2.455E+5y	1.000E+00	Th-230				
9 Th-230	7.538E+4y	1.000E+00	Ra-226				
10 Ra-226	1600y	1.000E+00	Rn-222				
11 Rn-222	3.8235d	1.000E+00	Po-218				
12 Po-218	3.10m	9.998E-01	Pb-214	2.000E-04	At-218		
13 Pb-214	26.8m	1.000E+00	Bi-214				
14 At-218	1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218		
15 Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210		
16 Rn-218	3.5E-2s	1.000E+00	Po-214				
17 Po-214	1.643E-4s	1.000E+00	Pb-210				
18 Tl-210	1.30m	1.000E+00	Pb-210				
19 Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206		
20 Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206		
21 Hg-206	8.15m	1.000E+00	Tl-206				
22 Po-210	138.376d	1.000E+00	Pb-206\$				
23 Tl-206	4.200m	1.000E+00	Pb-206\$				

Am-246m

Products -----				Daughter -----			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3	
Nuclide f4	Nuclide						
1 Am-246m	25.0m	1.000E+00	Cm-246				
2 Cm-246	4.76E+3y	9.997E-01	Pu-242	2.630E-04	SF		
3 Pu-242	3.75E+5y	1.000E+00	U-238	5.540E-06	SF		
4 U-238	4.468E+9y	1.000E+00	Th-234	5.450E-07	SF		
5 Th-234	24.10d	1.000E+00	Pa-234m				
6 Pa-234m	1.17m	1.600E-03	Pa-234	9.984E-01	U-234		
7 Pa-234	6.70h	1.000E+00	U-234				
8 U-234	2.455E+5y	1.000E+00	Th-230				
9 Th-230	7.538E+4y	1.000E+00	Ra-226				
10 Ra-226	1600y	1.000E+00	Rn-222				
11 Rn-222	3.8235d	1.000E+00	Po-218				
12 Po-218	3.10m	9.998E-01	Pb-214	2.000E-04	At-218		
13 Pb-214	26.8m	1.000E+00	Bi-214				
14 At-218	1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218		
15 Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210		
16 Rn-218	3.5E-2s	1.000E+00	Po-214				
17 Po-214	1.643E-4s	1.000E+00	Pb-210				
18 Tl-210	1.30m	1.000E+00	Pb-210				
19 Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206		

20 Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206
21 Hg-206	8.15m	1.000E+00	Tl-206		
22 Po-210	138.376d	1.000E+00	Pb-206\$		
23 Tl-206	4.200m	1.000E+00	Pb-206\$		

Am-247

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Am-247	23.0m	1.000E+00	Cm-247			
2 Cm-247	1.56E+7y	1.000E+00	Pu-243			
3 Pu-243	4.956h	1.000E+00	Am-243			
4 Am-243	7.37E+3y	1.000E+00	Np-239			
5 Np-239	2.3565d	1.000E+00	Pu-239			
6 Pu-239	2.411E+4y	9.994E-01	U-235m	6.000E-04	U-235	
7 U-235m	26m	1.000E+00	U-235			
8 U-235	7.04E+8y	1.000E+00	Th-231			
9 Th-231	25.52h	1.000E+00	Pa-231			
10 Pa-231	3.276E+4y	1.000E+00	Ac-227			
11 Ac-227	21.772y	9.862E-01	Th-227	1.380E-02	Fr-223	
12 Th-227	18.68d	1.000E+00	Ra-223			
13 Fr-223	22.00m	1.000E+00	Ra-223	6.000E-05	At-219	
14 Ra-223	11.43d	1.000E+00	Rn-219			
15 Rn-219	3.96s	1.000E+00	Po-215			
16 At-219	56s	9.700E-01	Bi-215			
17 Bi-215	7.6m	1.000E+00	Po-215			
18 Po-215	1.781E-3s	1.000E+00	Pb-211			
19 Pb-211	36.1m	1.000E+00	Bi-211			
20 Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211	
21 Tl-207	4.77m	1.000E+00	Pb-207\$			
22 Po-211	0.516s	1.000E+00	Pb-207\$			

Cm-238

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Cm-238	2.4h	9.616E-01	Am-238	3.840E-02	Pu-234	
2 Am-238	98m	1.000E+00	Pu-238	1.000E-06	Np-234	
3 Pu-234	8.8h	9.400E-01	Np-234	6.000E-02	U-230	
4 Pu-238	87.7y	1.000E+00	U-234	1.850E-09	SF	
5 Np-234	4.4d	1.000E+00	U-234			
6 U-234	2.455E+5y	1.000E+00	Th-230			
7 Th-230	7.538E+4y	1.000E+00	Ra-226			
8 Ra-226	1600y	1.000E+00	Rn-222			
9 Rn-222	3.8235d	1.000E+00	Po-218			
10 Po-218	3.10m	9.998E-01	Pb-214	2.000E-04	At-218	
11 Pb-214	26.8m	1.000E+00	Bi-214			
12 At-218	1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218	
13 Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210	
14 U-230	20.8d	1.000E+00	Th-226			

15	Th-226	30.57m	1.000E+00	Ra-222		
16	Ra-222	38.0s	1.000E+00	Rn-218		
17	Rn-218	3.5E-2s	1.000E+00	Po-214		
18	Po-214	1.643E-4s	1.000E+00	Pb-210		
19	Tl-210	1.30m	1.000E+00	Pb-210		
20	Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206
21	Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206
22	Hg-206	8.15m	1.000E+00	Tl-206		
23	Po-210	138.376d	1.000E+00	Pb-206\$		
24	Tl-206	4.200m	1.000E+00	Pb-206\$		

Cm-239

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Cm-239	2.9h	1.000E+00	Am-239			
2 Am-239	11.9h	9.999E-01	Pu-239	1.000E-04	Np-235	
3 Pu-239	2.411E+4y	9.994E-01	U-235m	6.000E-04	U-235	
4 Np-235	396.1d	3.993E-03	U-235m	9.960E-01	U-235	
2.600E-05 Pa-231						
5 U-235m	26m	1.000E+00	U-235			
6 U-235	7.04E+8y	1.000E+00	Th-231			
7 Th-231	25.52h	1.000E+00	Pa-231			
8 Pa-231	3.276E+4y	1.000E+00	Ac-227			
9 Ac-227	21.772y	9.862E-01	Th-227	1.380E-02	Fr-223	
10 Th-227	18.68d	1.000E+00	Ra-223			
11 Fr-223	22.00m	1.000E+00	Ra-223	6.000E-05	At-219	
12 Ra-223	11.43d	1.000E+00	Rn-219			
13 Rn-219	3.96s	1.000E+00	Po-215			
14 At-219	56s	9.700E-01	Bi-215			
15 Bi-215	7.6m	1.000E+00	Po-215			
16 Po-215	1.781E-3s	1.000E+00	Pb-211			
17 Pb-211	36.1m	1.000E+00	Bi-211			
18 Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211	
19 Tl-207	4.77m	1.000E+00	Pb-207\$			
20 Po-211	0.516s	1.000E+00	Pb-207\$			

Cm-240

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Cm-240	27d	9.970E-01	Pu-236	3.900E-08	SF	
2 Pu-236	2.858y	1.000E+00	U-232	1.370E-09	SF	
3 U-232	68.9y	1.000E+00	Th-228			
4 Th-228	1.9116y	1.000E+00	Ra-224			
5 Ra-224	3.66d	1.000E+00	Rn-220			
6 Rn-220	55.6s	1.000E+00	Po-216			
7 Po-216	0.145s	1.000E+00	Pb-212			
8 Pb-212	10.64h	1.000E+00	Bi-212			
9 Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208	

10	Po-212	2.99E-7s	1.000E+00	Pb-208\$
11	Tl-208	3.053m	1.000E+00	Pb-208\$

Cm-241

Products				----- Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4			Nuclide			
1 Cm-241	32.8d	9.900E-01	Am-241	1.000E-02	Pu-237	
2 Am-241	432.2y	1.000E+00	Np-237			
3 Pu-237	45.2d	1.000E+00	Np-237	4.200E-05	U-233	
4 Np-237	2.144E+6y	1.000E+00	Pa-233			
5 Pa-233	26.967d	1.000E+00	U-233			
6 U-233	1.592E+5y	1.000E+00	Th-229			
7 Th-229	7.34E+3y	1.000E+00	Ra-225			
8 Ra-225	14.9d	1.000E+00	Ac-225			
9 Ac-225	10.0d	1.000E+00	Fr-221			
10 Fr-221	4.9m	1.000E+00	At-217			
11 At-217	3.23E-2s	9.999E-01	Bi-213			
12 Bi-213	45.59m	9.791E-01	Po-213	2.090E-02	Tl-209	
13 Po-213	4.2E-6s	1.000E+00	Pb-209			
14 Tl-209	2.161m	1.000E+00	Pb-209			
15 Pb-209	3.253h	1.000E+00	Bi-209\$			

Cm-242

Products				----- Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4			Nuclide			
1 Cm-242	162.8d	1.000E+00	Pu-238	6.370E-08	SF	
2 Pu-238	87.7y	1.000E+00	U-234	1.850E-09	SF	
3 U-234	2.455E+5y	1.000E+00	Th-230			
4 Th-230	7.538E+4y	1.000E+00	Ra-226			
5 Ra-226	1600y	1.000E+00	Rn-222			
6 Rn-222	3.8235d	1.000E+00	Po-218			
7 Po-218	3.10m	9.998E-01	Pb-214	2.000E-04	At-218	
8 Pb-214	26.8m	1.000E+00	Bi-214			
9 At-218	1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218	
10 Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210	
11 Rn-218	3.5E-2s	1.000E+00	Po-214			
12 Po-214	1.643E-4s	1.000E+00	Pb-210			
13 Tl-210	1.30m	1.000E+00	Pb-210			
14 Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206	
15 Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206	
16 Hg-206	8.15m	1.000E+00	Tl-206			
17 Po-210	138.376d	1.000E+00	Pb-206\$			
18 Tl-206	4.200m	1.000E+00	Pb-206\$			

Cm-243

Products				----- Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3

Nuclide	f4	Nuclide				
1 Cm-243	29.1y	2.400E-03	Am-243	9.976E-01	Pu-239	
2 Am-243	7.37E+3y	1.000E+00	Np-239			
3 Np-239	2.3565d	1.000E+00	Pu-239			
4 Pu-239	2.411E+4y	9.994E-01	U-235m	6.000E-04	U-235	
5 U-235m	26m	1.000E+00	U-235			
6 U-235	7.04E+8y	1.000E+00	Th-231			
7 Th-231	25.52h	1.000E+00	Pa-231			
8 Pa-231	3.276E+4y	1.000E+00	Ac-227			
9 Ac-227	21.772y	9.862E-01	Th-227	1.380E-02	Fr-223	
10 Th-227	18.68d	1.000E+00	Ra-223			
11 Fr-223	22.00m	1.000E+00	Ra-223	6.000E-05	At-219	
12 Ra-223	11.43d	1.000E+00	Rn-219			
13 Rn-219	3.96s	1.000E+00	Po-215			
14 At-219	56s	9.700E-01	Bi-215			
15 Bi-215	7.6m	1.000E+00	Po-215			
16 Po-215	1.781E-3s	1.000E+00	Pb-211			
17 Pb-211	36.1m	1.000E+00	Bi-211			
18 Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211	
19 Tl-207	4.77m	1.000E+00	Pb-207\$			
20 Po-211	0.516s	1.000E+00	Pb-207\$			

Cm-244

				----- Daughter		
Products						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Cm-244	18.10y	1.000E+00	Pu-240	1.371E-06	SF	
2 Pu-240	6564y	1.000E+00	U-236	5.750E-08	SF	
3 U-236	2.342E+7y	1.000E+00	Th-232			
4 Th-232	1.405E10y	1.000E+00	Ra-228			
5 Ra-228	5.75y	1.000E+00	Ac-228			
6 Ac-228	6.15h	1.000E+00	Th-228			
7 Th-228	1.9116y	1.000E+00	Ra-224			
8 Ra-224	3.66d	1.000E+00	Rn-220			
9 Rn-220	55.6s	1.000E+00	Po-216			
10 Po-216	0.145s	1.000E+00	Pb-212			
11 Pb-212	10.64h	1.000E+00	Bi-212			
12 Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208	
13 Po-212	2.99E-7s	1.000E+00	Pb-208\$			
14 Tl-208	3.053m	1.000E+00	Pb-208\$			

Cm-245

				----- Daughter		
Products						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Cm-245	8.5E+3y	1.000E+00	Pu-241	6.100E-09	SF	
2 Pu-241	14.35y	1.000E+00	Am-241	2.450E-05	U-237	
3 Am-241	432.2y	1.000E+00	Np-237			
4 U-237	6.75d	1.000E+00	Np-237			
5 Np-237	2.144E+6y	1.000E+00	Pa-233			

6	Pa-233	26.967d	1.000E+00	U-233		
7	U-233	1.592E+5y	1.000E+00	Th-229		
8	Th-229	7.34E+3y	1.000E+00	Ra-225		
9	Ra-225	14.9d	1.000E+00	Ac-225		
10	Ac-225	10.0d	1.000E+00	Fr-221		
11	Fr-221	4.9m	1.000E+00	At-217		
12	At-217	3.23E-2s	9.999E-01	Bi-213		
13	Bi-213	45.59m	9.791E-01	Po-213	2.090E-02	Tl-209
14	Po-213	4.2E-6s	1.000E+00	Pb-209		
15	Tl-209	2.161m	1.000E+00	Pb-209		
16	Pb-209	3.253h	1.000E+00	Bi-209\$		

Cm-246

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1	Cm-246	4.76E+3y	9.997E-01	Pu-242	2.630E-04	SF
2	Pu-242	3.75E+5y	1.000E+00	U-238	5.540E-06	SF
3	U-238	4.468E+9y	1.000E+00	Th-234	5.450E-07	SF
4	Th-234	24.10d	1.000E+00	Pa-234m		
5	Pa-234m	1.17m	1.600E-03	Pa-234	9.984E-01	U-234
6	Pa-234	6.70h	1.000E+00	U-234		
7	U-234	2.455E+5y	1.000E+00	Th-230		
8	Th-230	7.538E+4y	1.000E+00	Ra-226		
9	Ra-226	1600y	1.000E+00	Rn-222		
10	Rn-222	3.8235d	1.000E+00	Po-218		
11	Po-218	3.10m	9.998E-01	Pb-214	2.000E-04	At-218
12	Pb-214	26.8m	1.000E+00	Bi-214		
13	At-218	1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218
14	Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210
15	Rn-218	3.5E-2s	1.000E+00	Po-214		
16	Po-214	1.643E-4s	1.000E+00	Pb-210		
17	Tl-210	1.30m	1.000E+00	Pb-210		
18	Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206
19	Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206
20	Hg-206	8.15m	1.000E+00	Tl-206		
21	Po-210	138.376d	1.000E+00	Pb-206\$		
22	Tl-206	4.200m	1.000E+00	Pb-206\$		

Cm-247

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1	Cm-247	1.56E+7y	1.000E+00	Pu-243		
2	Pu-243	4.956h	1.000E+00	Am-243		
3	Am-243	7.37E+3y	1.000E+00	Np-239		
4	Np-239	2.3565d	1.000E+00	Pu-239		
5	Pu-239	2.411E+4y	9.994E-01	U-235m	6.000E-04	U-235
6	U-235m	26m	1.000E+00	U-235		
7	U-235	7.04E+8y	1.000E+00	Th-231		

8	Th-231	25.52h	1.000E+00	Pa-231		
9	Pa-231	3.276E+4y	1.000E+00	Ac-227		
10	Ac-227	21.772y	9.862E-01	Th-227	1.380E-02	Fr-223
11	Th-227	18.68d	1.000E+00	Ra-223		
12	Fr-223	22.00m	1.000E+00	Ra-223	6.000E-05	At-219
13	Ra-223	11.43d	1.000E+00	Rn-219		
14	Rn-219	3.96s	1.000E+00	Po-215		
15	At-219	56s	9.700E-01	Bi-215		
16	Bi-215	7.6m	1.000E+00	Po-215		
17	Po-215	1.781E-3s	1.000E+00	Pb-211		
18	Pb-211	36.1m	1.000E+00	Bi-211		
19	Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211
20	Tl-207	4.77m	1.000E+00	Pb-207\$		
21	Po-211	0.516s	1.000E+00	Pb-207\$		

Cm-248

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Cm-248	3.48E+5y	9.161E-01	Pu-244	8.390E-02	SF	
2 Pu-244	8.00E+7y	9.988E-01	U-240	1.210E-03	SF	
3 U-240	14.1h	1.000E+00	Np-240m			
4 Np-240m	7.22m	1.100E-03	Np-240	9.989E-01	Pu-240	
5 Np-240	61.9m	1.000E+00	Pu-240			
6 Pu-240	6564y	1.000E+00	U-236	5.750E-08	SF	
7 U-236	2.342E+7y	1.000E+00	Th-232			
8 Th-232	1.405E10y	1.000E+00	Ra-228			
9 Ra-228	5.75y	1.000E+00	Ac-228			
10 Ac-228	6.15h	1.000E+00	Th-228			
11 Th-228	1.9116y	1.000E+00	Ra-224			
12 Ra-224	3.66d	1.000E+00	Rn-220			
13 Rn-220	55.6s	1.000E+00	Po-216			
14 Po-216	0.145s	1.000E+00	Pb-212			
15 Pb-212	10.64h	1.000E+00	Bi-212			
16 Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208	
17 Po-212	2.99E-7s	1.000E+00	Pb-208\$			
18 Tl-208	3.053m	1.000E+00	Pb-208\$			

Cm-249

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Cm-249	64.15m	1.000E+00	Bk-249			
2 Bk-249	330d	1.000E+00	Cf-249	1.450E-05	Am-245	
3 Cf-249	351y	1.000E+00	Cm-245	5.020E-09	SF	
4 Am-245	2.05h	1.000E+00	Cm-245			
5 Cm-245	8.5E+3y	1.000E+00	Pu-241	6.100E-09	SF	
6 Pu-241	14.35y	1.000E+00	Am-241	2.450E-05	U-237	
7 Am-241	432.2y	1.000E+00	Np-237			
8 U-237	6.75d	1.000E+00	Np-237			

9	Np-237	2.144E+6y	1.000E+00	Pa-233		
10	Pa-233	26.967d	1.000E+00	U-233		
11	U-233	1.592E+5y	1.000E+00	Th-229		
12	Th-229	7.34E+3y	1.000E+00	Ra-225		
13	Ra-225	14.9d	1.000E+00	Ac-225		
14	Ac-225	10.0d	1.000E+00	Fr-221		
15	Fr-221	4.9m	1.000E+00	At-217		
16	At-217	3.23E-2s	9.999E-01	Bi-213		
17	Bi-213	45.59m	9.791E-01	Po-213	2.090E-02	Tl-209
18	Po-213	4.2E-6s	1.000E+00	Pb-209		
19	Tl-209	2.161m	1.000E+00	Pb-209		
20	Pb-209	3.253h	1.000E+00	Bi-209\$		

Cm-250

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4		Nuclide				
1 Cm-250	8300y	1.800E-01	Pu-246	8.000E-02	Bk-250	
7.400E-01 SF						
2 Pu-246	10.84d	1.000E+00	Am-246m			
3 Bk-250	3.212h	1.000E+00	Cf-250			
4 Am-246m	25.0m	1.000E+00	Cm-246			
5 Cf-250	13.08y	9.992E-01	Cm-246	7.700E-04	SF	
6 Cm-246	4.76E+3y	9.997E-01	Pu-242	2.630E-04	SF	
7 Pu-242	3.75E+5y	1.000E+00	U-238	5.540E-06	SF	
8 U-238	4.468E+9y	1.000E+00	Th-234	5.450E-07	SF	
9 Th-234	24.10d	1.000E+00	Pa-234m			
10 Pa-234m	1.17m	1.600E-03	Pa-234	9.984E-01	U-234	
11 Pa-234	6.70h	1.000E+00	U-234			
12 U-234	2.455E+5y	1.000E+00	Th-230			
13 Th-230	7.538E+4y	1.000E+00	Ra-226			
14 Ra-226	1600y	1.000E+00	Rn-222			
15 Rn-222	3.8235d	1.000E+00	Po-218			
16 Po-218	3.10m	9.998E-01	Pb-214	2.000E-04	At-218	
17 Pb-214	26.8m	1.000E+00	Bi-214			
18 At-218	1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218	
19 Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210	
20 Rn-218	3.5E-2s	1.000E+00	Po-214			
21 Po-214	1.643E-4s	1.000E+00	Pb-210			
22 Tl-210	1.30m	1.000E+00	Pb-210			
23 Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206	
24 Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206	
25 Hg-206	8.15m	1.000E+00	Tl-206			
26 Po-210	138.376d	1.000E+00	Pb-206\$			
27 Tl-206	4.200m	1.000E+00	Pb-206\$			

Cm-251

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4		Nuclide				

1	Cm-251	16.8m	1.000E+00	Bk-251		
2	Bk-251	55.6m	1.000E+00	Cf-251		
3	Cf-251	900y	1.000E+00	Cm-247		
4	Cm-247	1.56E+7y	1.000E+00	Pu-243		
5	Pu-243	4.956h	1.000E+00	Am-243		
6	Am-243	7.37E+3y	1.000E+00	Np-239		
7	Np-239	2.3565d	1.000E+00	Pu-239		
8	Pu-239	2.411E+4y	9.994E-01	U-235m	6.000E-04	U-235
9	U-235m	26m	1.000E+00	U-235		
10	U-235	7.04E+8y	1.000E+00	Th-231		
11	Th-231	25.52h	1.000E+00	Pa-231		
12	Pa-231	3.276E+4y	1.000E+00	Ac-227		
13	Ac-227	21.772y	9.862E-01	Th-227	1.380E-02	Fr-223
14	Th-227	18.68d	1.000E+00	Ra-223		
15	Fr-223	22.00m	1.000E+00	Ra-223	6.000E-05	At-219
16	Ra-223	11.43d	1.000E+00	Rn-219		
17	Rn-219	3.96s	1.000E+00	Po-215		
18	At-219	56s	9.700E-01	Bi-215		
19	Bi-215	7.6m	1.000E+00	Po-215		
20	Po-215	1.781E-3s	1.000E+00	Pb-211		
21	Pb-211	36.1m	1.000E+00	Bi-211		
22	Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211
23	Tl-207	4.77m	1.000E+00	Pb-207\$		
24	Po-211	0.516s	1.000E+00	Pb-207\$		

Bk-245

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1	Bk-245	4.94d	9.988E-01	Cm-245	1.200E-03	Am-241
2	Cm-245	8.5E+3y	1.000E+00	Pu-241	6.100E-09	SF
3	Pu-241	14.35y	1.000E+00	Am-241	2.450E-05	U-237
4	Am-241	432.2y	1.000E+00	Np-237		
5	U-237	6.75d	1.000E+00	Np-237		
6	Np-237	2.144E+6y	1.000E+00	Pa-233		
7	Pa-233	26.967d	1.000E+00	U-233		
8	U-233	1.592E+5y	1.000E+00	Th-229		
9	Th-229	7.34E+3y	1.000E+00	Ra-225		
10	Ra-225	14.9d	1.000E+00	Ac-225		
11	Ac-225	10.0d	1.000E+00	Fr-221		
12	Fr-221	4.9m	1.000E+00	At-217		
13	At-217	3.23E-2s	9.999E-01	Bi-213		
14	Bi-213	45.59m	9.791E-01	Po-213	2.090E-02	Tl-209
15	Po-213	4.2E-6s	1.000E+00	Pb-209		
16	Tl-209	2.161m	1.000E+00	Pb-209		
17	Pb-209	3.253h	1.000E+00	Bi-209\$		

Bk-246

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3

Nuclide	f4	Nuclide			
1 Bk-246	1.80d	1.000E+00	Cm-246		
2 Cm-246	4.76E+3y	9.997E-01	Pu-242	2.630E-04	SF
3 Pu-242	3.75E+5y	1.000E+00	U-238	5.540E-06	SF
4 U-238	4.468E+9y	1.000E+00	Th-234	5.450E-07	SF
5 Th-234	24.10d	1.000E+00	Pa-234m		
6 Pa-234m	1.17m	1.600E-03	Pa-234	9.984E-01	U-234
7 Pa-234	6.70h	1.000E+00	U-234		
8 U-234	2.455E+5y	1.000E+00	Th-230		
9 Th-230	7.538E+4y	1.000E+00	Ra-226		
10 Ra-226	1600y	1.000E+00	Rn-222		
11 Rn-222	3.8235d	1.000E+00	Po-218		
12 Po-218	3.10m	9.998E-01	Pb-214	2.000E-04	At-218
13 Pb-214	26.8m	1.000E+00	Bi-214		
14 At-218	1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218
15 Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210
16 Rn-218	3.5E-2s	1.000E+00	Po-214		
17 Po-214	1.643E-4s	1.000E+00	Pb-210		
18 Tl-210	1.30m	1.000E+00	Pb-210		
19 Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206
20 Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206
21 Hg-206	8.15m	1.000E+00	Tl-206		
22 Po-210	138.376d	1.000E+00	Pb-206\$		
23 Tl-206	4.200m	1.000E+00	Pb-206\$		

Bk-247

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Bk-247	1.38E+3y	1.000E+00	Am-243			
2 Am-243	7.37E+3y	1.000E+00	Np-239			
3 Np-239	2.3565d	1.000E+00	Pu-239			
4 Pu-239	2.411E+4y	9.994E-01	U-235m	6.000E-04	U-235	
5 U-235m	26m	1.000E+00	U-235			
6 U-235	7.04E+8y	1.000E+00	Th-231			
7 Th-231	25.52h	1.000E+00	Pa-231			
8 Pa-231	3.276E+4y	1.000E+00	Ac-227			
9 Ac-227	21.772y	9.862E-01	Th-227	1.380E-02	Fr-223	
10 Th-227	18.68d	1.000E+00	Ra-223			
11 Fr-223	22.00m	1.000E+00	Ra-223	6.000E-05	At-219	
12 Ra-223	11.43d	1.000E+00	Rn-219			
13 Rn-219	3.96s	1.000E+00	Po-215			
14 At-219	56s	9.700E-01	Bi-215			
15 Bi-215	7.6m	1.000E+00	Po-215			
16 Po-215	1.781E-3s	1.000E+00	Pb-211			
17 Pb-211	36.1m	1.000E+00	Bi-211			
18 Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211	
19 Tl-207	4.77m	1.000E+00	Pb-207\$			
20 Po-211	0.516s	1.000E+00	Pb-207\$			

Bk-248m

Products -----				Daughter -----			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3	
Nuclide f4	Nuclide						
1 Bk-248m	23.7h	7.000E-01	Cf-248	3.000E-01	Cm-248		
2 Cf-248	334d	1.000E+00	Cm-244	2.900E-05	SF		
3 Cm-248	3.48E+5y	9.161E-01	Pu-244	8.390E-02	SF		
4 Cm-244	18.10y	1.000E+00	Pu-240	1.371E-06	SF		
5 Pu-244	8.00E+7y	9.988E-01	U-240	1.210E-03	SF		
6 U-240	14.1h	1.000E+00	Np-240m				
7 Np-240m	7.22m	1.100E-03	Np-240	9.989E-01	Pu-240		
8 Np-240	61.9m	1.000E+00	Pu-240				
9 Pu-240	6564y	1.000E+00	U-236	5.750E-08	SF		
10 U-236	2.342E+7y	1.000E+00	Th-232				
11 Th-232	1.405E10y	1.000E+00	Ra-228				
12 Ra-228	5.75y	1.000E+00	Ac-228				
13 Ac-228	6.15h	1.000E+00	Th-228				
14 Th-228	1.9116y	1.000E+00	Ra-224				
15 Ra-224	3.66d	1.000E+00	Rn-220				
16 Rn-220	55.6s	1.000E+00	Po-216				
17 Po-216	0.145s	1.000E+00	Pb-212				
18 Pb-212	10.64h	1.000E+00	Bi-212				
19 Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208		
20 Po-212	2.99E-7s	1.000E+00	Pb-208\$				
21 Tl-208	3.053m	1.000E+00	Pb-208\$				

Bk-249

Products -----				Daughter -----			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3	
Nuclide f4	Nuclide						
1 Bk-249	330d	1.000E+00	Cf-249	1.450E-05	Am-245		
2 Cf-249	351y	1.000E+00	Cm-245	5.020E-09	SF		
3 Am-245	2.05h	1.000E+00	Cm-245				
4 Cm-245	8.5E+3y	1.000E+00	Pu-241	6.100E-09	SF		
5 Pu-241	14.35y	1.000E+00	Am-241	2.450E-05	U-237		
6 Am-241	432.2y	1.000E+00	Np-237				
7 U-237	6.75d	1.000E+00	Np-237				
8 Np-237	2.144E+6y	1.000E+00	Pa-233				
9 Pa-233	26.967d	1.000E+00	U-233				
10 U-233	1.592E+5y	1.000E+00	Th-229				
11 Th-229	7.34E+3y	1.000E+00	Ra-225				
12 Ra-225	14.9d	1.000E+00	Ac-225				
13 Ac-225	10.0d	1.000E+00	Fr-221				
14 Fr-221	4.9m	1.000E+00	At-217				
15 At-217	3.23E-2s	9.999E-01	Bi-213				
16 Bi-213	45.59m	9.791E-01	Po-213	2.090E-02	Tl-209		
17 Po-213	4.2E-6s	1.000E+00	Pb-209				
18 Tl-209	2.161m	1.000E+00	Pb-209				
19 Pb-209	3.253h	1.000E+00	Bi-209\$				

Bk-250

Products -----				Daughter -----			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3	
Nuclide f4	Nuclide						
1 Bk-250	3.212h	1.000E+00	Cf-250				
2 Cf-250	13.08y	9.992E-01	Cm-246	7.700E-04	SF		
3 Cm-246	4.76E+3y	9.997E-01	Pu-242	2.630E-04	SF		
4 Pu-242	3.75E+5y	1.000E+00	U-238	5.540E-06	SF		
5 U-238	4.468E+9y	1.000E+00	Th-234	5.450E-07	SF		
6 Th-234	24.10d	1.000E+00	Pa-234m				
7 Pa-234m	1.17m	1.600E-03	Pa-234	9.984E-01	U-234		
8 Pa-234	6.70h	1.000E+00	U-234				
9 U-234	2.455E+5y	1.000E+00	Th-230				
10 Th-230	7.538E+4y	1.000E+00	Ra-226				
11 Ra-226	1600y	1.000E+00	Rn-222				
12 Rn-222	3.8235d	1.000E+00	Po-218				
13 Po-218	3.10m	9.998E-01	Pb-214	2.000E-04	At-218		
14 Pb-214	26.8m	1.000E+00	Bi-214				
15 At-218	1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218		
16 Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210		
17 Rn-218	3.5E-2s	1.000E+00	Po-214				
18 Po-214	1.643E-4s	1.000E+00	Pb-210				
19 Tl-210	1.30m	1.000E+00	Pb-210				
20 Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206		
21 Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206		
22 Hg-206	8.15m	1.000E+00	Tl-206				
23 Po-210	138.376d	1.000E+00	Pb-206\$				
24 Tl-206	4.200m	1.000E+00	Pb-206\$				

Bk-251

Products -----				Daughter -----			
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3	
Nuclide f4	Nuclide						
1 Bk-251	55.6m	1.000E+00	Cf-251				
2 Cf-251	900y	1.000E+00	Cm-247				
3 Cm-247	1.56E+7y	1.000E+00	Pu-243				
4 Pu-243	4.956h	1.000E+00	Am-243				
5 Am-243	7.37E+3y	1.000E+00	Np-239				
6 Np-239	2.3565d	1.000E+00	Pu-239				
7 Pu-239	2.411E+4y	9.994E-01	U-235m	6.000E-04	U-235		
8 U-235m	26m	1.000E+00	U-235				
9 U-235	7.04E+8y	1.000E+00	Th-231				
10 Th-231	25.52h	1.000E+00	Pa-231				
11 Pa-231	3.276E+4y	1.000E+00	Ac-227				
12 Ac-227	21.772y	9.862E-01	Th-227	1.380E-02	Fr-223		
13 Th-227	18.68d	1.000E+00	Ra-223				
14 Fr-223	22.00m	1.000E+00	Ra-223	6.000E-05	At-219		
15 Ra-223	11.43d	1.000E+00	Rn-219				
16 Rn-219	3.96s	1.000E+00	Po-215				
17 At-219	56s	9.700E-01	Bi-215				
18 Bi-215	7.6m	1.000E+00	Po-215				

19	Po-215	1.781E-3s	1.000E+00	Pb-211		
20	Pb-211	36.1m	1.000E+00	Bi-211		
21	Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211
22	Tl-207	4.77m	1.000E+00	Pb-207\$		
23	Po-211	0.516s	1.000E+00	Pb-207\$		

Cf-244

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Cf-244	19.4m	1.000E+00	Cm-240			
2 Cm-240	27d	9.970E-01	Pu-236	3.900E-08	SF	
3 Pu-236	2.858y	1.000E+00	U-232	1.370E-09	SF	
4 U-232	68.9y	1.000E+00	Th-228			
5 Th-228	1.9116y	1.000E+00	Ra-224			
6 Ra-224	3.66d	1.000E+00	Rn-220			
7 Rn-220	55.6s	1.000E+00	Po-216			
8 Po-216	0.145s	1.000E+00	Pb-212			
9 Pb-212	10.64h	1.000E+00	Bi-212			
10 Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208	
11 Po-212	2.99E-7s	1.000E+00	Pb-208\$			
12 Tl-208	3.053m	1.000E+00	Pb-208\$			

Cf-246

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Cf-246	35.7h	1.000E+00	Cm-242	2.500E-06	SF	
2 Cm-242	162.8d	1.000E+00	Pu-238	6.370E-08	SF	
3 Pu-238	87.7y	1.000E+00	U-234	1.850E-09	SF	
4 U-234	2.455E+5y	1.000E+00	Th-230			
5 Th-230	7.538E+4y	1.000E+00	Ra-226			
6 Ra-226	1600y	1.000E+00	Rn-222			
7 Rn-222	3.8235d	1.000E+00	Po-218			
8 Po-218	3.10m	9.998E-01	Pb-214	2.000E-04	At-218	
9 Pb-214	26.8m	1.000E+00	Bi-214			
10 At-218	1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218	
11 Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210	
12 Rn-218	3.5E-2s	1.000E+00	Po-214			
13 Po-214	1.643E-4s	1.000E+00	Pb-210			
14 Tl-210	1.30m	1.000E+00	Pb-210			
15 Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206	
16 Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206	
17 Hg-206	8.15m	1.000E+00	Tl-206			
18 Po-210	138.376d	1.000E+00	Pb-206\$			
19 Tl-206	4.200m	1.000E+00	Pb-206\$			

Cf-247

Products				Daughter		
----------	--	--	--	----------	--	--

Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Cf-247	3.11h	9.997E-01	Bk-247	3.500E-04	Cm-243	
2 Bk-247	1.38E+3y	1.000E+00	Am-243			
3 Cm-243	29.1y	2.400E-03	Am-243	9.976E-01	Pu-239	
4 Am-243	7.37E+3y	1.000E+00	Np-239			
5 Np-239	2.3565d	1.000E+00	Pu-239			
6 Pu-239	2.411E+4y	9.994E-01	U-235m	6.000E-04	U-235	
7 U-235m	26m	1.000E+00	U-235			
8 U-235	7.04E+8y	1.000E+00	Th-231			
9 Th-231	25.52h	1.000E+00	Pa-231			
10 Pa-231	3.276E+4y	1.000E+00	Ac-227			
11 Ac-227	21.772y	9.862E-01	Th-227	1.380E-02	Fr-223	
12 Th-227	18.68d	1.000E+00	Ra-223			
13 Fr-223	22.00m	1.000E+00	Ra-223	6.000E-05	At-219	
14 Ra-223	11.43d	1.000E+00	Rn-219			
15 Rn-219	3.96s	1.000E+00	Po-215			
16 At-219	56s	9.700E-01	Bi-215			
17 Bi-215	7.6m	1.000E+00	Po-215			
18 Po-215	1.781E-3s	1.000E+00	Pb-211			
19 Pb-211	36.1m	1.000E+00	Bi-211			
20 Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211	
21 Tl-207	4.77m	1.000E+00	Pb-207\$			
22 Po-211	0.516s	1.000E+00	Pb-207\$			

Cf-248

Products			Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Cf-248	334d	1.000E+00	Cm-244	2.900E-05	SF
2 Cm-244	18.10y	1.000E+00	Pu-240	1.371E-06	SF
3 Pu-240	6564y	1.000E+00	U-236	5.750E-08	SF
4 U-236	2.342E+7y	1.000E+00	Th-232		
5 Th-232	1.405E10y	1.000E+00	Ra-228		
6 Ra-228	5.75y	1.000E+00	Ac-228		
7 Ac-228	6.15h	1.000E+00	Th-228		
8 Th-228	1.9116y	1.000E+00	Ra-224		
9 Ra-224	3.66d	1.000E+00	Rn-220		
10 Rn-220	55.6s	1.000E+00	Po-216		
11 Po-216	0.145s	1.000E+00	Pb-212		
12 Pb-212	10.64h	1.000E+00	Bi-212		
13 Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208
14 Po-212	2.99E-7s	1.000E+00	Pb-208\$		
15 Tl-208	3.053m	1.000E+00	Pb-208\$		

Cf-249

Products			Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
Nuclide f4	Nuclide				
1 Cf-249	351y	1.000E+00	Cm-245	5.020E-09	SF

2	Cm-245	8.5E+3y	1.000E+00	Pu-241	6.100E-09	SF
3	Pu-241	14.35y	1.000E+00	Am-241	2.450E-05	U-237
4	Am-241	432.2y	1.000E+00	Np-237		
5	U-237	6.75d	1.000E+00	Np-237		
6	Np-237	2.144E+6y	1.000E+00	Pa-233		
7	Pa-233	26.967d	1.000E+00	U-233		
8	U-233	1.592E+5y	1.000E+00	Th-229		
9	Th-229	7.34E+3y	1.000E+00	Ra-225		
10	Ra-225	14.9d	1.000E+00	Ac-225		
11	Ac-225	10.0d	1.000E+00	Fr-221		
12	Fr-221	4.9m	1.000E+00	At-217		
13	At-217	3.23E-2s	9.999E-01	Bi-213		
14	Bi-213	45.59m	9.791E-01	Po-213	2.090E-02	Tl-209
15	Po-213	4.2E-6s	1.000E+00	Pb-209		
16	Tl-209	2.161m	1.000E+00	Pb-209		
17	Pb-209	3.253h	1.000E+00	Bi-209\$		

Cf-250

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1	Cf-250	13.08y	9.992E-01	Cm-246	7.700E-04	SF
2	Cm-246	4.76E+3y	9.997E-01	Pu-242	2.630E-04	SF
3	Pu-242	3.75E+5y	1.000E+00	U-238	5.540E-06	SF
4	U-238	4.468E+9y	1.000E+00	Th-234	5.450E-07	SF
5	Th-234	24.10d	1.000E+00	Pa-234m		
6	Pa-234m	1.17m	1.600E-03	Pa-234	9.984E-01	U-234
7	Pa-234	6.70h	1.000E+00	U-234		
8	U-234	2.455E+5y	1.000E+00	Th-230		
9	Th-230	7.538E+4y	1.000E+00	Ra-226		
10	Ra-226	1600y	1.000E+00	Rn-222		
11	Rn-222	3.8235d	1.000E+00	Po-218		
12	Po-218	3.10m	9.998E-01	Pb-214	2.000E-04	At-218
13	Pb-214	26.8m	1.000E+00	Bi-214		
14	At-218	1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218
15	Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210
16	Rn-218	3.5E-2s	1.000E+00	Po-214		
17	Po-214	1.643E-4s	1.000E+00	Pb-210		
18	Tl-210	1.30m	1.000E+00	Pb-210		
19	Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206
20	Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206
21	Hg-206	8.15m	1.000E+00	Tl-206		
22	Po-210	138.376d	1.000E+00	Pb-206\$		
23	Tl-206	4.200m	1.000E+00	Pb-206\$		

Cf-251

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1	Cf-251	900y	1.000E+00	Cm-247		

2	Cm-247	1.56E+7y	1.000E+00	Pu-243		
3	Pu-243	4.956h	1.000E+00	Am-243		
4	Am-243	7.37E+3y	1.000E+00	Np-239		
5	Np-239	2.3565d	1.000E+00	Pu-239		
6	Pu-239	2.411E+4y	9.994E-01	U-235m	6.000E-04	U-235
7	U-235m	26m	1.000E+00	U-235		
8	U-235	7.04E+8y	1.000E+00	Th-231		
9	Th-231	25.52h	1.000E+00	Pa-231		
10	Pa-231	3.276E+4y	1.000E+00	Ac-227		
11	Ac-227	21.772y	9.862E-01	Th-227	1.380E-02	Fr-223
12	Th-227	18.68d	1.000E+00	Ra-223		
13	Fr-223	22.00m	1.000E+00	Ra-223	6.000E-05	At-219
14	Ra-223	11.43d	1.000E+00	Rn-219		
15	Rn-219	3.96s	1.000E+00	Po-215		
16	At-219	56s	9.700E-01	Bi-215		
17	Bi-215	7.6m	1.000E+00	Po-215		
18	Po-215	1.781E-3s	1.000E+00	Pb-211		
19	Pb-211	36.1m	1.000E+00	Bi-211		
20	Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211
21	Tl-207	4.77m	1.000E+00	Pb-207\$		
22	Po-211	0.516s	1.000E+00	Pb-207\$		

Cf-252

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Cf-252	2.645y	9.691E-01	Cm-248	3.092E-02	SF	
2 Cm-248	3.48E+5y	9.161E-01	Pu-244	8.390E-02	SF	
3 Pu-244	8.00E+7y	9.988E-01	U-240	1.210E-03	SF	
4 U-240	14.1h	1.000E+00	Np-240m			
5 Np-240m	7.22m	1.100E-03	Np-240	9.989E-01	Pu-240	
6 Np-240	61.9m	1.000E+00	Pu-240			
7 Pu-240	6564y	1.000E+00	U-236	5.750E-08	SF	
8 U-236	2.342E+7y	1.000E+00	Th-232			
9 Th-232	1.405E10y	1.000E+00	Ra-228			
10 Ra-228	5.75y	1.000E+00	Ac-228			
11 Ac-228	6.15h	1.000E+00	Th-228			
12 Th-228	1.9116y	1.000E+00	Ra-224			
13 Ra-224	3.66d	1.000E+00	Rn-220			
14 Rn-220	55.6s	1.000E+00	Po-216			
15 Po-216	0.145s	1.000E+00	Pb-212			
16 Pb-212	10.64h	1.000E+00	Bi-212			
17 Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208	
18 Po-212	2.99E-7s	1.000E+00	Pb-208\$			
19 Tl-208	3.053m	1.000E+00	Pb-208\$			

Cf-253

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					

1	Cf-253	17.81d	9.969E-01	Es-253	3.100E-03	Cm-249
2	Es-253	20.47d	1.000E+00	Bk-249	8.900E-08	SF
3	Cm-249	64.15m	1.000E+00	Bk-249		
4	Bk-249	330d	1.000E+00	Cf-249	1.450E-05	Am-245
5	Cf-249	351y	1.000E+00	Cm-245	5.020E-09	SF
6	Am-245	2.05h	1.000E+00	Cm-245		
7	Cm-245	8.5E+3y	1.000E+00	Pu-241	6.100E-09	SF
8	Pu-241	14.35y	1.000E+00	Am-241	2.450E-05	U-237
9	Am-241	432.2y	1.000E+00	Np-237		
10	U-237	6.75d	1.000E+00	Np-237		
11	Np-237	2.144E+6y	1.000E+00	Pa-233		
12	Pa-233	26.967d	1.000E+00	U-233		
13	U-233	1.592E+5y	1.000E+00	Th-229		
14	Th-229	7.34E+3y	1.000E+00	Ra-225		
15	Ra-225	14.9d	1.000E+00	Ac-225		
16	Ac-225	10.0d	1.000E+00	Fr-221		
17	Fr-221	4.9m	1.000E+00	At-217		
18	At-217	3.23E-2s	9.999E-01	Bi-213		
19	Bi-213	45.59m	9.791E-01	Po-213	2.090E-02	Tl-209
20	Po-213	4.2E-6s	1.000E+00	Pb-209		
21	Tl-209	2.161m	1.000E+00	Pb-209		
22	Pb-209	3.253h	1.000E+00	Bi-209		

Cf-254

Products				----- Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Cf-254	60.5d	3.100E-03	Cm-250	9.969E-01	SF	
2 Cm-250	8300y	1.800E-01	Pu-246	8.000E-02	Bk-250	
7.400E-01 SF						
3 Pu-246	10.84d	1.000E+00	Am-246m			
4 Bk-250	3.212h	1.000E+00	Cf-250			
5 Am-246m	25.0m	1.000E+00	Cm-246			
6 Cf-250	13.08y	9.992E-01	Cm-246	7.700E-04	SF	
7 Cm-246	4.76E+3y	9.997E-01	Pu-242	2.630E-04	SF	
8 Pu-242	3.75E+5y	1.000E+00	U-238	5.540E-06	SF	
9 U-238	4.468E+9y	1.000E+00	Th-234	5.450E-07	SF	
10 Th-234	24.10d	1.000E+00	Pa-234m			
11 Pa-234m	1.17m	1.600E-03	Pa-234	9.984E-01	U-234	
12 Pa-234	6.70h	1.000E+00	U-234			
13 U-234	2.455E+5y	1.000E+00	Th-230			
14 Th-230	7.538E+4y	1.000E+00	Ra-226			
15 Ra-226	1600y	1.000E+00	Rn-222			
16 Rn-222	3.8235d	1.000E+00	Po-218			
17 Po-218	3.10m	9.998E-01	Pb-214	2.000E-04	At-218	
18 Pb-214	26.8m	1.000E+00	Bi-214			
19 At-218	1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218	
20 Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210	
21 Rn-218	3.5E-2s	1.000E+00	Po-214			
22 Po-214	1.643E-4s	1.000E+00	Pb-210			
23 Tl-210	1.30m	1.000E+00	Pb-210			

24 Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206
25 Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206
26 Hg-206	8.15m	1.000E+00	Tl-206		
27 Po-210	138.376d	1.000E+00	Pb-206\$		
28 Tl-206	4.200m	1.000E+00	Pb-206\$		

Cf-255

Products				----- Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Cf-255	85m	1.000E+00	Es-255			
2 Es-255	39.8d	9.200E-01	Fm-255	8.000E-02	Bk-251	
4.500E-05 SF						
3 Fm-255	20.07h	1.000E+00	Cf-251	2.300E-07	SF	
4 Bk-251	55.6m	1.000E+00	Cf-251			
5 Cf-251	900y	1.000E+00	Cm-247			
6 Cm-247	1.56E+7y	1.000E+00	Pu-243			
7 Pu-243	4.956h	1.000E+00	Am-243			
8 Am-243	7.37E+3y	1.000E+00	Np-239			
9 Np-239	2.3565d	1.000E+00	Pu-239			
10 Pu-239	2.411E+4y	9.994E-01	U-235m	6.000E-04	U-235	
11 U-235m	26m	1.000E+00	U-235			
12 U-235	7.04E+8y	1.000E+00	Th-231			
13 Th-231	25.52h	1.000E+00	Pa-231			
14 Pa-231	3.276E+4y	1.000E+00	Ac-227			
15 Ac-227	21.772y	9.862E-01	Th-227	1.380E-02	Fr-223	
16 Th-227	18.68d	1.000E+00	Ra-223			
17 Fr-223	22.00m	1.000E+00	Ra-223	6.000E-05	At-219	
18 Ra-223	11.43d	1.000E+00	Rn-219			
19 Rn-219	3.96s	1.000E+00	Po-215			
20 At-219	56s	9.700E-01	Bi-215			
21 Bi-215	7.6m	1.000E+00	Po-215			
22 Po-215	1.781E-3s	1.000E+00	Pb-211			
23 Pb-211	36.1m	1.000E+00	Bi-211			
24 Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211	
25 Tl-207	4.77m	1.000E+00	Pb-207\$			
26 Po-211	0.516s	1.000E+00	Pb-207\$			

Es-249

Products				----- Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Es-249	102.2m	9.943E-01	Cf-249	5.700E-03	Bk-245	
2 Cf-249	351y	1.000E+00	Cm-245	5.020E-09	SF	
3 Bk-245	4.94d	9.988E-01	Cm-245	1.200E-03	Am-241	
4 Cm-245	8.5E+3y	1.000E+00	Pu-241	6.100E-09	SF	
5 Pu-241	14.35y	1.000E+00	Am-241	2.450E-05	U-237	
6 Am-241	432.2y	1.000E+00	Np-237			
7 U-237	6.75d	1.000E+00	Np-237			
8 Np-237	2.144E+6y	1.000E+00	Pa-233			

9	Pa-233	26.967d	1.000E+00	U-233		
10	U-233	1.592E+5y	1.000E+00	Th-229		
11	Th-229	7.34E+3y	1.000E+00	Ra-225		
12	Ra-225	14.9d	1.000E+00	Ac-225		
13	Ac-225	10.0d	1.000E+00	Fr-221		
14	Fr-221	4.9m	1.000E+00	At-217		
15	At-217	3.23E-2s	9.999E-01	Bi-213		
16	Bi-213	45.59m	9.791E-01	Po-213	2.090E-02	Tl-209
17	Po-213	4.2E-6s	1.000E+00	Pb-209		
18	Tl-209	2.161m	1.000E+00	Pb-209		
19	Pb-209	3.253h	1.000E+00	Bi-209\$		

Es-250

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Es-250	8.6h	9.850E-01	Cf-250			
2 Cf-250	13.08y	9.992E-01	Cm-246	7.700E-04	SF	
3 Cm-246	4.76E+3y	9.997E-01	Pu-242	2.630E-04	SF	
4 Pu-242	3.75E+5y	1.000E+00	U-238	5.540E-06	SF	
5 U-238	4.468E+9y	1.000E+00	Th-234	5.450E-07	SF	
6 Th-234	24.10d	1.000E+00	Pa-234m			
7 Pa-234m	1.17m	1.600E-03	Pa-234	9.984E-01	U-234	
8 Pa-234	6.70h	1.000E+00	U-234			
9 U-234	2.455E+5y	1.000E+00	Th-230			
10 Th-230	7.538E+4y	1.000E+00	Ra-226			
11 Ra-226	1600y	1.000E+00	Rn-222			
12 Rn-222	3.8235d	1.000E+00	Po-218			
13 Po-218	3.10m	9.998E-01	Pb-214	2.000E-04	At-218	
14 Pb-214	26.8m	1.000E+00	Bi-214			
15 At-218	1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218	
16 Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210	
17 Rn-218	3.5E-2s	1.000E+00	Po-214			
18 Po-214	1.643E-4s	1.000E+00	Pb-210			
19 Tl-210	1.30m	1.000E+00	Pb-210			
20 Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206	
21 Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206	
22 Hg-206	8.15m	1.000E+00	Tl-206			
23 Po-210	138.376d	1.000E+00	Pb-206\$			
24 Tl-206	4.200m	1.000E+00	Pb-206\$			

Es-250m

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Es-250m	2.22h	1.000E+00	Cf-250			
2 Cf-250	13.08y	9.992E-01	Cm-246	7.700E-04	SF	
3 Cm-246	4.76E+3y	9.997E-01	Pu-242	2.630E-04	SF	
4 Pu-242	3.75E+5y	1.000E+00	U-238	5.540E-06	SF	
5 U-238	4.468E+9y	1.000E+00	Th-234	5.450E-07	SF	

6	Th-234	24.10d	1.000E+00	Pa-234m		
7	Pa-234m	1.17m	1.600E-03	Pa-234	9.984E-01	U-234
8	Pa-234	6.70h	1.000E+00	U-234		
9	U-234	2.455E+5y	1.000E+00	Th-230		
10	Th-230	7.538E+4y	1.000E+00	Ra-226		
11	Ra-226	1600y	1.000E+00	Rn-222		
12	Rn-222	3.8235d	1.000E+00	Po-218		
13	Po-218	3.10m	9.998E-01	Pb-214	2.000E-04	At-218
14	Pb-214	26.8m	1.000E+00	Bi-214		
15	At-218	1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218
16	Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210
17	Rn-218	3.5E-2s	1.000E+00	Po-214		
18	Po-214	1.643E-4s	1.000E+00	Pb-210		
19	Tl-210	1.30m	1.000E+00	Pb-210		
20	Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206
21	Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206
22	Hg-206	8.15m	1.000E+00	Tl-206		
23	Po-210	138.376d	1.000E+00	Pb-206\$		
24	Tl-206	4.200m	1.000E+00	Pb-206\$		

Es-251

Products				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
1 Es-251	33h	9.950E-01	Cf-251	5.000E-03	Bk-247	
2 Cf-251	900y	1.000E+00	Cm-247			
3 Bk-247	1.38E+3y	1.000E+00	Am-243			
4 Cm-247	1.56E+7y	1.000E+00	Pu-243			
5 Pu-243	4.956h	1.000E+00	Am-243			
6 Am-243	7.37E+3y	1.000E+00	Np-239			
7 Np-239	2.3565d	1.000E+00	Pu-239			
8 Pu-239	2.411E+4y	9.994E-01	U-235m	6.000E-04	U-235	
9 U-235m	26m	1.000E+00	U-235			
10 U-235	7.04E+8y	1.000E+00	Th-231			
11 Th-231	25.52h	1.000E+00	Pa-231			
12 Pa-231	3.276E+4y	1.000E+00	Ac-227			
13 Ac-227	21.772y	9.862E-01	Th-227	1.380E-02	Fr-223	
14 Th-227	18.68d	1.000E+00	Ra-223			
15 Fr-223	22.00m	1.000E+00	Ra-223	6.000E-05	At-219	
16 Ra-223	11.43d	1.000E+00	Rn-219			
17 Rn-219	3.96s	1.000E+00	Po-215			
18 At-219	56s	9.700E-01	Bi-215			
19 Bi-215	7.6m	1.000E+00	Po-215			
20 Po-215	1.781E-3s	1.000E+00	Pb-211			
21 Pb-211	36.1m	1.000E+00	Bi-211			
22 Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211	
23 Tl-207	4.77m	1.000E+00	Pb-207\$			
24 Po-211	0.516s	1.000E+00	Pb-207\$			

Es-253

----- Daughter

Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Es-253	20.47d	1.000E+00	Bk-249	8.900E-08	SF	
2 Bk-249	330d	1.000E+00	Cf-249	1.450E-05	Am-245	
3 Cf-249	351y	1.000E+00	Cm-245	5.020E-09	SF	
4 Am-245	2.05h	1.000E+00	Cm-245			
5 Cm-245	8.5E+3y	1.000E+00	Pu-241	6.100E-09	SF	
6 Pu-241	14.35y	1.000E+00	Am-241	2.450E-05	U-237	
7 Am-241	432.2y	1.000E+00	Np-237			
8 U-237	6.75d	1.000E+00	Np-237			
9 Np-237	2.144E+6y	1.000E+00	Pa-233			
10 Pa-233	26.967d	1.000E+00	U-233			
11 U-233	1.592E+5y	1.000E+00	Th-229			
12 Th-229	7.34E+3y	1.000E+00	Ra-225			
13 Ra-225	14.9d	1.000E+00	Ac-225			
14 Ac-225	10.0d	1.000E+00	Fr-221			
15 Fr-221	4.9m	1.000E+00	At-217			
16 At-217	3.23E-2s	9.999E-01	Bi-213			
17 Bi-213	45.59m	9.791E-01	Po-213	2.090E-02	Tl-209	
18 Po-213	4.2E-6s	1.000E+00	Pb-209			
19 Tl-209	2.161m	1.000E+00	Pb-209			
20 Pb-209	3.253h	1.000E+00	Bi-209			

Es-254

----- Daughter						
Products -----						
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Es-254	275.7d	1.000E+00	Bk-250	1.740E-06	Fm-254	
3.000E-08 SF						
2 Bk-250	3.212h	1.000E+00	Cf-250			
3 Fm-254	3.240h	9.994E-01	Cf-250	5.920E-04	SF	
4 Cf-250	13.08y	9.992E-01	Cm-246	7.700E-04	SF	
5 Cm-246	4.76E+3y	9.997E-01	Pu-242	2.630E-04	SF	
6 Pu-242	3.75E+5y	1.000E+00	U-238	5.540E-06	SF	
7 U-238	4.468E+9y	1.000E+00	Th-234	5.450E-07	SF	
8 Th-234	24.10d	1.000E+00	Pa-234m			
9 Pa-234m	1.17m	1.600E-03	Pa-234	9.984E-01	U-234	
10 Pa-234	6.70h	1.000E+00	U-234			
11 U-234	2.455E+5y	1.000E+00	Th-230			
12 Th-230	7.538E+4y	1.000E+00	Ra-226			
13 Ra-226	1600y	1.000E+00	Rn-222			
14 Rn-222	3.8235d	1.000E+00	Po-218			
15 Po-218	3.10m	9.998E-01	Pb-214	2.000E-04	At-218	
16 Pb-214	26.8m	1.000E+00	Bi-214			
17 At-218	1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218	
18 Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210	
19 Rn-218	3.5E-2s	1.000E+00	Po-214			
20 Po-214	1.643E-4s	1.000E+00	Pb-210			
21 Tl-210	1.30m	1.000E+00	Pb-210			
22 Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206	

23 Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206
24 Hg-206	8.15m	1.000E+00	Tl-206		
25 Po-210	138.376d	1.000E+00	Pb-206\$		
26 Tl-206	4.200m	1.000E+00	Pb-206\$		

Es-254m

Products			Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 Es-254m	39.3h	9.800E-01	Fm-254	7.600E-04	Cf-254
3.200E-03 Bk-250	4.500E-04	SF			
2 Fm-254	3.240h	9.994E-01	Cf-250	5.920E-04	SF
3 Cf-254	60.5d	3.100E-03	Cm-250	9.969E-01	SF
4 Cm-250	8300y	8.000E-02	Bk-250	1.800E-01	Pu-246
7.400E-01 SF					
5 Bk-250	3.212h	1.000E+00	Cf-250		
6 Cf-250	13.08y	9.992E-01	Cm-246	7.700E-04	SF
7 Pu-246	10.84d	1.000E+00	Am-246m		
8 Am-246m	25.0m	1.000E+00	Cm-246		
9 Cm-246	4.76E+3y	9.997E-01	Pu-242	2.630E-04	SF
10 Pu-242	3.75E+5y	1.000E+00	U-238	5.540E-06	SF
11 U-238	4.468E+9y	1.000E+00	Th-234	5.450E-07	SF
12 Th-234	24.10d	1.000E+00	Pa-234m		
13 Pa-234m	1.17m	1.600E-03	Pa-234	9.984E-01	U-234
14 Pa-234	6.70h	1.000E+00	U-234		
15 U-234	2.455E+5y	1.000E+00	Th-230		
16 Th-230	7.538E+4y	1.000E+00	Ra-226		
17 Ra-226	1600y	1.000E+00	Rn-222		
18 Rn-222	3.8235d	1.000E+00	Po-218		
19 Po-218	3.10m	9.998E-01	Pb-214	2.000E-04	At-218
20 Pb-214	26.8m	1.000E+00	Bi-214		
21 At-218	1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218
22 Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210
23 Rn-218	3.5E-2s	1.000E+00	Po-214		
24 Po-214	1.643E-4s	1.000E+00	Pb-210		
25 Tl-210	1.30m	1.000E+00	Pb-210		
26 Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206
27 Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206
28 Hg-206	8.15m	1.000E+00	Tl-206		
29 Po-210	138.376d	1.000E+00	Pb-206\$		
30 Tl-206	4.200m	1.000E+00	Pb-206\$		

Es-255

Products			Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 Es-255	39.8d	9.200E-01	Fm-255	8.000E-02	Bk-251
4.500E-05 SF					
2 Fm-255	20.07h	1.000E+00	Cf-251	2.300E-07	SF
3 Bk-251	55.6m	1.000E+00	Cf-251		

4	Cf-251	900y	1.000E+00	Cm-247		
5	Cm-247	1.56E+7y	1.000E+00	Pu-243		
6	Pu-243	4.956h	1.000E+00	Am-243		
7	Am-243	7.37E+3y	1.000E+00	Np-239		
8	Np-239	2.3565d	1.000E+00	Pu-239		
9	Pu-239	2.411E+4y	9.994E-01	U-235m	6.000E-04	U-235
10	U-235m	26m	1.000E+00	U-235		
11	U-235	7.04E+8y	1.000E+00	Th-231		
12	Th-231	25.52h	1.000E+00	Pa-231		
13	Pa-231	3.276E+4y	1.000E+00	Ac-227		
14	Ac-227	21.772y	9.862E-01	Th-227	1.380E-02	Fr-223
15	Th-227	18.68d	1.000E+00	Ra-223		
16	Fr-223	22.00m	1.000E+00	Ra-223	6.000E-05	At-219
17	Ra-223	11.43d	1.000E+00	Rn-219		
18	Rn-219	3.96s	1.000E+00	Po-215		
19	At-219	56s	9.700E-01	Bi-215		
20	Bi-215	7.6m	1.000E+00	Po-215		
21	Po-215	1.781E-3s	1.000E+00	Pb-211		
22	Pb-211	36.1m	1.000E+00	Bi-211		
23	Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211
24	Tl-207	4.77m	1.000E+00	Pb-207\$		
25	Po-211	0.516s	1.000E+00	Pb-207\$		

Es-256

Products				----- Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1	Es-256	25.4m	1.000E+00	Fm-256		
2	Fm-256	157.6m	8.100E-02	Cf-252	9.190E-01	SF
3	Cf-252	2.645y	9.691E-01	Cm-248	3.092E-02	SF
4	Cm-248	3.48E+5y	9.161E-01	Pu-244	8.390E-02	SF
5	Pu-244	8.00E+7y	9.988E-01	U-240	1.210E-03	SF
6	U-240	14.1h	1.000E+00	Np-240m		
7	Np-240m	7.22m	1.100E-03	Np-240	9.989E-01	Pu-240
8	Np-240	61.9m	1.000E+00	Pu-240		
9	Pu-240	6564y	1.000E+00	U-236	5.750E-08	SF
10	U-236	2.342E+7y	1.000E+00	Th-232		
11	Th-232	1.405E10y	1.000E+00	Ra-228		
12	Ra-228	5.75y	1.000E+00	Ac-228		
13	Ac-228	6.15h	1.000E+00	Th-228		
14	Th-228	1.9116y	1.000E+00	Ra-224		
15	Ra-224	3.66d	1.000E+00	Rn-220		
16	Rn-220	55.6s	1.000E+00	Po-216		
17	Po-216	0.145s	1.000E+00	Pb-212		
18	Pb-212	10.64h	1.000E+00	Bi-212		
19	Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208
20	Po-212	2.99E-7s	1.000E+00	Pb-208\$		
21	Tl-208	3.053m	1.000E+00	Pb-208\$		

Fm-251

----- Daughter

Products -----							
Nuclide	f4	Nuclide	f1	Nuclide	f2	Nuclide	f3
1 Fm-251		5.30h	9.820E-01	Es-251	1.800E-02	Cf-247	
2 Es-251		33h	9.950E-01	Cf-251	5.000E-03	Bk-247	
3 Cf-247		3.11h	9.997E-01	Bk-247	3.500E-04	Cm-243	
4 Cf-251		900y	1.000E+00	Cm-247			
5 Bk-247		1.38E+3y	1.000E+00	Am-243			
6 Cm-247		1.56E+7y	1.000E+00	Pu-243			
7 Pu-243		4.956h	1.000E+00	Am-243			
8 Cm-243		29.1y	2.400E-03	Am-243	9.976E-01	Pu-239	
9 Am-243		7.37E+3y	1.000E+00	Np-239			
10 Np-239		2.3565d	1.000E+00	Pu-239			
11 Pu-239		2.411E+4y	9.994E-01	U-235m	6.000E-04	U-235	
12 U-235m		26m	1.000E+00	U-235			
13 U-235		7.04E+8y	1.000E+00	Th-231			
14 Th-231		25.52h	1.000E+00	Pa-231			
15 Pa-231		3.276E+4y	1.000E+00	Ac-227			
16 Ac-227		21.772y	9.862E-01	Th-227	1.380E-02	Fr-223	
17 Th-227		18.68d	1.000E+00	Ra-223			
18 Fr-223		22.00m	1.000E+00	Ra-223	6.000E-05	At-219	
19 Ra-223		11.43d	1.000E+00	Rn-219			
20 Rn-219		3.96s	1.000E+00	Po-215			
21 At-219		56s	9.700E-01	Bi-215			
22 Bi-215		7.6m	1.000E+00	Po-215			
23 Po-215		1.781E-3s	1.000E+00	Pb-211			
24 Pb-211		36.1m	1.000E+00	Bi-211			
25 Bi-211		2.14m	9.972E-01	Tl-207	2.760E-03	Po-211	
26 Tl-207		4.77m	1.000E+00	Pb-207\$			
27 Po-211		0.516s	1.000E+00	Pb-207\$			

Fm-252

Products ----- Daughter							
Nuclide	f4	Nuclide	f1	Nuclide	f2	Nuclide	f3
1 Fm-252		25.39h	1.000E+00	Cf-248	2.300E-05	SF	
2 Cf-248		334d	1.000E+00	Cm-244	2.900E-05	SF	
3 Cm-244		18.10y	1.000E+00	Pu-240	1.371E-06	SF	
4 Pu-240		6564y	1.000E+00	U-236	5.750E-08	SF	
5 U-236		2.342E+7y	1.000E+00	Th-232			
6 Th-232		1.405E10y	1.000E+00	Ra-228			
7 Ra-228		5.75y	1.000E+00	Ac-228			
8 Ac-228		6.15h	1.000E+00	Th-228			
9 Th-228		1.9116y	1.000E+00	Ra-224			
10 Ra-224		3.66d	1.000E+00	Rn-220			
11 Rn-220		55.6s	1.000E+00	Po-216			
12 Po-216		0.145s	1.000E+00	Pb-212			
13 Pb-212		10.64h	1.000E+00	Bi-212			
14 Bi-212		60.55m	6.406E-01	Po-212	3.594E-01	Tl-208	
15 Po-212		2.99E-7s	1.000E+00	Pb-208\$			
16 Tl-208		3.053m	1.000E+00	Pb-208\$			

Fm-253

Products -----				Daughter -----		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Fm-253	3.00d	8.800E-01	Es-253	1.200E-01	Cf-249	
2 Es-253	20.47d	1.000E+00	Bk-249	8.900E-08	SF	
3 Bk-249	330d	1.000E+00	Cf-249	1.450E-05	Am-245	
4 Cf-249	351y	1.000E+00	Cm-245	5.020E-09	SF	
5 Am-245	2.05h	1.000E+00	Cm-245			
6 Cm-245	8.5E+3y	1.000E+00	Pu-241	6.100E-09	SF	
7 Pu-241	14.35y	1.000E+00	Am-241	2.450E-05	U-237	
8 Am-241	432.2y	1.000E+00	Np-237			
9 U-237	6.75d	1.000E+00	Np-237			
10 Np-237	2.144E+6y	1.000E+00	Pa-233			
11 Pa-233	26.967d	1.000E+00	U-233			
12 U-233	1.592E+5y	1.000E+00	Th-229			
13 Th-229	7.34E+3y	1.000E+00	Ra-225			
14 Ra-225	14.9d	1.000E+00	Ac-225			
15 Ac-225	10.0d	1.000E+00	Fr-221			
16 Fr-221	4.9m	1.000E+00	At-217			
17 At-217	3.23E-2s	9.999E-01	Bi-213			
18 Bi-213	45.59m	9.791E-01	Po-213	2.090E-02	Tl-209	
19 Po-213	4.2E-6s	1.000E+00	Pb-209			
20 Tl-209	2.161m	1.000E+00	Pb-209			
21 Pb-209	3.253h	1.000E+00	Bi-209\$			

Fm-254

Products -----				Daughter -----		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide f4	Nuclide					
1 Fm-254	3.240h	9.994E-01	Cf-250	5.920E-04	SF	
2 Cf-250	13.08y	9.992E-01	Cm-246	7.700E-04	SF	
3 Cm-246	4.76E+3y	9.997E-01	Pu-242	2.630E-04	SF	
4 Pu-242	3.75E+5y	1.000E+00	U-238	5.540E-06	SF	
5 U-238	4.468E+9y	1.000E+00	Th-234	5.450E-07	SF	
6 Th-234	24.10d	1.000E+00	Pa-234m			
7 Pa-234m	1.17m	1.600E-03	Pa-234	9.984E-01	U-234	
8 Pa-234	6.70h	1.000E+00	U-234			
9 U-234	2.455E+5y	1.000E+00	Th-230			
10 Th-230	7.538E+4y	1.000E+00	Ra-226			
11 Ra-226	1600y	1.000E+00	Rn-222			
12 Rn-222	3.8235d	1.000E+00	Po-218			
13 Po-218	3.10m	9.998E-01	Pb-214	2.000E-04	At-218	
14 Pb-214	26.8m	1.000E+00	Bi-214			
15 At-218	1.5s	9.990E-01	Bi-214	1.000E-03	Rn-218	
16 Bi-214	19.9m	9.998E-01	Po-214	2.100E-04	Tl-210	
17 Rn-218	3.5E-2s	1.000E+00	Po-214			
18 Po-214	1.643E-4s	1.000E+00	Pb-210			
19 Tl-210	1.30m	1.000E+00	Pb-210			

20 Pb-210	22.20y	1.000E+00	Bi-210	1.900E-08	Hg-206
21 Bi-210	5.013d	1.000E+00	Po-210	1.320E-06	Tl-206
22 Hg-206	8.15m	1.000E+00	Tl-206		
23 Po-210	138.376d	1.000E+00	Pb-206\$		
24 Tl-206	4.200m	1.000E+00	Pb-206\$		

Fm-255

Products			Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 Fm-255	20.07h	1.000E+00	Cf-251	2.300E-07	SF
2 Cf-251	900y	1.000E+00	Cm-247		
3 Cm-247	1.56E+7y	1.000E+00	Pu-243		
4 Pu-243	4.956h	1.000E+00	Am-243		
5 Am-243	7.37E+3y	1.000E+00	Np-239		
6 Np-239	2.3565d	1.000E+00	Pu-239		
7 Pu-239	2.411E+4y	9.994E-01	U-235m	6.000E-04	U-235
8 U-235m	26m	1.000E+00	U-235		
9 U-235	7.04E+8y	1.000E+00	Th-231		
10 Th-231	25.52h	1.000E+00	Pa-231		
11 Pa-231	3.276E+4y	1.000E+00	Ac-227		
12 Ac-227	21.772y	9.862E-01	Th-227	1.380E-02	Fr-223
13 Th-227	18.68d	1.000E+00	Ra-223		
14 Fr-223	22.00m	1.000E+00	Ra-223	6.000E-05	At-219
15 Ra-223	11.43d	1.000E+00	Rn-219		
16 Rn-219	3.96s	1.000E+00	Po-215		
17 At-219	56s	9.700E-01	Bi-215		
18 Bi-215	7.6m	1.000E+00	Po-215		
19 Po-215	1.781E-3s	1.000E+00	Pb-211		
20 Pb-211	36.1m	1.000E+00	Bi-211		
21 Bi-211	2.14m	9.972E-01	Tl-207	2.760E-03	Po-211
22 Tl-207	4.77m	1.000E+00	Pb-207\$		
23 Po-211	0.516s	1.000E+00	Pb-207\$		

Fm-256

Products			Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide f3
1 Fm-256	157.6m	8.100E-02	Cf-252	9.190E-01	SF
2 Cf-252	2.645y	9.691E-01	Cm-248	3.092E-02	SF
3 Cm-248	3.48E+5y	9.161E-01	Pu-244	8.390E-02	SF
4 Pu-244	8.00E+7y	9.988E-01	U-240	1.210E-03	SF
5 U-240	14.1h	1.000E+00	Np-240m		
6 Np-240m	7.22m	1.100E-03	Np-240	9.989E-01	Pu-240
7 Np-240	61.9m	1.000E+00	Pu-240		
8 Pu-240	6564y	1.000E+00	U-236	5.750E-08	SF
9 U-236	2.342E+7y	1.000E+00	Th-232		
10 Th-232	1.405E10y	1.000E+00	Ra-228		
11 Ra-228	5.75y	1.000E+00	Ac-228		
12 Ac-228	6.15h	1.000E+00	Th-228		

13	Th-228	1.9116y	1.000E+00	Ra-224		
14	Ra-224	3.66d	1.000E+00	Rn-220		
15	Rn-220	55.6s	1.000E+00	Po-216		
16	Po-216	0.145s	1.000E+00	Pb-212		
17	Pb-212	10.64h	1.000E+00	Bi-212		
18	Bi-212	60.55m	6.406E-01	Po-212	3.594E-01	Tl-208
19	Po-212	2.99E-7s	1.000E+00	Pb-208\$		
20	Tl-208	3.053m	1.000E+00	Pb-208\$		

Fm-257

Products -----				Daughter		
Nuclide	Halflife	f1	Nuclide	f2	Nuclide	f3
Nuclide	f4	Nuclide				
1 Fm-257	100.5d	9.979E-01	Cf-253	2.100E-03	SF	
2 Cf-253	17.81d	9.969E-01	Es-253	3.100E-03	Cm-249	
3 Es-253	20.47d	1.000E+00	Bk-249	8.900E-08	SF	
4 Cm-249	64.15m	1.000E+00	Bk-249			
5 Bk-249	330d	1.000E+00	Cf-249	1.450E-05	Am-245	
6 Cf-249	351y	1.000E+00	Cm-245	5.020E-09	SF	
7 Am-245	2.05h	1.000E+00	Cm-245			
8 Cm-245	8.5E+3y	1.000E+00	Pu-241	6.100E-09	SF	
9 Pu-241	14.35y	1.000E+00	Am-241	2.450E-05	U-237	
10 Am-241	432.2y	1.000E+00	Np-237			
11 U-237	6.75d	1.000E+00	Np-237			
12 Np-237	2.144E+6y	1.000E+00	Pa-233			
13 Pa-233	26.967d	1.000E+00	U-233			
14 U-233	1.592E+5y	1.000E+00	Th-229			
15 Th-229	7.34E+3y	1.000E+00	Ra-225			
16 Ra-225	14.9d	1.000E+00	Ac-225			
17 Ac-225	10.0d	1.000E+00	Fr-221			
18 Fr-221	4.9m	1.000E+00	At-217			
19 At-217	3.23E-2s	9.999E-01	Bi-213			
20 Bi-213	45.59m	9.791E-01	Po-213	2.090E-02	Tl-209	
21 Po-213	4.2E-6s	1.000E+00	Pb-209			
22 Tl-209	2.161m	1.000E+00	Pb-209			
23 Pb-209	3.253h	1.000E+00	Bi-209\$			

\$ stable nucleus.

Dose Equivalent Rate (Sv/s) per Unit Concentration (Bq/m3) - Water Immersion

Nuclide	Skin	Effective
H-3	0.00E+00	0.00E+00
Be-7	6.03E-18	4.81E-18
Be-10	1.37E-17	1.55E-19
C-10	2.68E-16	1.71E-16
C-11	1.47E-16	9.90E-17
C-14	2.55E-19	2.89E-21
N-13	1.56E-16	9.91E-17
N-16	8.19E-16	5.63E-16
O-14	4.70E-16	3.52E-16
O-15	1.75E-16	9.95E-17
O-19	2.49E-16	9.83E-17
F-17	1.75E-16	9.95E-17
F-18	1.33E-16	9.58E-17
Ne-19	1.92E-16	9.98E-17
Ne-24	1.22E-16	5.33E-17
Na-22	2.78E-16	2.20E-16
Na-24	5.59E-16	4.51E-16
Mg-27	1.57E-16	8.98E-17
Mg-28	1.74E-16	1.38E-16
Al-26	3.61E-16	2.78E-16
Al-28	3.14E-16	1.91E-16
Al-29	2.41E-16	1.44E-16
Si-31	4.03E-17	6.14E-19
Si-32	1.05E-18	1.14E-20
P-30	2.30E-16	1.01E-16
P-32	4.79E-17	6.45E-19
P-33	1.45E-18	1.57E-20
S-35	3.03E-19	3.40E-21
S-37	4.34E-16	3.34E-16
S-38	2.46E-16	1.83E-16
Cl-34	2.81E-16	1.02E-16
Cl-34m	2.97E-16	2.24E-16
Cl-36	1.56E-17	1.94E-19
Cl-38	2.99E-16	1.58E-16
Cl-39	2.37E-16	1.50E-16
Cl-40	6.34E-16	4.53E-16
Ar-37	0.00E+00	0.00E+00
Ar-39	1.13E-17	1.28E-19
Ar-41	1.88E-16	1.33E-16
Ar-42	1.24E-17	1.41E-19
Ar-43	2.91E-16	1.62E-16
Ar-44	2.77E-16	2.04E-16
K-38	4.86E-16	3.36E-16
K-40	5.45E-17	1.68E-17
K-42	1.41E-16	3.11E-17

K-43	1.35E-16	9.39E-17
K-44	4.09E-16	2.57E-16
K-45	3.01E-16	1.95E-16
K-46	5.43E-16	3.17E-16
Ca-41	0.00E+00	0.00E+00
Ca-45	1.53E-18	1.66E-20
Ca-47	1.51E-16	1.08E-16
Ca-49	4.70E-16	3.61E-16
Sc-42m	6.08E-16	4.28E-16
Sc-43	1.46E-16	9.55E-17
Sc-44	3.01E-16	2.14E-16
Sc-44m	3.52E-17	2.66E-17
Sc-46	2.49E-16	2.03E-16
Sc-47	2.04E-17	1.03E-17
Sc-48	4.22E-16	3.42E-16
Sc-49	5.77E-17	9.20E-19
Sc-50	5.18E-16	3.32E-16
Ti-44	1.61E-17	1.10E-17
Ti-45	1.29E-16	8.45E-17
Ti-51	1.06E-16	3.66E-17
Ti-52	6.69E-17	1.22E-17
V-47	1.77E-16	9.72E-17
V-48	3.66E-16	2.95E-16
V-49	0.00E+00	0.00E+00
V-50	1.77E-16	1.49E-16
V-52	2.56E-16	1.52E-16
V-53	1.99E-16	1.06E-16
Cr-48	5.29E-17	4.12E-17
Cr-49	1.68E-16	1.02E-16
Cr-51	3.86E-18	3.05E-18
Cr-55	7.98E-17	1.30E-18
Cr-56	5.01E-17	7.36E-18
Mn-50m	6.82E-16	4.71E-16
Mn-51	1.87E-16	9.76E-17
Mn-52m	3.78E-16	2.45E-16
Mn-52	4.27E-16	3.51E-16
Mn-53	0.00E+00	0.00E+00
Mn-54	1.01E-16	8.30E-17
Mn-56	2.68E-16	1.76E-16
Mn-57	9.07E-17	1.07E-17
Mn-58m	4.25E-16	2.47E-16
Fe-52	1.01E-16	7.13E-17
Fe-53	2.23E-16	1.15E-16
Fe-53m	3.76E-16	3.12E-16
Fe-55	1.96E-26	1.49E-26
Fe-59	1.50E-16	1.22E-16
Fe-60	6.91E-19	7.59E-21

Fe-61	2.50E-16	1.44E-16
Fe-62	1.19E-16	4.98E-17
Co-54m	6.38E-16	3.99E-16
Co-55	2.72E-16	1.99E-16
Co-56	4.60E-16	3.82E-16
Co-57	1.48E-17	1.11E-17
Co-58	1.20E-16	9.63E-17
Co-58m	7.22E-22	1.43E-22
Co-60	3.11E-16	2.58E-16
Co-60m	6.34E-19	4.23E-19
Co-61	4.11E-17	8.67E-18
Co-62	3.22E-16	1.70E-16
Co-62m	4.12E-16	2.81E-16
Ni-56	2.09E-16	1.70E-16
Ni-57	2.48E-16	1.99E-16
Ni-59	1.88E-21	1.50E-21
Ni-63	0.00E+00	0.00E+00
Ni-65	1.12E-16	5.83E-17
Ni-66	1.36E-18	1.48E-20
Cu-57	4.27E-16	1.19E-16
Cu-59	2.87E-16	1.44E-16
Cu-60	5.48E-16	4.06E-16
Cu-61	1.20E-16	8.02E-17
Cu-62	2.16E-16	9.90E-17
Cu-64	2.86E-17	1.80E-17
Cu-66	8.90E-17	1.11E-17
Cu-67	1.94E-17	1.08E-17
Cu-69	1.27E-16	5.41E-17
Zn-60	2.67E-16	1.49E-16
Zn-61	3.28E-16	1.55E-16
Zn-62	5.42E-17	4.21E-17
Zn-63	1.99E-16	1.08E-16
Zn-65	7.09E-17	5.88E-17
Zn-69m	5.18E-17	4.01E-17
Zn-69	1.92E-17	2.28E-19
Zn-71m	2.25E-16	1.53E-16
Zn-71	1.14E-16	3.22E-17
Zn-72	2.00E-17	1.37E-17
Ga-64	5.49E-16	3.55E-16
Ga-65	1.97E-16	1.13E-16
Ga-66	3.86E-16	2.69E-16
Ga-67	1.89E-17	1.45E-17
Ga-68	1.67E-16	9.27E-17
Ga-70	4.49E-17	1.32E-18
Ga-72	3.70E-16	2.83E-16
Ga-73	7.07E-17	3.37E-17
Ga-74	4.66E-16	3.35E-16

Ge-66	8.63E-17	6.46E-17
Ge-67	2.59E-16	1.41E-16
Ge-68	1.36E-20	2.05E-22
Ge-69	1.23E-16	9.49E-17
Ge-71	1.38E-20	2.08E-22
Ge-75	3.10E-17	3.71E-18
Ge-77	1.76E-16	1.07E-16
Ge-78	4.58E-17	2.68E-17
As-68	6.09E-16	3.80E-16
As-69	2.28E-16	1.13E-16
As-70	5.85E-16	4.32E-16
As-71	7.60E-17	5.56E-17
As-72	2.92E-16	1.77E-16
As-73	6.39E-19	3.55E-19
As-74	1.08E-16	7.38E-17
As-76	1.28E-16	4.25E-17
As-77	1.29E-17	9.34E-19
As-78	2.53E-16	1.35E-16
As-79	6.62E-17	4.20E-18
Se-70	9.89E-17	6.83E-17
Se-71	2.98E-16	1.60E-16
Se-72	2.92E-18	1.41E-18
Se-73	1.57E-16	1.05E-16
Se-73m	4.18E-17	2.55E-17
Se-75	4.69E-17	3.64E-17
Se-77m	1.30E-17	8.13E-18
Se-79	2.99E-19	3.38E-21
Se-79m	1.57E-18	8.01E-19
Se-81	4.24E-17	1.33E-18
Se-81m	2.45E-18	1.23E-18
Se-83	3.52E-16	2.68E-16
Se-83m	2.14E-16	1.02E-16
Se-84	8.76E-17	4.09E-17
Br-72	5.81E-16	3.03E-16
Br-73	2.72E-16	1.41E-16
Br-74	6.59E-16	4.98E-16
Br-74m	6.10E-16	4.33E-16
Br-75	1.81E-16	1.16E-16
Br-76	3.94E-16	2.91E-16
Br-76m	4.20E-18	2.19E-18
Br-77	3.85E-17	3.05E-17
Br-77m	2.69E-18	1.32E-18
Br-78	1.99E-16	1.01E-16
Br-80	5.98E-17	8.09E-18
Br-80m	1.67E-18	5.56E-19
Br-82	3.28E-16	2.64E-16
Br-82m	2.80E-18	3.19E-19

Br-83	2.04E-17	8.98E-19
Br-84	3.13E-16	1.92E-16
Br-84m	4.04E-16	2.83E-16
Br-85	8.29E-17	7.81E-18
Kr-74	1.68E-16	1.02E-16
Kr-75	2.70E-16	1.26E-16
Kr-76	5.11E-17	4.00E-17
Kr-77	1.73E-16	1.00E-16
Kr-79	3.14E-17	2.42E-17
Kr-81	3.21E-19	8.39E-20
Kr-81m	1.82E-17	1.22E-17
Kr-83m	7.65E-20	2.57E-21
Kr-85	1.41E-17	3.75E-19
Kr-85m	3.37E-17	1.49E-17
Kr-87	1.97E-16	8.51E-17
Kr-88	2.69E-16	2.10E-16
Kr-89	3.43E-16	2.06E-16
Rb-77	3.14E-16	1.53E-16
Rb-78	6.12E-16	4.41E-16
Rb-78m	5.08E-16	3.28E-16
Rb-79	2.31E-16	1.41E-16
Rb-80	3.00E-16	1.19E-16
Rb-81	6.86E-17	4.89E-17
Rb-81m	3.64E-18	2.33E-18
Rb-82	2.39E-16	1.09E-16
Rb-82m	3.61E-16	2.91E-16
Rb-83	5.89E-17	4.69E-17
Rb-84	1.20E-16	8.95E-17
Rb-84m	5.02E-17	3.66E-17
Rb-86	5.74E-17	1.01E-17
Rb-86m	6.67E-17	5.30E-17
Rb-87	3.59E-18	3.90E-20
Rb-88	2.39E-16	7.12E-17
Rb-89	3.47E-16	2.36E-16
Rb-90	4.19E-16	2.33E-16
Rb-90m	5.13E-16	3.51E-16
Sr-79	2.82E-16	1.16E-16
Sr-80	5.46E-17	4.17E-17
Sr-81	2.38E-16	1.35E-16
Sr-82	3.23E-19	1.10E-20
Sr-83	1.08E-16	8.02E-17
Sr-85	6.01E-17	4.77E-17
Sr-85m	2.67E-17	2.07E-17
Sr-87m	4.27E-17	3.07E-17
Sr-89	3.95E-17	5.26E-19
Sr-90	9.71E-18	1.09E-19
Sr-91	1.31E-16	7.14E-17

Sr-92	1.75E-16	1.39E-16
Sr-93	3.34E-16	2.31E-16
Sr-94	2.36E-16	1.49E-16
Y-81	2.87E-16	1.15E-16
Y-83	2.59E-16	1.33E-16
Y-83m	1.59E-16	8.15E-17
Y-84m	5.75E-16	3.98E-16
Y-85	1.64E-16	1.05E-16
Y-85m	2.03E-16	1.34E-16
Y-86	4.54E-16	3.64E-16
Y-86m	2.75E-17	2.10E-17
Y-87	5.34E-17	4.23E-17
Y-87m	4.19E-17	2.94E-17
Y-88	3.34E-16	2.82E-16
Y-89m	1.10E-16	9.02E-17
Y-90	6.65E-17	9.86E-19
Y-90m	7.98E-17	6.10E-17
Y-91	4.12E-17	8.61E-19
Y-91m	6.57E-17	5.13E-17
Y-92	1.39E-16	2.74E-17
Y-93	9.74E-17	1.13E-17
Y-94	2.32E-16	8.12E-17
Y-95	2.47E-16	1.23E-16
Zr-85	2.77E-16	1.45E-16
Zr-86	3.48E-17	2.63E-17
Zr-87	1.71E-16	9.10E-17
Zr-88	4.74E-17	3.68E-17
Zr-89	1.46E-16	1.15E-16
Zr-89m	7.91E-17	6.24E-17
Zr-93	6.75E-23	6.75E-25
Zr-95	9.30E-17	7.23E-17
Zr-97	1.57E-16	8.79E-17
Nb-87	2.75E-16	1.19E-16
Nb-88	6.18E-16	4.20E-16
Nb-88m	6.11E-16	4.13E-16
Nb-89	2.49E-16	1.40E-16
Nb-89m	2.14E-16	1.27E-16
Nb-90	5.51E-16	4.44E-16
Nb-91	7.11E-19	1.86E-19
Nb-91m	4.20E-18	2.59E-18
Nb-92	1.82E-16	1.48E-16
Nb-92m	1.17E-16	9.63E-17
Nb-93m	1.01E-19	7.13E-21
Nb-94	1.97E-16	1.55E-16
Nb-94m	1.06E-18	4.67E-19
Nb-95	9.30E-17	7.56E-17
Nb-95m	1.70E-17	6.10E-18

Nb-96	3.14E-16	2.45E-16
Nb-97	1.11E-16	6.56E-17
Nb-98m	3.98E-16	2.86E-16
Nb-99	1.29E-16	1.72E-17
Nb-99m	2.00E-16	8.26E-17
Mo-89	2.98E-16	1.22E-16
Mo-90	1.11E-16	7.98E-17
Mo-91	2.26E-16	9.66E-17
Mo-91m	2.10E-16	1.40E-16
Mo-93	5.66E-19	3.99E-20
Mo-93m	2.90E-16	2.36E-16
Mo-99	4.25E-17	1.48E-17
Mo-101	2.17E-16	1.51E-16
Mo-102	2.37E-17	2.01E-18
Tc-91	4.37E-16	2.60E-16
Tc-91m	3.16E-16	1.42E-16
Tc-92	6.04E-16	3.88E-16
Tc-93	1.96E-16	1.62E-16
Tc-93m	1.26E-16	1.01E-16
Tc-94	3.25E-16	2.63E-16
Tc-94m	2.93E-16	1.97E-16
Tc-95	9.60E-17	7.78E-17
Tc-95m	8.33E-17	6.64E-17
Tc-96	3.04E-16	2.48E-16
Tc-96m	5.44E-18	4.21E-18
Tc-97	6.30E-19	5.20E-20
Tc-97m	8.98E-19	8.10E-20
Tc-98	1.77E-16	1.39E-16
Tc-99	2.88E-18	3.14E-20
Tc-99m	1.56E-17	1.17E-17
Tc-101	7.15E-17	3.28E-17
Tc-102	1.58E-16	1.10E-17
Tc-102m	3.61E-16	2.56E-16
Tc-104	4.00E-16	2.37E-16
Tc-105	1.89E-16	8.10E-17
Ru-92	3.05E-16	2.05E-16
Ru-94	6.24E-17	4.96E-17
Ru-95	1.56E-16	1.23E-16
Ru-97	2.88E-17	2.18E-17
Ru-103	6.12E-17	4.80E-17
Ru-105	1.17E-16	7.34E-17
Ru-106	0.00E+00	0.00E+00
Ru-107	1.20E-16	3.57E-17
Ru-108	3.81E-17	6.10E-18
Rh-94	6.92E-16	3.89E-16
Rh-95	3.80E-16	2.62E-16
Rh-95m	1.25E-16	9.31E-17

Rh-96	5.32E-16	3.93E-16
Rh-96m	1.97E-16	1.30E-16
Rh-97	2.12E-16	1.43E-16
Rh-97m	2.88E-16	2.31E-16
Rh-98	3.20E-16	1.80E-16
Rh-99	6.81E-17	5.28E-17
Rh-99m	8.02E-17	6.28E-17
Rh-100	3.43E-16	2.85E-16
Rh-100m	6.78E-18	4.43E-18
Rh-101	3.46E-17	2.58E-17
Rh-101m	3.46E-17	2.64E-17
Rh-102	7.16E-17	4.86E-17
Rh-102m	2.61E-16	2.11E-16
Rh-103m	9.87E-20	1.32E-20
Rh-104	7.19E-17	2.26E-18
Rh-104m	4.18E-18	2.09E-18
Rh-105	1.61E-17	7.49E-18
Rh-106	1.30E-16	2.20E-17
Rh-106m	3.69E-16	2.86E-16
Rh-107	6.62E-17	3.05E-17
Rh-108	1.76E-16	3.34E-17
Rh-109	1.02E-16	2.95E-17
Pd-96	1.89E-16	1.41E-16
Pd-97	3.48E-16	2.43E-16
Pd-98	5.04E-17	3.85E-17
Pd-99	1.87E-16	1.28E-16
Pd-100	1.30E-17	8.19E-18
Pd-101	4.24E-17	3.22E-17
Pd-103	9.18E-19	1.24E-19
Pd-107	0.00E+00	0.00E+00
Pd-109	2.34E-17	6.88E-19
Pd-109m	1.62E-17	1.01E-17
Pd-111	6.51E-17	5.62E-18
Pd-112	1.85E-18	4.33E-20
Pd-114	3.84E-17	2.89E-18
Ag-99	3.80E-16	2.33E-16
Ag-100m	4.92E-16	2.87E-16
Ag-101	2.52E-16	1.56E-16
Ag-102	4.80E-16	3.47E-16
Ag-102m	2.77E-16	2.10E-16
Ag-103	1.15E-16	8.23E-17
Ag-104	3.35E-16	2.70E-16
Ag-104m	2.75E-16	1.83E-16
Ag-105	6.16E-17	4.81E-17
Ag-105m	1.24E-19	9.63E-20
Ag-106	1.19E-16	6.77E-17
Ag-106m	3.42E-16	2.79E-16

Ag-108	4.35E-17	2.32E-18
Ag-108m	1.96E-16	1.57E-16
Ag-109m	1.08E-18	3.56E-19
Ag-110	8.99E-17	4.38E-18
Ag-110m	3.40E-16	2.77E-16
Ag-111	2.49E-17	2.80E-18
Ag-111m	7.80E-19	3.71E-19
Ag-112	1.86E-16	7.24E-17
Ag-113	6.18E-17	7.75E-18
Ag-113m	3.90E-17	2.07E-17
Ag-114	1.94E-16	2.97E-17
Ag-115	1.39E-16	5.12E-17
Ag-116	4.01E-16	2.29E-16
Ag-117	2.57E-16	1.40E-16
Cd-101	3.82E-16	2.53E-16
Cd-102	1.05E-16	8.10E-17
Cd-103	2.83E-16	2.17E-16
Cd-104	2.92E-17	2.21E-17
Cd-105	1.75E-16	1.33E-16
Cd-107	3.03E-18	1.09E-18
Cd-109	2.11E-18	5.20E-19
Cd-111m	3.73E-17	2.64E-17
Cd-113	2.49E-18	2.72E-20
Cd-113m	8.91E-18	1.06E-19
Cd-115	4.22E-17	1.88E-17
Cd-115m	4.50E-17	3.87E-18
Cd-117	1.61E-16	1.10E-16
Cd-117m	2.66E-16	2.14E-16
Cd-118	7.19E-18	8.02E-20
Cd-119	2.61E-16	1.72E-16
Cd-119m	3.33E-16	2.41E-16
In-103	4.55E-16	2.82E-16
In-105	3.12E-16	1.94E-16
In-106m	4.69E-16	2.92E-16
In-106	5.12E-16	3.53E-16
In-107	2.11E-16	1.56E-16
In-108m	3.97E-16	2.92E-16
In-108	4.89E-16	3.93E-16
In-109m	7.64E-17	5.95E-17
In-109	7.92E-17	6.23E-17
In-110m	2.37E-16	1.57E-16
In-110	3.76E-16	3.06E-16
In-111m	6.12E-17	4.55E-17
In-111	4.95E-17	3.70E-17
In-112m	6.82E-18	2.15E-18
In-112	4.72E-17	2.56E-17
In-113m	3.95E-17	2.46E-17

ln-114m	1.51E-17	7.07E-18
ln-114	5.45E-17	9.87E-19
ln-115m	2.94E-17	1.50E-17
ln-115	6.56E-18	7.29E-20
ln-116m	3.23E-16	2.55E-16
ln-117m	3.94E-17	8.63E-18
ln-117	9.81E-17	6.69E-17
ln-118m	3.86E-16	2.83E-16
ln-118	1.53E-16	1.08E-17
ln-119m	8.11E-17	7.63E-18
ln-119	1.33E-16	7.63E-17
ln-121m	1.20E-16	7.29E-18
ln-121	1.83E-16	9.37E-17
Sn-106	1.53E-16	1.17E-16
Sn-108	8.27E-17	6.45E-17
Sn-109	2.76E-16	2.28E-16
Sn-110	3.50E-17	2.65E-17
Sn-111	7.20E-17	4.79E-17
Sn-113m	1.02E-18	2.38E-19
Sn-113	1.97E-18	7.73E-19
Sn-117m	2.29E-17	1.35E-17
Sn-119m	1.06E-18	2.17E-19
Sn-121m	1.36E-18	1.12E-19
Sn-121	3.98E-18	4.36E-20
Sn-123m	4.72E-17	1.34E-17
Sn-123	3.55E-17	1.15E-18
Sn-125m	9.86E-17	3.42E-17
Sn-125	9.78E-17	3.49E-17
Sn-126	8.08E-18	4.09E-18
Sn-127m	1.50E-16	5.72E-17
Sn-127	2.69E-16	1.95E-16
Sn-128	8.07E-17	5.49E-17
Sn-129	2.15E-16	1.02E-16
Sn-130m	2.10E-16	8.99E-17
Sn-130	1.40E-16	9.04E-17
Sb-111	2.81E-16	1.46E-16
Sb-113	2.05E-16	1.24E-16
Sb-114	4.20E-16	2.74E-16
Sb-115	1.23E-16	8.55E-17
Sb-116	3.17E-16	2.33E-16
Sb-116m	3.84E-16	3.11E-16
Sb-117	2.24E-17	1.59E-17
Sb-118	1.61E-16	7.86E-17
Sb-118m	3.19E-16	2.61E-16
Sb-119	1.68E-18	3.55E-19
Sb-120	7.53E-17	4.32E-17
Sb-120m	3.01E-16	2.46E-16

Sb-122	9.17E-17	4.39E-17
Sb-122m	7.17E-18	4.04E-18
Sb-124	2.53E-16	1.90E-16
Sb-124m	6.01E-17	4.30E-17
Sb-124n	6.04E-23	1.32E-23
Sb-125	5.53E-17	4.12E-17
Sb-126	3.56E-16	2.71E-16
Sb-126m	2.31E-16	1.52E-16
Sb-127	1.03E-16	6.80E-17
Sb-128	4.08E-16	3.05E-16
Sb-128m	3.00E-16	1.89E-16
Sb-129	2.04E-16	1.48E-16
Sb-130	4.51E-16	3.26E-16
Sb-130m	4.03E-16	2.72E-16
Sb-131	2.95E-16	2.13E-16
Sb-133	3.87E-16	2.87E-16
Te-113	4.02E-16	2.27E-16
Te-114	1.64E-16	1.28E-16
Te-115	3.34E-16	2.26E-16
Te-115m	3.70E-16	2.65E-16
Te-116	1.23E-17	8.08E-18
Te-117	2.05E-16	1.57E-16
Te-118	1.49E-18	3.56E-19
Te-119	9.29E-17	7.44E-17
Te-119m	1.84E-16	1.51E-16
Te-121	6.91E-17	5.45E-17
Te-121m	2.65E-17	1.98E-17
Te-123	2.59E-21	6.19E-22
Te-123m	1.81E-17	1.28E-17
Te-125m	3.60E-18	7.78E-19
Te-127	1.25E-17	6.02E-19
Te-127m	1.38E-18	2.55E-19
Te-129	4.18E-17	6.13E-18
Te-129m	1.89E-17	3.26E-18
Te-131	9.90E-17	4.14E-17
Te-131m	1.85E-16	1.45E-16
Te-132	2.94E-17	2.05E-17
Te-133	1.95E-16	1.23E-16
Te-133m	2.51E-16	1.87E-16
Te-134	1.15E-16	8.42E-17
I-118	3.96E-16	2.02E-16
I-118m	5.37E-16	3.71E-16
I-119	1.46E-16	8.79E-17
I-120	4.17E-16	2.76E-16
I-120m	4.97E-16	3.53E-16
I-121	5.12E-17	3.70E-17
I-122	1.98E-16	9.45E-17

I-123	2.05E-17	1.45E-17
I-124	1.49E-16	1.11E-16
I-125	3.32E-18	8.88E-19
I-126	6.17E-17	4.17E-17
I-128	6.04E-17	7.16E-18
I-129	2.35E-18	6.68E-19
I-130	2.75E-16	2.10E-16
I-130m	2.37E-17	1.05E-17
I-131	5.55E-17	3.69E-17
I-132	3.08E-16	2.26E-16
I-132m	4.57E-17	3.26E-17
I-133	1.00E-16	6.02E-17
I-134	3.55E-16	2.61E-16
I-134m	3.82E-17	2.60E-17
I-135	2.16E-16	1.64E-16
Xe-120	4.74E-17	3.60E-17
Xe-121	2.22E-16	1.50E-16
Xe-122	7.37E-18	4.81E-18
Xe-123	8.85E-17	6.20E-17
Xe-125	3.25E-17	2.37E-17
Xe-127	3.39E-17	2.48E-17
Xe-127m	2.33E-17	1.45E-17
Xe-129m	1.12E-17	2.01E-18
Xe-131m	6.17E-18	7.64E-19
Xe-133	8.01E-18	3.06E-18
Xe-133m	1.32E-17	2.75E-18
Xe-135	4.89E-17	2.39E-17
Xe-135m	5.78E-17	4.09E-17
Xe-137	1.51E-16	2.12E-17
Xe-138	1.84E-16	1.18E-16
Cs-121	2.73E-16	1.16E-16
Cs-121m	2.43E-16	1.16E-16
Cs-123	1.99E-16	1.06E-16
Cs-124	2.94E-16	1.16E-16
Cs-125	1.15E-16	7.31E-17
Cs-126	2.39E-16	1.14E-16
Cs-127	5.26E-17	4.01E-17
Cs-128	1.72E-16	8.71E-17
Cs-129	3.29E-17	2.46E-17
Cs-130	8.74E-17	4.83E-17
Cs-130m	7.67E-18	4.53E-18
Cs-131	1.86E-18	5.63E-19
Cs-132	8.62E-17	6.85E-17
Cs-134	1.97E-16	1.53E-16
Cs-134m	4.55E-18	1.77E-18
Cs-135	2.18E-18	2.37E-20
Cs-135m	1.96E-16	1.59E-16

Cs-136	2.65E-16	2.13E-16
Cs-137	9.22E-18	1.05E-19
Cs-138	3.84E-16	2.48E-16
Cs-138m	7.00E-17	4.14E-17
Cs-139	1.63E-16	3.45E-17
Cs-140	3.70E-16	1.91E-16
Ba-124	7.92E-17	5.46E-17
Ba-126	7.02E-17	5.57E-17
Ba-127	1.29E-16	7.08E-17
Ba-128	7.22E-18	4.67E-18
Ba-129	4.76E-17	3.13E-17
Ba-129m	1.94E-16	1.56E-16
Ba-131	5.73E-17	4.36E-17
Ba-131m	8.83E-18	5.93E-18
Ba-133	4.77E-17	3.56E-17
Ba-133m	1.86E-17	5.36E-18
Ba-135m	1.72E-17	4.65E-18
Ba-137m	7.65E-17	5.83E-17
Ba-139	6.91E-17	5.17E-18
Ba-140	3.84E-17	1.74E-17
Ba-141	1.81E-16	9.32E-17
Ba-142	1.53E-16	1.05E-16
La-128	4.44E-16	2.82E-16
La-129	1.54E-16	8.90E-17
La-130	3.55E-16	2.23E-16
La-131	9.13E-17	6.26E-17
La-132	2.86E-16	2.02E-16
La-132m	8.46E-17	6.42E-17
La-133	2.06E-17	1.39E-17
La-134	1.42E-16	7.02E-17
La-135	3.41E-18	1.73E-18
La-136	6.90E-17	3.86E-17
La-137	2.09E-18	7.20E-19
La-138	1.52E-16	1.26E-16
La-140	3.21E-16	2.39E-16
La-141	7.41E-17	3.86E-18
La-142	3.61E-16	2.56E-16
La-143	1.28E-16	2.91E-17
Ce-130	6.17E-17	4.66E-17
Ce-131	2.40E-16	1.61E-16
Ce-132	3.24E-17	2.40E-17
Ce-133	8.67E-17	4.96E-17
Ce-133m	2.15E-16	1.73E-16
Ce-134	2.46E-18	9.72E-19
Ce-135	9.99E-17	7.85E-17
Ce-137	3.65E-18	1.90E-18
Ce-137m	1.62E-17	4.18E-18

Ce-139	1.92E-17	1.32E-17
Ce-141	1.56E-17	6.87E-18
Ce-143	5.92E-17	2.58E-17
Ce-144	4.28E-18	1.61E-18
Ce-145	1.42E-16	7.87E-17
Pr-134	4.63E-16	3.12E-16
Pr-134m	3.99E-16	2.34E-16
Pr-135	1.45E-16	8.42E-17
Pr-136	3.18E-16	2.15E-16
Pr-137	5.73E-17	3.50E-17
Pr-138	1.85E-16	8.02E-17
Pr-138m	3.15E-16	2.45E-16
Pr-139	1.76E-17	1.11E-17
Pr-140	1.05E-16	5.27E-17
Pr-142	6.42E-17	6.94E-18
Pr-142m	0.00E+00	0.00E+00
Pr-143	1.87E-17	2.22E-19
Pr-144	9.20E-17	4.45E-18
Pr-144m	1.22E-18	5.76E-19
Pr-145	4.87E-17	2.46E-18
Pr-146	2.23E-16	1.06E-16
Pr-147	1.17E-16	4.69E-17
Pr-148	2.47E-16	1.03E-16
Pr-148m	2.40E-16	9.36E-17
Nd-134	7.54E-17	5.06E-17
Nd-135	2.25E-16	1.22E-16
Nd-136	3.37E-17	2.41E-17
Nd-137	1.64E-16	1.16E-16
Nd-138	4.41E-18	2.44E-18
Nd-139	6.73E-17	4.22E-17
Nd-139m	1.94E-16	1.56E-16
Nd-140	2.55E-18	1.04E-18
Nd-141	8.96E-18	5.79E-18
Nd-141m	8.84E-17	6.85E-17
Nd-144	0.00E+00	0.00E+00
Nd-147	2.92E-17	1.25E-17
Nd-149	7.53E-17	3.53E-17
Nd-151	1.45E-16	8.49E-17
Nd-152	3.90E-17	1.57E-17
Pm-136	4.95E-16	2.69E-16
Pm-137m	2.94E-16	1.74E-16
Pm-139	1.91E-16	9.24E-17
Pm-140	2.85E-16	1.05E-16
Pm-140m	4.41E-16	3.01E-16
Pm-141	1.33E-16	7.24E-17
Pm-142	2.02E-16	8.48E-17
Pm-143	3.74E-17	2.93E-17

Pm-144	1.89E-16	1.51E-16
Pm-145	2.88E-18	1.28E-18
Pm-146	9.54E-17	7.23E-17
Pm-147	8.51E-19	9.64E-21
Pm-148	1.21E-16	5.93E-17
Pm-148m	2.49E-16	1.95E-16
Pm-149	2.39E-17	1.41E-18
Pm-150	2.38E-16	1.50E-16
Pm-151	5.58E-17	3.12E-17
Pm-152	1.32E-16	3.04E-17
Pm-152m	2.46E-16	1.53E-16
Pm-153	5.45E-17	7.02E-18
Pm-154	2.81E-16	1.88E-16
Pm-154m	2.84E-16	1.84E-16
Sm-139	2.57E-16	1.44E-16
Sm-140	7.93E-17	5.49E-17
Sm-141	2.24E-16	1.40E-16
Sm-141m	2.64E-16	1.93E-16
Sm-142	1.50E-17	9.11E-18
Sm-143	9.93E-17	5.11E-17
Sm-143m	8.78E-17	6.75E-17
Sm-145	6.06E-18	2.86E-18
Sm-146	0.00E+00	0.00E+00
Sm-147	0.00E+00	0.00E+00
Sm-148	0.00E+00	0.00E+00
Sm-151	4.64E-22	6.20E-23
Sm-153	1.89E-17	4.65E-18
Sm-155	4.91E-17	9.44E-18
Sm-156	2.24E-17	1.04E-17
Sm-157	1.11E-16	4.09E-17
Eu-142	3.64E-16	1.23E-16
Eu-142m	5.50E-16	3.42E-16
Eu-143	2.40E-16	1.13E-16
Eu-144	2.93E-16	1.11E-16
Eu-145	1.58E-16	1.29E-16
Eu-146	2.95E-16	2.40E-16
Eu-147	5.69E-17	4.42E-17
Eu-148	2.71E-16	2.19E-16
Eu-149	7.11E-18	4.53E-18
Eu-150	1.89E-16	1.51E-16
Eu-150m	2.49E-17	4.88E-18
Eu-152	1.49E-16	1.17E-16
Eu-152m	7.00E-17	2.94E-17
Eu-152n	8.53E-18	5.92E-18
Eu-154	1.65E-16	1.25E-16
Eu-154m	7.55E-18	4.87E-18
Eu-155	7.41E-18	4.87E-18

Eu-156	1.81E-16	1.28E-16
Eu-157	5.76E-17	2.67E-17
Eu-158	2.19E-16	1.32E-16
Eu-159	9.60E-17	2.83E-17
Gd-142	1.81E-16	1.03E-16
Gd-143m	3.50E-16	2.11E-16
Gd-144	1.54E-16	9.19E-17
Gd-145	3.27E-16	2.55E-16
Gd-145m	9.44E-17	6.67E-17
Gd-146	2.93E-17	1.95E-17
Gd-147	1.73E-16	1.37E-16
Gd-148	0.00E+00	0.00E+00
Gd-149	6.51E-17	4.89E-17
Gd-150	0.00E+00	0.00E+00
Gd-151	7.88E-18	4.81E-18
Gd-152	0.00E+00	0.00E+00
Gd-153	1.14E-17	7.05E-18
Gd-159	2.42E-17	4.95E-18
Gd-162	6.97E-17	4.02E-17
Tb-146	5.60E-16	3.77E-16
Tb-147	2.86E-16	2.20E-16
Tb-147m	2.59E-16	1.97E-16
Tb-148	3.52E-16	2.40E-16
Tb-148m	4.02E-16	3.09E-16
Tb-149	1.71E-16	1.36E-16
Tb-149m	1.80E-16	1.34E-16
Tb-150	3.24E-16	2.54E-16
Tb-150m	3.12E-16	2.44E-16
Tb-151	1.22E-16	9.47E-17
Tb-151m	9.31E-18	6.99E-18
Tb-152	2.01E-16	1.51E-16
Tb-152m	9.60E-17	7.16E-17
Tb-153	3.93E-17	2.97E-17
Tb-154	2.87E-16	2.40E-16
Tb-155	2.06E-17	1.40E-17
Tb-156	2.37E-16	1.93E-16
Tb-156m	3.81E-18	2.13E-18
Tb-156n	5.95E-19	2.25E-19
Tb-157	4.55E-19	2.28E-19
Tb-158	9.98E-17	7.84E-17
Tb-160	1.48E-16	1.13E-16
Tb-161	1.02E-17	2.01E-18
Tb-162	1.67E-16	1.09E-16
Tb-163	1.16E-16	7.62E-17
Tb-164	3.53E-16	2.47E-16
Tb-165	1.65E-16	8.67E-17
Dy-148	8.73E-17	6.85E-17

Dy-149	2.03E-16	1.63E-16
Dy-150	3.33E-17	2.57E-17
Dy-151	1.69E-16	1.36E-16
Dy-152	3.43E-17	2.59E-17
Dy-153	1.06E-16	8.34E-17
Dy-154	0.00E+00	0.00E+00
Dy-155	8.13E-17	6.45E-17
Dy-157	4.14E-17	3.15E-17
Dy-159	4.46E-18	2.32E-18
Dy-165	3.15E-17	2.73E-18
Dy-165m	3.60E-18	1.55E-18
Dy-166	8.88E-18	2.91E-18
Dy-167	1.12E-16	5.17E-17
Dy-168	7.07E-17	3.74E-17
Ho-150	3.82E-16	1.88E-16
Ho-153	1.62E-16	9.99E-17
Ho-153m	1.75E-16	1.02E-16
Ho-154	3.10E-16	1.87E-16
Ho-154m	3.34E-16	2.37E-16
Ho-155	8.61E-17	5.89E-17
Ho-156	3.03E-16	2.12E-16
Ho-157	7.24E-17	5.38E-17
Ho-159	4.58E-17	3.36E-17
Ho-160	2.06E-16	1.66E-16
Ho-161	5.67E-18	3.06E-18
Ho-162	2.03E-17	1.43E-17
Ho-162m	6.80E-17	5.40E-17
Ho-163	0.00E+00	0.00E+00
Ho-164	1.04E-17	1.76E-18
Ho-164m	4.48E-18	2.44E-18
Ho-166	4.93E-17	3.34E-18
Ho-166m	2.00E-16	1.59E-16
Ho-167	5.50E-17	3.48E-17
Ho-168	1.60E-16	8.74E-17
Ho-168m	6.29E-19	3.46E-19
Ho-170	2.59E-16	1.69E-16
Er-154	8.69E-18	5.00E-18
Er-156	6.71E-18	3.89E-18
Er-159	1.20E-16	9.47E-17
Er-161	1.21E-16	9.70E-17
Er-163	4.05E-18	2.26E-18
Er-165	3.78E-18	2.08E-18
Er-167m	1.61E-17	8.83E-18
Er-169	2.95E-18	3.24E-20
Er-171	6.75E-17	3.50E-17
Er-172	6.62E-17	4.88E-17
Er-173	1.45E-16	8.08E-17

Tm-161	1.68E-16	1.28E-16
Tm-162	2.75E-16	1.98E-16
Tm-163	1.62E-16	1.31E-16
Tm-164	1.37E-16	7.70E-17
Tm-165	6.85E-17	5.23E-17
Tm-166	2.45E-16	2.02E-16
Tm-167	2.15E-17	1.21E-17
Tm-168	1.51E-16	1.20E-16
Tm-170	1.93E-17	5.14E-19
Tm-171	6.70E-20	3.89E-20
Tm-172	9.12E-17	4.92E-17
Tm-173	6.48E-17	3.74E-17
Tm-174	2.43E-16	1.75E-16
Tm-175	1.64E-16	1.07E-16
Tm-176	3.09E-16	2.03E-16
Yb-162	2.98E-17	2.21E-17
Yb-163	1.06E-16	7.13E-17
Yb-164	5.77E-18	3.64E-18
Yb-165	4.28E-17	3.01E-17
Yb-166	9.05E-18	5.42E-18
Yb-167	3.09E-17	2.14E-17
Yb-169	3.92E-17	2.65E-17
Yb-175	9.77E-18	3.73E-18
Yb-177	5.07E-17	1.95E-17
Yb-178	1.40E-17	3.74E-18
Yb-179	1.65E-16	9.52E-17
Lu-165	1.57E-16	1.09E-16
Lu-167	2.13E-16	1.72E-16
Lu-169	1.61E-16	1.32E-16
Lu-169m	3.48E-21	5.83E-23
Lu-170	3.20E-16	2.71E-16
Lu-171	7.73E-17	6.09E-17
Lu-171m	4.09E-20	2.24E-20
Lu-172	2.39E-16	1.94E-16
Lu-172m	1.31E-21	9.04E-23
Lu-173	2.08E-17	1.44E-17
Lu-174	1.33E-17	9.84E-18
Lu-174m	6.49E-18	4.04E-18
Lu-176	6.90E-17	4.52E-17
Lu-176m	2.98E-17	1.41E-18
Lu-177	9.73E-18	3.25E-18
Lu-177m	1.25E-16	9.29E-17
Lu-178	6.64E-17	1.34E-17
Lu-178m	1.51E-16	9.89E-17
Lu-179	3.54E-17	3.23E-18
Lu-180	2.25E-16	1.53E-16
Lu-181	1.23E-16	5.57E-17

Hf-167	1.10E-16	5.91E-17
Hf-169	8.50E-17	6.05E-17
Hf-170	5.24E-17	4.01E-17
Hf-172	1.12E-17	7.02E-18
Hf-173	4.76E-17	3.57E-17
Hf-174	0.00E+00	0.00E+00
Hf-175	4.36E-17	3.22E-17
Hf-177m	2.92E-16	2.15E-16
Hf-178m	2.76E-16	2.13E-16
Hf-179m	1.14E-16	8.59E-17
Hf-180m	1.22E-16	9.33E-17
Hf-181	7.04E-17	5.05E-17
Hf-182	3.02E-17	2.27E-17
Hf-182m	1.18E-16	8.69E-17
Hf-183	1.22E-16	7.58E-17
Hf-184	4.73E-17	2.15E-17
Ta-170	2.47E-16	1.05E-16
Ta-172	2.42E-16	1.69E-16
Ta-173	7.65E-17	5.58E-17
Ta-174	1.47E-16	9.68E-17
Ta-175	1.37E-16	1.11E-16
Ta-176	2.78E-16	2.32E-16
Ta-177	7.54E-18	4.90E-18
Ta-178	1.44E-17	1.04E-17
Ta-178m	1.42E-16	1.08E-16
Ta-179	2.59E-18	1.59E-18
Ta-180	6.71E-18	3.22E-18
Ta-182	1.63E-16	1.30E-16
Ta-182m	3.78E-17	2.31E-17
Ta-183	4.61E-17	2.63E-17
Ta-184	2.19E-16	1.54E-16
Ta-185	6.32E-17	1.43E-17
Ta-186	2.46E-16	1.39E-16
W-177	1.11E-16	8.70E-17
W-178	1.59E-18	9.89E-19
W-179	5.54E-18	3.32E-18
W-179m	1.27E-17	4.39E-18
W-181	4.21E-18	2.63E-18
W-185	4.77E-18	5.67E-20
W-185m	5.23E-18	2.05E-18
W-187	7.02E-17	4.33E-17
W-188	3.18E-18	2.08E-19
W-190	3.82E-17	1.26E-17
Re-178	2.52E-16	1.77E-16
Re-179	1.34E-16	1.07E-16
Re-180	1.53E-16	1.18E-16
Re-181	1.02E-16	7.66E-17

Re-182	2.21E-16	1.76E-16
Re-182m	1.50E-16	1.22E-16
Re-183	1.84E-17	1.24E-17
Re-184	1.08E-16	8.68E-17
Re-184m	4.65E-17	3.58E-17
Re-186	2.22E-17	1.99E-18
Re-186m	1.67E-18	9.72E-19
Re-187	0.00E+00	0.00E+00
Re-188	6.10E-17	6.60E-18
Re-188m	7.83E-18	5.12E-18
Re-189	2.52E-17	5.40E-18
Re-190	2.08E-16	1.31E-16
Re-190m	1.38E-16	8.96E-17
Os-180	1.45E-17	1.03E-17
Os-181	1.70E-16	1.37E-16
Os-182	5.25E-17	3.98E-17
Os-183	7.58E-17	5.83E-17
Os-183m	1.23E-16	1.00E-16
Os-185	8.36E-17	6.65E-17
Os-186	0.00E+00	0.00E+00
Os-189m	1.40E-20	2.38E-22
Os-190m	1.96E-16	1.53E-16
Os-191	9.97E-18	6.62E-18
Os-191m	6.63E-19	4.15E-19
Os-193	2.97E-17	6.41E-18
Os-194	2.67E-19	1.18E-19
Os-196	3.23E-17	7.73E-18
Ir-180	2.83E-16	1.56E-16
Ir-182	2.46E-16	1.39E-16
Ir-183	1.52E-16	1.19E-16
Ir-184	2.58E-16	1.96E-16
Ir-185	1.07E-16	8.59E-17
Ir-186	2.09E-16	1.66E-16
Ir-186m	1.59E-16	1.26E-16
Ir-187	3.99E-17	3.07E-17
Ir-188	2.62E-16	2.19E-16
Ir-189	8.86E-18	5.99E-18
Ir-190	1.81E-16	1.42E-16
Ir-190m	1.46E-20	2.65E-22
Ir-190n	6.62E-18	4.12E-18
Ir-191m	8.89E-18	5.96E-18
Ir-192	1.10E-16	7.86E-17
Ir-192m	6.07E-20	5.92E-21
Ir-192n	4.88E-18	9.60E-20
Ir-193m	8.95E-20	2.32E-20
Ir-194	6.80E-17	9.74E-18
Ir-194m	2.87E-16	2.26E-16

Ir-195	2.66E-17	4.72E-18
Ir-195m	5.66E-17	3.56E-17
Ir-196	1.14E-16	2.42E-17
Ir-196m	3.18E-16	2.39E-16
Pt-184	8.87E-17	6.63E-17
Pt-186	8.29E-17	6.51E-17
Pt-187	7.90E-17	5.81E-17
Pt-188	2.52E-17	1.78E-17
Pt-189	5.92E-17	4.51E-17
Pt-190	0.00E+00	0.00E+00
Pt-191	3.56E-17	2.60E-17
Pt-193	3.37E-20	6.57E-22
Pt-193m	3.86E-18	8.04E-19
Pt-195m	1.06E-17	5.52E-18
Pt-197	1.27E-17	2.10E-18
Pt-197m	2.47E-17	7.05E-18
Pt-199	5.96E-17	1.97E-17
Pt-200	1.48E-17	5.09E-18
Pt-202	4.49E-17	6.05E-19
Au-186	2.61E-16	1.49E-16
Au-187	1.37E-16	1.08E-16
Au-190	3.12E-16	2.51E-16
Au-191	7.32E-17	5.58E-17
Au-192	2.46E-16	2.02E-16
Au-193	2.03E-17	1.42E-17
Au-193m	2.61E-17	1.83E-17
Au-194	1.29E-16	1.05E-16
Au-195	9.18E-18	6.10E-18
Au-195m	2.67E-17	1.87E-17
Au-196	5.81E-17	4.42E-17
Au-196m	3.64E-17	2.14E-17
Au-198	6.82E-17	3.90E-17
Au-198m	6.97E-17	4.87E-17
Au-199	1.50E-17	8.74E-18
Au-200	8.43E-17	2.84E-17
Au-200m	2.51E-16	1.92E-16
Au-201	3.09E-17	3.62E-18
Au-202	9.88E-17	1.85E-17
Hg-190	2.38E-17	1.72E-17
Hg-191m	1.87E-16	1.46E-16
Hg-192	3.29E-17	2.44E-17
Hg-193	1.03E-16	8.29E-17
Hg-193m	1.26E-16	1.01E-16
Hg-194	4.46E-20	1.04E-21
Hg-195	2.38E-17	1.81E-17
Hg-195m	2.63E-17	1.83E-17
Hg-197	8.06E-18	5.41E-18

Hg-197m	1.69E-17	8.28E-18
Hg-199m	3.96E-17	1.65E-17
Hg-203	3.14E-17	2.27E-17
Hg-205	3.65E-17	9.63E-19
Hg-206	4.07E-17	1.19E-17
Hg-207	3.86E-16	2.77E-16
Tl-190	2.74E-16	1.28E-16
Tl-190m	3.57E-16	2.41E-16
Tl-194	1.55E-16	8.87E-17
Tl-194m	3.22E-16	2.46E-16
Tl-195	1.53E-16	1.25E-16
Tl-196	2.43E-16	1.91E-16
Tl-197	5.68E-17	4.40E-17
Tl-198	2.50E-16	2.06E-16
Tl-198m	1.55E-16	1.17E-16
Tl-199	3.15E-17	2.27E-17
Tl-200	1.61E-16	1.30E-16
Tl-201	1.08E-17	7.32E-18
Tl-202	5.65E-17	4.36E-17
Tl-204	1.32E-17	2.44E-19
Tl-206	3.60E-17	4.75E-19
Tl-206m	3.05E-16	2.37E-16
Tl-207	3.28E-17	6.50E-19
Tl-208	4.65E-16	3.64E-16
Tl-209	3.11E-16	2.20E-16
Tl-210	4.30E-16	2.85E-16
Pb-194	1.35E-16	1.07E-16
Pb-195m	2.15E-16	1.61E-16
Pb-196	6.29E-17	4.60E-17
Pb-197	1.93E-16	1.55E-16
Pb-197m	1.53E-16	1.14E-16
Pb-198	5.52E-17	4.07E-17
Pb-199	1.30E-16	1.04E-16
Pb-200	2.67E-17	1.81E-17
Pb-201	9.39E-17	7.28E-17
Pb-201m	6.13E-17	3.54E-17
Pb-202	6.24E-20	1.12E-21
Pb-202m	2.49E-16	1.97E-16
Pb-203	3.95E-17	2.88E-17
Pb-204m	2.58E-16	2.05E-16
Pb-205	6.32E-20	1.14E-21
Pb-209	9.87E-18	1.12E-19
Pb-210	3.03E-19	1.09E-19
Pb-211	3.71E-17	6.68E-18
Pb-212	2.32E-17	1.34E-17
Pb-214	4.53E-17	2.41E-17
Bi-197	2.25E-16	1.70E-16

Bi-200	3.10E-16	2.39E-16
Bi-201	2.15E-16	1.76E-16
Bi-202	3.44E-16	2.74E-16
Bi-203	2.98E-16	2.44E-16
Bi-204	3.59E-16	2.92E-16
Bi-205	2.10E-16	1.73E-16
Bi-206	4.06E-16	3.28E-16
Bi-207	1.95E-16	1.53E-16
Bi-208	3.38E-16	2.93E-16
Bi-210	2.44E-17	2.98E-19
Bi-210m	3.39E-17	2.49E-17
Bi-211	6.25E-18	4.51E-18
Bi-212	4.72E-17	1.08E-17
Bi-212n	3.56E-17	4.61E-19
Bi-213	4.38E-17	1.26E-17
Bi-214	2.28E-16	1.54E-16
Bi-215	7.52E-17	2.52E-17
Bi-216	1.87E-16	7.31E-17
Po-203	2.08E-16	1.64E-16
Po-204	1.44E-16	1.12E-16
Po-205	1.96E-16	1.59E-16
Po-206	1.49E-16	1.16E-16
Po-207	1.58E-16	1.27E-16
Po-208	2.69E-21	2.04E-21
Po-209	7.82E-19	6.01E-19
Po-210	1.19E-21	9.65E-22
Po-211	1.00E-18	8.08E-19
Po-212	0.00E+00	0.00E+00
Po-212m	1.01E-17	8.65E-18
Po-213	4.63E-21	3.71E-21
Po-214	1.01E-20	8.23E-21
Po-215	2.17E-20	1.70E-20
Po-216	1.87E-21	1.52E-21
Po-218	2.62E-22	2.86E-24
At-204	3.12E-16	2.26E-16
At-205	1.56E-16	1.13E-16
At-206	3.24E-16	2.44E-16
At-207	2.53E-16	2.03E-16
At-208	3.78E-16	3.03E-16
At-209	2.80E-16	2.24E-16
At-210	3.67E-16	3.03E-16
At-211	4.11E-18	2.86E-18
At-215	2.25E-20	1.64E-20
At-216	3.10E-19	2.12E-19
At-217	3.28E-20	2.31E-20
At-218	7.94E-20	1.25E-21
At-219	0.00E+00	0.00E+00

At-220	1.42E-16	4.46E-17
Rn-207	1.34E-16	9.59E-17
Rn-209	1.53E-16	1.19E-16
Rn-210	7.62E-18	5.89E-18
Rn-211	2.31E-16	1.87E-16
Rn-212	4.13E-20	3.32E-20
Rn-215	0.00E+00	0.00E+00
Rn-216	0.00E+00	0.00E+00
Rn-217	0.00E+00	0.00E+00
Rn-218	9.26E-20	7.39E-20
Rn-219	7.41E-18	5.60E-18
Rn-220	7.70E-20	6.10E-20
Rn-222	4.77E-20	3.76E-20
Rn-223	7.86E-17	3.35E-17
Fr-212	1.45E-16	1.14E-16
Fr-219	4.48E-19	3.41E-19
Fr-220	1.26E-18	7.85E-19
Fr-221	3.86E-18	2.75E-18
Fr-222	6.51E-17	1.74E-17
Fr-223	2.79E-17	4.55E-18
Fr-224	1.27E-16	5.63E-17
Fr-227	1.06E-16	4.32E-17
Ra-219	2.34E-17	1.61E-17
Ra-220	5.76E-19	4.51E-19
Ra-221	5.23E-18	3.24E-18
Ra-222	1.16E-18	8.81E-19
Ra-223	1.85E-17	1.27E-17
Ra-224	1.36E-18	9.87E-19
Ra-225	3.69E-18	5.43E-19
Ra-226	1.02E-18	6.84E-19
Ra-227	4.29E-17	1.37E-17
Ra-228	1.22E-19	6.78E-21
Ra-230	1.88E-17	7.23E-18
Ac-223	2.25E-18	1.60E-18
Ac-224	2.76E-17	2.06E-17
Ac-225	1.84E-18	1.26E-18
Ac-226	3.13E-17	1.23E-17
Ac-227	3.66E-20	8.25E-21
Ac-228	1.30E-16	8.67E-17
Ac-230	1.31E-16	5.70E-17
Ac-231	8.92E-17	3.98E-17
Ac-232	2.10E-16	1.22E-16
Ac-233	1.18E-16	4.92E-17
Th-223	9.07E-18	6.18E-18
Th-224	3.19E-18	2.14E-18
Th-226	1.18E-18	7.08E-19
Th-227	1.62E-17	1.15E-17

Th-228	3.24E-19	1.84E-19
Th-229	1.12E-17	7.40E-18
Th-230	1.02E-19	3.42E-20
Th-231	3.73E-18	1.02E-18
Th-232	7.41E-20	1.80E-20
Th-233	2.93E-17	3.63E-18
Th-234	1.45E-18	7.22E-19
Th-235	5.25E-17	5.86E-18
Th-236	2.57E-17	3.44E-18
Pa-227	2.43E-18	1.61E-18
Pa-228	1.68E-16	1.35E-16
Pa-229	7.40E-18	5.22E-18
Pa-230	8.19E-17	6.50E-17
Pa-231	4.91E-18	3.18E-18
Pa-232	1.17E-16	9.25E-17
Pa-233	3.26E-17	2.03E-17
Pa-234	1.92E-16	1.45E-16
Pa-234m	5.94E-17	2.45E-18
Pa-235	3.10E-17	3.93E-19
Pa-236	1.66E-16	9.38E-17
Pa-237	1.12E-16	6.07E-17
U-227	1.67E-17	1.07E-17
U-228	6.00E-19	3.53E-19
U-230	2.29E-19	1.02E-19
U-231	9.05E-18	5.96E-18
U-232	1.18E-19	2.43E-20
U-233	7.45E-20	2.35E-20
U-234	9.48E-20	1.40E-20
U-235	2.00E-17	1.51E-17
U-235m	0.00E+00	0.00E+00
U-236	7.90E-20	8.69E-21
U-237	1.92E-17	1.17E-17
U-238	6.39E-20	7.32E-21
U-239	3.07E-17	4.41E-18
U-240	3.67E-18	4.30E-19
U-242	2.87E-17	4.03E-18
Np-232	1.47E-16	1.16E-16
Np-233	1.05E-17	7.52E-18
Np-234	1.38E-16	1.13E-16
Np-235	3.30E-19	6.43E-20
Np-236	2.06E-17	1.23E-17
Np-236m	9.11E-18	4.18E-18
Np-237	3.31E-18	1.93E-18
Np-238	8.33E-17	5.88E-17
Np-239	2.85E-17	1.62E-17
Np-240	1.49E-16	1.03E-16
Np-240m	8.33E-17	3.20E-17

Np-241	3.07E-17	3.67E-18
Np-242	9.66E-17	2.82E-17
Np-242m	1.51E-16	8.99E-17
Pu-232	7.20E-18	5.16E-18
Pu-234	7.81E-18	5.58E-18
Pu-235	1.08E-17	7.70E-18
Pu-236	1.03E-19	1.00E-20
Pu-237	5.77E-18	4.00E-18
Pu-238	9.22E-20	7.81E-21
Pu-239	4.63E-20	8.51E-21
Pu-240	8.74E-20	7.66E-21
Pu-241	2.07E-22	1.37E-22
Pu-242	8.71E-20	1.43E-20
Pu-243	1.01E-17	2.08E-18
Pu-244	3.46E-18	2.09E-18
Pu-245	6.56E-17	3.92E-17
Pu-246	1.75E-17	1.20E-17
Am-237	4.56E-17	3.41E-17
Am-238	1.10E-16	8.88E-17
Am-239	3.14E-17	2.07E-17
Am-240	1.26E-16	1.02E-16
Am-241	2.75E-18	1.54E-18
Am-242	9.71E-18	1.27E-18
Am-242m	2.85E-19	4.53E-20
Am-243	6.52E-18	4.34E-18
Am-244	1.05E-16	7.77E-17
Am-244m	3.53E-17	1.89E-18
Am-245	1.91E-17	3.03E-18
Am-246	1.20E-16	7.09E-17
Am-246m	1.50E-16	9.86E-17
Am-247	4.89E-17	1.25E-17
Cm-238	9.44E-18	6.80E-18
Cm-239	3.09E-17	2.32E-17
Cm-240	1.07E-19	1.06E-20
Cm-241	6.40E-17	4.63E-17
Cm-242	9.54E-20	9.09E-21
Cm-243	1.85E-17	1.17E-17
Cm-244	8.39E-20	9.22E-21
Cm-245	1.32E-17	8.90E-18
Cm-246	6.52E-19	3.87E-19
Cm-247	3.85E-17	3.01E-17
Cm-248	2.20E-16	1.39E-16
Cm-249	1.80E-17	2.04E-18
Cm-250	2.29E-15	1.41E-15
Cm-251	4.21E-17	1.10E-17
Bk-245	3.10E-17	2.05E-17
Bk-246	1.03E-16	8.30E-17

Bk-247	1.97E-17	1.32E-17
Bk-248m	1.63E-17	4.91E-18
Bk-249	3.73E-20	5.42E-22
Bk-250	1.25E-16	9.03E-17
Bk-251	2.81E-17	7.70E-18
Cf-244	1.02E-19	1.01E-20
Cf-246	7.73E-20	1.12E-20
Cf-247	1.16E-17	7.95E-18
Cf-248	1.37E-19	4.40E-20
Cf-249	4.01E-17	3.11E-17
Cf-250	1.63E-18	1.04E-18
Cf-251	1.91E-17	1.07E-17
Cf-252	7.50E-17	4.81E-17
Cf-253	1.64E-18	5.64E-20
Cf-254	2.85E-15	1.78E-15
Cf-255	1.14E-17	1.30E-19
Es-249	5.00E-17	3.86E-17
Es-250	1.49E-16	1.14E-16
Es-250m	6.76E-17	5.42E-17
Es-251	1.16E-17	7.96E-18
Es-253	7.31E-20	3.30E-20
Es-254	1.18E-18	3.33E-19
Es-254m	6.81E-17	4.61E-17
Es-255	1.74E-18	8.96E-20
Es-256	3.85E-17	5.29E-19
Fm-251	1.88E-17	1.40E-17
Fm-252	1.24E-19	3.78E-20
Fm-253	8.26E-18	5.15E-18
Fm-254	1.18E-18	7.50E-19
Fm-255	9.72E-19	2.16E-19
Fm-256	2.01E-15	1.31E-15
Fm-257	2.06E-17	1.32E-17

From: OST02 HOC
Sent: Saturday, March 26, 2011 2:06 PM
To: Costa, Arlon; PMT03 Hoc; Chowdhury, Prosanta
Cc: OST01 HOC
Subject: RE: PMT Coordinator

The 3-11 PM shift is already staffed. 11:00 PM – 7:00 AM 4/1-4/2 is available as well as 7:00 – 3:00, and 11:00 PM – 7:00 AM 4/2-4/3.

OST02
NRC Operations Center
301-816-5100

From: Costa, Arlon
Sent: Saturday, March 26, 2011 1:56 PM
To: PMT03 Hoc; Chowdhury, Prosanta
Cc: OST02 HOC; OST01 HOC
Subject: RE: PMT Coordinator

I signed in for the 3-11PM.

From: PMT03 Hoc
Sent: Saturday, March 26, 2011 1:22 AM
To: Costa, Arlon; Chowdhury, Prosanta
Cc: OST02 HOC; OST01 HOC
Subject: PMT Coordinator

Arlon, Prosanta,

We're almost complete on the PMT Coordinator roster for next week, but there are two slots needing filled next Saturday, April 2nd, if you're available. The slots are 7am-3pm and 3pm-11pm (and actually 11pm-7am Sunday which I will take if it remains unfilled). If each of you can fill one of these slots, that would be great. Please respond by copying OST01 and OST02, to be placed on the roster.

Hope to see you then.

Thanks.

Lou

BBBBB/ 183

Release

Lee, Richard

From: Lee, Richard
Sent: Sunday, March 27, 2011 10:47 PM
To: Dana Powers
Subject: RE: long term storage of wastage

Thx, Dana:
Richard

From: Dana Powers [danapowers@msn.com]
Sent: Sunday, March 27, 2011 7:28 PM
To: Lee, Richard
Subject: RE: long term storage of wastage

Richard, The Hanford tanks are mild steel tanks - even the double walled tanks. They can hold waste only by making the waste extremely basic ($\text{pH} > 10$). Just making the waste water basic may not be enough for the waste water from Fukushima. The waste water is heavily contaminated with chloride and will be aggressive toward mild steel. The Hanford waste did not have a lot of sodium chloride in it.

The problem tanks at Hanford were those that had precipitated solids. Water from the Fukushima reactors will come in hot and will precipitate sodium chloride. Over time iron hydroxide and carbonates of various types will precipitate from the waste water. Over the long term, weird and unwonderful things can happen in the liquids trapped between the precipitated solids and the tank walls - crevice corrosion. I would think that they would want to use tanks better suited for the long term storage of the waste water. Steels with a little copper in it might work better. Plastic coated interiors will work for a while, but eventually the radiation dose will embrittle the plastic and cause it to flake off. They may also want to make sure that they can stir up the waste every once in a while so that concentrations at interfaces get dissipated. The second most readily attacked area of the tanks is the interface with the atmosphere.

On another score. If they inject water sparged with nitrogen into the core, they will start getting nitric acid formation in the gas phase. The nitric acid will begin to acidify the water in the core. It is not clear to me that they have enough buffer solution to stand up to the acidification. They may want to make sure that sparged water is well borated with sodium tetraborate or similar material.

I would expect that if there is precipitated sodium chloride in the vessel bottom, that some fraction of the cesium will ion exchange with sodium in the precipitated sodium chloride. I don't know how much or whether it will significantly reduce the amount of cesium in solution. It should reduce it some. I would expect some ion exchange also with barium and strontium - again, I don't know how much, probably not a lot. Dana

From: Richard.Lee@nrc.gov
To: danapowers@msn.com; dapower@sandia.gov
Date: Sun, 27 Mar 2011 18:13:53 -0400
Subject: long term storage of wastage

Dana:

Form your experience with the Hanford Water tanks, is there lesson-learned what to do better from the start so one does not have to go through what DOE did (spending \$Bs and none got clean up).

Richard

Reborn

Lee, Richard

From: Lee, Richard
Sent: Sunday, March 27, 2011 10:55 PM
To: Dana Powers
Subject: RE: long term storage of wastage

Dear Dana:

Tomorrow, I will forward these messages to DOE Science Council w/- cc: to you at Sandia.

Richard

From: Dana Powers [danapowers@msn.com]
Sent: Sunday, March 27, 2011 7:28 PM
To: Lee, Richard
Subject: RE: long term storage of wastage

Richard, The Hanford tanks are mild steel tanks - even the double walled tanks. They can hold waste only by making the waste extremely basic ($\text{pH} > 10$). Just making the waste water basic may not be enough for the waste water from Fukushima. The waste water is heavily contaminated with chloride and will be aggressive toward mild steel. The Hanford waste did not have a lot of sodium chloride in it.

The problem tanks at Hanford were those that had precipitated solids. Water from the Fukushima reactors will come in hot and will precipitate sodium chloride. Over time iron hydroxide and carbonates of various types will precipitate from the waste water. Over the long term, weird and unwonderful things can happen in the liquids trapped between the precipitated solids and the tank walls - crevice corrosion. I would think that they would want to use tanks better suited for the long term storage of the waste water. Steels with a little copper in it might work better. Plastic coated interiors will work for a while, but eventually the radiation dose will embrittle the plastic and cause it to flake off. They may also want to make sure that they can stir up the waste every once in a while so that concentrations at interfaces get dissipated. The second most readily attacked area of the tanks is the interface with the atmosphere.

On another score. If they inject water sparged with nitrogen into the core, they will start getting nitric acid formation in the gas phase. The nitric acid will begin to acidify the water in the core. It is not clear to me that they have enough buffer solution to stand up to the acidification. They may want to make sure that sparged water is well borated with sodium tetraborate or similar material.

I would expect that if there is precipitated sodium chloride in the vessel bottom, that some fraction of the cesium will ion exchange with sodium in the precipitated sodium chloride. I don't know how much or whether it will significantly reduce the amount of cesium in solution. It should reduce it some. I would expect some ion exchange also with barium and strontium - again, I don't know how much, probably not a lot. Dana

From: Richard.Lee@nrc.gov
To: danapowers@msn.com; dapower@sandia.gov
Date: Sun, 27 Mar 2011 18:13:53 -0400
Subject: long term storage of wastage

Dana:

Form your experience with the Hanford Water tanks, is there lesson-learned what to do better from the start so one does not have to go through what DOE did (spending \$Bs and none got clean up).

Richard

From: OST01 HOC
Sent: Monday, March 28, 2011 2:47 PM
To: Giitter, Joseph
Cc: Evans, Michele; OST02 HOC; OST01 HOC
Subject: RE: Updated ET Response Advisor Schedule for Pay Period 8

Joe,

You have been added to the ERO Staffing Roster in the ET Response Advisor for Thursday, 7am to 3pm.

Tony McMurtray
EST Coordinator

From: Giitter, Joseph
Sent: Monday, March 28, 2011 2:33 PM
To: McDermott, Brian; Miller, Chris; McGinty, Tim; Morris, Scott; Blount, Tom; Thaggard, Mark; Ross-Lee, MaryJane
Cc: Evans, Michele; OST01 HOC
Subject: RE: Updated ET Response Advisor Schedule for Pay Period 8

I can cover the Thursday dayshift since Allen will be back off shift then.

From: McDermott, Brian
Sent: Monday, March 28, 2011 8:19 AM
To: Miller, Chris; McGinty, Tim; Giitter, Joseph; Morris, Scott; Blount, Tom; Thaggard, Mark; Ross-Lee, MaryJane
Cc: Evans, Michele; OST01 HOC
Subject: RE: Updated ET Response Advisor Schedule for Pay Period 8

Everyone - We still have three shifts to fill later in the week – 2 dayshifts and one swing shift. Please check to see if you can fill in. Please reply to the group and OST01.HOC if you are able to cover.

Regarding our plan to reduce staffing, the EDO and DEDOs are working to align on the approach. I am hopeful that we will be able to implement sometime this week.

Thanks,
Brian

From: OST01 HOC
Sent: Monday, March 28, 2011 5:29 AM
To: McDermott, Brian; Miller, Chris; McGinty, Tim; Giitter, Joseph; Morris, Scott; Blount, Tom; Thaggard, Mark
Subject: Updated ET Response Advisor Schedule for Pay Period 8

Hello,

Attached is the most recent schedule for the ET Response Advisor for pay period 8. There have been some changes. Please verify that this information is correct.

Thank you.

EST Coordinator

BBB/ 186

Operations Center
301-816-5100

Franovich, Mike

From: Franovich, Mike
Sent: Monday, March 28, 2011 12:06 PM
To: Franovich, Rani
Subject: FW: 50 Mile EPZ justification response

This may have been intended for you. The TAs received the info in a separate e-mail.

From: LIA08 Hoc
Sent: Monday, March 28, 2011 11:58 AM
To: Franovich, Mike; Blount, Tom
Subject: FW: 50 Mile EPZ justification response

For your info. Jeff Temple

From: LIA08 Hoc
Sent: Monday, March 28, 2011 11:56 AM
To: Franovich, Mike; Orders, William; Snodderly, Michael; Castleman, Patrick; Marshall, Michael; Batkin, Joshua; Hipschman, Thomas
Cc: LIA06 Hoc
Subject: FW: 50 Mile EPZ justification response

FILED
MAY 12

Attached for your info is an email sent by the Ops Center Liaison Team to Mr. Takashi regarding questions he raised about the 50 mile evacuation recommendation we made for US Citizens in Japan. Please let me know if you have any questions or would like additional information about this.

Jeff Temple
Response Program Manager
Liaison Team/Interagency Response Team/Corporate Support Response Team
301-816-5185

From: LIA03 Hoc
Sent: Monday, March 28, 2011 11:07 AM
To: takashi.inutsuka@mofa.go.jp
Cc: Doane, Margaret; Mamish, Nader; LIA02 Hoc; LIA08 Hoc; Borchardt, Bill; LIA03 Hoc
Subject: 50 Mile EPZ justification response

On behalf of Bill Borchardt, we are responding to your questions:

1. In the NRC NEWS, March 16, 2011, there are attachments of the results of two sets of computer calculations. One, 15 March 2010 02:51am (EDT), has a hypothetical, single-reactor site, 2350 MWt, Boiling Water Reactor. On the other hand, 16 March 2010 12:24pm (EDT), has a hypothetical, four-reactor site. But in these attachments there is no detailed assumption for calculations about
(1) the power and type of reactor for the four-reactor site,
(2) weather, wind direction and speed, and the status of the problem at the reactors (for example: Source Term).

Q1: Are these sentences correct?

A1: These sentences are correct. Although the press release identified one of the computer calculations being based on a hypothetical four-reactor site, the source term used in

F-88-512

the calculation was the approximate activity available for release from one reactor and two spent fuel pools.

Q2: Have you ever explained these detailed assumptions to the public?

A2: The assumptions have been generally described in press releases, interviews, and congressional testimony.

Q3: Could you explain the relation between the number of Total EDE and 1rem (PAGs)? For example 8.1rem (15 March calculation) and 9.9rem (16 March calculation), 50 mi, and 1rem? Could you also explain the relation between the number of Thyroid CDE and 5rem (PAGs)? For example 23rem (15 March calculation) and 48rem (16 March calculation), 50 mi, and 5rem? Is there no need to calculate this for distances greater than 50 mi?

A3: As stated in the press release, these two computer calculations are hypothetical, rough estimates that would not necessarily characterize an actual release. Although the calculation references have TEDE and CDE doses exceeding PAGs beyond 50 miles, these were only two of several cases run. Given that other cases projected PAG doses less than 50 miles and there would be time to extend our recommendations beyond 50 miles, if necessary, the 50 mile recommendation was considered appropriate to protect US citizens.

2. At the White House Regular Briefing, March 17, 2011, Chairman Jaczko said, "We have a team of 11, some of our best technical experts in Tokyo, and they are working with counterparts from the utility in Tokyo as well as other individuals with the government. So that is one of the sources. We are collecting data from as many places as we can to make the best judgments we can with the information available. But I would stress that this is a very difficult situation. There is often conflicting information. And so we made what we thought was a prudent decision."

Q4: Does this statement accurately reflect the NRC's decisionmaking process that led to the recommendation (50 miles)?

A4: Yes.

Q5: Did NRC have evidence to suggest that radiation levels around Fukushima were higher than what Japanese officials had said?

A5: No. The NRC had very limited radiation level information at this time. The computer calculations and subsequent protective action decisions were based on conservative assumptions based on limited information and the deteriorating state of several reactors and spent fuel pools.

3. At the meeting of NRC, March 21, 2011, you said, "the situation that led to the 50 mile guidance in Japan was based upon what we understood and still believe had existed that there were degraded conditions in two spent-fuel pools at the site and, in all likelihood, some core damage in three of the reactor units. Based on the situation as we understood it at that time, we thought it was prudent to provide the recommendation to the ambassador to evacuate out to 50 miles in Japan."

Q6: Does this statement accurately reflect the NRC's decisionmaking process that led to the recommendation (50 miles)?

A6: Yes.

Q7: There are some differences on the basis for making recommendation between 1. and 3. Could you explain the basis for making the recommendation (50 miles) again?

A7: The comments made by NRC Chairman Jaczko and Mr. Borchardt were consistent in that seriously degrading conditions at several Daiichi units supported a need to take pre-emptive protective action. The computer calculations helped to provide perspective on possible impacts.

Q8: I understand the recommendation is prudent. How do you define "prudent" in the assumptions for your calculations? in the decision about the distance?

A8: Since communications were limited and there was a large degree of uncertainty about plant conditions at the time, it was difficult to accurately assess the radiological hazard. Computer models used meteorological model data appropriate for the Fukushima Daiichi vicinity. Source terms were based on hypothetical, but not unreasonable estimates of fuel damage, containment, and other release conditions. Subsequent modeling can be correlated with the ground deposition as observed in flyover and other monitoring data. Therefore, prudent (reasonable conservative protective actions made with a predictive approach to limit radiation exposure to US citizens) can be substantiated based on the conditions present and the information known at the time.

If you have additional questions please contact Mr. Borchardt at the email address above.

From: OST01 HOC
Sent: Monday, March 28, 2011 7:23 PM
To: Miller, Chris
Cc: McDermott, Brian
Subject: RE: Updated ET Response Advisor Schedule for Pay Period 8

Thanks Chris. You are on the schedule for April 9 from 7am-3pm.

Rebecca Stone
EST Coordinator

From: McDermott, Brian
Sent: Monday, March 28, 2011 7:21 PM
To: OST01 HOC
Subject: FW: Updated ET Response Advisor Schedule for Pay Period 8

From: Miller, Chris
Sent: Monday, March 28, 2011 8:30 AM
To: McDermott, Brian
Subject: Re: Updated ET Response Advisor Schedule for Pay Period 8

I could pick up day shift on 4-9.

From: McDermott, Brian
To: Miller, Chris; McGinty, Tim; Glitter, Joseph; Morris, Scott; Blount, Tom; Thaggard, Mark; Ross-Lee, MaryJane
Cc: Evans, Michele; OST01 HOC
Sent: Mon Mar 28 08:18:37 2011
Subject: RE: Updated ET Response Advisor Schedule for Pay Period 8

Everyone - We still have three shifts to fill later in the week - 2 dayshifts and one swing shift. Please check to see if you can fill in. Please reply to the group and OST01.HOC if you are able to cover.

Regarding our plan to reduce staffing, the EDO and DEDOs are working to align on the approach. I am hopeful that we will be able to implement sometime this week.

Thanks,
Brian

From: OST01 HOC
Sent: Monday, March 28, 2011 5:29 AM
To: McDermott, Brian; Miller, Chris; McGinty, Tim; Glitter, Joseph; Morris, Scott; Blount, Tom; Thaggard, Mark
Subject: Updated ET Response Advisor Schedule for Pay Period 8

Hello,

Attached is the most recent schedule for the ET Response Advisor for pay period 8. There have been some changes. Please verify that this information is correct.

BBBB/ 188

Thank you.

EST Coordinator
Operations Center
301-816-5100

From: PMT03 Hoc
Sent: Monday, March 28, 2011 7:55 PM
To: Hoc, PMT12
Subject: US Nuclear Plant Reported Measurements 03282011.xlsx
Attachments: US Nuclear Plant Reported Measurements 03282011.xlsx

OFFICIAL USE ONLY

Date	Plant	Isotope	Concentration
3/18/2011	San Onofre	I-131	1.4E-13 uCi/cc
3/18/2011	Diablo Canyon	I-131	3.8 to 6E-13 uCi/cc
3/19/2011	San Onofre	I-131	6.5E-13 to 7.0E-13 uCi/cc
3/19/2011	Palo Verde	Cs-134	2.22E-13 uCi/cc
3/19/2011	Palo Verde	Cs-137	3.58E-13 uCi/cc
3/19/2011	Palo Verde	I-131	1.54E-12 uCi/cc
3/20/2011	San Onofre	I-131	2.0E-12 uCi/cc
3/20/2011	Palo Verde	Cs-134	3.87E-13 uCi/cc
3/20/2011	Palo Verde	I-131	2.50E-12 uCi/cc
3/21/2011	Nine Mile Point	I-131	19.1 pCi/L (rainwater)
3/21/2011	Palo Verde	I-131	6.70E-13 uCi/cc
3/21/2011	Palo Verde	Cs-134	2.06E-13 uCi/cc,
3/21/2011	Palo Verde	Cs-137	2.71E-13 uCi/cc
3/22/2011	San Onofre	I-131	7.0 to 8.0E-13 uCi/cc
3/22/2011	San Onofre	Cs-137	1.25E-13 uCi/cc
3/22/2011	Columbia	I-131	6.74E-13 uCi/cc
3/22/2011	Nine Mile Point	I-131	18 pCi/L (rainwater)
3/22/2011	Ginna	I-131	26.8 pCi/L (rainwater)
3/22/2011	Palo Verde	I-131	2.01E-12 uCi/cc
3/22/2011	Palo Verde	Cs-137	2.93E-13 uCi/cc
3/22/2011	Palo Verde	Cs-134	2.76E-13 uCi/cc
3/23/2011	Millstone	I-131	25.6 pCi/L (rainwater)
3/23/2011	San Onofre	I-131	5E-13 to 6E-13 uCi/cc
3/23/2011	San Onofre	Cs-137	7E-14 uCi/cc
3/23/2011	Palo Verde	I-131	7.42E-13 uCi/cc
3/23/2011	TMI	I-131	95 pCi/L (rainwater)
3/24/2011	Palo Verde	I-131	6.30E-13 uCi/cc
3/24/2011	Oyster Creek	I-131	127 pCi/L (rainwater)
3/24/2011	San Onofre	I-131	3.0E-13 to 6.0E-13 uCi/cc
3/24/2011	Limerick	I-131	47 pCi/L (rainwater)
3/25/2011	South Texas	I-131	2.6E-13 uCi/cc
3/25/2011	San Onofre	I-131	9.0E-13 to 1E-12 uCi/cc
3/25/2011	San Onofre	Cs-137	1E-13 to 3E-13 uCi/cc
3/25/2011	Palo Verde	I-131	1.25E-12 uCi/cc
3/25/2011	Palo Verde	Cs-134	3.50E-13 uCi/cc
3/25/2011	Palo Verde	Cs-137	2.62E-13 uCi/cc
3/26/2011	Palo Verde	I-131	5.561E-13 uCi/cc
3/27/2011	Palo Verde	I-131	2.2181E-13 uCi/cc
3/27/2011	San Onofre	I-131	2E-13 to 3E-13 uCi/cc
3/28/2011	Beaver Valley	I-131	14.98 pCi/L (standing water)
3/28/2011	San Onofre	I-131	2.0 to 3E-13 uCi/cc

I-131 Reporting Levels
NUREG-1301 and NUREG-1302

	I-131	Units	I-131	Units
Drinking Water	2	pCi/L	2.00E-09	uCi/ml
Non-Drinking Water	20	pCi/L	2.00E-08	uCi/ml
Air	0.9	pCi/m3	9.00E-13	uCi/cc

from 2E-13 to 3E-13 microcuries/cc

~~OFFICIAL USE ONLY~~

From: LIA07 Hoc
Sent: Tuesday, March 29, 2011 6:35 PM
To: Borchardt, Bill; Bradford, Anna; Cohen, Shari; Collins, Elmo; Cooper, LaToya; Dyer, Jim; ET07 Hoc; Flory, Shirley; Gibbs, Catina; Haney, Catherine; Hudson, Sharon; Jaczko, Gregory; Johnson, Michael; Leeds, Eric; Loyd, Susan; Pace, Patti; Schwarz, Sherry; Sheron, Brian; Speiser, Herald; Sprogeris, Patricia; Taylor, Renee; Virgilio, Martin; Walker, Dwight; Walls, Lorena; Weber, Michael
Subject: Go Book Update - 1800 EDT, March 29, 2011
Attachments: TEPCO Press Release 211.pdf; TEPCO Press Release 208.pdf; TEPCO Press Release 209.pdf; TEPCO Press Release 210.pdf; ET Chronology 3-29-11 1500.pdf; March 29 1500 EDT one pager .docx; USNRC Earthquake-Tsunami Update.032911.1800EDT.pdf

Attached, please find updated information for the "Go Books".

The updates include:

- The 1800 EDT, 03/29/11 Status Update
- The latest ET Chronology
- The latest "One Pager" (1500 EDT, 03/29/11)
- TEPCO Press Releases (208-211)

Please let me know if you have any questions or concerns.

-Sara

Sara Mroz
Communications and Outreach
Office of Nuclear Security & Incident Response
US Nuclear Regulatory Commission
Sara.Mroz@nrc.gov
LIA07.HOC@nrc.gov (Operations Center)



Press Releases

Press Release (Mar 29,2011)

Status of TEPCO's Facilities and its services after the Tohoku-Taiheiyou-Oki Earthquake (as of 4:00PM)

Due to the Tohoku-Taiheiyou-Oki Earthquake which occurred on March 11th 2011, TEPCO's facilities including our nuclear power stations have been severely damaged. We deeply apologize for the anxiety and inconvenience caused.

Below is the status of TEPCO's major facilities.

*new items are underlined

[Nuclear Power Station]

Fukushima Daiichi Nuclear Power Station:

Units 1 to 3: shutdown due to the earthquake

(Units 4 to 6: outage due to regular inspections)

*The national government has instructed the public to evacuate for those local residents within 20km radius of the site periphery and to evacuate voluntarily for those local residents between 20km and 30km radius of the site periphery.

*Off-site power was connected to Unit 1 to 6.

***Unit 1**

- The explosive sound and white smoke was confirmed near Unit 1 when the big quake occurred at 3:36pm, March 12th.
- We started injection of sea water at 8:20 pm, March 12th, and then boric acid which absorbs neutron into the reactor afterwards.
- At approximately 2:30 am, March 23rd, we started the injection of sea water into the reactor from feed water system. After that, the injection of freshwater was started from 3:37 pm on March 25th (switched from the seawater injection). At 8:32 am, Mar 29th, transfer from the fire fighting pump to a temporary motor driven pump was made.
- At approximately 10:50 am on March 24th, white smoke was confirmed arising from the top of the reactor building.
- At approximately 11:30 am, March 24th, lights in the main control room were restored.

***Unit2**

- At 1:25 pm, March 14th, since the Reactor Core Isolation Cooling System has failed, it was determined that a specific incident stipulated in Clause 1, Article 15 of Act on Special Measures Concerning Nuclear Emergency Preparedness occurred (failure of reactor cooling function). At 5:17 pm, March 14th, while the water level in the reactor reached the top of the fuel rod, we have restarted the water injection with the valve operation.
- At approximately 6:14 am, March 15th, the abnormal sound was confirmed near the suppression chamber and the pressure inside the chamber decreased afterwards. It was determined that there is a possibility that something happened in the suppression chamber. While sea water injection to the reactor continued, TEPCO employees and workers from other companies not in charge of injection work started tentative evacuation to a safe location.
- Sea water injection to the reactor continued.
- On March 18th, power was delivered up to substation for backup power through offsite transmission line. We completed laying cable further to unit receiving facility in the building, and at 3:46 pm, March 20th the load-side power panel of the receiving facility started to be energized.
- From 3:05 pm to 5:20 pm on March 20th, about 40 tons of seawater was injected into Unit 2 by TEPCO employees.
- At approximately 6:20 pm on March 21st, white smoke was confirmed arising from the top of the reactor building. As of 7:11 am on March 22nd, smoke decreased to the level where we could hardly confirm.
- From around 4 pm to 5 pm on March 22nd, approximately 18 tons of sea water was injected into the spent fuel pool by TEPCO employees.
- From 10:30 am on March 25th, seawater injection through Fuel Pool Cooling

- and Filtering System was initiated. The work finished at 0:19 pm on March 25th.
- From 10:10 am on March 26th, freshwater (with boric acid) injection was initiated. (switched from the seawater injection) At 06:31pm, Mar 27th, transfer from the fire fighting pump to a temporary motor driven pump was made.
- At approximately 4:46 pm, March 26th, lights in the main control room were restored.
- *Unit 3
- At 6:50 am, March 14th, while water injection to the reactor was under operation (injection of boric acid was done on Mar 13th), the pressure in the reactor containment vessel increased to 530 kPa. As a result, at 7:44 am, it was determined that a specific incident stipulated in article 15, clause 1 occurred (abnormal increase of the pressure of reactor containment vessel). Afterwards, the pressure gradually decreased (as of 9:05 am, 490 kPa).
- At approximately 11:01 am, March 14th, an explosion followed by white smoke occurred near Unit 3. 4 TEPCO employees and 3 workers from other companies (all of them were conscious) sustained injuries and were taken to the hospital by ambulances.
- As the temperature of water in the spent fuel pool rose, spraying water by helicopters with the support of the Self Defense Force was considered. However the operation on March 16th was cancelled.
- At 6:15 am, March 17th, the pressure of the Suppression Chamber temporarily increased, but currently it is stable within a certain range. On March 20th, we were preparing to implement measures to reduce the pressure of the reactor containment vessel (partial discharge of air containing radioactive material to outside) in order to fully secure safety. However, at present, it is not a situation to immediately implement measures and discharge air containing radioactive material to outside. We will continue to monitor the status of the pressure of the reactor containment vessel.
- In order to cool spent fuel pool, water was sprayed by helicopters on March 17th with the cooperation of Self-Defense Forces.
- At approximately past 7:00 pm, March 17th, Self-Defense Forces and the police started spraying water by water cannon trucks upon our request for the cooperation. At 8:09 pm, March 17th, they finished the operation.
- At 2:00 pm, March 18th, spraying water by fire engines was started with the cooperation of Self-Defense Forces and the United States Armed Forces. At 2:45 pm, March 18th, the operation was finished.
- At approximately 12:30 am, March 19th, spraying water was started with the cooperation of Fire Rescue Task Forces of Tokyo Fire Department. At approximately 1:10 am, March 19th, the operation was finished. They resumed spraying water at 2:10 pm and finished at approximately 3:40 am, March 20th.
- At approximately 9:30 pm, March 20th, spraying water was started with the cooperation of Fire Rescue Task Forces of Tokyo Fire Department. At approximately 3:58 am, March 21th, they the operation was finished.
- At approximately 3:55 pm, March 21st, light gray smoke was confirmed arising from the southeast side of the 5th floor roof of the Unit 3 building. The situation was reported to the fire department at approximately 4:21 pm. The parameters of reactor pressure vessel, reactor containment vessel, and monitored environmental data remained stable without significant change. However, employees working around Unit 3 evacuated to a safe location. On March 22nd, the color of smoke changed to somewhat white and it is slowly dissipating.
- At approximately 3:10 pm on March 22nd, spraying water to Unit 3 by Tokyo Fire Department's Hyper Rescue and Osaka City Fire Department was conducted, and completed at approximately 4:00 PM on the same day.
- At approximately 10:45 pm on March 22nd, lights in the main control room were restored.
- At 11:00 am on March 23rd, the injection of sea water to spent fuel pool was conducted, and finished approximately at 1:20 pm on the same day.
- At 4:20 pm on March 23rd, light gray smoke was observed belching from Unit 3 building. The situation was reported to the fire department at 4:25 pm on March 23rd. The parameters of the reactor, the reactor containment vessel of Unit 3, and monitored figures around the site's immediate surroundings remained stable without significant change. To be safe, workers in the main control room of Unit 3 and around Unit 3 evacuated to a safe location. At approximately 11:30 pm on March 23rd and 4:50 am on March 24th, TEPCO employees confirmed the smoke has disappeared. Accordingly, workers evacuation was lifted.
- From approximately 5:35 am on March 24th, sea water injection through Fuel Pool Cooling and Filtering System was initiated, and finished at approximately 4:05 pm on the same day.
- From 1:28 pm on March 25th, Hyper Rescue team started water spray. The work finished at 4:00 pm on March 25th.
- From 6:02 pm on March 25th, the injection of freshwater to the reactor was started (switched from the seawater injection). At 8:30 pm on March 28th, the injection of fresh water is switched to temporary electricity pumps from the fire engine pumps.
- At approximately 12:34pm March 27th, the injection of water by the concrete pump truck was started. At approximately 2:36 pm, March 27th, the operation was finished.
- At approximately 2:17pm March 29th, the injection of fresh water by the concrete pump truck was started. (Sea water had been injected so far and

transfer from seawater to freshwater was made)

* Unit 4

- At approximately 6:00 am, March 15th, an explosive sound was heard and the damage in the 5th floor roof of Unit 4 reactor building was confirmed. At 9:38 am, the fire near the north-west part of 4th floor of Unit 4 reactor building was confirmed. At approximately 11:00 am, TEPCO employees confirmed that the fire was out.
- At approximately 5:45 am on March 16th, a TEPCO employee discovered a fire at the northwest corner of the Nuclear Reactor Building. TEPCO immediately reported this incident to the fire department and the local government and proceeded with the extinction of fire. At approximately 6:15 am, TEPCO staff confirmed at the site that there are no signs of fire.
- At approximately 8:21 am on March 20th, spraying water by fire engines was started with the cooperation of Self-Defense Forces and they finished the operation at approximately 9:40 am. At approximately 6:45 pm spraying water was started by Self-Defenses' water cannon trucks and finished at approximately 7:45 pm.
- At approximately 6:30 am, March 21st, spraying water by fire engines was started with the cooperation of Self-Defense Forces and the United States Armed Forces. At approximately 8:40 am, March 21, they had finished the operation.
- On March 21st, cabling has been completed from temporary substation to the main power center.
- From approximately 5:20 pm on March 22nd, spraying water from the concrete pumping vehicle was conducted and ended at approximately 8:30 pm on the same day.
- From approximately 10:00 am on March 23rd, spraying water from the concrete pumping vehicle was conducted and ended at approximately 1:00 pm on the same day.
- From approximately 2:35 pm on March 24th, spraying water by the concrete pumping vehicle was conducted and ended at approximately 5:30 pm on the same day.
- From 6:05 am on March 25th, seawater injection through Fuel Pool Cooling and Filtering System was initiated and finished at approximately 10:20 am on the same day.
- From 7:05 pm on March 25th, water spray by the concrete pumping vehicle was started and finished at 10:07 pm on March 25th.
- From 4:55 pm on March 27th, water spray by the concrete pumping vehicle was started and finished at 7:25 pm on March 27th.
- At approximately 11:50 am on March 29th, lights in the main control room were restored.

*Unit 5 and 6

- At 5 am on March 19th, we started the Residual Heat Removal System Pump (C) of Unit 5 in order to cool the spent fuel pool. At 10:14 pm, we started the Residual Heat Removal System Pump (B) of Unit 6 in order to cool the spent fuel pool.
- Unit 5 has been in reactor cold shutdown since 2:30 pm on March 20th.
- Unit 6 has been in reactor cold shutdown since 7:27 pm on March 20th.
- At Units 5 and 6, in order to prevent hydrogen gas from accumulating within the buildings, we have made three holes on the roof of the reactor building for each unit.
- At approximately 5:24 pm on March 23rd, the temporary Residual Heat Removal System Seawater Pump automatically stopped when its power source was switched. We restarted the pump at around 4:14 pm, March 24th, and resumed cooling of reactor at around 4:35 pm.

*On March 18th, regarding the spent fuel in the common spent fuel pool, we have confirmed that the water level of the pool is secured. At around 10:37 am March 21st, water spraying to common spent fuel pool and finished at 3:30 pm. At around 6:05 pm, fuel pool cooling pump was started to cool the pool.

*common spent fuel pool: a spent fuel pool for common use set in a separate building in a plant site in order to preserve spent fuel which are transferred from the spent fuel pool in each Unit building.

*On March 17th, we patrolled buildings for dry casks and found no signs of abnormal situation for the casks by visual observation. A detailed inspection is under preparation.

*dry cask: a measure to store spent fuel in a dry storage casks in storages. Fukushima Daiichi Nuclear Power Station started to utilize the measure from August 1995.

* In total 13 fire engines are lent for spraying water to the spent fuel pools and water injection to the nuclear reactors by various regional fire departments* as well as Tokyo Fire Department. Also, instruction regarding the setting and operation of large scale decontamination system was provided.

* On March 21st, 23rd to 28th, we detected technetium, cobalt, iodine, cesium, tellurium, barium, lanthanum and molybdenum from the seawater around discharge canal of Unit 1, 2, 3 and 4.

* On March 20th, 21st, 23rd to 28th, we detected iodine, cesium, tellurium and ruthenium in the air collected at the site of Fukushima Daiichi

Nuclear Power Station.

* Plutonium has detected from the sample of soil at the site of Fukushima Daiichi Nuclear Power Station collected on 21st and 22nd of March, . Concentration level of Plutonium detected was same as that of under usual environment and it is thought not to be harmful to human health. We will strengthen environmental monitoring of power station and surrounding environment.

* On March 28th, we detected radioactive materials contained in the puddles found in the turbine building of Unit 1 to 4.

* At approximately 3:30 pm, March 27th, we found water pooling in the vertical shaft of the trench outside of the turbine buildings for Units 1 to 3. The radiation dose at the surface of the water amounted 0.4 mSv/h in Unit 1 and over 1,000 mSv/h in Unit 2. We could not confirm the amount of the radiation dose in Unit 3. We will keep observing the condition of the water in the vertical shaft.

* At 12:03 pm, March 29th, when taking off the flange of the pipe to remove the residual heat in the seawater system, 3 workers from other companies received water in the pipe. Mopping up water, we confirmed no radioactive material had adhered to their bodies.

*We will continuously endeavor to securing safety, and monitoring of the surrounding environment.

Fukushima Daiichi Nuclear Power Station:

Units 1 to 4: shutdown due to the earthquake

* The national government has instructed evacuation for those local residents within 10km radius of the periphery.

* In order to achieve cold shutdown, reactor cooling function was restored and cooling of reactors was conducted. As a result, all reactors achieved cold shutdown: Unit 1 at 5:00 pm, March 14th, Unit 2 at 6:00 pm, March 14th, Unit 3 at 0:15 pm, March 12th, Unit 4 at 7:15 am, March 16th.

*Since March 12th, we had been preparing measures for reducing the pressure of reactor containment vessels (partial discharge of air containing radioactive materials to outside), but on March 17th, we stopped such preparation in all Units.

*** (Unit 1)**

As it is confirmed that the temperature of the Emergency Equipment Cooling Water System^{*1} has increased, at 3:20 pm, March 15th, we stopped the Residual Heat Removal System (B) for the inspection. Subsequently, failure was detected in the power supply facility associated with the pumps of the Emergency Equipment Cooling Water System. At 4:25 pm, March 15th, after replacing the power facility, the pumps and the Residual Heat Removal System (B) have been reactivated.

*** (Unit 4)**

As it is confirmed that the pressure at the outlet of the pumps of the Emergency Equipment Cooling Water System^{*1} has been decreased, at 8:05 pm, March 15th, we stopped the Residual Heat Removal System (B) for the inspection. Subsequently, failure was detected in the power supply facility associated with the pumps of the Emergency Equipment Cooling Water System. At 9:25 pm, March 15th, after replacing the relevant facility, the pumps and the Residual Heat Removal System (B) have been reactivated.

*1:emergency water system in which cooling water (pure water) circulates which exchanged the heat with sea water in order to cool down bearing pumps and/or heat exchangers etc.

Kashiwazaki Kariwa Nuclear Power Station:

Units 1, 5, 6, 7: normal operation

(Units 2 to 4: outage due to regular inspection)

[Thermal Power Station]

-Hirono Thermal Power Station Units 2 and 4: shutdown due to the earthquake
-Hitachinaka Thermal Power Station Unit 1: shutdown due to the earthquake
-Kashima Thermal Power Station Units 2, 3, 5, 6: shutdown due to the earthquake

[Hydro Power Station]

-All the stations have been restored.
(Facilities damaged by the earthquake are now being repaired in a timely manner.)

[Transmission System, etc.]

-All substation failed due to the earthquake have been restored.
(Facilities damaged by the earthquake are now being repaired in a timely manner.)

[Power Supply to TEPCO's Service Areas]

-Except in case of planned rolling blackouts, we can supply electricity to

our all service areas.

[Supply and Demand Status within TEPCO's Service Area to Secure Stable Power Supply]

-Considering the critical balance of our power supply capacity and expected power demand forward, in order to avoid unexpected blackout, TEPCO has been implementing rolling blackout (planned blackout alternates from one area to another) since Mar 14th. We will make our utmost to secure the stable power supply as early as possible. For customers who will be subject to rolling blackout, please be prepared for the announced blackout periods. Also for customers who are not subject to blackouts, TEPCO appreciates your continuous cooperation in reducing electricity usage by avoiding using unnecessary lighting and electrical equipment.

[Others]

- Please do NOT touch cut-off electric wires.
- In order to prevent fire, please make sure to switch off the electric appliances such as hair driers when you leave your house.
- For the customer who has in-house power generation, please secure fuel for generator.

[Back to Page 1st](#)



Press Releases

Press Release (Mar 29,2011)

Plant Status of Fukushima Daini Nuclear Power Station (as of 9:00 pm March 29th)

[No update from the last release issued at 3:00 pm, March 29th]

Unit Status

- | | |
|---|--|
| 1 | Reactor cold shutdown, stable water level, offsite power is available.
No reactor coolant is leaked to the reactor containment vessel.
Maintain average water temperature below 100°C in the Pressure Suppression Chamber. |
| 2 | Reactor cold shutdown, stable water level, offsite power is available.
No reactor coolant is leaked to the reactor containment vessel.
Maintain average water temperature below 100°C in the Pressure Suppression Chamber. |
| 3 | Reactor cold shutdown, stable water level, offsite power is available.
No reactor coolant is leaked to the reactor containment vessel.
Maintain average water temperature below 100°C in the Pressure Suppression Chamber. |
| 4 | Reactor cold shutdown, stable water level, offsite power is available.
No reactor coolant is leaked to the reactor containment vessel.
Maintain average water temperature below 100°C in the Pressure Suppression Chamber. |

Other N.A.

[Back to Page Top](#)

Press Releases

Press Release (Mar 29,2011)

Plant Status of Fukushima Daiichi Nuclear Power Station (as of 8:00 PM Mar 29th)

*Updates are underlined

All 6 units of Fukushima Daiichi Nuclear Power Station have been shut down.

Unit 1(Shut down)

- Explosive sound and white smoke were confirmed after the big quake occurred at 3:36 pm Mar 12th. It was assumed to be hydrogen explosion.
- At approximately 2:30 am on March 23rd, seawater injection to the nuclear reactor through the feed water system was initiated.
- At approximately 10:50 am on March 24th, white fog-like steam arising from the roof part of the reactor building was observed.
- At approximately 11:30 am on March 24th, lights in the main control room was restored.
- We had been injecting seawater into the reactor, but from 3:37 pm on March 25th, we started injecting freshwater.
- At 8:20 am on March 29th, we switched injection of fresh water from using fire engine to temporary electrical pump.

Unit 2(Shut down)

- At approximately 6:00 am on March 15th, an abnormal noise began emanating from nearby Pressure Suppression Chamber and the pressure within the chamber decreased.
- At 6:20 pm on March 21st, white smoke was confirmed arising from the top of the reactor building. As of 7:11 am on March 22nd, smoke decreased to the level to nearly non-existent.
- We have been injecting seawater into the reactor, but from 10:10 am on March 26th, we started injecting fresh water (with boric acid).
- At approximately 4:46 pm on March 26th, the light in the main control room was restored.
- We had been injecting fresh water in to the reactor utilizing fire pump, however, we switched over to utilizing temporary electrical pump from 6:31 pm on March 27th.

Unit 3(Shut down)

- Explosive sound and white smoke were confirmed at 11:01am March 4th. It was assumed to be hydrogen explosion.
- At 8:30am on March 16th, fog like steam was confirmed arising from the reactor building.
- At approximately 6:15 am on March 17th the pressure of the Suppression Chamber has temporarily increased. We were preparing to implement measures to reduce the pressure of the reactor containment vessel (partial discharge of air containing radioactive material to outside) in order to fully secure safety. However, at present, it is not a situation to immediately implement measures and discharge air containing radioactive material to outside. We will continue to monitor the status of the pressure of the reactor containment vessel.
- At approximately 4:00 pm, March 21st, light gray smoke was confirmed arising from the floor roof of the Unit 3 building. On March 22nd, the color of smoke changed to somewhat white and it is slowly dissipating.
- At approximately 10:45 pm on March 22nd, the light in the main control room was turned on.
- At around 4:20 pm on March 23rd, our staff confirmed light black smoke belching from the Unit 3 building. At approximately 11:30 pm on March 23rd and 4:50 am on March 24th, our employee found no signs of smoke.
- We had been injecting sea water into the reactor pressure vessel, but from 6:02 pm on March 25th, we started injecting freshwater.
- We had been injecting fresh water in to the reactor utilizing fire pump, however, we switched over to utilizing temporary electrical pump from 8:30 pm on March 28th.

Unit 4 (outage due to regular inspection)

- At approximately 6 am on March 15th, we confirmed the explosive sound and the sustained damage around the 5th floor rooftop area of the Nuclear

Reactor Building.

- On March 15th and 16th, we respectively confirmed the outbreak of fire at the 4th floor of the northwestern part of the Nuclear Reactor Building. We immediately reported this matter to the fire department and the related authorities. TEPCO employees confirmed that each fire had already died down by itself.
- At this moment, we do not consider any reactor coolant leakage inside the reactor happened.

Unit 5 (outage due to regular inspection)

- Sufficient level of reactor coolant to ensure safety is maintained.
- At 5 am, March 19th, we started the Residual Heat Removal System Pump (C) in order to cool the spent fuel pool.
- At 2:30 pm, March 20th, the reactor achieved reactor cold shutdown. At around 5:24 pm on March 23rd, when we switched the temporary Residual Heat Removal System Seawater Pump, it has stopped automatically. At around 4:14 pm, March 24th we replaced the pump, and restarted cooling of reactor at around 4:35 pm.
- At this moment, we do not consider any reactor coolant leakage inside the reactor happened.

Unit 6 (outage due to regular inspection)

- Sufficient level of reactor coolant to ensure safety is maintained.
- We completed the repair work on the emergency diesel generator (A).
- At 10:14 pm, March 19th, we started the Residual Heat Removal System Pump (B) of Unit 6 in order to cool the spent fuel pool.
- At 7:27 pm, March 20th, the reactor achieved reactor cold shutdown.
- In relation to the two seawater side pumps of the Residual Heat Removal System, we switched the power source from temporary to permanent at 3:38 PM and 3:42PM, Mar 25 respectively.
- At this moment, we do not consider any reactor coolant leakage inside the reactor happened.

Today's work for cooling the spent fuel pools

- From 2:17pm to 6:18pm, March 29th, water was injected into Unit 3 from a concrete pumping vehicle. Until March 28th, we had been injecting sea water, however, from March 29th, we started injecting fresh water.
- At Unit 2, seawater had been injected from the fire fighting pump, but at 4:30pm, March 29th, we started injecting fresh water from a temporary motor driven pump instead. The water was injected until 6:25pm, March 29th.
- We are considering further spraying subject to the conditions of spent fuel pools.

Casualty

- Presence of 2 TEPCO employees at the site is not confirmed on March 11th.
- On March 24th, it was confirmed that 3 workers from cooperative companies who were in charge of cable laying work in the 1st floor and the underground floor of turbine building were exposed to the radiation dose of more than 170 mSv. 2 of them were confirmed that their skins on legs were contaminated. After they were decontaminated, since there was a possibility of beta ray burn injury, they were transferred to Fukushima Medical University Hospital. The third worker was also transferred to Fukushima Medical University Hospital on March 25th. Later, the 3 workers were transferred to National Institute of Radiological Sciences in Chiba Prefecture. They all left the hospital on March 28th.
- Regarding this event, TEPCO has reported to the related government ministries and agencies on measures to be taken to assure appropriate radiation dose control and radiation exposure related operations. We will inform the related parties of countermeasures and continue to take all possible measures to future management.

Others

- We measured radioactive materials (iodine etc.) inside of the nuclear power station area (outdoor) by monitoring car and confirmed that radioactive materials level is getting higher than ordinary level. As listed below, we have determined that specific incidents stipulated in article 15, clause 1 of Act on Special Measures Concerning Nuclear Emergency Preparedness (Abnormal increase in radiation dose measured at site boundary) have occurred.
- Determined at 4:17 pm Mar 12th (Around Monitoring Post 4)
- Determined at 8:56 am Mar 13th (Around Monitoring Post 4)
- Determined at 2:15 pm Mar 13th (Around Monitoring Post 4)
- Determined at 3:50 am Mar 14th (Around Monitoring Post 6)
- Determined at 4:15 am Mar 14th (Around Monitoring Post 2)
- Determined at 9:27 am Mar 14th (Around Monitoring Post 3)
- Determined at 9:37 pm Mar 14th (Around main entrance)
- Determined at 6:51 am Mar 15th (Around main entrance)
- Determined at 8:11 am Mar 15th (Around main entrance)
- Determined at 4:17 pm Mar 15th (Around main entrance)
- Determined at 11:05 pm Mar 15th (Around main entrance)
- Determined at 8:58 am Mar 19th (Around MP5)
- From now on, if the measured figure fluctuates and goes above and below 500 micro Sv/h, we deem that as the continuous same event and will not regard that as a new specific incidents stipulated in article 15, clause 1 of the Act on Special Measures Concerning Nuclear Emergency Preparedness (Abnormal increase in radiation dose measured at site

boundary) has occurred. In the interim, if we measure a manifestly abnormal figure and it is evident that the event is not the continuous same event, we will determine and notify.

- The national government has instructed evacuation for those local residents within 20km radius of the periphery and evacuation to inside for those residents from 20km to 30km radius of the periphery, because it is possible that radioactive materials are discharged.
- At around 10:37 am March 21st, water spraying to common spent fuel pool and finished at 3:30 pm (conducted by TEPCO).
- At around 3:37 pm, March 24th, electricity supply to common spent fuel pool has started from external power source. At around 6:05 pm, fuel pool cooling pump was started to cool the pool.
- We found no signs of abnormal situation for the casks by visual observation during the patrol activity. A detailed inspection is under preparation.
- At Units 5 and 6, in order to prevent hydrogen gas from accumulating within the buildings, we have made three holes on the roof of the reactor building for each unit.
- In total 12 fire engines are lent for the water spraying to the spent fuel pools and water injection to the nuclear reactors by various regional fire departments* as well as Tokyo Fire Department. Also, instruction regarding the setting and operation of large scale decontamination system was provided by Niigata City Fire Headquarter and Hamamatsu City Fire Headquarter.
- *: Koriyama Fire Department, Iwaki Fire Brigade Headquarters, Fire Headquarters of Sukagawa District Wide Area Fire-fighting Association, Yonezawa City Fire Headquarters, Utsunomiya City Fire Headquarters, Fire Headquarters of Aizu-Wakamatsu wide area municipal association, Saitama City Fire Bureau, and Niigata City Fire Bureau.
- By March 22nd, Units 1 through 6 were started to be energized from the external power source.
- At 3:30PM, March 27th, we found that there was water in the trenches of Units 1 to 3. The radioactive emission at the surface of the water was 0.4mSv/h for Unit 1 and over 1,000mSv/h for Unit 2. As for Unit 3, we couldn't have access to the surface because of debris. We will continue to monitor water in the trenches.
- We will continue to take all measures to ensure the safety and to continue monitoring the surrounding environment around the Power Station.

[Back to page top](#)