

Subsection 2.4.14 Table of Contents

<u>Section</u>	<u>Title</u>	<u>Page</u>
2.4.14	Technical Specifications and Emergency Operation Requirements	2.4.14-1

2.4.14 Technical Specifications and Emergency Operation Requirements

The minimum finished site grade elevation of 95.0 feet (29.0 meters) NAVD 88 for the power block at the VCS site is above the elevations associated with the probable maximum flood (65.9 feet NAVD 88, as provided in Subsection 2.4.3.7) and the design basis cooling basin breach flood (91 feet NAVD 88, as provided in Subsection 2.4.4.3.2); therefore, due to design, there are no requirements for emergency protective measures designed to minimize the impact of hydrology-related events on safety-related facilities, and none are incorporated into the technical specifications or emergency procedures.