



South Texas Project Electric Generating Station P.O. Box 289 Wadsworth, Texas 77483

May 3, 2012  
NOC-AE-12002848  
10 CFR 54  
STI: 33514541  
File: G25

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
One White Flint North  
11555 Rockville Pike  
Rockville, MD 20852-2738

South Texas Project  
Units 1 and 2  
Docket Nos. STN 50-498, STN 50-499  
Response to Request for Additional Information (RAI) 3.3.2.2.12.2-1 for the  
South Texas Project License Renewal Application (TAC Nos. ME4936 and ME4937)

- References: 1. STPNOC letter dated October 25, 2010, from G. T. Powell to NRC Document Control Desk, "License Renewal Application" (NOC-AE-10002607) (ML103010257)
2. Record of Teleconference of April 26, 2012 between STPNOC and the NRC Regarding Request for Additional Information (RAI) 3.3.2.2.12.2-1 for the South Texas Project, Units 1 and 2, License Renewal Application (TAC Nos. ME4936 and ME4937) (ML121220190)

By Reference 1, STP Nuclear Operating Company (STPNOC) submitted a License Renewal Application (LRA) for South Texas Project (STP) Units 1 and 2. By Reference 2, STPNOC received RAI 3.3.2.2.12.2-1. The response to the request for additional information is provided in Enclosure 1 to this letter. Changes to LRA pages described in Enclosure 1 are depicted in line-in/line-out pages provided in Enclosure 2.

There are no regulatory commitments in this letter.

Should you have any questions regarding this letter, please contact either Arden Aldridge, STP License Renewal Project Lead, at (361) 972-8243 or Ken Taplett, STP License Renewal Project regulatory point-of-contact, at (361) 972-8416.

I declare under penalty of perjury that the foregoing is true and correct.

Executed on 5-3-2012

Kevin D. Richards  
President & Chief Executive Officer

KJT

- Enclosure: 1. STPNOC Supplemental Response to RAI 3.3.2.2.12.2-1  
2. STPNOC LRA Changes with Line-in/Line-out Annotations

A147  
NIRK

cc:

(paper copy)

Regional Administrator, Region IV  
U. S. Nuclear Regulatory Commission  
1600 East Lamar Boulevard  
Arlington, Texas 76011-4511

Balwant K. Singal  
Senior Project Manager  
U.S. Nuclear Regulatory Commission  
One White Flint North (MS 8B1)  
11555 Rockville Pike  
Rockville, MD 20852

Senior Resident Inspector  
U. S. Nuclear Regulatory Commission  
P. O. Box 289, Mail Code: MN116  
Wadsworth, TX 77483

C. M. Canady  
City of Austin  
Electric Utility Department  
721 Barton Springs Road  
Austin, TX 78704

John W. Daily  
License Renewal Project Manager (Safety)  
U.S. Nuclear Regulatory Commission  
One White Flint North (MS O11-F1)  
Washington, DC 20555-0001

Tam Tran  
License Renewal Project Manager  
(Environmental)  
U. S. Nuclear Regulatory Commission  
One White Flint North (MS O11F01)  
Washington, DC 20555-0001

(electronic copy)

A. H. Gutterman, Esquire  
Kathryn M. Sutton, Esquire  
Morgan, Lewis & Bockius, LLP

John Ragan  
Chris O'Hara  
Jim von Suskil  
NRG South Texas LP

Kevin Pollo  
Richard Pena  
City Public Service

Peter Nemeth  
Crain Caton & James, P.C.

C. Mele  
City of Austin

Richard A. Ratliff  
Alice Rogers  
Texas Department of State Health Services

Balwant K. Singal  
John W. Daily  
Tam Tran  
U. S. Nuclear Regulatory Commission

**Enclosure 1**

**STPNOC Supplemental Response to RAI 3.3.2.2.12.2-1**

**RAI 3.3.2.2.12.2-1**

LRA Section B2.1.23 describes the existing Lubricating Oil Analysis program as consistent, with exceptions to GALL Report AMP XI.M39.

LRA Section 3.3.2.2.12.2, associated with LRA Table 3.3.1, item 3.3.1.33, addresses loss of material due to pitting, crevice, and microbiologically influenced corrosion for stainless steel piping, piping components, and piping elements exposed to lubricating oil. It further states that the reactor coolant pump lube oil collection system is managed by the Inspection of Internal Surfaces in Miscellaneous Piping and Ducting Components Program (B2.1.22).

**Issue**

The staff notes that lubricating oil systems are in scope of GALL AMP XI.M39. It is not clear to the staff why the RCP lube oil collection system is in scope of the Inspection of Internal Surfaces in Miscellaneous Piping and Ducting Components Program.

**Request**

Please justify the use of the Inspection of Internal Surfaces in Miscellaneous Piping and Ducting Components Program in managing loss of material due to pitting, crevice, and microbiologically influenced corrosion for stainless steel components exposed to lubricating oil in the reactor coolant pump lube oil collection system.

**STPNOC Response**

LRA Section 3.3.2.2.12.2 incorrectly stated that the loss of material due to pitting, crevice, and microbiologically-influenced corrosion for stainless steel components exposed to lubricating oil in the reactor coolant pump (RCP) lube oil collection system is managed by the Inspection of Internal Surfaces in Miscellaneous Piping and Components program. Instead, management is provided by the Lubricating Oil Analysis program and the One-Time Inspection Program.

Enclosure 2 provides the line-in/line-out revision to LRA Section 3.3.2.2.12.

**Enclosure 2**

**STPNOC LRA Changes with Line-in/Line-out Annotations**

**List of Revised LRA Sections**

<b>RAI</b>	<b>Affected LRA Section</b>
3.3.2.2.12.2-1	3.3.2.2.12

**3.3.2.2.12      Loss of Material due to Pitting, Crevice, and Microbiologically-Influenced Corrosion**

**3.3.2.2.12.1    Stainless steel, aluminum, and copper alloy piping and components exposed to fuel oil**

The Fuel Oil Chemistry program (B2.1.14) and the One-Time Inspection program (B2.1.16) manage loss of material due to pitting, crevice and microbiologically influenced corrosion for stainless steel and copper components exposed to fuel oil. The one-time inspection will include selected components at susceptible locations where contaminants could accumulate (e.g. stagnant flow locations).

**3.3.2.2.12.2    Stainless steel piping and components exposed to lubricating oil**

The Lubricating Oil Analysis program (B2.1.23) and the One-Time Inspection program (B2.1.16) manage loss of material due to pitting, crevice, and microbiologically influenced corrosion for stainless steel components exposed to lubricating oil. The one-time inspection will include selected components at susceptible locations where contaminants such as water could accumulate.

~~For the RCP lube oil collection system, the Inspection of Internal Surfaces in Miscellaneous Piping and Ducting Components program (B2.1.22) manages loss of material due to pitting, crevice, and microbiologically influenced corrosion for stainless steel components exposed to lubricating oil.~~