

10 CFR 50, Appendix E

RA-12-052

May 16, 2012

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Oyster Creek Nuclear Generating Station
Renewed Facility Operating License No. DPR-16
NRC Docket Nos. 50-219


Subject: Oyster Creek Nuclear Generating Station
Emergency Response Data System Data Point Library Changes

In accordance with 10 CFR 50, Appendix E, Section VI, "*Emergency Response Data System*," Exelon Generation Company, LLC (Exelon) is submitting updated information related to the Emergency Response Data System (ERDS) for Oyster Creek Nuclear Generating Station (OCNGS). ERDS is a direct, near real-time, electronic data link between the computer data system used by OCNGS and the NRC's Operations Center which provides for the automated transmission of a limited data set of selected parameters. 10 CFR 50, Appendix E, Section VI.3.a requires that any changes in computer hardware or software that affect the transmitted data points identified in the ERDS Data Point Library must be submitted to the NRC within 30 days after the changes are completed.

Accordingly, the transmission of the attached ERDS data point information for OCNGS (i.e., Point ID: *SOURCE*, NRC ERDS Parameter: *N/A* (Simulator Data) is being discontinued. The OCNGS database will retain this data point as a spare, but the associated data will no longer be transmitted to the NRC via ERDS. This ERDS change was implemented on April 16, 2012, and the required notification is being submitted within 30 days of the change as required by 10 CFR 50, Appendix E, Section VI.a.3.

If you have any questions or require additional information, please do not hesitate to contact Richard Gropp at (610) 765-5557.

Respectfully,


Michael D. Jesse
Director, Licensing and Regulatory Affairs
Exelon Generation Company, LLC

Attachment

cc: Regional Administrator, USNRC Region I
NRC Senior Resident Inspector – OCNGS
NRC, Senior Project Manager, NRR – OCNGS

w/ Attachment
“
“

ATTACHMENT

Oyster Creek Nuclear Generating Station
Emergency Response Data System Data Point Library Change

Point ID: *SOURCE*
NRC ERDS Parameter: *N/A* (Simulator Data)

DATA POINT LIBRARY REFERENCE FILE

DATE: 03/24/93
REACTOR UNIT: OY1
DATA FEEDER: N/A
NRC ERDS PARAMETER: N/A
POINT ID: SOURCE
PLANT SPEC POINT DESC.: ERDS DATA SOURCE
GENERIC/COND DESC.: N/A
ANALOG/DIGITAL: D
ENGR UNITS/DIG STATES: 0 = PLANT DATA, 1 = SIMULATOR DATA
ENGR UNITS CONVERSION: N/A
MINIMUM INSTR RANGE: 0
MAXIMUM INSTR RANGE: 1
ZERO POINT REFERENCE: N/A
REFERENCE POINT NOTES: N/A
PROC OR SENS: P
NUMBER OF SENSORS: 0
HOW PROCESSED: N/A
SENSOR LOCATIONS: N/A
ALARM/TRIP SET POINTS: N/A
UNIQUE SYSTEM DESC.: N/A

Effective April 16, 2012, this ERDS data point information will no longer be transmitted to the NRC. This data point will be retained in the site database as a spare.