BREAKER CONTACTS ▶ CLOSED

◀ OPERATIONS

REFER TO MANUAL
SU-6150-2 FOR SERVICE INTERVALS

POSITION
LOCKING
HANDLE ▶

TO UNLOCK, TURN
COUNTER-CLOCK ND
PULL OUT

NOTE: UNLOCKIN REAKER

TO LOCK HANDLE IN
AND TU CKWISE

SOLENARC
AC HIGH VOLTAGE CIRCUIT BREAKER

TYPE DSE 15R SE NO. 50166

MFGD. 2/13/78 P RD 12045-167A

CIRCUIT KER RATINGS

CONTINUOUS CURRENT 1200 AMP. RMS-60 HZ.

NOMINAL VOLTAGE 12.47 KV. RMS VOLTAGE RANGE FACTOR 1.25

MAXIMUM VOLTAGE 15.0 KV. RMS

NOMINAL 3 PHASE SYMMETRICAL INTERRUPTING CAPACITY 500 MVA.

SYMMETRICAL CURRENT INTERRUPTING CAPACITY AT MAXIMUM VOLTAGE 23 KA. RMS

FULL WAVE BIL 95 KV. CREST INTERRUPT. TIME-5 CYCLE

NOTE: CONTROL VOLTAGE NAMEPLATE ON SIDE OF BREAKER

MADE IN FRANCE

SQUARE D COMPANY

MANUAL CHARGE

STORED ENERGY
MECHANISM

CHARGED ▶

DISCHARGED ▶

CLOSE

OPEN

MANUAL
CONTROLS