

5/8/12

To: Leeds, NRR  
Ref. G20120172

Mr. James Borchardt  
Executive Director for Operations  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

ays: EDO  
DEDMRT  
DEDR  
DEDCM  
AO  
RI  
OGC  
Mensah, NRR  
Banic, NRR  
Russell, NRR  
Scott, OGC  
Bowman,  
OEDO

Attn: Bhalchandra K. Vaidya, NRC Petition Manager

In the Matter of the James A. FitzPatrick Nuclear Plant in Scriba, New York

Dear Mr. Borchardt:

I wish to co-petition with the Alliance for a Green Economy and Beyond Nuclear's March 9, 2012 emergency enforcement petition to suspend the operation of the James A. FitzPatrick Nuclear Plant.

- The FitzPatrick plant is the only GE Mark I boiling water reactor in the US that did not install a Direct Torus Vent System as requested by the NRC in 1989 and instead, to save money, relies upon a "pre-existing" venting system that is not fully hardened against a severe accident.
- In deciding not to install such a vent, the FitzPatrick operator and the NRC relied upon assumptions that now place public health and safety at an undue risk.
- The hydrogen explosions at the Fukushima reactors show the dangers and unacceptable consequences posed by the current FitzPatrick severe accident venting plan, since the plan was approved on the assumptions that venting would prevent containment failure, and that there are "no likely" ignition sources along the vent path. Neither of these assumptions was correct during the Fukushima nuclear catastrophe.
- Subsequent to the Fukushima accident, the NRC inspected FitzPatrick and identified a "vulnerability, in that current procedures do not address hydrogen considerations" during a severe accident.

Therefore, I request NRC immediately suspend the FitzPatrick operating license until the following emergency enforcement actions are approved by the NRC:

1) Public hearings should be held on the continued operation of Entergy Nuclear Operations' Fitzpatrick plant and the adequacy of its plan to vent through a pre-existing path into the adjacent Standby Gas Treatment System building, blowing off the double doors to release a radiological accident to the outside environment at ground level. The public must be afforded due process to address the unacceptable risks to public health and safety posed by the FitzPatrick severe accident plan.

2) Entergy Nuclear Operations should publicly document for independent review its post-Fukushima re-analysis for the reliability and capability of the FitzPatrick pre-existing containment vent system.

- The analysis should include the reassessment of all assumptions regarding the reliability of the pre-existing containment venting and specifically address non-conservative assumptions behind the cost-benefit analysis used to justify not installing a fully hardened vent system.
- It should also include a reassessment of the assumption of "no likely ignition points" during emergency venting that would otherwise present catastrophic consequences associated with the detonation of hydrogen gas and the release of radioactivity generated during a severe accident.

I wish the NRC to process my request using the 2.206 process, and I understand that under this process, the contents of this message and my identity will be made public. The Alliance for a Green Economy is my point of contact for this petition, and their organizer, Jessica Azulay, will keep me informed about the developments of the petition and the opportunity to participate in a public meeting with the NRC Petition Review Board.

Thank you,

Name: Amanda Kaiet

Address: 7795 Bel-Air Dr. Rome NY 13440

Email: Amanda.kaiet@gmail.com

Template: EDO-001

E-RIDS: EDO-01

Mr. James Borchardt  
Executive Director for Operations  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Attn: Bhalchandra K. Vaidya, NRC Petition Manager

In the Matter of the James A. FitzPatrick Nuclear Plant in Scriba, New York

Dear Mr. Borchardt:

I wish to co-petition with the Alliance for a Green Economy and Beyond Nuclear's March 9, 2012 emergency enforcement petition to suspend the operation of the James A. FitzPatrick Nuclear Plant.

- The FitzPatrick plant is the only GE Mark I boiling water reactor in the US that did not install a Direct Torus Vent System as requested by the NRC in 1989 and instead, to save money, relies upon a "pre-existing" venting system that is not fully hardened against a severe accident.
- In deciding not to install such a vent, the FitzPatrick operator and the NRC relied upon assumptions that now place public health and safety at an undue risk.
- The hydrogen explosions at the Fukushima reactors show the dangers and unacceptable consequences posed by the current FitzPatrick severe accident venting plan, since the plan was approved on the assumptions that venting would prevent containment failure, and that there are "no likely" ignition sources along the vent path. Neither of these assumptions was correct during the Fukushima nuclear catastrophe.
- Subsequent to the Fukushima accident, the NRC inspected FitzPatrick and identified a "vulnerability, in that current procedures do not address hydrogen considerations" during a severe accident.

Therefore, I request NRC immediately suspend the FitzPatrick operating license until the following emergency enforcement actions are approved by the NRC:

1) Public hearings should be held on the continued operation of Entergy Nuclear Operations' Fitzpatrick plant and the adequacy of its plan to vent through a pre-existing path into the adjacent Standby Gas Treatment System building, blowing off the double doors to release a radiological accident to the outside environment at ground level. The public must be afforded due process to address the unacceptable risks to public health and safety posed by the FitzPatrick severe accident plan.

2) Entergy Nuclear Operations should publicly document for independent review its post-Fukushima re-analysis for the reliability and capability of the FitzPatrick pre-existing containment vent system.

- The analysis should include the reassessment of all assumptions regarding the reliability of the pre-existing containment venting and specifically address non-conservative assumptions behind the cost-benefit analysis used to justify not installing a fully hardened vent system.
- It should also include a reassessment of the assumption of "no likely ignition points" during emergency venting that would otherwise present catastrophic consequences associated with the detonation of hydrogen gas and the release of radioactivity generated during a severe accident.

I wish the NRC to process my request using the 2.206 process, and I understand that under this process, the contents of this message and my identity will be made public. The Alliance for a Green Economy is my point of contact for this petition, and their organizer, Jessica Azulay, will keep me informed about the developments of the petition and the opportunity to participate in a public meeting with the NRC Petition Review Board.

Thank you,

Name: BRIAN MORSE

Address: 401 VAN BUREN ST. SYRACUSE NY 13210

Email: bjmorse@syr.edu

Mr. James Borchardt  
Executive Director for Operations  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Attn: Bhalchandra K. Vaidya, NRC Petition Manager

In the Matter of the James A. FitzPatrick Nuclear Plant in Scriba, New York

Dear Mr. Borchardt:

I wish to co-petition with the Alliance for a Green Economy and Beyond Nuclear's March 9, 2012 emergency enforcement petition to suspend the operation of the James A. FitzPatrick Nuclear Plant.

- The FitzPatrick plant is the only GE Mark I boiling water reactor in the US that did not install a Direct Torus Vent System as requested by the NRC in 1989 and instead, to save money, relies upon a "pre-existing" venting system that is not fully hardened against a severe accident.
- In deciding not to install such a vent, the FitzPatrick operator and the NRC relied upon assumptions that now place public health and safety at an undue risk.
- The hydrogen explosions at the Fukushima reactors show the dangers and unacceptable consequences posed by the current FitzPatrick severe accident venting plan, since the plan was approved on the assumptions that venting would prevent containment failure, and that there are "no likely" ignition sources along the vent path. Neither of these assumptions was correct during the Fukushima nuclear catastrophe.
- Subsequent to the Fukushima accident, the NRC inspected FitzPatrick and identified a "vulnerability, in that current procedures do not address hydrogen considerations" during a severe accident.

Therefore, I request NRC immediately suspend the FitzPatrick operating license until the following emergency enforcement actions are approved by the NRC:

1) Public hearings should be held on the continued operation of Entergy Nuclear Operations' Fitzpatrick plant and the adequacy of its plan to vent through a pre-existing path into the adjacent Standby Gas Treatment System building, blowing off the double doors to release a radiological accident to the outside environment at ground level. The public must be afforded due process to address the unacceptable risks to public health and safety posed by the FitzPatrick severe accident plan.

2) Entergy Nuclear Operations should publicly document for independent review its post-Fukushima re-analysis for the reliability and capability of the FitzPatrick pre-existing containment vent system.

- The analysis should include the reassessment of all assumptions regarding the reliability of the pre-existing containment venting and specifically address non-conservative assumptions behind the cost-benefit analysis used to justify not installing a fully hardened vent system.
- It should also include a reassessment of the assumption of "no likely ignition points" during emergency venting that would otherwise present catastrophic consequences associated with the detonation of hydrogen gas and the release of radioactivity generated during a severe accident.

I wish the NRC to process my request using the 2.206 process, and I understand that under this process, the contents of this message and my identity will be made public. The Alliance for a Green Economy is my point of contact for this petition, and their organizer, Jessica Azulay, will keep me informed about the developments of the petition and the opportunity to participate in a public meeting with the NRC Petition Review Board.

Thank you,

Name: Alejandro Ciordia-Morandeira

Address: Day Hall 705, 1 Mt. Olympus Dr., Syracuse NY

Email: aciordia@syr.edu

Mr. James Borchardt  
Executive Director for Operations  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Attn: Bhalchandra K. Vaidya, NRC Petition Manager

In the Matter of the James A. FitzPatrick Nuclear Plant in Scriba, New York

Dear Mr. Borchardt:

I wish to co-petition with the Alliance for a Green Economy and Beyond Nuclear's March 9, 2012 emergency enforcement petition to suspend the operation of the James A. FitzPatrick Nuclear Plant.

- The FitzPatrick plant is the only GE Mark I boiling water reactor in the US that did not install a Direct Torus Vent System as requested by the NRC in 1989 and instead, to save money, relies upon a "pre-existing" venting system that is not fully hardened against a severe accident.
- In deciding not to install such a vent, the FitzPatrick operator and the NRC relied upon assumptions that now place public health and safety at an undue risk.
- The hydrogen explosions at the Fukushima reactors show the dangers and unacceptable consequences posed by the current FitzPatrick severe accident venting plan, since the plan was approved on the assumptions that venting would prevent containment failure, and that there are "no likely" ignition sources along the vent path. Neither of these assumptions was correct during the Fukushima nuclear catastrophe.
- Subsequent to the Fukushima accident, the NRC inspected FitzPatrick and identified a "vulnerability, in that current procedures do not address hydrogen considerations" during a severe accident.

Therefore, I request NRC immediately suspend the FitzPatrick operating license until the following emergency enforcement actions are approved by the NRC:

1) Public hearings should be held on the continued operation of Entergy Nuclear Operations' Fitzpatrick plant and the adequacy of its plan to vent through a pre-existing path into the adjacent Standby Gas Treatment System building, blowing off the double doors to release a radiological accident to the outside environment at ground level. The public must be afforded due process to address the unacceptable risks to public health and safety posed by the FitzPatrick severe accident plan.

2) Entergy Nuclear Operations should publicly document for independent review its post-Fukushima re-analysis for the reliability and capability of the FitzPatrick pre-existing containment vent system.

- The analysis should include the reassessment of all assumptions regarding the reliability of the pre-existing containment venting and specifically address non-conservative assumptions behind the cost-benefit analysis used to justify not installing a fully hardened vent system.
- It should also include a reassessment of the assumption of "no likely ignition points" during emergency venting that would otherwise present catastrophic consequences associated with the detonation of hydrogen gas and the release of radioactivity generated during a severe accident.

I wish the NRC to process my request using the 2.206 process, and I understand that under this process, the contents of this message and my identity will be made public. The Alliance for a Green Economy is my point of contact for this petition, and their organizer, Jessica Azulay, will keep me informed about the developments of the petition and the opportunity to participate in a public meeting with the NRC Petition Review Board.

Thank you,

Name:

Andrew Greco

Address:

1032 Lancaster Ave., Syracuse NY 13210

Email:

Andrewgreco2@gmail.com

Mr. James Borchardt  
Executive Director for Operations  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Attn: Bhalchandra K. Vaidya, NRC Petition Manager

In the Matter of the James A. FitzPatrick Nuclear Plant in Scriba, New York

Dear Mr. Borchardt:

I wish to co-petition with the Alliance for a Green Economy and Beyond Nuclear's March 9, 2012 emergency enforcement petition to suspend the operation of the James A. FitzPatrick Nuclear Plant.

- The FitzPatrick plant is the only GE Mark I boiling water reactor in the US that did not install a Direct Torus Vent System as requested by the NRC in 1989 and instead, to save money, relies upon a "pre-existing" venting system that is not fully hardened against a severe accident.
- In deciding not to install such a vent, the FitzPatrick operator and the NRC relied upon assumptions that now place public health and safety at an undue risk.
- The hydrogen explosions at the Fukushima reactors show the dangers and unacceptable consequences posed by the current FitzPatrick severe accident venting plan, since the plan was approved on the assumptions that venting would prevent containment failure, and that there are "no likely" ignition sources along the vent path. Neither of these assumptions was correct during the Fukushima nuclear catastrophe.
- Subsequent to the Fukushima accident, the NRC inspected FitzPatrick and identified a "vulnerability, in that current procedures do not address hydrogen considerations" during a severe accident.

Therefore, I request NRC immediately suspend the FitzPatrick operating license until the following emergency enforcement actions are approved by the NRC:

1) Public hearings should be held on the continued operation of Entergy Nuclear Operations' Fitzpatrick plant and the adequacy of its plan to vent through a pre-existing path into the adjacent Standby Gas Treatment System building, blowing off the double doors to release a radiological accident to the outside environment at ground level. The public must be afforded due process to address the unacceptable risks to public health and safety posed by the FitzPatrick severe accident plan.

2) Entergy Nuclear Operations should publicly document for independent review its post-Fukushima re-analysis for the reliability and capability of the FitzPatrick pre-existing containment vent system.

- The analysis should include the reassessment of all assumptions regarding the reliability of the pre-existing containment venting and specifically address non-conservative assumptions behind the cost-benefit analysis used to justify not installing a fully hardened vent system.
- It should also include a reassessment of the assumption of "no likely ignition points" during emergency venting that would otherwise present catastrophic consequences associated with the detonation of hydrogen gas and the release of radioactivity generated during a severe accident.

I wish the NRC to process my request using the 2.206 process, and I understand that under this process, the contents of this message and my identity will be made public. The Alliance for a Green Economy is my point of contact for this petition, and their organizer, Jessica Azulay, will keep me informed about the developments of the petition and the opportunity to participate in a public meeting with the NRC Petition Review Board.

Thank you,

Name:

FRANK R CETERA *fr R Et*

Address:

162 Cambridge St Syracuse NY 13210

Email:

franklen9807@gmail.com

Mr. James Borchardt  
Executive Director for Operations  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Attn: Bhalchandra K. Vaidya, NRC Petition Manager

In the Matter of the James A. FitzPatrick Nuclear Plant in Scriba, New York

Dear Mr. Borchardt:

I wish to co-petition with the Alliance for a Green Economy and Beyond Nuclear's March 9, 2012 emergency enforcement petition to suspend the operation of the James A. FitzPatrick Nuclear Plant.

- The FitzPatrick plant is the only GE Mark I boiling water reactor in the US that did not install a Direct Torus Vent System as requested by the NRC in 1989 and instead, to save money, relies upon a "pre-existing" venting system that is not fully hardened against a severe accident.
- In deciding not to install such a vent, the FitzPatrick operator and the NRC relied upon assumptions that now place public health and safety at an undue risk.
- The hydrogen explosions at the Fukushima reactors show the dangers and unacceptable consequences posed by the current FitzPatrick severe accident venting plan, since the plan was approved on the assumptions that venting would prevent containment failure, and that there are "no likely" ignition sources along the vent path. Neither of these assumptions was correct during the Fukushima nuclear catastrophe.
- Subsequent to the Fukushima accident, the NRC inspected FitzPatrick and identified a "vulnerability, in that current procedures do not address hydrogen considerations" during a severe accident.

Therefore, I request NRC immediately suspend the FitzPatrick operating license until the following emergency enforcement actions are approved by the NRC:

1) Public hearings should be held on the continued operation of Entergy Nuclear Operations' Fitzpatrick plant and the adequacy of its plan to vent through a pre-existing path into the adjacent Standby Gas Treatment System building, blowing off the double doors to release a radiological accident to the outside environment at ground level. The public must be afforded due process to address the unacceptable risks to public health and safety posed by the FitzPatrick severe accident plan.

2) Entergy Nuclear Operations should publicly document for independent review its post-Fukushima re-analysis for the reliability and capability of the FitzPatrick pre-existing containment vent system.

- The analysis should include the reassessment of all assumptions regarding the reliability of the pre-existing containment venting and specifically address non-conservative assumptions behind the cost-benefit analysis used to justify not installing a fully hardened vent system.
- It should also include a reassessment of the assumption of "no likely ignition points" during emergency venting that would otherwise present catastrophic consequences associated with the detonation of hydrogen gas and the release of radioactivity generated during a severe accident.

I wish the NRC to process my request using the 2.206 process, and I understand that under this process, the contents of this message and my identity will be made public. The Alliance for a Green Economy is my point of contact for this petition, and their organizer, Jessica Azulay, will keep me informed about the developments of the petition and the opportunity to participate in a public meeting with the NRC Petition Review Board.

Thank you,

Name:

Barbara Humphrey

Address:

834 Westcott St., 13210

Email:

bhumphrey@gmail.com

Mr. James Borchardt  
Executive Director for Operations  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Attn: Bhalchandra K. Vaidya, NRC Petition Manager

In the Matter of the James A. FitzPatrick Nuclear Plant in Scriba, New York

Dear Mr. Borchardt:

I wish to co-petition with the Alliance for a Green Economy and Beyond Nuclear's March 9, 2012 emergency enforcement petition to suspend the operation of the James A. FitzPatrick Nuclear Plant.

- The FitzPatrick plant is the only GE Mark I boiling water reactor in the US that did not install a Direct Torus Vent System as requested by the NRC in 1989 and instead, to save money, relies upon a "pre-existing" venting system that is not fully hardened against a severe accident.
- In deciding not to install such a vent, the FitzPatrick operator and the NRC relied upon assumptions that now place public health and safety at an undue risk.
- The hydrogen explosions at the Fukushima reactors show the dangers and unacceptable consequences posed by the current FitzPatrick severe accident venting plan, since the plan was approved on the assumptions that venting would prevent containment failure, and that there are "no likely" ignition sources along the vent path. Neither of these assumptions was correct during the Fukushima nuclear catastrophe.
- Subsequent to the Fukushima accident, the NRC inspected FitzPatrick and identified a "vulnerability, in that current procedures do not address hydrogen considerations" during a severe accident.

Therefore, I request NRC immediately suspend the FitzPatrick operating license until the following emergency enforcement actions are approved by the NRC:

1) Public hearings should be held on the continued operation of Entergy Nuclear Operations' Fitzpatrick plant and the adequacy of its plan to vent through a pre-existing path into the adjacent Standby Gas Treatment System building, blowing off the double doors to release a radiological accident to the outside environment at ground level. The public must be afforded due process to address the unacceptable risks to public health and safety posed by the FitzPatrick severe accident plan.

2) Entergy Nuclear Operations should publicly document for independent review its post-Fukushima re-analysis for the reliability and capability of the FitzPatrick pre-existing containment vent system.

- The analysis should include the reassessment of all assumptions regarding the reliability of the pre-existing containment venting and specifically address non-conservative assumptions behind the cost-benefit analysis used to justify not installing a fully hardened vent system.
- It should also include a reassessment of the assumption of "no likely ignition points" during emergency venting that would otherwise present catastrophic consequences associated with the detonation of hydrogen gas and the release of radioactivity generated during a severe accident.

I wish the NRC to process my request using the 2.206 process, and I understand that under this process, the contents of this message and my identity will be made public. The Alliance for a Green Economy is my point of contact for this petition, and their organizer, Jessica Azulay, will keep me informed about the developments of the petition and the opportunity to participate in a public meeting with the NRC Petition Review Board.

Thank you,

Name: Thomas R. Hester

Address: 5018 Pine Valley Dr Fayetteville

Email: \_\_\_\_\_

Mr. James Borchardt  
Executive Director for Operations  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Attn: Bhalchandra K. Vaidya, NRC Petition Manager

In the Matter of the James A. FitzPatrick Nuclear Plant in Scriba, New York

Dear Mr. Borchardt:

I wish to co-petition with the Alliance for a Green Economy and Beyond Nuclear's March 9, 2012 emergency enforcement petition to suspend the operation of the James A. FitzPatrick Nuclear Plant.

- The FitzPatrick plant is the only GE Mark I boiling water reactor in the US that did not install a Direct Torus Vent System as requested by the NRC in 1989 and instead, to save money, relies upon a "pre-existing" venting system that is not fully hardened against a severe accident.
- In deciding not to install such a vent, the FitzPatrick operator and the NRC relied upon assumptions that now place public health and safety at an undue risk.
- The hydrogen explosions at the Fukushima reactors show the dangers and unacceptable consequences posed by the current FitzPatrick severe accident venting plan, since the plan was approved on the assumptions that venting would prevent containment failure, and that there are "no likely" ignition sources along the vent path. Neither of these assumptions was correct during the Fukushima nuclear catastrophe.
- Subsequent to the Fukushima accident, the NRC inspected FitzPatrick and identified a "vulnerability, in that current procedures do not address hydrogen considerations" during a severe accident.

Therefore, I request NRC immediately suspend the FitzPatrick operating license until the following emergency enforcement actions are approved by the NRC:

1) Public hearings should be held on the continued operation of Entergy Nuclear Operations' Fitzpatrick plant and the adequacy of its plan to vent through a pre-existing path into the adjacent Standby Gas Treatment System building, blowing off the double doors to release a radiological accident to the outside environment at ground level. The public must be afforded due process to address the unacceptable risks to public health and safety posed by the FitzPatrick severe accident plan.

2) Entergy Nuclear Operations should publicly document for independent review its post-Fukushima re-analysis for the reliability and capability of the FitzPatrick pre-existing containment vent system.

- The analysis should include the reassessment of all assumptions regarding the reliability of the pre-existing containment venting and specifically address non-conservative assumptions behind the cost-benefit analysis used to justify not installing a fully hardened vent system.
- It should also include a reassessment of the assumption of "no likely ignition points" during emergency venting that would otherwise present catastrophic consequences associated with the detonation of hydrogen gas and the release of radioactivity generated during a severe accident.

I wish the NRC to process my request using the 2.206 process, and I understand that under this process, the contents of this message and my identity will be made public. The Alliance for a Green Economy is my point of contact for this petition, and their organizer, Jessica Azulay, will keep me informed about the developments of the petition and the opportunity to participate in a public meeting with the NRC Petition Review Board.

Thank you,

Name: William Todd Holley

Address: 213 E. Second St East Syracuse NY 13052

Email: Holley238@gmail.com



Mr. James Borchardt  
Executive Director for Operations  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Attn: Bhalchandra K. Vaidya, NRC Petition Manager

In the Matter of the James A. FitzPatrick Nuclear Plant in Scriba, New York

Dear Mr. Borchardt:

I wish to co-petition with the Alliance for a Green Economy and Beyond Nuclear's March 9, 2012 emergency enforcement petition to suspend the operation of the James A. FitzPatrick Nuclear Plant.

- The FitzPatrick plant is the only GE Mark I boiling water reactor in the US that did not install a Direct Torus Vent System as requested by the NRC in 1989 and instead, to save money, relies upon a "pre-existing" venting system that is not fully hardened against a severe accident.
- In deciding not to install such a vent, the FitzPatrick operator and the NRC relied upon assumptions that now place public health and safety at an undue risk.
- The hydrogen explosions at the Fukushima reactors show the dangers and unacceptable consequences posed by the current FitzPatrick severe accident venting plan, since the plan was approved on the assumptions that venting would prevent containment failure, and that there are "no likely" ignition sources along the vent path. Neither of these assumptions was correct during the Fukushima nuclear catastrophe.
- Subsequent to the Fukushima accident, the NRC inspected FitzPatrick and identified a "vulnerability, in that current procedures do not address hydrogen considerations" during a severe accident.

Therefore, I request NRC immediately suspend the FitzPatrick operating license until the following emergency enforcement actions are approved by the NRC:

1) Public hearings should be held on the continued operation of Entergy Nuclear Operations' Fitzpatrick plant and the adequacy of its plan to vent through a pre-existing path into the adjacent Standby Gas Treatment System building, blowing off the double doors to release a radiological accident to the outside environment at ground level. The public must be afforded due process to address the unacceptable risks to public health and safety posed by the FitzPatrick severe accident plan.

2) Entergy Nuclear Operations should publicly document for independent review its post-Fukushima re-analysis for the reliability and capability of the FitzPatrick pre-existing containment vent system.

- The analysis should include the reassessment of all assumptions regarding the reliability of the pre-existing containment venting and specifically address non-conservative assumptions behind the cost-benefit analysis used to justify not installing a fully hardened vent system.
- It should also include a reassessment of the assumption of "no likely ignition points" during emergency venting that would otherwise present catastrophic consequences associated with the detonation of hydrogen gas and the release of radioactivity generated during a severe accident.

I wish the NRC to process my request using the 2.206 process, and I understand that under this process, the contents of this message and my identity will be made public. The Alliance for a Green Economy is my point of contact for this petition, and their organizer, Jessica Azulay, will keep me informed about the developments of the petition and the opportunity to participate in a public meeting with the NRC Petition Review Board.

Thank you,

Name: Willow Lisowski

Address: 107 Dell St apt 2

Email: WillowTulsi@yahoo.com

Mr. James Borchardt  
Executive Director for Operations  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Attn: Bhalchandra K. Vaidya, NRC Petition Manager

In the Matter of the James A. FitzPatrick Nuclear Plant in Scriba, New York

Dear Mr. Borchardt:

I wish to co-petition with the Alliance for a Green Economy and Beyond Nuclear's March 9, 2012 emergency enforcement petition to suspend the operation of the James A. FitzPatrick Nuclear Plant.

- The FitzPatrick plant is the only GE Mark I boiling water reactor in the US that did not install a Direct Torus Vent System as requested by the NRC in 1989 and instead, to save money, relies upon a "pre-existing" venting system that is not fully hardened against a severe accident.
- In deciding not to install such a vent, the FitzPatrick operator and the NRC relied upon assumptions that now place public health and safety at an undue risk.
- The hydrogen explosions at the Fukushima reactors show the dangers and unacceptable consequences posed by the current FitzPatrick severe accident venting plan, since the plan was approved on the assumptions that venting would prevent containment failure, and that there are "no likely" ignition sources along the vent path. Neither of these assumptions was correct during the Fukushima nuclear catastrophe.
- Subsequent to the Fukushima accident, the NRC inspected FitzPatrick and identified a "vulnerability, in that current procedures do not address hydrogen considerations" during a severe accident.

Therefore, I request NRC immediately suspend the FitzPatrick operating license until the following emergency enforcement actions are approved by the NRC:

1) Public hearings should be held on the continued operation of Entergy Nuclear Operations' Fitzpatrick plant and the adequacy of its plan to vent through a pre-existing path into the adjacent Standby Gas Treatment System building, blowing off the double doors to release a radiological accident to the outside environment at ground level. The public must be afforded due process to address the unacceptable risks to public health and safety posed by the FitzPatrick severe accident plan.

2) Entergy Nuclear Operations should publicly document for independent review its post-Fukushima re-analysis for the reliability and capability of the FitzPatrick pre-existing containment vent system.

- The analysis should include the reassessment of all assumptions regarding the reliability of the pre-existing containment venting and specifically address non-conservative assumptions behind the cost-benefit analysis used to justify not installing a fully hardened vent system.
- It should also include a reassessment of the assumption of "no likely ignition points" during emergency venting that would otherwise present catastrophic consequences associated with the detonation of hydrogen gas and the release of radioactivity generated during a severe accident.

I wish the NRC to process my request using the 2.206 process, and I understand that under this process, the contents of this message and my identity will be made public. The Alliance for a Green Economy is my point of contact for this petition, and their organizer, Jessica Azulay, will keep me informed about the developments of the petition and the opportunity to participate in a public meeting with the NRC Petition Review Board.

Thank you,

Name: DON DEVENU

Address: 229 BRATTLE RD. SYRACUSE, NY 13203

Email: \_\_\_\_\_

Mr. James Borchardt  
Executive Director for Operations  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Attn: Bhalchandra K. Vaidya, NRC Petition Manager

In the Matter of the James A. FitzPatrick Nuclear Plant in Scriba, New York

Dear Mr. Borchardt:

I wish to co-petition with the Alliance for a Green Economy and Beyond Nuclear's March 9, 2012 emergency enforcement petition to suspend the operation of the James A. FitzPatrick Nuclear Plant.

- The FitzPatrick plant is the only GE Mark I boiling water reactor in the US that did not install a Direct Torus Vent System as requested by the NRC in 1989 and instead, to save money, relies upon a "pre-existing" venting system that is not fully hardened against a severe accident.
- In deciding not to install such a vent, the FitzPatrick operator and the NRC relied upon assumptions that now place public health and safety at an undue risk.
- The hydrogen explosions at the Fukushima reactors show the dangers and unacceptable consequences posed by the current FitzPatrick severe accident venting plan, since the plan was approved on the assumptions that venting would prevent containment failure, and that there are "no likely" ignition sources along the vent path. Neither of these assumptions was correct during the Fukushima nuclear catastrophe.
- Subsequent to the Fukushima accident, the NRC inspected FitzPatrick and identified a "vulnerability, in that current procedures do not address hydrogen considerations" during a severe accident.

Therefore, I request NRC immediately suspend the FitzPatrick operating license until the following emergency enforcement actions are approved by the NRC:

1) Public hearings should be held on the continued operation of Entergy Nuclear Operations' Fitzpatrick plant and the adequacy of its plan to vent through a pre-existing path into the adjacent Standby Gas Treatment System building, blowing off the double doors to release a radiological accident to the outside environment at ground level. The public must be afforded due process to address the unacceptable risks to public health and safety posed by the FitzPatrick severe accident plan.

2) Entergy Nuclear Operations should publicly document for independent review its post-Fukushima re-analysis for the reliability and capability of the FitzPatrick pre-existing containment vent system.

- The analysis should include the reassessment of all assumptions regarding the reliability of the pre-existing containment venting and specifically address non-conservative assumptions behind the cost-benefit analysis used to justify not installing a fully hardened vent system.
- It should also include a reassessment of the assumption of "no likely ignition points" during emergency venting that would otherwise present catastrophic consequences associated with the detonation of hydrogen gas and the release of radioactivity generated during a severe accident.

I wish the NRC to process my request using the 2.206 process, and I understand that under this process, the contents of this message and my identity will be made public. The Alliance for a Green Economy is my point of contact for this petition, and their organizer, Jessica Azulay, will keep me informed about the developments of the petition and the opportunity to participate in a public meeting with the NRC Petition Review Board.

Thank you,

Name:

Thurman Klein

Address:

4131 Chinook Drive, Apt, Syracuse, NY 13210

Email:

hr.klein@syr.edu

Mr. James Borchart  
Executive Director for Operations  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Attn: Bhalchandra K. Vaidya, NRC Petition Manager

In the Matter of the James A. FitzPatrick Nuclear Plant in Scriba, New York

Dear Mr. Borchart:

I wish to co-petition with the Alliance for a Green Economy and Beyond Nuclear's March 9, 2012 emergency enforcement petition to suspend the operation of the James A. FitzPatrick Nuclear Plant.

- The FitzPatrick plant is the only GE Mark I boiling water reactor in the US that did not install a Direct Torus Vent System as requested by the NRC in 1989 and instead, to save money, relies upon a "pre-existing" venting system that is not fully hardened against a severe accident.
- In deciding not to install such a vent, the FitzPatrick operator and the NRC relied upon assumptions that now place public health and safety at an undue risk.
- The hydrogen explosions at the Fukushima reactors show the dangers and unacceptable consequences posed by the current FitzPatrick severe accident venting plan, since the plan was approved on the assumptions that venting would prevent containment failure, and that there are "no likely" ignition sources along the vent path. Neither of these assumptions was correct during the Fukushima nuclear catastrophe.
- Subsequent to the Fukushima accident, the NRC inspected FitzPatrick and identified a "vulnerability, in that current procedures do not address hydrogen considerations" during a severe accident.

Therefore, I request NRC immediately suspend the FitzPatrick operating license until the following emergency enforcement actions are approved by the NRC:

1) Public hearings should be held on the continued operation of Entergy Nuclear Operations' Fitzpatrick plant and the adequacy of its plan to vent through a pre-existing path into the adjacent Standby Gas Treatment System building, blowing off the double doors to release a radiological accident to the outside environment at ground level. The public must be afforded due process to address the unacceptable risks to public health and safety posed by the FitzPatrick severe accident plan.

2) Entergy Nuclear Operations should publicly document for independent review its post-Fukushima re-analysis for the reliability and capability of the FitzPatrick pre-existing containment vent system.

- The analysis should include the reassessment of all assumptions regarding the reliability of the pre-existing containment venting and specifically address non-conservative assumptions behind the cost-benefit analysis used to justify not installing a fully hardened vent system.
- It should also include a reassessment of the assumption of "no likely ignition points" during emergency venting that would otherwise present catastrophic consequences associated with the detonation of hydrogen gas and the release of radioactivity generated during a severe accident.

I wish the NRC to process my request using the 2.206 process, and I understand that under this process, the contents of this message and my identity will be made public. The Alliance for a Green Economy is my point of contact for this petition, and their organizer, Jessica Azulay, will keep me informed about the developments of the petition and the opportunity to participate in a public meeting with the NRC Petition Review Board.

Thank you,

Name:

Kaley Freund  
Kaley Freund

Address:

700 E Raynor Avenue  
Syracuse NY 13210

Email:

Kaleyam@comcast.net

Mr. James Borchardt  
Executive Director for Operations  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Attn: Bhalchandra K. Vaidya, NRC Petition Manager

In the Matter of the James A. FitzPatrick Nuclear Plant in Scriba, New York

Dear Mr. Borchardt:

I wish to co-petition with the Alliance for a Green Economy and Beyond Nuclear's March 9, 2012 emergency enforcement petition to suspend the operation of the James A. FitzPatrick Nuclear Plant.

- The FitzPatrick plant is the only GE Mark I boiling water reactor in the US that did not install a Direct Torus Vent System as requested by the NRC in 1989 and instead, to save money, relies upon a "pre-existing" venting system that is not fully hardened against a severe accident.
- In deciding not to install such a vent, the FitzPatrick operator and the NRC relied upon assumptions that now place public health and safety at an undue risk.
- The hydrogen explosions at the Fukushima reactors show the dangers and unacceptable consequences posed by the current FitzPatrick severe accident venting plan, since the plan was approved on the assumptions that venting would prevent containment failure, and that there are "no likely" ignition sources along the vent path. Neither of these assumptions was correct during the Fukushima nuclear catastrophe.
- Subsequent to the Fukushima accident, the NRC inspected FitzPatrick and identified a "vulnerability, in that current procedures do not address hydrogen considerations" during a severe accident.

Therefore, I request NRC immediately suspend the FitzPatrick operating license until the following emergency enforcement actions are approved by the NRC:

1) Public hearings should be held on the continued operation of Entergy Nuclear Operations' Fitzpatrick plant and the adequacy of its plan to vent through a pre-existing path into the adjacent Standby Gas Treatment System building, blowing off the double doors to release a radiological accident to the outside environment at ground level. The public must be afforded due process to address the unacceptable risks to public health and safety posed by the FitzPatrick severe accident plan.

2) Entergy Nuclear Operations should publicly document for independent review its post-Fukushima re-analysis for the reliability and capability of the FitzPatrick pre-existing containment vent system.

- The analysis should include the reassessment of all assumptions regarding the reliability of the pre-existing containment venting and specifically address non-conservative assumptions behind the cost-benefit analysis used to justify not installing a fully hardened vent system.
- It should also include a reassessment of the assumption of "no likely ignition points" during emergency venting that would otherwise present catastrophic consequences associated with the detonation of hydrogen gas and the release of radioactivity generated during a severe accident.

I wish the NRC to process my request using the 2.206 process, and I understand that under this process, the contents of this message and my identity will be made public. The Alliance for a Green Economy is my point of contact for this petition, and their organizer, Jessica Azulay, will keep me informed about the developments of the petition and the opportunity to participate in a public meeting with the NRC Petition Review Board.

Thank you,

Name: Mark Fitzgerald  
Address: 110 Sudson St Syr 13210  
Email: Save-The-Planet@Verizon.net

Mr. James Borchart  
Executive Director for Operations  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Attn: Bhalchandra K. Vaidya, NRC Petition Manager

In the Matter of the James A. FitzPatrick Nuclear Plant in Scriba, New York

Dear Mr. Borchart:

I wish to co-petition with the Alliance for a Green Economy and Beyond Nuclear's March 9, 2012 emergency enforcement petition to suspend the operation of the James A. FitzPatrick Nuclear Plant.

- The FitzPatrick plant is the only GE Mark I boiling water reactor in the US that did not install a Direct Torus Vent System as requested by the NRC in 1989 and instead, to save money, relies upon a "pre-existing" venting system that is not fully hardened against a severe accident.
- In deciding not to install such a vent, the FitzPatrick operator and the NRC relied upon assumptions that now place public health and safety at an undue risk.
- The hydrogen explosions at the Fukushima reactors show the dangers and unacceptable consequences posed by the current FitzPatrick severe accident venting plan, since the plan was approved on the assumptions that venting would prevent containment failure, and that there are "no likely" ignition sources along the vent path. Neither of these assumptions was correct during the Fukushima nuclear catastrophe.
- Subsequent to the Fukushima accident, the NRC inspected FitzPatrick and identified a "vulnerability, in that current procedures do not address hydrogen considerations" during a severe accident.

Therefore, I request NRC immediately suspend the FitzPatrick operating license until the following emergency enforcement actions are approved by the NRC:

1) Public hearings should be held on the continued operation of Entergy Nuclear Operations' Fitzpatrick plant and the adequacy of its plan to vent through a pre-existing path into the adjacent Standby Gas Treatment System building, blowing off the double doors to release a radiological accident to the outside environment at ground level. The public must be afforded due process to address the unacceptable risks to public health and safety posed by the FitzPatrick severe accident plan.

2) Entergy Nuclear Operations should publicly document for independent review its post-Fukushima re-analysis for the reliability and capability of the FitzPatrick pre-existing containment vent system.

- The analysis should include the reassessment of all assumptions regarding the reliability of the pre-existing containment venting and specifically address non-conservative assumptions behind the cost-benefit analysis used to justify not installing a fully hardened vent system.
- It should also include a reassessment of the assumption of "no likely ignition points" during emergency venting that would otherwise present catastrophic consequences associated with the detonation of hydrogen gas and the release of radioactivity generated during a severe accident.

I wish the NRC to process my request using the 2.206 process, and I understand that under this process, the contents of this message and my identity will be made public. The Alliance for a Green Economy is my point of contact for this petition, and their organizer, Jessica Azulay, will keep me informed about the developments of the petition and the opportunity to participate in a public meeting with the NRC Petition Review Board.

Thank you,

Name: Hannah Morgan

Address: Syracuse, NY

Email: hkmorgan@syrr.edu

Mr. James Borchardt  
Executive Director for Operations  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Attn: Bhalchandra K. Vaidya, NRC Petition Manager

In the Matter of the James A. FitzPatrick Nuclear Plant in Scriba, New York

Dear Mr. Borchardt:

I wish to co-petition with the Alliance for a Green Economy and Beyond Nuclear's March 9, 2012 emergency enforcement petition to suspend the operation of the James A. FitzPatrick Nuclear Plant.

- The FitzPatrick plant is the only GE Mark I boiling water reactor in the US that did not install a Direct Torus Vent System as requested by the NRC in 1989 and instead, to save money, relies upon a "pre-existing" venting system that is not fully hardened against a severe accident.
- In deciding not to install such a vent, the FitzPatrick operator and the NRC relied upon assumptions that now place public health and safety at an undue risk.
- The hydrogen explosions at the Fukushima reactors show the dangers and unacceptable consequences posed by the current FitzPatrick severe accident venting plan, since the plan was approved on the assumptions that venting would prevent containment failure, and that there are "no likely" ignition sources along the vent path. Neither of these assumptions was correct during the Fukushima nuclear catastrophe.
- Subsequent to the Fukushima accident, the NRC inspected FitzPatrick and identified a "vulnerability, in that current procedures do not address hydrogen considerations" during a severe accident.

Therefore, I request NRC immediately suspend the FitzPatrick operating license until the following emergency enforcement actions are approved by the NRC:

1) Public hearings should be held on the continued operation of Entergy Nuclear Operations' Fitzpatrick plant and the adequacy of its plan to vent through a pre-existing path into the adjacent Standby Gas Treatment System building, blowing off the double doors to release a radiological accident to the outside environment at ground level. The public must be afforded due process to address the unacceptable risks to public health and safety posed by the FitzPatrick severe accident plan.

2) Entergy Nuclear Operations should publicly document for independent review its post-Fukushima re-analysis for the reliability and capability of the FitzPatrick pre-existing containment vent system.

- The analysis should include the reassessment of all assumptions regarding the reliability of the pre-existing containment venting and specifically address non-conservative assumptions behind the cost-benefit analysis used to justify not installing a fully hardened vent system.
- It should also include a reassessment of the assumption of "no likely ignition points" during emergency venting that would otherwise present catastrophic consequences associated with the detonation of hydrogen gas and the release of radioactivity generated during a severe accident.

I wish the NRC to process my request using the 2.206 process, and I understand that under this process, the contents of this message and my identity will be made public. The Alliance for a Green Economy is my point of contact for this petition, and their organizer, Jessica Azulay, will keep me informed about the developments of the petition and the opportunity to participate in a public meeting with the NRC Petition Review Board.

Thank you,

Name: 

Address: 36 Mac/C Rd

Email: ScottMcGrady@yahoo.com

Mr. James Borchardt  
Executive Director for Operations  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Attn: Bhalchandra K. Vaidya, NRC Petition Manager

In the Matter of the James A. FitzPatrick Nuclear Plant in Scriba, New York

Dear Mr. Borchardt:

I wish to co-petition with the Alliance for a Green Economy and Beyond Nuclear's March 9, 2012 emergency enforcement petition to suspend the operation of the James A. FitzPatrick Nuclear Plant.

- The FitzPatrick plant is the only GE Mark I boiling water reactor in the US that did not install a Direct Torus Vent System as requested by the NRC in 1989 and instead, to save money, relies upon a "pre-existing" venting system that is not fully hardened against a severe accident.
- In deciding not to install such a vent, the FitzPatrick operator and the NRC relied upon assumptions that now place public health and safety at an undue risk.
- The hydrogen explosions at the Fukushima reactors show the dangers and unacceptable consequences posed by the current FitzPatrick severe accident venting plan, since the plan was approved on the assumptions that venting would prevent containment failure, and that there are "no likely" ignition sources along the vent path. Neither of these assumptions was correct during the Fukushima nuclear catastrophe.
- Subsequent to the Fukushima accident, the NRC inspected FitzPatrick and identified a "vulnerability, in that current procedures do not address hydrogen considerations" during a severe accident.

Therefore, I request NRC immediately suspend the FitzPatrick operating license until the following emergency enforcement actions are approved by the NRC:

1) Public hearings should be held on the continued operation of Entergy Nuclear Operations' Fitzpatrick plant and the adequacy of its plan to vent through a pre-existing path into the adjacent Standby Gas Treatment System building, blowing off the double doors to release a radiological accident to the outside environment at ground level. The public must be afforded due process to address the unacceptable risks to public health and safety posed by the FitzPatrick severe accident plan.

2) Entergy Nuclear Operations should publicly document for independent review its post-Fukushima re-analysis for the reliability and capability of the FitzPatrick pre-existing containment vent system.

- The analysis should include the reassessment of all assumptions regarding the reliability of the pre-existing containment venting and specifically address non-conservative assumptions behind the cost-benefit analysis used to justify not installing a fully hardened vent system.
- It should also include a reassessment of the assumption of "no likely ignition points" during emergency venting that would otherwise present catastrophic consequences associated with the detonation of hydrogen gas and the release of radioactivity generated during a severe accident.

I wish the NRC to process my request using the 2.206 process, and I understand that under this process, the contents of this message and my identity will be made public. The Alliance for a Green Economy is my point of contact for this petition, and their organizer, Jessica Azulay, will keep me informed about the developments of the petition and the opportunity to participate in a public meeting with the NRC Petition Review Board.

Thank you,

Name: JOSHUA HIGHTON

Address: 125 VAN RENSSELAER ST SYRACUSE NY 13204

Email: N/A



Mr. James Borchardt  
Executive Director for Operations  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Attn: Bhalchandra K. Vaidya, NRC Petition Manager

In the Matter of the James A. FitzPatrick Nuclear Plant in Scriba, New York

Dear Mr. Borchardt:

I wish to co-petition with the Alliance for a Green Economy and Beyond Nuclear's March 9, 2012 emergency enforcement petition to suspend the operation of the James A. FitzPatrick Nuclear Plant.

- The FitzPatrick plant is the only GE Mark I boiling water reactor in the US that did not install a Direct Torus Vent System as requested by the NRC in 1989 and instead, to save money, relies upon a "pre-existing" venting system that is not fully hardened against a severe accident.
- In deciding not to install such a vent, the FitzPatrick operator and the NRC relied upon assumptions that now place public health and safety at an undue risk.
- The hydrogen explosions at the Fukushima reactors show the dangers and unacceptable consequences posed by the current FitzPatrick severe accident venting plan, since the plan was approved on the assumptions that venting would prevent containment failure, and that there are "no likely" ignition sources along the vent path. Neither of these assumptions was correct during the Fukushima nuclear catastrophe.
- Subsequent to the Fukushima accident, the NRC inspected FitzPatrick and identified a "vulnerability, in that current procedures do not address hydrogen considerations" during a severe accident.

Therefore, I request NRC immediately suspend the FitzPatrick operating license until the following emergency enforcement actions are approved by the NRC:

1) Public hearings should be held on the continued operation of Entergy Nuclear Operations' Fitzpatrick plant and the adequacy of its plan to vent through a pre-existing path into the adjacent Standby Gas Treatment System building, blowing off the double doors to release a radiological accident to the outside environment at ground level. The public must be afforded due process to address the unacceptable risks to public health and safety posed by the FitzPatrick severe accident plan.

2) Entergy Nuclear Operations should publicly document for independent review its post-Fukushima re-analysis for the reliability and capability of the FitzPatrick pre-existing containment vent system.

- The analysis should include the reassessment of all assumptions regarding the reliability of the pre-existing containment venting and specifically address non-conservative assumptions behind the cost-benefit analysis used to justify not installing a fully hardened vent system.
- It should also include a reassessment of the assumption of "no likely ignition points" during emergency venting that would otherwise present catastrophic consequences associated with the detonation of hydrogen gas and the release of radioactivity generated during a severe accident.

I wish the NRC to process my request using the 2.206 process, and I understand that under this process, the contents of this message and my identity will be made public. The Alliance for a Green Economy is my point of contact for this petition, and their organizer, Jessica Azulay, will keep me informed about the developments of the petition and the opportunity to participate in a public meeting with the NRC Petition Review Board.

Thank you,

Name: Marie Lange  
231 Greenwood Pl.  
Address: Syracuse, NY 13210  
Email: mlange20@gmail.com

Mr. James Borchardt  
Executive Director for Operations  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Attn: Bhalchandra K. Vaidya, NRC Petition Manager

In the Matter of the James A. FitzPatrick Nuclear Plant in Scriba, New York

Dear Mr. Borchardt:

I wish to co-petition with the Alliance for a Green Economy and Beyond Nuclear's March 9, 2012 emergency enforcement petition to suspend the operation of the James A. FitzPatrick Nuclear Plant.

- The FitzPatrick plant is the only GE Mark I boiling water reactor in the US that did not install a Direct Torus Vent System as requested by the NRC in 1989 and instead, to save money, relies upon a "pre-existing" venting system that is not fully hardened against a severe accident.
- In deciding not to install such a vent, the FitzPatrick operator and the NRC relied upon assumptions that now place public health and safety at an undue risk.
- The hydrogen explosions at the Fukushima reactors show the dangers and unacceptable consequences posed by the current FitzPatrick severe accident venting plan, since the plan was approved on the assumptions that venting would prevent containment failure, and that there are "no likely" ignition sources along the vent path. Neither of these assumptions was correct during the Fukushima nuclear catastrophe.
- Subsequent to the Fukushima accident, the NRC inspected FitzPatrick and identified a "vulnerability, in that current procedures do not address hydrogen considerations" during a severe accident.

Therefore, I request NRC immediately suspend the FitzPatrick operating license until the following emergency enforcement actions are approved by the NRC:

1) Public hearings should be held on the continued operation of Entergy Nuclear Operations' Fitzpatrick plant and the adequacy of its plan to vent through a pre-existing path into the adjacent Standby Gas Treatment System building, blowing off the double doors to release a radiological accident to the outside environment at ground level. The public must be afforded due process to address the unacceptable risks to public health and safety posed by the FitzPatrick severe accident plan.

2) Entergy Nuclear Operations should publicly document for independent review its post-Fukushima re-analysis for the reliability and capability of the FitzPatrick pre-existing containment vent system.

- The analysis should include the reassessment of all assumptions regarding the reliability of the pre-existing containment venting and specifically address non-conservative assumptions behind the cost-benefit analysis used to justify not installing a fully hardened vent system.
- It should also include a reassessment of the assumption of "no likely ignition points" during emergency venting that would otherwise present catastrophic consequences associated with the detonation of hydrogen gas and the release of radioactivity generated during a severe accident.

I wish the NRC to process my request using the 2.206 process, and I understand that under this process, the contents of this message and my identity will be made public. The Alliance for a Green Economy is my point of contact for this petition, and their organizer, Jessica Azulay, will keep me informed about the developments of the petition and the opportunity to participate in a public meeting with the NRC Petition Review Board.

Thank you,

Name: Rachel M. Orke

Address: 30 PRINCE STREET APT 1, ROCHESTER, NY 14601

Email: Rachelorke@gmail.com

Mr. James Borchardt  
Executive Director for Operations  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Attn: Bhalchandra K. Vaidya, NRC Petition Manager

In the Matter of the James A. FitzPatrick Nuclear Plant in Scriba, New York

Dear Mr. Borchardt:

I wish to co-petition with the Alliance for a Green Economy and Beyond Nuclear's March 9, 2012 emergency enforcement petition to suspend the operation of the James A. FitzPatrick Nuclear Plant.

- The FitzPatrick plant is the only GE Mark I boiling water reactor in the US that did not install a Direct Torus Vent System as requested by the NRC in 1989 and instead, to save money, relies upon a "pre-existing" venting system that is not fully hardened against a severe accident.
- In deciding not to install such a vent, the FitzPatrick operator and the NRC relied upon assumptions that now place public health and safety at an undue risk.
- The hydrogen explosions at the Fukushima reactors show the dangers and unacceptable consequences posed by the current FitzPatrick severe accident venting plan, since the plan was approved on the assumptions that venting would prevent containment failure, and that there are "no likely" ignition sources along the vent path. Neither of these assumptions was correct during the Fukushima nuclear catastrophe.
- Subsequent to the Fukushima accident, the NRC inspected FitzPatrick and identified a "vulnerability, in that current procedures do not address hydrogen considerations" during a severe accident.

Therefore, I request NRC immediately suspend the FitzPatrick operating license until the following emergency enforcement actions are approved by the NRC:

1) Public hearings should be held on the continued operation of Entergy Nuclear Operations' Fitzpatrick plant and the adequacy of its plan to vent through a pre-existing path into the adjacent Standby Gas Treatment System building, blowing off the double doors to release a radiological accident to the outside environment at ground level. The public must be afforded due process to address the unacceptable risks to public health and safety posed by the FitzPatrick severe accident plan.

2) Entergy Nuclear Operations should publicly document for independent review its post-Fukushima re-analysis for the reliability and capability of the FitzPatrick pre-existing containment vent system.

- The analysis should include the reassessment of all assumptions regarding the reliability of the pre-existing containment venting and specifically address non-conservative assumptions behind the cost-benefit analysis used to justify not installing a fully hardened vent system.
- It should also include a reassessment of the assumption of "no likely ignition points" during emergency venting that would otherwise present catastrophic consequences associated with the detonation of hydrogen gas and the release of radioactivity generated during a severe accident.

I wish the NRC to process my request using the 2.206 process, and I understand that under this process, the contents of this message and my identity will be made public. The Alliance for a Green Economy is my point of contact for this petition, and their organizer, Jessica Azulay, will keep me informed about the developments of the petition and the opportunity to participate in a public meeting with the NRC Petition Review Board.

Thank you

Name: Pete D. King

Address: 606 Thurber St. Syracuse, NY 13210

Email: pedrox@earthlink.net

Mr. James Borchardt  
Executive Director for Operations  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Attn: Bhalchandra K. Vaidya, NRC Petition Manager

In the Matter of the James A. FitzPatrick Nuclear Plant in Scriba, New York

Dear Mr. Borchardt:

I wish to co-petition with the Alliance for a Green Economy and Beyond Nuclear's March 9, 2012 emergency enforcement petition to suspend the operation of the James A. FitzPatrick Nuclear Plant.

- The FitzPatrick plant is the only GE Mark I boiling water reactor in the US that did not install a Direct Torus Vent System as requested by the NRC in 1989 and instead, to save money, relies upon a "pre-existing" venting system that is not fully hardened against a severe accident.
- In deciding not to install such a vent, the FitzPatrick operator and the NRC relied upon assumptions that now place public health and safety at an undue risk.
- The hydrogen explosions at the Fukushima reactors show the dangers and unacceptable consequences posed by the current FitzPatrick severe accident venting plan, since the plan was approved on the assumptions that venting would prevent containment failure, and that there are "no likely" ignition sources along the vent path. Neither of these assumptions was correct during the Fukushima nuclear catastrophe.
- Subsequent to the Fukushima accident, the NRC inspected FitzPatrick and identified a "vulnerability, in that current procedures do not address hydrogen considerations" during a severe accident.

Therefore, I request NRC immediately suspend the FitzPatrick operating license until the following emergency enforcement actions are approved by the NRC:

1) Public hearings should be held on the continued operation of Entergy Nuclear Operations' Fitzpatrick plant and the adequacy of its plan to vent through a pre-existing path into the adjacent Standby Gas Treatment System building, blowing off the double doors to release a radiological accident to the outside environment at ground level. The public must be afforded due process to address the unacceptable risks to public health and safety posed by the FitzPatrick severe accident plan.

2) Entergy Nuclear Operations should publicly document for independent review its post-Fukushima re-analysis for the reliability and capability of the FitzPatrick pre-existing containment vent system.

- The analysis should include the reassessment of all assumptions regarding the reliability of the pre-existing containment venting and specifically address non-conservative assumptions behind the cost-benefit analysis used to justify not installing a fully hardened vent system.
- It should also include a reassessment of the assumption of "no likely ignition points" during emergency venting that would otherwise present catastrophic consequences associated with the detonation of hydrogen gas and the release of radioactivity generated during a severe accident.

I wish the NRC to process my request using the 2.206 process, and I understand that under this process, the contents of this message and my identity will be made public. The Alliance for a Green Economy is my point of contact for this petition, and their organizer, Jessica Azulay, will keep me informed about the developments of the petition and the opportunity to participate in a public meeting with the NRC Petition Review Board.

Thank you,

Name: Ursula Rozum

Address: 116 2 Cambridge St Syr. NY 13210

Email: URSULA.ROZUM@gmail.com

Mr. James Borchardt  
Executive Director for Operations  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Attn: Bhalchandra K. Vaidya, NRC Petition Manager

In the Matter of the James A. FitzPatrick Nuclear Plant in Scriba, New York

Dear Mr. Borchardt:

I wish to co-petition with the Alliance for a Green Economy and Beyond Nuclear's March 9, 2012 emergency enforcement petition to suspend the operation of the James A. FitzPatrick Nuclear Plant.

- The FitzPatrick plant is the only GE Mark I boiling water reactor in the US that did not install a Direct Torus Vent System as requested by the NRC in 1989 and instead, to save money, relies upon a "pre-existing" venting system that is not fully hardened against a severe accident.
- In deciding not to install such a vent, the FitzPatrick operator and the NRC relied upon assumptions that now place public health and safety at an undue risk.
- The hydrogen explosions at the Fukushima reactors show the dangers and unacceptable consequences posed by the current FitzPatrick severe accident venting plan, since the plan was approved on the assumptions that venting would prevent containment failure, and that there are "no likely" ignition sources along the vent path. Neither of these assumptions was correct during the Fukushima nuclear catastrophe.
- Subsequent to the Fukushima accident, the NRC inspected FitzPatrick and identified a "vulnerability, in that current procedures do not address hydrogen considerations" during a severe accident.

Therefore, I request NRC immediately suspend the FitzPatrick operating license until the following emergency enforcement actions are approved by the NRC:

1) Public hearings should be held on the continued operation of Entergy Nuclear Operations' Fitzpatrick plant and the adequacy of its plan to vent through a pre-existing path into the adjacent Standby Gas Treatment System building, blowing off the double doors to release a radiological accident to the outside environment at ground level. The public must be afforded due process to address the unacceptable risks to public health and safety posed by the FitzPatrick severe accident plan.

2) Entergy Nuclear Operations should publicly document for independent review its post-Fukushima re-analysis for the reliability and capability of the FitzPatrick pre-existing containment vent system.

- The analysis should include the reassessment of all assumptions regarding the reliability of the pre-existing containment venting and specifically address non-conservative assumptions behind the cost-benefit analysis used to justify not installing a fully hardened vent system.
- It should also include a reassessment of the assumption of "no likely ignition points" during emergency venting that would otherwise present catastrophic consequences associated with the detonation of hydrogen gas and the release of radioactivity generated during a severe accident.

I wish the NRC to process my request using the 2.206 process, and I understand that under this process, the contents of this message and my identity will be made public. The Alliance for a Green Economy is my point of contact for this petition, and their organizer, Jessica Azulay, will keep me informed about the developments of the petition and the opportunity to participate in a public meeting with the NRC Petition Review Board.

Thank you,

Name:

Lula A. Cook

Address:

127 Victoria Place, Syracuse NY

Email:

Lulacooks@aol.com

Mr. James Borchardt  
Executive Director for Operations  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Attn: Bhalchandra K. Vaidya, NRC Petition Manager

In the Matter of the James A. FitzPatrick Nuclear Plant in Scriba, New York

Dear Mr. Borchardt:

I wish to co-petition with the Alliance for a Green Economy and Beyond Nuclear's March 9, 2012 emergency enforcement petition to suspend the operation of the James A. FitzPatrick Nuclear Plant.

- The FitzPatrick plant is the only GE Mark I boiling water reactor in the US that did not install a Direct Torus Vent System as requested by the NRC in 1989 and instead, to save money, relies upon a "pre-existing" venting system that is not fully hardened against a severe accident.
- In deciding not to install such a vent, the FitzPatrick operator and the NRC relied upon assumptions that now place public health and safety at an undue risk.
- The hydrogen explosions at the Fukushima reactors show the dangers and unacceptable consequences posed by the current FitzPatrick severe accident venting plan, since the plan was approved on the assumptions that venting would prevent containment failure, and that there are "no likely" ignition sources along the vent path. Neither of these assumptions was correct during the Fukushima nuclear catastrophe.
- Subsequent to the Fukushima accident, the NRC inspected FitzPatrick and identified a "vulnerability, in that current procedures do not address hydrogen considerations" during a severe accident.

Therefore, I request NRC immediately suspend the FitzPatrick operating license until the following emergency enforcement actions are approved by the NRC:

1) Public hearings should be held on the continued operation of Entergy Nuclear Operations' Fitzpatrick plant and the adequacy of its plan to vent through a pre-existing path into the adjacent Standby Gas Treatment System building, blowing off the double doors to release a radiological accident to the outside environment at ground level. The public must be afforded due process to address the unacceptable risks to public health and safety posed by the FitzPatrick severe accident plan.

2) Entergy Nuclear Operations should publicly document for independent review its post-Fukushima re-analysis for the reliability and capability of the FitzPatrick pre-existing containment vent system.

- The analysis should include the reassessment of all assumptions regarding the reliability of the pre-existing containment venting and specifically address non-conservative assumptions behind the cost-benefit analysis used to justify not installing a fully hardened vent system.
- It should also include a reassessment of the assumption of "no likely ignition points" during emergency venting that would otherwise present catastrophic consequences associated with the detonation of hydrogen gas and the release of radioactivity generated during a severe accident.

I wish the NRC to process my request using the 2.206 process, and I understand that under this process, the contents of this message and my identity will be made public. The Alliance for a Green Economy is my point of contact for this petition, and their organizer, Jessica Azulay, will keep me informed about the developments of the petition and the opportunity to participate in a public meeting with the NRC Petition Review Board.

Thank you,

Name:

James Zemot

Address:

7430 Munich Rd Liverpool NY 13098

Email:

JimZemot@yahoo.com

Mr. James Borchardt  
Executive Director for Operations  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Attn: Bhalchandra K. Vaidya, NRC Petition Manager

In the Matter of the James A. FitzPatrick Nuclear Plant in Scriba, New York

Dear Mr. Borchardt:

I wish to co-petition with the Alliance for a Green Economy and Beyond Nuclear's March 9, 2012 emergency enforcement petition to suspend the operation of the James A. FitzPatrick Nuclear Plant.

- The FitzPatrick plant is the only GE Mark I boiling water reactor in the US that did not install a Direct Torus Vent System as requested by the NRC in 1989 and instead, to save money, relies upon a "pre-existing" venting system that is not fully hardened against a severe accident.
- In deciding not to install such a vent, the FitzPatrick operator and the NRC relied upon assumptions that now place public health and safety at an undue risk.
- The hydrogen explosions at the Fukushima reactors show the dangers and unacceptable consequences posed by the current FitzPatrick severe accident venting plan, since the plan was approved on the assumptions that venting would prevent containment failure, and that there are "no likely" ignition sources along the vent path. Neither of these assumptions was correct during the Fukushima nuclear catastrophe.
- Subsequent to the Fukushima accident, the NRC inspected FitzPatrick and identified a "vulnerability, in that current procedures do not address hydrogen considerations" during a severe accident.

Therefore, I request NRC immediately suspend the FitzPatrick operating license until the following emergency enforcement actions are approved by the NRC:

1) Public hearings should be held on the continued operation of Entergy Nuclear Operations' Fitzpatrick plant and the adequacy of its plan to vent through a pre-existing path into the adjacent Standby Gas Treatment System building, blowing off the double doors to release a radiological accident to the outside environment at ground level. The public must be afforded due process to address the unacceptable risks to public health and safety posed by the FitzPatrick severe accident plan.

2) Entergy Nuclear Operations should publicly document for independent review its post-Fukushima re-analysis for the reliability and capability of the FitzPatrick pre-existing containment vent system.

- The analysis should include the reassessment of all assumptions regarding the reliability of the pre-existing containment venting and specifically address non-conservative assumptions behind the cost-benefit analysis used to justify not installing a fully hardened vent system.
- It should also include a reassessment of the assumption of "no likely ignition points" during emergency venting that would otherwise present catastrophic consequences associated with the detonation of hydrogen gas and the release of radioactivity generated during a severe accident.

I wish the NRC to process my request using the 2.206 process, and I understand that under this process, the contents of this message and my identity will be made public. The Alliance for a Green Economy is my point of contact for this petition, and their organizer, Jessica Azulay, will keep me informed about the developments of the petition and the opportunity to participate in a public meeting with the NRC Petition Review Board.

Thank you,

Name:

Gretchen Shafer

Address:

1015 Euclid Ave - Syracuse, NY 13210

Email:

Shafer.gm@gmail.com

Mr. James Borchardt  
Executive Director for Operations  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Attn: Bhalchandra K. Vaidya, NRC Petition Manager

In the Matter of the James A. FitzPatrick Nuclear Plant in Scriba, New York

Dear Mr. Borchardt:

I wish to co-petition with the Alliance for a Green Economy and Beyond Nuclear's March 9, 2012 emergency enforcement petition to suspend the operation of the James A. FitzPatrick Nuclear Plant.

- The FitzPatrick plant is the only GE Mark I boiling water reactor in the US that did not install a Direct Torus Vent System as requested by the NRC in 1989 and instead, to save money, relies upon a "pre-existing" venting system that is not fully hardened against a severe accident.
- In deciding not to install such a vent, the FitzPatrick operator and the NRC relied upon assumptions that now place public health and safety at an undue risk.
- The hydrogen explosions at the Fukushima reactors show the dangers and unacceptable consequences posed by the current FitzPatrick severe accident venting plan, since the plan was approved on the assumptions that venting would prevent containment failure, and that there are "no likely" ignition sources along the vent path. Neither of these assumptions was correct during the Fukushima nuclear catastrophe.
- Subsequent to the Fukushima accident, the NRC inspected FitzPatrick and identified a "vulnerability, in that current procedures do not address hydrogen considerations" during a severe accident.

Therefore, I request NRC immediately suspend the FitzPatrick operating license until the following emergency enforcement actions are approved by the NRC:

1) Public hearings should be held on the continued operation of Entergy Nuclear Operations' Fitzpatrick plant and the adequacy of its plan to vent through a pre-existing path into the adjacent Standby Gas Treatment System building, blowing off the double doors to release a radiological accident to the outside environment at ground level. The public must be afforded due process to address the unacceptable risks to public health and safety posed by the FitzPatrick severe accident plan.

2) Entergy Nuclear Operations should publicly document for independent review its post-Fukushima re-analysis for the reliability and capability of the FitzPatrick pre-existing containment vent system.

- The analysis should include the reassessment of all assumptions regarding the reliability of the pre-existing containment venting and specifically address non-conservative assumptions behind the cost-benefit analysis used to justify not installing a fully hardened vent system.
- It should also include a reassessment of the assumption of "no likely ignition points" during emergency venting that would otherwise present catastrophic consequences associated with the detonation of hydrogen gas and the release of radioactivity generated during a severe accident.

I wish the NRC to process my request using the 2.206 process, and I understand that under this process, the contents of this message and my identity will be made public. The Alliance for a Green Economy is my point of contact for this petition, and their organizer, Jessica Azulay, will keep me informed about the developments of the petition and the opportunity to participate in a public meeting with the NRC Petition Review Board.

Thank you;

Name: Joannah Fine

Address: 710 Maryland Ave, Syracuse NY 13210

Email: fine line henna@gmail.com



Mr. James Borchardt  
Executive Director for Operations  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Attn: Bhalchandra K. Vaidya, NRC Petition Manager

In the Matter of the James A. FitzPatrick Nuclear Plant in Scriba, New York

Dear Mr. Borchardt:

I wish to co-petition with the Alliance for a Green Economy and Beyond Nuclear's March 9, 2012 emergency enforcement petition to suspend the operation of the James A. FitzPatrick Nuclear Plant.

- The FitzPatrick plant is the only GE Mark I boiling water reactor in the US that did not install a Direct Torus Vent System as requested by the NRC in 1989 and instead, to save money, relies upon a "pre-existing" venting system that is not fully hardened against a severe accident.
- In deciding not to install such a vent, the FitzPatrick operator and the NRC relied upon assumptions that now place public health and safety at an undue risk.
- The hydrogen explosions at the Fukushima reactors show the dangers and unacceptable consequences posed by the current FitzPatrick severe accident venting plan, since the plan was approved on the assumptions that venting would prevent containment failure, and that there are "no likely" ignition sources along the vent path. Neither of these assumptions was correct during the Fukushima nuclear catastrophe.
- Subsequent to the Fukushima accident, the NRC inspected FitzPatrick and identified a "vulnerability, in that current procedures do not address hydrogen considerations" during a severe accident.

Therefore, I request NRC immediately suspend the FitzPatrick operating license until the following emergency enforcement actions are approved by the NRC:

1) Public hearings should be held on the continued operation of Entergy Nuclear Operations' Fitzpatrick plant and the adequacy of its plan to vent through a pre-existing path into the adjacent Standby Gas Treatment System building, blowing off the double doors to release a radiological accident to the outside environment at ground level. The public must be afforded due process to address the unacceptable risks to public health and safety posed by the FitzPatrick severe accident plan.

2) Entergy Nuclear Operations should publicly document for independent review its post-Fukushima re-analysis for the reliability and capability of the FitzPatrick pre-existing containment vent system.

- The analysis should include the reassessment of all assumptions regarding the reliability of the pre-existing containment venting and specifically address non-conservative assumptions behind the cost-benefit analysis used to justify not installing a fully hardened vent system.
- It should also include a reassessment of the assumption of "no likely ignition points" during emergency venting that would otherwise present catastrophic consequences associated with the detonation of hydrogen gas and the release of radioactivity generated during a severe accident.

I wish the NRC to process my request using the 2.206 process, and I understand that under this process, the contents of this message and my identity will be made public. The Alliance for a Green Economy is my point of contact for this petition, and their organizer, Jessica Azulay, will keep me informed about the developments of the petition and the opportunity to participate in a public meeting with the NRC Petition Review Board.

Thank you,

Name:

Stephanie F. Leeds      Stephanie F. Leeds

Address:

234 Houston Ave. Syracuse NY 13224

Email:

SFLEEDS@VERIZON.NET

Mr. James Borchardt  
Executive Director for Operations  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Attn: Bhalchandra K. Vaidya, NRC Petition Manager

In the Matter of the James A. FitzPatrick Nuclear Plant in Scriba, New York

Dear Mr. Borchardt:

I wish to co-petition with the Alliance for a Green Economy and Beyond Nuclear's March 9, 2012 emergency enforcement petition to suspend the operation of the James A. FitzPatrick Nuclear Plant.

- The FitzPatrick plant is the only GE Mark I boiling water reactor in the US that did not install a Direct Torus Vent System as requested by the NRC in 1989 and instead, to save money, relies upon a "pre-existing" venting system that is not fully hardened against a severe accident.
- In deciding not to install such a vent, the FitzPatrick operator and the NRC relied upon assumptions that now place public health and safety at an undue risk.
- The hydrogen explosions at the Fukushima reactors show the dangers and unacceptable consequences posed by the current FitzPatrick severe accident venting plan, since the plan was approved on the assumptions that venting would prevent containment failure, and that there are "no likely" ignition sources along the vent path. Neither of these assumptions was correct during the Fukushima nuclear catastrophe.
- Subsequent to the Fukushima accident, the NRC inspected FitzPatrick and identified a "vulnerability, in that current procedures do not address hydrogen considerations" during a severe accident.

Therefore, I request NRC immediately suspend the FitzPatrick operating license until the following emergency enforcement actions are approved by the NRC:

1) Public hearings should be held on the continued operation of Entergy Nuclear Operations' Fitzpatrick plant and the adequacy of its plan to vent through a pre-existing path into the adjacent Standby Gas Treatment System building, blowing off the double doors to release a radiological accident to the outside environment at ground level. The public must be afforded due process to address the unacceptable risks to public health and safety posed by the FitzPatrick severe accident plan.

2) Entergy Nuclear Operations should publicly document for independent review its post-Fukushima re-analysis for the reliability and capability of the FitzPatrick pre-existing containment vent system.

- The analysis should include the reassessment of all assumptions regarding the reliability of the pre-existing containment venting and specifically address non-conservative assumptions behind the cost-benefit analysis used to justify not installing a fully hardened vent system.
- It should also include a reassessment of the assumption of "no likely ignition points" during emergency venting that would otherwise present catastrophic consequences associated with the detonation of hydrogen gas and the release of radioactivity generated during a severe accident.

I wish the NRC to process my request using the 2.206 process, and I understand that under this process, the contents of this message and my identity will be made public. The Alliance for a Green Economy is my point of contact for this petition, and their organizer, Jessica Azulay, will keep me informed about the developments of the petition and the opportunity to participate in a public meeting with the NRC Petition Review Board.

Thank you,

Name: Ly Ho

Address: ~~2 Mt Olympus~~ 2 Mt Olympus

Email: lyho@syrause.com

Syracuse 13210

Mr. James Borchardt  
Executive Director for Operations  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Attn: Bhalchandra K. Vaidya, NRC Petition Manager

In the Matter of the James A. FitzPatrick Nuclear Plant in Scriba, New York

Dear Mr. Borchardt:

I wish to co-petition with the Alliance for a Green Economy and Beyond Nuclear's March 9, 2012 emergency enforcement petition to suspend the operation of the James A. FitzPatrick Nuclear Plant.

- The FitzPatrick plant is the only GE Mark I boiling water reactor in the US that did not install a Direct Torus Vent System as requested by the NRC in 1989 and instead, to save money, relies upon a "pre-existing" venting system that is not fully hardened against a severe accident.
- In deciding not to install such a vent, the FitzPatrick operator and the NRC relied upon assumptions that now place public health and safety at an undue risk.
- The hydrogen explosions at the Fukushima reactors show the dangers and unacceptable consequences posed by the current FitzPatrick severe accident venting plan, since the plan was approved on the assumptions that venting would prevent containment failure, and that there are "no likely" ignition sources along the vent path. Neither of these assumptions was correct during the Fukushima nuclear catastrophe.
- Subsequent to the Fukushima accident, the NRC inspected FitzPatrick and identified a "vulnerability, in that current procedures do not address hydrogen considerations" during a severe accident.

Therefore, I request NRC immediately suspend the FitzPatrick operating license until the following emergency enforcement actions are approved by the NRC:

1) Public hearings should be held on the continued operation of Entergy Nuclear Operations' Fitzpatrick plant and the adequacy of its plan to vent through a pre-existing path into the adjacent Standby Gas Treatment System building, blowing off the double doors to release a radiological accident to the outside environment at ground level. The public must be afforded due process to address the unacceptable risks to public health and safety posed by the FitzPatrick severe accident plan.

2) Entergy Nuclear Operations should publicly document for independent review its post-Fukushima re-analysis for the reliability and capability of the FitzPatrick pre-existing containment vent system.

- The analysis should include the reassessment of all assumptions regarding the reliability of the pre-existing containment venting and specifically address non-conservative assumptions behind the cost-benefit analysis used to justify not installing a fully hardened vent system.
- It should also include a reassessment of the assumption of "no likely ignition points" during emergency venting that would otherwise present catastrophic consequences associated with the detonation of hydrogen gas and the release of radioactivity generated during a severe accident.

I wish the NRC to process my request using the 2.206 process, and I understand that under this process, the contents of this message and my identity will be made public. The Alliance for a Green Economy is my point of contact for this petition, and their organizer, Jessica Azulay, will keep me informed about the developments of the petition and the opportunity to participate in a public meeting with the NRC Petition Review Board.

Thank you,

Name: Mikaela Shubley

Address: 202 Ray St. Ithaca, NY 14857

Email: mkshubley@gmail.com