

WBN2Public Resource

From: Poole, Justin
Sent: Thursday, May 17, 2012 9:06 AM
To: 'garent@tva.gov'; Bryan, Robert H Jr
Cc: WBN2HearingFile Resource
Subject: RE: DRAFT Need for clarification on Fire Protection Report
Attachments: additional WBN clarifying question (5-17-12).docx

Gordon,

As a follow on to the emails sent on 5/10, 5/11, and 5/15, the staff is adding the attached question to the list. Again, this email does not convey a formal NRC staff position, and it does not formally request information. Thanks.

Justin C. Poole
Sr. Project Manager
NRR/DORL/LPWB
U.S. Nuclear Regulatory Commission
(301)415-2048
email: Justin.Poole@nrc.gov

From: Poole, Justin
Sent: Tuesday, May 15, 2012 3:10 PM
To: 'garent@tva.gov'; 'Bryan, Robert H Jr'
Cc: WBN2HearingFile Resource
Subject: RE: DRAFT Need for clarification on Fire Protection Report

Gordon,

As a follow on to the emails sent Thursday and Friday of last week, the staff is adding the attached question to the list. Again, this email does not convey a formal NRC staff position, and it does not formally request information. Thanks.

Justin C. Poole
Sr. Project Manager
NRR/DORL/LPWB
U.S. Nuclear Regulatory Commission
(301)415-2048
email: Justin.Poole@nrc.gov

From: Poole, Justin
Sent: Friday, May 11, 2012 4:19 PM
To: 'garent@tva.gov'
Cc: WBN2HearingFile Resource
Subject: RE: DRAFT Need for clarification on Fire Protection Report

Gordon,

As a follow on to the email sent Thursday afternoon, the staff would like to add the attached question to the ones sent previously. Again, this email does not convey a formal NRC staff position, and it does not formally request information. Thanks.

Justin C. Poole
Sr. Project Manager
NRR/DORL/LPWB
U.S. Nuclear Regulatory Commission
(301)415-2048
email: Justin.Poole@nrc.gov

From: Poole, Justin
Sent: Thursday, May 10, 2012 3:07 PM
To: 'garent@tva.gov'
Cc: WBN2HearingFile Resource
Subject: DRAFT Need for clarification on Fire Protection Report

Gordon,

In reviewing TVA's recent FPR submittal, the staff has come up with the attached questions. Please review to ensure that the questions are understandable, the regulatory basis is clear, there is no proprietary information contained, and to determine if the information was previously docketed. If further clarification is needed, and you would like to discuss the questions in a conference call, let us know. This email does not convey a formal NRC staff position, and it does not formally request for additional information.

Hearing Identifier: Watts_Bar_2_Operating_LA_Public
Email Number: 691

Mail Envelope Properties (19D990B45D535548840D1118C451C74DE1C85B9F73)

Subject: RE: DRAFT Need for clarification on Fire Protection Report
Sent Date: 5/17/2012 9:05:56 AM
Received Date: 5/17/2012 9:05:59 AM
From: Poole, Justin

Created By: Justin.Poole@nrc.gov

Recipients:

"WBN2HearingFile Resource" <WBN2HearingFile.Resource@nrc.gov>
Tracking Status: None
"garent@tva.gov" <garent@tva.gov>
Tracking Status: None
"Bryan, Robert H Jr" <rhbryan@tva.gov>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	2383	5/17/2012 9:05:59 AM
additional WBN clarifying question (5-17-12).docx		21761

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

11. In the response to RAI FPR VII-30, TVA stated that for hose stations with hose lengths greater than 100 feet, additional pressure was required to account for the additional length of hose. However, the response did not include a clear conclusion that the additional pressure is sufficient to achieve the required flow rate and satisfy the minimum pressure requirement of the nozzle. Confirm that for the hose stations with hose lengths greater than 100 feet, the required pressures are sufficient to achieve the required flow rates and satisfy the minimum pressure requirement of the nozzles.

DRAFT