



*Leslie Fields, Sr. Project Manager
Jay Robinson, Sr. Fire Protection Engineer
DRA, Fire Protection Branch*

**NFPA 805 Generic RAI Development
10 CFR 50.48(c)**

*NFPA 805 Public Meeting
US NRC Headquarters Offices
May 24, 2012*



Phases of LAR Review

- Acceptance Review
- Technical Review
- Audit Questions
- Onsite Audit
- RAI Development
- SER Development

Technical Review

- NRC/Contractors conduct acceptance review
- Pre-audit questions prepared by technical reviewers
- QA review of pre-audit questions
- Management review of pre-audit questions
- Pre-audit questions sent to licensee
- Audit discussions/RAI development

RAI Development

- RAIs are developed from
 - Pre-audit questions not resolved during audit
 - Or responses to pre-audit questions which need to be docketed
- RAI Coordination
 - One NRC Staff Member Functions as the RAI Coordinator for all NFPA 805 LARs

Common/Generic RAIs

- Same Issue Identified in Different LARs
- Same Issue Identified During Different Audits
- Issue Identified in Later LARs that Apply to Earlier LARs that are Still Under Review

LAR Audits and RAIs

- RAI responses are currently being prepared by 5 licensees
- VC Summer is the next scheduled audit

LAR	Plant	Audit Date
FY11		
1	D.C. Cook 1&2	Nov
2	Duane Arnold	Dec
FY12		
3	Callaway	Jan
4	Fort Calhoun	Mar
5	Waterford 3	May
6	V.C. Summer	Jun
7	ANO 2	TBD
8	Cooper	TBD
9	Turkey Point	TBD
10	Nine Mile Point 1	TBD

Different Methods

- Identification of deviations is to ensure staff explicit review and determination of acceptability
- Staff has noticed that applications identified some items as deviations, but not others
 - Some not identified because method allowed justification for use of different values
- To meet intent, should identify methods that are different, including those involving justifications