

  
**MITSUBISHI HEAVY INDUSTRIES, LTD.**  
16-5, KONAN 2-CHOME, MINATO-KU  
TOKYO, JAPAN

May 29, 2012

Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Attention: Mr. Jeffrey A. Ciocco

Docket No. 52-021  
MHI Ref: UAP-HF-12129

**Subject: MHI's 2<sup>nd</sup> Amended Response to US-APWR DCD RAI No. 354-2585  
Revision 0 (SRP 06.02.02 and 06.03)**

- References:** [1] "Request for Additional Information No. 354-2585 Revision 0, SRP Section: 06.02.02 – Containment Heat Removal System –Application Section: 6.2.2 and 6.3," dated May 7, 2009 (ML091270651).  
[2] MHI Letter UAP-HF-09365, "MHI's Response to US-APWR DCD RAI No. 354-2585 Revision 0 (SRP 06.02.02 and 06.03)," dated July 7, 2009 (ML091910256).  
[3] MHI Letter UAP-HF-09487, "MHI's Amended Response to US-APWR DCD RAI No. 354-2585 Revision 0 (SRP 06.02.02 and 06.03)," dated October 19, 2009 (ML092950148).  
[4] MHI Letter UAP-HF-09382, "MHI's Second Response to US-APWR DCD RAI No. 354-2585 Revision 0 (SRP 06.02.02 and 06.03)," dated July 17, 2009 (ML092030412).  
[5] MHI Letter UAP-HF-12131, "MHI's 2<sup>nd</sup> Amended Response to US-APWR DCD RAI No. 815-5986 Revision 3 (SRP 06.03)," dated May 2012.

With this letter, Mitsubishi Heavy Industries, Ltd. ("MHI") transmits to the U.S. Nuclear Regulatory Commission ("NRC") a document entitled "2<sup>nd</sup> Amended Response to Request for Additional Information No. 354-2585 Revision 0 (SRP 06.02.02 and 06.03)". In Reference 2, MHI provided the original response to the NRC's Request for Additional Information ("RAI") in Reference 1, except for Question 06.02.02-44. The response for Question 06.02.02-44 of Reference 1 was provided in Reference 4.

Reference 3 subsequently provided an amended response for Question 06.02.02-24. Enclosed is the 2<sup>nd</sup> amended response to Question 06.02.02-24. This response supersedes the previous responses to Question 06.02.02-24 that were transmitted in References 2 and 3. Also enclosed is the amended response to Question 06.02.02-44. This response supersedes the previous response to Question 06.02.02-44 that was transmitted in Reference 4.

The enclosed RAI response to Question No. 06.02.02-24 is related to the drain piping from the refueling cavity as part of the recirculation flow path during post-LOCA conditions that is related to GSI-191. MHI changed the design of recirculation water flow path in post-LOCA condition, as described in response to RAI 815-5986 in Reference 5, after the RAI in Reference 1 was issued. In order to appropriately reflect the design change, the response to RAI 345-2585 Question No. 06.02.02-24 was revised (see response to Question No. 06.02.02-24 in Enclosure 2).

DOB  
NRO

The enclosed RAI response to Question No. 06.02.02-44 is not affected by the design change described in the response to RAI 815-5986 in Reference 5. However, MHI has changed the design inside containment and modified the description in the DCD to close GSI-191 issues since the original response was submitted to the NRC in July 2009. Therefore, MHI clarified the response in accordance with the latest DCD and containment design information (see response to Question No. 06.02.02-44 in Enclosure 2).

As indicated in the enclosed materials, this document contains information that MHI considers proprietary, and therefore should be withheld from public disclosure pursuant to 10 C.F.R. § 2.390 (a)(4) as trade secrets and commercial or financial information which is privileged or confidential. A non-proprietary version of the document is also being submitted with the information identified as proprietary redacted and replaced by the designation "[ ]".

This letter includes a copy of the proprietary version (Enclosure 2) of the revised response, a copy of the non-proprietary version (Enclosure 3) of the revised response, and the Affidavit of Yoshiki Ogata (Enclosure 1) which identifies the reasons MHI respectfully requests that all materials designated as "Proprietary" in Enclosure 2 be withheld from public disclosure pursuant to 10 C.F.R. § 2.390 (a)(4).

Please contact Mr. Joseph Tapia, General Manager of Licensing Department, Mitsubishi Nuclear Energy Systems, Inc. if the NRC has questions concerning any aspect of this submittal. His contact information is provided below.

Sincerely,

A handwritten signature in black ink, appearing to read "Y. Ogata".

Yoshiki Ogata,  
Director - APWR Promoting Department  
Mitsubishi Heavy Industries, LTD.

Enclosures:

1. Affidavit of Yoshiki Ogata
2. 2<sup>nd</sup> Amended Response to Request for Additional Information No. 354-2585 Revision 0 (SRP 06.02.02 and 06.03) (proprietary version)
3. 2<sup>nd</sup> Amended Response to Request for Additional Information No. 354-2585 Revision 0 (SRP 06.02.02 and 06.03) (non-proprietary version)

CC: J. A. Ciocco  
J. Tapia

Contact Information

Joseph Tapia, General Manager of Licensing Department  
Mitsubishi Nuclear Energy Systems, Inc.  
1001 19th Street North, Suite 710  
Arlington, VA 22209  
E-mail: joseph\_tapia@mnes-us.com  
Telephone: (703) 908 – 8055

## Enclosure 1

Docket No. 52-021  
MHI Ref: UAP-HF-12129

### MITSUBISHI HEAVY INDUSTRIES, LTD.

#### AFFIDAVIT

I, Yoshiki Ogata, state as follows:

1. I am Director, APWR Promoting Department, of Mitsubishi Heavy Industries, LTD ("MHI"), and have been delegated the function of reviewing MHI's US-APWR documentation to determine whether it contains information that should be withheld from public disclosure pursuant to 10 C.F.R. § 2.390 (a)(4) as trade secrets and commercial or financial information which is privileged or confidential.
2. In accordance with my responsibilities, I have reviewed the enclosed document entitled "2<sup>nd</sup> Amended Response to Request for Additional Information No. 354-2585 Revision 0 (SRP 06.02.02 and 06.03)," dated May 2012, and have determined that portions of the document contain proprietary information that should be withheld from public disclosure. Those pages containing proprietary information are identified with the label "Proprietary" on the top of the page and the proprietary information has been bracketed with an open and closed bracket as shown here "[ ]". The first page of the document indicates that all information identified as "Proprietary" should be withheld from public disclosure pursuant to 10 C.F.R. § 2.390 (a)(4).
3. The information identified as proprietary in the enclosed document has in the past been, and will continue to be, held in confidence by MHI and its disclosure outside the company is limited to regulatory bodies, customers and potential customers, and their agents, suppliers, and licensees, and others with a legitimate need for the information, and is always subject to suitable measures to protect it from unauthorized use or disclosure.
4. The basis for holding the referenced information confidential is that it describes the unique design and methodology developed by MHI for performing the nuclear design of the US-APWR reactor.
5. The referenced information is being furnished to the Nuclear Regulatory Commission ("NRC") in confidence and solely for the purpose of information to the NRC staff.
6. The referenced information is not available in public sources and could not be gathered readily from other publicly available information. Other than through the provisions in paragraph 3 above, MHI knows of no way the information could be lawfully acquired by organizations or individuals outside of MHI.
7. Public disclosure of the referenced information would assist competitors of MHI in their design of new nuclear power plants without incurring the costs or risks associated with the design of the subject systems. Therefore, disclosure of the information contained in the referenced document would have the following negative impacts on the competitive position of MHI in the U.S. nuclear plant market:
  - A. Loss of competitive advantage due to the costs associated with development of

methodology related to the analysis.

- B. Loss of competitive advantage of the US-APWR created by benefits of modeling information.

I declare under penalty of perjury that the foregoing affidavit and the matters stated therein are true and correct to the best of my knowledge, information and belief.

Executed on this 29<sup>th</sup> day of May, 2012.

A handwritten signature in black ink, appearing to read "Y. Ogata". The signature is written in a cursive style with a long horizontal stroke at the end.

Yoshiaki Ogata,  
Director - APWR Promoting Department  
Mitsubishi Heavy Industries, LTD.

Docket No. 52-021  
MHI Ref: UAP-HF-12129

Enclosure 3

UAP-HF-12129  
Docket No. 52-021

2<sup>nd</sup> Amended Response to Request for Additional Information  
No. 354-2585 Revision 0 (SRP 06.02.02 and 06.03)

May 2012  
(Non-Proprietary)

---

---

**RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION**

---

---

5/29/2012

**US-APWR Design Certification  
Mitsubishi Heavy Industries, Ltd.  
Docket No. 52-021**

**RAI NO.:** NO. 354-2585 REVISION 0  
**SRP SECTION:** 06.02.02 – Containment Heat Removal System  
**APPLICATION SECTION:** 6.2.2 & 6.3  
**DATE OF RAI ISSUE:** 05/07/2009

---

**QUESTION NO.: 06.02.02-24**

MUAP 08001-NP (R2) Section 3.7.1 states, "In the refueling cavity, there are two 8 inches drain pipes which are communicated to bottom portion of the containment...and it is quite unlikely that a large amount of fibrous debris will blow down on the cavity, and block the drain path." The NRC staff requests that MHI provide the following information regarding upstream effects associated with these two 8 inch drain pipes:

- 1) Please describe what "communicated to bottom portion of containment" means? Do they go directly to RWSP? Are these drains depicted in the DCD (for example, DCD Figure 6.2.1-9)?
  - 2) If the drain pipes were to fully block flow, how much water holdup would occur and what would the impact be on cooling the core and cooling containment?
  - 3) What amount of water holdup (expressed in gallons or cubic meters and height in refueling cavity as well as height in RWSP) would result in challenging head loss across strainer (submergence etc) and/or NPSHa?
  - 4) Operating plants with similar drain configurations have installed debris interceptors to ensure the drains remain functional during an accident. What is the APWR justification for not establishing debris interceptors?
- 

**ANSWER:**

As described in Enclosure 2 of response to RAI 815-5986 (Reference 1), the recirculation flow path is changed from the original design. In order to reflect the design change of the recirculation flow path, the previous response to Question 06.02.02-24 is amended as follows:

- 1) The drain piping from the reactor cavity is connected to the header compartment and the drained water fills the header compartment. After the header compartment is filled, the overflow is directed to the RWSP through overflow piping installed in the header compartment. Therefore, the drain piping is not directly connected to the RWSP.

- 2) If the refueling cavity drain pipes were to become fully blocked, the containment spray water may not be drained from the refueling cavity. As a result, the safety pumps required for long term cooling may not be operated safely because the RWSP minimum water level will be lower than the design basis.
- 3) The amount of water in the refueling cavity accounted for as an "in-effective pool (i.e., 810 ft<sup>3</sup>)" was provided in Table 3-10 of the technical report MUAP-08001 (Reference 2). In addition, a 1 in height of water stream on the refueling cavity floor (i.e., 180 ft<sup>3</sup>) was included as part of the "water stream on the floor" (i.e., 7,320 ft<sup>3</sup>, See Table 3-10). No hold up volume due to full blockage of the cavity drains was accounted for in the upstream effect evaluation. Given the additional hold up volumes beyond the design basis, the RWSP water level will be reduced approximately 1 inch for every 470 ft<sup>3</sup> increase in entrapped water.
- 4) The following design considerations are employed as a counter measure against blockage of the drain piping.
  - The US-APWR will be categorized as a low-fiber plant. Fiber debris existing in containment is only latent fiber. No fiber insulation is expected, but 4.5 lbm fiber is taken into account as operating margin for the design basis of the sump strainer. In general, the US-APWR has relatively low risk for potential blockage.
  - Since the US-APWR credits several gratings as blocking large debris as an upstream effect, there is no "large" debris which potentially blocks the cavity drains.
  - Given a pipe break inside the secondary shield walls, a layer of gratings at elevation 55'-1" and 73'-1" (See Figure-1), the grating at 55'-1" prevents large debris from blowing out through opening on the floor opening at 76'-1", which is located just above the reactor coolant pump. The grating at 73'-1" prevents large debris, except the fibrous insulation installed on the main steam pipe support at the top of the secondary shield wall, from blowing out through steam generator compartment opening. Therefore, only "small" debris, except fibrous insulation on main steam pipe support at the top of secondary shield wall, can be transported on the operating floor or refueling cavity.
  - Given a pipe break outside the secondary shield walls, the only large debris that can reach the refueling cavity is generated by the main steam pipe break at the steam generator top nozzle.
  - To cope with the large debris, a grating with approximately 120 ft<sup>2</sup> of horizontal area will be provided in the pit to prevent credible large debris from reaching the refueling cavity drains. (See DCD Figure 6.2.1-9)

In conclusion, the following gratings are important to the prevention of large debris blockage of the refueling cavity drains, and shall be maintained during plant operation:

- Grating inside secondary shield wall at EL. 55'-1" (Loop-A,B,C, and D)
- Grating inside secondary shield wall at EL. 73'-1" (Loop-A,B,C, and D)
- Grating at upper core internal laydown pit (in refueling cavity)

The gratings are classified as non safety-related, and designed as seismic category II structures. As discussed in response to Question 06.02.02-31, design change control procedures, procedures for conduct of maintenance activities, and administrative procedures for maintaining the cited gratings will also be established. These processes will ensure that the gratings are maintained within the bounds of the analyses and design bases that support



Emergency Core Cooling (ECC) and Containment Spray (CS) recirculation functions and ensure the long-term core cooling requirements of 10 CFR 50.46 will be accomplished.

**References**

- 1) MHI Letter No. UAP-HF-12131, "MHI's 2<sup>nd</sup> Amended Response to US-APWR DCD RAI No. 815-5986 Revision 3 (SRP 06.03)", dated May 2012.
- 2) MHI Letter No. UAP-HF-12125, MUAP-08001 Revision 6, "US-APWR Sump Strainer Performance", dated May 2012.

**Impact on DCD**

There is no impact on the DCD.

**Impact on R-COLA**

There is no impact on the R-COLA.

**Impact on S-COLA**

There is no impact on the S-COLA.

**Impact on PRA**

There is no impact on the PRA.

**Impact on Technical/Topical Report**

There is no impact on the Technical/Topical Report.




Figure-1 Gratings important to preventing credible large debris from blocking the refueling cavity drains (inside secondary shield wall)




Figure-2 Grating important to preventing credible large debris from blocking the refueling cavity drains (refueling cavity)

---

---

**RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION**

---

---

5/29/2012

**US-APWR Design Certification  
Mitsubishi Heavy Industries, Ltd.  
Docket No. 52-021**

**RAI NO.:** NO. 354-2585 REVISION 0  
**SRP SECTION:** 06.02.02 – Containment Heat Removal System  
**APPLICATION SECTION:** 6.2.2 & 6.3  
**DATE OF RAI ISSUE:** 05/07/2009

---

**QUESTION NO.: 06.02.02-44**

As part of its review of the US-APWR design aspects that address GSI-191, the staff reviewed the applicant's sump strainer performance to the applicable regulatory criteria 10CFR52.47 "Contents of Applications; technical information" using the guidance of RG 1.206 Combined License Applications for Nuclear Power Plants. RG 1.206 outlines information to be submitted with design certification applications that will facilitate review by the NRC staff. The following information items, outlined in Section C.I.6.2.2 Containment Heat Removal Systems, as it relates to sumps, were not provided in the US-APWR DC application and form the basis for this request for additional information:

- 1) Discuss [in the DCD FSAR] the types of insulation used inside the containment and identify where and in what quantities each type is used. As part of the DCD FSAR discussion, identify the design basis debris source term used for the strainer performance analysis to include LOCA generated and Latent debris types and quantities.
  - 2) Describe the methods used to attach the insulation to piping and components.
- 

**ANSWER:**

MHI has changed the design inside the containment to close GSI-191 issues since the original response was submitted to the NRC in July 2009. Due to the change, values provided in the previous response to this RAI question needed to be changed. This amended response updates those values.

In addition, the previous version of the response to this question provided updates to the DCD. However, those DCD revisions have already been incorporated to the latest version of the DCD and have been submitted to the NRC as part of a DCD Tracking Report (Reference 2). Therefore, the description in this RAI response has also been revised to be consistent with the latest version of the DCD.

- 1) Type, application and quantity of insulation

The primal insulation used in the containment is reflective metallic insulation (RMI). Fibrous (blanket) insulation is not used in the containment of the US-APWR, but 4.5 lbm of fibrous debris are used as a design basis value for the evaluation of sump strainer performance as an operating margin. Pre-formed, buoyant type insulation is used as anti-sweat insulation chiller piping. NEI GR discusses that the buoyant insulation is not considered a problem for fully submerged strainer plant, and therefore it is excluded from debris source.

The discussion about debris type and the quantity for the sump strainer performance evaluation is discussed in Section 3.2 of Technical Report MUAP-08001 "Sump Strainer Performance" (Reference 1). Also the discussion has been reflected to the revised DCD as shown in Section 6.2.2.3.2 and 6.2.2.3.3 of the Tracking Report (Reference 1).

The type, application and quantity of insulation in the containment are listed as follow:

**Table-1 Insulation used in the containment**





2) Methods used for attachment of the insulation

At the time of the previous RAI response, there was no description in the DCD about the method to attach insulation. However, MHI has added the description in the revised DCD as shown in Section 6.2.2.3.2 of the Tracking Report of DCD Revision 3 (Reference 2).

**References**

- 1) MHI Letter No. UAP-HF-12125, MUAP-08001 Revision 6, "Sump Strainer Performance", May 2012.
- 2) MHI Letter No. UAP-HF-12085, "Submittal of the US-APWR DCD Revision 3 Tracking Report Revision2", April 6, 2012.

**Impact on DCD**

There is no impact on the DCD.

**Impact on R-COLA**

There is no impact on the R-COLA.

**Impact on S-COLA**

There is no impact on the S-COLA.

**Impact on PRA**

There is no impact on the PRA.

**Impact on Technical/Topical Report**

There is no impact on the Technical/Topical Report.