

10 CFR 50.46

RA-12-060
June 1, 2012

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

Oyster Creek Nuclear Generating Station
Renewed Facility Operating License No. DPR-16
NRC Docket No. 50-219

Subject: 10 CFR 50.46 Annual Report

Reference: 1) Letter from Michael D. Jesse (Exelon Generation Company, LLC) to U.S. Nuclear Regulatory Commission, "10 CFR 50.46 Annual Report," dated June 3, 2011

The purpose of this letter is to transmit the annual 10 CFR 50.46 reporting information for Oyster Creek Nuclear Generating Station (OCNGS). The previous annual 50.46 report for OCNGS (Reference 1) provided the cumulative Peak Cladding Temperature (PCT) errors for the most recent fuel designs.

Since the referenced annual report was issued, no vendor notifications of Emergency Core Cooling System (ECCS) model errors/changes that are applicable to OCNGS have been issued. Also, no ECCS-related changes or modifications have occurred at OCNGS that affect the assumptions of the ECCS analyses.

Two attachments are included with this letter that provide the current OCNGS 10 CFR 50.46 status. Attachment 1, "Peak Cladding Temperature Rack-Up Sheet," provides information regarding the PCT for the limiting large break LOCA analysis evaluations for OCNGS. Attachment 2, "Assessment Notes," contains a detailed description for each change or error reported.

There are no commitments contained in this letter. If you have any questions, please contact Tom Loomis at 610-765-5510.

Respectfully,



Michael D. Jesse
Director - Licensing & Regulatory Affairs
Exelon Generation Company, LLC

10 CFR 50.46 Annual Report
June 1, 2012
Page 2

Attachments: 1) Peak Cladding Temperature Rack-Up Sheet
2) Assessment Notes

cc: W. Dean, USNRC Administrator, Region I
J. Lamb, USNRC Senior Project Manager, OCNGS
J. A. Kulp, USNRC Senior Resident Inspector, OCNGS

ATTACHMENT 1

**10 CFR 50.46
“Acceptance Criteria for Emergency Core Cooling Systems
for Light-Water Nuclear Power Reactors”**

**Report of the Emergency Core Cooling System Evaluation Model Changes
and Errors**

Assessments as of June 1, 2012

Peak Cladding Temperature Rack-Up Sheet

Oyster Creek Nuclear Generating Station

PLANT NAME: Oyster Creek
ECCS EVALUATION MODEL: SAFER/CORCL/GESTR-LOCA
REPORT REVISION DATE: 6/1/12
CURRENT OPERATING CYCLE: 23

ANALYSIS OF RECORD

Evaluation Model:

1. NEDC-23785-1-PA, Rev. 1, "The GESTR-LOCA and SAFER Models for the Evaluation of the Loss-Of-Coolant Accident Volume II, SAFER – Long Term Inventory Model for BWR Loss-Of-Coolant Analysis," October 1984.
2. NEDC-30996P-A, "SAFER Model for Evaluation of Loss-of-Coolant Accidents for Jet Pump and Non-jet Pump Plants, Volume I, SAFER – Long Term Inventory Model for BWR Loss-of-Coolant Analysis," October 1987.
3. NEDC-32950P, "Compilation of Improvements to GENE's SAFER ECCS-LOCA Evaluation Model," January 2000.
4. NEDC-30996P-A, "SAFER Model for Evaluation of Loss-of-Coolant Accidents for Jet Pump and Non-jet Pump Plants, Volume II, SAFER Application Methodology for Non-jet Pump Plants," October 1987.

Calculations:

1. GE-NE-0000-0001-7486-01P, "Oyster Creek Generating Station Loss-of-Coolant Accident Evaluation for GE11," GE Nuclear Energy, dated July 2002.
2. Report 0000-0098-3503-R2, "Oyster Creek Generating Station GNF2 ECCS-LOCA Evaluation," GEH Nuclear Energy, dated November 2010.
3. GNF Letter Report CFL-EXN-EN1-11-031, "Transmittal of Updated Exposure-Dependent GE11 and GNF2 Fuel MAPLHGR Limits for Oyster Creek Cycle 23," dated April 29, 2011.
4. GEH Letter Report CFL-EXN-EN1-12-068, "Transmittal of Revised Exposure-dependent GNF2 Fuel MAPLHGR Limits for Oyster Creek Cycle 23," dated May 3, 2012.

Fuel: GE11/GNF2

Limiting Fuel Type: GE11/GNF2

Limiting Single Failure: ADS Valve

Limiting Break Size and Location: 4.66 ft² Double-Ended Guillotine (DEG) in a Recirculation Discharge Pipe

Reference Peak Cladding Temperature (PCT)

PCT = 2150°F

MARGIN ALLOCATION

A. PRIOR LOCA MODEL ASSESSMENTS

Annual 10 CFR 50.46 Report dated June 3, 2011 (See Note 1)	$\Delta\text{PCT} = 0^\circ\text{F}$
NET PCT (GE11/GNF2)	2150°F

B. CURRENT LOCA MODEL ASSESSMENTS

None (see Note 2)	$\Delta\text{PCT} = 0^\circ\text{F}$
Total PCT Change from Current Assessments	$\sum\Delta\text{PCT} = 0^\circ\text{F}$
Cumulative PCT Change from Current Assessments	$\sum \Delta\text{PCT} = 0^\circ\text{F}$
NET PCT (GE11/GNF2)	2150°F

ATTACHMENT 2

10 CFR 50.46

**“Acceptance Criteria for Emergency Core Cooling Systems
for Light-Water Nuclear Power Reactors”**

**Report of the Emergency Core Cooling System Evaluation Model Changes
and Errors**

Assessments as of June 1, 2012

Assessment Notes

Oyster Creek Nuclear Generating Station

1. Prior LOCA Assessment

Updated LOCA/MAPLHGR analyses were performed for both GE11 and GNF2 fuel in support of operating Cycle 23. These analyses maintained the calculated PCT at 2150°F and superseded all prior LOCA assessments. These analyses incorporated all ECCS/LOCA methodology errors and changes known/resolved at that time (as of April 2011).

[Reference: GNF Letter Report CFL-EXN-EN1-11-031, "Transmittal of Updated Exposure-Dependent GE11 and GNF2 Fuel MAPLHGR Limits for Oyster Creek Cycle 23," dated April 29, 2011]

2. Current LOCA Assessment

OCNGS has implemented a new mid-cycle LOCA/MAPLHGR analysis for the GNF2 fuel during operating Cycle 23. This analysis maintains the calculated PCT at 2150°F and supersedes all prior GNF2 LOCA/MAPLHGR assessments. This analysis incorporates all ECCS/LOCA methodology errors and changes known/resolved to date.

Since the last OCNGS 10 CFR 50.46 annual report (June 3, 2011), no vendor notifications of ECCS model error/changes that are applicable to OCNGS have been issued. No ECCS-related changes or modifications have occurred at OCNGS that affect the assumptions of the ECCS analyses.

[Reference: GEH Letter Report CFL-EXN-EN1-12-068, "Transmittal of Revised Exposure-dependent GNF2 Fuel MAPLHGR Limits for Oyster Creek Cycle 23," dated May 3, 2012]