

Attachment 2 to

GNRO-2012/00039

**Entergy Nuclear Grand Gulf Nuclear Station License Renewal Environmental Audit –
Hydrology Patton, - Attachment A labeled “Radial Collector Well Data”**

Attachment A

Radial Collector Well Data

GG
UFSAR

TABLE 2.4-20
RADIAL COLLECTOR WELL DATA

	WELL 1	WELL 3	WELL 4	WELL 5
Pump floor elev., ft msl	97.06	96.5	96.5	96.5
Minimum design pumping level in caisson, ft msl	-20.0	-21.9	-22.5	-22.5
Diameter of laterals, in.	16	16	12	16
Elevation of centerline of laterals, ft msl	N/A	N/A	N/A	N/A
tier top	N/A	N/A	N/A	N/A
tier middle	N/A	N/A	-32.5	N/A
tier bottom	-36.75	-32.2	N/A	-32.8
Dimension of Caisson I.D. x O.D., ft	13x17	13x17	16x20	13x17
Bottom of caisson, ft msl	-38.75	-34.4	-35.0	-35.5
Elevation at top of aquifer, ft. msl	+35	+55	+56	+67

**Attachment 2 to
GNRO-2012/00039**

**Entergy Nuclear Grand Gulf Nuclear Station License Renewal Environmental Audit –
Hydrology Patton, - Attachment A labeled “Radial Collector Well Data”**