



May 24, 2012
E-32690

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
One White Flint North
11555 Rockville Pike
Rockville, MD 20852

Subject: Revision 2 to Transnuclear, Inc. (TN) Application for Amendment 3 to Standardized Advanced NUHOMS[®] Certificate of Compliance No. 1029, Supplemental Information (Docket No. 72-1029; TAC No. L24607)

Based on discussions with the NRC staff, this submittal provides supplemental information for the CoC 1029 Amendment 3 application. Enclosure 2 provides changed UFSAR pages containing information regarding the equation for the determination of fuel assembly decay heat and information regarding design basis source terms. Enclosures 3 and 4 provide a summary listing of files associated with the vacuum drying operation, and the computer files associated with that operation, respectively.

Certain portions of this submittal include proprietary information which may not be used for any purpose other than to support the NRC staff's review of the application. In accordance with 10 CFR 2.390, I am providing an affidavit (Enclosure 1) specifically requesting that you withhold this proprietary information from public disclosure. Enclosure 5 provides a public version of changed proprietary UFSAR pages. Enclosure 4 is entirely proprietary and therefore no public version is provided.

Should the NRC staff require additional information to support review of this application, please do not hesitate to contact Mr. Don Shaw at 410-910-6878 or me at 410-910-6881.

Sincerely,

A handwritten signature in black ink that reads "Jayant Bondre".

Jayant Bondre, PhD
Vice President - Engineering

TRANSNUCLEAR INC.

7135 Minstrel Way • Suite 300 • Columbia, MD 21045
Tel: 410-910-6900 • Fax: 410-910-6902
www.transnuclear.com

NH5526
NH55

cc: Steve Ruffin (NRC SFST) (cover letter and Enclosures 1, 2, 3, and 4)

Enclosures:

1. Affidavit Pursuant to 10 CFR 2.390
2. Changed Pages for UFSAR Chapter B.5 (proprietary)
3. Listing of Computer Files Contained in Enclosure 4
4. Computer Files Associated with CoC 1029 Amendment 3, Revision 2 (proprietary)
5. Public Version of UFSAR Chapter B.5 pages

Listing of Computer Files Contained in Enclosure 4

Disk ID No. (size)	Discipline	System/ Component	File Series (topics)	Number of files
DVD-1 (2.51 GB)	Thermal	NUHOMS® 32PTH2 Storage Conditions	1-VacuumDrying-32.0 kW – Directory Vacuum Drying Thermal Evaluation of 32PTH2 DSC with 32.0 kW heat load	11
DVD-2 (2.51 GB)	Thermal	NUHOMS® 32PTH2 Storage Conditions	2-VacuumDrying-37.2 kW – Directory Vacuum Drying Thermal Evaluation of 32PTH2 DSC with 37.2 kW heat load	11

Enclosure 5 to TN E-32690

Public Version of UFSAR Chapter B.5 pages

near the AHSM-HS where the dose rates are substantially larger than at the other locations near the AHSM-HS: at the bottom air inlet vents in the front face of the module and air outlet vents on the AHSM-HS roof. The response function that simulates penetration and streaming of source particles to the vent opening on top of the AHSM-HS roof slab is used in the current analysis for ranking sources for the AHSM-HS. The OS200FC TC model allows an estimate of dose rates on the side of the transfer cask. Collectively, these locations are referred to as locations of interest. Source terms with the same source energy structure can then simply be multiplied by the response functions to get the dose rate at the locations of interest. It is also reasonable to expect that if some radiological source results in bounding dose rates at the location of interest, it would result in bounding dose rates at all other locations where dose rates are calculated.

However, shielding evaluations with full scale models may result in dose rates at the locations of interest that differ from those obtained herein using the response function since the ranking of the radiological sources (determination of the source that results in the highest dose rates) is the only concern in the current analysis. Therefore, the simplified shielding models of the OS200FC TC and the AHSM-HS employed herein are acceptable for the purpose of determining the fuel assembly BECT parameters resulting in the bounding source.

Response function entries are determined for the important primary gamma energy range of 0.6 MeV to 3.0 MeV since this energy range contributed to more than 98% of the primary gamma dose rates for the zones depicted on Figure B.2.1-1. Neutron response functions are based on the Cm-244 Watt fission spectrum which account for the neutron radiation and the secondary gamma (n,γ) sources. The response functions for both the AHSM-HS and OS200FC TC are presented in Table B.5.5-13 and Table B.5.5-14, respectively. *Detailed results are discussed in Section B.5.4.9.*

B.5.2.2.2 Fuel Qualification Methodology

Fuel qualification is performed to determine acceptable combinations of burnup and enrichment for the spent fuel assemblies as shown in Table B.2.1-6. Radiation sources from each of these burnup and enrichment combinations are calculated using SAS2H/ORIGEN-S and are ranked in the order of their importance to dose rates *using the response functions*. The cooling times employed for these evaluations are such that the resulting fuel assembly satisfies the decay heat limitations per Figure B.2.1-1, including *the minimum allowed* cooling time of 5.0 years. Therefore, the calculated cooling times for the ranking of the radiological sources correspond to the minimum required cooling times for fuel assemblies in order to qualify for loading as a function of assembly enrichment and burnup. These sets of radiological sources are converted to sets of dose rates using the response functions. BECT combinations resulting in the largest dose rates are identified and employed in TRITON\T-DEPL depletion models to calculate design basis radiological source terms from four axial exposure regions of the design basis fuel assembly. The design basis radiological source terms calculated with TRITON\T-DEPL models are shown in Table B.5.5-21 through Table B.5.5-23.

The source terms are calculated using a constant cycle specific power of 30 MW to maximize actinide production rate. One day of down time is conservatively assumed in the depletion models. The cobalt concentration used in the various hardware materials and the total for the

entire fuel assembly are selected to maximize the gamma source terms. Boron concentration, moderator temperature, and density values are selected in the depletion model to

Decay heat values in watts per fuel assembly are very well represented with an equation of this form:

$$f(Bu, En, T) = P(Bu, En) \times (G \times \exp(-H \times T) + I \times \exp(-J \times T)),$$

where

$$P(Bu, En) = A + B \times Bu + C \times \ln(En) + D \times Bu^2 + E \times \ln(En)^2 + F \times Bu \times \ln(En),$$

and

$$A = -55.1, B = 55.4, C = 226, D = 0.691, E = 63.4 \\ F = -19.7, G = 1.75, H = 0.483, I = 0.310, J = 0.022.$$

The variables in $f(Bu, En, T)$ correspond to assembly average burnup in GWd/MTU, assembly average enrichment in wt. % U-235, and cooling time in years. The following are the additional considerations when using the DHE.

- Fitting parameters of the DHE are determined using decay heat data at certain burnup and enrichment combinations. The DHE is only applicable to the burnup and enrichment combinations designated as analyzed regions 1 and 2 only in Chapter 2, Table B.2.1-6.
- Fitting parameters of the DHE are determined using decay heat data corresponding to cooling times in the range of 5 to 32 years. The decay heat values obtained beyond this range of cooling times are not fully validated. However, the DHE results in conservative decay heat values at cooling times greater than 32 years, and the extent of the conservatism increases with cooling times greater than 32 years.
- The DHE can under predict the decay heat values for cooling times between 5.0 to 6.0 years. However, the extent of the under prediction does not exceed 6%, and gradually decreases when the cooling time is 6.0 years. Therefore, a 6% margin should be added to the decay heat values predicted with the DHE.
- The DHE equation results in conservative decay heat values when cooling times are greater than 6.0 years. The extent of conservatism is within 3.0 % for cooling times between 6.0 to 28.0 years.
- The results predicted with the DHE are also applicable to fuel assemblies with control components (CCs).

Proprietary information withheld pursuant to 10 CFR 2.390.

B.5.2.4 Qualification of Fuel Assemblies with Reconstituted Fuel Rods

A reconstituted fuel assembly is defined as a fuel assembly where fuel rods are replaced with fuel or non-fuel (reconstituted) rods and could undergo further irradiation. It is assumed in the shielding analysis that the replacement rods have the same length and outer diameter as the fuel rods they replace. It is assumed when analyzing fuel assemblies with replacement rods undergoing further irradiation, the reconstitution occurred at the end of the first irradiation cycle.

Proprietary information on pages B.5.4-5 and B.5.4-6
withheld pursuant to 10 CFR 2.390.

***Table B.5.5-30
Not Used.***

Proprietary information on pages B.5.5-31b through B.5.5-31cc
withheld pursuant to 10 CFR 2.390.